



**SPP**

*Southwest  
Power Pool*

***System Impact Study***

***SPP-2005-030***

***For Transmission Service***

***Requested By:***

***Exelon Generation Company,  
LLC***

***From CSWS to AECL***

***For a Reserved Amount Of***

***258 MW***

***From 04/01/05***

***To 06/01/05***

# ***SPP Transmission Planning***

<b>1. EXECUTIVE SUMMARY .....</b>	<b>3</b>
<b>2. INTRODUCTION .....</b>	<b>4</b>
<b>3. STUDY METHODOLOGY.....</b>	<b>5</b>
A. DESCRIPTION.....	5
B. MODEL UPDATES.....	5
C. TRANSFER ANALYSIS .....	5
<b>4. STUDY RESULTS .....</b>	<b>6</b>
<b>5. CONCLUSION.....</b>	<b>7</b>

## **1. Executive Summary**

Exelon Generation Company, LLC has requested a system impact study for monthly firm transmission service from CSWS to AECI. The period of the transaction is from 04/01/05 to 06/01/05. The request is for reservations 847697, 847698, 847699, and 847700 for the amount of 258 MW.

The 258 MW transactions from CSWS to AECI have an impact on the following flowgate with no ATC: PECXFRMUSCLA. To provide the ATC necessary for this transfer, the impact on these flowgates must be relieved.

After studying many scenarios using curtailment of reservations and generation redispatch, there are several feasible scenarios that will relieve the flowgate(s) in question.

## 2. Introduction

Exelon Generation Company, LLC has requested a system impact study for transmission service from CSWS to AECL.

There is one constrained flowgate that requires relief in order for this reservation to be accepted. The flowgate and the explanation is as follows:

PECXFRMUSCLA: Pecan 345/161 kV Transformer for the loss of Muskogee to Clarksville 345 KV line

### **3. Study Methodology**

#### **A. Description**

Southwest Power Pool used Managing and Utilizing System Transmission (MUST) to obtain possible unit pairings that would relieve the constraint. MUST calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

#### **B. Model Updates**

The 2004 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

#### **C. Transfer Analysis**

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using Managing and Utilizing System Transmission (MUST), specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by MUST is the amount of redispatch necessary to relieve the impact on the affected flowgate.

## **4. Study Results**

After studying the impacts of request 847697, 847698, 847699, and 847700, one flowgate requires relief. The flowgate and associated amount of relief is as follows:

**Table 1**

<b>Flowgates</b>	<b>Sensitivity Redirect (%)</b>	<b>Sensitivity Original (%)</b>	<b>Duration</b>	<b>Required Relief (MW)</b>
PECXFRMUSCLA	4.3	3.8	May	2

Table 2 displays a list of reservation paths that offer relief for the flowgates in question.

**Table 2**

<b>Transactions Path</b>	<b>PECXFRMUSCLA Sensitivity (%)</b>
CSWS – AMRN	3.8

Table 3 displays the amount of capacity required for each reservation path to relieve the flowgates in question.

**Table 3**

<b>Transactions Path</b>	<b>PECXFRMUSCLA Sensitivity (MW)</b>
CSWS – AMRN	53

## 5. Conclusion

Reservation curtailment and generation redispatch options were studied in order to relieve the necessary constraint. The results of this study shows that the constraints on the flowgates in question could be relieved by executing one or more of the options described in the Study Results section of this document. Before the Transmission Provider accepts the reservations, proof of one of these relief options must be presented to Southwest Power Pool. Noncompliance with this guideline will result in the refusal of the reservation.

[