



*Aggregate Facility Study  
SPP-2006-AG2-AFS-1  
For Transmission Service  
Requested by  
Aggregate Transmission Customers*

*SPP Engineering, SPP Tariff Studies*

## *Table of Contents*

1. Executive Summary.....	3
2. Introduction .....	4
A. FINANCIAL ANALYSIS.....	7
B. THIRD PARTY UPGRADES.....	8
3. Study Methodology .....	10
A. DESCRIPTION .....	10
B. MODEL DEVELOPMENT.....	11
C. TRANSFER ANALYSIS .....	12
D. CURTAILMENT AND REDISPATCH EVALUATION .....	12
4. Study Results.....	14
A. STUDY ANALYSIS RESULTS.....	14
B. STUDY DEFINITIONS .....	14
5. Conclusion.....	17
Appendix .....	19

## **1. Executive Summary**

Pursuant to Attachment Z of the Southwest Power Pool Open Access Transmission Tariff (OATT), 4418 MW of long-term transmission service requests have been restudied in this Aggregate Facility Study (AFS). The first phase of the AFS consisted of a revision of the impact study to reflect the withdrawal of requests for which an Aggregate Facility Study Agreement was not executed. The principal objective of the AFS is to identify system problems and potential modifications necessary to facilitate these transfers while maintaining or improving system reliability as well as summarizing the operating limits and determination of the financial characteristics associated with facility upgrades.

Facility upgrade costs are allocated on a prorated basis to all requests positively impacting any individual overloaded facility. Further, Attachment Z provides for facility upgrade cost recovery by stating that “[a]ny charges paid by a customer in excess of the transmission access charges in compensation for the revenue requirements for allocated facility upgrade(s) shall be recovered by such customer from future transmission service revenues until the customer has been fully compensated.”

The total assigned facility upgrade Engineering and Construction (E &C) cost determined by the AFS is \$524,863,466. Additionally \$ 5,355,000 of assigned E & C cost for 3<sup>rd</sup> party facility upgrades are assignable to the customer. The total upgrade levelized revenue requirement for all transmission requests is \$2,039,034,622. This is based on full allocation of levelized revenue requirements for upgrades to customers without consideration of base plan funding. The AFS data tables reflect the allocation of upgrade costs to customers both with and without potential base plan funding based on either the requested reservation period or the deferred reservation period without

redispatch if applicable. Total upgrade levelized revenue requirements for all transmission requests after consideration of potential base plan funding is \$1,286,970,217.

Third-party facilities must be upgraded when it is determined they are constrained in order to accommodate the requested Transmission Service. These include both first-tier neighboring facilities outside SPP and Transmission Owner facilities within SPP that are not under the SPP OATT. In this AFS, 2 third-party facilities were identified. Total engineering and construction cost estimates for required third-party facility upgrades are \$5,355,000.

The Transmission Provider will tender a Letter of Intent on Friday, September 8th, 2006. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), the Transmission Provider must receive from the Transmission Customer (Customer) by September 23rd, 2006, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to WITHDRAW the request or leave the request in STUDY mode.

At the conclusion of the ATSS, Service Agreements for each request for service will be tendered identifying the terms and conditions of the confirmed service.

If customers withdraw from the ATSS after posting of this AFS, the AFS will be re-performed to determine final cost allocation and Available Transmission Capability (ATC) in consideration of the remaining ATSS participants. All allocated revenue requirements for facility upgrades are assigned to the customer in the AFS data tables.

Potential base plan funding allowable is contingent upon validation of designated resources meeting Attachment J, Section III B criteria.

## **2. Introduction**

On January 21, 2005, the Federal Energy Regulatory Commission accepted Southwest Power Pool's proposed aggregate transmission study procedures in Docket ER05-109 to become effective February 1, 2005. The proposed cost allocation and cost recovery provisions were accepted for filing and suspended to become effective the earlier of five months from the requested effective date (July 1, 2005) or a further order of the Commission in the proceeding subject to refund. Since that time, the cost allocation and cost recovery provisions have been accepted with modification. The following link can be used to access the SPP Regulatory/FERC webpage:

([http://www.spp.org/Objects/FERC\\_filings.cfm](http://www.spp.org/Objects/FERC_filings.cfm)). The hyperlinks under the heading ER05-109 (Attach Z Filing) open Southwest Power Pool's October 29, 2004 filing containing Attachment Z to the SPP OATT and the Commission's January 21, 2005 Order. In compliance with this Order, the fourth open season commenced on February 1, 2006. All requests for long-term transmission service received prior to June 1, 2006 with a signed study agreement were then included in this fourth Aggregate Transmission Service Study (ATSS).

Approximately 4418MW of long-term transmission service has been restudied in this Aggregate Facility Study (AFS) with over \$524 Million in transmission upgrades being proposed. The results of the AFS are detailed in Tables 1 through 6. A highly tangible benefit of studying transmission requests aggregately under the SPP OATT Attachment Z is the sharing of costs among customers using the same facility. The detailed results show individual upgrade costs by study as well as potential base plan allowances as determined by Attachments J and Z. The following link can be used to access the SPP OATT: ([http://www.spp.org/Publications/SPP\\_Tariff.pdf](http://www.spp.org/Publications/SPP_Tariff.pdf)). In order to understand the

extent to which base plan upgrades may be applied to both point-to-point and network transmission services, it is necessary to highlight the definition of Designated Resource. Per Section 1.9a of the SPP OATT, a Designated Resource is “[a]ny designated generation resource owned, purchased or leased by a Transmission Customer to serve load in the SPP Region. Designated Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Transmission Customer's load on a non-interruptible basis.” Therefore, not only network service, but also point-to-point service has potential for base plan funding if the conditions for classifying upgrades associated with designated resources as base plan upgrades as defined in Section III.B of Attachment J are met.

Pursuant to Attachment J, Section III B of the SPP OATT, the Transmission Customer must provide SPP information necessary to verify that the new or changed Designated Resource meets the following conditions:

1. Transmission Customer’s commitment to the requested new or changed Designated Resource must have a duration of at least five years.
2. During the first year the Designated Resource is planned to be used by the Transmission Customer, the accredited capacity of the Transmission Customer’s existing Designated Resources plus the lesser of (a) the planned maximum net dependable capacity applicable to the Transmission Customer or (b) the requested capacity; shall not exceed 125% of the Transmission Customer’s projected system peak responsibility determined pursuant to SPP Criteria 2.

According to Attachment Z Section VI.A, Point-to-Point customers pay the higher of the monthly transmission access charge (base rate) or the monthly revenue requirement associated with the assigned facility upgrades including any prepayments for redispatch required during construction.

Network Integration Service customers pay the total monthly transmission access charges and the monthly revenue requirement associated with the facility upgrades including any prepayments for redispatch during construction.

Transmission Customers paying for a directly assigned network upgrade shall receive credits for new transmission service using the facility as specified in Attachment Z Section VII.

Facilities identified as limiting the requested Transmission Service have been reviewed to determine the required in-service date of each Network Upgrade. The year that each Network Upgrade is required to accommodate a request is determined by interpolating between the applicable model years given the respective loading data. Both previously assigned facilities and the facilities assigned to this request for Transmission Service were evaluated.

In some instances due to lead times for engineering and construction, Network Upgrades may not be available when required to accommodate a request for Transmission Service. When this occurs, the ATC with available Network Upgrades will be less than the capacity requested during either a portion of or all of the requested reservation period. As a result, the lowest seasonal allocated ATC within the requested reservation period will be offered to the Transmission Customer on an applicable annual basis as listed in Table 1. The ATC may be limited by transmission owner planned projects, expansion plan projects, or customer assigned upgrades.

Some constraints identified in the AFS were not assigned to the Customer as the Transmission Provider determined that upgrades are not required due to various reasons or the Transmission Owner has construction plans pending for these upgrades. These facilities are listed by reservation in Table 3. This table also includes constrained

facilities in the current planning horizon that limit the rollover rights of the Transmission Customer. Table 6 lists possible redispatch pairs to allow start of service prior to completion of assigned network upgrades.

#### **A. Financial Analysis**

The AFS utilizes the allocated customer E & C cost in a present worth analysis to determine the monthly levelized revenue requirement of each facility upgrade over the term of the reservation. In some cases, network upgrades cannot be completed within the requested reservation period, thus deferred reservation periods will be utilized in the present worth analysis. If the Customer chooses Option 3, Redispatch, in the Letter Agreement sent coincident with this AFS, the present worth analysis will be re-performed within the original reservation period in the subsequent AFS. The upgrade levelized revenue requirement includes interest, depreciation, and carrying costs.

Each request for Transmission Service is evaluated independently as the cost associated with each Network Upgrade is assigned to a request. When facilities are upgraded throughout the reservation period, the Transmission Customer shall 1) pay the total E & C costs and other annual operating costs associated with the new facilities, and 2) receive credits associated with the depreciated book value of removed usable facilities, salvage value of removed non-usable facilities, and the carrying charges, excluding depreciation, associated with all removed usable facilities based on their respective book values.

In the event that the engineering and construction of a previously assigned Network Upgrade may be expedited, with no additional upgrades, to accommodate a new request for Transmission Service, then the levelized present worth of only the incremental expenses through the reservation period of the new request, excluding depreciation, shall be assigned to the new request. These incremental expenses, excluding depreciation,



include 1) the levelized difference in present worth of the engineering and construction expenses given the change in date to complete construction to account for additional interest expense and reduced engineering and construction expense due to inflation, 2) the levelized present worth of all expediting fees, and 3) the levelized present worth of the incremental annual carrying charges, excluding depreciation and interest, during the new reservation period taking into account both a) the reservation in which the project was originally assigned, and b) a reservation, if any, in which the project was previously expedited.

### **B. Third-Party Facilities**

For third-party facilities listed in Table 3 and Table 5, the Transmission Customer is responsible for funding the necessary upgrades of these facilities per Section 21.1 of the Transmission Provider's OATT. In this AFS, 2 third-party facilities were identified. Total engineering and construction cost estimates for required third-party facility upgrades are \$5,355,000. The Transmission Provider will undertake reasonable efforts to assist the Transmission Customer in making arrangements for necessary engineering, permitting, and construction of the third-party facilities. Third-party facility upgrade engineering and construction cost estimates are not utilized to determine the present worth value of levelized revenue requirements for SPP system network upgrades.

All modeled facilities within the Transmission Provider system were monitored during the development of this Study as well as certain facilities in first-tier neighboring systems. Third-party facilities must be upgraded when it is determined that they are overloaded while accommodating the requested Transmission Service. These facilities also include those owned by members of the Transmission Provider who have not placed their facilities under the Transmission Provider's OATT.

Third-party facilities are evaluated for only those requests whose load sinks within the SPP footprint. The Customer must arrange for study of 3<sup>rd</sup> party facilities for load that sinks outside the SPP footprint with the applicable Transmission Providers.

### **3. Study Methodology**

#### **A. Description**

The system impact analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier Non - SPP control area systems. The steady-state analysis was done to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled. The Southwest Power Pool conforms to the NERC Reliability Standards, which provide the strictest requirements, related to voltage violations and thermal overloads during normal conditions and during a contingency. It requires that all facilities be within normal operating ratings for normal system conditions and within emergency ratings after a contingency. Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP MDWG models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 110% and 90%. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations.

The contingency set includes all SPP control area branches and ties 69kV and above, first tier Non - SPP control area branches and ties 115 kV and above, any defined contingencies for these control areas, and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier Non – SPP control area branches and ties 69 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier Non – SPP control area facilities, a 3 % TDF cutoff was applied to AEI, AMRN, and ENTR and a 2 % TDF cutoff was applied to MEC, NPPD, and OPPD. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

## **B. Model Development**

SPP used fifteen seasonal models to study the aggregate transfers of 4418 MW over a variety of requested service periods. The SPP MDWG 2006 Series Cases Update 1 2006 Summer Peak (06SP), 2006 Summer Shoulder (06SH), 2006 Fall Peak (06FA), 2006/07 Winter Peak (06WP), 2007 April Minimum (07AP), 2007 Spring Peak (07G), 2007 Summer Peak (07SP), 2007 Summer Shoulder (07SH), 2007 Fall Peak (07FA), 2007/08 Winter Peak (07WP), 2008 Summer Peak (08SP), 2008/09 Winter Peak (08WP), 2011 Summer Peak (11SP), 2011/12 Winter Peak (11WP), and 2016 Summer Peak (16SP) were used to study the impact of the requested service on the transmission system. The Spring Peak models apply to April and May, the Summer Peak models apply to June through September, the Fall Peak models apply to October and November, and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the most current modeling information. Four groups of requests were developed from the aggregate of 4418 MW in order to minimize counterflows among requested service. Each request was included in two to four groups depending on the requested path. From the thirteen seasonal models, three system scenarios were developed. Scenario 1 includes SWPP OASIS transmission requests not already included in the SPP 2006 Series Cases flowing in a West to East direction with ERCOT exporting and SPS exporting to outside zones and exporting to the

Lamar HVDC Tie. Scenario 2 includes transmission requests not already included in the SPP 2006 Series Cases flowing in an East to West direction with ERCOT net importing and SPS importing from an outside zone and exporting to the Lamar HVDC Tie.

Scenario 3 includes transmission requests not already included in the SPP 2006 Series Cases flowing in a West to East direction with ERCOT net importing and SPS importing from an outside zone and importing from the Lamar HVDC Tie. Scenario 4 includes transmission requests not already included in the SPP 2006 Series Cases flowing in a North to South direction with ERCOT importing and SPS importing from outside zones and importing from the Lamar HVDC tie. The system scenarios were developed to minimize counter flows from previously confirmed, higher priority requests not included in the MDWG Base Case.

### **C. Transfer Analysis**

Using the selected cases both with and without the requested transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs (SPP and 1<sup>st</sup>-Tier) and voltage threshold (0.02 change below 0.90 pu) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

### **D. Curtailment and Redispatch Evaluation**

During any period when SPP determines that a transmission constraint exists on the Transmission System, and such constraint may impair the reliability of the Transmission

System, SPP will take whatever actions that are reasonably necessary to maintain the reliability of the Transmission System. To the extent SPP determines that the reliability of the Transmission System can be maintained by redispatching resources, SPP will evaluate curtailment of existing confirmed service or interim redispatch of units to provide service prior to completion of any assigned network upgrades. Any redispatch may not unduly discriminate between the Transmission Owners' use of the Transmission System on behalf of their Native Load Customers and any Transmission Customer's use of the Transmission System to serve its designated load. Redispatch was evaluated to provide only interim service during the time frame prior to completion of any assigned network upgrades.

SPP determined potential relief pairs to relieve the incremental MW impact on limiting facilities as identified in Table 6. Using the selected cases where the limiting facilities were identified, potential incremental and decremental units were identified by determining the generation amount available for increasing and decreasing from the units generation amount, maximum generation amount, and minimum generation amount. If the incremental or decremental amount was greater than 1 MW, the unit was considered as a potential incremental or decremental unit. Generation shift factors were calculated for the potential incremental and decremental units using Managing and Utilizing System Transmission (MUST). From the generation shift factors for the incremental and decremental units, top 100 relief pairs with a greater than 3% TDF were determined from the incremental units with the lowest generation shift factors and decremental units with highest generation shift factors. The potential relief pairs **were not** evaluated to determine impacts on limiting facilities in the SPP and 1st-Tier systems. The redispatch requirements would be called upon prior to implementing NERC TLR Level 5a.

## **4. Study Results**

### **A. Study Analysis Results**

Tables 1 through 6 contain the steady-state analysis results of the ASIS. Table 1 identifies the participating long-term transmission service requests included in the AFS. This table lists deferred start and stop dates both with and without redispatch (if applicable), the minimum annual allocated ATC without upgrades and season of first impact. Table 2 identifies total E & C cost allocated to each Transmission Customer, letter of credit requirements, third party E & C cost assignments, potential base plan E & C funding (lower of allocated E & C or Attachment J Section III B criteria) , total revenue requirements for assigned upgrades without consideration of potential base plan funding, point-to-point base rate charge, total revenue requirements for assigned upgrades with consideration of potential base plan funding, and final total cost allocation to the Transmission Customer. Table 3 provides additional details for each request including all assigned facility upgrades required, allocated E & C costs, allocated revenue requirements for upgrades, upgrades not assigned to customer but required for service to be confirmed, facilities limiting rollover rights, credits to be paid for previously assigned AFS facility upgrades, and any third party upgrades required. This includes the season in the planning horizon where rollover rights are limited. Table 4 lists all upgrade requirements with associated solutions needed to provide transmission service for the AFS, Minimum ATC per upgrade with season of impact, Earliest Date Upgrade is required (COD), Estimated Date of Upgrade Completion (EOC), and Estimated E & C cost. Table 5 lists identified Third-Party constrained facilities. Table 6 identifies potential redispatch pairs available to relieve the aggregate impacts on identified constraints to prevent deferral of start of service.

Potential base plan funding allowable is contingent upon meeting each of the conditions for classifying upgrades associated with designated resources as base plan upgrades as

defined in Section III.B of Attachment J. The lesser of the planned maximum net dependable capacity or the requested capacity is multiplied by \$180,000 to determine potential base plan funding allowable. If this additional capacity exceeds the 125% resource to load criteria for a given year, the value of capacity not exceeding 125% of load will set the determinant for base plan funding consideration. For example, a customer submits a request to add a new resource of 50MW in 2010 that meets all other conditions for base plan funding. The Customer's load forecast for 2010 is 500MW with forecasted firm resources of 600MW. The additional 50MW of resources increases the resource to load ratio from 120% to 130%. Therefore the E & C cost for that portion of the 50MW request not exceeding 125% resource to load, or 25MW, would be compared to the E & C cost for the full 50MW to determine a prorata share of the cost that can be covered by base plan funding. Any allocated customer costs in excess of base plan funding will be assigned to the customer.

Regarding application of base plan funding for PTP requests, if PTP base rate exceeds upgrade revenue requirements without taking into effect the reduction of revenue requirements by potential base plan funding, then the base rate revenue pays back the Transmission Owner for upgrades and no base plan funding is applicable as the access charge must be paid as it is the higher of "OR" pricing.

However, if initially the upgrade revenue requirements exceed the PTP base rate, then potential base plan funding would be applicable. The test of the higher of "OR" pricing would then be made against the remaining assignable revenue requirements versus PTP base rate. Examples are as follows:

Example A:

E & C allocated for upgrades is 74 million with revenue requirements of 140 million and PTP base rate of 101 million. Potential base plan funding is 47 million with the difference of 27 million E & C assignable to the customer. If the revenue requirements for the assignable portion is 54 million and the PTP base rate is 101 million, the customer will pay the higher “OR” pricing of 101 million base rate of which 54 million revenue requirements will be paid back to the Transmission Owners for the upgrades and the remaining revenue requirements of (140-54) or 86 million will be paid by base plan funding.

Example B:

E & C allocated for upgrades is 74 million with revenue requirements of 140 million and PTP base rate of 101 million. Potential base plan funding is 10 million with the difference of 64 million E & C assignable to the customer. If the revenue requirements for this assignable portion is 128 million and the PTP base rate is 101 million the customer will pay the higher “OR” pricing of 128 million revenue requirements to be paid back to the Transmission Owners and the remaining revenue requirements of (140-128) or 12 million will be paid by base plan funding.

Example C:

E & C allocated for upgrades is 25 million with revenue requirements of 50 million and PTP base rate of 101 million. Potential base plan funding is 10 million. Base plan funding is not applicable as the higher “OR” pricing of PTP base rate of 101 million must be paid and the 50 million revenue requirements will be paid from this.

The 125% resource to load determination is performed on a per request basis and is not based on a total of designated resource requests per Customer. A footnote will provide the maximum resource designation allowable for base plan funding consideration per Customer basis per year.



Base plan funding verification requires that each Transmission Customer with potential for base plan funding provide SPP power supply contracts or agreements verifying that the firm capacity of the requested designated resource is committed for a minimum five year duration.

## **B. Study Definitions**

The Commercial Operation Date (COD) is the earliest date the upgrade is required to alleviate a constraint considering all requests. End of Construction (EOC) is the estimated date the upgrade will be completed and in service. The Total Engineering and Construction Cost (E & C) is the upgrade solution cost as determined by the transmission owner. The Transmission Customer Allocation Cost is the estimated engineering and construction cost based upon the allocation of costs to all Transmission Customers in the AFS who positively impact facilities by at least 3% subsequently overloaded by the AFS. Minimum ATC is the portion of the requested capacity that can be accommodated with out upgrading facilities. Annual ATC allocated to the Transmission Customer is determined by the least amount of allocated seasonal ATC within each year of a reservation period.

## **5. Conclusion**

The results of the AFS show that limiting constraints exist in many areas of the regional transmission system. Due to these constraints, transmission service cannot be granted unless noted in Table 3.

The Transmission Provider will tender a Letter of Intent on Friday, September 8th, 2006. This will open a 15-day window for Customer response. To remain in the Aggregate

Transmission Service Study (ATSS), the Transmission Provider must receive from the Transmission Customer (Customer) by September 23rd, 2006, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to WITHDRAW the request or leave the request in STUDY mode.

The Transmission Provider must receive an unconditional and irrevocable letter of credit in the amount of the total allocated Engineering and Construction costs assigned to the Customer. This letter of credit is required regardless of base plan funding consideration. This amount is for all assignable Network Upgrades less pre-payment requirements. The amount of the letter of credit will be adjusted down on an annual basis to reflect amortization of these costs. The Transmission Provider will issue letters of authorization to construct facility upgrades to the constructing Transmission Owner. This date is determined by the engineering and construction lead time provided for each facility upgrade.

## Appendix A

### PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

#### BASE CASES:

Solutions - Fixed slope decoupled Newton-Raphson solution (FDNS)

1. Tap adjustment – Stepping
2. Area interchange control – Tie lines and loads
3. Var limits – Apply immediately
4. Solution options -  Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

#### ACCC CASES:

Solutions – AC contingency checking (ACCC)

1. MW mismatch tolerance – 0.5
2. Contingency case rating – Rate B
3. Percent of rating – 100
4. Output code – Summary
5. Min flow change in overload report – 3mw
6. Exclcd cases w/ no overloads form report – YES
7. Exclude interfaces from report – NO
8. Perform voltage limit check – YES
9. Elements in available capacity table – 60000
10. Cutoff threshold for available capacity table – 99999.0
11. Min. contng. case Vltg chng for report – 0.02
12. Sorted output – None

#### Newton Solution:

1. Tap adjustment – Stepping
2. Area interchange control – Tie lines and loads
3. Var limits - Apply automatically
4. Solution options -  Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

**Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study**

Customer	Study Number	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Start Date with Redispatch	Stop Date with Redispatch	Mimum Allocated ATC (MW) within reservation period	Season of Minimum Allocated ATC within reservation period
AECC	AG2-2006-017	1079577	CSWS	EES	25	1/1/2007	1/1/2009	6/1/2009	6/1/2011	N/A	N/A	0	06WP
AECC	AG2-2006-039	1089945	WR	CSWS	50	12/1/2007	12/1/2027	6/1/2009	6/1/2029	N/A	N/A	0	07WP
AECC	AG2-2006-064	1090457	WR	EES	50	12/1/2007	12/1/2027					0	11WP
AEPM	AG2-2006-024	1086238	WFEC	CSWS	16	7/1/2007	7/1/2027	6/1/2010	6/1/2030	6/1/2009 <sup>1</sup>	6/1/2029	0	07FA
AEPM	AG2-2006-033	1087745	EES	CSWS	225	1/1/2007	1/1/2010	6/1/2010	6/1/2013	6/1/2009 <sup>1</sup>	6/1/2012	0	06WP
AEPM	AG2-2006-034	1087757	CSWS	CSWS	172	6/1/2008	6/1/2028	6/1/2010	6/1/2030	6/1/2009 <sup>1</sup>	6/1/2029	0	08SP
APM	AG2-2006-031	1087085	AECI	OKGE	3	12/1/2006	12/1/2007	6/1/2010 <sup>2</sup>	6/1/2011	N/A	N/A	1	07G
CALP	AG2-2006-004	1040980	NPPD	ERCOTE	50	1/1/2007	1/1/2008	6/1/2010	6/1/2011	N/A	N/A	0	06WP
EDE	AG2-2006-018	1080018	EES	EDE	50	6/1/2010	6/1/2040					0	11SP
GSEC	AG2-2006-054	1090270	CSWS	CSWS	10	10/1/2006	10/1/2036	6/1/2011 <sup>2</sup>	6/1/2041	6/1/2010 <sup>1</sup>	6/1/2040	0	06WP
GSEC	AG2-2006-056	1090288	SECI	SPS	400	6/1/2011	6/1/2041					0	11SP
GSEC	AG2-2006-086	1090767	CSWS	CSWS	8	10/1/2006	10/1/2036	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A	0	07SP
GSEC	AG2-2006-087	1090789	CSWS	CSWS	6	10/1/2006	10/1/2036	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A	0	07SP
GSEC	AG2-2006-126	1090298	SPS	SPS	15	10/1/2007	10/1/2037					0	16SP
GSEC	AG2-2006-127	1090301	SPS	SPS	20	3/1/2007	3/1/2037	6/1/2010	6/1/2040	3/1/2007 <sup>1</sup>	3/1/2037	0	07AP
GSEC	AG2-2006-128	1090310	SPS	SPS	20	7/1/2007	7/1/2037	6/1/2011 <sup>2</sup>	6/1/2041	6/1/2010 <sup>1</sup>	6/1/2040	0	07FA
GSEC	AG2-2006-129	1090315	SPS	SPS	20	9/1/2007	9/1/2037	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A	0	08SP
GSEC	AG2-2006-130	1090320	SPS	SPS	25	3/1/2011	3/1/2041					0	16SP
GSEC	AG2-2006-131	1090322	SPS	SPS	25	3/1/2009	3/1/2039					0	16SP
GSEC	AG2-2006-132	1090454	SPS	SPS	5	10/1/2006	10/1/2036	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A	0	07G
GSEC	AG2-2006-133	1090487	SPS	SPS	150	4/1/2007	4/1/2017	6/1/2010 <sup>2</sup>	6/1/2020	N/A	N/A	0	07AP
GSEC	AG2-2006-134	1090324	SPS	SPS	25	3/1/2013	3/1/2043					0	16SP
GSEC	AG2-2006-135	1090328	SPS	SPS	25	3/1/2016	3/1/2046					0	16SP
GSEC	AG2-2006-136	1090456	SPS	SPS	15	7/1/2007	7/1/2037	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A	0	07SH
KBPU	AG2-2006-041	1089950	WR	KACY	25	10/1/2007	10/1/2027	6/1/2011 <sup>2</sup>	6/1/2028	6/1/2010 <sup>1</sup>	6/1/2028	0	07FA
KBPU	AG2-2006-042	1089952	SPA	KACY	39	7/1/2007	7/1/2017	1/1/2009	1/1/2018	7/1/2007 <sup>1</sup>	7/1/2017	0	07FA
KCPS	AG2-2006-090	1090801	KCPL	AECI	1	11/1/2006	6/1/2025					1	N/A
KCPS	AG2-2006-090	1090802	KCPL	AECI	1	11/1/2006	6/1/2025					1	N/A
KCPS	AG2-2006-091	1090773	KCPL	KACY	10	11/1/2006	6/1/2010	6/1/2008	6/1/2010	11/1/2006 <sup>1</sup>	6/1/2010	3	07SP
KCPS	AG2-2006-091	1090782	KCPL	KACY	24	11/1/2006	6/1/2010	6/1/2008	6/1/2010	11/1/2006 <sup>1</sup>	6/1/2010	6	07SP
KCPS	AG2-2006-091	1090787	KCPL	KACY	11	11/1/2006	6/1/2010	6/1/2008	6/1/2010	11/1/2006 <sup>1</sup>	6/1/2010	3	07SP
KCPS	AG2-2006-091	1090815	KCPL	KACY	12	11/1/2006	6/1/2010	6/1/2008	6/1/2010	11/1/2006 <sup>1</sup>	6/1/2010	3	07SP
KCPS	AG2-2006-091	1090818	KCPL	KACY	25	11/1/2006	6/1/2010	6/1/2008	6/1/2010	11/1/2006 <sup>1</sup>	6/1/2010	6	07SP
KEPC	AG2-2006-067	1090416	KCPL	WR	30	6/1/2010	6/1/2030	6/1/2011	6/1/2031	6/1/2010 <sup>1</sup>	6/1/2030	0	11SP
KEPC	AG2-2006-105	1090808	WR	WR	6	10/1/2006	10/1/2036	6/1/2011 <sup>2</sup>	6/1/2041	6/1/2010 <sup>1</sup>	6/1/2040	0	07SP
KEPC	AG2-2006-105	1090825	WR	WR	5	10/1/2006	10/1/2026	6/1/2011	6/1/2031	12/1/2007 <sup>1</sup>	12/1/2027	0	07SP
KEPC	AG2-2006-120	1090745	SECI	WPEK	25	6/1/2010	6/1/2030					0	11SP
KEPC	AG2-2006-121	1090754	SECI	WR	25	6/1/2010	6/1/2030					0	11SP
KEPC	AG2-2006-122	1090729	WR	KCPL	14	6/1/2007	6/1/2012	6/1/2010 <sup>2</sup>	6/1/2015	N/A	N/A	0	07FA
KEPC	AG2-2006-123	1090823	WR	WR	5	6/1/2007	6/1/2027	6/1/2011 <sup>2</sup>	6/1/2031	12/1/2007 <sup>1</sup>	12/1/2027	0	07FA
KMEA	AG2-2006-065	1090401	GRDA	KCPL	1	5/1/2007	5/1/2026					0	08SP
KMEA	AG2-2006-065	1090528	GRDA	KCPL	1	5/1/2007	5/1/2026					0	08SP
KMEA	AG2-2006-081	1090662	WR	WR	16	10/1/2006	10/1/2016	6/1/2011	6/1/2021	6/1/2010 <sup>1</sup>	6/1/2020	0	06FA
KMEA	AG2-2006-082	1090674	GRDA	WR	1	5/1/2007	5/1/2026	6/1/2011 <sup>2</sup>	6/1/2026	10/1/2007 <sup>1</sup>	10/1/2026	0	07FA
KMEA	AG2-2006-083	1090676	GRDA	WR	1	5/1/2010	5/1/2026	6/1/2011 <sup>2</sup>	6/1/2026	5/1/2010 <sup>1</sup>	5/1/2026	0	11SP
KMEA	AG2-2006-084	1090548	GRDA	KCPL	1	5/1/2010	5/1/2026					0	11SP
KPP	AG2-2006-078	1090609	WR	WR	129	10/1/2006	10/1/2016	6/1/2011	6/1/2021	10/1/2007 <sup>1</sup>	10/1/2017	0	06FA
KPP	AG2-2006-079	1090613	SECI	WPEK	25	10/1/2006	10/1/2016	6/1/2010 <sup>2</sup>	6/1/2020	N/A	N/A	0	07SH
KPP	AG2-2006-125	1090612	WPEK	WPEK	13	10/1/2006	10/1/2016	6/1/2011 <sup>2</sup>	6/1/2021	10/1/2008 <sup>1</sup>	10/1/2018	0	06WP
MECB	AG2-2006-140	1103355	MEC	AECI	100	1/1/2007	1/1/2008	6/1/2010 <sup>2</sup>	6/1/2011	N/A	N/A	55	07SP
MECB	AG2-2006-140	1103357	MEC	AECI	50	1/1/2007	1/1/2008	6/1/2010 <sup>2</sup>	6/1/2011	N/A	N/A	27	07SP
MIDW	AG2-2006-047	1090244	WR	WR	2	6/1/2008	6/1/2013	6/1/2010 <sup>2</sup>	6/1/2015	N/A	N/A	0	08SP
MIDW	AG2-2006-050	1090329	WR	WR	36	6/1/2010	6/1/2035	6/1/2011 <sup>2</sup>	6/1/2036	6/1/2010 <sup>1</sup>	6/1/2035	0	11SP
MIDW	AG2-2006-050	1090331	WR	WR	9	6/1/2010	6/1/2035	6/1/2011 <sup>2</sup>	6/1/2036	6/1/2010 <sup>1</sup>	6/1/2035	0	11SP
MIDW	AG2-2006-050	1090332	WR	WR	49	6/1/2010	6/1/2035	6/1/2011 <sup>2</sup>	6/1/2036	6/1/2010 <sup>1</sup>	6/1/2035	0	11SP
MIDW	AG2-2006-050	1090334	WR	WR	11	6/1/2010	6/1/2035	6/1/2011 <sup>2</sup>	6/1/2036	6/1/2010 <sup>1</sup>	6/1/2035	0	11SP
MIDW	AG2-2006-051	1090325	WR	WR	24	6/1/2008	6/1/2038	6/1/2011 <sup>2</sup>	6/1/2041	6/1/2008 <sup>1</sup>	6/1/2038	0	08SP
MIDW	AG2-2006-051	1090327	WR	WR	6	6/1/2008	6/1/2038	6/1/2011 <sup>2</sup>	6/1/2041	6/1/2008 <sup>1</sup>	6/1/2038	0	08SP

**Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study**

MIDW	AG2-2006-052	1090245	WR	WR	6	6/1/2008	6/1/2013	6/1/2010 <sup>2</sup>	6/1/2015	N/A	N/A				0	08SP
MIDW	AG2-2006-058	1090377	EES	WR	40	5/1/2010	5/1/2040	6/1/2011 <sup>2</sup>	6/1/2041		5/1/2010 <sup>1</sup>	5/1/2040			0	11SP
MIDW	AG2-2006-058	1090378	EES	WR	10	5/1/2010	5/1/2040	6/1/2011 <sup>2</sup>	6/1/2041		5/1/2010 <sup>1</sup>	5/1/2040			0	11SP
MIDW	AG2-2006-058	1090382	EES	WR	20	5/1/2010	5/1/2040	6/1/2011 <sup>2</sup>	6/1/2041		5/1/2010 <sup>1</sup>	5/1/2040			0	11SP
MIDW	AG2-2006-058	1090383	EES	WR	5	5/1/2010	5/1/2040	6/1/2011 <sup>2</sup>	6/1/2041		5/1/2010 <sup>1</sup>	5/1/2040			0	11SP
MIDW	AG2-2006-059	1090388	EES	WR	7	5/1/2010	5/1/2040								0	11SP
MIDW	AG2-2006-059	1090390	EES	WR	3	5/1/2010	5/1/2040								0	11SP
MIDW	AG2-2006-060	1090392	EES	WR	1	5/1/2010	5/1/2040								0	11SP
MIDW	AG2-2006-060	1090394	EES	WR	1	5/1/2010	5/1/2040								0	11SP
MIDW	AG2-2006-061	1090396	EES	WR	2	5/1/2010	5/1/2040								0	11SP
MIDW	AG2-2006-061	1090399	EES	WR	1	5/1/2010	5/1/2040								0	11SP
MIDW	AG2-2006-096	1091026	WR	WR	3	6/1/2008	6/1/2038	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A				0	08SP
MIDW	AG2-2006-096	1091027	WR	WR	7	6/1/2008	6/1/2038	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A				0	08SP
MIDW	AG2-2006-096	1091028	WR	WR	8	6/1/2008	6/1/2038	6/1/2011 <sup>2</sup>	6/1/2041		6/1/2010 <sup>1</sup>	6/1/2040			0	08SP
MIDW	AG2-2006-096	1091032	WR	WR	10	6/1/2008	6/1/2038	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A				0	08SP
MIDW	AG2-2006-096	1091066	WR	WR	17	6/1/2008	6/1/2013	6/1/2010 <sup>2</sup>	6/1/2015	N/A	N/A				0	08SP
MIDW	AG2-2006-097	1090917	WR	WR	20	6/1/2008	6/1/2038	6/1/2011	6/1/2041		6/1/2008 <sup>1</sup>	6/1/2038			4	08SP
MIDW	AG2-2006-097	1090919	WR	WR	5	6/1/2008	6/1/2038	6/1/2011	6/1/2041		6/1/2008 <sup>1</sup>	6/1/2038			1	08SP
MIDW	AG2-2006-097	1090920	WR	WR	40	6/1/2008	6/1/2038	6/1/2011	6/1/2041		6/1/2008 <sup>1</sup>	6/1/2038			8	08SP
MIDW	AG2-2006-097	1090921	WR	WR	10	6/1/2008	6/1/2038	6/1/2011	6/1/2041		6/1/2008 <sup>1</sup>	6/1/2038			2	08SP
MIDW	AG2-2006-097	1090922	WR	WR	50	6/1/2008	6/1/2038	6/1/2011	6/1/2041		6/1/2008 <sup>1</sup>	6/1/2038			0	11WP
MIDW	AG2-2006-097	1090923	WR	WR	11	6/1/2008	6/1/2038	6/1/2011	6/1/2041		6/1/2008 <sup>1</sup>	6/1/2038			0	11WP
MIDW	AG2-2006-097	1090934	WR	WR	60	6/1/2008	6/1/2038	6/1/2011	6/1/2041		6/1/2008 <sup>1</sup>	6/1/2038			12	08SP
MIDW	AG2-2006-097	1090935	WR	WR	15	6/1/2008	6/1/2038	6/1/2011	6/1/2041		6/1/2008 <sup>1</sup>	6/1/2038			3	08SP
MIDW	AG2-2006-098	1090958	WR	WR	3	6/1/2008	6/2/2038	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A				0	08SP
MIDW	AG2-2006-098	1091043	WR	WR	1	6/1/2008	6/1/2038	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A				0	08SP
MIDW	AG2-2006-098	1091044	WR	WR	2	6/1/2008	6/1/2038	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A				0	08SP
MIDW	AG2-2006-098	1091045	WR	WR	2	6/1/2008	6/1/2038	6/1/2011 <sup>2</sup>	6/1/2041		6/1/2010 <sup>1</sup>	6/1/2040			0	08SP
MIDW	AG2-2006-099	1091034	WR	WR	1	6/1/2008	6/1/2038	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A				0	08SP
MIDW	AG2-2006-099	1091035	WR	WR	1	6/1/2008	6/1/2038	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A				0	08SP
MIDW	AG2-2006-099	1091036	WR	WR	1	6/1/2008	6/1/2038	6/1/2011 <sup>2</sup>	6/1/2041		6/1/2010 <sup>1</sup>	6/1/2040			0	08SP
MIDW	AG2-2006-099	1091041	WR	WR	2	6/1/2008	6/1/2038	6/1/2010 <sup>2</sup>	6/1/2040	N/A	N/A				0	08SP
MIDW	AG2-2006-106	1090964	WR	WR	35	1/1/2007	1/1/2012	6/1/2011 <sup>2</sup>	6/1/2016		10/1/2008 <sup>1</sup>	10/1/2013			0	07SH
MIDW	AG2-2006-106	1090965	WR	WR	10	1/1/2007	1/1/2012	6/1/2011 <sup>2</sup>	6/1/2016		10/1/2008 <sup>1</sup>	10/1/2013			0	07SH
MIDW	AG2-2006-107	1090817	WR	WR	25	6/1/2007	6/1/2017	6/1/2011 <sup>2</sup>	6/1/2021		10/1/2008 <sup>1</sup>	10/1/2018			0	07SH
MIDW	AG2-2006-108	1090826	WR	WR	40	6/1/2008	6/1/2028	6/1/2011 <sup>2</sup>	6/1/2031		6/1/2008 <sup>1</sup>	6/1/2028			0	08SP
MIDW	AG2-2006-108	1090829	WR	WR	15	6/1/2008	6/1/2028								0	11SP
MIDW	AG2-2006-108	1090839	WR	WR	40	6/1/2008	6/1/2018	6/1/2011 <sup>2</sup>	6/1/2021		6/1/2008 <sup>1</sup>	6/1/2018			0	08SP
MIDW	AG2-2006-108	1090841	WR	WR	40	6/1/2008	6/1/2018	6/1/2011 <sup>2</sup>	6/1/2021		6/1/2008 <sup>1</sup>	6/1/2018			0	08SP
MIDW	AG2-2006-108	1090844	WR	WR	10	6/1/2008	6/1/2028	6/1/2011 <sup>2</sup>	6/1/2031		6/1/2008 <sup>1</sup>	6/1/2028			0	08SP
MIDW	AG2-2006-108	1090852	WR	WR	10	6/1/2008	6/1/2018	6/1/2011 <sup>2</sup>	6/1/2021		6/1/2008 <sup>1</sup>	6/1/2018			0	08SP
MIDW	AG2-2006-108	1090853	WR	WR	19	6/1/2008	6/1/2018	6/1/2011 <sup>2</sup>	6/1/2021		6/1/2008 <sup>1</sup>	6/1/2018			0	08SP
MIDW	AG2-2006-108	1090854	WR	WR	6	6/1/2008	6/1/2018	6/1/2011 <sup>2</sup>	6/1/2021		6/1/2008 <sup>1</sup>	6/1/2018			0	08SP
MIDW	AG2-2006-108	1091052	WR	WR	10	6/1/2008	6/1/2013	6/1/2011 <sup>2</sup>	6/1/2016		6/1/2008 <sup>1</sup>	6/1/2013			0	08SP
MIDW	AG2-2006-108	1091053	WR	WR	20	6/1/2008	6/1/2013	6/1/2011 <sup>2</sup>	6/1/2016		6/1/2008 <sup>1</sup>	6/1/2013			0	08SP
MIDW	AG2-2006-108	1091055	WR	WR	30	6/1/2008	6/1/2013	6/1/2011 <sup>2</sup>	6/1/2016		6/1/2008 <sup>1</sup>	6/1/2013			0	08SP
MIDW	AG2-2006-108	1091057	WR	WR	10	6/1/2008	6/1/2018	6/1/2011 <sup>2</sup>	6/1/2021		6/1/2008 <sup>1</sup>	6/1/2018			0	08SP
MIDW	AG2-2006-109	1090851	WR	WR	5	6/1/2011	6/1/2031								0	11SP
MIDW	AG2-2006-109	1090855	WR	WR	15	6/1/2011	6/1/2021								0	11SP
MIDW	AG2-2006-109	1090856	WR	WR	5	6/1/2011	6/1/2021								0	11SP
MIDW	AG2-2006-110	1090759	WR	WR	5	6/1/2015	6/1/2025								0	16SP
MIDW	AG2-2006-110	1091068	WR	WR	15	6/1/2015	6/1/2025								0	16SP
MIDW	AG2-2006-118	1090959	SECI	WR	75	6/1/2011	6/1/2041								0	11WP
OGF	AG2-2006-035	1087908	OKGE	EES	10	12/1/2006	12/1/2011	6/1/2009	6/1/2014		12/1/2006 <sup>1</sup>	12/1/2011			0	08SP
PNMM	AG2-2006-089	1090813	SECI	BLKW	75	6/1/2011	6/1/2041								0	11SP
PNMM	AG2-2006-089	1090814	SECI	BLKW	75	6/1/2011	6/1/2041								0	11SP
SEPC	AG2-2006-043	1090236	SECI	WPEK	150	6/1/2011	6/1/2041								0	11SP
SHDY	AG2-2006-019	1085305	OKGE	CSWS	320	1/8/2008	1/8/2009	6/1/2010	6/1/2011		1/8/2008 <sup>1</sup>	1/8/2009			271	08SP
SPSM	AG2-2006-072	1090680	CSWS	BLKW	50	10/1/2006	3/1/2012	6/1/2011 <sup>2</sup>	6/1/2016		6/1/2010 <sup>1</sup>	6/1/2015			0	07AP
SPSM	AG2-2006-073	1090695	OKGE	EDDY	30	1/1/2007	1/1/2013	6/1/2011 <sup>2</sup>	6/1/2017		6/1/2010 <sup>1</sup>	6/1/2016			0	07AP
SPSM	AG2-2006-074	1090699	WPEK	KCPL	50	10/1/2006	10/1/2007	6/1/2010	6/1/2011	N/A	N/A				0	06WP

**Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study**

SPSM	AG2-2006-124	1090705	WPEK	KCPL	50	10/1/2006	10/1/2007	6/1/2010	6/1/2011	N/A	N/A	0	06WP
UCU	AG2-2006-006	1052923	KCPL	MPS	160	6/1/2010	6/1/2030					0	11WP
UCU	AG2-2006-071	1090573	EES	MPS	100	6/1/2010	6/1/2040					0	11SP
UCU	AG2-2006-071	1090578	EES	MPS	50	6/1/2010	6/1/2040					0	11SP
WRGS	AG2-2006-015	1076157	KCPL	AECI	30	6/1/2010	6/1/2015					0	11SP
WRGS	AG2-2006-016	1076158	KCPL	AMRN	20	6/1/2010	6/1/2015					0	11SP
WRGS	AG2-2006-030	1086655	OKGE	WR	225	10/1/2006	10/1/2026	6/1/2011 <sup>2</sup>	6/1/2031	5/1/2007 <sup>1</sup>	5/1/2027	0	11WP
WRGS	AG2-2006-030	1086656	OKGE	WR	75	10/1/2006	10/1/2026	6/1/2011 <sup>2</sup>	6/1/2031	5/1/2007 <sup>1</sup>	5/1/2027	0	11WP

**Note 1:** Disregard Redispatch shown in Table 5 for limitations identified earlier than the start date with redispatch with the exception of limitations identified in the 2006 Fall Peak, 2007 Spring Peak, 2007

**Note 2:** Reservation being deferred due to impact on limitations requiring upgrades with no cost assignment.

**Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests**

Customer	Study Number	Reservation	Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements	<sup>1</sup> Letter of Credit Amount Required	<sup>2</sup> Potential Base Plan Engineering and Construction Funding Allowable	<sup>3</sup> Additional Engineering and Construction Cost for 3rd Party Upgrades	<sup>20</sup> Total Revenue Requirements for Assigned Upgrades over term of reservation without potential base plan funding allocation	<sup>20</sup> Total Revenue Requirements for Assigned Upgrades over term of reservation WITH potential base plan funding allocation	Point-to-Point Base Rate over reservation period	<sup>4</sup> Total Cost of Reservation Assignable to Customer contingent upon base plan funding
AECC	AG2-2006-017	1079577	\$ 3,706,760	\$ 3,706,760			\$ 6,235,589	\$ 6,235,589		\$ 6,235,589
AECC	AG2-2006-039	1089945	\$ 3,873,307	\$ 3,887,090	\$ 900,000		\$ 12,778,376	\$ 9,779,536		\$ 9,779,536
AECC	AG2-2006-064	1090457	\$ 482,089	\$ 482,089			\$ 1,683,746	\$ 1,683,746	\$ 10,800,000	\$ 10,800,000
AEPM	AG2-2006-024	1086238	\$ 799,255	\$ -	\$ 180,000		\$ 3,069,114	\$ 2,361,425		\$ 2,361,425
AEPM	AG2-2006-033	1087745	\$ 10,363,205	\$ -			\$ 21,932,913	\$ 21,932,913		\$ 21,932,913
AEPM	AG2-2006-034	1087757	\$ 8,529,279	\$ -	\$ 8,529,279		\$ 32,743,607	\$ -		Sch 9 charges
APM	AG2-2006-031	1087085	\$ 17,399	\$ 17,399			\$ 36,512	\$ 36,512		\$ 36,512
CALP	AG2-2006-004	1040980	\$ 340,542	\$ 340,542			\$ 714,581	\$ 714,581	\$ 630,000	\$ 714,581
EDE	AG2-2006-018	1080018	\$ 10,897,665	\$ -			\$ 36,273,200	\$ 36,273,200		\$ 36,273,200
GSEC	AG2-2006-054	1090270	\$ 6,678,605	\$ 6,853,492			\$ 24,350,003	\$ 24,350,003		\$ 24,350,003
GSEC	AG2-2006-056	1090288	\$ 107,196,883	\$ 107,219,996	\$ 72,000,000		\$ 503,397,656	\$ 165,284,922		\$ 165,284,922
GSEC	AG2-2006-126	1090298	\$ 2,177,669	\$ 2,177,669			\$ 6,333,288	\$ 6,333,288		\$ 6,333,288
GSEC	AG2-2006-127	1090301	\$ 13,500,200	\$ 13,500,200			\$ 57,492,506	\$ 57,492,506		\$ 57,492,506
GSEC	AG2-2006-128	1090310	\$ 7,124,975	\$ 7,124,975			\$ 35,415,681	\$ 35,415,681		\$ 35,415,681
GSEC	AG2-2006-129	1090315	\$ 6,223,734	\$ 6,223,734			\$ 26,127,508	\$ 26,127,508		\$ 26,127,508
GSEC	AG2-2006-130	1090320	\$ 1,834,993	\$ 1,834,993			\$ 8,542,156	\$ 8,542,156		\$ 8,542,156
GSEC	AG2-2006-131	1090322	\$ 2,054,819	\$ 2,054,819			\$ 8,097,954	\$ 8,097,954		\$ 8,097,954
GSEC	AG2-2006-134	1090324	\$ 2,703,925	\$ 2,703,925			\$ 14,759,052	\$ 14,759,052		\$ 14,759,052
GSEC	AG2-2006-135	1090328	\$ 2,703,925	\$ 2,703,925			\$ 18,735,153	\$ 18,735,153		\$ 18,735,153
GSEC	AG2-2006-132	1090454	\$ 1,290,059	\$ 1,290,059			\$ 5,256,562	\$ 5,256,562		\$ 5,256,562
GSEC	AG2-2006-136	1090456	\$ 4,007,543	\$ 4,007,543			\$ 18,122,564	\$ 18,122,564		\$ 18,122,564
GSEC	AG2-2006-133	1090487	\$ 10,800,988	\$ 10,800,988	\$ 10,800,988		\$ 26,136,866	\$ (0)		Sch 9 charges
GSEC	AG2-2006-086	1090767	\$ 5,130,552	\$ 5,221,274			\$ 16,904,263	\$ 16,904,263		\$ 16,904,263
GSEC	AG2-2006-087	1090789	\$ 3,945,595	\$ 4,022,248			\$ 12,864,840	\$ 12,864,840		\$ 12,864,840
KBPU	AG2-2006-041	1089950	\$ 1,955,689	\$ 1,961,714			\$ 7,480,706	\$ 7,480,706	\$ 4,488,542	\$ 7,480,706
KBPU	AG2-2006-042	1089952	\$ 3,016,651	\$ 3,016,651			\$ 7,074,526	\$ 7,074,526	\$ 3,706,278	\$ 7,074,526
KCPS	AG2-2006-091	1090773	\$ -	\$ -			\$ -	\$ -	\$ 189,070	\$ 189,070
KCPS	AG2-2006-091	1090782	\$ -	\$ -			\$ -	\$ -	\$ 453,769	\$ 453,769
KCPS	AG2-2006-091	1090787	\$ -	\$ -			\$ -	\$ -	\$ 207,978	\$ 207,978
KCPS	AG2-2006-090	1090801	\$ -	\$ -			\$ -	\$ -	\$ 200,700	\$ 200,700
KCPS	AG2-2006-090	1090802	\$ -	\$ -			\$ -	\$ -	\$ 200,700	\$ 200,700
KCPS	AG2-2006-091	1090815	\$ -	\$ -			\$ -	\$ -	\$ 226,885	\$ 226,885
KCPS	AG2-2006-091	1090818	\$ -	\$ -			\$ -	\$ -	\$ 472,676	\$ 472,676
KEPC	AG2-2006-067	1090416	\$ 2,432,531	\$ 2,440,462	\$ 2,432,531		\$ 9,893,858	\$ 0		Sch 9 charges
KEPC	AG2-2006-122	1090729	\$ 1,470,212	\$ 1,471,934	\$ 1,470,212		\$ 3,607,543	\$ -		Sch 9 charges
KEPC	AG2-2006-120	1090745	\$ 2,426,620	\$ 2,436,382	\$ 2,426,620		\$ 9,070,998	\$ 0		Sch 9 charges
KEPC	AG2-2006-121	1090754	\$ 3,951,469	\$ 3,956,597	\$ 3,951,469		\$ 12,616,953	\$ (0)		Sch 9 charges
KEPC	AG2-2006-105	1090808	\$ 1,904,474	\$ 1,905,055			\$ 7,788,057	\$ 7,788,057		\$ 7,788,057
KEPC	AG2-2006-123	1090823	\$ 572,747	\$ 572,747			\$ 2,235,675	\$ 2,235,675		\$ 2,235,675
KEPC	AG2-2006-105	1090825	\$ 528,494	\$ 528,494			\$ 1,944,987	\$ 1,944,987		\$ 1,944,987
KMEA	AG2-2006-065	1090401	\$ 186,088	\$ 186,088	\$ 180,000		\$ 356,011	\$ 11,647		\$ 11,647
KMEA	AG2-2006-065	1090528	\$ 186,088	\$ 186,088	\$ 180,000		\$ 356,011	\$ 11,647		\$ 11,647
KMEA	AG2-2006-084	1090548	\$ 186,088	\$ 186,088	\$ 180,000		\$ 421,673	\$ 13,795		\$ 13,795
KMEA	AG2-2006-081	1090662	\$ 2,146,329	\$ 2,151,909	\$ 2,146,329	<sup>5</sup>	\$ 6,912,173	\$ -		Sch 9 charges
KMEA	AG2-2006-082	1090674	\$ 332,118	\$ 332,457		<sup>5</sup>	\$ 1,157,061	\$ 1,157,061		\$ 1,157,061
KMEA	AG2-2006-083	1090676	\$ 332,044	\$ 332,407		<sup>5</sup>	\$ 1,156,843	\$ 1,156,843		\$ 1,156,843
KPP	AG2-2006-078	1090609	\$ 33,002,167	\$ 33,042,167	\$ 31,154,045	<sup>7</sup>	\$ 80,300,699	\$ 4,265,005		\$ 4,265,005
KPP	AG2-2006-125	1090612	\$ 12,648,811	\$ 12,748,811	\$ 1,260,000	<sup>6</sup>	\$ 48,151,107	\$ 43,354,578		\$ 43,354,578
KPP	AG2-2006-079	1090613	\$ 1,185,788	\$ 1,186,273		<sup>6</sup>	\$ 3,171,481	\$ 3,171,481		\$ 3,171,481

**Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests**

Customer	Study Number	Reservation	Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements	<sup>1</sup> Letter of Credit Amount Required	<sup>2</sup> Potential Base Plan Engineering and Construction Funding Allowable	<sup>3</sup> Additional Engineering and Construction Cost for 3rd Party Upgrades	<sup>20</sup> Total Revenue Requirements for Assigned Upgrades over term of reservation without potential base plan funding allocation	<sup>20</sup> Total Revenue Requirements for Assigned Upgrades over term of reservation WITH potential base plan funding allocation	Point-to-Point Base Rate over reservation period	<sup>4</sup> Total Cost of Reservation Assignable to Customer contingent upon base plan funding
MECB	AG2-2006-140	1103355	\$ 3,922,876	\$ 3,922,876		\$ 2,853,476	\$ 6,002,035	\$ 6,002,035	\$ 1,080,000	\$8,855,511
MECB	AG2-2006-140	1103357	\$ 1,961,168	\$ 1,961,168		\$ 1,426,524	\$ 3,000,618	\$ 3,000,618	\$ 540,000	\$4,427,142
MIDW	AG2-2006-047	1090244	\$ 493,277	\$ 493,277			\$ 1,245,924	\$ 1,245,924		\$ 1,245,924
MIDW	AG2-2006-052	1090245	\$ 541,667	\$ 541,667			\$ 1,276,212	\$ 1,276,212		\$ 1,276,212
MIDW	AG2-2006-051	1090325	\$ 2,223,555	\$ 2,223,555			\$ 12,616,751	\$ 12,616,751		\$ 12,616,751
MIDW	AG2-2006-051	1090327	\$ 555,918	\$ 555,918			\$ 3,154,311	\$ 3,154,311		\$ 3,154,311
MIDW	AG2-2006-050	1090329	\$ 3,339,806	\$ 3,339,806			\$ 16,779,501	\$ 16,779,501		\$ 16,779,501
MIDW	AG2-2006-050	1090331	\$ 834,940	\$ 834,940			\$ 4,194,827	\$ 4,194,827		\$ 4,194,827
MIDW	AG2-2006-050	1090332	\$ 4,545,787	\$ 4,545,787			\$ 22,838,513	\$ 22,838,513		\$ 22,838,513
MIDW	AG2-2006-050	1090334	\$ 1,020,481	\$ 1,020,481			\$ 5,127,006	\$ 5,127,006		\$ 5,127,006
MIDW	AG2-2006-058	1090377	\$ 5,320,156	\$ 5,320,156			\$ 30,164,686	\$ 30,164,686		\$ 30,164,686
MIDW	AG2-2006-058	1090378	\$ 1,330,032	\$ 1,330,032			\$ 7,541,099	\$ 7,541,099		\$ 7,541,099
MIDW	AG2-2006-058	1090382	\$ 2,660,076	\$ 2,660,076			\$ 15,082,334	\$ 15,082,334		\$ 15,082,334
MIDW	AG2-2006-058	1090383	\$ 665,038	\$ 665,038			\$ 3,770,665	\$ 3,770,665		\$ 3,770,665
MIDW	AG2-2006-059	1090388	\$ 203,262	\$ 203,262			\$ 749,134	\$ 749,134		\$ 749,134
MIDW	AG2-2006-059	1090390	\$ 87,114	\$ 87,114			\$ 321,054	\$ 321,054		\$ 321,054
MIDW	AG2-2006-060	1090392	\$ 182,767	\$ 182,767			\$ 942,617	\$ 942,617		\$ 942,617
MIDW	AG2-2006-060	1090394	\$ 182,767	\$ 182,767			\$ 942,617	\$ 942,617		\$ 942,617
MIDW	AG2-2006-061	1090396	\$ 99,529	\$ 99,529			\$ 543,879	\$ 543,879		\$ 543,879
MIDW	AG2-2006-061	1090399	\$ 49,794	\$ 49,794			\$ 272,066	\$ 272,066		\$ 272,066
MIDW	AG2-2006-110	1090759	\$ 160,982	\$ 160,982			\$ 544,302	\$ 544,302		\$ 544,302
MIDW	AG2-2006-107	1090817	\$ 1,486,045	\$ 1,486,045			\$ 4,565,817	\$ 4,565,817		\$ 4,565,817
MIDW	AG2-2006-108	1090826	\$ 2,377,710	\$ 2,377,710			\$ 9,700,724	\$ 9,700,724		\$ 9,700,724
MIDW	AG2-2006-108	1090829	\$ 875,301	\$ 875,301			\$ 2,899,950	\$ 2,899,950		\$ 2,899,950
MIDW	AG2-2006-108	1090839	\$ 2,377,710	\$ 2,377,710			\$ 7,305,448	\$ 7,305,448		\$ 7,305,448
MIDW	AG2-2006-108	1090841	\$ 2,377,710	\$ 2,377,710			\$ 7,305,448	\$ 7,305,448		\$ 7,305,448
MIDW	AG2-2006-108	1090844	\$ 594,408	\$ 594,408			\$ 2,425,089	\$ 2,425,089		\$ 2,425,089
MIDW	AG2-2006-109	1090851	\$ 291,752	\$ 291,752			\$ 1,187,093	\$ 1,187,093		\$ 1,187,093
MIDW	AG2-2006-108	1090852	\$ 594,408	\$ 594,408			\$ 1,826,293	\$ 1,826,293		\$ 1,826,293
MIDW	AG2-2006-108	1090853	\$ 1,129,399	\$ 1,129,399			\$ 3,470,044	\$ 3,470,044		\$ 3,470,044
MIDW	AG2-2006-108	1090854	\$ 356,656	\$ 356,656			\$ 1,095,819	\$ 1,095,819		\$ 1,095,819
MIDW	AG2-2006-109	1090855	\$ 875,301	\$ 875,301			\$ 2,682,856	\$ 2,682,856		\$ 2,682,856
MIDW	AG2-2006-109	1090856	\$ 291,752	\$ 291,752			\$ 894,229	\$ 894,229		\$ 894,229
MIDW	AG2-2006-097	1090917	\$ 303,700	\$ 303,700			\$ 1,871,267	\$ 1,871,267		\$ 1,871,267
MIDW	AG2-2006-097	1090919	\$ 75,922	\$ 75,922			\$ 467,799	\$ 467,799		\$ 467,799
MIDW	AG2-2006-097	1090920	\$ 607,387	\$ 607,387			\$ 3,742,458	\$ 3,742,458		\$ 3,742,458
MIDW	AG2-2006-097	1090921	\$ 151,843	\$ 151,843			\$ 935,592	\$ 935,592		\$ 935,592
MIDW	AG2-2006-097	1090922	\$ 560,019	\$ 560,019			\$ 3,599,228	\$ 3,599,228		\$ 3,599,228
MIDW	AG2-2006-097	1090923	\$ 123,223	\$ 123,223			\$ 791,949	\$ 791,949		\$ 791,949
MIDW	AG2-2006-097	1090934	\$ 911,087	\$ 911,087			\$ 5,613,725	\$ 5,613,725		\$ 5,613,725
MIDW	AG2-2006-097	1090935	\$ 227,765	\$ 227,765			\$ 1,403,392	\$ 1,403,392		\$ 1,403,392
MIDW	AG2-2006-098	1090958	\$ 214,734	\$ 214,734			\$ 1,109,487	\$ 1,109,487		\$ 1,109,487
MIDW	AG2-2006-118	1090959	\$ 7,272,020	\$ 7,287,440			\$ 41,117,136	\$ 41,117,136		\$ 41,117,136
MIDW	AG2-2006-106	1090964	\$ 2,080,531	\$ 2,080,531	\$ 2,080,531		\$ 5,471,729	\$ -		Sch 9 charges
MIDW	AG2-2006-106	1090965	\$ 594,408	\$ 594,408	\$ 594,408		\$ 1,563,264	\$ -		Sch 9 charges
MIDW	AG2-2006-096	1091026	\$ 148,843	\$ 148,843			\$ 627,333	\$ 627,333		\$ 627,333
MIDW	AG2-2006-096	1091027	\$ 347,220	\$ 347,220			\$ 1,463,458	\$ 1,463,458		\$ 1,463,458
MIDW	AG2-2006-096	1091028	\$ 197,123	\$ 197,123			\$ 827,577	\$ 827,577		\$ 827,577
MIDW	AG2-2006-096	1091032	\$ 495,991	\$ 495,991			\$ 2,090,492	\$ 2,090,492		\$ 2,090,492
MIDW	AG2-2006-099	1091034	\$ 239,510	\$ 239,510			\$ 1,234,404	\$ 1,234,404		\$ 1,234,404



**Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests**

Customer	Study Number	Reservation	Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements	<sup>1</sup> Letter of Credit Amount Required	<sup>2</sup> Potential Base Plan Engineering and Construction Funding Allowable	<sup>3</sup> Additional Engineering and Construction Cost for 3rd Party Upgrades	<sup>20</sup> Total Revenue Requirements for Assigned Upgrades over term of reservation without potential base plan funding allocation	<sup>20</sup> Total Revenue Requirements for Assigned Upgrades over term of reservation WITH potential base plan funding allocation	Point-to-Point Base Rate over reservation period	<sup>4</sup> Total Cost of Reservation Assignable to Customer contingent upon base plan funding
MIDW	AG2-2006-099	1091035	\$ 239,510	\$ 239,510			\$ 1,234,404	\$ 1,234,404		\$ 1,234,404
MIDW	AG2-2006-099	1091036	\$ 227,986	\$ 227,986			\$ 1,293,324	\$ 1,293,324		\$ 1,293,324
MIDW	AG2-2006-099	1091041	\$ 479,292	\$ 479,292			\$ 2,470,195	\$ 2,470,195		\$ 2,470,195
MIDW	AG2-2006-098	1091043	\$ 71,575	\$ 71,575			\$ 369,840	\$ 369,840		\$ 369,840
MIDW	AG2-2006-098	1091044	\$ 143,176	\$ 143,176			\$ 739,756	\$ 739,756		\$ 739,756
MIDW	AG2-2006-098	1091045	\$ 99,635	\$ 99,635			\$ 608,394	\$ 608,394		\$ 608,394
MIDW	AG2-2006-108	1091052	\$ 594,408	\$ 594,408			\$ 1,563,264	\$ 1,563,264		\$ 1,563,264
MIDW	AG2-2006-108	1091053	\$ 1,188,854	\$ 1,188,854			\$ 3,126,645	\$ 3,126,645		\$ 3,126,645
MIDW	AG2-2006-108	1091055	\$ 1,783,304	\$ 1,783,304			\$ 4,690,033	\$ 4,690,033		\$ 4,690,033
MIDW	AG2-2006-108	1091057	\$ 594,408	\$ 594,408			\$ 1,826,293	\$ 1,826,293		\$ 1,826,293
MIDW	AG2-2006-096	1091066	\$ 1,067,316	\$ 1,067,316			\$ 2,331,985	\$ 2,331,985		\$ 2,331,985
MIDW	AG2-2006-110	1091068	\$ 482,954	\$ 482,954			\$ 1,633,011	\$ 1,633,011		\$ 1,633,011
OGE	AG2-2006-035	1087908	\$ 5,760,802	\$ 20,188		\$ 1,075,000	\$ 10,334,754	\$ 10,334,754	\$ 540,000	\$ 11,409,754
PNMM	AG2-2006-089	1090813	\$ 23,183,421	\$ 23,187,694			\$ 112,564,311	\$ 112,564,311	\$ 39,177,000	\$ 112,564,311
PNMM	AG2-2006-089	1090814	\$ 23,183,421	\$ 23,187,694			\$ 112,564,311	\$ 112,564,311	\$ 39,177,000	\$ 112,564,311
SEPC	AG2-2006-043	1090236	\$ 16,093,154	\$ 14,760,402			\$ 91,652,453	\$ 91,652,453	\$ 52,812,000	\$ 91,652,453
SHDY	AG2-2006-019	1085305	\$ 21,608,260	\$ 21,608,260			\$ 42,785,449	\$ 42,785,449	\$ 4,032,000	\$ 42,492,550
SPSM	AG2-2006-072	1090680	\$ 13,536,837	\$ 2,101,500			\$ 31,793,260	\$ 31,793,260	\$ 2,357,875	\$ 31,793,260
SPSM	AG2-2006-073	1090695	\$ 8,286,109	\$ 1,271,149			\$ 19,757,289	\$ 19,757,289	\$ 3,134,160	\$ 19,757,289
SPSM	AG2-2006-074	1090699	\$ 1,612,790	\$ 1,203,278			\$ 3,497,710	\$ 3,497,710	\$ 528,000	\$ 3,497,710
SPSM	AG2-2006-124	1090705	\$ 1,612,790	\$ 1,203,278			\$ 3,497,710	\$ 3,497,710	\$ 528,000	\$ 3,497,710
UCU	AG2-2006-006	1052923	\$ 3,440,181	\$ 2,373,070	\$ 3,440,181		\$ 12,494,574	\$ -	\$ 61,862,400	\$ 65,302,581
UCU	AG2-2006-071	1090573	\$ 1,395,513	\$ 706,920			\$ 5,972,051	\$ 5,972,051	\$ 57,996,000	\$ 57,996,000
UCU	AG2-2006-071	1090578	\$ 743,070	\$ 398,774			\$ 3,230,030	\$ 3,230,030	\$ 28,998,000	\$ 28,998,000
WRGS	AG2-2006-015	1076157	\$ 345,910	\$ 354,974			\$ 850,640	\$ 850,640	\$ 1,620,000	\$ 1,620,000
WRGS	AG2-2006-016	1076158	\$ 230,607	\$ 236,650			\$ 567,094	\$ 567,094	\$ 1,080,000	\$ 1,080,000
WRGS	AG2-2006-030	1086655	\$ 40,086,975	\$ 23,621,441	\$ 40,086,975		\$ 155,614,795	\$ 0		Sch 9 charges
WRGS	AG2-2006-030	1086656	\$ 13,362,344	\$ 7,873,799	\$ 13,362,344		\$ 51,871,748	\$ (0)		Sch 9 charges
<b>Totals</b>			<b>\$ 524,863,446</b>		<b>\$ 197,355,912</b>	<b>\$ 5,355,000</b>	<b>\$ 2,039,034,622</b>	<b>\$ 1,286,995,523</b>		

- Note 1:** Letter of Credit required for financial security for transmission owner for network upgrades is determined by allocated engineering and construction costs less engineering and construction costs for upgrades when network customer is the transmission
- Note 2:** If potential base plan funding is applicable, this value is the lesser of the Engineering and Construction costs of assignable upgrades or the value of base plan funding calculated pursuant to Attachment J, Section III B criteria. Allocation of base plan
- Note 3:** Additional Engineering and Construction costs assignable to customer based on 3rd party upgrades.
- Note 4:** For PTP requests, total cost is based on the higher of the base rate or assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirement. Allocation of base plan funding will be
- Note 5:** KMEA Additional 15 MW potential base plan funding for year 2007.
- Note 6:** KPP Potential base plan funding is based on assumption that 1032991 from 2006-AG1 will be confirmed. If confirmed, then 7MW additional beyond the 85MW previously allocated is available for base funding in 2008.
- Note 7:** KPP has 236MW of 250MW resources forecast eligible for potential base base plan funding for year 2007.
- Note 8:** Midwest has a load estimate of 336MW for the combined M and W system for 2011. Thus total Base plan funding available for 2011 is capped at 420MW of Total resources.
- Note 9:** Kaw Valley has a load estimate of 39MW for 2010. Thus 10MW is the cap for additional resources eligible for base plan funding up to a total of 49MW. This equates to \$1,800,000 of potential base funding for a new or changed designated resource.
- Note 10:** Kaw Valley has a load estimate of 38MW for 2008. Thus 9MW is the cap for additional resources eligible for base plan funding up to a total of 47MW. This equates to \$1,620,000 of potential base funding for a new or changed designated resource.
- Note 11:** Total Base plan funding available for 2008 to serve combined M and W system Midwest load based on 333MW of load is up to 416 MW of resources or 102 Additional MW more than forecast. This equates to \$18,360,000 potential base plan funding for the full 102
- Note 12:** Midwest has a load estimate of 335MW for the combined M and W system for 2010. Thus total Base plan funding available for 2010 is capped at 419MW of Total resources.
- Note 13:** NMEC has a load estimate of 12MW for 2010. Thus 3MW is the cap for additional resources eligible for base plan funding up to a total of 15MW. This equates to \$540,000 of potential base funding for a new or changed designated resource.
- Note 14:** NMEC has a load estimate of 12MW for 2008. Thus 3MW is the cap for additional resources eligible for base plan funding up to a total of 15MW. This equates to \$540,000 of potential base funding for a new or changed designated resource.
- Note 15:** Doniphan has a load estimate of 5MW for 2010. Thus 1MW is the cap for additional resources eligible for base plan funding up to a total of 6MW of resources. This equates to \$180,000 of potential base funding for a new or changed designated resource.
- Note 16:** Doniphan has a load estimate of 5MW for 2008. Thus 1MW is the cap for additional resources eligible for base plan funding up to a total of 6MW of resources. This equates to \$180,000 of potential base funding for a new or changed designated resource.
- Note 17:** Midwest has a load estimate of 343MW for the combined M and W system for 2015. Thus total Base plan funding available for 2015 is capped at 429MW of Total resources.
- Note 18:** Midwest has up to 425MW of resources allowable for base funding for year 2007 based on 332MW load.
- Note 19:** UCU has up to 161MW of resources in 2010 allowable for base funding for year 2010.
- Note 20:** Revenue Requirements are based upon deferred end dates as applicable without redispatch. If a restudy is required, deferred terms with redispatch will be utilized if that option is selected by the Customer.
- Note 21:** Revenue Requirements include expediting of Coffeyville Tap - North Bartlesville and Bartlesville Southeast - North Bartlesville to 6/1/2011 EOC

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
 AECC AG2-2006-017

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AECC	1079577	CSWS	EES	25	1/1/2007	1/1/2009	6/1/2009	6/1/2011			\$ 3,706,760	\$ 6,235,589
									\$ -	\$ -	\$ 3,706,760	\$ 6,235,589

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1079577	5 TRIBES - PECAN CREEK 161KV CKT 1	6/1/2008	6/1/2009		No	\$ 408,191	\$ 1,200,000	\$ 642,513
	BROKEN BOW - CRAIG JUNCTION 138KV CKT 1	10/1/2006	6/1/2008		Yes	\$ 747,374	\$ 4,000,000	\$ 1,577,365
	PECAN CREEK (PECANCK1) 345/161/13.8KV TRANSFORMER CKT 1	6/1/2008	6/1/2009		No	\$ 2,551,195	\$ 7,500,000	\$ 4,015,711
Total						\$ 3,706,760	\$ 12,700,000	\$ 6,235,589

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1079577	IAEPW PLANNED UPGRADE FOR NW ARKANSAS	12/1/2006	6/1/2009		No

Third Party Limitations

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost
1079577	COUCH SES - MC NIEL 115KV CKT 1	12/1/2006	12/1/2006				
Total							

**Customer Study Number**  
 AECC AG2-2006-039

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AECC	1089945	WR	CSWS	50	12/1/2007	12/1/2027	6/1/2009	6/1/2029			\$ 3,887,090	\$ 12,778,376
									\$ -	\$ -	\$ 3,887,090	\$ 12,778,376

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1089945	BANN - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2011	6/1/2011			\$ 3,783	\$ 20,000	\$ -
	BROKEN BOW - CRAIG JUNCTION 138KV CKT 1	10/1/2006	6/1/2008		Yes	\$ 1,358,029	\$ 4,000,000	\$ 5,393,087
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1	6/1/2012	6/1/2012			\$ 2,033,568	\$ 2,244,000	\$ 5,509,257
	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER	6/1/2007	3/1/2008	10/1/2007	No	\$ 481,710	\$ 4,000,000	\$ 1,876,032
	SUB 389 - JOPLIN SOUTHWEST - SUB 422 - JOPLIN 24TH & CONNECTICUT 161KV CKT 1	6/1/2008	6/1/2008			\$ 10,000	\$ 10,000	\$ -
Total						\$ 3,887,090	\$ 10,274,000	\$ 12,778,376

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1089945	IAEPW PLANNED UPGRADE FOR NW ARKANSAS	12/1/2006	6/1/2009		No
	ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	No
	BONANZA - BONANZA TAP 161KV CKT 1	6/1/2013	6/1/2013		
	Siloam Springs - South Fayetteville 161 kV	6/1/2015	6/1/2015		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1089945	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		

Third Party Limitations

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost
1087908	HUBEN (HUBEN) 345/161/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016				
Total							

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
 AECC AG2-2006-064

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
AECC	1090457	WR	EES	50	12/1/2007	12/1/2027					\$ 482,089	\$ 1,683,746	
										\$ -	\$ -	\$ 482,089	\$ 1,683,746

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090457	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER	6/1/2007	3/1/2008	10/1/2007	No	\$ 482,089	\$ 4,000,000	\$ 1,683,746	
						Total	\$ 482,089	\$ 4,000,000	\$ 1,683,746

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090457	GRANDVIEW EAST - MARTIN CITY 161KV CKT 1	12/1/2011	12/1/2011		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090457	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		

**Customer Study Number**  
 AEPM AG2-2006-024

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
AEPM	1086238	WFEC	CSWS	16	7/1/2007	7/1/2027	6/1/2010	6/1/2030			\$ 800,674	\$ 3,069,114	
										\$ -	\$ -	\$ 800,674	\$ 3,069,114

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1086238	BANN - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2011	6/1/2011			\$ 1,419	\$ 20,000	\$ -	
	SOUTHWEST SHREVEPORT - SOUTHWEST SHREVEPORT TAP 138KV CKT 1	6/1/2011	6/1/2011			\$ 44,327	\$ 1,300,000	\$ 140,713	
	SW SHREVEPORT EXPANSION	6/1/2008	6/1/2010		Yes	\$ 754,928	\$ 40,000,000	\$ 2,928,401	
						Total	\$ 800,674	\$ 41,320,000	\$ 3,069,114

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1086238	ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	Yes
	GLASS MOUNTAIN - MOORELAND 138KV CKT 1	6/1/2008	6/1/2008		
	LINWOOD - MCWILLIE STREET 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	Yes
	WOODWARD - WOODWARD 69KV CKT 1	6/1/2007	1/1/2008		Yes

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1086238	FPL SWITCH - MOORELAND 138KV CKT 1 OKGE	6/1/2006	4/1/2008		Yes
	FPL SWITCH - MOORELAND 138KV CKT 1 WFEC	6/1/2006	4/1/2008		Yes
	FT SUPPLY 138/69KV TRANSFORMER CKT 1	12/1/2006	6/1/2008		Yes
	HAMON BUTLER - MOREWOOD 69KV CKT 1	6/1/2006	4/1/2008		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1086238	FPL SWITCH - MOORELAND 138KV CKT 1 OKGE	12/1/2007	4/1/2008		Yes
	FPL SWITCH - MOORELAND 138KV CKT 1 WFEC	12/1/2007	4/1/2008		Yes
	FT SUPPLY 138/69KV TRANSFORMER CKT 1	6/1/2007	6/1/2008		Yes
	HAMON BUTLER - MOREWOOD 69KV CKT 1	6/1/2007	4/1/2008		Yes

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
 AEPM AG2-2006-033

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
AEPM	1087745	EES	CSWS	225	1/1/2007	1/1/2010	6/1/2010	6/1/2013			\$ 10,363,205	\$ 21,932,913	
										\$ -	\$ -	\$ 10,363,205	\$ 21,932,913

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1087745	SOUTHWEST SHREVEPORT - SOUTHWEST SHREVEPORT TAP 138KV CKT 1	6/1/2011	6/1/2011			\$ 770,492	\$ 1,300,000	\$ 1,352,750
	SW SHREVEPORT EXPANSION	6/1/2008	6/1/2010		Yes	\$ 9,592,713	\$ 40,000,000	\$ 20,580,164
Total						\$ 10,363,205	\$ 41,300,000	\$ 21,932,913

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1087745	LINWOOD - MCWILLIE STREET 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	Yes

Third Party Limitations

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost
1087745	AMELIA BULK - HELBIG BULK 230KV CKT 1	6/1/2016	6/1/2016				
	COUCH SES - MC NIEL 115KV CKT 1	12/1/2006	12/1/2006				
	Entergy Project (Reduce Load MVAR)	6/1/2016	6/1/2016				
	HARTBURG - INLAND-ORANGE 230KV CKT 1	4/1/2007	4/1/2007				
	HELBIG BULK - MCLEWIS 230KV CKT 1	4/1/2007	4/1/2007				
	INLAND-ORANGE - MCLEWIS 230KV CKT 1	4/1/2007	4/1/2007				
Total							

**Customer Study Number**  
 AEPM AG2-2006-034

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
AEPM	1087757	CSWS	CSWS	172	6/1/2008	6/1/2028	6/1/2010	6/1/2030			\$ 8,544,078	\$ 32,743,607	
										\$ -	\$ -	\$ 8,544,078	\$ 32,743,607

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1087757	BANN - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2011	6/1/2011			\$ 14,799	\$ 20,000	\$ -
	SOUTHWEST SHREVEPORT - SOUTHWEST SHREVEPORT TAP 138KV CKT 1	6/1/2011	6/1/2011			\$ 485,181	\$ 1,300,000	\$ 1,540,177
	SW SHREVEPORT EXPANSION	6/1/2008	6/1/2010		Yes	\$ 8,044,098	\$ 40,000,000	\$ 31,203,430
Total						\$ 8,544,078	\$ 41,320,000	\$ 32,743,607

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1087757	AEPW PLANNED UPGRADE FOR NW ARKANSAS	12/1/2006	6/1/2009		No
	ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	No
	LINWOOD - MCWILLIE STREET 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	No
	Siloam Springs - South Fayetteville 161 kV	6/1/2015	6/1/2015		

**Customer Study Number**  
 APM AG2-2006-031

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
APM	1087085	AECI	OKGE	3	12/1/2006	12/1/2007	6/1/2010	6/1/2011			\$ 17,399	\$ 36,512	
										\$ -	\$ -	\$ 17,399	\$ 36,512

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1087085	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 76	\$ 1,515,113	\$ 160
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 4,997	\$ 14,795,676	\$ 10,417
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 12,149	\$ 38,504,390	\$ 25,562
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 177	\$ 3,200,000	\$ 372
Total						\$ 17,399	\$ 58,015,179	\$ 36,512

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
CALP AG2-2006-004

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
CALP	1040980	NPPD	ERCOTE	50	1/1/2007	1/1/2008	6/1/2010	6/1/2011			\$ 340,542	\$ 714,581	
										\$ -	\$ -	\$ 340,542	\$ 714,581

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1040980	Hitchland 345 and 115 KV Interchange	4/1/2007	6/1/2010		No	\$ 100,163	\$ 14,795,676	\$ 208,810	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 240,379	\$ 38,504,390	\$ 505,771	
						Total	\$ 340,542	\$ 53,300,066	\$ 714,581

**Third Party Limitations**

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost
1040980	4TAMINA 138 - KINDER MORGAN PIPE 138KV CKT 1	6/1/2007	6/1/2007				
	4TAMINA 138 - TAMINA 138KV CKT 1	6/1/2007	6/1/2007				
	CHINA - SABINE 230KV CKT 1	6/1/2009	6/1/2009				
	CONROE BULK - PLANTATION 138KV CKT 1	6/1/2008	6/1/2008				
	COUCH SES - MC NIEL 115KV CKT 1	12/1/2006	12/1/2006				
	HARTBURG - INLAND-ORANGE 230KV CKT 1	4/1/2007	4/1/2007				
	HELBIG BULK - MCLEWIS 230KV CKT 1	4/1/2007	4/1/2007				
	INLAND-ORANGE - MCLEWIS 230KV CKT 1	4/1/2007	4/1/2007				
	KINDER MORGAN PIPE - PLANTATION 138KV CKT 1	6/1/2007	6/1/2007				
						Total	

**Customer Study Number**  
EDE AG2-2006-018

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
EDE	1080018	EES	EDE	50	6/1/2010	6/1/2040					\$ 10,952,665	\$ 36,273,200	
										\$ -	\$ -	\$ 10,952,665	\$ 36,273,200

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1080018	SUB 110 - ORONOJO JCT. (ORONOJO) 161/69/12.5KV TRANSFORMER CKT 1	6/1/2015	6/1/2015			\$ 5,000,000	\$ 5,000,000	\$ 17,255,427	
	SUB 145 - JOPLIN WEST 7TH - SUB 439 - STATELINE 161KV CKT 1	6/1/2016	6/1/2016			\$ 5,897,665	\$ 6,920,000	\$ 19,017,773	
	SUB 145 - JOPLIN WEST 7TH - SUB 64 - JOPLIN 10TH ST 69KV CKT 1	6/1/2013	6/1/2013			\$ 55,000	\$ 55,000	-	
						Total	\$ 10,952,665	\$ 11,975,000	\$ 36,273,200

**Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.**

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1080018	BULL SHOALS - BULL SHOALS 161KV CKT 1	6/1/2009	6/1/2009		
	JAMESVILLE - SUB 415 - BLACKHAWK JCT 69KV CKT 1	6/1/2011	6/1/2011		
	SUB 124 - AURORA HT - SUB 152 - MONETT HT 69KV CKT 1	6/1/2011	6/1/2011		
	SUB 167 - RIVERTON - SUB 406 - RIVERTON SOUTH 69KV CKT 1	6/1/2016	6/1/2016		

**Third Party Limitations**

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost
1080018	HUBEN (HUBEN) 345/161/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016				
						Total	

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
GSEC AG2-2006-054

Customer	Reservation	POB	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090270	CSWS	CSWS	10	10/1/2006	10/1/2036	6/1/2011	6/1/2041			\$ 6,853,492	\$ 24,350,003	
										\$ -	\$ -	\$ 6,853,492	\$ 24,350,003

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090270	ALTUS JCT TAP - RUSSELL 138KV CKT 1	6/1/2011	6/1/2011			\$ 664,691	\$ 3,125,000	\$ 2,126,574
	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 63,455	\$ 6,000,000	\$ 226,503
	CANADIAN - CEDAR LANE 138KV CKT 1	6/1/2014	6/1/2014			\$ 7,201	\$ 50,000	\$ -
	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 28,239	\$ 2,500,000	\$ 168,430
	CLINTON CITY - THOMAS TAP 69KV CKT 1	6/1/2015	6/1/2015			\$ 2,922,872	\$ 7,000,000	\$ 10,900,915
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 20,497	\$ 2,500,000	\$ 113,513
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 4,099	\$ 500,000	\$ 22,708
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 97,297	\$ 9,200,000	\$ 347,302
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 2,274	\$ 1,515,113	\$ 13,198
	ELDORADO - ELDORADO JCT 69KV CKT 1	6/1/2015	6/1/2015			\$ 1,007,934	\$ 2,600,000	\$ 2,793,477
	ELDORADO - LAKE PAULINE 69KV CKT 1	6/1/2015	6/1/2015			\$ 38,787	\$ 100,000	\$ -
	ELDORADO JCT - GYPSUM 69KV CKT 1	6/1/2015	6/1/2015			\$ 697,800	\$ 1,800,000	\$ 1,933,944
	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	6/1/2016	6/1/2016			\$ 3,388	\$ 100,000	\$ -
	GSEC Midway Interconnection #1	10/1/2006	10/1/2006			\$ 70,000	\$ 70,000	\$ -
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 70,989	\$ 14,795,676	\$ 408,220
	HOBART JUNCTION - TAMARAC TAP 138KV CKT 1	6/1/2012	6/1/2012			\$ 37,753	\$ 100,000	\$ -
	LAKE PAULINE - RUSSELL 138KV CKT 1	6/1/2016	6/1/2016			\$ 17,778	\$ 50,000	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 464,750	\$ 94,396,814	\$ 2,113,191
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 12,308	\$ 2,500,000	\$ 40,405
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 27,993	\$ 5,000,000	\$ 91,895
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 4,347	\$ 3,200,000	\$ 25,229
	Speerville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 30,791	\$ 31,000,000	\$ 143,023
	Speerville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 20,858	\$ 21,000,000	\$ 68,472
	THOMAS TAP - WEATHERFORD 69KV CKT 1	6/1/2011	6/1/2011			\$ 207,925	\$ 450,000	\$ 1,002,440
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 116,525	\$ 24,875,000	\$ 529,832
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 44,390	\$ 10,318,679	\$ 201,839
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 168,571	\$ 42,000,000	\$ 1,078,893
Total						\$ 6,853,492	\$ 286,746,282	\$ 24,350,003

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090270	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	ELK CITY - ELK CITY 69KV CKT 1 AEPW	12/1/2011	12/1/2011		
	GYPSUM - RUSSELL 69KV CKT 1	6/1/2015	6/1/2015		
	SNYDER AEPW- SNYDER WFEC INTERCONNECTION	6/1/2015	6/1/2015		
	Stateline Project	6/1/2014	6/1/2014		
	WEATHERFORD SOUTHEAST (WITH SE) 138/69/13.8KV TRANSFORMER CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090270	HAMON BUTLER - MOREWOOD 69KV CKT 1	6/1/2006	4/1/2008		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090270	HAMON BUTLER - MOREWOOD 69KV CKT 1	6/1/2007	4/1/2008		Yes
1090270	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
GSEC AG2-2006-056

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090288	SECI	SPS	400	6/1/2011	6/1/2041					\$ 107,219,996	\$ 503,397,656	
										\$ -	\$ -	\$ 107,219,996	\$ 503,397,656

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090288	ALTUS JCT TAP - RUSSELL 138KV CKT 1	6/1/2011	6/1/2011			\$ 847,036	\$ 3,125,000	\$ 2,709,958
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		No	\$ 770,363	\$ 1,515,113	\$ 4,471,069
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 33,068	\$ 153,114	\$ 252,030
	Hart Interchange 115/69 kV	6/1/2016	6/1/2016			\$ 1,607,463	\$ 3,500,000	\$ 5,433,357
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 6,581,966	\$ 14,795,676	\$ 37,849,345
	LEA COUNTY INTERCHANGE 230KV CAPACITORS	4/1/2008	4/1/2008			\$ 483,904	\$ 1,381,023	\$ 2,622,860
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 23,113	\$ 100,000	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 48,736,116	\$ 94,396,814	\$ 221,600,306
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,290,725	\$ 2,500,000	\$ 4,237,181
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 577,179	\$ 5,000,000	\$ 1,894,758
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 14,173,529	\$ 38,504,390	\$ 82,261,001
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 1,647,873	\$ 3,200,000	\$ 9,564,004
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 11,887,784	\$ 31,000,000	\$ 55,218,210
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 8,053,015	\$ 21,000,000	\$ 26,436,368
	Tex-Hitchland-Sherman Tap 115 kV ckt	4/1/2007	6/1/2010		No	\$ 4,478	\$ 2,401,645	\$ 25,751
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 4,461,195	\$ 24,875,000	\$ 20,284,796
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011		No	\$ 5,151,897	\$ 10,318,679	\$ 23,425,378
	YOAKUM COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2007	6/1/2008	10/1/2007	No	\$ 889,292	\$ 2,500,000	\$ 5,111,283
Total						\$ 107,219,996	\$ 260,266,454	\$ 503,397,656

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090288	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	COX INTERCHANGE - LH-COX3 115KV CKT 1	6/1/2016	6/1/2015		
	HALE CO INTERCHANGE - LH-COX3 115KV CKT 1	6/1/2016	6/1/2015		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	KRESS INTERCHANGE 115/69KV TRANSFORMERS	6/1/2007	6/1/2007		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No
	SNYDER AEPW- SNYDER WFEC INTERCONNECTION	6/1/2015	6/1/2015		
	Stateline Project	6/1/2014	6/1/2014		
	TUCO INTERCHANGE 115/69KV TRANSFORMER	6/1/2007	6/1/2007		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090288	TUCO INTERCHANGE 230KV #1	6/1/2007	6/1/2007		
	TUCO INTERCHANGE 230KV #2	6/1/2008	6/1/2008		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
GSEC AG2-2006-086

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090767	CSWS	CSWS	8	10/1/2006	10/1/2036	6/1/2010	6/1/2040			\$ 5,221,274	\$ 16,904,263	
										\$ -	\$ -	\$ 5,221,274	\$ 16,904,263

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090767	ALTUS JCT TAP - RUSSELL 138KV CKT 1	6/1/2011	6/1/2011			\$ 498,274	\$ 3,125,000	\$ 1,526,920	
	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 50,250	\$ 6,000,000	\$ 165,188	
	CANADIAN - CEDAR LANE 138KV CKT 1	6/1/2014	6/1/2014			\$ 5,986	\$ 50,000	\$ -	
	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 18,851	\$ 2,500,000	\$ 102,716	
	CLINTON CITY - THOMAS TAP 69KV CKT 1	6/1/2015	6/1/2015			\$ 2,333,333	\$ 7,000,000	\$ 8,014,281	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 13,611	\$ 2,500,000	\$ 69,419	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 2,722	\$ 500,000	\$ 14,024	
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 77,050	\$ 9,200,000	\$ 253,288	
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 1,518	\$ 1,515,113	\$ 8,130	
	ELDORADO - ELDORADO JCT 69KV CKT 1	6/1/2015	6/1/2015			\$ 866,365	\$ 2,600,000	\$ 2,299,859	
	ELDORADO - LAKE PAULINE 69KV CKT 1	6/1/2015	6/1/2015			\$ 33,322	\$ 100,000	\$ -	
	ELDORADO JCT - GYPSUM 69KV CKT 1	6/1/2015	6/1/2015			\$ 599,791	\$ 1,800,000	\$ 1,592,210	
	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	6/1/2016	6/1/2016			\$ 2,811	\$ 100,000	\$ -	
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 47,410	\$ 14,795,676	\$ 251,587	
	HOBART JUNCTION - TAMARAC TAP 138KV CKT 1	6/1/2012	6/1/2012			\$ 33,320	\$ 100,000	\$ -	
	LAKE PAULINE - RUSSELL 138KV CKT 1	6/1/2016	6/1/2016			\$ 15,283	\$ 50,000	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 308,964	\$ 94,396,814	\$ 1,296,409	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 8,183	\$ 2,500,000	\$ 25,730	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 18,013	\$ 5,000,000	\$ 56,639	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 2,905	\$ 3,200,000	\$ 15,559	
	Spearville - Mooreland 345 kV SLUNC	6/1/2011	6/1/2011			\$ 20,719	\$ 31,000,000	\$ 90,812	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 14,035	\$ 21,000,000	\$ 44,131	
	THOMAS TAP - WEATHERFORD 69KV CKT 1	6/1/2011	6/1/2011			\$ 141,017	\$ 450,000	\$ 626,120	
	Tuco - Talk 345KV	6/1/2011	6/1/2011			\$ 77,835	\$ 24,875,000	\$ 326,595	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 29,706	\$ 10,318,679	\$ 124,646	
						Total	\$ 5,221,274	\$ 244,676,282	\$ 16,904,263

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090767	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	ELK CITY - ELK CITY 69KV CKT 1 AEPW	12/1/2011	12/1/2011		
	GYPSUM - RUSSELL 69KV CKT 1	6/1/2015	6/1/2015		
	SNYDER AEPW- SNYDER WFEC INTERCONNECTION	6/1/2015	6/1/2015		
	Stateline Project	6/1/2014	6/1/2014		
	WEATHERFORD SOUTHEAST (WTH_SE) 138/69/13.8KV TRANSFORMER CKT 1	6/1/2007	1/1/2008	10/1/2007	No

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090767	HAMON BUTLER - MOREWOOD 69KV CKT 1	6/1/2006	4/1/2008		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090767	HAMON BUTLER - MOREWOOD 69KV CKT 1	6/1/2007	4/1/2008		Yes
1090767	IST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
GSEC AG2-2006-087

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
GSEC	1090789	CSWS	CSWS	6	10/1/2006	10/1/2036	6/1/2010	6/1/2040			\$ 4,022,248	\$ 12,864,840
									\$ -	\$ -	\$ 4,022,248	\$ 12,864,840

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090789	ALTUS JCT TAP - RUSSELL 138KV CKT 1	6/1/2011	6/1/2011			\$ 396,667	\$ 3,125,000	\$ 1,215,554
	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 37,045	\$ 6,000,000	\$ 121,779
	CANADIAN - CEDAR LANE 138KV CKT 1	6/1/2014	6/1/2014			\$ 4,777	\$ 50,000	\$ -
	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 12,730	\$ 2,500,000	\$ 69,363
	CLINTON CITY - THOMAS TAP 69KV CKT 1	6/1/2015	6/1/2015			\$ 1,743,794	\$ 7,000,000	\$ 5,989,396
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 9,592	\$ 2,500,000	\$ 48,921
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 1,918	\$ 500,000	\$ 9,882
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 56,802	\$ 9,200,000	\$ 186,726
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 1,017	\$ 1,515,113	\$ 5,447
	ELDORADO - ELDORADO JCT 69KV CKT 1	6/1/2015	6/1/2015			\$ 725,702	\$ 2,600,000	\$ 1,926,454
	ELDORADO - LAKE PAULINE 69KV CKT 1	6/1/2015	6/1/2015			\$ 27,912	\$ 100,000	\$ -
	ELDORADO JCT - GYPSUM 69KV CKT 1	6/1/2015	6/1/2015			\$ 502,409	\$ 1,800,000	\$ 1,333,699
	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	6/1/2016	6/1/2016			\$ 2,234	\$ 100,000	\$ -
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 31,914	\$ 14,795,676	\$ 169,355
	HOBART JUNCTION - TAMARAC TAP 138KV CKT 1	6/1/2012	6/1/2012			\$ 28,927	\$ 100,000	\$ -
	LAKE PAULINE - RUSSELL 138KV CKT 1	6/1/2016	6/1/2016			\$ 12,803	\$ 50,000	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 208,205	\$ 94,396,814	\$ 873,626
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 5,514	\$ 2,500,000	\$ 17,338
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 11,394	\$ 5,000,000	\$ 35,827
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 1,952	\$ 3,200,000	\$ 10,455
	Spearville - Mooreland 345 kV SLUNC	6/1/2011	6/1/2011			\$ 15,976	\$ 31,000,000	\$ 70,023
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 10,823	\$ 21,000,000	\$ 34,031
	THOMAS TAP - WEATHERFORD 69KV CKT 1	6/1/2011	6/1/2011			\$ 101,058	\$ 450,000	\$ 448,701
	Tuco - Talk 345KV	6/1/2011	6/1/2011			\$ 51,430	\$ 24,875,000	\$ 215,800
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 19,653	\$ 10,318,679	\$ 82,464
<b>Total</b>						\$ 4,022,248	\$ 244,676,282	\$ 12,864,840

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090789	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	ELK CITY - ELK CITY 69KV CKT 1 AEPW	12/1/2011	12/1/2011		
	GYPSUM - RUSSELL 69KV CKT 1	6/1/2015	6/1/2015		
	SNYDER AEPW- SNYDER WFEC INTERCONNECTION	6/1/2015	6/1/2015		
	Stateline Project	6/1/2014	6/1/2014		
	WEATHERFORD SOUTHEAST (WTH_SE) 138/69/13.8KV TRANSFORMER CKT 1	6/1/2007	1/1/2008	10/1/2007	No

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090789	HAMON BUTLER - MOREWOOD 69KV CKT 1	6/1/2006	4/1/2008		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090789	HAMON BUTLER - MOREWOOD 69KV CKT 1	6/1/2007	4/1/2008		Yes
1090789	IST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
GSEC AG2-2006-126

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090298	SPS	SPS	15	10/1/2007	10/1/2037					\$ 2,177,669	\$ 6,333,288	
										\$ -	\$ -	\$ 2,177,669	\$ 6,333,288

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090298	BAILEY COUNTY SUNNYSIDE Interconnection	10/1/2007	6/1/2006			\$ -	\$ -	\$ -
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		No	\$ 23,666	\$ 1,515,113	\$ 102,297
	Hart Interchange 115/69 kV	6/1/2016	6/1/2016			\$ 1,345,111	\$ 3,500,000	\$ 3,386,175
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 200,725	\$ 94,396,814	\$ 679,743
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 5,316	\$ 2,500,000	\$ 14,900
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 4,396	\$ 5,000,000	\$ 12,321
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 70,115	\$ 38,504,390	\$ 303,076
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 49,591	\$ 3,200,000	\$ 214,360
	SOUTH PLAINS WOLFFORTH Interconnection	3/1/2011	3/1/2011			\$ -	\$ -	\$ -
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 30,324	\$ 31,000,000	\$ 113,841
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 20,542	\$ 21,000,000	\$ 57,576
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 342,162	\$ 24,875,000	\$ 1,158,711
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 85,721	\$ 10,318,679	\$ 290,289
<b>Total</b>						<b>\$ 2,177,669</b>	<b>\$ 235,809,996</b>	<b>\$ 6,333,288</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090298	BC-EARTH INTERCHANGE 115KV	6/1/2013	6/1/2013		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No

**Customer** Study Number  
GSEC AG2-2006-127

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090301	SPS	SPS	20	3/1/2007	3/1/2037	6/1/2010	6/1/2040			\$ 13,500,200	\$ 57,492,506	
										\$ -	\$ -	\$ 13,500,200	\$ 57,492,506

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090301	Bailey County - Curry County 115 kV	6/1/2011	6/1/2011			\$ 10,648,185	\$ 10,648,185	\$ 43,464,105
	BAILEY COUNTY PROGRESS Interconnection #1	3/1/2007	3/1/2007			\$ -	\$ -	\$ -
	BAILEY COUNTY PROGRESS Interconnection #2	6/1/2011	6/1/2011			\$ -	\$ -	\$ -
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 351,962	\$ 1,515,113	\$ 1,885,066
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 304,034	\$ 94,396,814	\$ 1,275,723
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 8,052	\$ 2,500,000	\$ 25,318
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 5,958	\$ 5,000,000	\$ 18,734
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 725,939	\$ 38,504,390	\$ 3,888,042
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 735,111	\$ 3,200,000	\$ 3,937,166
	SOUTH PLAINS WOLFFORTH Interconnection	3/1/2011	3/1/2011			\$ -	\$ -	\$ -
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 50,983	\$ 31,000,000	\$ 223,460
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 34,537	\$ 21,000,000	\$ 108,596
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 510,845	\$ 24,875,000	\$ 2,143,500
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 124,594	\$ 10,318,679	\$ 522,795
<b>Total</b>						<b>\$ 13,500,200</b>	<b>\$ 242,958,181</b>	<b>\$ 57,492,506</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090301	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	MUSTANG STATION 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2008		No
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
 GSEC AG2-2006-128

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090310	SPS	SPS	20	7/1/2007	7/1/2037	6/1/2011	6/1/2041			\$ 7,124,975	\$ 35,415,681	
										\$ -	\$ -	\$ 7,124,975	\$ 35,415,681

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090310	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 479,580	\$ 2,500,000	\$ 2,860,431	
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 4,967	\$ 1,515,113	\$ 28,828	
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 734,079	\$ 14,795,676	\$ 4,221,293	
	MOORE COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2012	6/1/2012			\$ 672,224	\$ 6,837,000	\$ 2,803,321	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 1,887,448	\$ 94,396,814	\$ 8,582,117	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 49,987	\$ 2,500,000	\$ 164,097	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 15,668	\$ 5,000,000	\$ 51,435	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 9,759	\$ 3,200,000	\$ 56,640	
	SOUTH PLAINS WOLFFORTH Interconnection	3/1/2011	3/1/2011			\$ -	\$ -	\$ -	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 418,938	\$ 31,000,000	\$ 1,945,948	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 283,797	\$ 21,000,000	\$ 931,646	
	Tex-Hitchland-Sherman Tap 115 kV ckt	4/1/2007	6/1/2010		Yes	\$ 675,970	\$ 2,401,645	\$ 3,887,140	
	TRI COUNTY PRAIRIE Interconnection #1	7/1/2007	7/1/2007			\$ -	\$ -	\$ -	
	TRI COUNTY PRAIRIE Interconnection #2	7/1/2007	6/1/2008		No	\$ 687,484	\$ 1,500,000	\$ 3,895,699	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 755,771	\$ 24,875,000	\$ 3,436,447	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 175,366	\$ 10,318,679	\$ 797,379	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 273,937	\$ 42,000,000	\$ 1,753,260	
						<b>Total</b>	<b>\$ 7,124,975</b>	<b>\$ 263,839,927</b>	<b>\$ 35,415,681</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090310	BC-EARTH INTERCHANGE 115KV	6/1/2013	6/1/2013		
	BOOKER 69KV	6/1/2016	6/1/2016		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	Pringle - Etter 115 kV	6/1/2012	6/1/2012		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090310	HOLCOMB - PLYMELL - PIONEER TAP 115KV CKT 1	6/1/2007	6/1/2008		Yes
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
GSEC AG2-2006-129

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
GSEC	1090315	SPS	SPS	20	9/1/2007	9/1/2037	6/1/2010	6/1/2040			\$ 6,223,734	\$ 26,127,508
									\$ -	\$ -	\$ 6,223,734	\$ 26,127,508

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090315	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 64,451	\$ 2,500,000	\$ 351,182
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 7,802	\$ 1,515,113	\$ 41,787
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 899,900	\$ 14,795,676	\$ 4,775,423
	MOORE COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2012	6/1/2012			\$ 2,635,389	\$ 6,837,000	\$ 10,141,878
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 1,306,128	\$ 94,396,814	\$ 5,480,498
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 34,591	\$ 2,500,000	\$ 108,766
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 8,487	\$ 5,000,000	\$ 26,686
	RITA BLANCA RITA (Sherman) Interconnection	9/1/2007	9/1/2007			\$ -	\$ -	\$ -
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 15,325	\$ 3,200,000	\$ 82,079
	SOUTH PLAINS WOLFFORTH Interconnection	3/1/2011	3/1/2011			\$ -	\$ -	\$ -
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 252,673	\$ 31,000,000	\$ 1,107,474
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 171,166	\$ 21,000,000	\$ 538,206
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 680,094	\$ 24,875,000	\$ 2,853,666
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 147,728	\$ 10,318,679	\$ 619,865
Total						\$ 6,223,734	\$ 217,938,282	\$ 26,127,508

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090315	BC-EARTH INTERCHANGE 115KV	6/1/2013	6/1/2013		
	BOOKER 69KV	6/1/2016	6/1/2016		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	Pringle - Etter 115 kV	6/1/2012	6/1/2012		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No
	Stateline Project	6/1/2014	6/1/2014		

**Customer** Study Number  
GSEC AG2-2006-130

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
GSEC	1090320	SPS	SPS	25	3/1/2011	3/1/2041					\$ 1,834,993	\$ 8,542,156
									\$ -	\$ -	\$ 1,834,993	\$ 8,542,156

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090320	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		No	\$ 7,453	\$ 1,515,113	\$ 42,389
	Hart Interchange 115/69 kV	6/1/2016	6/1/2016			\$ 1,918	\$ 3,500,000	\$ 6,353
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 320,695	\$ 94,396,814	\$ 1,428,955
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 8,493	\$ 2,500,000	\$ 27,580
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 7,277	\$ 5,000,000	\$ 23,631
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 246,220	\$ 38,504,390	\$ 1,400,381
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 18,541	\$ 3,200,000	\$ 105,452
	SOUTH PLAINS WOLFFORTH Interconnection	3/1/2011	3/1/2011			\$ -	\$ -	\$ -
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 47,773	\$ 31,000,000	\$ 218,681
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 32,362	\$ 21,000,000	\$ 105,090
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 819,719	\$ 24,875,000	\$ 3,652,510
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 252,268	\$ 10,318,679	\$ 1,124,058
	YOAKUM COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2007	6/1/2008	10/1/2007	No	\$ 72,274	\$ 2,500,000	\$ 407,075
Total						\$ 1,834,993	\$ 238,309,996	\$ 8,542,156

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090320	BC-EARTH INTERCHANGE 115KV	6/1/2013	6/1/2013		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
GSEC AG2-2006-131

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090322	SPS	SPS	25	3/1/2009	3/1/2039					\$ 2,054,819	\$ 8,097,954	
										\$ -	\$ -	\$ 2,054,819	\$ 8,097,954

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090322	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		No	\$ 8,041	\$ 1,515,113	\$ 38,943	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 378,725	\$ 94,396,814	\$ 1,436,977	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 10,030	\$ 2,500,000	\$ 29,880	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 8,417	\$ 5,000,000	\$ 25,075	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 240,353	\$ 38,504,390	\$ 1,164,051	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 19,473	\$ 3,200,000	\$ 94,309	
	SOUTH PLAINS ALCOVE Interconnection	3/1/2009	3/1/2009			\$ -	\$ -	\$ -	
	SOUTH PLAINS WOLFFORTH Interconnection	3/1/2011	3/1/2011			\$ -	\$ -	\$ -	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 56,883	\$ 31,000,000	\$ 231,750	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 38,520	\$ 21,000,000	\$ 114,754	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 936,232	\$ 24,875,000	\$ 3,552,298	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 307,312	\$ 10,318,679	\$ 1,166,018	
	YOAKUM COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2007	6/1/2008	10/1/2007	No	\$ 50,853	\$ 2,500,000	\$ 243,898	
						<b>Total</b>	<b>\$ 2,054,819</b>	<b>\$ 234,809,996</b>	<b>\$ 8,097,954</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090322	BC-EARTH INTERCHANGE 115KV	6/1/2013	6/1/2013		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No

**Customer** Study Number  
GSEC AG2-2006-132

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090454	SPS	SPS	5	10/1/2006	10/1/2036	6/1/2010	6/1/2040			\$ 1,290,059	\$ 5,256,562	
										\$ -	\$ -	\$ 1,290,059	\$ 5,256,562

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090454	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 3,716	\$ 1,515,113	\$ 19,902	
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 73,142	\$ 14,795,676	\$ 388,136	
	MOORE COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2012	6/1/2012			\$ 613,728	\$ 6,837,000	\$ 2,361,835	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 286,013	\$ 94,396,814	\$ 1,200,107	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 7,575	\$ 2,500,000	\$ 23,818	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 5,854	\$ 5,000,000	\$ 18,407	
	RITA BLANCA Masterson (EXELL) Interconnection	10/1/2006	10/1/2006			\$ -	\$ -	\$ -	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 7,519	\$ 3,200,000	\$ 40,271	
	SOUTH PLAINS WOLFFORTH Interconnection	3/1/2011	3/1/2011			\$ -	\$ -	\$ -	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 44,336	\$ 31,000,000	\$ 194,326	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 30,034	\$ 21,000,000	\$ 94,437	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 179,301	\$ 24,875,000	\$ 752,345	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 38,841	\$ 10,318,679	\$ 162,976	
						<b>Total</b>	<b>\$ 1,290,059</b>	<b>\$ 215,438,282</b>	<b>\$ 5,256,562</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090454	BC-EARTH INTERCHANGE 115KV	6/1/2013	6/1/2013		
	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	MUSTANG STATION 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2008		No
	Pringle - Etter 115 kV	6/1/2012	6/1/2012		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No
	Stateline Project	6/1/2014	6/1/2014		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
GSEC AG2-2006-133

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090487	SPS	SPS	150	4/1/2007	4/1/2017	6/1/2010	6/1/2020			\$ 10,800,988	\$ 26,136,866	
										\$ -	\$ -	\$ 10,800,988	\$ 26,136,866

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090487	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 285,905	\$ 1,515,113	\$ 841,182
	Hart Interchange 115/69 kV	6/1/2016	6/1/2016			\$ 540,183	\$ 3,500,000	\$ 925,593
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 783,941	\$ 14,795,676	\$ 2,285,273
	MOORE COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2012	6/1/2012			\$ 2,302,674	\$ 6,837,000	\$ 4,867,918
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 1,667,795	\$ 94,396,814	\$ 3,844,272
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 44,170	\$ 2,500,000	\$ 95,921
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 27,649	\$ 5,000,000	\$ 60,043
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 556,728	\$ 3,200,000	\$ 1,637,989
	SOUTH PLAINS WOLFFORTH Interconnection	3/1/2011	3/1/2011			\$ -	\$ -	\$ -
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 276,386	\$ 31,000,000	\$ 756,100
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 187,229	\$ 21,000,000	\$ 406,591
	Tex-Hitchland-Sherman Tap 115 kV ckt	4/1/2007	6/1/2010		Yes	\$ 227,596	\$ 2,401,645	\$ 663,467
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 1,943,134	\$ 24,875,000	\$ 4,478,929
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 706,759	\$ 10,318,679	\$ 1,629,081
	YOAKUM COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2007	6/1/2008	10/1/2007	Yes	\$ 1,250,839	\$ 2,500,000	\$ 3,644,508
Total						\$ 10,800,988	\$ 223,839,927	\$ 26,136,866

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090487	BC-EARTH INTERCHANGE 115KV	6/1/2013	6/1/2013		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	KRESS INTERCHANGE 115/69KV TRANSFORMERS	6/1/2007	6/1/2007		
	MUSTANG STATION 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2008		Yes
	Pringle - Etter 115 kV	6/1/2012	6/1/2012		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		Yes
	TUCO INTERCHANGE 115/69KV TRANSFORMER	6/1/2007	6/1/2007		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090487	TERRY COUNTY INTERCHANGE 115/69KV TRANSFORMERS	6/1/2007	6/1/2007		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
GSEC AG2-2006-134

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090324	SPS	SPS	25	3/1/2013	3/1/2043					\$ 2,703,925	\$ 14,759,052	
										\$ -	\$ -	\$ 2,703,925	\$ 14,759,052

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090324	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		No	\$ 10,935	\$ 1,515,113	\$ 73,043	
	Hart Interchange 115/69 kV	6/1/2016	6/1/2016			\$ 2,663	\$ 3,500,000	\$ 10,360	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 370,338	\$ 94,396,814	\$ 1,938,030	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 9,808	\$ 2,500,000	\$ 34,719	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 8,443	\$ 5,000,000	\$ 29,887	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 340,580	\$ 38,504,390	\$ 2,274,982	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 27,391	\$ 3,200,000	\$ 182,964	
	SOUTH PLAINS MILWAUKEE and SLIDE Interconnection	3/1/2013	3/1/2013			\$ -	\$ -	\$ -	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 55,030	\$ 31,000,000	\$ 282,934	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 37,279	\$ 21,000,000	\$ 131,961	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 1,338,630	\$ 24,875,000	\$ 7,005,235	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 384,457	\$ 10,318,679	\$ 2,011,917	
	YOAKUM COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2007	6/1/2008	10/1/2007	No	\$ 118,371	\$ 2,500,000	\$ 783,021	
						Total	\$ 2,703,925	\$ 238,309,996	\$ 14,759,052

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090324	BC-EARTH INTERCHANGE 115KV	6/1/2013	6/1/2013		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No

**Customer** Study Number  
GSEC AG2-2006-135

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090328	SPS	SPS	25	3/1/2016	3/1/2046					\$ 2,703,925	\$ 18,735,153	
										\$ -	\$ -	\$ 2,703,925	\$ 18,735,153

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090328	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		No	\$ 10,935	\$ 1,515,113	\$ 92,967	
	Hart Interchange 115/69 kV	6/1/2016	6/1/2016			\$ 2,663	\$ 3,500,000	\$ 13,165	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 370,338	\$ 94,396,814	\$ 2,466,673	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 9,808	\$ 2,500,000	\$ 39,514	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 8,443	\$ 5,000,000	\$ 34,015	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 340,580	\$ 38,504,390	\$ 2,895,536	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 27,391	\$ 3,200,000	\$ 232,872	
	SOUTH PLAINS MILWAUKEE and SLIDE Interconnection	3/1/2013	3/1/2013			\$ -	\$ -	\$ -	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 55,030	\$ 31,000,000	\$ 336,801	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 37,279	\$ 21,000,000	\$ 150,188	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 1,338,630	\$ 24,875,000	\$ 8,916,078	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 384,457	\$ 10,318,679	\$ 2,560,714	
	YOAKUM COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2007	6/1/2008	10/1/2007	No	\$ 118,371	\$ 2,500,000	\$ 996,609	
						Total	\$ 2,703,925	\$ 238,309,996	\$ 18,735,153

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090328	BC-EARTH INTERCHANGE 115KV	6/1/2013	6/1/2013		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
GSEC AG2-2006-136

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
GSEC	1090456	SPS	SPS	15	7/1/2007	7/1/2037	6/1/2010	6/1/2040			\$ 4,007,543	\$ 18,122,564	
										\$ -	\$ -	\$ 4,007,543	\$ 18,122,564

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090456	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 98,611	\$ 2,500,000	\$ 537,313
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 3,112	\$ 1,515,113	\$ 16,668
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 745,661	\$ 14,795,676	\$ 3,956,936
	MOORE COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	6/1/2012	6/1/2012			\$ 612,985	\$ 6,837,000	\$ 2,358,976
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 971,549	\$ 94,396,814	\$ 4,076,608
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 25,730	\$ 2,500,000	\$ 80,904
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 4,896	\$ 5,000,000	\$ 15,395
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 5,944	\$ 3,200,000	\$ 31,835
	SOUTH PLAINS WOLFFORTH Interconnection	3/1/2011	3/1/2011			\$ -	\$ -	\$ -
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 205,200	\$ 31,000,000	\$ 899,398
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 139,006	\$ 21,000,000	\$ 437,083
	Tex-Hitchland-Sherman Tap 115 kV ckt	4/1/2007	6/1/2010		Yes	\$ 628,362	\$ 2,401,645	\$ 3,334,475
	TRI COUNTY HILLER Interconnection	7/1/2007	7/1/2007			\$ -	\$ -	\$ -
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 471,884	\$ 24,875,000	\$ 1,980,020
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 94,603	\$ 10,318,679	\$ 396,953
Total						\$ 4,007,543	\$ 220,339,927	\$ 18,122,564

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090456	BC-EARTH INTERCHANGE 115KV	6/1/2013	6/1/2013		
	BOOKER 69KV	6/1/2016	6/1/2016		
	Hart Interchange 230/115 kV	6/1/2011	6/1/2011		
	Pringle - Etter 115 kV	6/1/2012	6/1/2012		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090456	HOLCOMB - PLYMELL - PIONEER TAP 115KV CKT 1	6/1/2007	6/1/2008		Yes
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
 KBPU AG2-2006-041

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
KBPU	1089950	WR	KACY	25	10/1/2007	10/1/2027	6/1/2011	6/1/2028			\$ 1,961,714	\$ 7,480,706	
										\$ -	\$ -	\$ 1,961,714	\$ 7,480,706

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1089950	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 228	\$ 1,515,113	\$ 916
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 12,503	\$ 14,795,676	\$ 49,784
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 187,198	\$ 2,250,000	\$ 501,861
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	Yes	\$ 578,378	\$ 2,200,000	\$ 2,479,990
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 167,630	\$ 94,396,814	\$ 527,774
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 4,439	\$ 2,500,000	\$ 11,535
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 41,733	\$ 5,000,000	\$ 108,443
	PLATTE CITY - POPE 161 161KV CKT 1	12/1/2011	12/1/2011			\$ 6,025	\$ 100,000	\$ -
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 39,431	\$ 38,504,390	\$ 158,464
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 621	\$ 3,200,000	\$ 2,496
	SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2007	3/1/2008	10/1/2007	No	\$ 644,693	\$ 1,400,000	\$ 2,770,626
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 150,241	\$ 31,000,000	\$ 519,918
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 101,776	\$ 21,000,000	\$ 264,464
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 20,362	\$ 24,875,000	\$ 64,109
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 6,456	\$ 10,318,679	\$ 20,326
<b>Total</b>						<b>\$ 1,961,714</b>	<b>\$ 253,055,672</b>	<b>\$ 7,480,706</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1089950	95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1	6/1/2009	6/1/2009		
	BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1	8/1/2008	10/1/2008		Yes
	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2007	1/1/2008	10/1/2007	No
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1	12/1/2006	1/1/2009		Yes
	Stateline Project	6/1/2014	6/1/2014		
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1089950	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	KAW WEST 161/69KV TRANSFORMER CKT 1	6/1/2007	6/1/2008		No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
KBPU AG2-2006-042

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KBPU	1089952	SPA	KACY	39	7/1/2007	7/1/2017	1/1/2009	1/1/2018			\$ 3,016,651	\$ 7,074,526
									\$ -	\$ -	\$ 3,016,651	\$ 7,074,526

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1089952	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 317,661	\$ 6,000,000	\$ 487,502
	BROKEN BOW - CRAIG JUNCTION 138KV CKT 1	10/1/2006	6/1/2008		Yes	\$ 1,894,596	\$ 4,000,000	\$ 5,046,320
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 89,422	\$ 2,500,000	\$ 212,914
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 17,884	\$ 500,000	\$ 46,112
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 487,081	\$ 9,200,000	\$ 747,504
	IATAN - STRANGER CREEK 345KV CKT 2	6/1/2011	6/1/2011			\$ 210,007	\$ 4,123,803	\$ 534,174
<b>Total</b>						<b>\$ 3,016,651</b>	<b>\$ 26,323,803</b>	<b>\$ 7,074,526</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1089952	MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1	12/1/2006	1/1/2009		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1089952	KAW WEST 161/69KV TRANSFORMER CKT 1	6/1/2007	6/1/2008		No

**Customer Study Number**  
KCPS AG2-2006-090

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KCPS	1090801	KCPL	AECI	1	11/1/2006	6/1/2025					\$ -	\$ -
KCPS	1090802	KCPL	AECI	1	11/1/2006	6/1/2025					\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090801	None					\$ -	\$ -	\$ -
1090802	None					\$ -	\$ -	\$ -
<b>Total</b>						<b>\$ -</b>	<b>\$ -</b>	<b>\$ -</b>

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
 KCPS AG2-2006-091

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KCPS	1090773	KCPL	KACY	10	11/1/2006	6/1/2010	6/1/2008	6/1/2010	\$ -	\$ -	\$ -	\$ -
KCPS	1090782	KCPL	KACY	24	11/1/2006	6/1/2010	6/1/2008	6/1/2010	\$ -	\$ -	\$ -	\$ -
KCPS	1090787	KCPL	KACY	11	11/1/2006	6/1/2010	6/1/2008	6/1/2010	\$ -	\$ -	\$ -	\$ -
KCPS	1090815	KCPL	KACY	12	11/1/2006	6/1/2010	6/1/2008	6/1/2010	\$ -	\$ -	\$ -	\$ -
KCPS	1090818	KCPL	KACY	25	11/1/2006	6/1/2010	6/1/2008	6/1/2010	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090773	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -
1090782	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -
1090787	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -
1090815	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -
1090818	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090773	KAW WEST 161/69KV TRANSFORMER CKT 1		6/1/2007	6/1/2008	No
1090782	KAW WEST 161/69KV TRANSFORMER CKT 1		6/1/2007	6/1/2008	No
1090787	KAW WEST 161/69KV TRANSFORMER CKT 1		6/1/2007	6/1/2008	No
1090815	KAW WEST 161/69KV TRANSFORMER CKT 1		6/1/2007	6/1/2008	No
1090818	KAW WEST 161/69KV TRANSFORMER CKT 1		6/1/2007	6/1/2008	No

**Customer Study Number**  
 KEPC AG2-2006-067

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KEPC	1090416	KCPL	WR	30	6/1/2010	6/1/2030	6/1/2011	6/1/2031	\$ -	\$ -	\$ 2,440,462	\$ 9,893,858
									\$ -	\$ -	\$ 2,440,462	\$ 9,893,858

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090416	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 140,256	\$ 2,500,000	\$ 587,061
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 28,051	\$ 500,000	\$ 119,942
	CRESWELL - NEWKIRK 138KV CKT 1 OKGE	6/1/2012	6/1/2012			\$ 119,483	\$ 4,500,000	\$ 475,947
	CRESWELL - NEWKIRK 138KV CKT 1 WERE	6/1/2012	6/1/2012			\$ 125,856	\$ 4,740,000	\$ 423,819
	CRESWELL (CRESWL1X) 138/69/13.2KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 195,357	\$ 4,000,000	\$ 698,298
	CRESWELL (CRESWL2X) 138/69/13.2KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 134,380	\$ 4,000,000	\$ 480,338
	EEC - COWSKIN 138KV	6/1/2009	6/1/2009			\$ 1,148,619	\$ 10,000,000	\$ 4,613,799
	IATAN - STRANGER CREEK 345KV CKT 2	6/1/2011	6/1/2011			\$ 258,248	\$ 4,123,803	\$ 1,193,929
	PLATTE CITY - POPE 161 161KV CKT 1	12/1/2011	12/1/2011			\$ 7,931	\$ 100,000	\$ -
	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER	6/1/2007	3/1/2008	10/1/2007	No	\$ 214,326	\$ 4,000,000	\$ 965,040
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 67,955	\$ 42,000,000	\$ 335,686
Total						\$ 2,440,462	\$ 80,463,803	\$ 9,893,858

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090416	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090416	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
KEPC AG2-2006-105

Customer	Reservation	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KEPC	1090808	6	10/1/2006	10/1/2036	6/1/2011	6/1/2041			\$ 1,905,055	\$ 7,789,057
KEPC	1090825	5	10/1/2006	10/1/2026	6/1/2011	6/1/2031			\$ 528,494	\$ 1,944,987
							\$ -	\$ -	\$ 2,433,549	\$ 9,733,044

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090808	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1		6/1/2016	6/1/2016		\$ 144,235	\$ 6,000,000	\$ 514,847	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW		6/1/2009	6/1/2009		\$ 59,050	\$ 2,500,000	\$ 327,021	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE		6/1/2009	6/1/2009		\$ 11,810	\$ 500,000	\$ 65,427	
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1		6/1/2016	6/1/2016		\$ 221,160	\$ 9,200,000	\$ 789,430	
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2		4/1/2007	6/1/2010	Yes	\$ 44	\$ 1,515,113	\$ 255	
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1		6/1/2007	2/1/2008	10/1/2007	Yes	\$ 23,444	\$ 1,500,000	\$ 142,144
	Hitchland 345 and 115 kV Interchange		4/1/2007	6/1/2010	No	\$ 2,901	\$ 14,795,676	\$ 16,682	
	KEPCO Humbolt Interconnection		10/1/2006	10/1/2006		\$ -	\$ -	\$ -	
	LAWRENCE HILL - WREN 115KV CKT 1		6/1/2011	6/1/2011		\$ 218,652	\$ 1,200,000	\$ 1,066,244	
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1		6/1/2016	6/1/2016		\$ 224,319	\$ 2,250,000	\$ 848,439	
	Mooreland - TUCO 345 kV SPS		6/1/2011	6/1/2011		\$ 26,918	\$ 94,396,814	\$ 122,395	
	Mooreland - TUCO 345 kV WFEC		6/1/2011	6/1/2011		\$ 713	\$ 2,500,000	\$ 2,341	
	Mooreland 345/138 kV Transformer		6/1/2011	6/1/2011		\$ 6,820	\$ 5,000,000	\$ 22,389	
	PLATTE CITY - POPE 161 161KV CKT 1		12/1/2011	12/1/2011		\$ 581	\$ 100,000	\$ -	
	Potter - Roosevelt 345KV		4/1/2007	6/1/2010	No	\$ 8,125	\$ 38,504,390	\$ 47,156	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1		4/1/2007	6/1/2010	No	\$ 111	\$ 3,200,000	\$ 644	
	SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1		6/1/2007	3/1/2008	10/1/2007	Yes	\$ 168,970	\$ 1,400,000	\$ 1,024,489
	Spearville - Mooreland 345 kV SUNC		6/1/2011	6/1/2011		\$ 24,395	\$ 31,000,000	\$ 113,314	
	Spearville - Mooreland 345 kV WFEC		6/1/2011	6/1/2011		\$ 16,526	\$ 21,000,000	\$ 54,251	
	SUB 145 - JOPLIN WEST 7TH - SUB 439 - STATELINE 161KV CKT 1		6/1/2016	6/1/2016		\$ 740,688	\$ 6,920,000	\$ 2,605,159	
	Tuco - Talk 345KV		6/1/2011	6/1/2011		\$ 4,243	\$ 24,875,000	\$ 19,293	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1		6/1/2011	6/1/2011		\$ 1,350	\$ 10,318,679	\$ 6,138	
					Total	\$ 1,905,055	\$ 278,675,672	\$ 7,788,057	
1090825	CLAY CENTER - GREENLEAF 115KV CKT 1		6/1/2007	12/1/2007	No	\$ 873	\$ 7,520,000	\$ 4,450	
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1		6/1/2007	2/1/2008	10/1/2007	Yes	\$ 23,969	\$ 1,500,000	\$ 112,167
	KEPCO Louisville Interconnection		10/1/2006	10/1/2006		\$ -	\$ -	\$ -	
	LAWRENCE HILL - WREN 115KV CKT 1		6/1/2011	6/1/2011		\$ 209,549	\$ 1,200,000	\$ 788,687	
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1		6/1/2016	6/1/2016		\$ 190,927	\$ 2,250,000	\$ 557,363	
	Mooreland - TUCO 345 kV SPS		6/1/2011	6/1/2011		\$ 5,384	\$ 94,396,814	\$ 18,579	
	Mooreland - TUCO 345 kV WFEC		6/1/2011	6/1/2011		\$ 143	\$ 2,500,000	\$ 393	
	Mooreland 345/138 kV Transformer		6/1/2011	6/1/2011		\$ 1,488	\$ 5,000,000	\$ 4,090	
	Spearville - Mooreland 345 kV SUNC		6/1/2011	6/1/2011		\$ 5,126	\$ 31,000,000	\$ 19,059	
	Spearville - Mooreland 345 kV WFEC		6/1/2011	6/1/2011		\$ 3,472	\$ 21,000,000	\$ 9,543	
	Tuco - Talk 345KV		6/1/2011	6/1/2011		\$ 962	\$ 24,875,000	\$ 3,320	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1		6/1/2011	6/1/2011		\$ 306	\$ 10,318,679	\$ 1,056	
	WICHITA - RENO 345KV		10/1/2006	6/1/2011	Yes	\$ 86,295	\$ 42,000,000	\$ 426,282	
					Total	\$ 528,494	\$ 243,560,493	\$ 1,944,987	

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090808	95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1		6/1/2009	6/1/2009	
	BOOKER 69KV		6/1/2016	6/1/2016	
	CARTER JCT CAPACITOR		6/1/2011	6/1/2011	
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1		6/1/2010	6/1/2010	
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1		6/1/2010	6/1/2010	
	COUNTY LINE - HOOK JCT 115KV CKT 1		6/1/2011	6/1/2011	
	FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1		6/1/2007	1/1/2008	10/1/2007
	GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1		6/1/2007	1/1/2008	10/1/2007
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1		6/1/2011	6/1/2011	
	Stateline Project		6/1/2014	6/1/2014	
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1		10/1/2007	4/1/2008	12/1/2007
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1		6/1/2009	6/1/2009	
1090825	95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1		6/1/2009	6/1/2009	
	COUNTY LINE - HOOK JCT 115KV CKT 1		6/1/2011	6/1/2011	
	FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1		6/1/2007	1/1/2008	10/1/2007
	GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1		6/1/2007	1/1/2008	10/1/2007
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1		6/1/2011	6/1/2011	
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1		6/1/2009	6/1/2009	

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090808	IATAN - ST JOE 345KV CKT 1		6/1/2011	6/1/2011	
	ST JOHN CAPACITOR		6/1/2007	6/1/2008	10/1/2007
1090825	ST JOHN CAPACITOR		6/1/2007	6/1/2008	10/1/2007

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
KEPC AG2-2006-120

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
KEPC	1090745	SECI	WPEK	25	6/1/2010	6/1/2030					\$ 2,436,382	\$ 9,070,998	
										\$ -	\$ -	\$ 2,436,382	\$ 9,070,998

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090745	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 352,155	\$ 7,520,000	\$ 1,639,700
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		No	\$ 1,327	\$ 1,515,113	\$ 5,394
	EEC - COWSKIN 138KV	6/1/2009	6/1/2009			\$ 517,574	\$ 10,000,000	\$ 1,933,513
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 14,317	\$ 153,114	\$ 74,200
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 154,067	\$ 14,795,676	\$ 620,468
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 9,762	\$ 100,000	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 1,417	\$ 94,396,814	\$ 4,512
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 38	\$ 2,500,000	\$ 100
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 116,881	\$ 5,000,000	\$ 307,701
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 247,777	\$ 38,504,390	\$ 1,007,126
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 3,504	\$ 3,200,000	\$ 14,243
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 280,568	\$ 3,700,000	\$ 1,113,555
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 321,584	\$ 31,000,000	\$ 1,128,237
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 217,847	\$ 21,000,000	\$ 573,504
	Tex-Hitchland-Sherman Tap 115 kV ckt	4/1/2007	6/1/2010		No	\$ 23,285	\$ 2,401,645	\$ 93,775
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 131,978	\$ 24,875,000	\$ 420,269
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 42,301	\$ 10,318,679	\$ 134,703
<b>Total</b>						<b>\$ 2,436,382</b>	<b>\$ 270,980,431</b>	<b>\$ 9,070,998</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090745	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090745	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
KEPC AG2-2006-121

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
KEPC	1090754	SECI	WR	25	6/1/2010	6/1/2030					\$ 3,956,597	\$ 12,616,953	
										\$ -	\$ -	\$ 3,956,597	\$ 12,616,953

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090754	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 393,406	\$ 6,000,000	\$ 977,437	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 149,297	\$ 2,500,000	\$ 575,502	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 29,859	\$ 500,000	\$ 118,738	
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 603,222	\$ 9,200,000	\$ 1,498,736	
	CRESWELL - NEWKIRK 138KV CKT 1 OKGE	6/1/2012	6/1/2012			\$ 160,671	\$ 4,500,000	\$ 584,044	
	CRESWELL - NEWKIRK 138KV CKT 1 WERE	6/1/2012	6/1/2012			\$ 169,240	\$ 4,740,000	\$ 530,031	
	CRESWELL (CRESWL1X) 138/69/13.2KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 188,723	\$ 4,000,000	\$ 627,377	
	CRESWELL (CRESWL2X) 138/69/13.2KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 129,816	\$ 4,000,000	\$ 431,551	
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		No	\$ 1,681	\$ 1,515,113	\$ 6,833	
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 7,337	\$ 153,114	\$ 38,025	
	Hitchland 345 and 115 kv Interchange	4/1/2007	6/1/2010		No	\$ 154,182	\$ 14,795,676	\$ 620,931	
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 5,128	\$ 100,000	\$ -	
	Mooreland - TUCO 345 kv SPS	6/1/2011	6/1/2011			\$ 161,283	\$ 94,396,814	\$ 513,588	
	Mooreland - TUCO 345 kv WFEC	6/1/2011	6/1/2011			\$ 4,271	\$ 2,500,000	\$ 11,244	
	Mooreland 345/138 kv Transformer	6/1/2011	6/1/2011			\$ 175,038	\$ 5,000,000	\$ 460,805	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 313,816	\$ 38,504,390	\$ 1,275,551	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 4,414	\$ 3,200,000	\$ 17,941	
	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER	6/1/2007	3/1/2008	10/1/2007	No	\$ 117,337	\$ 4,000,000	\$ 491,357	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 100,918	\$ 3,700,000	\$ 400,536	
	Spearville - Mooreland 345 kv SUNC	6/1/2011	6/1/2011			\$ 515,754	\$ 31,000,000	\$ 1,809,459	
	Spearville - Mooreland 345 kv WFEC	6/1/2011	6/1/2011			\$ 349,382	\$ 21,000,000	\$ 919,783	
	Tex-Hitchland-Sherman Tap 115 kv ckt	4/1/2007	6/1/2010		No	\$ 1,323	\$ 2,401,645	\$ 5,328	
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 167,005	\$ 24,875,000	\$ 531,809	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 53,494	\$ 10,318,679	\$ 170,346	
						Total	\$ 3,956,597	\$ 292,900,431	\$ 12,616,953

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090754	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090754	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
 KEPC AG2-2006-122

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
KEPC	1090729	WR	KCPL	14	6/1/2007	6/1/2012	6/1/2010	6/1/2015			\$ 1,471,934	\$ 3,607,543	
										\$ -	\$ -	\$ 1,471,934	\$ 3,607,543

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090729	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 76	\$ 1,515,113	\$ 187
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 4,271	\$ 14,795,676	\$ 10,389
	LAWRENCE HILL - WREN 115KV CKT 1	6/1/2011	6/1/2011			\$ 592,236	\$ 1,200,000	\$ 1,303,898
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	Yes	\$ 181,581	\$ 2,200,000	\$ 495,938
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 48,679	\$ 94,396,814	\$ 93,631
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,289	\$ 2,500,000	\$ 2,528
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 11,577	\$ 5,000,000	\$ 22,702
	PLATTE CITY - POPE 161 161KV CKT 1	12/1/2011	12/1/2011			\$ 1,722	\$ 100,000	\$ -
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 12,928	\$ 38,504,390	\$ 31,740
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 200	\$ 3,200,000	\$ 491
	SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2007	3/1/2008	10/1/2007	Yes	\$ 537,822	\$ 1,400,000	\$ 1,472,251
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 42,156	\$ 31,000,000	\$ 100,786
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 28,557	\$ 21,000,000	\$ 55,999
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 6,709	\$ 24,875,000	\$ 12,904
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 2,131	\$ 10,318,679	\$ 4,099
<b>Total</b>						<b>\$ 1,471,934</b>	<b>\$ 252,005,672</b>	<b>\$ 3,607,543</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090729	95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1	6/1/2009	6/1/2009		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	Stateline Project	6/1/2014	6/1/2014		
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	Yes
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090729	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
KEPC AG2-2006-123

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
KEPC	1090823	WR	WR	5	6/1/2007	6/1/2027	6/1/2011	6/1/2031			\$ 572,747	\$ 2,235,675	
										\$ -	\$ -	\$ 572,747	\$ 2,235,675

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090823	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	Yes	\$ 18,450	\$ 1,500,000	\$ 86,340	
	KEPCO K-18 Interconnection	6/1/2007	6/1/2007			\$ -	\$ -	\$ -	
	KEPCO Louisville Interconnection	10/1/2006	10/1/2006			\$ -	\$ -	\$ -	
	LAWRENCE HILL - WREN 115KV CKT 1	6/1/2011	6/1/2011			\$ 179,563	\$ 1,200,000	\$ 675,828	
	LAWRENCE HILL (LAWHL29X) 230/115/113.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 160,891	\$ 2,250,000	\$ 469,680	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 8,047	\$ 94,396,814	\$ 27,768	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 213	\$ 2,500,000	\$ 585	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 2,146	\$ 5,000,000	\$ 5,898	
	SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2007	3/1/2008	10/1/2007	No	\$ 48,515	\$ 1,400,000	\$ 227,033	
	Spearsville - Mooreland 345 kV SLINC	6/1/2011	6/1/2011			\$ 7,485	\$ 31,000,000	\$ 27,829	
	Spearsville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 5,071	\$ 21,000,000	\$ 13,938	
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 1,270	\$ 24,875,000	\$ 4,382	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 401	\$ 10,318,679	\$ 1,384	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 140,695	\$ 42,000,000	\$ 695,009	
						<b>Total</b>	<b>\$ 572,747</b>	<b>\$ 237,440,493</b>	<b>\$ 2,235,675</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090823	95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1	6/1/2009	6/1/2009		
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090823	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Customer** Study Number  
KMEA AG2-2006-065

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
KMEA	1090401	GRDA	KCPL	1	5/1/2007	5/1/2026					\$ 186,088	\$ 356,011	
KMEA	1090528	GRDA	KCPL	1	5/1/2007	5/1/2026					\$ 186,088	\$ 356,011	
										\$ -	\$ -	\$ 372,176	\$ 712,023

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090401	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 17,466	\$ 6,000,000	\$ 32,638	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 4,357	\$ 2,500,000	\$ 12,632	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 871	\$ 500,000	\$ 2,692	
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 26,781	\$ 9,200,000	\$ 50,044	
	IATAN - STRANGER CREEK 345KV CKT 2	6/1/2011	6/1/2011			\$ -	\$ 4,123,803	\$ -	
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1	6/1/2012	6/1/2012			\$ 42,731	\$ 2,244,000	\$ 89,954	
	SUB 145 - JOPLIN WEST 7TH - SUB 439 - STATELINE 161KV CKT 1	6/1/2016	6/1/2016			\$ 93,882	\$ 6,920,000	\$ 168,051	
						<b>Total</b>	<b>\$ 186,088</b>	<b>\$ 31,487,803</b>	<b>\$ 356,011</b>
1090528	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 17,466	\$ 6,000,000	\$ 32,638	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 4,357	\$ 2,500,000	\$ 12,632	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 871	\$ 500,000	\$ 2,692	
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 26,781	\$ 9,200,000	\$ 50,044	
	IATAN - STRANGER CREEK 345KV CKT 2	6/1/2011	6/1/2011			\$ -	\$ 4,123,803	\$ -	
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1	6/1/2012	6/1/2012			\$ 42,731	\$ 2,244,000	\$ 89,954	
	SUB 145 - JOPLIN WEST 7TH - SUB 439 - STATELINE 161KV CKT 1	6/1/2016	6/1/2016			\$ 93,882	\$ 6,920,000	\$ 168,051	
						<b>Total</b>	<b>\$ 186,088</b>	<b>\$ 31,487,803</b>	<b>\$ 356,011</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090401	GRAY TAP - PENSACOLA 69KV CKT 1	6/1/2008	6/1/2008		
1090528	GRAY TAP - PENSACOLA 69KV CKT 1	6/1/2008	6/1/2008		



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
KMEA AG2-2006-081

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	1090662	WR	WR	16	10/1/2006	10/1/2016	6/1/2011	6/1/2021			\$ 2,151,909	\$ 6,912,173
									\$ -	\$ -	\$ 2,151,909	\$ 6,912,173

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090662	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 305	\$ 1,515,113	\$ 972
	EEC - COWSKIN 138KV	6/1/2009	6/1/2009			\$ 190,315	\$ 10,000,000	\$ 567,195
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		Yes	\$ 7,984	\$ 153,114	\$ 31,812
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 33,606	\$ 14,795,676	\$ 106,159
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 5,580	\$ 100,000	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 53,950	\$ 94,396,814	\$ 134,756
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,429	\$ 2,500,000	\$ 3,240
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 20,699	\$ 5,000,000	\$ 46,930
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 59,757	\$ 38,504,390	\$ 190,521
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 821	\$ 3,200,000	\$ 2,618
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 907,775	\$ 3,700,000	\$ 2,769,951
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 45,569	\$ 31,000,000	\$ 132,111
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 30,870	\$ 21,000,000	\$ 69,990
	Tex-Hitchland-Sherman Tap 115 kV ckt	4/1/2007	6/1/2010		No	\$ 3,623	\$ 2,401,645	\$ 11,445
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 32,153	\$ 24,875,000	\$ 80,312
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011		Yes	\$ 10,338	\$ 10,318,679	\$ 25,822
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 747,135	\$ 42,000,000	\$ 2,738,340
Total						\$ 2,151,909	\$ 305,460,431	\$ 6,912,173

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090662	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER_JCT CAPACITOR	6/1/2011	6/1/2011		
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090662	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
KMEA AG2-2006-082

Customer	Reservation	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	1090674	1	5/1/2007	5/1/2026	6/1/2011	6/1/2026			\$ 332,457	\$ 1,157,061
							\$ -	\$ -	\$ 332,457	\$ 1,157,061

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090674	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 14,191	\$ 6,000,000	\$ 32,685
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 3,567	\$ 2,500,000	\$ 12,746
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 713	\$ 500,000	\$ 2,640
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 21,760	\$ 9,200,000	\$ 50,118
	CRESWELL - NEWKIRK 138KV CKT 1 OKGE	6/1/2012	6/1/2012			\$ 4,230	\$ 4,500,000	\$ 14,212
	CRESWELL - NEWKIRK 138KV CKT 1 WERE	6/1/2012	6/1/2012			\$ 4,456	\$ 4,740,000	\$ 12,992
	EEC - COWSKIN 138KV	6/1/2009	6/1/2009			\$ 16,146	\$ 10,000,000	\$ 56,154
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		Yes	\$ 485	\$ 153,114	\$ 2,324
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1	6/1/2012	6/1/2012			\$ 41,120	\$ 2,244,000	\$ 113,943
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 339	\$ 100,000	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 15,471	\$ 94,396,814	\$ 45,706
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 410	\$ 2,500,000	\$ 1,025
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 4,126	\$ 5,000,000	\$ 10,319
	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER	6/1/2007	3/1/2008	10/1/2007	Yes	\$ 4,306	\$ 4,000,000	\$ 16,787
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 63,875	\$ 3,700,000	\$ 234,385
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 14,623	\$ 31,000,000	\$ 48,172
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 9,906	\$ 21,000,000	\$ 24,775
	SPS MUST RUN GENERATION #3	10/1/2007	10/1/2007			\$ -	\$ -	\$ -
	SPS MUST RUN GENERATION #4	6/1/2007	6/1/2007			\$ -	\$ -	\$ -
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 2,343	\$ 24,875,000	\$ 6,922
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 749	\$ 10,318,879	\$ 2,213
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 109,641	\$ 42,000,000	\$ 468,943
<b>Total</b>						<b>\$ 332,457</b>	<b>\$ 278,727,607</b>	<b>\$ 1,157,061</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090674	ANZIO - FORT JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	GRAY TAP - PENSACOLA 69KV CKT 1	6/1/2008	6/1/2008		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090674	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
KMEA AG2-2006-083

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	1090676	GRDA	WR	1	5/1/2010	5/1/2026	6/1/2011	6/1/2026	\$ -	\$ -	\$ 332,407	\$ 1,156,843
									\$ -	\$ -	\$ 332,407	\$ 1,156,843

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090676	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 14,191	\$ 6,000,000	\$ 32,685	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 3,567	\$ 2,500,000	\$ 12,746	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 713	\$ 500,000	\$ 2,640	
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 21,760	\$ 9,200,000	\$ 50,118	
	CRESWELL - NEWKIRK 138KV CKT 1 OKGE	6/1/2012	6/1/2012			\$ 4,230	\$ 4,500,000	\$ 14,212	
	CRESWELL - NEWKIRK 138KV CKT 1 WERE	6/1/2012	6/1/2012			\$ 4,456	\$ 4,740,000	\$ 12,992	
	EEC - COWSKIN 138KV	6/1/2009	6/1/2009			\$ 16,146	\$ 10,000,000	\$ 56,154	
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 519	\$ 153,114	\$ 2,487	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1	6/1/2012	6/1/2012			\$ 41,120	\$ 2,244,000	\$ 113,943	
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 363	\$ 100,000	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 15,471	\$ 94,396,814	\$ 45,706	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 410	\$ 2,500,000	\$ 1,025	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 4,126	\$ 5,000,000	\$ 10,319	
	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER	6/1/2007	3/1/2008	10/1/2007	No	\$ 4,373	\$ 4,000,000	\$ 17,048	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 63,700	\$ 3,700,000	\$ 233,743	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 14,623	\$ 31,000,000	\$ 48,172	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 9,906	\$ 21,000,000	\$ 24,775	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 2,343	\$ 24,875,000	\$ 6,922	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 749	\$ 10,318,679	\$ 2,213	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 109,641	\$ 42,000,000	\$ 468,943	
						<b>Total</b>	<b>\$ 332,407</b>	<b>\$ 278,727,607</b>	<b>\$ 1,156,843</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090676	GRAY TAP - PENSACOLA 69KV CKT 1	6/1/2008	6/1/2008		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090676	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Customer** Study Number  
KMEA AG2-2006-084

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	1090548	GRDA	KCPL	1	5/1/2010	5/1/2026			\$ -	\$ -	\$ 186,088	\$ 421,673
									\$ -	\$ -	\$ 186,088	\$ 421,673

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090548	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 17,466	\$ 6,000,000	\$ 38,010	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 4,357	\$ 2,500,000	\$ 14,711	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 871	\$ 500,000	\$ 3,070	
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 26,781	\$ 9,200,000	\$ 58,281	
	IATAN - STRANGER CREEK 345KV CKT 2	6/1/2011	6/1/2011			\$ -	\$ 4,123,803	\$ -	
	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1	6/1/2012	6/1/2012			\$ 42,731	\$ 2,244,000	\$ 109,950	
	SUB 145 - JOPLIN WEST 7TH - SUB 439 - STATELINE 161KV CKT 1	6/1/2016	6/1/2016			\$ 93,882	\$ 6,920,000	\$ 197,651	
						<b>Total</b>	<b>\$ 186,088</b>	<b>\$ 31,487,803</b>	<b>\$ 421,673</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090548	GRAY TAP - PENSACOLA 69KV CKT 1	6/1/2008	6/1/2008		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
KPP AG2-2006-078

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
KPP	1090609	WR	WR	129	10/1/2006	10/1/2016	6/1/2011	6/1/2021			\$ 33,042,167	\$ 80,300,699	
										\$ -	\$ -	\$ 33,042,167	\$ 80,300,699

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090609	ARKANSAS CITY - PARIS 69KV CKT 1	6/1/2007	3/1/2008	10/1/2007	Yes	\$ 600,000	\$ 600,000	\$ 1,665,010
	CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1	6/1/2016	6/1/2016			\$ 40,000	\$ 40,000	\$ -
	CITY OF WELLINGTON - SUMNER COUNTY NO. 4 ROME 69KV CKT 1	6/1/2011	6/1/2011			\$ 3,550,000	\$ 3,550,000	\$ 7,248,354
	CITY OF WINFIELD - RAINBOW 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	Yes	\$ 1,560,000	\$ 1,560,000	\$ 4,329,025
	CITY OF WINFIELD - TIMBER JUNCTION 69KV CKT 1	6/1/2011	6/1/2011			\$ 4,960,000	\$ 4,960,000	\$ 10,127,277
	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		Yes	\$ 1,622,831	\$ 7,520,000	\$ 5,809,304
	CRESWELL - NEWKIRK 138KV CKT 1 OKGE	6/1/2012	6/1/2012			\$ 1,316,512	\$ 4,500,000	\$ 3,671,673
	CRESWELL - NEWKIRK 138KV CKT 1 WERE	6/1/2012	6/1/2012			\$ 1,386,726	\$ 4,740,000	\$ 3,464,765
	CRESWELL - OAK 69KV CKT 1	6/1/2007	6/1/2007			\$ 250,000	\$ 250,000	\$ 240,513
	CRESWELL - PARIS 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	Yes	\$ 300,000	\$ 300,000	\$ 832,505
	CRESWELL - SUMNER COUNTY NO. 4 ROME 69KV CKT 1	6/1/2011	6/1/2011			\$ 3,200,000	\$ 3,200,000	\$ 6,533,727
	CRESWELL (CRESWL1X) 138/69/13.2KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 3,615,920	\$ 4,000,000	\$ 9,589,752
	CRESWELL (CRESWL2X) 138/69/13.2KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 2,487,268	\$ 4,000,000	\$ 6,596,463
	OAK - RAINBOW 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	Yes	\$ 1,800,000	\$ 1,800,000	\$ 4,995,029
	RICHLAND - ROSE HILL JUNCTION 69KV CKT 1	4/1/2007	3/1/2008		Yes	\$ 1,900,000	\$ 1,900,000	\$ 2,750,777
	RICHLAND - UDALL 69KV CKT 1	6/1/2007	5/1/2008	10/1/2007	Yes	\$ 2,900,000	\$ 2,900,000	\$ 8,047,546
	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER	6/1/2007	3/1/2008	10/1/2007	Yes	\$ 852,910	\$ 4,000,000	\$ 2,849,381
	TIMBER JUNCTION - UDALL 69KV CKT 1	6/1/2010	6/1/2010			\$ 700,000	\$ 700,000	\$ 1,549,600
<b>Total</b>						<b>\$ 33,042,167</b>	<b>\$ 50,520,000</b>	<b>\$ 80,300,699</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090609	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090609	ROSE HILL JUNCTION - WEAVER 69KV CKT 1	10/1/2006	6/1/2009		Yes

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
KPP AG2-2006-079

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
KPP	1090613	SECI	WPEK	25	10/1/2006	10/1/2016	6/1/2010	6/1/2020	\$ -	\$ -	\$ 1,186,273	\$ 3,171,481	
										\$ -	\$ -	\$ 1,186,273	\$ 3,171,481

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090613	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		Yes	\$ 201,132	\$ 7,520,000	\$ 657,754	
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 1,066	\$ 1,515,113	\$ 3,136	
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		Yes	\$ 7,748	\$ 153,114	\$ 28,203	
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 75,203	\$ 14,795,676	\$ 219,225	
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 485	\$ 100,000	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 154,199	\$ 94,396,814	\$ 355,429	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 4,084	\$ 2,500,000	\$ 8,869	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 76,371	\$ 5,000,000	\$ 165,849	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 212,914	\$ 38,504,390	\$ 626,429	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 2,861	\$ 3,200,000	\$ 8,418	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 177,583	\$ 31,000,000	\$ 485,808	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 120,298	\$ 21,000,000	\$ 261,242	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 115,218	\$ 24,875,000	\$ 265,578	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 37,111	\$ 10,318,679	\$ 85,541	
						Total	\$ 1,186,273	\$ 254,878,786	\$ 3,171,481

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090613	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	Yes
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090613	HOLCOMB - PLYMELL - PIONEER TAP 115KV CKT 1	6/1/2007	6/1/2008		Yes
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Customer** Study Number  
KPP AG2-2006-125

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
KPP	1090612	WPEK	WPEK	13	10/1/2006	10/1/2016	6/1/2011	6/1/2021	\$ -	\$ -	\$ 12,748,811	\$ 48,151,107	
										\$ -	\$ -	\$ 12,748,811	\$ 48,151,107

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090612	Ashland Capacitor	6/1/2012	6/1/2012			\$ 100,000	\$ 100,000	\$ -	
	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		Yes	\$ 150,965	\$ 7,520,000	\$ 540,415	
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	Yes	\$ 54,076	\$ 1,500,000	\$ 187,756	
	Hoisington Capacitors	6/1/2008	6/1/2008			\$ 150,000	\$ 150,000	\$ 457,704	
	Kingman 115 kV and 34.5 kV Expansion	10/1/2006	6/1/2010		No	\$ 10,000,000	\$ 10,000,000	\$ 39,844,708	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 357,020	\$ 94,396,814	\$ 891,762	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 9,455	\$ 2,500,000	\$ 21,437	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 105,343	\$ 5,000,000	\$ 238,838	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 365,333	\$ 31,000,000	\$ 1,059,153	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 247,484	\$ 21,000,000	\$ 561,105	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 54,143	\$ 24,875,000	\$ 135,238	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 17,300	\$ 10,318,679	\$ 43,212	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 1,137,692	\$ 42,000,000	\$ 4,169,779	
						Total	\$ 12,748,811	\$ 250,360,493	\$ 48,151,107

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090612	GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	Yes

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
MECB AG2-2006-140

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
MECB	1103355	MEC	AECI	100	1/1/2007	1/1/2008	6/1/2010	6/1/2011			\$ 3,922,876	\$ 6,002,035	
MECB	1103357	MEC	AECI	50	1/1/2007	1/1/2008	6/1/2010	6/1/2011			\$ 1,961,168	\$ 3,000,618	
										\$ -	\$ -	\$ 5,884,044	\$ 9,002,653

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1103355	CLRND to MARYVILLE 161KV Ckt 1 MIPU	1/1/2007	6/1/2009		No	\$ 3,673,517	\$ 5,510,000	\$ 5,478,775
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 925	\$ 1,515,113	\$ 1,946
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 72,589	\$ 14,795,676	\$ 151,326
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 173,405	\$ 38,504,390	\$ 364,854
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 2,440	\$ 3,200,000	\$ 5,134
					Total	\$ 3,922,876	\$ 63,525,179	\$ 6,002,035
1103357	CLRND to MARYVILLE 161KV Ckt 1 MIPU	1/1/2007	6/1/2009		No	\$ 1,836,483	\$ 5,510,000	\$ 2,738,976
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 462	\$ 1,515,113	\$ 972
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 36,300	\$ 14,795,676	\$ 75,675
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 86,703	\$ 38,504,390	\$ 182,428
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 1,220	\$ 3,200,000	\$ 2,567
					Total	\$ 1,961,168	\$ 63,525,179	\$ 3,000,618

Third Party Limitations

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	
1103355	CLRND to MARYVILLE 161KV Ckt 1 MEC	1/1/2007	6/1/2009			\$ 2,853,476	\$ 4,280,000	
1103357	CLRND to MARYVILLE 161KV Ckt 1 MEC	1/1/2007	6/1/2009			\$ 1,426,524	\$ 4,280,000	
						Total	\$ 4,280,000	\$ 8,560,000

**Customer** Study Number  
MIDW AG2-2006-047

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
MIDW	1090244	WR	WR	2	6/1/2008	6/1/2013	6/1/2010	6/1/2015			\$ 493,277	\$ 1,245,924	
										\$ -	\$ -	\$ 493,277	\$ 1,245,924

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090244	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 9,509	\$ 7,520,000	\$ 25,437	
	COUNTY LINE (COLINE5X) 115/69/34.5KV TRANSFORMER CKT 1	6/1/2008	6/1/2008			\$ 334,091	\$ 1,500,000	\$ 880,827	
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 65	\$ 1,515,113	\$ 160	
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 201	\$ 153,114	\$ 598	
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 4,881	\$ 14,795,676	\$ 11,873	
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	No	\$ 23,751	\$ 2,200,000	\$ 64,869	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 19,154	\$ 94,396,814	\$ 36,841	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 507	\$ 2,500,000	\$ 994	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 8,212	\$ 5,000,000	\$ 16,103	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 12,123	\$ 38,504,390	\$ 29,764	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 177	\$ 3,200,000	\$ 435	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 26,422	\$ 3,700,000	\$ 64,807	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 26,060	\$ 31,000,000	\$ 62,304	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 17,654	\$ 21,000,000	\$ 34,619	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 6,413	\$ 24,875,000	\$ 12,335	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 2,057	\$ 10,318,679	\$ 3,957	
						Total	\$ 493,277	\$ 262,178,786	\$ 1,245,924

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090244	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090244	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
 MIDW AG2-2006-050

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
MIDW	1090329	WR	WR	36	6/1/2010	6/1/2035	6/1/2011	6/1/2036			\$ 3,339,806	\$ 16,779,501	
MIDW	1090331	WR	WR	9	6/1/2010	6/1/2035	6/1/2011	6/1/2036			\$ 834,940	\$ 4,194,827	
MIDW	1090332	WR	WR	49	6/1/2010	6/1/2035	6/1/2011	6/1/2036			\$ 4,545,787	\$ 22,838,513	
MIDW	1090334	WR	WR	11	6/1/2010	6/1/2035	6/1/2011	6/1/2036			\$ 1,020,481	\$ 5,127,006	
										\$ -	\$ -	\$ 9,741,014	\$ 48,939,847

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090329	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 50,652	\$ 7,520,000	\$ 301,262
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 296,044	\$ 94,396,814	\$ 1,179,242
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 7,840	\$ 2,500,000	\$ 23,593
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 106,266	\$ 5,000,000	\$ 319,793
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 354,986	\$ 31,000,000	\$ 1,479,957
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 240,474	\$ 21,000,000	\$ 723,675
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 67,710	\$ 24,875,000	\$ 289,712
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 21,594	\$ 10,318,679	\$ 86,016
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 2,194,240	\$ 42,000,000	\$ 12,396,251
				Total	\$ 3,339,806	\$ 238,610,493	\$ 16,779,501	
1090331	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 12,653	\$ 7,520,000	\$ 75,256
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 74,011	\$ 94,396,814	\$ 294,811
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,960	\$ 2,500,000	\$ 5,898
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 26,565	\$ 5,000,000	\$ 79,944
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 88,743	\$ 31,000,000	\$ 369,975
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 60,117	\$ 21,000,000	\$ 180,914
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 16,921	\$ 24,875,000	\$ 67,402
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 5,401	\$ 10,318,679	\$ 21,514
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 548,569	\$ 42,000,000	\$ 3,099,114
				Total	\$ 834,940	\$ 238,610,493	\$ 4,194,827	
1090332	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 68,933	\$ 7,520,000	\$ 409,992
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 402,923	\$ 94,396,814	\$ 1,604,977
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 10,671	\$ 2,500,000	\$ 32,113
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 144,639	\$ 5,000,000	\$ 435,272
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 483,167	\$ 31,000,000	\$ 2,014,350
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 327,306	\$ 21,000,000	\$ 984,984
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 92,154	\$ 24,875,000	\$ 367,080
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 29,389	\$ 10,318,679	\$ 117,066
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 2,986,605	\$ 42,000,000	\$ 16,872,678
				Total	\$ 4,545,787	\$ 238,610,493	\$ 22,838,513	
1090334	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 15,487	\$ 7,520,000	\$ 92,112
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 90,445	\$ 94,396,814	\$ 360,273
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 2,395	\$ 2,500,000	\$ 7,207
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 32,471	\$ 5,000,000	\$ 97,717
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 108,468	\$ 31,000,000	\$ 452,209
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 73,478	\$ 21,000,000	\$ 221,122
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 20,695	\$ 24,875,000	\$ 82,435
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 6,593	\$ 10,318,679	\$ 26,262
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 670,449	\$ 42,000,000	\$ 3,787,669
				Total	\$ 1,020,481	\$ 238,610,493	\$ 5,127,006	

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer**    **Study Number**  
 MIDW        AG2-2006-050

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090329	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
1090331	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
1090332	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
1090334	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090329	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090331	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090332	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090334	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
 MIDW AG2-2006-051

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MIDW	1090325	WR	WR	24	6/1/2008	6/1/2038	6/1/2011	6/1/2041			\$ 2,223,555	\$ 12,616,751
MIDW	1090327	WR	WR	6	6/1/2008	6/1/2038	6/1/2011	6/1/2041			\$ 555,918	\$ 3,154,311
									\$ -	\$ -	\$ 2,779,473	\$ 15,771,063

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090325	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 30,857	\$ 7,520,000	\$ 211,290
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 197,325	\$ 94,396,814	\$ 897,225
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 5,226	\$ 2,500,000	\$ 17,156
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 70,844	\$ 5,000,000	\$ 232,566
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 236,649	\$ 31,000,000	\$ 1,099,224
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 160,311	\$ 21,000,000	\$ 526,268
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 45,140	\$ 24,875,000	\$ 205,249
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 14,389	\$ 10,318,679	\$ 65,426
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 1,462,814	\$ 42,000,000	\$ 9,362,348
					Total	\$ 2,223,555	\$ 238,610,493	\$ 12,616,751
1090327	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 7,704	\$ 7,520,000	\$ 52,752
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 49,359	\$ 94,396,814	\$ 224,433
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,307	\$ 2,500,000	\$ 4,291
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 17,713	\$ 5,000,000	\$ 58,148
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 59,162	\$ 31,000,000	\$ 274,805
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 40,078	\$ 21,000,000	\$ 131,568
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 11,285	\$ 24,875,000	\$ 51,312
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 3,597	\$ 10,318,679	\$ 16,355
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 365,713	\$ 42,000,000	\$ 2,340,648
					Total	\$ 555,918	\$ 238,610,493	\$ 3,154,311

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090325	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
1090327	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090325	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090327	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
 MIDW AG2-2006-052

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements		
MIDW	1090245	WR	WR	6	6/1/2008	6/1/2013	6/1/2010	6/1/2015			\$ 541,667	\$ 1,276,212		
											\$	\$	\$ 541,667	\$ 1,276,212

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090245	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 189,565	\$ 7,520,000	\$ 507,090
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 185	\$ 1,515,113	\$ 454
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 583	\$ 153,114	\$ 1,736
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 13,885	\$ 14,795,676	\$ 33,776
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 51,740	\$ 94,396,814	\$ 99,518
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,370	\$ 2,500,000	\$ 2,687
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 22,875	\$ 5,000,000	\$ 44,857
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 34,292	\$ 38,504,390	\$ 84,191
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 498	\$ 3,200,000	\$ 1,198
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 81,736	\$ 3,700,000	\$ 186,373
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 72,109	\$ 31,000,000	\$ 172,398
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 48,848	\$ 21,000,000	\$ 95,789
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 18,179	\$ 24,875,000	\$ 34,966
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 5,812	\$ 10,318,679	\$ 11,179
<b>Total</b>						<b>\$ 541,667</b>	<b>\$ 258,478,786</b>	<b>\$ 1,276,212</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090245	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090245	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
 MIDW AG2-2006-058

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
MIDW	1090377	EES	WR	40	5/1/2010	5/1/2040	6/1/2011	6/1/2041	-	-	\$ 5,320,156	\$ 30,164,686	
MIDW	1090378	EES	WR	10	5/1/2010	5/1/2040	6/1/2011	6/1/2041	-	-	\$ 1,330,032	\$ 7,541,099	
MIDW	1090382	EES	WR	20	5/1/2010	5/1/2040	6/1/2011	6/1/2041	-	-	\$ 2,660,076	\$ 15,082,334	
MIDW	1090383	EES	WR	5	5/1/2010	5/1/2040	6/1/2011	6/1/2041	-	-	\$ 665,038	\$ 3,770,665	
										\$	\$	\$ 9,975,302	\$ 56,558,784

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090377	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 13,740	\$ 7,520,000	\$ 94,083
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 536,551	\$ 94,396,814	\$ 2,439,666
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 14,210	\$ 2,500,000	\$ 46,648
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 157,121	\$ 5,000,000	\$ 515,795
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 545,754	\$ 31,000,000	\$ 2,535,002
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 369,704	\$ 21,000,000	\$ 1,213,661
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 103,402	\$ 24,875,000	\$ 470,163
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 32,955	\$ 10,318,679	\$ 149,844
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 3,546,719	\$ 42,000,000	\$ 22,699,822
Total						\$ 5,320,156	\$ 238,610,493	\$ 30,164,686
1090378	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 3,435	\$ 7,520,000	\$ 23,521
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 134,138	\$ 94,396,814	\$ 609,918
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 3,552	\$ 2,500,000	\$ 11,660
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 39,282	\$ 5,000,000	\$ 128,955
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 136,444	\$ 31,000,000	\$ 633,776
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 92,430	\$ 21,000,000	\$ 303,428
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 25,851	\$ 24,875,000	\$ 117,543
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 8,239	\$ 10,318,679	\$ 37,462
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 886,661	\$ 42,000,000	\$ 5,674,835
Total						\$ 1,330,032	\$ 238,610,493	\$ 7,541,099
1090382	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 6,870	\$ 7,520,000	\$ 47,042
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 268,275	\$ 94,396,814	\$ 1,219,831
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 7,105	\$ 2,500,000	\$ 23,324
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 78,560	\$ 5,000,000	\$ 257,896
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 272,877	\$ 31,000,000	\$ 1,267,501
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 184,852	\$ 21,000,000	\$ 606,831
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 51,701	\$ 24,875,000	\$ 235,081
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 16,477	\$ 10,318,679	\$ 74,920
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 1,773,359	\$ 42,000,000	\$ 11,349,908
Total						\$ 2,660,076	\$ 238,610,493	\$ 15,082,334
1090383	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 1,708	\$ 7,520,000	\$ 11,695
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 67,097	\$ 94,396,814	\$ 305,086
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,777	\$ 2,500,000	\$ 5,834
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 19,641	\$ 5,000,000	\$ 64,477
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 68,216	\$ 31,000,000	\$ 316,860
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 46,211	\$ 21,000,000	\$ 151,701
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 12,925	\$ 24,875,000	\$ 58,769
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 4,114	\$ 10,318,679	\$ 18,706
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 443,349	\$ 42,000,000	\$ 2,837,536
Total						\$ 665,038	\$ 238,610,493	\$ 3,770,665

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090377	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
1090378	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
1090382	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
1090383	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090377	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090378	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090382	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090383	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
 MIDW AG2-2006-059

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MIDW	1090388	EES	WR	7	5/1/2010	5/1/2040			\$ -	\$ -	\$ 203,262	\$ 749,134
MIDW	1090390	EES	WR	3	5/1/2010	5/1/2040			\$ -	\$ -	\$ 87,114	\$ 321,054
									\$ -	\$ -	\$ 290,376	\$ 1,070,188

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090388	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 40,003	\$ 6,000,000	\$ 130,586
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 12,041	\$ 2,500,000	\$ 60,984
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 2,408	\$ 500,000	\$ 12,330
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 61,337	\$ 9,200,000	\$ 200,229
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 33,889	\$ 94,396,814	\$ 141,231
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 898	\$ 2,500,000	\$ 2,813
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 6,163	\$ 5,000,000	\$ 19,308
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 24,132	\$ 31,000,000	\$ 105,251
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 16,347	\$ 21,000,000	\$ 51,213
	Tuco - Talk 345kV	6/1/2011	6/1/2011			\$ 4,588	\$ 24,875,000	\$ 19,120
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 1,456	\$ 10,318,679	\$ 6,068
	Total						\$ 203,262	\$ 207,290,493
1090390	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 17,149	\$ 6,000,000	\$ 55,981
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 5,164	\$ 2,500,000	\$ 26,154
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 1,033	\$ 500,000	\$ 5,290
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 26,295	\$ 9,200,000	\$ 85,838
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 14,507	\$ 94,396,814	\$ 60,457
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 384	\$ 2,500,000	\$ 1,203
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 2,642	\$ 5,000,000	\$ 8,277
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 10,347	\$ 31,000,000	\$ 45,128
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 7,010	\$ 21,000,000	\$ 21,961
	Tuco - Talk 345kV	6/1/2011	6/1/2011			\$ 1,961	\$ 24,875,000	\$ 8,172
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 622	\$ 10,318,679	\$ 2,592
	Total						\$ 87,114	\$ 207,290,493

**Customer** Study Number  
 MIDW AG2-2006-060

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MIDW	1090392	EES	WR	1	5/1/2010	5/1/2040			\$ -	\$ -	\$ 182,767	\$ 942,617
MIDW	1090394	EES	WR	1	5/1/2010	5/1/2040			\$ -	\$ -	\$ 182,767	\$ 942,617
									\$ -	\$ -	\$ 365,534	\$ 1,885,233

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090392	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 5,669	\$ 6,000,000	\$ 18,506
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 1,721	\$ 2,500,000	\$ 8,716
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 344	\$ 500,000	\$ 1,761
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 8,693	\$ 9,200,000	\$ 28,377
	COUNTY LINE (COLINE5X) 115/69/34.5KV TRANSFORMER CKT 1	6/1/2008	6/1/2008			\$ 156,439	\$ 1,500,000	\$ 844,387
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 6,916	\$ 2,250,000	\$ 24,178
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	No	\$ 2,985	\$ 2,200,000	\$ 16,691
Total						\$ 182,767	\$ 24,150,000	\$ 942,617
1090394	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 5,669	\$ 6,000,000	\$ 18,506
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 1,721	\$ 2,500,000	\$ 8,716
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 344	\$ 500,000	\$ 1,761
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 8,693	\$ 9,200,000	\$ 28,377
	COUNTY LINE (COLINE5X) 115/69/34.5KV TRANSFORMER CKT 1	6/1/2008	6/1/2008			\$ 156,439	\$ 1,500,000	\$ 844,387
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 6,916	\$ 2,250,000	\$ 24,178
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	No	\$ 2,985	\$ 2,200,000	\$ 16,691
Total						\$ 182,767	\$ 24,150,000	\$ 942,617

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090392	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
1090394	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No

**Customer** Study Number  
 MIDW AG2-2006-061

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements		
MIDW	1090396	EES	WR	2	5/1/2010	5/1/2040					\$ 99,529	\$ 543,879		
MIDW	1090399	EES	WR	1	5/1/2010	5/1/2040					\$ 49,794	\$ 272,066		
											\$ -	\$ -	\$ 149,323	\$ 815,944

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090396	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 65,013	\$ 7,520,000	\$ 403,573
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 3,398	\$ 2,500,000	\$ 17,210
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 680	\$ 500,000	\$ 3,482
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 10,597	\$ 94,396,814	\$ 44,163
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 281	\$ 2,500,000	\$ 880
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 2,394	\$ 5,000,000	\$ 7,500
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 8,814	\$ 31,000,000	\$ 38,442
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 5,971	\$ 21,000,000	\$ 18,706
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 1,801	\$ 24,875,000	\$ 7,506
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 580	\$ 10,318,679	\$ 2,417
Total						\$ 99,529	\$ 199,610,493	\$ 543,879
1090399	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 32,506	\$ 7,520,000	\$ 201,763
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 1,704	\$ 2,500,000	\$ 8,630
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 341	\$ 500,000	\$ 1,746
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 5,327	\$ 94,396,814	\$ 22,200
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 141	\$ 2,500,000	\$ 442
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 1,197	\$ 5,000,000	\$ 3,750
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 4,407	\$ 31,000,000	\$ 19,221
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 2,986	\$ 21,000,000	\$ 9,355
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 900	\$ 24,875,000	\$ 3,751
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 285	\$ 10,318,679	\$ 1,188
Total						\$ 49,794	\$ 199,610,493	\$ 272,066

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090396	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
1090399	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
 MIDW AG2-2006-096

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements		
MIDW	1091026	WR	WR	3	6/1/2008	6/1/2038	6/1/2010	6/1/2040			\$ 148,843	\$ 627,333		
MIDW	1091027	WR	WR	7	6/1/2008	6/1/2038	6/1/2010	6/1/2040			\$ 347,220	\$ 1,463,458		
MIDW	1091028	WR	WR	8	6/1/2008	6/1/2038	6/1/2011	6/1/2041			\$ 197,123	\$ 827,577		
MIDW	1091032	WR	WR	10	6/1/2008	6/1/2038	6/1/2010	6/1/2040			\$ 495,991	\$ 2,090,492		
MIDW	1091066	WR	WR	17	6/1/2008	6/1/2038	6/1/2010	6/1/2015			\$ 1,067,316	\$ 2,331,985		
											\$ -	\$ -	\$ 2,256,493	\$ 7,340,845

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1091026	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 54	\$ 1,515,113	\$ 289
	Hitchland 345 and 115 KV Interchange	4/1/2007	6/1/2010		No	\$ 3,189	\$ 14,795,676	\$ 16,923
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 17,052	\$ 2,250,000	\$ 59,982
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 29,355	\$ 94,396,814	\$ 123,173
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 777	\$ 2,500,000	\$ 2,443
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 8,626	\$ 5,000,000	\$ 27,752
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 9,034	\$ 38,504,390	\$ 48,385
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 133	\$ 3,200,000	\$ 712
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 23,088	\$ 3,700,000	\$ 123,108
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 30,479	\$ 31,000,000	\$ 133,590
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 20,647	\$ 21,000,000	\$ 64,921
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 4,711	\$ 24,875,000	\$ 19,767
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 1,498	\$ 10,318,679	\$ 6,286
		Total				\$ 148,843	\$ 253,055,672	\$ 627,333
1091027	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 120	\$ 1,515,113	\$ 643
	Hitchland 345 and 115 KV Interchange	4/1/2007	6/1/2010		No	\$ 7,437	\$ 14,795,676	\$ 39,465
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 39,765	\$ 2,250,000	\$ 139,877
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 68,457	\$ 94,396,814	\$ 287,245
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,813	\$ 2,500,000	\$ 5,701
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 20,590	\$ 5,000,000	\$ 64,742
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 21,105	\$ 38,504,390	\$ 113,036
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 311	\$ 3,200,000	\$ 1,666
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 53,853	\$ 3,700,000	\$ 287,151
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 71,114	\$ 31,000,000	\$ 311,695
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 48,174	\$ 21,000,000	\$ 151,476
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 10,989	\$ 24,875,000	\$ 46,110
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 3,492	\$ 10,318,679	\$ 14,652
		Total				\$ 347,220	\$ 253,055,672	\$ 1,463,458
1091028	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 65	\$ 1,515,113	\$ 377
	Hitchland 345 and 115 KV Interchange	4/1/2007	6/1/2010		No	\$ 3,523	\$ 14,795,676	\$ 20,259
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 52,783	\$ 2,250,000	\$ 199,641
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 42,389	\$ 94,396,814	\$ 192,740
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,123	\$ 2,500,000	\$ 3,687
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 11,394	\$ 5,000,000	\$ 37,404
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 10,747	\$ 38,504,390	\$ 62,374
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 155	\$ 3,200,000	\$ 900
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 40,312	\$ 31,000,000	\$ 187,247
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 27,308	\$ 21,000,000	\$ 89,646
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 5,562	\$ 24,875,000	\$ 25,290
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 1,762	\$ 10,318,679	\$ 8,012
		Total				\$ 544,343	\$ 502,411,344	\$ 2,291,035
	1091032	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 174	\$ 1,515,113
Hitchland 345 and 115 KV Interchange		4/1/2007	6/1/2010		No	\$ 10,626	\$ 14,795,676	\$ 56,388
LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1		6/1/2016	6/1/2016			\$ 56,817	\$ 2,250,000	\$ 199,860
Mooreland - TUCO 345 kV SPS		6/1/2011	6/1/2011			\$ 97,756	\$ 94,396,814	\$ 410,183
Mooreland - TUCO 345 kV WFEC		6/1/2011	6/1/2011			\$ 2,589	\$ 2,500,000	\$ 8,141
Mooreland 345/138 kV Transformer		6/1/2011	6/1/2011			\$ 29,412	\$ 5,000,000	\$ 92,482
Potter - Roosevelt 345KV		4/1/2007	6/1/2010		No	\$ 30,138	\$ 38,504,390	\$ 161,416
ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1		4/1/2007	6/1/2010		No	\$ 444	\$ 3,200,000	\$ 2,378
SEWARD - ST JOHN 115KV CKT 1		6/1/2008	6/1/2008			\$ 76,941	\$ 3,700,000	\$ 410,259
Spearville - Mooreland 345 kV SUNC		6/1/2011	6/1/2011			\$ 101,594	\$ 31,000,000	\$ 445,290
Spearville - Mooreland 345 kV WFEC		6/1/2011	6/1/2011			\$ 68,822	\$ 21,000,000	\$ 216,400
Tuco - Tolk 345kV		6/1/2011	6/1/2011			\$ 15,688	\$ 24,875,000	\$ 65,827
TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1		6/1/2011	6/1/2011			\$ 4,990	\$ 10,318,679	\$ 20,938
		Total				\$ 495,991	\$ 253,055,672	\$ 2,090,492
1091066	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 571	\$ 1,515,113	\$ 1,402
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 1,855	\$ 153,114	\$ 5,523
	Hitchland 345 and 115 KV Interchange	4/1/2007	6/1/2010		No	\$ 42,805	\$ 14,795,676	\$ 104,125
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 154,199	\$ 94,396,814	\$ 296,592
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 4,084	\$ 2,500,000	\$ 8,009
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 70,189	\$ 5,000,000	\$ 137,599
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 105,159	\$ 38,504,390	\$ 258,179
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 1,508	\$ 3,200,000	\$ 3,702
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 243,243	\$ 3,700,000	\$ 554,639
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 220,673	\$ 31,000,000	\$ 527,583
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 149,488	\$ 21,000,000	\$ 293,142
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 55,734	\$ 24,875,000	\$ 107,201
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 17,828	\$ 10,318,679	\$ 34,291
		Total				\$ 1,067,316	\$ 250,958,786	\$ 2,331,985

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
 MIDW AG2-2006-096

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1091026	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	Stateline Project	6/1/2014	6/1/2014		
1091027	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
1091028	Stateline Project	6/1/2014	6/1/2014		
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
	BOOKER 69KV	6/1/2016	6/1/2016		
1091032	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	Stateline Project	6/1/2014	6/1/2014		
1091032	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
1091066	Stateline Project	6/1/2014	6/1/2014		
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	Stateline Project	6/1/2014	6/1/2014		
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1091026	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091027	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091032	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091066	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
 MIDW AG2-2006-097

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements		
MIDW	1090917	WR	WR	20	6/1/2008	6/1/2008	6/1/2011	6/1/2041			\$ 303,700	\$ 1,871,267		
MIDW	1090919	WR	WR	5	6/1/2008	6/1/2008	6/1/2011	6/1/2041			\$ 75,922	\$ 467,799		
MIDW	1090920	WR	WR	40	6/1/2008	6/1/2008	6/1/2011	6/1/2041			\$ 607,387	\$ 3,742,458		
MIDW	1090921	WR	WR	10	6/1/2008	6/1/2008	6/1/2011	6/1/2041			\$ 151,843	\$ 935,592		
MIDW	1090922	WR	WR	50	6/1/2008	6/1/2008	6/1/2011	6/1/2041			\$ 560,019	\$ 3,599,228		
MIDW	1090923	WR	WR	11	6/1/2008	6/1/2008	6/1/2011	6/1/2041			\$ 123,223	\$ 791,949		
MIDW	1090934	WR	WR	60	6/1/2008	6/1/2008	6/1/2011	6/1/2041			\$ 911,087	\$ 5,613,725		
MIDW	1090935	WR	WR	15	6/1/2008	6/1/2008	6/1/2011	6/1/2041			\$ 227,765	\$ 1,403,392		
											\$ -	\$ -	\$ 2,960,946	\$ 18,425,410

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090917	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 128,626	\$ 3,700,000	\$ 750,753	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 175,074	\$ 42,000,000	\$ 1,120,514	
						Total	\$ 303,700	\$ 45,700,000	\$ 1,871,267
1090919	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 32,153	\$ 3,700,000	\$ 187,668	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 43,769	\$ 42,000,000	\$ 280,132	
						Total	\$ 75,922	\$ 45,700,000	\$ 467,799
1090920	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 257,238	\$ 3,700,000	\$ 1,501,423	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 350,149	\$ 42,000,000	\$ 2,241,035	
						Total	\$ 607,387	\$ 45,700,000	\$ 3,742,458
1090921	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 64,306	\$ 3,700,000	\$ 375,335	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 87,537	\$ 42,000,000	\$ 560,257	
						Total	\$ 151,843	\$ 45,700,000	\$ 935,592
1090922	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 144,037	\$ 7,520,000	\$ 986,277	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 87,717	\$ 3,700,000	\$ 511,979	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 328,265	\$ 42,000,000	\$ 2,100,972	
						Total	\$ 415,982	\$ 45,700,000	\$ 2,612,951
1090923	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 31,691	\$ 7,520,000	\$ 217,001	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 19,303	\$ 3,700,000	\$ 112,666	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 72,229	\$ 42,000,000	\$ 462,282	
						Total	\$ 91,532	\$ 45,700,000	\$ 574,948
1090934	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 385,864	\$ 3,700,000	\$ 2,252,176	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 525,223	\$ 42,000,000	\$ 3,361,549	
						Total	\$ 911,087	\$ 45,700,000	\$ 5,613,725
1090935	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 96,459	\$ 3,700,000	\$ 563,003	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 131,306	\$ 42,000,000	\$ 840,389	
						Total	\$ 227,765	\$ 45,700,000	\$ 1,403,392

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090922	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
1090923	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090917	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090919	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090920	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090921	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090922	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090923	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090934	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090935	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
 MIDW AG2-2006-098

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
MIDW	1090958	WR	WR	3	6/1/2008	6/2/2038	6/1/2010	6/1/2040	\$ -	\$ -	\$ 214,734	\$ 1,109,487	
MIDW	1091043	WR	WR	1	6/1/2008	6/1/2038	6/1/2010	6/1/2040	\$ -	\$ -	\$ 71,575	\$ 369,840	
MIDW	1091044	WR	WR	2	6/1/2008	6/1/2038	6/1/2010	6/1/2040	\$ -	\$ -	\$ 143,176	\$ 739,756	
MIDW	1091045	WR	WR	2	6/1/2008	6/1/2038	6/1/2011	6/1/2041	\$ -	\$ -	\$ 99,635	\$ 608,394	
										\$ -	\$ -	\$ 529,120	\$ 2,827,476

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090958	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 95,287	\$ 7,520,000	\$ 596,061
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 44	\$ 1,515,113	\$ 236
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 2,579	\$ 14,795,676	\$ 13,686
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 27,938	\$ 94,396,814	\$ 117,228
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 740	\$ 2,500,000	\$ 2,327
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 7,877	\$ 5,000,000	\$ 24,768
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 7,632	\$ 38,504,390	\$ 40,876
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 111	\$ 3,200,000	\$ 595
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 21,027	\$ 3,700,000	\$ 112,118
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 27,593	\$ 31,000,000	\$ 120,941
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 18,692	\$ 21,000,000	\$ 58,774
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 3,959	\$ 24,875,000	\$ 16,612
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 1,255	\$ 10,318,679	\$ 5,266
					Total	\$ 214,734	\$ 258,325,672	\$ 1,109,487
	1091043	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 31,769	\$ 7,520,000
CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2		4/1/2007	6/1/2010		Yes	\$ 16	\$ 1,515,113	\$ 86
Hitchland 345 and 115 kV Interchange		4/1/2007	6/1/2010		No	\$ 863	\$ 14,795,676	\$ 4,580
Mooreland - TUCO 345 kV SPS		6/1/2011	6/1/2011			\$ 9,294	\$ 94,396,814	\$ 38,998
Mooreland - TUCO 345 kV WFEC		6/1/2011	6/1/2011			\$ 246	\$ 2,500,000	\$ 774
Mooreland 345/138 kV Transformer		6/1/2011	6/1/2011			\$ 2,624	\$ 5,000,000	\$ 8,251
Potter - Roosevelt 345KV		4/1/2007	6/1/2010		No	\$ 2,544	\$ 38,504,390	\$ 13,625
ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1		4/1/2007	6/1/2010		No	\$ 44	\$ 3,200,000	\$ 236
SEWARD - ST JOHN 115KV CKT 1		6/1/2008	6/1/2008			\$ 7,004	\$ 3,700,000	\$ 37,346
Spearville - Mooreland 345 kV SUNC		6/1/2011	6/1/2011			\$ 9,198	\$ 31,000,000	\$ 40,315
Spearville - Mooreland 345 kV WFEC		6/1/2011	6/1/2011			\$ 6,231	\$ 21,000,000	\$ 19,592
Tuco - Tolk 345kV		6/1/2011	6/1/2011			\$ 1,320	\$ 24,875,000	\$ 5,539
TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1		6/1/2011	6/1/2011			\$ 422	\$ 10,318,679	\$ 1,771
					Total	\$ 71,575	\$ 258,325,672	\$ 369,840
1091044		CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 63,538	\$ 7,520,000
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 27	\$ 1,515,113	\$ 145
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 1,715	\$ 14,795,676	\$ 9,101
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 18,644	\$ 94,396,814	\$ 78,230
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 494	\$ 2,500,000	\$ 1,553
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 5,253	\$ 5,000,000	\$ 16,517
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 5,088	\$ 38,504,390	\$ 27,251
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 67	\$ 3,200,000	\$ 359
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 14,022	\$ 3,700,000	\$ 74,767
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 18,395	\$ 31,000,000	\$ 80,626
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 12,461	\$ 21,000,000	\$ 39,182
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 2,639	\$ 24,875,000	\$ 11,073
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 833	\$ 10,318,679	\$ 3,495
					Total	\$ 143,176	\$ 258,325,672	\$ 739,756
	1091045	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 70,369	\$ 7,520,000
CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2		4/1/2007	6/1/2010		Yes	\$ 11	\$ 1,515,113	\$ 64
Hitchland 345 and 115 kV Interchange		4/1/2007	6/1/2010		No	\$ 472	\$ 14,795,676	\$ 2,714
Mooreland - TUCO 345 kV SPS		6/1/2011	6/1/2011			\$ 9,691	\$ 94,396,814	\$ 44,064
Mooreland - TUCO 345 kV WFEC		6/1/2011	6/1/2011			\$ 257	\$ 2,500,000	\$ 844
Mooreland 345/138 kV Transformer		6/1/2011	6/1/2011			\$ 2,220	\$ 5,000,000	\$ 7,288
Potter - Roosevelt 345KV		4/1/2007	6/1/2010		No	\$ 1,739	\$ 38,504,390	\$ 10,093
ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1		4/1/2007	6/1/2010		No	\$ 22	\$ 3,200,000	\$ 128
Spearville - Mooreland 345 kV SUNC		6/1/2011	6/1/2011			\$ 8,156	\$ 31,000,000	\$ 37,884
Spearville - Mooreland 345 kV WFEC		6/1/2011	6/1/2011			\$ 5,525	\$ 21,000,000	\$ 18,137
Tuco - Tolk 345kV		6/1/2011	6/1/2011			\$ 888	\$ 24,875,000	\$ 4,038
TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1		6/1/2011	6/1/2011			\$ 285	\$ 10,318,679	\$ 1,296
					Total	\$ 242,811	\$ 512,951,344	\$ 1,348,149

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
 MIDW AG2-2006-098

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090958	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		
1091043	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		
1091044	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		
1091045	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090958	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091043	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091044	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091045	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
 MIDW AG2-2006-099

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MIDW	1091034	WR	WR	1	6/1/2008	6/1/2008	6/1/2010	6/1/2040			\$ 239,510	\$ 1,234,404
MIDW	1091035	WR	WR	1	6/1/2008	6/1/2008	6/1/2010	6/1/2040			\$ 239,510	\$ 1,234,404
MIDW	1091036	WR	WR	1	6/1/2008	6/1/2008	6/1/2011	6/1/2041			\$ 227,986	\$ 1,293,324
MIDW	1091041	WR	WR	2	6/1/2008	6/1/2008	6/1/2010	6/1/2040			\$ 479,292	\$ 2,470,195
											\$ -	\$ 6,232,326

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1091034	COUNTY LINE (COLINE5X) 115/69/34.5KV TRANSFORMER CKT 1	6/1/2008	6/1/2008			\$ 170,076	\$ 1,500,000	\$ 923,667
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 16	\$ 1,515,113	\$ 86
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 990	\$ 14,795,676	\$ 5,254
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 10,102	\$ 2,250,000	\$ 35,535
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	No	\$ 15,259	\$ 2,200,000	\$ 85,848
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 10,257	\$ 94,396,814	\$ 43,038
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 272	\$ 2,500,000	\$ 855
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 2,920	\$ 5,000,000	\$ 9,182
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 2,881	\$ 38,504,390	\$ 15,430
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 44	\$ 3,200,000	\$ 236
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 7,597	\$ 3,700,000	\$ 40,508
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 10,204	\$ 31,000,000	\$ 44,724
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 6,912	\$ 21,000,000	\$ 21,734
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 1,505	\$ 24,875,000	\$ 6,315
TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 475	\$ 10,318,679	\$ 1,993	
Total						\$ 239,510	\$ 256,755,672	\$ 1,234,404
1091035	COUNTY LINE (COLINE5X) 115/69/34.5KV TRANSFORMER CKT 1	6/1/2008	6/1/2008			\$ 170,076	\$ 1,500,000	\$ 923,667
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 16	\$ 1,515,113	\$ 86
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 990	\$ 14,795,676	\$ 5,254
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 10,102	\$ 2,250,000	\$ 35,535
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	No	\$ 15,259	\$ 2,200,000	\$ 85,848
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 10,257	\$ 94,396,814	\$ 43,038
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 272	\$ 2,500,000	\$ 855
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 2,920	\$ 5,000,000	\$ 9,182
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 2,881	\$ 38,504,390	\$ 15,430
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 44	\$ 3,200,000	\$ 236
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 7,597	\$ 3,700,000	\$ 40,508
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 10,204	\$ 31,000,000	\$ 44,724
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 6,912	\$ 21,000,000	\$ 21,734
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 1,505	\$ 24,875,000	\$ 6,315
TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 475	\$ 10,318,679	\$ 1,993	
Total						\$ 239,510	\$ 256,755,672	\$ 1,234,404
1091036	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 8,345	\$ 7,520,000	\$ 57,141
	COUNTY LINE (COLINE5X) 115/69/34.5KV TRANSFORMER CKT 1	6/1/2008	6/1/2008			\$ 172,538	\$ 1,500,000	\$ 1,007,547
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 5	\$ 1,515,113	\$ 29
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 357	\$ 14,795,676	\$ 2,053
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 11,018	\$ 2,250,000	\$ 41,673
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	No	\$ 17,780	\$ 2,200,000	\$ 107,558
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 5,780	\$ 94,396,814	\$ 26,281
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 153	\$ 2,500,000	\$ 502
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 1,401	\$ 5,000,000	\$ 4,599
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 1,220	\$ 38,504,390	\$ 7,081
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 22	\$ 3,200,000	\$ 128
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 5,090	\$ 31,000,000	\$ 23,643
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 3,448	\$ 21,000,000	\$ 11,319
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 629	\$ 24,875,000	\$ 2,860
TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 200	\$ 10,318,679	\$ 909	
Total						\$ 227,986	\$ 260,575,672	\$ 1,293,324
1091041	COUNTY LINE (COLINE5X) 115/69/34.5KV TRANSFORMER CKT 1	6/1/2008	6/1/2008			\$ 340,341	\$ 1,500,000	\$ 1,848,360
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 33	\$ 1,515,113	\$ 177
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 1,969	\$ 14,795,676	\$ 10,449
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 20,205	\$ 2,250,000	\$ 71,073
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	No	\$ 30,518	\$ 2,200,000	\$ 171,696
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 20,571	\$ 94,396,814	\$ 86,316
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 545	\$ 2,500,000	\$ 1,714
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 5,841	\$ 5,000,000	\$ 18,366
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 5,789	\$ 38,504,390	\$ 31,005
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 89	\$ 3,200,000	\$ 477
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 15,194	\$ 3,700,000	\$ 81,016
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 20,419	\$ 31,000,000	\$ 89,497
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 13,832	\$ 21,000,000	\$ 43,493
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 2,997	\$ 24,875,000	\$ 12,575
TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 949	\$ 10,318,679	\$ 3,982	
Total						\$ 479,292	\$ 256,755,672	\$ 2,470,195

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
 MIDW AG2-2006-099

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1091034	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
1091035	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No
1091036	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		
1091041	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Stateline Project	6/1/2014	6/1/2014		
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	No

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1091034	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091035	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091041	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
 MIDW AG2-2006-106

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
MIDW	1090964	WR	WR	35	1/1/2007	1/1/2012	6/1/2011	6/1/2016			\$ 2,080,531	\$ 5,471,729	
MIDW	1090965	WR	WR	10	1/1/2007	1/1/2012	6/1/2011	6/1/2016			\$ 594,408	\$ 1,563,264	
										\$ -	\$ -	\$ 2,674,939	\$ 7,034,993

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090964	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		Yes	\$ 66,643	\$ 7,520,000	\$ 195,164
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	Yes	\$ 144,575	\$ 1,500,000	\$ 425,584
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 276,096	\$ 94,396,814	\$ 575,529
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 7,312	\$ 2,500,000	\$ 14,971
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 107,976	\$ 5,000,000	\$ 221,073
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 354,866	\$ 31,000,000	\$ 899,177
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 240,393	\$ 21,000,000	\$ 492,187
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 70,189	\$ 24,875,000	\$ 146,311
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 22,417	\$ 10,318,679	\$ 46,729
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 790,064	\$ 42,000,000	\$ 2,455,004
					Total	\$ 2,080,531	\$ 240,110,493	\$ 5,471,729
1090965	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		Yes	\$ 19,038	\$ 7,520,000	\$ 55,753
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	Yes	\$ 41,305	\$ 1,500,000	\$ 121,589
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 78,885	\$ 94,396,814	\$ 164,438
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 2,089	\$ 2,500,000	\$ 4,277
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 30,848	\$ 5,000,000	\$ 63,159
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 101,390	\$ 31,000,000	\$ 256,907
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 68,684	\$ 21,000,000	\$ 140,625
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 20,054	\$ 24,875,000	\$ 41,803
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 6,403	\$ 10,318,679	\$ 13,347
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 225,712	\$ 42,000,000	\$ 701,366
					Total	\$ 594,408	\$ 240,110,493	\$ 1,563,264

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090964	ANZIO - FORT JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	Yes
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
1090965	ANZIO - FORT JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	Yes
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090964	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090965	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
 MIDW AG2-2006-107

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
MIDW	1090817	WR	WR	25	6/1/2007	6/1/2017	6/1/2011	6/1/2021			\$ 1,486,045	\$ 4,565,817	
										\$ -	\$ -	\$ 1,486,045	\$ 4,565,817

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090817	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		Yes	\$ 47,585	\$ 7,520,000	\$ 170,342
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	Yes	\$ 103,254	\$ 1,500,000	\$ 358,507
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 197,211	\$ 94,396,814	\$ 492,592
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 5,223	\$ 2,500,000	\$ 11,842
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 77,124	\$ 5,000,000	\$ 174,859
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 253,476	\$ 31,000,000	\$ 734,863
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 171,709	\$ 21,000,000	\$ 389,305
	Tuco - Talk 345kV	6/1/2011	6/1/2011			\$ 50,135	\$ 24,875,000	\$ 125,227
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 16,013	\$ 10,318,879	\$ 39,997
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 564,315	\$ 42,000,000	\$ 2,068,283
Total						\$ 1,486,045	\$ 240,110,493	\$ 4,565,817

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090817	ANZIO - FORT JUNCTION SWITCHING STATION 115KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1	6/1/2007	1/1/2008	10/1/2007	Yes
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	Yes
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090817	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
 MIDW AG2-2006-108

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MIDW	1090826	WR	WR	40	6/1/2008	6/1/2008	6/1/2011	6/1/2031			\$ 2,377,710	\$ 9,700,724
MIDW	1090829	WR	WR	15	6/1/2008	6/1/2008	6/1/2011	6/1/2031			\$ 875,301	\$ 2,899,950
MIDW	1090839	WR	WR	40	6/1/2008	6/1/2018	6/1/2011	6/1/2021			\$ 2,377,710	\$ 7,305,448
MIDW	1090841	WR	WR	40	6/1/2008	6/1/2018	6/1/2011	6/1/2021			\$ 2,377,710	\$ 7,305,448
MIDW	1090844	WR	WR	10	6/1/2008	6/1/2008	6/1/2011	6/1/2031			\$ 594,408	\$ 2,425,089
MIDW	1090852	WR	WR	10	6/1/2008	6/1/2018	6/1/2011	6/1/2021			\$ 594,408	\$ 1,826,293
MIDW	1090853	WR	WR	19	6/1/2008	6/1/2018	6/1/2011	6/1/2021			\$ 1,129,399	\$ 3,470,044
MIDW	1090854	WR	WR	6	6/1/2008	6/1/2018	6/1/2011	6/1/2021			\$ 356,656	\$ 1,095,819
MIDW	1091052	WR	WR	10	6/1/2008	6/1/2013	6/1/2011	6/1/2016			\$ 594,408	\$ 1,563,264
MIDW	1091053	WR	WR	20	6/1/2008	6/1/2013	6/1/2011	6/1/2016			\$ 1,188,854	\$ 3,126,645
MIDW	1091055	WR	WR	30	6/1/2008	6/1/2013	6/1/2011	6/1/2016			\$ 1,783,304	\$ 4,690,033
MIDW	1091057	WR	WR	10	6/1/2008	6/1/2018	6/1/2011	6/1/2021			\$ 594,408	\$ 1,826,293
											\$ -	\$ -
											\$ 14,844,276	\$ 47,235,049

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090826	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 76,152	\$ 7,520,000	\$ 388,132	
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$ 165,219	\$ 1,500,000	\$ 773,168	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 315,538	\$ 94,396,814	\$ 1,088,837	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 8,357	\$ 2,500,000	\$ 22,969	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 123,400	\$ 5,000,000	\$ 339,166	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 405,561	\$ 31,000,000	\$ 1,507,887	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 274,735	\$ 21,000,000	\$ 755,112	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 80,216	\$ 24,875,000	\$ 276,804	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 25,613	\$ 10,318,679	\$ 88,384	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 902,919	\$ 42,000,000	\$ 4,460,263	
						Total	\$ 2,377,710	\$ 240,110,493	\$ 9,700,724
1090829	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 29,052	\$ 7,520,000	\$ 112,894	
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$ 45,106	\$ 1,500,000	\$ 169,795	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 118,327	\$ 94,396,814	\$ 320,878	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 3,134	\$ 2,500,000	\$ 7,569	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 46,276	\$ 5,000,000	\$ 111,767	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 152,085	\$ 31,000,000	\$ 475,094	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 103,026	\$ 21,000,000	\$ 248,832	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 30,081	\$ 24,875,000	\$ 81,573	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 9,610	\$ 10,318,679	\$ 26,600	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 338,604	\$ 42,000,000	\$ 1,345,487	
						Total	\$ 875,301	\$ 240,110,493	\$ 2,899,950
1090839	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 76,152	\$ 7,520,000	\$ 272,604	
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$ 165,219	\$ 1,500,000	\$ 573,654	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 315,538	\$ 94,396,814	\$ 788,149	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 8,357	\$ 2,500,000	\$ 18,947	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 123,400	\$ 5,000,000	\$ 279,777	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 405,561	\$ 31,000,000	\$ 1,175,779	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 274,735	\$ 21,000,000	\$ 622,890	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 80,216	\$ 24,875,000	\$ 200,363	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 25,613	\$ 10,318,679	\$ 63,976	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 902,919	\$ 42,000,000	\$ 3,309,308	
						Total	\$ 2,377,710	\$ 240,110,493	\$ 7,305,448
1090841	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 76,152	\$ 7,520,000	\$ 272,604	
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$ 165,219	\$ 1,500,000	\$ 573,654	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 315,538	\$ 94,396,814	\$ 788,149	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 8,357	\$ 2,500,000	\$ 18,947	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 123,400	\$ 5,000,000	\$ 279,777	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 405,561	\$ 31,000,000	\$ 1,175,779	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 274,735	\$ 21,000,000	\$ 622,890	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 80,216	\$ 24,875,000	\$ 200,363	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 25,613	\$ 10,318,679	\$ 63,976	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 902,919	\$ 42,000,000	\$ 3,309,308	
						Total	\$ 2,377,710	\$ 240,110,493	\$ 7,305,448
1090844	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 19,038	\$ 7,520,000	\$ 97,033	
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$ 41,305	\$ 1,500,000	\$ 193,293	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 78,885	\$ 94,396,814	\$ 272,211	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 2,089	\$ 2,500,000	\$ 5,742	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 30,848	\$ 5,000,000	\$ 84,786	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 101,390	\$ 31,000,000	\$ 376,971	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 68,684	\$ 21,000,000	\$ 188,779	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 20,054	\$ 24,875,000	\$ 69,201	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 6,403	\$ 10,318,679	\$ 22,095	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 225,712	\$ 42,000,000	\$ 1,114,978	
						Total	\$ 594,408	\$ 240,110,493	\$ 2,425,089
1090852	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 19,038	\$ 7,520,000	\$ 68,151	
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$ 41,305	\$ 1,500,000	\$ 143,414	

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$	-	\$	-
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$	78,885	\$	94,396,814
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$	2,089	\$	2,500,000
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$	30,848	\$	5,000,000
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$	101,390	\$	31,000,000
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$	68,684	\$	21,000,000
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$	20,054	\$	24,875,000
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$	6,403	\$	10,318,679
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$	225,712	\$	42,000,000
					Total	\$	594,408	\$	240,110,493
1090853	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$	36,174	\$	7,520,000
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$	78,474	\$	1,500,000
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$	-	\$	-
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$	149,892	\$	94,396,814
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$	3,970	\$	2,500,000
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$	58,614	\$	5,000,000
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$	192,637	\$	31,000,000
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$	130,496	\$	21,000,000
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$	38,098	\$	24,875,000
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$	12,163	\$	10,318,679
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$	428,881	\$	42,000,000
					Total	\$	1,128,399	\$	240,110,493
1090854	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$	11,431	\$	7,520,000
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$	24,780	\$	1,500,000
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$	-	\$	-
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$	47,319	\$	94,396,814
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$	1,253	\$	2,500,000
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$	18,510	\$	5,000,000
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$	60,839	\$	31,000,000
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$	41,213	\$	21,000,000
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$	12,037	\$	24,875,000
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$	3,840	\$	10,318,679
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$	135,434	\$	42,000,000
					Total	\$	356,656	\$	240,110,493
1091052	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$	19,038	\$	7,520,000
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$	41,305	\$	1,500,000
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$	78,885	\$	94,396,814
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$	2,089	\$	2,500,000
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$	30,848	\$	5,000,000
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$	101,390	\$	31,000,000
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$	68,684	\$	21,000,000
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$	20,054	\$	24,875,000
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$	6,403	\$	10,318,679
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$	225,712	\$	42,000,000
					Total	\$	951,064	\$	480,220,986
1091053	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$	38,076	\$	7,520,000
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$	82,610	\$	1,500,000
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$	157,769	\$	94,396,814
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$	4,178	\$	2,500,000
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$	61,700	\$	5,000,000
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$	202,780	\$	31,000,000
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$	137,367	\$	21,000,000
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$	40,108	\$	24,875,000
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$	12,806	\$	10,318,679
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$	451,460	\$	42,000,000
					Total	\$	2,139,918	\$	720,331,479
1091055	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$	57,114	\$	7,520,000
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$	123,914	\$	1,500,000
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$	236,654	\$	94,396,814
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$	6,268	\$	2,500,000
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$	92,552	\$	5,000,000
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$	304,171	\$	31,000,000
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$	206,051	\$	21,000,000
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$	60,162	\$	24,875,000
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$	19,210	\$	10,318,679
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$	677,208	\$	42,000,000
					Total	\$	3,923,222	\$	960,441,972
1091057	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$	19,038	\$	7,520,000
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$	41,305	\$	1,500,000
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$	-	\$	-
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$	78,885	\$	94,396,814
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$	2,089	\$	2,500,000
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$	30,848	\$	5,000,000
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$	101,390	\$	31,000,000
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$	68,684	\$	21,000,000
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$	20,054	\$	24,875,000
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$	6,403	\$	10,318,679
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$	225,712	\$	42,000,000
					Total	\$	594,408	\$	240,110,493



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
 MIDW AG2-2006-108

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090826	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
1090829	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
1090839	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
1090841	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
1090844	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
1090852	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
1090853	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
1090854	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
1091052	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
1091053	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
1091055	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
1091057	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090826	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090829	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090839	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090841	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090844	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090852	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090853	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1090854	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091052	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091053	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091055	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
1091057	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
 MIDW AG2-2006-109

Customer	Reservation	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MIDW	1090851	5	6/1/2011	6/1/2031					\$ 291,752	\$ 1,187,093
MIDW	1090855	15	6/1/2011	6/1/2021					\$ 875,301	\$ 2,682,856
MIDW	1090856	5	6/1/2011	6/1/2021					\$ 291,752	\$ 894,229
									\$ 1,458,805	\$ 4,764,178

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090851	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 9,684	\$ 7,520,000	\$ 49,358
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$ 15,030	\$ 1,500,000	\$ 70,335
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 39,442	\$ 94,396,814	\$ 136,104
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,045	\$ 2,500,000	\$ 2,872
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 15,424	\$ 5,000,000	\$ 42,393
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 50,695	\$ 31,000,000	\$ 188,485
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 34,342	\$ 21,000,000	\$ 94,389
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 10,027	\$ 24,875,000	\$ 34,601
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 3,207	\$ 10,318,679	\$ 11,067
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		No	\$ 112,856	\$ 42,000,000	\$ 557,489
					Total	\$ 291,752	\$ 240,110,493	\$ 1,187,093
	1090855	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 29,052	\$ 7,520,000
GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1		6/1/2007	2/1/2008	10/1/2007	No	\$ 45,106	\$ 1,500,000	\$ 156,612
HEIZER 115/69KV TRANSFORMER CKT 2		6/1/2016	6/1/2016			\$ -	\$ -	\$ -
Mooreland - TUCO 345 kV SPS		6/1/2011	6/1/2011			\$ 118,327	\$ 94,396,814	\$ 295,556
Mooreland - TUCO 345 kV WFEC		6/1/2011	6/1/2011			\$ 3,134	\$ 2,500,000	\$ 7,106
Mooreland 345/138 kV Transformer		6/1/2011	6/1/2011			\$ 46,276	\$ 5,000,000	\$ 104,919
Spearville - Mooreland 345 kV SUNC		6/1/2011	6/1/2011			\$ 152,085	\$ 31,000,000	\$ 440,916
Spearville - Mooreland 345 kV WFEC		6/1/2011	6/1/2011			\$ 103,026	\$ 21,000,000	\$ 233,585
Tuco - Tolk 345kV		6/1/2011	6/1/2011			\$ 30,081	\$ 24,875,000	\$ 75,136
TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1		6/1/2011	6/1/2011			\$ 9,610	\$ 10,318,679	\$ 24,004
WICHITA - RENO 345KV		10/1/2006	6/1/2011		No	\$ 338,604	\$ 42,000,000	\$ 1,241,025
					Total	\$ 875,301	\$ 240,110,493	\$ 2,682,856
1090856		CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 9,684	\$ 7,520,000
	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1	6/1/2007	2/1/2008	10/1/2007	No	\$ 15,030	\$ 1,500,000	\$ 52,185
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 39,442	\$ 94,396,814	\$ 98,518
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,045	\$ 2,500,000	\$ 2,369
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 15,424	\$ 5,000,000	\$ 34,970
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 50,695	\$ 31,000,000	\$ 146,972
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 34,342	\$ 21,000,000	\$ 77,862
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 10,027	\$ 24,875,000	\$ 25,045
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 3,207	\$ 10,318,679	\$ 8,010
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		No	\$ 112,856	\$ 42,000,000	\$ 413,631
					Total	\$ 291,752	\$ 240,110,493	\$ 894,229

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090851	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
1090855	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
1090856	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090851	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
1090855	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
1090856	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
MIDW AG2-2006-110

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements		
MIDW	1090759	WR	WR	5	6/1/2015	6/1/2025					\$ 160,982	\$ 544,302		
MIDW	1091068	WR	WR	15	6/1/2015	6/1/2025					\$ 482,954	\$ 1,633,011		
											\$ -	\$ -	\$ 643,936	\$ 2,177,313

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090759	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 9,703	\$ 7,520,000	\$ 49,881	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 39,272	\$ 94,396,814	\$ 135,293	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,040	\$ 2,500,000	\$ 2,802	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 15,032	\$ 5,000,000	\$ 40,496	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 49,486	\$ 31,000,000	\$ 180,987	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 33,522	\$ 21,000,000	\$ 90,309	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 9,805	\$ 24,875,000	\$ 33,779	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 3,122	\$ 10,318,679	\$ 10,755	
						Total	\$ 160,982	\$ 196,610,493	\$ 544,302
1091068	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 29,149	\$ 7,520,000	\$ 149,849	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 117,817	\$ 94,396,814	\$ 405,883	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 3,120	\$ 2,500,000	\$ 8,405	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 45,092	\$ 5,000,000	\$ 121,478	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 148,433	\$ 31,000,000	\$ 542,870	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 100,551	\$ 21,000,000	\$ 270,885	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 29,403	\$ 24,875,000	\$ 101,294	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 9,389	\$ 10,318,679	\$ 32,345	
						Total	\$ 482,954	\$ 196,610,493	\$ 1,633,011

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090759	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		
1091068	COUNTY LINE - HOOK JCT 115KV CKT 1	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	6/1/2011	6/1/2011		
	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	6/1/2009	6/1/2009		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090759	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		
1091068	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
MIDW AG2-2006-118

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
MIDW	1090959	SECI	WR	75	6/1/2011	6/1/2041					\$ 7,287,440	\$ 41,117,136	
										\$ -	\$ -	\$ 7,287,440	\$ 41,117,136

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090959	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		No	\$ 3,286	\$ 1,515,113	\$ 19,071	
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 22,061	\$ 153,114	\$ 168,140	
	HEIZER 115/69KV TRANSFORMER CKT 2	6/1/2016	6/1/2016			\$ -	\$ -	\$ -	
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 350,616	\$ 14,795,676	\$ 2,016,204	
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 15,420	\$ 100,000	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 189,164	\$ 94,396,814	\$ 860,118	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 5,010	\$ 2,500,000	\$ 16,447	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 268,487	\$ 5,000,000	\$ 881,387	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 632,461	\$ 38,504,390	\$ 3,670,707	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 6,738	\$ 3,200,000	\$ 50,714	
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 150,218	\$ 3,700,000	\$ 876,779	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 698,809	\$ 31,000,000	\$ 3,245,936	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 473,387	\$ 21,000,000	\$ 1,554,031	
	Tex-Hitchland-Sherman Tap 115 kV ckt	4/1/2007	6/1/2010		No	\$ 32,525	\$ 2,401,645	\$ 187,034	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 338,598	\$ 24,875,000	\$ 1,539,586	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 108,665	\$ 10,318,679	\$ 494,093	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		No	\$ 3,989,995	\$ 42,000,000	\$ 25,536,891	
						Total	\$ 7,287,440	\$ 295,460,431	\$ 41,117,136

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090959	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090959	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Customer** Study Number  
OGE AG2-2006-035

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
OGE	1087908	OKGE	EES	10	12/1/2006	12/1/2011	6/1/2009	6/1/2014			\$ 5,760,802	\$ 10,334,754	
										\$ -	\$ -	\$ 5,760,802	\$ 10,334,754

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1087908	5 TRIBES - PECAN CREEK 161KV CKT 1	6/1/2008	6/1/2009		Yes	\$ 791,809	\$ 1,200,000	\$ 1,419,479	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 16,823	\$ 2,500,000	\$ 35,704	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 3,365	\$ 500,000	\$ 7,828	
	PECAN CREEK (PECANCK1) 345/161/13.8KV TRANSFORMER CKT 1	6/1/2008	6/1/2009		Yes	\$ 4,948,805	\$ 7,500,000	\$ 8,871,743	
						Total	\$ 5,760,802	\$ 11,700,000	\$ 10,334,754

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1087908	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		

Third Party Limitations

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	
1087908	4LUTHER 138 (LUTHER) 138/69/13.8KV TRANSFORMER CKT 1	6/1/2008	6/1/2008			\$ 1,075,000	\$ 1,075,000	
						Total	\$ 1,075,000	\$ 1,075,000

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
PNMM AG2-2006-089

Customer	Reservation	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
PNMM	1090813	75	6/1/2011	6/1/2041					\$ 23,187,694	\$ 112,564,311
PNMM	1090814	75	6/1/2011	6/1/2041					\$ 23,187,694	\$ 112,564,311
									\$ -	\$ -
									\$ 46,375,388	\$ 225,128,621

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090813	ALTUS JCT TAP - RUSSELL 138KV CKT 1	6/1/2011	6/1/2011			\$ 150,001	\$ 3,125,000	\$ 479,905
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 6,114	\$ 153,114	\$ 46,598
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 780,280	\$ 14,795,676	\$ 4,486,970
	LEA COUNTY INTERCHANGE 230KV CAPACITORS	4/1/2008	4/1/2008			\$ 133,534	\$ 1,381,023	\$ 723,782
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 4,273	\$ 100,000	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 8,933,160	\$ 94,396,814	\$ 40,618,563
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 236,585	\$ 2,500,000	\$ 776,659
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 107,289	\$ 5,000,000	\$ 352,207
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 6,658,054	\$ 38,504,390	\$ 38,642,330
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 2,183,100	\$ 31,000,000	\$ 10,140,399
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,478,874	\$ 21,000,000	\$ 4,854,835
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 2,150,160	\$ 24,875,000	\$ 9,776,653
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 366,270	\$ 10,318,679	\$ 1,665,409
Total						\$ 23,187,694	\$ 247,149,696	\$ 112,564,311
1090814	ALTUS JCT TAP - RUSSELL 138KV CKT 1	6/1/2011	6/1/2011			\$ 150,001	\$ 3,125,000	\$ 479,905
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 6,114	\$ 153,114	\$ 46,598
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 780,280	\$ 14,795,676	\$ 4,486,970
	LEA COUNTY INTERCHANGE 230KV CAPACITORS	4/1/2008	4/1/2008			\$ 133,534	\$ 1,381,023	\$ 723,782
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 4,273	\$ 100,000	\$ -
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 8,933,160	\$ 94,396,814	\$ 40,618,563
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 236,585	\$ 2,500,000	\$ 776,659
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 107,289	\$ 5,000,000	\$ 352,207
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 6,658,054	\$ 38,504,390	\$ 38,642,330
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 2,183,100	\$ 31,000,000	\$ 10,140,399
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,478,874	\$ 21,000,000	\$ 4,854,835
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 2,150,160	\$ 24,875,000	\$ 9,776,653
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 366,270	\$ 10,318,679	\$ 1,665,409
Total						\$ 23,187,694	\$ 247,149,696	\$ 112,564,311

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090813	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No
	SNYDER AEPW- SNYDER WFEC INTERCONNECTION	6/1/2015	6/1/2015		
	Stateline Project	6/1/2014	6/1/2014		
1090814	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No
	SNYDER AEPW- SNYDER WFEC INTERCONNECTION	6/1/2015	6/1/2015		
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090813	TUCO INTERCHANGE 230KV #1	6/1/2007	6/1/2007		
	TUCO INTERCHANGE 230KV #2	6/1/2008	6/1/2008		
1090814	TUCO INTERCHANGE 230KV #1	6/1/2007	6/1/2007		
	TUCO INTERCHANGE 230KV #2	6/1/2008	6/1/2008		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer** Study Number  
SEPC AG2-2006-043

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
SEPC	1090236	SECI	WPEK	150	6/1/2011	6/1/2041					\$ 16,095,050	\$ 91,652,453	
										\$ -	\$ -	\$ 16,095,050	\$ 91,652,453

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090236	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 1,003,273	\$ 2,500,000	\$ 5,983,972	
	CLAY CENTER - GREENLEAF 115KV CKT 1	6/1/2007	12/1/2007		No	\$ 3,541,383	\$ 7,520,000	\$ 24,249,228	
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		No	\$ 6,648	\$ 1,515,113	\$ 38,584	
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		No	\$ 2,713	\$ 153,114	\$ 20,677	
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 1,674,447	\$ 14,795,676	\$ 9,628,844	
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 1,896	\$ 100,000	\$ -	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 669,838	\$ 94,396,814	\$ 3,045,715	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 17,740	\$ 2,500,000	\$ 58,237	
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 487,821	\$ 5,000,000	\$ 1,601,415	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 1,214,666	\$ 38,504,390	\$ 7,049,736	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 17,477	\$ 3,200,000	\$ 101,434	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 1,334,648	\$ 31,000,000	\$ 6,199,379	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 904,116	\$ 21,000,000	\$ 2,968,024	
	Tex-Hitchland-Sherman Tap 115 kV ckt	4/1/2007	6/1/2010		No	\$ 804,483	\$ 2,401,645	\$ 4,626,149	
	TRI COUNTY PRAIRIE Interconnection #1	7/1/2007	7/1/2007			\$ -	\$ -	\$ -	
	TRI COUNTY PRAIRIE Interconnection #2	7/1/2007	6/1/2008		No	\$ 812,516	\$ 1,500,000	\$ 4,604,205	
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 642,971	\$ 24,875,000	\$ 2,923,552	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 205,705	\$ 10,318,679	\$ 935,329	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		No	\$ 2,752,709	\$ 42,000,000	\$ 17,617,974	
						Total	\$ 16,095,050	\$ 303,280,431	\$ 91,652,453

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090236	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090236	TUCO INTERCHANGE 230KV #1	6/1/2007	6/1/2007		
	TUCO INTERCHANGE 230KV #2	6/1/2008	6/1/2008		

**Customer** Study Number  
SHDY AG2-2006-019

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
SHDY	1085305	OKGE	CSWS	320	1/8/2008	1/8/2009	6/1/2010	6/1/2011			\$ 21,608,260	\$ 42,785,449	
										\$ -	\$ -	\$ 21,608,260	\$ 42,785,449

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1085305	SW SHREVEPORT EXPANSION	6/1/2008	6/1/2010		Yes	\$ 21,608,260	\$ 40,000,000	\$ 42,785,449	
						Total	\$ 21,608,260	\$ 40,000,000	\$ 42,785,449

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1085305	LINWOOD - MCWILLIE STREET 138KV CKT 1	6/1/2007	4/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
SPSM AG2-2006-072

Customer	Reservation	1090680	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SPSM		1090680	CSWS	BLKW	50	10/1/2006	3/1/2012	6/1/2011	6/1/2016			\$ 13,536,837	\$ 31,793,260
										\$ -	\$ -	\$ 13,536,837	\$ 31,793,260

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090680	ALTUS JCT TAP - RUSSELL 138KV CKT 1	6/1/2011	6/1/2011			\$ 272,235	\$ 3,125,000	\$ 543,213	
	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 180,333	\$ 2,500,000	\$ 460,008	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 73,824	\$ 2,500,000	\$ 184,753	
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 14,765	\$ 500,000	\$ 39,713	
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 177,530	\$ 14,795,676	\$ 468,018	
	LEA COUNTY INTERCHANGE 230KV CAPACITORS	4/1/2008	4/1/2008			\$ 71,370	\$ 1,381,023	\$ 177,345	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 5,282,088	\$ 94,396,814	\$ 11,010,644	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 139,891	\$ 2,500,000	\$ 286,417	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 3,713,724	\$ 38,504,390	\$ 9,881,281	
	Speanville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 184,577	\$ 31,000,000	\$ 467,691	
	Speanville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 125,036	\$ 21,000,000	\$ 256,002	
	SPS MUST RUN GENERATION #2	10/1/2006	10/1/2006			\$ -	\$ -	\$ -	
	SPS MUST RUN GENERATION #3	10/1/2007	10/1/2007			\$ -	\$ -	\$ -	
	SPS MUST RUN GENERATION #4	6/1/2007	6/1/2007			\$ -	\$ -	\$ -	
	SPS MUST RUN GENERATION #5	12/1/2008	12/1/2008			\$ -	\$ -	\$ -	
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 1,822,551	\$ 24,875,000	\$ 3,799,153	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 368,074	\$ 10,318,679	\$ 767,259	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 1,110,839	\$ 42,000,000	\$ 3,451,764	
						Total	\$ 13,536,837	\$ 289,396,582	\$ 31,793,260

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090680	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		No
	SNYDER AEPW- SNYDER WFEC INTERCONNECTION	6/1/2015	6/1/2015		
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090680	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
	TUCO INTERCHANGE 230KV #1	6/1/2007	6/1/2007		
	TUCO INTERCHANGE 230KV #2	6/1/2008	6/1/2008		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
SPSM AG2-2006-073

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
SPSM	1090695	OKGE	EDDY	30	1/1/2007	1/1/2013	6/1/2011	6/1/2017			\$ 8,335,070	\$ 19,757,289	
										\$ -	\$ -	\$ 8,335,070	\$ 19,757,289

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
1090695	ALTUS JCT TAP - RUSSELL 138KV CKT 1	6/1/2011	6/1/2011			\$ 146,095	\$ 3,125,000	\$ 297,610	
	CANADIAN - CEDAR LANE 138KV CKT 1	6/1/2014	6/1/2014			\$ 32,035	\$ 50,000	\$ -	
	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 91,819	\$ 2,500,000	\$ 244,138	
	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	6/1/2016	6/1/2016			\$ 12,790	\$ 100,000	\$ -	
	Hitchland 345 and 115 kV Interchange	4/1/2007	6/1/2010		No	\$ 113,023	\$ 14,795,676	\$ 309,256	
	LAKE PAULINE - RUSSELL 138KV CKT 1	6/1/2016	6/1/2016			\$ 4,136	\$ 50,000	\$ -	
	LEA COUNTY INTERCHANGE 230KV CAPACITORS	4/1/2008	4/1/2008			\$ 558,680	\$ 1,381,023	\$ 1,440,880	
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 3,564,650	\$ 94,396,814	\$ 7,712,322	
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 94,406	\$ 2,500,000	\$ 197,331	
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 1,199,299	\$ 38,504,390	\$ 3,312,015	
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 13,928	\$ 3,200,000	\$ 38,464	
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 107,786	\$ 31,000,000	\$ 280,722	
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 73,016	\$ 21,000,000	\$ 152,621	
	SPS MUST RUN GENERATION #3	10/1/2007	10/1/2007			\$ -	\$ -	\$ -	
	SPS MUST RUN GENERATION #4	6/1/2007	6/1/2007			\$ -	\$ -	\$ -	
	SPS MUST RUN GENERATION #5	12/1/2008	12/1/2008			\$ -	\$ -	\$ -	
	Tuco - Tolk 345KV	6/1/2011	6/1/2011			\$ 1,405,883	\$ 24,875,000	\$ 3,041,707	
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 208,458	\$ 10,318,679	\$ 451,011	
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 709,066	\$ 42,000,000	\$ 2,279,212	
						Total	\$ 8,335,070	\$ 289,796,582	\$ 19,757,289

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090695	BOOKER 69KV	6/1/2016	6/1/2016		
	CARTER JCT CAPACITOR	6/1/2011	6/1/2011		
	MUSTANG STATION 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2008		Yes
	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009		Yes
	SNYDER AEPW- SNYDER WFEC INTERCONNECTION	6/1/2015	6/1/2015		
	Stateline Project	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090695	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No
	TUCO INTERCHANGE 230KV #1	6/1/2007	6/1/2007		
	TUCO INTERCHANGE 230KV #2	6/1/2008	6/1/2008		



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
SPSM AG2-2006-074

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SPSM	1090699	WPEK	KCPL	50	10/1/2006	10/1/2007	6/1/2010	6/1/2011	\$ -	\$ -	\$ 1,627,474	\$ 3,497,710
									\$ -	\$ -	\$ 1,627,474	\$ 3,497,710

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090699	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 261,056	\$ 2,500,000	\$ 511,757
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 1,959	\$ 1,515,113	\$ 4,122
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		Yes	\$ 21,008	\$ 153,114	\$ 52,625
	Hitchland 345 and 115 KV Interchange	4/1/2007	6/1/2010		No	\$ 101,717	\$ 14,795,676	\$ 212,050
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 14,684	\$ 100,000	\$ -
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	Yes	\$ 665,752	\$ 2,200,000	\$ 1,580,869
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 315,530	\$ 38,504,390	\$ 663,893
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 4,990	\$ 3,200,000	\$ 10,499
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 240,778	\$ 3,700,000	\$ 461,897
Total						\$ 1,627,474	\$ 66,668,293	\$ 3,497,710

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090699	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1	12/1/2006	1/1/2009		Yes
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090699	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Customer Study Number**  
SPSM AG2-2006-124

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SPSM	1090705	WPEK	KCPL	50	10/1/2006	10/1/2007	6/1/2010	6/1/2011	\$ -	\$ -	\$ 1,627,474	\$ 3,497,710
									\$ -	\$ -	\$ 1,627,474	\$ 3,497,710

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090705	Cimarron Plant Substation Expansion	6/1/2009	6/1/2009			\$ 261,056	\$ 2,500,000	\$ 511,757
	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	4/1/2007	6/1/2010		Yes	\$ 1,959	\$ 1,515,113	\$ 4,122
	GREENSBURG - JUDSON LARGE 115KV CKT 1	10/1/2006	6/1/2007		Yes	\$ 21,008	\$ 153,114	\$ 52,625
	Hitchland 345 and 115 KV Interchange	4/1/2007	6/1/2010		No	\$ 101,717	\$ 14,795,676	\$ 212,050
	MEDICINE LODGE - SUN CITY 115KV CKT 1	6/1/2007	6/1/2007			\$ 14,684	\$ 100,000	\$ -
	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1	10/1/2007	3/1/2008	12/1/2007	Yes	\$ 665,752	\$ 2,200,000	\$ 1,580,869
	Potter - Roosevelt 345KV	4/1/2007	6/1/2010		No	\$ 315,530	\$ 38,504,390	\$ 663,893
	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	4/1/2007	6/1/2010		No	\$ 4,990	\$ 3,200,000	\$ 10,499
	SEWARD - ST JOHN 115KV CKT 1	6/1/2008	6/1/2008			\$ 240,778	\$ 3,700,000	\$ 461,897
Total						\$ 1,627,474	\$ 66,668,293	\$ 3,497,710

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090705	HAYS PLANT - SOUTH HAYS 115KV CKT 1	6/1/2007	6/1/2009	10/1/2008	No
	MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1	12/1/2006	1/1/2009		Yes
	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	10/1/2007	4/1/2008	12/1/2007	Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090705	ST JOHN CAPACITOR	6/1/2007	6/1/2008	10/1/2007	No

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
UCU AG2-2006-006

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
UCU	1052923	KCPL	MPS	160	6/1/2010	6/1/2030					\$ 3,508,815	\$ 12,494,574	
										\$ -	\$ -	\$ 3,508,815	\$ 12,494,574

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1052923	HARRISONVILLE 161/69KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 1,067,111	\$ 2,100,000	\$ 2,448,967
	IATAN - STRANGER CREEK 345KV CKT 2	6/1/2011	6/1/2011			\$ 2,373,070	\$ 4,123,803	\$ 10,045,607
	PLATTE CITY - POPE 161 161KV CKT 1	12/1/2011	12/1/2011			\$ 68,634	\$ 100,000	\$ -
Total						\$ 3,508,815	\$ 6,323,803	\$ 12,494,574

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1052923	ANACONDA - FREEMAN 69KV CKT 1	6/1/2011	6/1/2011		
	ANACONDA - HARRISONVILLE WEST 69KV CKT 1	6/1/2011	6/1/2011		
	BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1	6/1/2011	6/1/2011		
	EAST 20MVAR CAPACITOR	6/1/2011	6/1/2011		
	GRANDVIEW EAST - MARTIN CITY 161KV CKT 1	12/1/2011	12/1/2011		
	HARRISONVILLE NORTH - RALPH GREEN 69KV CKT 1	6/1/2011	6/1/2011		
	MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1	12/1/2006	1/1/2009		No
	RALPH GREEN CAPACITOR	6/1/2011	6/1/2011		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1052923	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		

Customer Study Number  
UCU AG2-2006-071

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
UCU	1090573	EES	MPS	100	6/1/2010	6/1/2040					\$ 1,395,513	\$ 5,972,051	
UCU	1090578	EES	MPS	50	6/1/2010	6/1/2040					\$ 743,070	\$ 3,230,030	
										\$ -	\$ -	\$ 2,138,583	\$ 9,202,080

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1090573	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 209,421	\$ 2,500,000	\$ 1,068,096
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 41,884	\$ 500,000	\$ 215,798
	HARRISONVILLE 161/69KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 688,593	\$ 2,100,000	\$ 2,107,760
	IATAN - STRANGER CREEK 345KV CKT 2	6/1/2011	6/1/2011			\$ 455,615	\$ 4,123,803	\$ 2,580,396
Total						\$ 1,395,513	\$ 9,223,803	\$ 5,972,051
1090578	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 123,690	\$ 2,500,000	\$ 630,848
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 24,738	\$ 500,000	\$ 127,457
	HARRISONVILLE 161/69KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 344,296	\$ 2,100,000	\$ 1,053,879
	IATAN - STRANGER CREEK 345KV CKT 2	6/1/2011	6/1/2011			\$ 250,346	\$ 4,123,803	\$ 1,417,846
Total						\$ 743,070	\$ 9,223,803	\$ 3,230,030

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1090573	ANACONDA - FREEMAN 69KV CKT 1	6/1/2011	6/1/2011		
	ANACONDA - HARRISONVILLE WEST 69KV CKT 1	6/1/2011	6/1/2011		
	BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1	6/1/2011	6/1/2011		
	EAST 20MVAR CAPACITOR	6/1/2011	6/1/2011		
	GRANDVIEW EAST - MARTIN CITY 161KV CKT 1	12/1/2011	12/1/2011		
	HARRISONVILLE NORTH - RALPH GREEN 69KV CKT 1	6/1/2011	6/1/2011		
	MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1	12/1/2006	1/1/2009		No
	RALPH GREEN CAPACITOR	6/1/2011	6/1/2011		
1090578	ANACONDA - FREEMAN 69KV CKT 1	6/1/2011	6/1/2011		
	ANACONDA - HARRISONVILLE WEST 69KV CKT 1	6/1/2011	6/1/2011		
	BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1	6/1/2011	6/1/2011		
	EAST 20MVAR CAPACITOR	6/1/2011	6/1/2011		
	GRANDVIEW EAST - MARTIN CITY 161KV CKT 1	12/1/2011	12/1/2011		
	HARRISONVILLE NORTH - RALPH GREEN 69KV CKT 1	6/1/2011	6/1/2011		
	RALPH GREEN CAPACITOR	6/1/2011	6/1/2011		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

**Customer Study Number**  
WRGS AG2-2006-015

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
WRGS	1076157	KCPL	AECI	30	6/1/2010	6/1/2015					\$ 354,974	\$ 850,640	
										\$ -	\$ -	\$ 354,974	\$ 850,640

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1076157	IATAN - STRANGER CREEK 345KV CKT 2	6/1/2011	6/1/2011			\$ 345,910	\$ 4,123,803	\$ 850,640
	PLATTE CITY - POPE 161 161KV CKT 1	12/1/2011	12/1/2011			\$ 9,064	\$ 100,000	-
<b>Total</b>						<b>\$ 354,974</b>	<b>\$ 4,223,803</b>	<b>\$ 850,640</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1076157	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	GRANDVIEW EAST - MARTIN CITY 161KV CKT 1	12/1/2011	12/1/2011		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1076157	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		

**Customer Study Number**  
WRGS AG2-2006-016

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
WRGS	1076158	KCPL	AMRN	20	6/1/2010	6/1/2015					\$ 236,650	\$ 567,094	
										\$ -	\$ -	\$ 236,650	\$ 567,094

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1076158	IATAN - STRANGER CREEK 345KV CKT 2	6/1/2011	6/1/2011			\$ 230,607	\$ 4,123,803	\$ 567,094
	PLATTE CITY - POPE 161 161KV CKT 1	12/1/2011	12/1/2011			\$ 6,043	\$ 100,000	-
<b>Total</b>						<b>\$ 236,650</b>	<b>\$ 4,223,803</b>	<b>\$ 567,094</b>

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1076158	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	6/1/2010	6/1/2010		
	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		
	GRANDVIEW EAST - MARTIN CITY 161KV CKT 1	12/1/2011	12/1/2011		
	KELLY - KING HILL N.M. COOP 115KV CKT 1	6/1/2010	6/1/2010		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1076158	IATAN - ST JOE 345KV CKT 1	6/1/2011	6/1/2011		

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated costs for Each Upgrade**

Customer Study Number  
WRGS AG2-2006-030

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date	Deferred Stop Date	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
WRGS	1086655	OKGE	WR	228	10/1/2006	10/1/2026	6/1/2011	6/1/2031			\$ 35,223,057	\$ 141,994,153	
WRGS	1086656	OKGE	WR	75	10/1/2006	10/1/2026	6/1/2011	6/1/2031			\$ 11,741,039	\$ 47,331,534	
										\$ -	\$ -	\$ 46,964,096	\$ 189,325,687

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1086655	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 3,633,509	\$ 6,000,000	\$ 15,780,720
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 1,161,425	\$ 2,500,000	\$ 4,861,302
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 232,285	\$ 500,000	\$ 993,217
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 5,571,381	\$ 9,200,000	\$ 24,197,040
	CONTINENTAL BLACKS - OSAGE 69KV CKT 1	6/1/2012	6/1/2012			\$ 150,002	\$ 200,000	\$ 572,482
	CRESWELL - NEWKIRK 138KV CKT 1 OKGE	6/1/2012	6/1/2012			\$ 2,171,152	\$ 4,500,000	\$ 8,648,530
	CRESWELL - NEWKIRK 138KV CKT 1 WERE	6/1/2012	6/1/2012			\$ 2,286,947	\$ 4,740,000	\$ 7,701,273
	CRESWELL (CRESWL2X) 138/69/13.2KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 936,408	\$ 4,000,000	\$ 3,347,164
	EEC - COWSKIN 138KV	6/1/2009	6/1/2009			\$ 6,083,362	\$ 10,000,000	\$ 24,435,787
	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	6/1/2016	6/1/2016			\$ 59,083	\$ 100,000	\$ -
	GILL ENERGY CENTER EAST - INTERSTATE 138KV CKT 1	6/1/2009	6/1/2009			\$ 15,000	\$ 20,000	\$ -
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 941,243	\$ 2,250,000	\$ 2,747,720
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 1,794,679	\$ 94,396,814	\$ 6,192,958
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 47,530	\$ 2,500,000	\$ 130,637
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 517,668	\$ 5,000,000	\$ 1,422,816
	REPLACE HOOVER BREAKER	6/1/2009	6/1/2009			\$ 74,999	\$ 100,000	\$ -
	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER	6/1/2007	3/1/2008	10/1/2007	Yes	\$ 1,382,211	\$ 4,000,000	\$ 6,223,647
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 1,803,791	\$ 31,000,000	\$ 6,706,546
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 1,221,923	\$ 21,000,000	\$ 3,358,469
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 361,304	\$ 24,875,000	\$ 1,246,764
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 114,994	\$ 10,318,679	\$ 396,814
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 4,662,161	\$ 42,000,000	\$ 23,030,268
					Total	\$ 35,223,057	\$ 279,200,493	\$ 141,994,153
1086656	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 1,211,170	\$ 6,000,000	\$ 5,260,320
	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	6/1/2009	6/1/2009			\$ 387,139	\$ 2,500,000	\$ 1,620,423
	COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE	6/1/2009	6/1/2009			\$ 77,428	\$ 500,000	\$ 331,071
	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	6/1/2016	6/1/2016			\$ 1,857,127	\$ 9,200,000	\$ 8,065,680
	CONTINENTAL BLACKS - OSAGE 69KV CKT 1	6/1/2012	6/1/2012			\$ 49,998	\$ 200,000	\$ 190,817
	CRESWELL - NEWKIRK 138KV CKT 1 OKGE	6/1/2012	6/1/2012			\$ 723,721	\$ 4,500,000	\$ 2,882,858
	CRESWELL - NEWKIRK 138KV CKT 1 WERE	6/1/2012	6/1/2012			\$ 762,320	\$ 4,740,000	\$ 2,567,106
	CRESWELL (CRESWL2X) 138/69/13.2KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 312,128	\$ 4,000,000	\$ 1,115,693
	EEC - COWSKIN 138KV	6/1/2009	6/1/2009			\$ 2,027,837	\$ 10,000,000	\$ 8,145,462
	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	6/1/2016	6/1/2016			\$ 19,694	\$ 100,000	\$ -
	GILL ENERGY CENTER EAST - INTERSTATE 138KV CKT 1	6/1/2009	6/1/2009			\$ 5,000	\$ 20,000	\$ -
	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1	6/1/2016	6/1/2016			\$ 313,748	\$ 2,250,000	\$ 915,908
	Mooreland - TUCO 345 kV SPS	6/1/2011	6/1/2011			\$ 598,207	\$ 94,396,814	\$ 2,064,253
	Mooreland - TUCO 345 kV WFEC	6/1/2011	6/1/2011			\$ 15,843	\$ 2,500,000	\$ 43,545
	Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011			\$ 172,558	\$ 5,000,000	\$ 474,278
	REPLACE HOOVER BREAKER	6/1/2009	6/1/2009			\$ 25,001	\$ 100,000	\$ -
	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER	6/1/2007	3/1/2008	10/1/2007	Yes	\$ 460,737	\$ 4,000,000	\$ 2,074,549
	Spearville - Mooreland 345 kV SUNC	6/1/2011	6/1/2011			\$ 601,264	\$ 31,000,000	\$ 2,235,517
	Spearville - Mooreland 345 kV WFEC	6/1/2011	6/1/2011			\$ 407,308	\$ 21,000,000	\$ 1,119,491
	Tuco - Tolk 345kV	6/1/2011	6/1/2011			\$ 120,435	\$ 24,875,000	\$ 415,589
	TUCO INTERCHANGE 345/115KV TRANSFORMER CKT 1	6/1/2011	6/1/2011			\$ 38,335	\$ 10,318,679	\$ 132,284
	WICHITA - RENO 345KV	10/1/2006	6/1/2011		Yes	\$ 1,554,041	\$ 42,000,000	\$ 7,676,693
					Total	\$ 11,741,039	\$ 279,200,493	\$ 47,331,534

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available
1086655	COFFEYVILLE SUB - DEARING 69KV CKT 1	4/1/2007	2/1/2008	5/1/2007	Yes
	DEARING (DEARIN1X) 138/69/13.2KV TRANSFORMER CKT 1	12/1/2011	12/1/2011		
1086656	COFFEYVILLE SUB - DEARING 69KV CKT 1	4/1/2007	2/1/2008	5/1/2007	Yes
	DEARING (DEARIN1X) 138/69/13.2KV TRANSFORMER CKT 1	12/1/2011	12/1/2011		

Upgrades required for Additional 100 MW Transfer Modeled from OKGE to WR at customer's request for compliance purposes with FERC Order in Docket EC06-48

Reservation	Upgrade Name	COD	EOC	Earliest Service Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
1086655	KILDARE - WHITE EAGLE	6/1/2016	6/1/2016			\$ 5,013,000	\$ 6,684,000	\$ 13,620,642
1086656	KILDARE - WHITE EAGLE	6/1/2016	6/1/2016			\$ 1,671,000	\$ 6,684,000	\$ 4,540,214

Notes:

Modeling of request 1086656 assumes New Designated Network Resource no longer Designated Network Resource for OMPA Network Load in OKGE

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (COD)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
AEPW	BANN - NW TEXARKANA-BANN T 138KV CKT 1	Reset Bann Relay	6/1/2011	6/1/2011	\$ 20,000
AEPW	BANN - NW TEXARKANA-BANN T 138KV CKT 1	Reset Relays	6/1/2011	6/1/2011	\$ 20,000
AEPW	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1	Rebuild 8.37 miles of 795 ACSR with 1590 ACSR & reset relays @ BSf	6/1/2016	6/1/2016	\$ 6,000,000
AEPW	BROKEN BOW - CRAIG JUNCTION 138KV CKT 1	Rebuild 7.66 miles of 3/0 CW CU with 795 ACSR	10/1/2006	6/1/2008	\$ 4,000,000
AEPW	CLINTON CITY - THOMAS TAP 69KV CKT 1	Rebuild 13.9 miles of 4/0 ACSR with 795 ACSR	6/1/2015	6/1/2015	\$ 7,000,000
AEPW	COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW	Tie Line. Rebuild 3.93 miles of 795 ACSR with 1590 ACSR	6/1/2009	6/1/2009	\$ 2,500,000
AEPW	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1	Rebuild 13.11 miles of 795 ACSR with 1590 ACSR	6/1/2016	6/1/2016	\$ 9,200,000
AEPW	ELDORADO - LAKE PAULINE 69KV CKT 1	Upgrade Terminal Equipment at Lake Pauline CT1	6/1/2015	6/1/2015	\$ 100,000
AEPW	HOBART JUNCTION - TAMARAC TAP 138KV CKT 1	Replace Hobart Jct. Wavetrap	6/1/2012	6/1/2012	\$ 100,000
AEPW	SOUTHWEST SHREVEPORT - SOUTHWEST SHREVEPORT TAP 138KV CKT 1	Rebuild 2.29 miles of 2-397.5 ACSR with 1590 ACSR	6/1/2011	6/1/2011	\$ 1,300,000
AEPW	SW SHREVEPORT EXPANSION	Build SW Shreveport - Port Robson 345 kv line and install 345/138 kv auto @ Port Robson	6/1/2008	6/1/2010	\$ 40,000,000
AEPW	THOMAS TAP - WEATHERFORD 69KV CKT 1	Rebuild 0.9 miles of 4/0 ACSR with 795 ACSR. Replace Weatherford wavetrap	6/1/2011	6/1/2011	\$ 450,000
EMDE	SUB 110 - ORONOGO JCT. (ORONOGO) 161/69/12.5KV TRANSFORMER CKT 1	Install new 161/12 kv 22.4 transmer and take load off 69 kv system	6/1/2015	6/1/2015	\$ 5,000,000
EMDE	SUB 110 - ORONOGO JCT. (ORONOGO) 161/69/12.5KV TRANSFORMER CKT 1	Replace 75 MVA Auto-xfmr at Oronogo Jct with 150 MVA Auto-xfmr and install 69 kv bank breaker. Auto-xfmr wi have an impedance similar to Aurora 59468, 59537, 59704.	6/1/2015	6/1/2015	\$ 5,000,000
EMDE	SUB 145 - JOPLIN WEST 7TH - SUB 439 - STATELINE 161KV CKT 1	Reconductor Line	6/1/2016	6/1/2016	\$ 6,920,000
EMDE	SUB 145 - JOPLIN WEST 7TH - SUB 64 - JOPLIN 10TH ST 69KV CKT 1	Replace 600 amp disconnects and leads to breaker #6965 at Joplin #6	6/1/2013	6/1/2013	\$ 55,000
EMDE	SUB 389 - JOPLIN SOUTHWEST - SUB 422 - JOPLIN 24TH & CONNECTICUT 161KV CKT 1	Change CT Ratio at Sub #389 on Breaker #16170 for 268 MVA Rate B	6/1/2008	6/1/2008	\$ 10,000
GRDA	KANSAS TAP - WEST SILOAM SPRINGS 161KV CKT 1	Rebuild line to 1590 ACSR	6/1/2012	6/1/2012	\$ 2,244,000
KACP	IATAN - STRANGER CREEK 345KV CKT 2	Convert Iatan-Stranger Creek 161kv line to 345kv	6/1/2011	6/1/2011	\$ 4,123,803
MIDW	HEIZER 115/69KV TRANSFORMER CKT 2		6/1/2016	6/1/2016	\$ -
MIPU	CLRND A TO MARYVILLE 161KV Ckt 1 MIPU	Rebuild 16.7 miles with 954 ACSR Conductor and Replace Terminal Equipment to Increase MEC to SPP Contract Path Capacity by 68 MW	1/1/2007	6/1/2009	\$ 5,510,000
MIPU	HARRISONVILLE 161/69KV TRANSFORMER CKT 1	Transformer Upgrade	6/1/2016	6/1/2016	\$ 2,100,000
MIPU	PLATTE CITY - POPE 161 161KV CKT 1	Replacement of the wavetrap at Platte City	12/1/2011	12/1/2011	\$ 100,000
OKGE	5 TRIBES - PECAN CREEK 161KV CKT 1	replace 636AS33 conductor with 795AS33	6/1/2008	6/1/2009	\$ 1,200,000
OKGE	CANADIAN - CEDAR LANE 138KV CKT 1	Replace 800A trap at Cedar Lane	6/1/2014	6/1/2014	\$ 50,000
OKGE	CONTINENTAL BLACKS - OSAGE 69KV CKT 1	Rebuild & Reconductor 0.57 Miles of 477AS33 to 477 ACCC/TN	6/1/2012	6/1/2012	\$ 200,000
OKGE	CRESWELL - NEWKIRK 138KV CKT 1 OKGE	OG E rebuild 11.5 miles of line to 795AS33 conductor, OGE's portion of this line would be rated at a summer rate B c the conductor limit at 308 MVA. Next limit is WR disconnect switches and bus at 287MVA.	6/1/2012	6/1/2012	\$ 4,500,000
OKGE	KILDARE - WHITE EAGLE	Rebuild 11.14 miles	6/1/2016	6/1/2016	\$ 6,684,000
OKGE	PECAN CREEK (PECANCK1) 345/161/13.8KV TRANSFORMER CKT 1	Tap Muskogee to Riverside line and install a second xfmr at Pecan Cree	6/1/2008	6/1/2009	\$ 7,500,000
SPS	Bailey County - Curry County 115 kv	New 115 kv 397 ACSR circuit between Bailey and Curry	6/1/2011	6/1/2011	\$ 10,648,185
SPS	BAILEY COUNTY PROGRESS Interconnection #1	New Delivery Point on Bailey County to Curry County 69 kv line at 51233 WMULES will require a dual windin distribution transformer for future 69 to 115 kv conversion Interconnection costs indeterminate.	3/1/2007	3/1/2007	\$ -
SPS	BAILEY COUNTY PROGRESS Interconnection #2	Move BAILEY COUNTY PROGRESS Interconnection on new 115 kv Line from Bailey County to Curry County Cos Indeterminate.	6/1/2011	6/1/2011	\$ -
SPS	BAILEY COUNTY SUNNYSIDE Interconnection	New Delivery Point on Castro County to Lamton 69 kv Line at 51291 DS-#12 Interconnection costs indeterminate.	10/1/2007	6/1/2006	\$ -
SPS	CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2	Upgrade Roosevelt to Curry 115 kv circuit w/795 ACSR	4/1/2007	6/1/2010	\$ 1,515,113
SPS	GSEC Midway Interconnection #1	New Delivery Point tapping 69 kv Tie Line from AEPW Shamrock to SPS Magic Ct	10/1/2006	10/1/2006	\$ 70,000
SPS	Hart Interchange 115/69 kv	New 115/69 kv Hart Intg with Lamton to Castro Co 69 kv ckt, 40 MVA auto Move Normally Open 69 kv Point South of Hart	6/1/2016	6/1/2016	\$ 3,500,000
SPS	Hitchland 345 and 115 kv Interchang	Three breaker 345 kv bus, 345/115 kv transformer, five 115 kv breakers	4/1/2007	6/1/2010	\$ 14,795,676
SPS	LEA COUNTY INTERCHANGE 230KV CAPACITORS	Install 2 - 50 MVar capacitor banks on the 230 kv bus at Lea County Interchang	4/1/2008	4/1/2008	\$ 1,381,023
SPS	MOORE COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	Add 2nd 230/115 kv transformer at Moore County	6/1/2012	6/1/2012	\$ 6,837,000
SPS	Mooreland - TUCO 345 kv SPS	New 345 kv line from Tuco to Mooreland on wooden h-frame structures	6/1/2011	6/1/2011	\$ 94,396,814
SPS	Potter - Roosevelt 345KV	New 345 kv circuit from Potter - Roosevelt 2-795 ACSR & 345/230 kv 560 MVA transforme	4/1/2007	6/1/2010	\$ 38,504,390
SPS	RITA BLANCA Masterson (EXELL) Interconnector	New Delivery Point Interconnection at 50674 EXELL 69 kv costs indeterminate	10/1/2006	10/1/2006	\$ -
SPS	RITA BLANCA RITA (Sherman) Interconnector	New Delivery Point at 50622 SHERMN 69 kv Interconnection costs indeterminate	9/1/2007	9/1/2007	\$ -
SPS	ROOSEVELT COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	Add 2nd transformer 230/115 kv 252 MVA	4/1/2007	6/1/2010	\$ 3,200,000
SPS	SOUTH PLAINS ALCOVE Interconnector	New Delivery Point at 51656 Carlisle 115 kv Interconnection costs indeterminate	3/1/2009	3/1/2009	\$ -
SPS	SOUTH PLAINS MILWAUKEE and SLIDE Interconnector	New Delivery Points at Wolforth 115 kv Interconnection costs indeterminate	3/1/2013	3/1/2013	\$ -
SPS	SOUTH PLAINS WOLFFORTH Interconnector	New Delivery Point on Wolforth to Yuma 115 kv line Interconnection costs indeterminate	3/1/2011	3/1/2011	\$ -
SPS	SPS MUST RUN GENERATION #2	SPS Voltage Instability for Tolk to Eddy 345 kv outage due to Scheduled Cunningham Outage and either High Win Generation Level or Import Level in 2006 Fall Peak MUST Run Cunningham and Maddox Generation in order to not exceed approximately 225 MW of Flow	10/1/2006	10/1/2006	\$ -
SPS	SPS MUST RUN GENERATION #3	SPS Voltage Instability for Tolk to Eddy 345 kv outage due to Scheduled Cunningham Outage and either High Win Generation Level or Import Level in 2007 Fall Peak MUST Run Cunningham and Maddox Generation in order to not exceed approximately 225 MW of Flow	10/1/2007	10/1/2007	\$ -
SPS	SPS MUST RUN GENERATION #4	SPS Voltage Instability for Tolk to Eddy 345 kv outage due to High Wind Generation Level and/or Import Level in 200 Summer Shoulder MUST Run Cunningham and Maddox Generation in order to not exceed approximately 225 MW of Flow on Tolk to Eddy 345 kv line.	6/1/2007	6/1/2007	\$ -
SPS	SPS MUST RUN GENERATION #5	Must Run Requirement of Cunningham #2 and Maddox #1 to prevent Voltage Collapse in Winter Peaks for the Tolk to Eddy 345 kv line outage	12/1/2008	12/1/2008	\$ -
SPS	Tex-Hitchland-Sherman Tap 115 kv ck	Route Sherman Tap to Texas Co in/out of New Hitchland Interchang	4/1/2007	6/1/2010	\$ 2,401,645
SPS	TRI COUNTY HILLER Interconnector	New Delivery Point addition at Texas County 115 kv Interconnection costs indeterminate	7/1/2007	7/1/2007	\$ -
SPS	TRI COUNTY PRAIRIE Interconnection #1	New Delivery Point on Texas County to Liberal 115 kv line Interconnection costs indeterminate	7/1/2007	7/1/2007	\$ -
SPS	TRI COUNTY PRAIRIE Interconnection #2	Move Texas County Phase Shifter to TRI COUNTY PRAIRIE Interconnectio	7/1/2007	6/1/2008	\$ 1,500,000

**Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study**

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (COD)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
SPS	Tuco - Tolk 345kV	Build new 345kV line from Tuco to Tolk	6/1/2011	6/1/2011	\$ 24,875,000
SPS	TUCO INTERCHANGE 345/115KV TRANSFORMER CRT 1	Install 345/115 kV Transformer at Tuco	6/1/2011	6/1/2011	\$ 10,318,679
SPS	YOAKUM COUNTY INTERCHANGE 230/115KV TRANSFORMER CRT 1	Upgrade Transformer 230/115 kV 252 MVA	6/1/2007	6/1/2008	\$ 2,500,000
SUNC	Spearville - Mooreland 345 kV SUNC	New 345 kV line from Spearville to Kansas/Oklahoma Stateline	6/1/2011	6/1/2011	\$ 31,000,000
WEPL	Ashland Capacitor	Add 1x0.6 Mvar Cap banks at Ashlanx	6/1/2012	6/1/2012	\$ 100,000
WEPL	Cimarron Plant Substation Expansion	Integrate SUNC North Cimarron Top into reconfigured WEPL Cimarron Plant Sul	6/1/2009	6/1/2009	\$ 2,500,000
WEPL	CLAY CENTER - GREENLEAF 115KV CRT 1	Building a new 115 kV tie with Westar from Greenleaf to Clay Cente	6/1/2007	12/1/2007	\$ 7,520,000
WEPL	GREENSBURG - JUDSON LARGE 115KV CRT 1	Replace relaying	10/1/2006	6/1/2007	\$ 153,114
WEPL	Hoisington Capacitors	Add 2x0.8 Mvar Cap banks at Hoisington	6/1/2008	6/1/2008	\$ 150,000
WEPL	Kingman 115 kV and 34.5 kV Expansion	Build 17 mile 115 kV line from Pratt to Cunningham with new 115/34.5 kV Substation at Cunningham and upgrade 1 mile 34.5 kV line from Cunningham to Kingman	10/1/2006	6/1/2010	\$ 10,000,000
WEPL	MEDICINE LODGE - SUN CITY 115KV CRT 1	Upgrade CTs and Wave Trap Limits	6/1/2007	6/1/2007	\$ 100,000
WEPL	SEWARD - ST JOHN 115KV CRT 1	Rebuild Seward - St John 115KV Line	6/1/2008	6/1/2008	\$ 3,700,000
WERE	ARKANSAS CITY - PARIS 69KV CRT 1	Tear down / rebuild 1.67-mile line, 954 kcmil ACSF	6/1/2007	3/1/2008	\$ 600,000
WERE	CHAPMAN - CLAY CENTER JUNCTION 115KV CRT 1	Reset terminal equipment	6/1/2016	6/1/2016	\$ 40,000
WERE	CITY OF WELLINGTON - SUMNER COUNTY NO. 4 ROME 69KV CRT 1	Tear down / Rebuild 9.1-mile line	6/1/2011	6/1/2011	\$ 3,550,000
WERE	CITY OF WINFIELD - RAINBOW 69KV CRT 1	Rainbow-Winfield line	6/1/2007	2/1/2008	\$ 1,560,000
WERE	CITY OF WINFIELD - TIMBER JUNCTION 69KV CRT 1	Rebuild 14.63-mile Timber Tap-Winfield 69 kV line, 954 ACSF	6/1/2011	6/1/2011	\$ 4,960,000
WERE	COFFEYVILLE TAP - DEARING 138KV CRT 1 WERE	Rebuild line using 1590 ACSR, WERE portion is 1.09 mile	6/1/2009	6/1/2009	\$ 500,000
WERE	COUNTY LINE (COLINE5X) 115/69/34.5KV TRANSFORMER CRT 1	Replace County Line Transforme	6/1/2008	6/1/2008	\$ 1,500,000
WERE	CRESWELL - NEWKIRK 138KV CRT 1 WERE	Rebuild Creswell-Newkirk 138	6/1/2012	6/1/2012	\$ 4,740,000
WERE	CRESWELL - OAK 69KV CRT 1	Rebuild substations	6/1/2007	6/1/2007	\$ 250,000
WERE	CRESWELL - OAK 69KV CRT 1	Replace jumpers and bus, and reset CTs and relaying. Rebuild substation	6/1/2007	6/1/2007	\$ 250,000
WERE	CRESWELL - PARIS 69KV CRT 1	Rebuild substations	6/1/2007	2/1/2008	\$ 300,000
WERE	CRESWELL - SUMNER COUNTY NO. 4 ROME 69KV CRT 1	Rebuild 9.43 mile Creswell-SC4 Rome as a 138 kV line but operate at 69 kV	6/1/2011	6/1/2011	\$ 3,200,000
WERE	CRESWELL (CRESWL1X) 138/69/13.2KV TRANSFORMER CRT 1	Replace transformers	6/1/2011	6/1/2011	\$ 4,000,000
WERE	CRESWELL (CRESWL2X) 138/69/13.2KV TRANSFORMER CRT 1	Replace transformers	6/1/2011	6/1/2011	\$ 4,000,000
WERE	EEC - COWSKIN 138KV		6/1/2009	6/1/2009	\$ 10,000,000
WERE	GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CRT 1	Rebuild Gill-Gill Jc	6/1/2007	2/1/2008	\$ 1,500,000
WERE	GILL ENERGY CENTER EAST - INTERSTATE 138KV CRT 1	Replace wave trap	6/1/2009	6/1/2009	\$ 20,000
WERE	KEPCO Humbolt Interconnector	New Delivery Point at 57650 UN8HUMB 69 kV Interconnection costs indeterminat	10/1/2006	10/1/2006	\$ -
WERE	KEPCO K-18 Interconnector	New Delivery Point at 57330 JCTCTY 115 kV Interconnection costs indeterminat	6/1/2007	6/1/2007	\$ -
WERE	KEPCO Louisville Interconnector	New Delivery Point at 57339 S ALMA 115 kV Interconnection costs indeterminat	10/1/2006	10/1/2006	\$ -
WERE	LAWRENCE HILL - WREN 115KV CRT 1	Rebuild 3.43 mile Lawrence Hill-Wren 115 kV line	6/1/2011	6/1/2011	\$ 1,200,000
WERE	LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CRT 1	Install second Lawrence Hill 230-115 kV transformer	6/1/2016	6/1/2016	\$ 2,250,000
WERE	MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CRT 1	Tear down and rebuild 6.40 mile Mockingbird-Stull Tap 115 kV line.	10/1/2007	3/1/2008	\$ 2,200,000
WERE	OAK - RAINBOW 69KV CRT 1	Oak-Rainbow rebuild	6/1/2007	2/1/2008	\$ 1,800,000
WERE	REPLACE HOOVER BREAKER		6/1/2009	6/1/2009	\$ 100,000
WERE	RICHLAND - ROSE HILL JUNCTION 69KV CRT 1	Rebuild 5.43 mile Rose Hill Junction-Richland as a 138 kV line but operate at 69 kV	4/1/2007	3/1/2008	\$ 1,900,000
WERE	RICHLAND - UDALL 69KV CRT 1	Richland-Udall rebuild	6/1/2007	5/1/2008	\$ 2,900,000
WERE	ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER	Add third 345-138 kV transformer at Rose Hill	6/1/2007	3/1/2008	\$ 4,000,000
WERE	SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CRT 1	Rebuild 4.09 mile SW Lawrence-Wakarusa 115 kV line	6/1/2007	3/1/2008	\$ 1,400,000
WERE	TIMBER JUNCTION - UDALL 69KV CRT 1	Udall-Timber rebuild	6/1/2010	6/1/2010	\$ 700,000
WERE	WICHITA - RENO 345KV	Build 345kV from Wichita to Reno Cc	10/1/2006	6/1/2011	\$ 42,000,000
WFEC	ALTUS JCT TAP - RUSSELL 138KV CRT 1	Reconductor 12.5 miles from 336 to 795 ACSR	6/1/2011	6/1/2011	\$ 3,125,000
WFEC	ELDORADO - ELDORADO JCT 69KV CRT 1	Rebuild 1/0 to 336 ACSR - 11.5 miles	6/1/2015	6/1/2015	\$ 2,600,000
WFEC	ELDORADO JCT - GYPSUM 69KV CRT 1	Rebuild 1/0 to 336 ACSR - 8.0 miles	6/1/2015	6/1/2015	\$ 1,800,000
WFEC	FRANKLIN SW - MIDWEST TAP 138KV CRT 1	Replace switches and wavetrap at Franklin Switch to 2000.	6/1/2016	6/1/2016	\$ 100,000
WFEC	LAKE PAULINE - RUSSELL 138KV CRT 1	Upgrade Terminal Equipment (Adjust CT's	6/1/2016	6/1/2016	\$ 50,000
WFEC	Mooreland - TUCO 345 kV WFEC	345 kV line Termina	6/1/2011	6/1/2011	\$ 2,500,000
WFEC	Mooreland 345/138 kV Transformer	New Mooreland 345/138 kV Transformer	6/1/2011	6/1/2011	\$ 5,000,000
WFEC	Spearville - Mooreland 345 kV WFEC	New 345 kV line from Kansas/Oklahoma Stateline to Mooreland	6/1/2011	6/1/2011	\$ 21,000,000

Construction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (COD)	Estimated Date of Upgrade Completion (EOC)
KACY	KAW WEST 161/69KV TRANSFORMER CRT 1	Move load to 161kV system	6/1/2007	6/1/2008
MIDW	ST JOHN CAPACITOR	MIDW St. John Capacitors (2008 Summer)	6/1/2007	6/1/2008
MIPU	IATAN - ST JOE 345KV CRT 1	Circuit Breaker	6/1/2011	6/1/2011
OKGE	FPL SWITCH - MOORELAND 138KV CRT 1 OKGE	OGE would rebuild .18 miles of 267AS33 with 795AS33. This would raise OGE's summer and winter Rate B to 287MVA. The limit will still be at WFEC's Mooreland at 390A & 600A.	12/1/2007	4/1/2008
SPS	TERRY COUNTY INTERCHANGE 115/69KV TRANSFORMERS	Upgrade both existing transformer by 10/1/2007.	6/1/2007	6/1/2007
SPS	TUCO INTERCHANGE 230KV #1	SPS Proposed Plan for SPP-2004-006,007,008,009 WTMPA to 2 50 MVAR Shunt Capacitors at TUCO 230 kV, a 50 MVAR Shunt Capacitor at Swisher 230 kV, a 50 MVAR Shunt Capacitor at Lubbock South 230 kV, and a 50 MVAR Shunt Capacitor at Carlisle 230 kV	6/1/2007	6/1/2007
SPS	TUCO INTERCHANGE 230KV #2	SPS Proposed Plan for SPP-2004-006,007,008,009 WTMPA to Add +150/-50 SVC at TUCO 230 kV	6/1/2008	6/1/2008
SUNC	HOLCOMB - PLYMELL - PIONEER TAP 115KV CRT 1	Holcomb to Pioneer Tap Rebuild	6/1/2007	6/1/2008
WERE	ROSE HILL JUNCTION - WEAVER 69KV CRT 1	Rebuild 5.73 mile Weaver-Rose Hill Junction as a 138 kV line but operate at 69 kV	10/1/2006	6/1/2009
WFEC	FPL SWITCH - MOORELAND 138KV CRT 1 WFEC	Upgrade terminal equipment FPL Sw & Mooreland	12/1/2007	4/1/2008
WFEC	FT SUPPLY 138/69KV TRANSFORMER CRT 1	Install 2nd 70 MVA auto at Ft Supply	6/1/2007	6/1/2008
WFEC	HAMON BUTLER - MOREWOOD 69KV CRT 1	Reconductor 1/0 to 336 ACSR - 15.0 miles	6/1/2007	4/1/2008

**Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study**

Expansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (COD)	Estimated Date of Upgrade Completion (EOC)
AEPW	AEPW PLANNED UPGRADE FOR NW ARKANSAS	NW Project phase II scheduled to be in-service 06/2007	12/1/2006	6/1/2009
AEPW	ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1	Rebuild 1.68 miles of 1024 ACAR with 2156 ACSR. Replace wavetraps & jumpers with 2156 ACSR. Replace Switch 2285 @ Alumax Tap.	6/1/2007	4/1/2008
AEPW	BONANZA - BONANZA TAP 161KV CKT 1	Rebuild 0.06 miles of 397 ACSR with 1272 ACSR & reset relay @ Bonanza or Bonanza T-Excelsior-Midland-N Huntington 161 kV loop	6/1/2013	6/1/2013
AEPW	ELK CITY - ELK CITY 69KV CKT 1 AEPW	Replace metering CTs & Jumpers and reset relay Ct:	12/1/2011	12/1/2011
AEPW	LINWOOD - MCWILLIE STREET 138KV CKT 1	Rebuild 2.09 miles of 666 ACSR with 1272 ACSR	6/1/2007	4/1/2008
AEPW	Siloam Springs - South Fayetteville 161 K	Convert Existing 69 kV Line to 161 kV Operation	6/1/2015	6/1/2015
AEPW	WEATHERFORD SOUTHEAST (WTH_SE) 138/69/13.8KV TRANSFORMER CKT 1	Install new 90 MVA Autc	6/1/2007	1/1/2008
AEPW/WFEC	SNYDER AEPW- SNYDER WFEC INTERCONNECTION	New Tie line between AEPW's Snyder and WFEC's Snyder	6/1/2015	6/1/2015
EMDE	JAMESVILLE - SUB 415 - BLACKHAWK JCT 69KV CKT 1	Replace Jumpers to breaker #6950 at Blackhawk Jct	6/1/2011	6/1/2011
EMDE	SUB 124 - AURORA HT - SUB 152 - MONETT HT 69KV CKT 1	Change CT Ratio on breaker #6936 at Aurora #124	6/1/2011	6/1/2011
EMDE	SUB 167 - RIVERTON - SUB 406 - RIVERTON SOUTH 69KV CKT 1	Change Relay Settings and change jumpers on switch at Riverton Sub #40	6/1/2016	6/1/2016
GRDA	GRAY TAP - PENSACOLA 69KV CKT 1	Rebuild line to 795 ACSR	6/1/2008	6/1/2008
MIDW	HAYS PLANT - SOUTH HAYS 115KV CKT 1	Reconductor line	6/1/2007	6/1/2009
MIPU	ANACONDA - FREEMAN 69KV CKT 1	Conductor	6/1/2011	6/1/2011
MIPU	ANACONDA - HARRISONVILLE WEST 69KV CKT 1	Conductor	6/1/2011	6/1/2011
MIPU	BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1	Conductor	6/1/2008	10/1/2008
MIPU	BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1	Conductor	6/1/2011	6/1/2011
MIPU	EAST 20MVAR CAPACITOR	Add 20MVAR capacitor at East 161kV	6/1/2011	6/1/2011
MIPU	GRANDVIEW EAST - MARTIN CITY 161KV CKT 1	Wave Trap	12/1/2011	12/1/2011
MIPU	HARRISONVILLE NORTH - RALPH GREEN 69KV CKT 1	Rebuild line to larger conductor	6/1/2011	6/1/2011
MIPU	MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1	Upgrade to bundled 795 26/7 ACSR conductor	12/1/2006	12/31/2008
MIPU	RALPH GREEN CAPACITOR	12MVAR at Ralph Green	6/1/2011	6/1/2011
SPS	BC-EARTH INTERCHANGE 115KV	Install 1 - 14.4 MVar capacitor bank	6/1/2013	6/1/2013
SPS	BOOKER 69KV	Install 1 - 7.2 MVar capacitor bank at Booker 69 kV	6/1/2016	6/1/2016
SPS	COX INTERCHANGE - LH-COX3 115KV CKT 1	Rebuild Cox-LHCox 115 kV circuit w/397 ACSR	6/1/2016	6/1/2015
SPS	HALE CO INTERCHANGE - LH-COX3 115KV CKT 1	Rebuild Hale -LHCox 115 kV circuit w/397 ACSR	6/1/2016	6/1/2015
SPS	Hart Interchange 230/115 kV	New 230/115 kV Hart Intg with 115 kV 397 ACSR ckt to Kress Int, 3-brkr 230 kV ring, 150 MVA auto, 115 kV terminal	6/1/2011	6/1/2011
SPS	KRESS INTERCHANGE 115/69KV TRANSFORMERS	Upgrade both existing transformers	6/1/2007	6/1/2007
SPS	MUSTANG STATION 230/115KV TRANSFORMER CKT 1	Expedite SPS Planned Upgrade with 6/1/2009 inservice date to install 252 MVA Transformer for GSEC Mustang DNR to 6/1/2008	4/1/2007	6/1/2008
SPS	Pringle - Etter 115 kV	Build New 115 kV line from Pringle to Etter	6/1/2012	6/1/2012
SPS	Seven Rivers to Pecos to Potash Junction 230kV	Seven Rivers to Pecos to Potash Junction 230kV	6/1/2007	6/1/2009
SPS	Stalene Project	Tap Elk City - Grapevine. New line from Stalene Tap to Graves Co. New 115/69kVfmr at Graves Ct	6/1/2014	6/1/2014
SPS	TUCO INTERCHANGE 115/69KV TRANSFORMER	Move Load to 115 kV at TUCO	6/1/2007	6/1/2007
SWPA	BULL SHOALS - BULL SHOALS 161KV CKT 1	Replace buswork in Bull Shoals switchyard	6/1/2009	6/1/2009
WERE	95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1	Rebuild 7.61 miles from 95th & Waverly-Captain Junction 115 kV line	6/1/2009	6/1/2009
WERE	ANZIO - FORT JUNCTION SWITCHING STATION 115KV CKT 1	Tear down / Rebuild 3.53-mile section of line, 556.5 kcmil ACSR	6/1/2007	1/1/2008
WERE	CIRCLEVILLE - HOYT HTI SWITCHING JUNCTION 115KV CKT 1	Rebuild 16.66 mile Circleville-Hoyt HTI Junction 115 kV line	6/1/2010	6/1/2010
WERE	CIRCLEVILLE - KING HILL N.M. COOP 115KV CKT 1	Rebuild 15.15 mile line with 1192.5 kcmil ACSR and replace CT	6/1/2010	6/1/2010
WERE	COFFEYVILLE SUB - DEARING 69KV CKT 1	Replace line switches and CTs/Rebuild 1.13-mile section of Coffeyville city-Dearing 69 kV line	4/1/2007	2/1/2008
WERE	COUNTY LINE - HOOK JCT 115KV CKT 1	Tear down / rebuild 2.52-mile County Line-Hook Jct 115 kV line, 1192 ACSI	6/1/2011	6/1/2011
WERE	DEARING (DEARIN1X) 138/69/13.2KV TRANSFORMER CKT 1	2nd Dearing 138-69 kV Transformer	12/1/2011	12/1/2011
WERE	FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1	Rebuild 1.53-mile Co-op-Wakarusa 115 kV line.	6/1/2007	1/1/2008
WERE	GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1	Rebuild 5.56-mile line, 954 ACSR	6/1/2007	1/1/2008
WERE	HOOK JCT - TECUMSEH ENERGY CENTER 115KV CKT 1	Rebuild 4.04-mile Hook Jct-TEC 115 kV line, 1192.5 ACSR	6/1/2011	6/1/2011
WERE	KELLY - KING HILL N.M. COOP 115KV CKT 1	Rebuild 9.61-mile line, 1192.5 ACSR	6/1/2010	6/1/2010
WERE	STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1	Rebuild 9.84-mile line, 1192.5 ACSR	10/1/2007	4/1/2008
WERE	TECUMSEH ENERGY CENTER - TECUMSEH HILL 115KV CKT 1	Upgrade 0.24 mile TEC-Tecumseh Hill 115 kV line to 100 degree operator	6/1/2009	6/1/2009
WFEC	CARTER JCT CAPACITOR	Increase 6 to 24 MVAR at Carter JCT	6/1/2011	6/1/2011
WFEC	GLASS MOUNTAIN - MOORELAND 138KV CKT 1	Terminal Upgrade at Mooreland (CT'S)	6/1/2008	6/1/2008
WFEC	GYPSUM - RUSSELL 69KV CKT 1	Reconductor 1/0 to 336 ACSR - 3.1 miles	6/1/2015	6/1/2015
WFEC	WOODWARD - WOODWARD 69KV CKT 1	Replace Terminal Equipment	6/1/2007	1/1/2008

Previously Assigned Aggregate Study Upgrades requiring credits to Previous Aggregate Study Customers

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (COD)	Estimated Date of Upgrade Completion (EOC)
OKGE	FPL SWITCH - MOORELAND 138KV CKT 1 OKGE	OGE would rebuild .18 miles of 267AS33 with 795AS33. This would raise OGE's summer and winter Rate B to 287MVA. The limit will still be at WFEC's Mooreland at 390A & 600A.	6/1/2006	4/1/2008
WFEC	FPL SWITCH - MOORELAND 138KV CKT 1 WFEC	Upgrade terminal equipment FPL Sw & Mooreland	6/1/2006	4/1/2008
WFEC	FT SUPPLY 138/69KV TRANSFORMER CKT 1	Install 2nd 70 MVA auto at Ft Supply	12/1/2006	6/1/2008
WFEC	HAMON BUTLER - MOREWOOD 69KV CKT 1	Reconductor 1/0 to 336 ACSR - 15.0 miles	6/1/2006	4/1/2008

**Table 5 - Third Party Facility Constraints**

Transmission Owner	Upgrade	Solution	Minimum ATC per Upgrade (MW)	Season of Minimum Allocated ATC	Earliest Date Upgrade Required (COD)	Estimated Date of Upgrade Completion	Estimated Engineering & Construction
AECI	4LUTHER 138 (LUTHER) 138/69/13.8KV TRANSFORMER CKT 1	Add 2nd Luther 138/69 kV 56 MVA transformer including breakers, switches and relaying.	0	08WP	6/1/2008	6/1/2008	\$ 1,075,000
AECI	HUBEN (HUBEN) 345/161/13.8KV TRANSFORMER CKT 1	Indeterminate	0	16SP	6/1/2016	6/1/2016	Indeterminate
EES	4TAMINA 138 - KINDER MORGAN PIPE 138KV CKT 1	Indeterminate	0	07SP	6/1/2007	6/1/2007	Indeterminate
EES	4TAMINA 138 - TAMINA 138KV CKT 1	Indeterminate	0	07SP	6/1/2007	6/1/2007	Indeterminate
EES	AMELIA BULK - HELBIG BULK 230KV CKT 1	Indeterminate	0	16SP	6/1/2016	6/1/2016	Indeterminate
EES	CHINA - SABINE 230KV CKT 1	Indeterminate	0	11SP	6/1/2009	6/1/2009	Indeterminate
EES	CONROE BULK - PLANTATION 138KV CKT 1	Indeterminate	0	11SP	6/1/2008	6/1/2008	Indeterminate
EES	COUCH SES - MC NIEL 115KV CKT 1	Indeterminate	0	06WP	12/1/2006	12/1/2006	Indeterminate
EES	HARTBURG - INLAND-ORANGE 230KV CKT 1	Indeterminate	0	07AP	4/1/2007	4/1/2007	Indeterminate
EES	HELBIG BULK - MCLEWIS 230KV CKT 1	Indeterminate	0	07AP	4/1/2007	4/1/2007	Indeterminate
EES	INLAND-ORANGE - MCLEWIS 230KV CKT 1	Indeterminate	0	07AP	4/1/2007	4/1/2007	Indeterminate
EES	KINDER MORGAN PIPE - PLANTATION 138KV CKT 1	Indeterminate	0	11SP	6/1/2007	6/1/2007	Indeterminate
MEC	CLRND to MARYVILLE 161kV Ckt 1 MEC	Rebuild 12.6 miles with 954 ACSR Conductor and Replace Terminal Equipment to Increase MEC to SPP Contract Path Capacity by 68 MW	0	06WP	1/1/2007	1/1/2009	\$ 4,280,000

**Construction Pending Projects**

Transmission Owner	Upgrade	Solution	Minimum ATC per Upgrade (MW)	Season of Minimum Allocated ATC	Earliest Date Upgrade Required (COD)	Estimated Date of Upgrade Completion
ENTR	Entergy Project (Reduce Load MVAR)	Entergy Project (Reduce Load MVAR)	0	16SP	6/1/2016	6/1/2016



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Upgrade: ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1  
 Limiting Facility: ALUMAX TAP - NORTHWEST TEXARKANA 138KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-AEPW-29  
 Flowgate: 53245533001SPP-AEPW-292107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount										
1086238		0.6	7.0									
1087745		6.4	7.0									
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	COMANCHE 138KV	160	0.01244	-0.10002	70			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	COMANCHE 69KV	63	0.01239	-0.09997	70			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	SOUTHWESTERN STATION 138KV	335	0.01212	-0.0997	70			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	WEATHERFORD 34KV	148	0.01152	-0.0991	70			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	WELSH 345KV	990	0.01228	-0.09986	70			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	COGENTRIX 345KV	665	0.00882	-0.0964	72			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	RIVERSIDE STATION 138KV	646	0.00877	-0.09635	72			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	WELEETKA 138KV	70	0.00961	-0.09719	72			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	NORTHEASTERN STATION 138KV	405	0.00807	-0.09565	73			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	NORTHEASTERN STATION 138KV	95	0.00807	-0.09565	73			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	NORTHEASTERN STATION 345KV	645	0.00807	-0.09565	73			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	OEC 345KV	206	0.00854	-0.09612	73			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	TULSA POWER STATION 138KV	112	0.0087	-0.09628	73			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	TULSA POWER STATION 138KV	147	0.0087	-0.09628	73			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	FLINT CREEK 161KV	420	0.00713	-0.09471	74			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	FITZHUGH 161KV	126	0.00382	-0.0914	76			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	LEBRUCK 345KV	365	-0.00885	-0.07873	89			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	PIRKEY GENERATION 138KV	475	-0.01311	-0.07447	94			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	COMANCHE 138KV	160	0.01244	-0.07321	95			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	COMANCHE 69KV	63	0.01239	-0.07316	95			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	SOUTHWESTERN STATION 138KV	335	0.01212	-0.07289	96			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	WELSH 345KV	990	0.01228	-0.07305	96			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	EASTMAN 138KV	155	-0.01562	-0.07196	97			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	KNOXLEE 138KV	247.5259	-0.01564	-0.07194	97			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	WEATHERFORD 34KV	148	0.01152	-0.07229	97			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	WILKES 345KV	311	-0.01738	-0.0702	99			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	WELEETKA 138KV	70	0.00961	-0.07038	99			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	COGENTRIX 345KV	665	0.00882	-0.06959	100			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	RIVERSIDE STATION 138KV	646	0.00877	-0.06954	100			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	NORTHEASTERN STATION 138KV	405	0.00807	-0.06884	101			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	NORTHEASTERN STATION 138KV	95	0.00807	-0.06884	101			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	NORTHEASTERN STATION 345KV	645	0.00807	-0.06884	101			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	OEC 345KV	206	0.00854	-0.06931	101			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	TULSA POWER STATION 138KV	147	0.0087	-0.06947	101			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	TULSA POWER STATION 138KV	112	0.0087	-0.06947	101			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	FLINT CREEK 161KV	420	0.00713	-0.0679	103			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	FITZHUGH 161KV	126	0.00382	-0.06459	108			
AEPW	LONESTAR POWER PLANT 69KV	50	-0.08758	AEPW	LIEBERMAN 138KV	91	-0.02651	-0.06107	114			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	LEBRUCK 345KV	365	-0.00885	-0.05192	134			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	PIRKEY GENERATION 138KV	475	-0.01311	-0.04766	147			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	EASTMAN 138KV	155	-0.01562	-0.04515	155			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	KNOXLEE 138KV	247.5259	-0.01564	-0.04513	155			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	WILKES 345KV	311	-0.01738	-0.04339	161			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	COMANCHE 138KV	160	0.01244	-0.03895	179			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	COMANCHE 69KV	63	0.01239	-0.0389	179			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	WELSH 345KV	990	0.01228	-0.03879	180			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	SOUTHWESTERN STATION 138KV	335	0.01212	-0.03863	181			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	WEATHERFORD 34KV	148	0.01152	-0.03803	184			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	WELEETKA 138KV	70	0.00961	-0.03612	193			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	COGENTRIX 345KV	665	0.00882	-0.03533	198			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	RIVERSIDE STATION 138KV	646	0.00877	-0.03528	198			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	TULSA POWER STATION 138KV	147	0.0087	-0.03521	198			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	TULSA POWER STATION 138KV	112	0.0087	-0.03521	198			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	OEC 345KV	206	0.00854	-0.03505	199			
AEPW	ARSENAL HILL 69KV	75	-0.02242	AEPW	COMANCHE 138KV	160	0.01244	-0.03486	200			
AEPW	ARSENAL HILL 69KV	75	-0.02242	AEPW	WELSH 345KV	990	0.01228	-0.0347	201			
AEPW	ARSENAL HILL 69KV	75	-0.02242	AEPW	SOUTHWESTERN STATION 138KV	335	0.01212	-0.03454	202			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	NORTHEASTERN STATION 138KV	405	0.00807	-0.03458	202			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	NORTHEASTERN STATION 138KV	95	0.00807	-0.03458	202			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	NORTHEASTERN STATION 345KV	645	0.00807	-0.03458	202			
AEPW	WILKES 138KV	97.62759	-0.06077	AEPW	LIEBERMAN 138KV	91	-0.02651	-0.03426	204			
AEPW	ARSENAL HILL 69KV	75	-0.02242	AEPW	WEATHERFORD 34KV	148	0.01152	-0.03394	206			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	FLINT CREEK 161KV	420	0.00713	-0.03364	208			
AEPW	ARSENAL HILL 69KV	75	-0.02242	AEPW	COGENTRIX 345KV	665	0.00882	-0.03124	224			
AEPW	ARSENAL HILL 69KV	75	-0.02242	AEPW	RIVERSIDE STATION 138KV	646	0.00877	-0.03119	224			
AEPW	ARSENAL HILL 69KV	75	-0.02242	AEPW	TULSA POWER STATION 138KV	112	0.0087	-0.03112	224			
AEPW	ARSENAL HILL 69KV	75	-0.02242	AEPW	TULSA POWER STATION 138KV	147	0.0087	-0.03112	224			
AEPW	LIEBERMAN 138KV	137	-0.02651	AEPW	FITZHUGH 161KV	126	0.00382	-0.03033	230			

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ANZIO - FORT JUNCTION SWITCHING STATION 115KV CKT 1  
 Limiting Facility: ANZIO - FORT JUNCTION SWITCHING STATION 115KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-46  
 Flowgate: 57321573281SPP-WERE-462207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount							
1090609		0.8	4.6						
1090609		0.3	4.6						
1090609		0.2	4.6						
1090609		0.6	4.6						
1090674		0.1	4.6						
1090817		0.9	4.6						
1090964		1.3	4.6						
1090965		0.4	4.6						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.54434	8
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CHANUTE 69KV	46.617	0.00108	-0.53102	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.5308	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF BURLINGTON 69KV	7.8	0.00193	-0.53187	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.53102	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF FREDONIA 69KV	5.225	0.00093	-0.53087	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF IOLA 69KV	19.865	0.00119	-0.53113	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF MULVANE 69KV	6.189	0.00035	-0.53029	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.52983	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.53187	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.53078	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.52935	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	HOLTON 115KV	12.2	0.00576	-0.5357	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.53973	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.53078	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.53881	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.53946	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	SOUTH SENECA 115KV	8.5	0.00463	-0.53457	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	WACO 138KV	17.947	-0.00045	-0.52949	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	HUTCHINSON ENERGY CENTER 115KV	80.00001	-0.08161	-0.44833	10
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CHANUTE 69KV	46.617	0.00108	-0.38628	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.38606	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF BURLINGTON 69KV	7.8	0.00193	-0.38713	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.38628	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF FREDONIA 69KV	5.225	0.00093	-0.38613	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF IOLA 69KV	19.865	0.00119	-0.38639	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF MULVANE 69KV	6.189	0.00035	-0.38555	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.38509	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.38713	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.38604	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.38461	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	HOLTON 115KV	12.2	0.00576	-0.39096	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.39499	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.38604	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.39407	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.39472	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	SOUTH SENECA 115KV	8.5	0.00463	-0.38983	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.3996	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	WACO 138KV	17.947	-0.00045	-0.38475	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	HUTCHINSON ENERGY CENTER 115KV	80.00001	-0.08161	-0.30359	15
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.11283	41
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.10822	43
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.1073	43
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.10795	43
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	CHANUTE 69KV	46.617	0.00108	-0.09951	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.09929	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.09951	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	CITY OF IOLA 69KV	19.865	0.00119	-0.09962	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.10036	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.09927	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.09927	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.09832	47
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.09784	47
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	WACO 138KV	17.947	-0.00045	-0.09798	47
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.09601	48
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.09598	48
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.0914	50
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.09137	50
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.09048	51
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.09113	51
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.09045	51
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.0911	51
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.09045	51
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.08584	54
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.08492	54
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.08557	54
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.08354	55
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.08351	55
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	CHANUTE 69KV	46.617	0.00108	-0.08269	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.08247	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.08269	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	CITY OF IOLA 69KV	19.865	0.00119	-0.0828	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.0815	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.08245	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.08245	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	CHANUTE 69KV	46.617	0.00108	-0.08266	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.08244	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.08266	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	CITY OF IOLA 69KV	19.865	0.00119	-0.08277	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.08147	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.08242	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.08242	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.08102	57
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.08099	57
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.07798	59
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	CHANUTE 69KV	46.617	0.00108	-0.07713	60
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.07691	60
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.07713	60
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.07689	60
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.07689	60
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.07594	61
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.07546	61

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ANZIO - FORT JUNCTION SWITCHING STATION 115KV CKT 1  
 Limiting Facility: ANZIO - FORT JUNCTION SWITCHING STATION 115KV CKT 1  
 Direction: To->From  
 Line Outage: WR-DOUBLE12  
 Flowgate: 57321573281WR-DOUBLE122207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.8	4.6

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
	1090609	0.3	4.6						
	1090609	0.2	4.6						
	1090609	0.6	4.6						
	1090674	0.1	4.6						
	1090817	0.9	4.6						
	1090964	1.3	4.6						
	1090965	0.4	4.6						
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.54434	8
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CHANUTE 69KV	46.617	0.00108	-0.53102	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.5308	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF BURLINGTON 69KV	7.8	0.00193	-0.53187	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.53102	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF FREDONIA 69KV	5.225	0.00093	-0.53087	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF IOLA 69KV	19.865	0.00119	-0.53113	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF MULVANE 69KV	6.189	0.00035	-0.53029	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.52983	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.53187	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.53078	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.52935	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	HOLTON 115KV	12.2	0.00576	-0.5357	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.53973	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.53078	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.53881	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.53946	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	SOUTH SENeca 115KV	8.5	0.00463	-0.53457	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	WACO 138KV	17.947	-0.00045	-0.52949	9
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.52994	WERE	HUTCHINSON ENERGY CENTER 115KV	80.00001	-0.08161	-0.44833	10
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CHANUTE 69KV	46.617	0.00108	-0.38628	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.38606	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF BURLINGTON 69KV	7.8	0.00193	-0.38713	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.38628	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF FREDONIA 69KV	5.225	0.00093	-0.38613	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF IOLA 69KV	19.865	0.00119	-0.38639	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF MULVANE 69KV	6.189	0.00035	-0.38555	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.38509	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.38713	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.38604	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.38461	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	HOLTON 115KV	12.2	0.00576	-0.39096	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.39499	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.38604	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.39407	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.39472	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	SOUTH SENeca 115KV	8.5	0.00463	-0.38983	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.3996	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	WACO 138KV	17.947	-0.00045	-0.38475	12
WERE	ABILENE ENERGY CENTER 115KV	66	-0.3852	WERE	HUTCHINSON ENERGY CENTER 115KV	80.00001	-0.08161	-0.30359	15
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.11283	41
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.10822	43
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.1073	43
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.10795	43
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	CHANUTE 69KV	46.617	0.00108	-0.09951	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.09929	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.09951	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	CITY OF IOLA 69KV	19.865	0.00119	-0.09962	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.10036	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.09927	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.09927	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.09832	47
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.09784	47
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.09843	WERE	WACO 138KV	17.947	-0.00045	-0.09798	47
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.09601	48
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.09598	48
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.0914	50
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.09137	50
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.09048	51
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.09113	51
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.09045	51
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.0911	51
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0144	-0.09045	51
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00979	-0.08584	54
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00887	-0.08492	54
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	0.00952	-0.08557	54
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.08354	55
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.08351	55
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	CHANUTE 69KV	46.617	0.00108	-0.08269	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.08247	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.08269	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	CITY OF IOLA 69KV	19.865	0.00119	-0.0828	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.0815	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.08245	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.08245	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	CHANUTE 69KV	46.617	0.00108	-0.08266	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.08244	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.08266	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	CITY OF IOLA 69KV	19.865	0.00119	-0.08277	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.08147	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.08242	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.08242	56
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.08161	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.08102	57
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.08158	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.08099	57
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00193	-0.07798	59
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	CHANUTE 69KV	46.617	0.00108	-0.07713	60
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	CITY OF AUGUSTA 69KV	20.02	0.00086	-0.07691	60
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	CITY OF ERIE 69KV	22.264	0.00108	-0.07713	60
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	EVANS ENERGY CENTER 138KV	262.1094	0.00084	-0.07689	60
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00084	-0.07689	60
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00011	-0.07594	61
WERE	SMOKYHIL 230 230KV	72	-0.07605	WERE	GILL ENERGY CENTER 138KV	77	-0.00059	-0.07546	61

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Upgrade: ARKANSAS CITY - PARIS 69KV CKT 1  
 Limiting Facility: ARKANSAS CITY - PARIS 69KV CKT 1  
 Direction: To->From  
 Line Outage: CRESWELL - OAK 69KV CKT 1  
 Flowgate: 57542575481575435754713307SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount								
1090609		5.2	7.9							
1090609		0.8	7.9							
1090609		0.3	7.9							
1090609		1.0	7.9							
1090609		0.5	7.9							

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	CITY OF WELLINGTON 69KV	41.45	0.0587	-0.71062	11
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	ABILENE ENERGY CENTER 115KV	6.757809	-0.00218	-0.64974	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	CHANUTE 69KV	46.617	-0.00233	-0.64959	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	CITY OF BURLINGTON 69KV	7.8	-0.00407	-0.64785	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	CITY OF ERIE 69KV	22.264	-0.00233	-0.64959	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	CITY OF FREDONIA 69KV	5.225	-0.0027	-0.64922	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	CITY OF IOLA 69KV	19.865	-0.00204	-0.64988	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	CITY OF MULVANE 69KV	6.189	-0.0035	-0.64842	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	CLAY CENTER JUNCTION 115KV	17.01001	-0.00224	-0.64968	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	-0.00407	-0.64785	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	EVANS ENERGY CENTER 138KV	305	-0.00394	-0.64798	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	GILL ENERGY CENTER 138KV	77	-0.00265	-0.64927	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	HOLTON 115KV	12.2	-0.00269	-0.64923	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	HUTCHINSON ENERGY CENTER 115KV	80.00001	-0.00191	-0.65001	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	JEFFREY ENERGY CENTER 230KV	470	-0.00229	-0.64963	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	JEFFREY ENERGY CENTER 345KV	940	-0.00228	-0.64964	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	LAWRENCE ENERGY CENTER 115KV	60	-0.00223	-0.64969	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	LAWRENCE ENERGY CENTER 230KV	232.5762	-0.00227	-0.64965	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	SOUTH SENeca 115KV	8.5	-0.00314	-0.64878	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	TECUMSEH ENERGY CENTER 115KV	108	-0.00232	-0.6496	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	WACO 138KV	17.947	-0.00278	-0.64914	12
WERE	CITY OF WINFIELD 69KV	40	-0.65192	WERE	CITY OF AUGUSTA 69KV	20.02	-0.05262	-0.5993	13
WERE	GETTY 69KV	35	-0.01732	WERE	CITY OF WELLINGTON 69KV	41.45	0.0587	-0.07602	104

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ARKANSAS CITY - PARIS 69KV CKT 1  
 Limiting Facility: ARKANSAS CITY - PARIS 69KV CKT 1  
 Direction: To->From  
 Line Outage: CRESWELL - OAK 69KV CKT 1  
 Flowgate: 57542575481575435754713307SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1090609		1.5	13.8							
1090609		0.7	13.8							
1090609		1.7	13.8							
1090609		0.8	13.8							
1090609		9.0	13.8							

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	CITY OF WELLINGTON 69KV	41.45	0.0587	-0.71062	19
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	ABILENE ENERGY CENTER 115KV	40	-0.00218	-0.64974	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	BPU - CITY OF MCPHERSON 115KV	135	-0.00198	-0.64994	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	CHANUTE 69KV	56.723	-0.00233	-0.64959	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	CITY OF BURLINGTON 69KV	10.12	-0.00407	-0.64785	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	CITY OF ERIE 69KV	22.274	-0.00233	-0.64959	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	CITY OF IOLA 69KV	24.267	-0.00203	-0.64989	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	CITY OF MULVANE 69KV	8.288	-0.0035	-0.64842	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	CLAY CENTER JUNCTION 115KV	28.875	-0.00224	-0.64968	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	-0.00407	-0.64785	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	EVANS ENERGY CENTER 138KV	394.978	-0.00394	-0.64798	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	GILL ENERGY CENTER 138KV	155	-0.00265	-0.64927	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	HOLTON 115KV	12.2	-0.00269	-0.64923	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	HUTCHINSON ENERGY CENTER 115KV	120	-0.00191	-0.65001	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	JEFFREY ENERGY CENTER 230KV	470	-0.00229	-0.64963	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	JEFFREY ENERGY CENTER 345KV	940	-0.00228	-0.64964	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	LAWRENCE ENERGY CENTER 115KV	85	-0.00223	-0.64969	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	LAWRENCE ENERGY CENTER 230KV	234.5685	-0.00227	-0.64965	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	SOUTH SENeca 115KV	8.5	-0.00314	-0.64878	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	TECUMSEH ENERGY CENTER 115KV	128	-0.00232	-0.6496	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	WACO 138KV	17.96	-0.00278	-0.64914	21
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	CITY OF AUGUSTA 69KV	25.12	-0.05262	-0.5993	23

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1  
 Limiting Facility: BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1  
 Direction: From->To  
 Line Outage: GRD OAK - PLEASANT HILL 345KV CKT 1  
 Flowgate: 59340592591591985920011308SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1089950		1.1	1.1							

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
MIPU	ARIES 161KV	595	-0.04476	MIPU	SOUTH HARPER 161KV	315	0.39836	-0.44312	2
MIPU	GREENWOOD 161KV	193.0817	-0.04777	MIPU	SOUTH HARPER 161KV	315	0.39836	-0.44613	2
MIPU	LAKE ROAD 161KV	91	-0.01621	MIPU	SOUTH HARPER 161KV	315	0.39836	-0.41457	3
MIPU	NEVADA 69KV	20.3	-0.01018	MIPU	SOUTH HARPER 161KV	315	0.39836	-0.40854	3
MIPU	RALPH GREEN 69KV	73.7	0.07409	MIPU	SOUTH HARPER 161KV	315	0.39836	-0.32427	3

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

MIPU	SIBLEY 161KV'	18.38968	-0.0334	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.43176	3
MIPU	SIBLEY 69KV'	1.200012	-0.0327	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.43106	3
MIPU	TWA 161KV'	32.1	-0.0244	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.42276	3
KACP	NORTHEAST 13KV'	56	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 13KV'	56	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 13KV'	58	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 13KV'	59	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 161KV'	55	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 161KV'	58	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 161KV'	58	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 161KV'	58	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	GRAND AVENUE 161KV'	65	-0.02874	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.06974	16
KACP	MONTROSE 161KV'	24.39473	-0.02035	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.06135	18
KACP	MARSHALL 161KV'	54.1	-0.01561	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.05661	19
KACP	GARDNER 161KV'	11	-0.0068	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.0478	23
KACP	BULL CREEK 161KV'	124.343	-0.00436	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.04536	24
MIPU	GREENWOOD 161KV'	193.0817	-0.04777	MIPU	LAKE ROAD 161KV'	35	-0.01621	-0.03156	34
MIPU	GREENWOOD 161KV'	193.0817	-0.04777	MIPU	LAKE ROAD 34KV'	92	-0.01621	-0.03156	34

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: CRAIG JUNCTION - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151540155600411107WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1079577	0.8	4.5
1086238	0.4	4.5
1089945	1.7	4.5
1089952	1.3	4.5
1090609	0.2	4.5

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV'	40.14902	0.0146	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.55337	8
SWPA	BULL SHOALS 161KV'	96.02807	0.00807	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.5599	8
SWPA	CARTHAGE 69KV'	20	0.01477	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.5532	8
SWPA	CLARENCE CANNON DAM 69KV'	58	0.00785	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56012	8
SWPA	DARDANELLE 161KV'	44.56081	0.00557	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.5624	8
SWPA	EUFAULA 138KV'	16.68303	0.03385	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.53412	8
SWPA	EUFAULA 161KV'	8.341516	0.03381	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.53416	8
SWPA	FORT GIBSON 161KV'	13.83629	0.022	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.54597	8
SWPA	GREERS FERRY 161KV'	30.51932	0.00243	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56554	8
SWPA	INDEPENDENCE 161KV'	13	0.00231	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56566	8
SWPA	JONESBORO 161KV'	2.799999	0.00195	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56602	8
SWPA	KENNETT 69KV'	29	0.00238	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56559	8
SWPA	KEYSTONE DAM 161KV'	19.52976	0.02239	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.54558	8
SWPA	MALDEN 69KV'	15	0.00255	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56542	8
SWPA	NORFORK 161KV'	23.60118	0.00625	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56172	8
SWPA	OZARK 161KV'	48.63363	0.01221	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.55576	8
SWPA	PARAGOULD 69KV'	17.5	0.00213	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56584	8
SWPA	PIGGOTT 69KV'	7.5	0.00244	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56553	8
SWPA	POPLAR BLUFF 69KV'	13	0.0035	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56447	8
SWPA	ROBERT S. KERR 161KV'	34.99723	0.02027	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.5477	8
SWPA	STOCKTON 161KV'	14.44538	0.01249	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.55548	8
SWPA	TABLE ROCK 161KV'	61.03864	0.01191	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.55606	8
SWPA	TENKILLER FERRY 161KV'	11.59864	0.02636	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.54161	8
SWPA	TRUMAN 161KV'	93.36607	0.01068	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.55731	8
SWPA	WEBBERS FALLS 161KV'	35.81681	0.02636	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.54161	8
SWPA	DENISON 138KV'	19.52976	0.05631	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.51166	9
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	COMANCHE 69KV'	63	0.02584	-0.15899	28
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.16038	28
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	COGENTRIX 345KV'	665	0.02134	-0.15449	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	COMANCHE 138KV'	160	0.02456	-0.15771	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	NORTHEASTERN STATION 138KV'	95	0.02003	-0.15318	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	NORTHEASTERN STATION 138KV'	207	0.02003	-0.15318	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	NORTHEASTERN STATION 345KV'	600	0.01959	-0.15274	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	OEC 345KV'	206	0.02036	-0.15351	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	RIVERSIDE STATION 138KV'	235	0.02283	-0.15598	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.1576	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	FLINT CREEK 161KV'	400	0.01738	-0.15053	30
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	L&D13 69KV'	11	0.01523	-0.14838	30
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	FITZHUGH 161KV'	31	0.01223	-0.14538	31
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	LIEBERMAN 138KV'	48.94702	-0.02612	-0.10703	42
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	EASTMAN 138KV'	155	-0.02795	-0.1052	43
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	KNOXLEE 138KV'	103	-0.02772	-0.10543	43
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	LEBROCK 345KV'	365	-0.0275	-0.10565	43
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	PIRKEY GENERATION 138KV'	450	-0.02767	-0.10548	43
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	WILKES 345KV'	191	-0.02861	-0.10544	43
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	WELSH 345KV'	975.0001	-0.02975	-0.1034	44
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	WILKES 138KV'	119.4252	-0.03189	-0.10126	44
AEPW	FULTON 115KV'	153	-0.06196	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.08919	50
WFEC	MORLND 138KV'	133.0715	0.02302	WFEC	HUGO 138KV'	450	0.11223	-0.08921	50
AEPW	FULTON 115KV'	153	-0.06196	AEPW	COMANCHE 69KV'	63	0.02584	-0.0878	51
AEPW	FULTON 115KV'	153	-0.06196	AEPW	COMANCHE 138KV'	160	0.02456	-0.08652	52
AEPW	FULTON 115KV'	153	-0.06196	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.08641	52
WFEC	ANADARKO 138KV'	90	0.02784	WFEC	HUGO 138KV'	450	0.11223	-0.08439	53
WFEC	ANADARKO 69KV'	76	0.0277	WFEC	HUGO 138KV'	450	0.11223	-0.08453	53
WFEC	BLUCAN14 138 138KV'	151.2	0.02727	WFEC	HUGO 138KV'	450	0.11223	-0.08496	53
AEPW	FULTON 115KV'	153	-0.06196	AEPW	RIVERSIDE STATION 138KV'	235	0.02283	-0.08479	53
AEPW	FULTON 115KV'	153	-0.06196	AEPW	COGENTRIX 345KV'	665	0.02134	-0.0833	54
AEPW	FULTON 115KV'	153	-0.06196	AEPW	NORTHEASTERN STATION 138KV'	95	0.02003	-0.08199	55
AEPW	FULTON 115KV'	153	-0.06196	AEPW	NORTHEASTERN STATION 138KV'	207	0.02003	-0.08199	55
AEPW	FULTON 115KV'	153	-0.06196	AEPW	NORTHEASTERN STATION 345KV'	600	0.01959	-0.08155	55
AEPW	FULTON 115KV'	153	-0.06196	AEPW	OEC 345KV'	206	0.02036	-0.08232	55
AEPW	FULTON 115KV'	153	-0.06196	AEPW	FLINT CREEK 161KV'	400	0.01738	-0.07934	57
AEPW	FULTON 115KV'	153	-0.06196	AEPW	FITZHUGH 161KV'	31	0.01223	-0.07419	61
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05979	75
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05912	76
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	COMANCHE 69KV'	63	0.02584	-0.0584	77
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	COMANCHE 69KV'	63	0.02584	-0.05773	78

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	COMANCHE 138KV'	160	0.02456	-0.05712	79
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.05701	79
AEPW	WELSH 345KV'	68.99991	-0.02975	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05698	79
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	COMANCHE 138KV'	160	0.02456	-0.05645	80
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.05634	80
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	RIVERSIDE STATION 138KV'	235	0.02283	-0.05539	81
AEPW	WELSH 345KV'	68.99991	-0.02975	AEPW	COMANCHE 69KV'	63	0.02584	-0.05559	81
AEPW	WILKES 345KV'	120	-0.02861	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05584	81
AEPW	EASTMAN 138KV'	330.01	-0.02795	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05518	82
AEPW	KNOXLEE 138KV'	260	-0.02772	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05495	82
AEPW	KNOXLEE 138KV'	60	-0.02772	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05495	82
AEPW	LEBROCK 345KV'	332	-0.0275	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05473	82
AEPW	PIRKEY GENERATION 138KV'	65	-0.02767	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.0549	82
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	RIVERSIDE STATION 138KV'	235	0.02283	-0.05472	82
AEPW	WELSH 345KV'	68.99991	-0.02975	AEPW	COMANCHE 138KV'	160	0.02456	-0.05431	83
AEPW	WELSH 345KV'	68.99991	-0.02975	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.0542	83
AEPW	WILKES 345KV'	120	-0.02861	AEPW	COMANCHE 69KV'	63	0.02584	-0.05445	83
AEPW	EASTMAN 138KV'	330.01	-0.02795	AEPW	COMANCHE 69KV'	63	0.02584	-0.05379	84
SWPA	GREERS FERRY 161KV'	30.51932	0.00243	SWPA	DENISON 138KV'	50.47024	0.05631	-0.05388	84
SWPA	KENNETT 69KV'	29	0.00238	SWPA	DENISON 138KV'	50.47024	0.05631	-0.05393	84
AEPW	KNOXLEE 138KV'	260	-0.02772	AEPW	COMANCHE 69KV'	63	0.02584	-0.05356	84
AEPW	KNOXLEE 138KV'	60	-0.02772	AEPW	COMANCHE 69KV'	63	0.02584	-0.05356	84
AEPW	LEBROCK 345KV'	332	-0.0275	AEPW	COMANCHE 69KV'	63	0.02584	-0.05334	84
AEPW	LIEBERMAN 138KV'	179.053	-0.02612	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05335	84
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	COGENTRIX 345KV'	665	0.02134	-0.0539	84
AEPW	PIRKEY GENERATION 138KV'	65	-0.02767	AEPW	COMANCHE 69KV'	63	0.02584	-0.05351	84
AEPW	TENASKA GATEWAY 345KV'	937.03	-0.0262	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05343	84
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	OEC 345KV'	206	0.02036	-0.05292	85
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	COGENTRIX 345KV'	665	0.02134	-0.05323	85
AEPW	WILKES 345KV'	120	-0.02861	AEPW	COMANCHE 138KV'	160	0.02456	-0.05317	85
AEPW	WILKES 345KV'	120	-0.02861	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.05306	85
AEPW	ARSENAL HILL 69KV'	99	-0.02535	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05258	86
AEPW	EASTMAN 138KV'	330.01	-0.02795	AEPW	COMANCHE 138KV'	160	0.02456	-0.05251	86

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: CRAIG JUNCTION - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151540155600412106FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount							Redispatch Amount (MW)
1090609	0.3	0.3							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV'	12.35929	0.01471	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55336	1
SWPA	BULL SHOALS 161KV'	194.8001	0.00814	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55993	1
SWPA	CARTHAGE 69KV'	32	0.0149	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55317	1
SWPA	CLARENCE CANNON DAM 69KV'	58	0.00786	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56021	1
SWPA	DARDANELLE 161KV'	55.80006	0.00561	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56246	1
SWPA	DENISON 138KV'	3.400024	0.05643	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.51164	1
SWPA	EUFULA 138KV'	2.800026	0.03405	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.53402	1
SWPA	EUFULA 161KV'	1.400013	0.03401	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.53406	1
SWPA	FORT GIBSON 161KV'	14.00001	0.02213	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.54594	1
SWPA	GREERS FERRY 161KV'	5.20005	0.00247	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.5656	1
SWPA	INDEPENDENCE 161KV'	13	0.00235	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56572	1
SWPA	JONESBORO 161KV'	76	0.00198	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56609	1
SWPA	KENNETT 69KV'	29	0.0024	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56567	1
SWPA	KEYSTONE DAM 161KV'	35.00001	0.02277	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.5453	1
SWPA	MALDEN 69KV'	15.4	0.00257	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.5655	1
SWPA	NORFORK 161KV'	65.00001	0.00632	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56175	1
SWPA	OZARK 161KV'	51.00003	0.01219	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55588	1
SWPA	PARAGOULD 69KV'	17.5	0.00215	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56592	1
SWPA	PIGGOTT 69KV'	7.5	0.00246	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56561	1
SWPA	POPLAR BLUFF 69KV'	13	0.00348	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56459	1
SWPA	ROBERT S. KERR 161KV'	31.20005	0.02035	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.54772	1
SWPA	STOCKTON 161KV'	2.500019	0.01261	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55546	1
SWPA	TABLE ROCK 161KV'	60.00008	0.01203	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55604	1
SWPA	TENKILLER FERRY 161KV'	26.00001	0.02652	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.54155	1
SWPA	TRUMAN 161KV'	37.00006	0.0108	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55727	1
SWPA	WEBBERS FALLS 161KV'	38.20001	0.02652	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.54155	1
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	COGENTRIX 345KV'	665	0.02078	-0.15389	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	COMANCHE 138KV'	160	0.02463	-0.15774	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	COMANCHE 69KV'	63	0.02591	-0.15902	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	FITZHUGH 161KV'	61	0.0122	-0.14531	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	FLINT CREEK 161KV'	400	0.01749	-0.1506	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	L&D13 69KV'	11	0.01526	-0.14837	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	NORTHEASTERN STATION 138KV'	240	0.02027	-0.15338	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	NORTHEASTERN STATION 138KV'	95	0.02027	-0.15338	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	NORTHEASTERN STATION 345KV'	550	0.01967	-0.15278	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	OEC 345KV'	256	0.02031	-0.15342	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	RIVERSIDE STATION 138KV'	245	0.02397	-0.15708	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	SOUTHWESTERN STATION 138KV'	86	0.02732	-0.16043	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	WEATHERFORD 34KV'	148	0.02453	-0.15764	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	EASTMAN 138KV'	155	-0.02785	-0.10526	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	KNOXLEE 138KV'	15.88934	-0.02761	-0.1055	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	LEBROCK 345KV'	365	-0.02744	-0.10567	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	LIEBERMAN 138KV'	4	-0.0261	-0.10701	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	PIRKEY GENERATION 138KV'	440	-0.02761	-0.1055	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	WELSH 345KV'	990	-0.02972	-0.10339	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	WILKES 138KV'	7	-0.03193	-0.10118	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	WILKES 345KV'	74.26818	-0.0286	-0.10451	3
WFEC	ANADARKO 138KV'	269.9937	0.02793	WFEC	HUGO 138KV'	370.8604	0.11232	-0.08439	4
WFEC	ANADARKO 138KV'	90	0.02793	WFEC	HUGO 138KV'	370.8604	0.11232	-0.08439	4
WFEC	ANADARKO 69KV'	76	0.02779	WFEC	HUGO 138KV'	370.8604	0.11232	-0.08453	4
WFEC	BLUCAN14 138 138KV'	151.2	0.02735	WFEC	HUGO 138KV'	370.8604	0.11232	-0.08497	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	COGENTRIX 345KV'	665	0.02078	-0.08272	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	COMANCHE 138KV'	160	0.02463	-0.08657	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	COMANCHE 69KV'	63	0.02591	-0.08785	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	FITZHUGH 161KV'	61	0.0122	-0.07414	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	FLINT CREEK 161KV'	400	0.01749	-0.07943	4

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	FULTON 115KV	153	-0.06194	AEPW	L&D13 69KV	11	0.01526	-0.0772	4
AEPW	FULTON 115KV	153	-0.06194	AEPW	NORTHEASTERN STATION 138KV	95	0.02027	-0.08221	4
AEPW	FULTON 115KV	153	-0.06194	AEPW	NORTHEASTERN STATION 138KV	240	0.02027	-0.08221	4
AEPW	FULTON 115KV	153	-0.06194	AEPW	NORTHEASTERN STATION 345KV	550	0.01967	-0.08161	4
AEPW	FULTON 115KV	153	-0.06194	AEPW	OEC 345KV	256	0.02031	-0.08225	4
AEPW	FULTON 115KV	153	-0.06194	AEPW	RIVERSIDE STATION 138KV	245	0.02397	-0.08591	4
AEPW	FULTON 115KV	153	-0.06194	AEPW	SOUTHWESTERN STATION 138KV	86	0.02732	-0.08926	4
AEPW	FULTON 115KV	153	-0.06194	AEPW	WEATHERFORD 34KV	148	0.02453	-0.08647	4
WFEC	MORLND 138KV	320	0.02308	WFEC	HUGO 138KV	370.8604	0.11232	-0.08924	4
AEPW	ARSENAL HILL 69KV	99	-0.02533	AEPW	COMANCHE 69KV	63	0.02591	-0.05124	6
AEPW	ARSENAL HILL 69KV	99	-0.02533	AEPW	SOUTHWESTERN STATION 138KV	86	0.02732	-0.05265	6
AEPW	EASTMAN 138KV	330.01	-0.02785	AEPW	COMANCHE 138KV	160	0.02463	-0.05248	6
AEPW	EASTMAN 138KV	330.01	-0.02785	AEPW	COMANCHE 69KV	63	0.02591	-0.05376	6
AEPW	EASTMAN 138KV	330.01	-0.02785	AEPW	RIVERSIDE STATION 138KV	245	0.02397	-0.05182	6
AEPW	EASTMAN 138KV	330.01	-0.02785	AEPW	SOUTHWESTERN STATION 138KV	86	0.02732	-0.05517	6
AEPW	EASTMAN 138KV	330.01	-0.02785	AEPW	WEATHERFORD 34KV	148	0.02453	-0.05238	6
SWPA	GREERS FERRY 161KV	5.20005	0.00247	SWPA	DENISON 138KV	66.59998	0.05643	-0.05396	6
SWPA	INDEPENDENCE 161KV	13	0.00235	SWPA	DENISON 138KV	66.59998	0.05643	-0.05408	6
SWPA	JONESBORO 161KV	76	0.00198	SWPA	DENISON 138KV	66.59998	0.05643	-0.05445	6
SWPA	KENNETT 69KV	29	0.0024	SWPA	DENISON 138KV	66.59998	0.05643	-0.05403	6
AEPW	KNOXLEE 138KV	347.1107	-0.02761	AEPW	COMANCHE 138KV	160	0.02463	-0.05224	6
AEPW	KNOXLEE 138KV	60	-0.02761	AEPW	COMANCHE 138KV	160	0.02463	-0.05224	6
AEPW	KNOXLEE 138KV	347.1107	-0.02761	AEPW	COMANCHE 69KV	63	0.02591	-0.05352	6
AEPW	KNOXLEE 138KV	60	-0.02761	AEPW	COMANCHE 69KV	63	0.02591	-0.05352	6
AEPW	KNOXLEE 138KV	347.1107	-0.02761	AEPW	RIVERSIDE STATION 138KV	245	0.02397	-0.05158	6
AEPW	KNOXLEE 138KV	60	-0.02761	AEPW	RIVERSIDE STATION 138KV	245	0.02397	-0.05158	6
AEPW	KNOXLEE 138KV	347.1107	-0.02761	AEPW	SOUTHWESTERN STATION 138KV	86	0.02732	-0.05493	6
AEPW	KNOXLEE 138KV	60	-0.02761	AEPW	SOUTHWESTERN STATION 138KV	86	0.02732	-0.05493	6
AEPW	KNOXLEE 138KV	347.1107	-0.02761	AEPW	WEATHERFORD 34KV	148	0.02453	-0.05214	6
AEPW	KNOXLEE 138KV	60	-0.02761	AEPW	WEATHERFORD 34KV	148	0.02453	-0.05214	6
AEPW	LEBROCK 345KV	332	-0.02744	AEPW	COMANCHE 138KV	160	0.02463	-0.05207	6
AEPW	LEBROCK 345KV	332	-0.02744	AEPW	COMANCHE 69KV	63	0.02591	-0.05335	6
AEPW	LEBROCK 345KV	332	-0.02744	AEPW	RIVERSIDE STATION 138KV	245	0.02397	-0.05141	6
AEPW	LEBROCK 345KV	332	-0.02744	AEPW	SOUTHWESTERN STATION 138KV	86	0.02732	-0.05476	6
AEPW	LEBROCK 345KV	332	-0.02744	AEPW	WEATHERFORD 34KV	148	0.02453	-0.05197	6
AEPW	LIEBERMAN 138KV	224	-0.0261	AEPW	COMANCHE 69KV	63	0.02591	-0.05201	6
AEPW	LIEBERMAN 138KV	224	-0.0261	AEPW	SOUTHWESTERN STATION 138KV	86	0.02732	-0.05342	6
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03267	AEPW	COGENTRIX 345KV	665	0.02078	-0.05345	6
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03267	AEPW	COMANCHE 138KV	160	0.02463	-0.0573	6
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03267	AEPW	COMANCHE 69KV	63	0.02591	-0.05858	6
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03267	AEPW	NORTHEASTERN STATION 138KV	95	0.02027	-0.05294	6
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03267	AEPW	NORTHEASTERN STATION 138KV	240	0.02027	-0.05294	6
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03267	AEPW	NORTHEASTERN STATION 345KV	550	0.01967	-0.05234	6
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03267	AEPW	OEC 345KV	256	0.02031	-0.05298	6

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: CRAIG JUNCTION - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151540155600412107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1079577	0.1	0.5
1086238	0.1	0.5
1089952	0.2	0.5
1090609	0.1	0.5

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV	23.0457	0.01448	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.55337	1
SWPA	BULL SHOALS 161KV	51.81354	0.00795	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.5599	1
SWPA	CARTHAGE 69KV	1.999998	0.01468	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.55317	1
SWPA	CLARENCE CANNON DAM 69KV	8.768707	0.00781	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.56004	1
SWPA	DARDANELLE 161KV	55.73309	0.0054	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.56245	1
SWPA	DENISON 138KV	10.56222	0.0562	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.51165	1
SWPA	EUFULA 138KV	8.967567	0.03373	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.53412	1
SWPA	EUFULA 161KV	4.483784	0.03369	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.53416	1
SWPA	FORT GIBSON 161KV	7.573032	0.02189	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.54596	1
SWPA	GREERS FERRY 161KV	16.5406	0.00227	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.56558	1
SWPA	INDEPENDENCE 161KV	13	0.00217	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.56568	1
SWPA	KENNETT 69KV	21.8	0.00229	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.56556	1
SWPA	KEYSTONE DAM 161KV	10.56222	0.02229	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.54556	1
SWPA	MALDEN 69KV	10	0.00248	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.56537	1
SWPA	NORFORK 161KV	64.98728	0.00614	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.56171	1
SWPA	OZARK 161KV	36.9504	0.01205	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.5558	1
SWPA	PARAGOULD 69KV	12	0.00203	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.56582	1
SWPA	PIGGOTT 69KV	7.5	0.00236	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.56549	1
SWPA	POPLAR BLUFF 69KV	7	0.00342	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.56443	1
SWPA	ROBERT S. KERR 161KV	19.13182	0.02012	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.54773	1
SWPA	STOCKTON 161KV	7.871956	0.01241	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.55544	1
SWPA	TABLE ROCK 161KV	33.08119	0.01181	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.55604	1
SWPA	TENKILLER FERRY 161KV	25.98982	0.02623	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.54162	1
SWPA	TRUMAN 161KV	77.93513	0.0106	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.55725	1
SWPA	WEBBERS FALLS 161KV	29.9752	0.02623	SWPA	BROKEN BOW 138KV	93.4594	0.56785	-0.54162	1
AEPW	NARROWS 69KV	3	-0.13328	AEPW	COMANCHE 138KV	160	0.02446	-0.15774	3
AEPW	NARROWS 69KV	3	-0.13328	AEPW	COMANCHE 69KV	63	0.02574	-0.15902	3
AEPW	NARROWS 69KV	3	-0.13328	AEPW	RIVERSIDE STATION 138KV	646	0.02273	-0.15601	3
AEPW	NARROWS 69KV	3	-0.13328	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.16041	3
AEPW	NARROWS 69KV	3	-0.13328	AEPW	WEATHERFORD 34KV	148	0.02435	-0.15763	3
AEPW	NARROWS 69KV	3	-0.13328	AEPW	WELEETKA 138KV	70	0.05322	-0.1865	3
AEPW	NARROWS 69KV	3	-0.13328	AEPW	COGENTRIX 345KV	665	0.02123	-0.15451	4
AEPW	NARROWS 69KV	3	-0.13328	AEPW	FITZHUGH 161KV	126	0.01207	-0.14535	4
AEPW	NARROWS 69KV	3	-0.13328	AEPW	FLINT CREEK 161KV	420	0.01727	-0.15055	4
AEPW	NARROWS 69KV	3	-0.13328	AEPW	L&D13 69KV	11	0.01508	-0.14836	4
AEPW	NARROWS 69KV	3	-0.13328	AEPW	NORTHEASTERN STATION 138KV	405	0.01993	-0.15321	4
AEPW	NARROWS 69KV	3	-0.13328	AEPW	NORTHEASTERN STATION 138KV	95	0.01993	-0.15321	4
AEPW	NARROWS 69KV	3	-0.13328	AEPW	NORTHEASTERN STATION 345KV	645	0.0195	-0.15278	4
AEPW	NARROWS 69KV	3	-0.13328	AEPW	OEC 345KV	206	0.02026	-0.15354	4
AEPW	NARROWS 69KV	3	-0.13328	AEPW	TULSA POWER STATION 138KV	112	0.02212	-0.1554	4
AEPW	NARROWS 69KV	3	-0.13328	AEPW	TULSA POWER STATION 138KV	147	0.02212	-0.1554	4
AEPW	FULTON 115KV	153	-0.0621	AEPW	WELEETKA 138KV	70	0.05322	-0.11532	5

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	NARROWS 69KV	3	-0.13328	AEPW	ARSENAL HILL 69KV	15	-0.02548	-0.1078	5
AEPW	NARROWS 69KV	3	-0.13328	AEPW	EASTMAN 138KV	155	-0.02808	-0.1052	5
AEPW	NARROWS 69KV	3	-0.13328	AEPW	KNOXLEE 138KV	247,525	-0.02784	-0.10544	5
AEPW	NARROWS 69KV	3	-0.13328	AEPW	LEBROCK 345KV	365	-0.02762	-0.10566	5
AEPW	NARROWS 69KV	3	-0.13328	AEPW	LIEBERMAN 138KV	91	-0.02624	-0.10704	5
AEPW	NARROWS 69KV	3	-0.13328	AEPW	PIRKEY GENERATION 138KV	475	-0.02779	-0.10549	5
AEPW	NARROWS 69KV	3	-0.13328	AEPW	WELSH 345KV	990	-0.02987	-0.10341	5
AEPW	NARROWS 69KV	3	-0.13328	AEPW	WILKES 138KV	365,3724	-0.03201	-0.10127	5
AEPW	NARROWS 69KV	3	-0.13328	AEPW	WILKES 345KV	311	-0.02873	-0.10455	5
WFEC	ANADARKO 138KV	5,542664	0.02774	WFEC	HUGO 138KV	450	0.11212	-0.08438	6
WFEC	ANADARKO 138KV	90	0.02774	WFEC	HUGO 138KV	450	0.11212	-0.08438	6
WFEC	ANADARKO 69KV	76	0.0276	WFEC	HUGO 138KV	450	0.11212	-0.08452	6
WFEC	BLUCAN14 138 138KV	151.2	0.02717	WFEC	HUGO 138KV	450	0.11212	-0.08495	6
AEPW	FULTON 115KV	153	-0.0621	AEPW	COMANCHE 138KV	160	0.02446	-0.08656	6
AEPW	FULTON 115KV	153	-0.0621	AEPW	COMANCHE 69KV	63	0.02574	-0.08784	6
AEPW	FULTON 115KV	153	-0.0621	AEPW	RIVERSIDE STATION 138KV	646	0.02273	-0.08483	6
AEPW	FULTON 115KV	153	-0.0621	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.08923	6
AEPW	FULTON 115KV	153	-0.0621	AEPW	TULSA POWER STATION 138KV	112	0.02212	-0.08422	6
AEPW	FULTON 115KV	153	-0.0621	AEPW	TULSA POWER STATION 138KV	147	0.02212	-0.08422	6
AEPW	FULTON 115KV	153	-0.0621	AEPW	WEATHERFORD 34KV	148	0.02435	-0.08645	6
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	WELEETKA 138KV	70	0.05322	-0.0859	6
WFEC	MORLND 138KV	25,26624	0.02292	WFEC	HUGO 138KV	450	0.11212	-0.0892	6
AEPW	WILKES 138KV	97,62759	-0.03201	AEPW	WELEETKA 138KV	70	0.05322	-0.08523	6
AEPW	ARSENAL HILL 69KV	75	-0.02548	AEPW	WELEETKA 138KV	70	0.05322	-0.0787	7
AEPW	EASTMAN 138KV	330.01	-0.02808	AEPW	WELEETKA 138KV	70	0.05322	-0.0813	7
AEPW	FULTON 115KV	153	-0.0621	AEPW	COGENTRIX 345KV	665	0.02123	-0.08333	7
AEPW	FULTON 115KV	153	-0.0621	AEPW	FITZHUGH 161KV	126	0.01207	-0.07417	7
AEPW	FULTON 115KV	153	-0.0621	AEPW	FLINT CREEK 161KV	420	0.01727	-0.07937	7
AEPW	FULTON 115KV	153	-0.0621	AEPW	L&D13 69KV	11	0.01508	-0.07718	7
AEPW	FULTON 115KV	153	-0.0621	AEPW	NORTHEASTERN STATION 138KV	95	0.01993	-0.08203	7
AEPW	FULTON 115KV	153	-0.0621	AEPW	NORTHEASTERN STATION 138KV	405	0.01993	-0.08203	7
AEPW	FULTON 115KV	153	-0.0621	AEPW	NORTHEASTERN STATION 345KV	645	0.0195	-0.0816	7
AEPW	FULTON 115KV	153	-0.0621	AEPW	OEC 345KV	206	0.02026	-0.08236	7
AEPW	KNOXLEE 138KV	115,4741	-0.02784	AEPW	WELEETKA 138KV	70	0.05322	-0.08106	7
AEPW	KNOXLEE 138KV	60	-0.02784	AEPW	WELEETKA 138KV	70	0.05322	-0.08106	7
AEPW	LEBROCK 345KV	332	-0.02762	AEPW	WELEETKA 138KV	70	0.05322	-0.08084	7
AEPW	LIEBERMAN 138KV	137	-0.02624	AEPW	WELEETKA 138KV	70	0.05322	-0.07946	7
AEPW	NORTH MARSHALL 69KV	5	-0.02811	AEPW	WELEETKA 138KV	70	0.05322	-0.08133	7
AEPW	PIRKEY GENERATION 138KV	40	-0.02779	AEPW	WELEETKA 138KV	70	0.05322	-0.08101	7
AEPW	TENASKA GATEWAY 345KV	937.03	-0.02632	AEPW	WELEETKA 138KV	70	0.05322	-0.07954	7
AEPW	WELSH 345KV	54	-0.02987	AEPW	WELEETKA 138KV	70	0.05322	-0.08309	7
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	COMANCHE 69KV	63	0.02574	-0.05842	9
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05891	9
AEPW	WILKES 138KV	97,62759	-0.03201	AEPW	COMANCHE 69KV	63	0.02574	-0.05775	9
AEPW	WILKES 138KV	97,62759	-0.03201	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05914	9
AEPW	ARSENAL HILL 69KV	75	-0.02548	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05261	10
AEPW	EASTMAN 138KV	330.01	-0.02808	AEPW	COMANCHE 138KV	160	0.02446	-0.05254	10
AEPW	EASTMAN 138KV	330.01	-0.02808	AEPW	COMANCHE 69KV	63	0.02574	-0.05382	10
AEPW	EASTMAN 138KV	330.01	-0.02808	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05521	10
AEPW	EASTMAN 138KV	330.01	-0.02808	AEPW	WEATHERFORD 34KV	148	0.02435	-0.05243	10
SWPA	GREERS FERRY 161KV	16,5406	0.00227	SWPA	DENISON 138KV	59,43778	0.0562	-0.05393	10
SWPA	INDEPENDENCE 161KV	13	0.00217	SWPA	DENISON 138KV	59,43778	0.0562	-0.05403	10
SWPA	KENNETT 69KV	21,8	0.00229	SWPA	DENISON 138KV	59,43778	0.0562	-0.05391	10
AEPW	KNOXLEE 138KV	115,4741	-0.02784	AEPW	COMANCHE 138KV	160	0.02446	-0.0523	10
AEPW	KNOXLEE 138KV	60	-0.02784	AEPW	COMANCHE 138KV	160	0.02446	-0.0523	10
AEPW	KNOXLEE 138KV	115,4741	-0.02784	AEPW	COMANCHE 69KV	63	0.02574	-0.05358	10
AEPW	KNOXLEE 138KV	60	-0.02784	AEPW	COMANCHE 69KV	63	0.02574	-0.05358	10
AEPW	KNOXLEE 138KV	115,4741	-0.02784	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05497	10

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: CRAIG JUNCTION - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151540155600413106WP  
 Date Redispatch Needed: 12/1/06 - 4/1/07  
 Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1079577	0.8	1.0
1090609	0.2	1.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV	40,55142	0.01453	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.55338	2
SWPA	BULL SHOALS 161KV	98,0007	0.00796	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.55995	2
SWPA	CARTHAGE 69KV	21	0.01474	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.55317	2
SWPA	CLARENCE CANNON DAM 69KV	58	0.00786	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56005	2
SWPA	DARDANELLE 161KV	45,80034	0.00537	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56254	2
SWPA	DENISON 138KV	19,80014	0.05626	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.51165	2
SWPA	EUFAULA 138KV	17,00013	0.03387	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.53404	2
SWPA	EUFAULA 161KV	8,500065	0.03384	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.53407	2
SWPA	FORT GIBSON 161KV	14,00011	0.02196	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.54595	2
SWPA	GREERS FERRY 161KV	31,20022	0.00228	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56563	2
SWPA	INDEPENDENCE 161KV	13	0.00217	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56574	2
SWPA	JONESBORO 161KV	3,399998	0.00183	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56608	2
SWPA	KENNETT 69KV	29	0.00228	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56563	2
SWPA	KEYSTONE DAM 161KV	19,80014	0.0226	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.54531	2
SWPA	MALDEN 69KV	15	0.00246	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56545	2
SWPA	NORFORK 161KV	24,20018	0.00615	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56176	2
SWPA	OZARK 161KV	49,00019	0.01204	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.55587	2
SWPA	PARAGOULD 69KV	17,5	0.00202	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56589	2
SWPA	PIGGOTT 69KV	7,5	0.00234	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56557	2
SWPA	POPLAR BLUFF 69KV	13	0.00336	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.56455	2
SWPA	ROBERT S. KERR 161KV	36,00027	0.02016	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.54775	2
SWPA	STOCKTON 161KV	14,80011	0.01246	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.55545	2
SWPA	TABLE ROCK 161KV	62,40044	0.01185	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.55606	2
SWPA	TENKILLER FERRY 161KV	12,00009	0.02634	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.54157	2
SWPA	TRUMAN 161KV	94,00026	0.01068	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.55723	2
SWPA	WEBBERS FALLS 161KV	36,00011	0.02634	SWPA	BROKEN BOW 138KV	78,79978	0.56791	-0.54157	2
AEPW	NARROWS 69KV	30	-0.13328	AEPW	COMANCHE 138KV	160	0.02447	-0.15775	6
AEPW	NARROWS 69KV	30	-0.13328	AEPW	COMANCHE 69KV	63	0.02576	-0.15904	6
AEPW	NARROWS 69KV	30	-0.13328	AEPW	RIVERSIDE STATION 138KV	234	0.02379	-0.15707	6
AEPW	NARROWS 69KV	30	-0.13328	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.16044	6



Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

AEPW	NARROWS 69KV	30	-0.13328	AEPW	WEATHERFORD 34KV	148	0.02438	-0.15766	6
AEPW	NARROWS 69KV	30	-0.13328	AEPW	COGENTRIX 345KV	665	0.02061	-0.15389	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	FITZHUGH 161KV	81	0.01206	-0.14534	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	FLINT CREEK 161KV	400	0.01732	-0.1506	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	L&D13 69KV	11	0.01508	-0.14836	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	NORTHEASTERN STATION 138KV	207	0.02011	-0.15339	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	NORTHEASTERN STATION 138KV	95	0.02011	-0.15339	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	NORTHEASTERN STATION 345KV	600	0.01951	-0.15279	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	OEC 345KV	256	0.02013	-0.15341	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	EASTMAN 138KV	155	-0.02801	-0.10527	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	KNOXLEE 138KV	103	-0.02777	-0.10551	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	LEBROCK 345KV	365	-0.0276	-0.10568	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	LIEBERMAN 138KV	4	-0.02626	-0.10702	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	PIRKEY GENERATION 138KV	450	-0.02777	-0.10551	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	WELSH 345KV	960	-0.02988	-0.1034	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	WILKES 138KV	141.6191	-0.03209	-0.10119	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	WILKES 345KV	147.4476	-0.02876	-0.10452	10
AEPW	FULTON 115KV	153	-0.06212	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.08928	11
WFEC	MORLND 138KV	320	0.02296	WFEC	HUGO 138KV	450	0.11216	-0.0892	11
WFEC	ANADARKO 138KV	67.87025	0.02777	WFEC	HUGO 138KV	450	0.11216	-0.08439	12
WFEC	ANADARKO 138KV	90	0.02777	WFEC	HUGO 138KV	450	0.11216	-0.08439	12
WFEC	ANADARKO 69KV	76	0.02764	WFEC	HUGO 138KV	450	0.11216	-0.08452	12
WFEC	BLUCAN14 138 138KV	151.2	0.0272	WFEC	HUGO 138KV	450	0.11216	-0.08496	12
AEPW	FULTON 115KV	153	-0.06212	AEPW	COGENTRIX 345KV	665	0.02061	-0.08273	12
AEPW	FULTON 115KV	153	-0.06212	AEPW	COMANCHE 138KV	160	0.02447	-0.08659	12
AEPW	FULTON 115KV	153	-0.06212	AEPW	COMANCHE 69KV	63	0.02576	-0.08788	12
AEPW	FULTON 115KV	153	-0.06212	AEPW	NORTHEASTERN STATION 138KV	95	0.02011	-0.08223	12
AEPW	FULTON 115KV	153	-0.06212	AEPW	NORTHEASTERN STATION 138KV	207	0.02011	-0.08223	12
AEPW	FULTON 115KV	153	-0.06212	AEPW	OEC 345KV	256	0.02013	-0.08225	12
AEPW	FULTON 115KV	153	-0.06212	AEPW	RIVERSIDE STATION 138KV	234	0.02379	-0.08591	12
AEPW	FULTON 115KV	153	-0.06212	AEPW	WEATHERFORD 34KV	148	0.02438	-0.0865	12
AEPW	FULTON 115KV	153	-0.06212	AEPW	FLINT CREEK 161KV	400	0.01732	-0.07944	13
AEPW	FULTON 115KV	153	-0.06212	AEPW	L&D13 69KV	11	0.01508	-0.0772	13
AEPW	FULTON 115KV	153	-0.06212	AEPW	NORTHEASTERN STATION 345KV	600	0.01951	-0.08163	13
AEPW	FULTON 115KV	153	-0.06212	AEPW	FITZHUGH 161KV	81	0.01206	-0.07418	14
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03283	AEPW	COMANCHE 69KV	63	0.02576	-0.05859	17
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03283	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.05999	17
AEPW	WILKES 138KV	321.3809	-0.03209	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.05925	17
AEPW	EASTMAN 138KV	330.01	-0.02801	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.05517	18
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03283	AEPW	COMANCHE 138KV	160	0.02447	-0.0573	18
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03283	AEPW	RIVERSIDE STATION 138KV	234	0.02379	-0.05662	18
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03283	AEPW	WEATHERFORD 34KV	148	0.02438	-0.05721	18
AEPW	WELSH 345KV	84	-0.02988	AEPW	COMANCHE 69KV	63	0.02576	-0.05564	18
AEPW	WELSH 345KV	84	-0.02988	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.05704	18
AEPW	WILKES 138KV	321.3809	-0.03209	AEPW	COMANCHE 138KV	160	0.02447	-0.05656	18
AEPW	WILKES 138KV	321.3809	-0.03209	AEPW	COMANCHE 69KV	63	0.02576	-0.05785	18
AEPW	WILKES 138KV	321.3809	-0.03209	AEPW	RIVERSIDE STATION 138KV	234	0.02379	-0.05588	18
AEPW	WILKES 138KV	321.3809	-0.03209	AEPW	WEATHERFORD 34KV	148	0.02438	-0.05647	18
AEPW	WILKES 345KV	163.5524	-0.02876	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.05592	18
AEPW	ARSENAL HILL 69KV	99	-0.02549	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.05265	19
AEPW	EASTMAN 138KV	330.01	-0.02801	AEPW	COMANCHE 138KV	160	0.02447	-0.05248	19
AEPW	EASTMAN 138KV	330.01	-0.02801	AEPW	COMANCHE 69KV	63	0.02576	-0.05377	19
AEPW	EASTMAN 138KV	330.01	-0.02801	AEPW	WEATHERFORD 34KV	148	0.02438	-0.05239	19
SWPA	GREERS FERRY 161KV	31.20022	0.00228	SWPA	DENISON 138KV	50.19986	0.05626	-0.05398	19
SWPA	INDEPENDENCE 161KV	13	0.00217	SWPA	DENISON 138KV	50.19986	0.05626	-0.05409	19
SWPA	KENNETT 69KV	29	0.00228	SWPA	DENISON 138KV	50.19986	0.05626	-0.05398	19
AEPW	KNOXLEE 138KV	260	-0.02777	AEPW	COMANCHE 69KV	63	0.02576	-0.05353	19
AEPW	KNOXLEE 138KV	60	-0.02777	AEPW	COMANCHE 69KV	63	0.02576	-0.05353	19
AEPW	KNOXLEE 138KV	260	-0.02777	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.05493	19
AEPW	KNOXLEE 138KV	60	-0.02777	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.05493	19
AEPW	LEBROCK 345KV	332	-0.0276	AEPW	COMANCHE 69KV	63	0.02576	-0.05336	19
AEPW	LEBROCK 345KV	332	-0.0276	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.05476	19
AEPW	LIEBERMAN 138KV	224	-0.02626	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.05342	19
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03283	AEPW	COGENTRIX 345KV	665	0.02061	-0.05344	19
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03283	AEPW	NORTHEASTERN STATION 138KV	207	0.02011	-0.05294	19
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03283	AEPW	NORTHEASTERN STATION 138KV	95	0.02011	-0.05294	19
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03283	AEPW	NORTHEASTERN STATION 345KV	600	0.01951	-0.05234	19
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03283	AEPW	OEC 345KV	256	0.02013	-0.05296	19
SWPA	MALDEN 69KV	15	0.00246	SWPA	DENISON 138KV	50.19986	0.05626	-0.0538	19
SWPA	PARAGOULD 69KV	17.5	0.00202	SWPA	DENISON 138KV	50.19986	0.05626	-0.05424	19

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: CRAIG JUNCTION - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151540155600413107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1079577	0.8	3.3
1086238	0.4	3.3
1089952	1.7	3.3
1090609	0.4	3.3

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV	11.47467	0.01451	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.55336	6
SWPA	BULL SHOALS 161KV	194.6908	0.00797	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.5599	6
SWPA	CARTHAGE 69KV	32	0.0147	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.55317	6
SWPA	CLARENCE CANNON DAM 69KV	3.360355	0.00782	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.56005	6
SWPA	DARDANELLE 161KV	55.72362	0.00541	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.56246	6
SWPA	DENISON 138KV	4.152222	0.05622	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.51165	6
SWPA	EUFAULA 138KV	3.559044	0.03374	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.53413	6
SWPA	FORT GIBSON 161KV	13.97386	0.0219	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.54597	6
SWPA	GREERS FERRY 161KV	6.324776	0.00228	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.56559	6
SWPA	INDEPENDENCE 161KV	13	0.00217	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.5657	6
SWPA	JONESBORO 161KV	76	0.00185	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.56602	6
SWPA	KENNETT 69KV	29	0.00229	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.56558	6
SWPA	KEYSTONE DAM 161KV	34.97459	0.0223	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.54557	6
SWPA	MALDEN 69KV	15	0.00248	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.56539	6
SWPA	NORFORK 161KV	64.98547	0.00616	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.56171	6
SWPA	OZARK 161KV	50.95354	0.01206	SWPA	BROKEN BOW 138KV	103.6752	0.56787	-0.55581	6

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SWPA	PARAGOULD 69KV'	17.5	0.00204	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56583	6
SWPA	PIGGOTT 69KV'	7.5	0.00236	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56551	6
SWPA	POPLAR BLUFF 69KV'	13	0.00343	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56444	6
SWPA	ROBERT S. KERR 161KV'	31.13089	0.02014	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.54773	6
SWPA	STOCKTON 161KV'	3.064487	0.01244	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.55543	6
SWPA	TABLE ROCK 161KV'	59.88382	0.01183	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.55604	6
SWPA	TENKILLER FERRY 161KV'	25.98838	0.02625	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.54162	6
SWPA	TRUMAN 161KV'	67.11809	0.01063	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.55724	6
SWPA	WEBBERS FALLS 161KV'	38.17764	0.02625	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.54162	6
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.16042	20
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	COGENTRIX 345KV'	665	0.02125	-0.15452	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	COMANCHE 138KV'	160	0.02448	-0.15775	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	COMANCHE 69KV'	63	0.02576	-0.15903	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	'NORTHEASTERN STATION 138KV'	95	0.01995	-0.15322	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	'NORTHEASTERN STATION 138KV'	207	0.01995	-0.15322	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	OEC 345KV'	256	0.02027	-0.15354	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	RIVERSIDE STATION 138KV'	245	0.02274	-0.15601	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	'WEATHERFORD 34KV'	148	0.02437	-0.15764	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	FLINT CREEK 161KV'	400	0.01729	-0.15056	22
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	L&D13 69KV'	11	0.01509	-0.14836	22
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	'NORTHEASTERN STATION 345KV'	550	0.01951	-0.15278	22
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	FITZHUGH 161KV'	92	0.01208	-0.14535	23
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	EASTMAN 138KV'	155	-0.02807	-0.1052	31
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	KNOXLEE 138KV'	42	-0.02783	-0.10544	31
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	LEBROCK 345KV'	365	-0.02761	-0.10566	31
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	PIRKEY GENERATION 138KV'	440	-0.02778	-0.10549	31
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	'WILKES 345KV'	76.02601	-0.02872	-0.10455	31
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	'WELSH 345KV'	990	-0.02986	-0.10341	32
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	'WILKES 138KV'	36.91098	-0.032	-0.10127	32
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COMANCHE 69KV'	63	0.02576	-0.08786	37
AEPW	FULTON 115KV'	153	-0.0621	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.08925	37
WFEC	MORLND 138KV'	320	0.02294	WFEC	HUGO 138KV'	450	0.11213	-0.08919	37
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COMANCHE 138KV'	160	0.02448	-0.08658	38
AEPW	FULTON 115KV'	153	-0.0621	AEPW	'WEATHERFORD 34KV'	148	0.02437	-0.08647	38
WFEC	ANADARKO 138KV'	40.57323	0.02776	WFEC	HUGO 138KV'	450	0.11213	-0.08437	39
WFEC	ANADARKO 138KV'	90	0.02776	WFEC	HUGO 138KV'	450	0.11213	-0.08437	39
WFEC	ANADARKO 69KV'	76	0.02762	WFEC	HUGO 138KV'	450	0.11213	-0.08451	39
WFEC	BLUCAN14 138 138KV'	151.2	0.02719	WFEC	HUGO 138KV'	450	0.11213	-0.08494	39
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COGENTRIX 345KV'	665	0.02125	-0.08335	39
AEPW	FULTON 115KV'	153	-0.0621	AEPW	RIVERSIDE STATION 138KV'	245	0.02274	-0.08484	39
AEPW	FULTON 115KV'	153	-0.0621	AEPW	'NORTHEASTERN STATION 138KV'	95	0.01995	-0.08205	40
AEPW	FULTON 115KV'	153	-0.0621	AEPW	'NORTHEASTERN STATION 138KV'	207	0.01995	-0.08205	40
AEPW	FULTON 115KV'	153	-0.0621	AEPW	'NORTHEASTERN STATION 345KV'	550	0.01951	-0.08161	40
AEPW	FULTON 115KV'	153	-0.0621	AEPW	OEC 345KV'	256	0.02027	-0.08237	40
AEPW	FULTON 115KV'	153	-0.0621	AEPW	FLINT CREEK 161KV'	400	0.01729	-0.07939	41
AEPW	FULTON 115KV'	153	-0.0621	AEPW	FITZHUGH 161KV'	92	0.01208	-0.07418	44
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05982	55
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	COMANCHE 69KV'	63	0.02576	-0.05843	56
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05915	56
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	COMANCHE 138KV'	160	0.02448	-0.05715	57
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	COMANCHE 69KV'	63	0.02576	-0.05776	57
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	'WEATHERFORD 34KV'	148	0.02437	-0.05704	58
AEPW	WELSH 345KV'	54	-0.02986	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05701	58
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	COMANCHE 138KV'	160	0.02448	-0.05648	58
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	'WEATHERFORD 34KV'	148	0.02437	-0.05637	58
AEPW	EASTMAN 138KV'	330.01	-0.02807	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05522	59
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	RIVERSIDE STATION 138KV'	245	0.02274	-0.05541	59
AEPW	WELSH 345KV'	54	-0.02986	AEPW	COMANCHE 69KV'	63	0.02576	-0.05562	59
AEPW	WILKES 345KV'	234.974	-0.02872	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05587	59
SWPA	JONESBORO 161KV'	76	0.00185	SWPA	DENISON 138KV'	65.84778	0.05622	-0.05437	60
AEPW	KNOXLEE 138KV'	321	-0.02783	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05498	60
AEPW	KNOXLEE 138KV'	60	-0.02783	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05498	60
AEPW	LEBROCK 345KV'	332	-0.02761	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05476	60
AEPW	PIRKEY GENERATION 138KV'	75	-0.02778	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05493	60
AEPW	WELSH 345KV'	54	-0.02986	AEPW	COMANCHE 138KV'	160	0.02448	-0.05434	60
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	RIVERSIDE STATION 138KV'	245	0.02274	-0.05474	60
AEPW	WILKES 345KV'	234.974	-0.02872	AEPW	COMANCHE 69KV'	63	0.02576	-0.05448	60
AEPW	EASTMAN 138KV'	330.01	-0.02807	AEPW	COMANCHE 69KV'	63	0.02576	-0.05383	61
SWPA	KENNETT 69KV'	29	0.00229	SWPA	DENISON 138KV'	65.84778	0.05622	-0.05393	61
AEPW	KNOXLEE 138KV'	321	-0.02783	AEPW	COMANCHE 69KV'	63	0.02576	-0.05359	61
AEPW	KNOXLEE 138KV'	60	-0.02783	AEPW	COMANCHE 69KV'	63	0.02576	-0.05359	61
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	COGENTRIX 345KV'	665	0.02125	-0.05392	61
AEPW	PIRKEY GENERATION 138KV'	75	-0.02778	AEPW	COMANCHE 69KV'	63	0.02576	-0.05354	61
AEPW	TENASKA GATEWAY 345KV'	937.03	0.02631	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05346	61
AEPW	WELSH 345KV'	54	-0.02986	AEPW	'WEATHERFORD 34KV'	148	0.02437	-0.05423	61
AEPW	ARSENAL HILL 69KV'	99	-0.02547	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05262	62
AEPW	LEBROCK 345KV'	332	-0.02761	AEPW	COMANCHE 69KV'	63	0.02576	-0.05337	62
AEPW	LIEBERMAN 138KV'	224	-0.02623	AEPW	'SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05338	62
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	'NORTHEASTERN STATION 138KV'	207	0.01995	-0.05262	62
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	'NORTHEASTERN STATION 138KV'	95	0.01995	-0.05262	62
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	OEC 345KV'	256	0.02027	-0.05294	62
AEPW	WELSH 345KV'	54	-0.02986	AEPW	RIVERSIDE STATION 138KV'	245	0.02274	-0.0526	62
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	COGENTRIX 345KV'	665	0.02125	-0.05325	62
AEPW	WILKES 345KV'	234.974	-0.02872	AEPW	COMANCHE 138KV'	160	0.02448	-0.0532	62

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: CRAIG JUNCTION - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151540155600413107G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount
1079577	0.8	1.0
1090609	0.2	1.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV'	34.13196	0.01453	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55338	2
SWPA	BULL SHOALS 161KV'	90.8008	0.00795	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55996	2
SWPA	CARTHAGE 69KV'	32	0.01474	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55317	2
SWPA	CLARENCE CANNON DAM 69KV'	58	0.00784	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56007	2

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

SWPA	DARDANELLE 161KV'	42.20037	0.00537	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56254	2
SWPA	DENISON 138KV'	18.40016	0.05627	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.51164	2
SWPA	EUFAULA 138KV'	15.80014	0.03387	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.53404	2
SWPA	EUFAULA 161KV'	7.900072	0.03383	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.53408	2
SWPA	FORT GIBSON 161KV'	13.20012	0.02196	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.54595	2
SWPA	GREERS FERRY 161KV'	29.00026	0.00227	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56564	2
SWPA	INDEPENDENCE 161KV'	13	0.00216	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56575	2
SWPA	JONESBORO 161KV'	76	0.00182	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56609	2
SWPA	KENNETT 69KV'	29	0.00227	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56564	2
SWPA	KEYSTONE DAM 161KV'	18.40016	0.0226	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.54531	2
SWPA	MALDEN 69KV'	14	0.00246	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56545	2
SWPA	NORFORK 161KV'	22.4002	0.00614	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56177	2
SWPA	OZARK 161KV'	47.00022	0.01204	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55587	2
SWPA	PARAGOULD 69KV'	17.5	0.00201	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.5659	2
SWPA	PIGGOTT 69KV'	7.5	0.00234	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56557	2
SWPA	POPLAR BLUFF 69KV'	13	0.00336	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56455	2
SWPA	ROBERT S. KERR 161KV'	33.20031	0.02016	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.54775	2
SWPA	STOCKTON 161KV'	13.70012	0.01246	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55545	2
SWPA	TABLE ROCK 161KV'	58.00002	0.01185	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55606	2
SWPA	TENKILLER FERRY 161KV'	11.00001	0.02634	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.54157	2
SWPA	TRUMAN 161KV'	91.60003	0.01068	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55723	2
SWPA	WEBBERS FALLS 161KV'	35.00011	0.02634	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.54157	2
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	COMANCHE 138KV'	160	0.02448	-0.15776	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	COMANCHE 69KV'	63	0.02576	-0.15904	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	RIVERSIDE STATION 138KV'	379	0.02379	-0.15707	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.16045	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	TULSA POWER STATION 138KV'	38	0.02304	-0.15632	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.15767	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	COGENTRIX 345KV'	665	0.02061	-0.15389	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	FITZHUGH 161KV'	89	0.01206	-0.14534	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	FLINT CREEK 161KV'	400	0.01732	-0.1506	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	L&D13 69KV'	11	0.01508	-0.14836	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	NORTHEASTERN STATION 138KV'	95	0.02011	-0.15339	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	NORTHEASTERN STATION 138KV'	304	0.02011	-0.15339	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	NORTHEASTERN STATION 345KV'	550	0.01951	-0.15279	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	OEC 345KV'	256	0.02014	-0.15342	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	LIEBERMAN 138KV'	48.63074	-0.02626	-0.10702	9
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	EASTMAN 138KV'	155	-0.02801	-0.10527	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	KNOXLEE 138KV'	103	-0.02777	-0.10551	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	LEBROCK 345KV'	365	-0.0276	-0.10568	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	PIRKEY GENERATION 138KV'	440	-0.02777	-0.10551	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	WELSH 345KV'	1012	-0.02988	-0.1034	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	WILKES 138KV'	133	-0.03209	-0.10119	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	WILKES 345KV'	200.1422	-0.02876	-0.10452	10
AEPW	FULTON 115KV'	153	-0.06212	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.08929	11
WFEC	MORLND 138KV'	320	0.02296	WFEC	HUGO 138KV'	450	0.11216	-0.0892	11
WFEC	ANADARKO 138KV'	41.68806	0.02778	WFEC	HUGO 138KV'	450	0.11216	-0.08438	12
WFEC	ANADARKO 138KV'	90	0.02778	WFEC	HUGO 138KV'	450	0.11216	-0.08438	12
WFEC	ANADARKO 69KV'	76	0.02764	WFEC	HUGO 138KV'	450	0.11216	-0.08452	12
WFEC	BLUCAN14 138 138KV'	151.2	0.0272	WFEC	HUGO 138KV'	450	0.11216	-0.08496	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	COGENTRIX 345KV'	665	0.02061	-0.08273	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	COMANCHE 138KV'	160	0.02448	-0.0866	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	COMANCHE 69KV'	63	0.02576	-0.08788	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	NORTHEASTERN STATION 138KV'	304	0.02011	-0.08223	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	NORTHEASTERN STATION 138KV'	95	0.02011	-0.08223	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	NORTHEASTERN STATION 345KV'	550	0.01951	-0.08163	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	OEC 345KV'	256	0.02014	-0.08226	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	RIVERSIDE STATION 138KV'	379	0.02379	-0.08591	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	TULSA POWER STATION 138KV'	38	0.02304	-0.08516	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.08651	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	FLINT CREEK 161KV'	400	0.01732	-0.07944	13
AEPW	FULTON 115KV'	153	-0.06212	AEPW	L&D13 69KV'	11	0.01508	-0.0772	13
AEPW	FULTON 115KV'	153	-0.06212	AEPW	FITZHUGH 161KV'	89	0.01206	-0.07418	14
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	COMANCHE 69KV'	63	0.02576	-0.05859	17
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.06	17
AEPW	WILKES 138KV'	330	-0.03209	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05926	17
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05518	18
AEPW	KNOXLEE 138KV'	260	-0.02777	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05494	18
AEPW	KNOXLEE 138KV'	60	-0.02777	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05494	18
AEPW	LEBROCK 345KV'	332	-0.0276	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05477	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	COMANCHE 138KV'	160	0.02448	-0.05731	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	RIVERSIDE STATION 138KV'	379	0.02379	-0.05662	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	TULSA POWER STATION 138KV'	38	0.02304	-0.05587	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.05722	18
AEPW	PIRKEY GENERATION 138KV'	75	-0.02777	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05494	18
AEPW	WELSH 345KV'	32	-0.02988	AEPW	COMANCHE 69KV'	63	0.02576	-0.05564	18
AEPW	WELSH 345KV'	32	-0.02988	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05705	18
AEPW	WILKES 138KV'	330	-0.03209	AEPW	COMANCHE 138KV'	160	0.02448	-0.05657	18
AEPW	WILKES 138KV'	330	-0.03209	AEPW	COMANCHE 69KV'	63	0.02576	-0.05785	18
AEPW	WILKES 138KV'	330	-0.03209	AEPW	RIVERSIDE STATION 138KV'	379	0.02379	-0.05588	18
AEPW	WILKES 138KV'	330	-0.03209	AEPW	TULSA POWER STATION 138KV'	38	0.02304	-0.05513	18
AEPW	WILKES 138KV'	330	-0.03209	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.05648	18
AEPW	WILKES 345KV'	110.8578	-0.02876	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05593	18
AEPW	ARSENAL HILL 69KV'	99	-0.02549	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05266	19
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	COMANCHE 138KV'	160	0.02448	-0.05249	19
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	COMANCHE 69KV'	63	0.02576	-0.05377	19
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.0524	19
SWPA	GREERS FERRY 161KV'	29.00026	0.00227	SWPA	DENISON 138KV'	51.59984	0.05627	-0.054	19
SWPA	INDEPENDENCE 161KV'	13	0.00216	SWPA	DENISON 138KV'	51.59984	0.05627	-0.05411	19
SWPA	JONESBORO 161KV'	76	0.00182	SWPA	DENISON 138KV'	51.59984	0.05627	-0.05445	19
SWPA	KENNETT 69KV'	29	0.00227	SWPA	DENISON 138KV'	51.59984	0.05627	-0.054	19
AEPW	KNOXLEE 138KV'	260	-0.02777	AEPW	COMANCHE 138KV'	160	0.02448	-0.05225	19
AEPW	KNOXLEE 138KV'	60	-0.02777	AEPW	COMANCHE 138KV'	160	0.02448	-0.05225	19
AEPW	KNOXLEE 138KV'	260	-0.02777	AEPW	COMANCHE 69KV'	63	0.02576	-0.05353	19
AEPW	KNOXLEE 138KV'	60	-0.02777	AEPW	COMANCHE 69KV'	63	0.02576	-0.05353	19
AEPW	KNOXLEE 138KV'	260	-0.02777	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.05216	19

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: BBDAMP4 - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151558235600411107WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Season Flowgate Identified: 2007 Winter Peak		Aggregate Relief Amount							
Reservation	Relief Amount								
1079577	0.8	4.5							
1086238	0.4	4.5							
1089945	1.7	4.5							
1089952	1.3	4.5							
1090609	0.2	4.5							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV'	40.14902	0.0146	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.55337	8
SWPA	BULL SHOALS 161KV'	96.02807	0.00807	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.5599	8
SWPA	CARTHAGE 69KV'	20	0.01477	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.5532	8
SWPA	CLARENCE CANNON DAM 69KV'	58	0.00785	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56012	8
SWPA	DARDANELLE 161KV'	44.56081	0.00557	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.5624	8
SWPA	EUFAULA 138KV'	16.68303	0.03385	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.53412	8
SWPA	EUFAULA 161KV'	8.341516	0.03381	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.53416	8
SWPA	FORT GIBSON 161KV'	13.83629	0.022	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.54597	8
SWPA	GREERS FERRY 161KV'	30.51932	0.00243	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56554	8
SWPA	INDEPENDENCE 161KV'	13	0.00231	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56566	8
SWPA	JONESBORO 161KV'	2.799999	0.00195	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56602	8
SWPA	KENNETT 69KV'	29	0.00238	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56559	8
SWPA	KEYSTONE DAM 161KV'	19.52976	0.02239	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.54558	8
SWPA	MALDEN 69KV'	15	0.00255	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56542	8
SWPA	NORFORK 161KV'	23.60118	0.00625	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56172	8
SWPA	OZARK 161KV'	48.63363	0.01221	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.55576	8
SWPA	PARAGOULD 69KV'	17.5	0.00213	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56584	8
SWPA	PIGGOTT 69KV'	7.5	0.00244	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56553	8
SWPA	POPLAR BLUFF 69KV'	13	0.0035	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56447	8
SWPA	ROBERT S. KERR 161KV'	34.99723	0.02027	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.5477	8
SWPA	STOCKTON 161KV'	14.44538	0.01249	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.55548	8
SWPA	TABLE ROCK 161KV'	61.03864	0.01191	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.56606	8
SWPA	TENKILLER FERRY 161KV'	11.59864	0.02636	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.54161	8
SWPA	TRUMAN 161KV'	93.36607	0.01066	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.55731	8
SWPA	WEBBERS FALLS 161KV'	35.81681	0.02636	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.54161	8
SWPA	DENISON 138KV'	19.52976	0.05631	SWPA	BROKEN BOW 138KV'	79.48068	0.56797	-0.51166	9
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	COMANCHE 69KV'	63	0.02584	-0.15899	28
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.16038	28
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	COGENTRIX 345KV'	665	0.02134	-0.15449	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	COMANCHE 138KV'	160	0.02456	-0.15771	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	NORTHEASTERN STATION 138KV'	207	0.02003	-0.15318	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	NORTHEASTERN STATION 138KV'	95	0.02003	-0.15318	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	NORTHEASTERN STATION 345KV'	600	0.01959	-0.15274	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	OEC 345KV'	206	0.02036	-0.15351	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	RIVERSIDE STATION 138KV'	235	0.02283	-0.15598	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.1576	29
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	FLINT CREEK 161KV'	400	0.01738	-0.15053	30
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	L&D13 69KV'	11	0.01523	-0.14838	30
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	FITZHUGH 161KV'	31	0.01223	-0.14538	31
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	LIEBERMAN 138KV'	48.94702	-0.02612	-0.10703	42
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	EASTMAN 138KV'	155	-0.02795	-0.1052	43
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	KNOXLEE 138KV'	103	-0.02772	-0.10543	43
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	LEBROCK 345KV'	365	-0.0275	-0.10565	43
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	PIRKEY GENERATION 138KV'	450	-0.02767	-0.10548	43
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	WILKES 345KV'	191	-0.02861	-0.10454	43
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	WELSH 345KV'	975.0001	-0.02975	-0.1034	44
AEPW	NARROWS 69KV'	30	-0.13315	AEPW	WILKES 138KV'	119.4252	-0.03189	-0.10126	44
AEPW	FULTON 115KV'	153	-0.06196	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.08919	50
WFEC	MORLND 138KV'	133.0715	0.02302	WFEC	HUGO 138KV'	450	0.11223	-0.08921	50
AEPW	FULTON 115KV'	153	-0.06196	AEPW	COMANCHE 69KV'	63	0.02584	-0.0878	51
AEPW	FULTON 115KV'	153	-0.06196	AEPW	COMANCHE 138KV'	160	0.02456	-0.08652	52
AEPW	FULTON 115KV'	153	-0.06196	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.08641	52
WFEC	ANADARKO 138KV'	90	0.02784	WFEC	HUGO 138KV'	450	0.11223	-0.08439	53
WFEC	ANADARKO 69KV'	76	0.0277	WFEC	HUGO 138KV'	450	0.11223	-0.08453	53
WFEC	BLUCAN14 138 138KV'	151.2	0.02727	WFEC	HUGO 138KV'	450	0.11223	-0.08496	53
AEPW	FULTON 115KV'	153	-0.06196	AEPW	RIVERSIDE STATION 138KV'	235	0.02283	-0.08479	53
AEPW	FULTON 115KV'	153	-0.06196	AEPW	COGENTRIX 345KV'	665	0.02134	-0.0833	54
AEPW	FULTON 115KV'	153	-0.06196	AEPW	NORTHEASTERN STATION 138KV'	95	0.02003	-0.08199	55
AEPW	FULTON 115KV'	153	-0.06196	AEPW	NORTHEASTERN STATION 138KV'	207	0.02003	-0.08199	55
AEPW	FULTON 115KV'	153	-0.06196	AEPW	NORTHEASTERN STATION 345KV'	600	0.01959	-0.08155	55
AEPW	FULTON 115KV'	153	-0.06196	AEPW	OEC 345KV'	206	0.02036	-0.08232	55
AEPW	FULTON 115KV'	153	-0.06196	AEPW	FLINT CREEK 161KV'	400	0.01738	-0.07934	57
AEPW	FULTON 115KV'	153	-0.06196	AEPW	FITZHUGH 161KV'	31	0.01223	-0.07419	61
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05979	75
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05912	76
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	COMANCHE 69KV'	63	0.02584	-0.0584	77
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	COMANCHE 69KV'	63	0.02584	-0.05773	78
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	COMANCHE 138KV'	160	0.02456	-0.05712	79
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.05701	79
AEPW	WELSH 345KV'	68.99991	-0.02975	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05698	79
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	COMANCHE 138KV'	160	0.02456	-0.05645	80
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.05634	80
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	RIVERSIDE STATION 138KV'	235	0.02283	-0.05539	81
AEPW	WELSH 345KV'	68.99991	-0.02975	AEPW	COMANCHE 69KV'	63	0.02584	-0.05559	81
AEPW	WILKES 345KV'	120	-0.02861	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05584	81
AEPW	EASTMAN 138KV'	330.01	-0.02795	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05518	82
AEPW	KNOXLEE 138KV'	260	-0.02772	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05495	82
AEPW	KNOXLEE 138KV'	60	-0.02772	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05495	82
AEPW	LEBROCK 345KV'	332	-0.0275	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05473	82
AEPW	PIRKEY GENERATION 138KV'	65	-0.02767	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.0549	82
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	RIVERSIDE STATION 138KV'	235	0.02283	-0.05472	82
AEPW	WELSH 345KV'	68.99991	-0.02975	AEPW	COMANCHE 138KV'	160	0.02456	-0.05431	83
AEPW	WELSH 345KV'	68.99991	-0.02975	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.0542	83
AEPW	WILKES 345KV'	120	-0.02861	AEPW	COMANCHE 69KV'	63	0.02584	-0.05445	83
AEPW	EASTMAN 138KV'	330.01	-0.02795	AEPW	COMANCHE 69KV'	63	0.02584	-0.05379	84
SWPA	GREERS FERRY 161KV'	30.51932	0.00243	SWPA	DENISON 138KV'	50.47024	0.05631	-0.05388	84
SWPA	KENNETT 69KV'	29	0.00238	SWPA	DENISON 138KV'	50.47024	0.05631	-0.05393	84
AEPW	KNOXLEE 138KV'	260	-0.02772	AEPW	COMANCHE 69KV'	63	0.02584	-0.05356	84
AEPW	KNOXLEE 138KV'	60	-0.02772	AEPW	COMANCHE 69KV'	63	0.02584	-0.05356	84
AEPW	LEBROCK 345KV'	332	-0.0275	AEPW	COMANCHE 69KV'	63	0.02584	-0.05334	84
AEPW	LIEBERMAN 138KV'	179.053	-0.02612	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05335	84
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	COGENTRIX 345KV'	665	0.02134	-0.0539	84
AEPW	PIRKEY GENERATION 138KV'	65	-0.02767	AEPW	COMANCHE 69KV'	63	0.02584	-0.05351	84
AEPW	TENASKA GATEWAY 345KV'	937.03	-0.0262	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05343	84
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03256	AEPW	OEC 345KV'	206	0.02036	-0.05292	85
AEPW	WILKES 138KV'	343.5748	-0.03189	AEPW	COGENTRIX 345KV'	665	0.02134	-0.05323	85

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	WILKES 345KV'	120	-0.02861	AEPW	COMANCHE 138KV'	160	0.02456	-0.05317	85
AEPW	WILKES 345KV'	120	-0.02861	AEPW	WEATHERFORD 34KV'	148	0.02445	-0.05306	85
AEPW	ARSENAL HILL 69KV'	99	-0.02535	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02723	-0.05258	86
AEPW	EASTMAN 138KV'	330.01	-0.02795	AEPW	COMANCHE 138KV'	160	0.02456	-0.05251	86

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: BBDAMP4 - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151558235600412106FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount			Maximum Decrement (MW)	GSF	Factor	Redispatch Amount (MW)	
1090609	0.3	0.3							
Source Control Area	Source	Maximum Increment (MW)	GSF	Sink Control Area	Sink	Maximum Decrement (MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV'	12.35929	0.01471	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55336	1
SWPA	BULL SHOALS 161KV'	194.8001	0.00814	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55993	1
SWPA	CARTHAGE 69KV'	32	0.0149	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55317	1
SWPA	CLARENCE CANNON DAM 69KV'	58	0.00786	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56021	1
SWPA	DARDANELLE 161KV'	55.80006	0.00561	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56246	1
SWPA	DENISON 138KV'	3.400024	0.05643	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.51164	1
SWPA	EUFAULA 138KV'	2.800026	0.03405	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.53402	1
SWPA	EUFAULA 161KV'	1.400013	0.03401	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.53406	1
SWPA	FORT GIBSON 161KV'	14.00001	0.02213	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.54594	1
SWPA	GREERS FERRY 161KV'	5.20005	0.00247	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.5656	1
SWPA	INDEPENDENCE 161KV'	13	0.00235	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56572	1
SWPA	JONESBORO 161KV'	76	0.00198	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56609	1
SWPA	KENNETT 69KV'	29	0.0024	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56567	1
SWPA	KEYSTONE DAM 161KV'	35.00001	0.02277	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.5453	1
SWPA	MALDEN 69KV'	15.4	0.00257	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.5655	1
SWPA	NORFORK 161KV'	65.00001	0.00632	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56175	1
SWPA	OZARK 161KV'	51.00003	0.01219	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55588	1
SWPA	PARAGOULD 69KV'	17.5	0.00215	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56592	1
SWPA	PIGGOTT 69KV'	7.5	0.00246	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56561	1
SWPA	POPLAR BLUFF 69KV'	13	0.00348	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.56459	1
SWPA	ROBERT S. KERR 161KV'	31.20005	0.02035	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.54772	1
SWPA	STOCKTON 161KV'	2.500019	0.01261	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55546	1
SWPA	TABLE ROCK 161KV'	60.00008	0.01203	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55604	1
SWPA	TENKILLER FERRY 161KV'	26.00001	0.02652	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.54155	1
SWPA	TRUMAN 161KV'	37.00006	0.0108	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.55727	1
SWPA	WEBBERS FALLS 161KV'	38.20001	0.02652	SWPA	BROKEN BOW 138KV'	104.7999	0.56807	-0.54155	1
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	COGENTRIX 345KV'	665	0.02078	-0.15389	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	COMANCHE 138KV'	160	0.02463	-0.15774	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	COMANCHE 69KV'	63	0.02591	-0.15902	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	FITZHUGH 161KV'	61	0.0122	-0.14531	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	FLINT CREEK 161KV'	400	0.01749	-0.1506	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	L&D13 69KV'	11	0.01526	-0.14837	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	NORTHEASTERN STATION 138KV'	95	0.02027	-0.15338	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	NORTHEASTERN STATION 138KV'	240	0.02027	-0.15338	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	NORTHEASTERN STATION 345KV'	550	0.01967	-0.15278	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	OEC 345KV'	256	0.02031	-0.15342	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	RIVERSIDE STATION 138KV'	245	0.02397	-0.15708	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	SOUTHWESTERN STATION 138KV'	86	0.02732	-0.16043	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	WEATHERFORD 34KV'	148	0.02453	-0.15764	2
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	EASTMAN 138KV'	155	-0.02785	-0.10526	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	KNOXLEE 138KV'	15.88934	-0.02761	-0.1055	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	LEBROCK 345KV'	365	-0.02744	-0.10567	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	LIEBERMAN 138KV'	4	-0.0261	-0.10701	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	PIRKEY GENERATION 138KV'	440	-0.02761	-0.1055	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	WELSH 345KV'	990	-0.02972	-0.10339	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	WILKES 138KV'	7	-0.03193	-0.10118	3
AEPW	NARROWS 69KV'	30	-0.13311	AEPW	WILKES 345KV'	74.26818	-0.0286	-0.10451	3
WFEC	ANADARKO 138KV'	269.9937	0.02793	WFEC	HUGO 138KV'	370.8604	0.11232	-0.08439	4
WFEC	ANADARKO 138KV'	90	0.02793	WFEC	HUGO 138KV'	370.8604	0.11232	-0.08439	4
WFEC	ANADARKO 69KV'	76	0.02779	WFEC	HUGO 138KV'	370.8604	0.11232	-0.08453	4
WFEC	BLUCAN14 138 138KV'	151.2	0.02735	WFEC	HUGO 138KV'	370.8604	0.11232	-0.08497	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	COGENTRIX 345KV'	665	0.02078	-0.08272	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	COMANCHE 138KV'	160	0.02463	-0.08657	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	COMANCHE 69KV'	63	0.02591	-0.08785	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	FITZHUGH 161KV'	61	0.0122	-0.07414	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	FLINT CREEK 161KV'	400	0.01749	-0.07943	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	L&D13 69KV'	11	0.01526	-0.0772	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	NORTHEASTERN STATION 138KV'	240	0.02027	-0.08221	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	NORTHEASTERN STATION 138KV'	95	0.02027	-0.08221	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	NORTHEASTERN STATION 345KV'	550	0.01967	-0.08161	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	OEC 345KV'	256	0.02031	-0.08225	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	RIVERSIDE STATION 138KV'	245	0.02397	-0.08591	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	SOUTHWESTERN STATION 138KV'	86	0.02732	-0.08926	4
AEPW	FULTON 115KV'	153	-0.06194	AEPW	WEATHERFORD 34KV'	148	0.02453	-0.08647	4
WFEC	MORLND 138KV'	320	0.02308	WFEC	HUGO 138KV'	370.8604	0.11232	-0.08924	4
AEPW	ARSENAL HILL 69KV'	99	-0.02533	AEPW	COMANCHE 69KV'	63	0.02591	-0.05124	6
AEPW	ARSENAL HILL 69KV'	99	-0.02533	AEPW	SOUTHWESTERN STATION 138KV'	86	0.02732	-0.05265	6
AEPW	EASTMAN 138KV'	330.01	-0.02785	AEPW	COMANCHE 138KV'	160	0.02463	-0.05248	6
AEPW	EASTMAN 138KV'	330.01	-0.02785	AEPW	COMANCHE 69KV'	63	0.02591	-0.05376	6
AEPW	EASTMAN 138KV'	330.01	-0.02785	AEPW	RIVERSIDE STATION 138KV'	245	0.02397	-0.05182	6
AEPW	EASTMAN 138KV'	330.01	-0.02785	AEPW	SOUTHWESTERN STATION 138KV'	86	0.02732	-0.05517	6
AEPW	EASTMAN 138KV'	330.01	-0.02785	AEPW	WEATHERFORD 34KV'	148	0.02453	-0.05238	6
SWPA	GREERS FERRY 161KV'	5.20005	0.00247	SWPA	DENISON 138KV'	66.59998	0.05643	-0.05396	6
SWPA	INDEPENDENCE 161KV'	13	0.00235	SWPA	DENISON 138KV'	66.59998	0.05643	-0.05408	6
SWPA	JONESBORO 161KV'	76	0.00198	SWPA	DENISON 138KV'	66.59998	0.05643	-0.05445	6
SWPA	KENNETT 69KV'	29	0.0024	SWPA	DENISON 138KV'	66.59998	0.05643	-0.05403	6
AEPW	KNOXLEE 138KV'	347.1107	-0.02761	AEPW	COMANCHE 138KV'	160	0.02463	-0.05224	6
AEPW	KNOXLEE 138KV'	60	-0.02761	AEPW	COMANCHE 138KV'	160	0.02463	-0.05224	6
AEPW	KNOXLEE 138KV'	347.1107	-0.02761	AEPW	COMANCHE 69KV'	63	0.02591	-0.05352	6
AEPW	KNOXLEE 138KV'	60	-0.02761	AEPW	COMANCHE 69KV'	63	0.02591	-0.05352	6
AEPW	KNOXLEE 138KV'	347.1107	-0.02761	AEPW	RIVERSIDE STATION 138KV'	245	0.02397	-0.05158	6
AEPW	KNOXLEE 138KV'	60	-0.02761	AEPW	RIVERSIDE STATION 138KV'	245	0.02397	-0.05158	6
AEPW	KNOXLEE 138KV'	347.1107	-0.02761	AEPW	SOUTHWESTERN STATION 138KV'	86	0.02732	-0.05493	6
AEPW	KNOXLEE 138KV'	60	-0.02761	AEPW	SOUTHWESTERN STATION 138KV'	86	0.02732	-0.05493	6
AEPW	KNOXLEE 138KV'	347.1107	-0.02761	AEPW	WEATHERFORD 34KV'	148	0.02453	-0.05214	6

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	KNOXLEE 138KV'	60	-0.02761	AEPW	WEATHERFORD 34KV'	148	0.02453	-0.05214	6
AEPW	LEBROCK 345KV'	332	-0.02744	AEPW	COMANCHE 138KV'	160	0.02463	-0.05207	6
AEPW	LEBROCK 345KV'	332	-0.02744	AEPW	COMANCHE 69KV'	63	0.02591	-0.05335	6
AEPW	LEBROCK 345KV'	332	-0.02744	AEPW	RIVERSIDE STATION 138KV'	245	0.02397	-0.05141	6
AEPW	LEBROCK 345KV'	332	-0.02744	AEPW	SOUTHWESTERN STATION 138KV'	86	0.02732	-0.05476	6
AEPW	LEBROCK 345KV'	332	-0.02744	AEPW	WEATHERFORD 34KV'	148	0.02453	-0.05197	6
AEPW	LIEBERMAN 138KV'	224	-0.0261	AEPW	COMANCHE 69KV'	63	0.02591	-0.05201	6
AEPW	LIEBERMAN 138KV'	224	-0.0261	AEPW	SOUTHWESTERN STATION 138KV'	86	0.02732	-0.05342	6
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	COGENTRIX 345KV'	665	0.02078	-0.05345	6
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	COMANCHE 138KV'	160	0.02463	-0.0573	6
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	COMANCHE 69KV'	63	0.02591	-0.05858	6
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	NORTHEASTERN STATION 138KV'	240	0.02027	-0.05294	6
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	NORTHEASTERN STATION 138KV'	95	0.02027	-0.05294	6
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	NORTHEASTERN STATION 345KV'	550	0.01967	-0.05234	6
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	OEC 345KV'	256	0.02031	-0.05298	6

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: BDDAMTP4 - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151558235600412107SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1079577	0.2	0.9
1086238	0.2	0.9
1089952	0.4	0.9
1090609	0.1	0.9

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV'	29.64485	0.01448	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.55337	2
SWPA	BULL SHOALS 161KV'	66.21312	0.00795	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.5599	2
SWPA	CARTHAGE 69KV'	32	0.01468	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.55317	2
SWPA	CLARENCE CANNON DAM 69KV'	11.06856	0.00781	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.56004	2
SWPA	DARDANELLE 161KV'	55.72948	0.0054	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.56245	2
SWPA	DENISON 138KV'	13.36206	0.0562	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.51165	2
SWPA	EUFULA 138KV'	11.56756	0.03372	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.53413	2
SWPA	EUFULA 161KV'	5.78379	0.03369	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.53416	2
SWPA	FORT GIBSON 161KV'	9.572918	0.02189	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.54596	2
SWPA	GREERS FERRY 161KV'	21.14047	0.00227	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.56558	2
SWPA	INDEPENDENCE 161KV'	13	0.00217	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.56568	2
SWPA	KENNETT 69KV'	27.5	0.00229	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.56556	2
SWPA	KEYSTONE DAM 161KV'	13.36206	0.02229	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.54556	2
SWPA	MALDEN 69KV'	12.5	0.00248	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.56537	2
SWPA	NORFORK 161KV'	64.9866	0.00614	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.56171	2
SWPA	OZARK 161KV'	40.55012	0.01205	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.5558	2
SWPA	PARAGOULD 69KV'	17.5	0.00203	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.56582	2
SWPA	PIGGOTT 69KV'	7.5	0.00236	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.56549	2
SWPA	POPLAR BLUFF 69KV'	13	0.00342	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.56443	2
SWPA	ROBERT S. KERR 161KV'	24.33163	0.02012	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.54773	2
SWPA	STOCKTON 161KV'	9.971848	0.01241	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.55544	2
SWPA	TABLE ROCK 161KV'	42.28094	0.01181	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.55604	2
SWPA	TENKILLER FERRY 161KV'	25.98928	0.02623	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.54162	2
SWPA	TRUMAN 161KV'	83.13512	0.0106	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.55725	2
SWPA	WEBBERS FALLS 161KV'	31.77506	0.02623	SWPA	BROKEN BOW 138KV'	88.85953	0.56785	-0.54162	2
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	COGENTRIX 345KV'	665	0.02123	-0.15451	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	COMANCHE 138KV'	160	0.02446	-0.15774	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	COMANCHE 69KV'	63	0.02574	-0.15902	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	FITZHUGH 161KV'	100	0.01207	-0.14535	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	FLINT CREEK 161KV'	400	0.01727	-0.15055	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	L&D13 69KV'	11	0.01508	-0.14836	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	NORTHEASTERN STATION 138KV'	95	0.01993	-0.15321	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	NORTHEASTERN STATION 138KV'	405	0.01993	-0.15321	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	NORTHEASTERN STATION 345KV'	608	0.0195	-0.15278	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	OEC 345KV'	206	0.02026	-0.15354	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	RIVERSIDE STATION 138KV'	482	0.02273	-0.15601	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.16041	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	TULSA POWER STATION 138KV'	39	0.02212	-0.1554	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	TULSA POWER STATION 138KV'	38	0.02212	-0.1554	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	WEATHERFORD 34KV'	148	0.02435	-0.15763	6
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	EASTMAN 138KV'	155	-0.02807	-0.10521	9
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	KNOXLEE 138KV'	103	-0.02784	-0.10544	9
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	LEBROCK 345KV'	365	-0.02761	-0.10567	9
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	LIEBERMAN 138KV'	4	-0.02624	-0.10704	9
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	PIRKEY GENERATION 138KV'	440	-0.02779	-0.10549	9
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	WELSH 345KV'	960	-0.02987	-0.10341	9
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	WILKES 138KV'	145.7758	-0.03201	-0.10127	9
AEPW	NARROWS 69KV'	3	-0.13328	AEPW	WILKES 345KV'	157.124	-0.02873	-0.10455	9
AEPW	FULTON 115KV'	153	-0.0621	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.08923	10
WFEC	MORLND 138KV'	159.9824	0.02292	WFEC	HUGO 138KV'	450	0.11212	-0.0892	10
WFEC	ANADARKO 138KV'	9.679344	0.02774	WFEC	HUGO 138KV'	450	0.11212	-0.08438	11
WFEC	ANADARKO 138KV'	90	0.02774	WFEC	HUGO 138KV'	450	0.11212	-0.08438	11
WFEC	ANADARKO 69KV'	76	0.0276	WFEC	HUGO 138KV'	450	0.11212	-0.08452	11
WFEC	BLUCAN14 138 138KV'	151.2	0.02717	WFEC	HUGO 138KV'	450	0.11212	-0.08495	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COGENTRIX 345KV'	665	0.02123	-0.08333	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COMANCHE 138KV'	160	0.02446	-0.08656	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COMANCHE 69KV'	63	0.02574	-0.08784	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	NORTHEASTERN STATION 138KV'	405	0.01993	-0.08203	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	NORTHEASTERN STATION 138KV'	95	0.01993	-0.08203	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	NORTHEASTERN STATION 345KV'	608	0.0195	-0.0816	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	OEC 345KV'	206	0.02026	-0.08236	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	RIVERSIDE STATION 138KV'	482	0.02273	-0.08483	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	TULSA POWER STATION 138KV'	39	0.02212	-0.08422	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	TULSA POWER STATION 138KV'	38	0.02212	-0.08422	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	WEATHERFORD 34KV'	148	0.02435	-0.08645	11
AEPW	FULTON 115KV'	153	-0.0621	AEPW	FLINT CREEK 161KV'	400	0.01727	-0.07937	12
AEPW	FULTON 115KV'	153	-0.0621	AEPW	L&D13 69KV'	11	0.01508	-0.07718	12
AEPW	FULTON 115KV'	153	-0.0621	AEPW	FITZHUGH 161KV'	103	0.01207	-0.07417	13
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	COMANCHE 138KV'	160	0.02446	-0.05714	16
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	COMANCHE 69KV'	63	0.02574	-0.05842	16
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.05981	16

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	WEATHERFORD 34KV'	148	0.02435	-0.05703	16
AEPW	WELSH 345KV'	84	-0.02987	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.057	16
AEPW	WILKES 138KV'	317.2242	-0.03201	AEPW	COMANCHE 138KV'	160	0.02446	-0.05647	16
AEPW	WILKES 138KV'	317.2242	-0.03201	AEPW	COMANCHE 69KV'	63	0.02574	-0.05775	16
AEPW	WILKES 138KV'	317.2242	-0.03201	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.05914	16
AEPW	EASTMAN 138KV'	330.01	-0.02807	AEPW	COMANCHE 69KV'	63	0.02574	-0.05381	17
AEPW	EASTMAN 138KV'	330.01	-0.02807	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.0552	17
SWPA	GREERS FERRY 161KV'	21.14047	0.00227	SWPA	DENISON 138KV'	56.63794	0.0562	-0.05393	17
SWPA	INDEPENDENCE 161KV'	13	0.00217	SWPA	DENISON 138KV'	56.63794	0.0562	-0.05403	17
SWPA	KENNETT 69KV'	27.5	0.00229	SWPA	DENISON 138KV'	56.63794	0.0562	-0.05391	17
AEPW	KNOXLEE 138KV'	260	-0.02784	AEPW	COMANCHE 69KV'	63	0.02574	-0.05358	17
AEPW	KNOXLEE 138KV'	60	-0.02784	AEPW	COMANCHE 69KV'	63	0.02574	-0.05358	17
AEPW	KNOXLEE 138KV'	260	-0.02784	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.05497	17
AEPW	KNOXLEE 138KV'	60	-0.02784	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.05497	17
AEPW	LEBROCK 345KV'	332	-0.02761	AEPW	COMANCHE 69KV'	63	0.02574	-0.05335	17
AEPW	LEBROCK 345KV'	332	-0.02761	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.05474	17
AEPW	LIEBERMAN 138KV'	224	-0.02624	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.05337	17
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	COGENTRIX 345KV'	665	0.02123	-0.05391	17
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	RIVERSIDE STATION 138KV'	482	0.02273	-0.05541	17
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	TULSA POWER STATION 138KV'	39	0.02212	-0.0548	17
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	TULSA POWER STATION 138KV'	38	0.02212	-0.0548	17
SWPA	MALDEN 69KV'	12.5	0.00248	SWPA	DENISON 138KV'	56.63794	0.0562	-0.05372	17
SWPA	PARAGOULD 69KV'	17.5	0.00203	SWPA	DENISON 138KV'	56.63794	0.0562	-0.05417	17
SWPA	PIGGOTT 69KV'	7.5	0.00236	SWPA	DENISON 138KV'	56.63794	0.0562	-0.05384	17
AEPW	PIRKEY GENERATION 138KV'	75	-0.02779	AEPW	COMANCHE 69KV'	63	0.02574	-0.05353	17
AEPW	PIRKEY GENERATION 138KV'	75	-0.02779	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.05492	17
AEPW	TENASKA GATEWAY 345KV'	937.03	-0.02632	AEPW	SOUTHWESTERN STATION 138KV'	184	0.02713	-0.05345	17
AEPW	WELSH 345KV'	84	-0.02987	AEPW	COMANCHE 138KV'	160	0.02446	-0.05433	17
AEPW	WELSH 345KV'	84	-0.02987	AEPW	COMANCHE 69KV'	63	0.02574	-0.05561	17

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: BBDAMTP4 - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151558235600412107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1079577	0.8	2.8
1086238	0.4	2.8
1089952	1.4	2.8
1090609	0.3	2.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV'	23.0457	0.01448	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.55337	5
SWPA	BULL SHOALS 161KV'	51.81354	0.00795	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.5599	5
SWPA	CARTHAGE 69KV'	1.99998	0.01468	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.55317	5
SWPA	CLARENCE CANNON DAM 69KV'	8.768707	0.00781	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.56004	5
SWPA	DARDANELLE 161KV'	55.73309	0.0054	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.56245	5
SWPA	EUFAULA 138KV'	8.967567	0.03373	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.53412	5
SWPA	EUFAULA 161KV'	4.483784	0.03369	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.53416	5
SWPA	FORT GIBSON 161KV'	7.573032	0.02189	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.54596	5
SWPA	GREERS FERRY 161KV'	16.5406	0.00227	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.56558	5
SWPA	INDEPENDENCE 161KV'	13	0.00217	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.56568	5
SWPA	KENNETT 69KV'	21.8	0.00229	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.56556	5
SWPA	KEYSTONE DAM 161KV'	10.56222	0.02229	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.54556	5
SWPA	MALDEN 69KV'	10	0.00248	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.56537	5
SWPA	NORFORK 161KV'	64.98728	0.00614	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.56171	5
SWPA	OZARK 161KV'	36.9504	0.01205	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.5558	5
SWPA	PARAGOULD 69KV'	12	0.00203	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.56582	5
SWPA	PIGGOTT 69KV'	7.5	0.00236	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.56549	5
SWPA	POPLAR BLUFF 69KV'	7	0.00342	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.56443	5
SWPA	ROBERT S. KERR 161KV'	19.13182	0.02012	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.54773	5
SWPA	STOCKTON 161KV'	7.871956	0.01241	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.55544	5
SWPA	TABLE ROCK 161KV'	33.08119	0.01181	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.55604	5
SWPA	TENKILLER FERRY 161KV'	25.99882	0.02623	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.54162	5
SWPA	TRUMAN 161KV'	77.93513	0.0106	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.55725	5
SWPA	WEBBERS FALLS 161KV'	29.9752	0.02623	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.54162	5
SWPA	DENISON 138KV'	10.56222	0.0562	SWPA	BROKEN BOW 138KV'	93.4594	0.56785	-0.51165	6
AEPW	FULTON 115KV'	153	-0.0621	AEPW	WELEETKA 138KV'	70	0.05322	-0.11532	24
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COMANCHE 69KV'	63	0.02574	-0.08784	32
AEPW	FULTON 115KV'	153	-0.0621	AEPW	SOUTHWESTERN STATION 138KV'	335	0.02713	-0.08923	32
WFEC	MORLND 138KV'	25.26624	0.02292	WFEC	HUGO 138KV'	450	0.11212	-0.0892	32
WFEC	ANADARKO 138KV'	90	0.02774	WFEC	HUGO 138KV'	450	0.11212	-0.08438	33
WFEC	ANADARKO 69KV'	76	0.0276	WFEC	HUGO 138KV'	450	0.11212	-0.08452	33
WFEC	BLUCAN14 138 138KV'	151.2	0.02717	WFEC	HUGO 138KV'	450	0.11212	-0.08495	33
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COMANCHE 138KV'	160	0.02446	-0.08656	33
AEPW	FULTON 115KV'	153	-0.0621	AEPW	RIVERSIDE STATION 138KV'	646	0.02273	-0.08483	33
AEPW	FULTON 115KV'	153	-0.0621	AEPW	TULSA POWER STATION 138KV'	112	0.02212	-0.08422	33
AEPW	FULTON 115KV'	153	-0.0621	AEPW	TULSA POWER STATION 138KV'	147	0.02212	-0.08422	33
AEPW	FULTON 115KV'	153	-0.0621	AEPW	WEATHERFORD 34KV'	148	0.02435	-0.08645	33
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	WELEETKA 138KV'	70	0.05322	-0.0859	33
AEPW	WILKES 138KV'	97.62759	-0.03201	AEPW	WELEETKA 138KV'	70	0.05322	-0.08523	33
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COGENTRIX 345KV'	665	0.02123	-0.08333	34
AEPW	FULTON 115KV'	153	-0.0621	AEPW	NORTHEASTERN STATION 138KV'	405	0.01993	-0.08203	34
AEPW	FULTON 115KV'	153	-0.0621	AEPW	NORTHEASTERN STATION 138KV'	95	0.01993	-0.08203	34
AEPW	FULTON 115KV'	153	-0.0621	AEPW	NORTHEASTERN STATION 345KV'	645	0.0195	-0.0816	34
AEPW	FULTON 115KV'	153	-0.0621	AEPW	OEC 345KV'	206	0.02026	-0.08236	34
AEPW	WELSH 345KV'	54	-0.02987	AEPW	WELEETKA 138KV'	70	0.05322	-0.08309	34
AEPW	EASTMAN 138KV'	330.01	-0.02808	AEPW	WELEETKA 138KV'	70	0.05322	-0.0813	35
AEPW	FULTON 115KV'	153	-0.0621	AEPW	FLINT CREEK 161KV'	420	0.01727	-0.07937	35
AEPW	KNOXLEE 138KV'	115.4741	-0.02784	AEPW	WELEETKA 138KV'	70	0.05322	-0.08106	35
AEPW	KNOXLEE 138KV'	60	-0.02784	AEPW	WELEETKA 138KV'	70	0.05322	-0.08106	35
AEPW	LEBROCK 345KV'	332	-0.02762	AEPW	WELEETKA 138KV'	70	0.05322	-0.08084	35
AEPW	LIEBERMAN 138KV'	137	-0.02624	AEPW	WELEETKA 138KV'	70	0.05322	-0.07946	35
AEPW	PIRKEY GENERATION 138KV'	40	-0.02779	AEPW	WELEETKA 138KV'	70	0.05322	-0.08101	35
AEPW	TENASKA GATEWAY 345KV'	937.03	-0.02632	AEPW	WELEETKA 138KV'	70	0.05322	-0.07954	35
AEPW	ARSENAL HILL 69KV'	75	-0.02548	AEPW	WELEETKA 138KV'	70	0.05322	-0.0787	36
AEPW	FULTON 115KV'	153	-0.0621	AEPW	FITZHUGH 161KV'	126	0.01207	-0.07417	38
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	SOUTHWESTERN STATION 138KV'	335	0.02713	-0.05981	47
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03268	AEPW	COMANCHE 69KV'	63	0.02574	-0.05842	48

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	WILKES 138KV	97.62759	-0.03201	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05914	48
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	COMANCHE 138KV	160	0.02446	-0.05714	49
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	WEATHERFORD 34KV	148	0.02435	-0.05703	49
AEPW	WELSH 345KV	54	-0.02987	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.057	49
AEPW	WILKES 138KV	97.62759	-0.03201	AEPW	COMANCHE 69KV	63	0.02574	-0.05775	49
AEPW	WILKES 138KV	97.62759	-0.03201	AEPW	COMANCHE 138KV	160	0.02446	-0.05647	50
AEPW	WILKES 138KV	97.62759	-0.03201	AEPW	WEATHERFORD 34KV	148	0.02435	-0.05636	50
AEPW	EASTMAN 138KV	330.01	-0.02808	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05521	51
AEPW	KNOXLEE 138KV	115.4741	-0.02784	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05497	51
AEPW	KNOXLEE 138KV	60	-0.02784	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05497	51
AEPW	LEBROCK 345KV	332	-0.02762	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05475	51
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	RIVERSIDE STATION 138KV	646	0.02273	-0.05541	51
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	TULSA POWER STATION 138KV	112	0.02212	-0.0548	51
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	TULSA POWER STATION 138KV	147	0.02212	-0.0548	51
AEPW	PIRKEY GENERATION 138KV	40	-0.02779	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05492	51
AEPW	WELSH 345KV	54	-0.02987	AEPW	COMANCHE 69KV	63	0.02574	-0.05561	51
AEPW	WILKES 138KV	97.62759	-0.03201	AEPW	RIVERSIDE STATION 138KV	646	0.02273	-0.05474	51
AEPW	EASTMAN 138KV	330.01	-0.02808	AEPW	COMANCHE 69KV	63	0.02574	-0.05382	52
SWPA	KENNETT 69KV	21.8	0.00229	SWPA	DENISON 138KV	59.43778	0.0562	-0.05391	52
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	COGENTRIX 345KV	665	0.02123	-0.05391	52
AEPW	WELSH 345KV	54	-0.02987	AEPW	COMANCHE 138KV	160	0.02446	-0.05433	52
AEPW	WELSH 345KV	54	-0.02987	AEPW	WEATHERFORD 34KV	148	0.02435	-0.05422	52
AEPW	WILKES 138KV	97.62759	-0.03201	AEPW	TULSA POWER STATION 138KV	112	0.02212	-0.05413	52
AEPW	WILKES 138KV	97.62759	-0.03201	AEPW	TULSA POWER STATION 138KV	147	0.02212	-0.05413	52
AEPW	ARSENAL HILL 69KV	75	-0.02548	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05261	53
AEPW	KNOXLEE 138KV	115.4741	-0.02784	AEPW	COMANCHE 69KV	63	0.02574	-0.05358	53
AEPW	KNOXLEE 138KV	60	-0.02784	AEPW	COMANCHE 69KV	63	0.02574	-0.05358	53
AEPW	LEBROCK 345KV	332	-0.02762	AEPW	COMANCHE 69KV	63	0.02574	-0.05336	53
AEPW	LIEBERMAN 138KV	137	-0.02624	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05337	53
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	NORTHEASTERN STATION 138KV	405	0.01993	-0.05261	53
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	NORTHEASTERN STATION 138KV	95	0.01993	-0.05261	53
AEPW	LONESTAR POWER PLANT 69KV	50	-0.03268	AEPW	OEC 345KV	206	0.02026	-0.05294	53
AEPW	PIRKEY GENERATION 138KV	40	-0.02779	AEPW	COMANCHE 69KV	63	0.02574	-0.05353	53
AEPW	TENASKA GATEWAY 345KV	937.03	-0.02632	AEPW	SOUTHWESTERN STATION 138KV	335	0.02713	-0.05345	53
AEPW	WILKES 138KV	97.62759	-0.03201	AEPW	COGENTRIX 345KV	665	0.02123	-0.05324	53
AEPW	EASTMAN 138KV	330.01	-0.02808	AEPW	COMANCHE 138KV	160	0.02446	-0.05254	54
AEPW	EASTMAN 138KV	330.01	-0.02808	AEPW	WEATHERFORD 34KV	148	0.02435	-0.05243	54
AEPW	KNOXLEE 138KV	115.4741	-0.02784	AEPW	COMANCHE 138KV	160	0.02446	-0.0523	54
AEPW	KNOXLEE 138KV	60	-0.02784	AEPW	COMANCHE 138KV	160	0.02446	-0.0523	54
AEPW	KNOXLEE 138KV	115.4741	-0.02784	AEPW	WEATHERFORD 34KV	148	0.02435	-0.05219	54
AEPW	KNOXLEE 138KV	60	-0.02784	AEPW	WEATHERFORD 34KV	148	0.02435	-0.05219	54
AEPW	LEBROCK 345KV	332	-0.02762	AEPW	COMANCHE 138KV	160	0.02446	-0.05208	54
AEPW	LEBROCK 345KV	332	-0.02762	AEPW	WEATHERFORD 34KV	148	0.02435	-0.05197	54

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: BDDAMP4 - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151558235600413106WP  
 Date Redispatch Needed: 12/1/06 - 4/1/07  
 Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1079577	0.8	1.0
1090609	0.2	1.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV	40.55142	0.01453	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.55338	2
SWPA	BULL SHOALS 161KV	98.00077	0.00796	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.55995	2
SWPA	CARTHAGE 69KV	21	0.01474	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.55317	2
SWPA	CLARENCE CANNON DAM 69KV	58	0.00786	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56005	2
SWPA	DARDANELLE 161KV	45.80034	0.00537	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56254	2
SWPA	DENISON 138KV	19.80014	0.05626	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.51165	2
SWPA	EUFULA 138KV	17.00013	0.03387	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.53404	2
SWPA	EUFULA 161KV	8.500065	0.03384	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.53407	2
SWPA	FORT GIBSON 161KV	14.00011	0.02196	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.54595	2
SWPA	GREERS FERRY 161KV	31.20022	0.00228	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56563	2
SWPA	INDEPENDENCE 161KV	13	0.00217	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56574	2
SWPA	JONESBORO 161KV	3.399998	0.00183	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56608	2
SWPA	KENNETT 69KV	29	0.00228	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56563	2
SWPA	KEYSTONE DAM 161KV	19.80014	0.0226	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.54531	2
SWPA	MALDEN 69KV	15	0.00246	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56545	2
SWPA	NORFORK 161KV	24.20018	0.00615	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56176	2
SWPA	OZARK 161KV	49.00019	0.01204	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.55587	2
SWPA	PARAGOULD 69KV	17.5	0.00202	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56589	2
SWPA	PIGGOTT 69KV	7.5	0.00234	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56557	2
SWPA	POPLAR BLUFF 69KV	13	0.00336	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.56455	2
SWPA	ROBERT S. KERR 161KV	36.00027	0.02016	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.54775	2
SWPA	STOCKTON 161KV	14.80011	0.01246	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.55545	2
SWPA	TABLE ROCK 161KV	62.40044	0.01185	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.55606	2
SWPA	TENKILLER FERRY 161KV	12.00009	0.02634	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.54157	2
SWPA	TRUMAN 161KV	94.00026	0.01068	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.55723	2
SWPA	WEBBERS FALLS 161KV	36.00011	0.02634	SWPA	BROKEN BOW 138KV	78.79978	0.56791	-0.54157	2
AEPW	NARROWS 69KV	30	-0.13328	AEPW	COMANCHE 138KV	160	0.02447	-0.15775	6
AEPW	NARROWS 69KV	30	-0.13328	AEPW	COMANCHE 69KV	63	0.02576	-0.15904	6
AEPW	NARROWS 69KV	30	-0.13328	AEPW	RIVERSIDE STATION 138KV	234	0.02379	-0.15707	6
AEPW	NARROWS 69KV	30	-0.13328	AEPW	SOUTHWESTERN STATION 138KV	29	0.02716	-0.16044	6
AEPW	NARROWS 69KV	30	-0.13328	AEPW	WEATHERFORD 34KV	148	0.02438	-0.15766	6
AEPW	NARROWS 69KV	30	-0.13328	AEPW	COGENTRIX 345KV	665	0.02061	-0.15389	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	FITZHUGH 161KV	81	0.01206	-0.14534	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	FLINT CREEK 161KV	400	0.01732	-0.15056	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	L&D13 69KV	11	0.01508	-0.14836	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	NORTHEASTERN STATION 138KV	207	0.02011	-0.15339	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	NORTHEASTERN STATION 138KV	95	0.02011	-0.15339	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	NORTHEASTERN STATION 345KV	600	0.01951	-0.15279	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	OEC 345KV	256	0.02013	-0.15341	7
AEPW	NARROWS 69KV	30	-0.13328	AEPW	EASTMAN 138KV	155	-0.02801	-0.10527	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	KNOXLEE 138KV	103	-0.02777	-0.10551	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	LEBROCK 345KV	365	-0.0276	-0.10568	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	LIEBERMAN 138KV	4	-0.02626	-0.10702	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	PIRKEY GENERATION 138KV	450	-0.02777	-0.10551	10
AEPW	NARROWS 69KV	30	-0.13328	AEPW	WELSH 345KV	960	-0.02988	-0.1034	10



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	NARROWS 69KV'	30	-0.13328	AEPW	WILKES 138KV'	141.6191	-0.03209	-0.10119	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	WILKES 345KV'	147.4476	-0.02876	-0.10452	10
AEPW	FULTON 115KV'	153	-0.06212	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.08928	11
WFEC	MORLND 138KV'	320	0.02296	WFEC	HUGO 138KV'	450	0.11216	-0.0892	11
WFEC	ANADARKO 138KV'	67.87025	0.02777	WFEC	HUGO 138KV'	450	0.11216	-0.08439	12
WFEC	ANADARKO 138KV'	90	0.02777	WFEC	HUGO 138KV'	450	0.11216	-0.08439	12
WFEC	ANADARKO 69KV'	76	0.02764	WFEC	HUGO 138KV'	450	0.11216	-0.08452	12
WFEC	BLUCAN14 138 138KV'	151.2	0.0272	WFEC	HUGO 138KV'	450	0.11216	-0.08496	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	COGENTRIX 345KV'	665	0.02061	-0.08273	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	COMANCHE 138KV'	160	0.02447	-0.08659	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	COMANCHE 69KV'	63	0.02576	-0.08788	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	NORTHEASTERN STATION 138KV'	95	0.02011	-0.08223	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	NORTHEASTERN STATION 138KV'	207	0.02011	-0.08223	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	OEC 345KV'	256	0.02013	-0.08225	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	RIVERSIDE STATION 138KV'	234	0.02379	-0.08591	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	WEATHERFORD 34KV'	148	0.02438	-0.0865	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	FLINT CREEK 161KV'	400	0.01732	-0.07944	13
AEPW	FULTON 115KV'	153	-0.06212	AEPW	L&D13 69KV'	11	0.01508	-0.0772	13
AEPW	FULTON 115KV'	153	-0.06212	AEPW	NORTHEASTERN STATION 345KV'	600	0.01951	-0.08163	13
AEPW	FULTON 115KV'	153	-0.06212	AEPW	FITZHUGH 161KV'	81	0.01206	-0.07418	14
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	COMANCHE 69KV'	63	0.02576	-0.05859	17
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.05999	17
AEPW	WILKES 138KV'	321.3809	-0.03209	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.05925	17
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.05517	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	COMANCHE 138KV'	160	0.02447	-0.0573	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	RIVERSIDE STATION 138KV'	234	0.02379	-0.05662	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	WEATHERFORD 34KV'	148	0.02438	-0.05721	18
AEPW	WELSH 345KV'	84	-0.02988	AEPW	COMANCHE 69KV'	63	0.02576	-0.05564	18
AEPW	WELSH 345KV'	84	-0.02988	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.05704	18
AEPW	WILKES 138KV'	321.3809	-0.03209	AEPW	COMANCHE 138KV'	160	0.02447	-0.05656	18
AEPW	WILKES 138KV'	321.3809	-0.03209	AEPW	COMANCHE 69KV'	63	0.02576	-0.05785	18
AEPW	WILKES 138KV'	321.3809	-0.03209	AEPW	RIVERSIDE STATION 138KV'	234	0.02379	-0.05588	18
AEPW	WILKES 138KV'	321.3809	-0.03209	AEPW	WEATHERFORD 34KV'	148	0.02438	-0.05647	18
AEPW	WILKES 345KV'	163.5524	-0.02876	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.05592	18
AEPW	ARSENAL HILL 69KV'	99	-0.02549	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.05265	19
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	COMANCHE 138KV'	160	0.02447	-0.05248	19
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	COMANCHE 69KV'	63	0.02576	-0.05377	19
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	WEATHERFORD 34KV'	148	0.02438	-0.05239	19
SWPA	GREERS FERRY 161KV'	31.20022	0.00228	SWPA	DENISON 138KV'	50.19986	0.05626	-0.05398	19
SWPA	INDEPENDENCE 161KV'	13	0.00217	SWPA	DENISON 138KV'	50.19986	0.05626	-0.05409	19
SWPA	KENNETT 69KV'	29	0.00228	SWPA	DENISON 138KV'	50.19986	0.05626	-0.05398	19
AEPW	KNOXLEE 138KV'	260	-0.02777	AEPW	COMANCHE 69KV'	63	0.02576	-0.05353	19
AEPW	KNOXLEE 138KV'	60	-0.02777	AEPW	COMANCHE 69KV'	63	0.02576	-0.05353	19
AEPW	KNOXLEE 138KV'	260	-0.02777	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.05493	19
AEPW	KNOXLEE 138KV'	60	-0.02777	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.05493	19
AEPW	LEBROCK 345KV'	332	-0.0276	AEPW	COMANCHE 69KV'	63	0.02576	-0.05336	19
AEPW	LEBROCK 345KV'	332	-0.0276	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.05476	19
AEPW	LIEBERMAN 138KV'	224	-0.02626	AEPW	SOUTHWESTERN STATION 138KV'	29	0.02716	-0.05342	19
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	COGENTRIX 345KV'	665	0.02061	-0.05344	19
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	NORTHEASTERN STATION 138KV'	95	0.02011	-0.05294	19
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	NORTHEASTERN STATION 138KV'	207	0.02011	-0.05294	19
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	NORTHEASTERN STATION 345KV'	600	0.01951	-0.05234	19
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	OEC 345KV'	256	0.02013	-0.05296	19
SWPA	MALDEN 69KV'	15	0.00246	SWPA	DENISON 138KV'	50.19986	0.05626	-0.0538	19
SWPA	PARAGOULD 69KV'	17.5	0.00202	SWPA	DENISON 138KV'	50.19986	0.05626	-0.05424	19

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: BDDAMP4 - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151558235600413107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1079577	0.8	3.3
1086238	0.4	3.3
1089952	1.7	3.3
1090609	0.4	3.3

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV'	11.47467	0.01451	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.55336	6
SWPA	BULL SHOALS 161KV'	194.6908	0.00797	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.5599	6
SWPA	CARTHAGE 69KV'	32	0.0147	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.55317	6
SWPA	CLARENCE CANNON DAM 69KV'	3.360355	0.00782	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56005	6
SWPA	DARDANELLE 161KV'	55.72362	0.00541	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56246	6
SWPA	DENISON 138KV'	4.152222	0.05622	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.51165	6
SWPA	EUFULA 138KV'	3.559044	0.03374	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.53413	6
SWPA	FORT GIBSON 161KV'	13.97386	0.0219	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.54597	6
SWPA	GREERS FERRY 161KV'	6.324776	0.00228	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56559	6
SWPA	INDEPENDENCE 161KV'	13	0.00217	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.5657	6
SWPA	JONESBORO 161KV'	76	0.00185	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56602	6
SWPA	KENNETT 69KV'	29	0.00229	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56558	6
SWPA	KEYSTONE DAM 161KV'	34.97459	0.0223	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.54557	6
SWPA	MALDEN 69KV'	15.4	0.00248	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56539	6
SWPA	NORFORK 161KV'	64.98547	0.00616	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56171	6
SWPA	OZARK 161KV'	50.95354	0.01206	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.55581	6
SWPA	PARAGOULD 69KV'	17.5	0.00204	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56583	6
SWPA	PIGGOTT 69KV'	7.5	0.00236	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56551	6
SWPA	POPLAR BLUFF 69KV'	13	0.00343	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.56444	6
SWPA	ROBERT S. KERR 161KV'	31.13089	0.02014	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.54773	6
SWPA	STOCKTON 161KV'	3.064487	0.01244	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.55543	6
SWPA	TABLE ROCK 161KV'	59.88382	0.01183	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.55604	6
SWPA	TENKILLER FERRY 161KV'	25.98838	0.02625	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.54162	6
SWPA	TRUMAN 161KV'	67.11809	0.01063	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.55724	6
SWPA	WEBBERS FALLS 161KV'	38.17764	0.02625	SWPA	BROKEN BOW 138KV'	103.6752	0.56787	-0.54162	6
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.16042	20
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	COGENTRIX 345KV'	665	0.02125	-0.15452	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	COMANCHE 138KV'	160	0.02448	-0.15775	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	COMANCHE 69KV'	63	0.02576	-0.15903	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	NORTHEASTERN STATION 138KV'	207	0.01995	-0.15322	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	NORTHEASTERN STATION 138KV'	95	0.01995	-0.15322	21

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	NARROWS 69KV'	30	-0.13327	AEPW	OEC 345KV'	256	0.02027	-0.15354	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	RIVERSIDE STATION 138KV'	245	0.02274	-0.15601	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	WEATHERFORD 34KV'	148	0.02437	-0.15764	21
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	FLINT CREEK 161KV'	400	0.01729	-0.15056	22
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	L&D13 69KV'	11	0.01509	-0.14836	22
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	NORTHEASTERN STATION 345KV'	550	0.01951	-0.15278	22
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	FITZHUGH 161KV'	92	0.01208	-0.14535	23
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	EASTMAN 138KV'	155	-0.02807	-0.1052	31
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	KNOXLEE 138KV'	42	-0.02783	-0.10544	31
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	LEBROCK 345KV'	365	-0.02761	-0.10566	31
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	PIRKEY GENERATION 138KV'	440	-0.02778	-0.10549	31
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	WILKES 345KV'	76.02601	-0.02872	-0.10455	31
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	WELSH 345KV'	990	-0.02986	-0.10341	32
AEPW	NARROWS 69KV'	30	-0.13327	AEPW	WILKES 138KV'	36.91098	-0.032	-0.10127	32
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COMANCHE 69KV'	63	0.02576	-0.08786	37
AEPW	FULTON 115KV'	153	-0.0621	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.08925	37
WFEC	MORLND 138KV'	320	0.02294	WFEC	HUGO 138KV'	450	0.11213	-0.08919	37
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COMANCHE 138KV'	160	0.02448	-0.08658	38
AEPW	FULTON 115KV'	153	-0.0621	AEPW	WEATHERFORD 34KV'	148	0.02437	-0.08647	38
WFEC	ANADARKO 138KV'	40.57323	0.02776	WFEC	HUGO 138KV'	450	0.11213	-0.08437	39
WFEC	ANADARKO 138KV'	90	0.02776	WFEC	HUGO 138KV'	450	0.11213	-0.08437	39
WFEC	ANADARKO 69KV'	76	0.02762	WFEC	HUGO 138KV'	450	0.11213	-0.08451	39
WFEC	BLUCAN14 138 138KV'	151.2	0.02719	WFEC	HUGO 138KV'	450	0.11213	-0.08494	39
AEPW	FULTON 115KV'	153	-0.0621	AEPW	COGENTRIX 345KV'	665	0.02125	-0.08335	39
AEPW	FULTON 115KV'	153	-0.0621	AEPW	RIVERSIDE STATION 138KV'	245	0.02274	-0.08484	39
AEPW	FULTON 115KV'	153	-0.0621	AEPW	NORTHEASTERN STATION 138KV'	95	0.01995	-0.08205	40
AEPW	FULTON 115KV'	153	-0.0621	AEPW	NORTHEASTERN STATION 138KV'	207	0.01995	-0.08205	40
AEPW	FULTON 115KV'	153	-0.0621	AEPW	NORTHEASTERN STATION 345KV'	550	0.01951	-0.08161	40
AEPW	FULTON 115KV'	153	-0.0621	AEPW	OEC 345KV'	256	0.02027	-0.08237	40
AEPW	FULTON 115KV'	153	-0.0621	AEPW	FLINT CREEK 161KV'	400	0.01729	-0.07939	41
AEPW	FULTON 115KV'	153	-0.0621	AEPW	FITZHUGH 161KV'	92	0.01208	-0.07418	44
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05982	55
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	COMANCHE 69KV'	63	0.02576	-0.05843	56
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05915	56
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	COMANCHE 138KV'	160	0.02448	-0.05715	57
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	COMANCHE 69KV'	63	0.02576	-0.05776	57
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	WEATHERFORD 34KV'	148	0.02437	-0.05704	58
AEPW	WELSH 345KV'	54	-0.02986	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05701	58
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	COMANCHE 138KV'	160	0.02448	-0.05648	58
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	WEATHERFORD 34KV'	148	0.02437	-0.05637	58
AEPW	EASTMAN 138KV'	330.01	-0.02807	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05522	59
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	RIVERSIDE STATION 138KV'	245	0.02274	-0.05541	59
AEPW	WELSH 345KV'	54	-0.02986	AEPW	COMANCHE 69KV'	63	0.02576	-0.05562	59
AEPW	WILKES 345KV'	234.974	-0.02872	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05587	59
SWPA	JONESBORO 161KV'	76	0.00185	SWPA	DENISON 138KV'	65.84778	0.05622	-0.05437	60
AEPW	KNOXLEE 138KV'	321	-0.02783	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05498	60
AEPW	KNOXLEE 138KV'	60	-0.02783	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05498	60
AEPW	LEBROCK 345KV'	332	-0.02761	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05476	60
AEPW	PIRKEY GENERATION 138KV'	75	-0.02778	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05493	60
AEPW	WELSH 345KV'	54	-0.02986	AEPW	COMANCHE 138KV'	160	0.02448	-0.05434	60
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	RIVERSIDE STATION 138KV'	245	0.02274	-0.05474	60
AEPW	WILKES 345KV'	234.974	-0.02872	AEPW	COMANCHE 69KV'	63	0.02576	-0.05448	60
AEPW	EASTMAN 138KV'	330.01	-0.02807	AEPW	COMANCHE 69KV'	63	0.02576	-0.05383	61
SWPA	KENNETT 69KV'	29	0.00229	SWPA	DENISON 138KV'	65.84778	0.05622	-0.05393	61
AEPW	KNOXLEE 138KV'	321	-0.02783	AEPW	COMANCHE 69KV'	63	0.02576	-0.05359	61
AEPW	KNOXLEE 138KV'	60	-0.02783	AEPW	COMANCHE 69KV'	63	0.02576	-0.05359	61
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	COGENTRIX 345KV'	665	0.02125	-0.05392	61
AEPW	PIRKEY GENERATION 138KV'	75	-0.02778	AEPW	COMANCHE 69KV'	63	0.02576	-0.05354	61
AEPW	TENASKA GATEWAY 345KV'	937.03	-0.02631	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05346	61
AEPW	WELSH 345KV'	54	-0.02986	AEPW	WEATHERFORD 34KV'	148	0.02437	-0.05423	61
AEPW	ARSENAL HILL 69KV'	99	-0.02547	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05262	62
AEPW	LEBROCK 345KV'	332	-0.02761	AEPW	COMANCHE 69KV'	63	0.02576	-0.05337	62
AEPW	LIEBERMAN 138KV'	224	-0.02623	AEPW	SOUTHWESTERN STATION 138KV'	69	0.02715	-0.05338	62
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	NORTHEASTERN STATION 138KV'	207	0.01995	-0.05262	62
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	NORTHEASTERN STATION 138KV'	95	0.01995	-0.05262	62
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03267	AEPW	OEC 345KV'	256	0.02027	-0.05294	62
AEPW	WELSH 345KV'	54	-0.02986	AEPW	RIVERSIDE STATION 138KV'	245	0.02274	-0.0526	62
AEPW	WILKES 138KV'	426.089	-0.032	AEPW	COGENTRIX 345KV'	665	0.02125	-0.05325	62
AEPW	WILKES 345KV'	234.974	-0.02872	AEPW	COMANCHE 138KV'	160	0.02448	-0.0532	62

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Limiting Facility: BROKEN BOW - CRAIG JUNCTION 138KV CKT 1  
 Direction: From->To  
 Line Outage: BBDAMP4 - MOUNTAIN RIVER 138KV CKT 1  
 Flowgate: 52814540151558235600413107G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount
1079577	0.8	1.0
1090609	0.2	1.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SWPA	BEAVER 161KV'	34.13196	0.01453	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55338	2
SWPA	BULL SHOALS 161KV'	90.8008	0.00795	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55996	2
SWPA	CARTHAGE 69KV'	32	0.01474	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55317	2
SWPA	CLARENCE CANNON DAM 69KV'	58	0.00784	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56007	2
SWPA	DARDANELLE 161KV'	42.20037	0.00537	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56254	2
SWPA	DENISON 138KV'	18.40016	0.05627	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.51164	2
SWPA	EUFULA 138KV'	15.80014	0.03387	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.53404	2
SWPA	EUFULA 161KV'	7.900072	0.03383	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.53408	2
SWPA	FORT GIBSON 161KV'	13.20012	0.02196	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.54595	2
SWPA	GREERS FERRY 161KV'	29.00026	0.00227	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56564	2
SWPA	INDEPENDENCE 161KV'	13	0.00218	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56575	2
SWPA	JONESBORO 161KV'	76	0.00182	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56609	2
SWPA	KENNETT 69KV'	29	0.00227	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56564	2
SWPA	KEYSTONE DAM 161KV'	18.40016	0.0226	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.54531	2
SWPA	MALDEN 69KV'	14	0.00246	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56545	2
SWPA	NORFORK 161KV'	22.4002	0.00614	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56177	2
SWPA	OZARK 161KV'	47.00022	0.01204	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55587	2
SWPA	PARAGOULD 69KV'	17.5	0.00201	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.5659	2
SWPA	PIGGOTT 69KV'	7.5	0.00234	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56557	2

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SWPA	POPLAR BLUFF 69KV'	13	0.00336	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.56455	2
SWPA	ROBERT S. KERR 161KV'	33.20031	0.02016	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.54775	2
SWPA	STOCKTON 161KV'	13.70012	0.01246	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55545	2
SWPA	TABLE ROCK 161KV'	58.00052	0.01185	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55606	2
SWPA	TENKILLER FERRY 161KV'	11.0001	0.02634	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.54157	2
SWPA	TRUMAN 161KV'	91.6003	0.01068	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.55723	2
SWPA	WEBBERS FALLS 161KV'	35.00011	0.02634	SWPA	BROKEN BOW 138KV'	80.99974	0.56791	-0.54157	2
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	COMANCHE 138KV'	160	0.02448	-0.15776	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	COMANCHE 69KV'	63	0.02576	-0.15904	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	RIVERSIDE STATION 138KV'	379	0.02379	-0.15707	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.16045	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	TULSA POWER STATION 138KV'	38	0.02304	-0.15632	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.15767	6
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	COGENTRIX 345KV'	665	0.02061	-0.15389	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	FITZHUGH 161KV'	89	0.01206	-0.14534	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	FLINT CREEK 161KV'	400	0.01732	-0.15067	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	L&D13 69KV'	11	0.01508	-0.14836	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	NORTHEASTERN STATION 138KV'	304	0.02011	-0.15339	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	NORTHEASTERN STATION 138KV'	95	0.02011	-0.15339	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	NORTHEASTERN STATION 345KV'	550	0.01951	-0.15279	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	OEC 345KV'	256	0.02014	-0.15342	7
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	LIEBERMAN 138KV'	48.63074	-0.02626	-0.10702	9
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	EASTMAN 138KV'	155	-0.02801	-0.10527	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	KNOXLEE 138KV'	103	-0.02777	-0.10551	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	LEBROCK 345KV'	365	-0.0276	-0.10568	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	PIRKEY GENERATION 138KV'	440	-0.02777	-0.10551	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	WELSH 345KV'	1012	-0.02988	-0.1034	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	WILKES 138KV'	133	-0.03209	-0.10119	10
AEPW	NARROWS 69KV'	30	-0.13328	AEPW	WILKES 345KV'	200.1422	-0.02876	-0.10452	10
AEPW	FULTON 115KV'	153	-0.06212	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.08929	11
WFEC	MORLND 138KV'	320	0.02296	WFEC	HUGO 138KV'	450	0.11216	-0.0892	11
WFEC	ANADARKO 138KV'	41.68806	0.02778	WFEC	HUGO 138KV'	450	0.11216	-0.08438	12
WFEC	ANADARKO 138KV'	90	0.02778	WFEC	HUGO 138KV'	450	0.11216	-0.08438	12
WFEC	ANADARKO 69KV'	76	0.02764	WFEC	HUGO 138KV'	450	0.11216	-0.08452	12
WFEC	BLUCAN14 138 138KV'	151.2	0.0272	WFEC	HUGO 138KV'	450	0.11216	-0.08496	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	COGENTRIX 345KV'	665	0.02061	-0.08273	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	COMANCHE 138KV'	160	0.02448	-0.0866	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	COMANCHE 69KV'	63	0.02576	-0.08788	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	NORTHEASTERN STATION 138KV'	95	0.02011	-0.08223	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	NORTHEASTERN STATION 138KV'	304	0.02011	-0.08223	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	NORTHEASTERN STATION 345KV'	550	0.01951	-0.08163	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	OEC 345KV'	256	0.02014	-0.08226	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	RIVERSIDE STATION 138KV'	379	0.02379	-0.08591	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	TULSA POWER STATION 138KV'	38	0.02304	-0.08516	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.08651	12
AEPW	FULTON 115KV'	153	-0.06212	AEPW	FLINT CREEK 161KV'	400	0.01732	-0.07944	13
AEPW	FULTON 115KV'	153	-0.06212	AEPW	L&D13 69KV'	11	0.01508	-0.0772	13
AEPW	FULTON 115KV'	153	-0.06212	AEPW	FITZHUGH 161KV'	89	0.01206	-0.07418	14
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	COMANCHE 69KV'	63	0.02576	-0.05859	17
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.06	17
AEPW	WILKES 138KV'	330	-0.03209	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05926	17
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05518	18
AEPW	KNOXLEE 138KV'	260	-0.02777	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05494	18
AEPW	KNOXLEE 138KV'	60	-0.02777	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05494	18
AEPW	LEBROCK 345KV'	332	-0.0276	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05477	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	COMANCHE 138KV'	160	0.02448	-0.05731	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	RIVERSIDE STATION 138KV'	379	0.02379	-0.05662	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	TULSA POWER STATION 138KV'	38	0.02304	-0.05587	18
AEPW	LONESTAR POWER PLANT 69KV'	50	-0.03283	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.05722	18
AEPW	PIRKEY GENERATION 138KV'	75	-0.02777	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05494	18
AEPW	WELSH 345KV'	32	-0.02988	AEPW	COMANCHE 69KV'	63	0.02576	-0.05564	18
AEPW	WELSH 345KV'	32	-0.02988	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05705	18
AEPW	WILKES 138KV'	330	-0.03209	AEPW	COMANCHE 138KV'	160	0.02448	-0.05657	18
AEPW	WILKES 138KV'	330	-0.03209	AEPW	COMANCHE 69KV'	63	0.02576	-0.05785	18
AEPW	WILKES 138KV'	330	-0.03209	AEPW	RIVERSIDE STATION 138KV'	379	0.02379	-0.05588	18
AEPW	WILKES 138KV'	330	-0.03209	AEPW	TULSA POWER STATION 138KV'	38	0.02304	-0.05513	18
AEPW	WILKES 138KV'	330	-0.03209	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.05648	18
AEPW	WILKES 345KV'	110.8578	-0.02876	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05593	18
AEPW	ARSENAL HILL 69KV'	99	-0.02549	AEPW	SOUTHWESTERN STATION 138KV'	143	0.02717	-0.05266	19
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	COMANCHE 138KV'	160	0.02448	-0.05249	19
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	COMANCHE 69KV'	63	0.02576	-0.05377	19
AEPW	EASTMAN 138KV'	330.01	-0.02801	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.0524	19
SWPA	GREERS FERRY 161KV'	29.00026	0.00227	SWPA	DENISON 138KV'	51.59984	0.05627	-0.054	19
SWPA	INDEPENDENCE 161KV'	13	0.00216	SWPA	DENISON 138KV'	51.59984	0.05627	-0.05411	19
SWPA	JONESBORO 161KV'	76	0.00182	SWPA	DENISON 138KV'	51.59984	0.05627	-0.05445	19
SWPA	KENNETT 69KV'	29	0.00227	SWPA	DENISON 138KV'	51.59984	0.05627	-0.054	19
AEPW	KNOXLEE 138KV'	260	-0.02777	AEPW	COMANCHE 138KV'	160	0.02448	-0.05225	19
AEPW	KNOXLEE 138KV'	60	-0.02777	AEPW	COMANCHE 138KV'	160	0.02448	-0.05225	19
AEPW	KNOXLEE 138KV'	260	-0.02777	AEPW	COMANCHE 69KV'	63	0.02576	-0.05353	19
AEPW	KNOXLEE 138KV'	60	-0.02777	AEPW	COMANCHE 69KV'	63	0.02576	-0.05353	19
AEPW	KNOXLEE 138KV'	260	-0.02777	AEPW	WEATHERFORD 34KV'	148	0.02439	-0.05216	19

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: CITY OF WINFIELD - RAINBOW 69KV CKT 1  
 Limiting Facility: CITY OF WINFIELD - RAINBOW 69KV CKT 1  
 Direction: To->From  
 Line Outage: OAK - STROTHER FIELD (CITY OF WINFIELD) 69KV CKT 1  
 Flowgate: 57561575491575475755613307SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	5.4	8.1
1090609	0.9	8.1
1090609	0.4	8.1
1090609	0.9	8.1
1090609	0.5	8.1

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.76383	11
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	ABILENE ENERGY CENTER 115KV'	6.757809	-0.00235	-0.69839	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	CHANUTE 69KV'	46.617	-0.0025	-0.69824	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	CITY OF BURLINGTON 69KV'	7.8	-0.00437	-0.69637	12

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	CITY OF ERIE 69KV'	22.264	-0.0025	-0.69824	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	CITY OF FREDONIA 69KV'	5.225	-0.0029	-0.69784	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	CITY OF IOLA 69KV'	19.865	-0.00219	-0.69855	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	CITY OF MULVANE 69KV'	6.189	-0.00377	-0.69697	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	CLAY CENTER JUNCTION 115KV'	17.01001	-0.0024	-0.69834	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	-0.00437	-0.69637	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	EVANS ENERGY CENTER 138KV'	305	-0.00424	-0.6965	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	GILL ENERGY CENTER 138KV'	77	-0.00285	-0.69789	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	HOLTON 115KV'	12.2	-0.0029	-0.69784	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.00206	-0.69868	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	JEFFREY ENERGY CENTER 230KV'	470	-0.00246	-0.69828	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	JEFFREY ENERGY CENTER 345KV'	940	-0.00246	-0.69828	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	LAWRENCE ENERGY CENTER 115KV'	60	-0.0024	-0.69834	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	LAWRENCE ENERGY CENTER 230KV'	232.5762	-0.00244	-0.6983	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	SOUTH SENECA 115KV'	8.5	-0.00338	-0.69736	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	TECUMSEH ENERGY CENTER 115KV'	108	-0.00249	-0.69825	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	WACO 138KV'	17.947	-0.00299	-0.69775	12
WERE	CITY OF WINFIELD 69KV'	40	-0.70074	WERE	CITY OF AUGUSTA 69KV'	20.02	-0.05656	-0.64418	13
WERE	GETTY 69KV'	35	-0.01861	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.0817	99
WERE	LATHAM1234.0 345KV'	150	-0.00475	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06784	119
WERE	EVANS ENERGY CENTER 138KV'	488	-0.00424	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06733	120
WERE	CHANUTE 69KV'	41.183	-0.0025	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06559	123
WERE	GILL ENERGY CENTER 138KV'	118	-0.00285	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06594	123
WERE	JEFFREY ENERGY CENTER 345KV'	42	-0.00246	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06555	123
WERE	LAWRENCE ENERGY CENTER 115KV'	78	-0.0024	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06549	123
WERE	TECUMSEH ENERGY CENTER 115KV'	52.99999	-0.00249	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06558	123
WERE	TECUMSEH ENERGY CENTER 69KV'	41	-0.00249	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06558	123
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.00213	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06522	124
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.00206	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06515	124
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.00206	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06515	124
WERE	SMOKYHIL 230 230KV'	72	-0.00209	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06518	124

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: CITY OF WINFIELD - RAINBOW 69KV CKT 1  
 Limiting Facility: CITY OF WINFIELD - RAINBOW 69KV CKT 1  
 Direction: To->From  
 Line Outage: OAK - STROTHER FIELD (CITY OF WINFIELD) 69KV CKT 1  
 Flowgate: 575615754915754755613307SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.9	8.0
1090609	0.4	8.0
1090609	1.1	8.0
1090609	0.5	8.0
1090609	5.1	8.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.76383	10
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	ABILENE ENERGY CENTER 115KV'	40	-0.00235	-0.69839	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	BPU - CITY OF MCPHERSON 115KV'	135	-0.00213	-0.69861	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	CHANUTE 69KV'	56.723	-0.0025	-0.69824	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	CITY OF BURLINGTON 69KV'	10.12	-0.00438	-0.69636	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	CITY OF ERIE 69KV'	22.274	-0.0025	-0.69824	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	CITY OF FREDONIA 69KV'	5.225	-0.0029	-0.69784	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	CITY OF GIRARD 69KV'	4.789	-0.00123	-0.69951	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	CITY OF IOLA 69KV'	24.267	-0.00219	-0.69855	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	CITY OF MULVANE 69KV'	8.288	-0.00377	-0.69697	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	CLAY CENTER JUNCTION 115KV'	28.875	-0.0024	-0.69834	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	-0.00438	-0.69636	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	EVANS ENERGY CENTER 138KV'	394.978	-0.00424	-0.6965	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	GILL ENERGY CENTER 138KV'	155	-0.00285	-0.69789	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	HOLTON 115KV'	12.2	-0.0029	-0.69784	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	-0.00206	-0.69868	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	JEFFREY ENERGY CENTER 230KV'	470	-0.00246	-0.69828	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	JEFFREY ENERGY CENTER 345KV'	940	-0.00246	-0.69828	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	LAWRENCE ENERGY CENTER 115KV'	85	-0.0024	-0.69834	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	LAWRENCE ENERGY CENTER 230KV'	234.5685	-0.00244	-0.6983	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	SOUTH SENECA 115KV'	8.5	-0.00338	-0.69736	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	TECUMSEH ENERGY CENTER 115KV'	128	-0.00249	-0.69825	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	WACO 138KV'	17.96	-0.00299	-0.69775	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.70074	WERE	CITY OF AUGUSTA 69KV'	25.12	-0.05656	-0.64418	12
WERE	GETTY 69KV'	35	-0.01861	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.0817	97
WERE	LATHAM1234.0 345KV'	150	-0.00475	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06784	118
WERE	EVANS ENERGY CENTER 138KV'	178.022	-0.00424	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06733	118
WERE	JEFFREY ENERGY CENTER 345KV'	42	-0.00246	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06555	121
WERE	TECUMSEH ENERGY CENTER 69KV'	41	-0.00249	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06558	121
WERE	HUTCHINSON ENERGY CENTER 115KV'	263	-0.00206	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06515	122
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.00206	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06515	122
WERE	SMOKYHIL 230 230KV'	72	-0.00209	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06518	122
WERE	NEOSHO ENERGY CENTER 138KV'	47	-0.00173	WERE	CITY OF WELLINGTON 69KV'	41.45	0.06309	-0.06482	123

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: CLAY CENTER - GREENLEAF 115KV CKT 1  
 Limiting Facility: KELLY - SOUTH SENECA 115KV CKT 1  
 Direction: From->To  
 Line Outage: CONCORDIA - EAST MANHATTAN 230KV CKT 1  
 Flowgate: 5721757371587585686112207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	2.0	14.9
1090609	0.7	14.9
1090609	1.7	14.9
1090609	0.9	14.9
1090609	4.2	14.9
1090612	1.4	14.9
1090613	1.3	14.9

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1090674		0.1							14.9
1090817		1.0							14.9
1090964		1.4							14.9
1090965		0.4							14.9
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CHANUTE 69KV'	46.617	-0.00046	-0.86901	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00074	-0.87021	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF BURLINGTON 69KV'	7.8	-0.00075	-0.86872	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF ERIE 69KV'	22.264	-0.00046	-0.86901	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF IOLA 69KV'	19.865	-0.0005	-0.86897	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF MULVANE 69KV'	6.189	-0.00131	-0.86816	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF WELLINGTON 69KV'	41.45	-0.00166	-0.86781	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CLAY CENTER JUNCTION 115KV'	17.01001	-0.01018	-0.85929	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	-0.00075	-0.86872	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'EVANS ENERGY CENTER 138KV'	262.1094	-0.00154	-0.86793	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'GILL ENERGY CENTER 138KV'	77	-0.00221	-0.86726	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'HOLTON 115KV'	12.2	0.03515	-0.90462	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'JEFFREY ENERGY CENTER 230KV'	470	-0.00344	-0.86603	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'JEFFREY ENERGY CENTER 345KV'	940	-0.00347	-0.866	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'LAWRENCE ENERGY CENTER 115KV'	60	-0.00099	-0.86848	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'LAWRENCE ENERGY CENTER 230KV'	235.9986	-0.00137	-0.8681	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'TECUMSEH ENERGY CENTER 115KV'	108	-0.00054	-0.86893	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'WACO 138KV'	17.947	-0.00214	-0.86733	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.02718	-0.84229	18
WEPL	GREENLEAF 115KV	14.2	-0.61704	WEPL	'GRAY COUNTY WIND FARM 115KV'	73	-0.02828	-0.58876	25
WEPL	GREENLEAF 115KV	14.2	-0.61704	WEPL	'JUDSON LARGE 115KV'	100.6043	-0.02824	-0.5888	25
WEPL	GREENLEAF 115KV	14.2	-0.61704	WEPL	'A. M. MULLERGREEN GENERATOR 115KV'	63	-0.05418	-0.56286	27
WEPL	CLIFTON 115KV	70	-0.54644	WEPL	'GRAY COUNTY WIND FARM 115KV'	73	-0.02828	-0.51816	29
WEPL	CLIFTON 115KV	70	-0.54644	WEPL	'JUDSON LARGE 115KV'	100.6043	-0.02824	-0.5182	29
WEPL	CLIFTON 115KV	70	-0.54644	WEPL	'A. M. MULLERGREEN GENERATOR 115KV'	63	-0.05418	-0.49226	30
WEPL	BELOIT 115KV	16.6	-0.38422	WEPL	'GRAY COUNTY WIND FARM 115KV'	73	-0.02828	-0.35594	42
WEPL	BELOIT 115KV	16.6	-0.38422	WEPL	'JUDSON LARGE 115KV'	100.6043	-0.02824	-0.35598	42
WEPL	BELOIT 115KV	16.6	-0.38422	WEPL	'A. M. MULLERGREEN GENERATOR 115KV'	63	-0.05418	-0.33004	45

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: CLAY CENTER - GREENLEAF 115KV CKT 1  
 Limiting Facility: KELLY - SOUTH SENECA 115KV CKT 1  
 Direction: From->To  
 Line Outage: CONCORDIA (CONCORD6) 230-115-13.8KV TRANSFORMER CKT 1  
 Flowgate: 57217573371CONCORD66312207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	2.0	14.9
1090609	0.7	14.9
1090609	1.7	14.9
1090609	0.9	14.9
1090609	4.2	14.9
1090612	1.4	14.9
1090613	1.3	14.9
1090674	0.1	14.9
1090817	1.0	14.9
1090964	1.4	14.9
1090965	0.4	14.9

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CHANUTE 69KV'	46.617	-0.00046	-0.86901	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00074	-0.87021	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF BURLINGTON 69KV'	7.8	-0.00075	-0.86872	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF ERIE 69KV'	22.264	-0.00046	-0.86901	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF IOLA 69KV'	19.865	-0.0005	-0.86897	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF MULVANE 69KV'	6.189	-0.00131	-0.86816	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CITY OF WELLINGTON 69KV'	41.45	-0.00166	-0.86781	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'CLAY CENTER JUNCTION 115KV'	17.01001	-0.01018	-0.85929	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	-0.00075	-0.86872	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'EVANS ENERGY CENTER 138KV'	262.1094	-0.00154	-0.86793	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'GILL ENERGY CENTER 138KV'	77	-0.00221	-0.86726	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'HOLTON 115KV'	12.2	0.03515	-0.90462	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'JEFFREY ENERGY CENTER 230KV'	470	-0.00344	-0.86603	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'JEFFREY ENERGY CENTER 345KV'	940	-0.00347	-0.866	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'LAWRENCE ENERGY CENTER 115KV'	60	-0.00099	-0.86848	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'LAWRENCE ENERGY CENTER 230KV'	235.9986	-0.00137	-0.8681	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'TECUMSEH ENERGY CENTER 115KV'	108	-0.00054	-0.86893	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'WACO 138KV'	17.947	-0.00214	-0.86733	17
WERE	SOUTH SENECA 115KV	8.2	-0.86947	WERE	'HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.02718	-0.84229	18
WEPL	GREENLEAF 115KV	14.2	-0.61704	WEPL	'GRAY COUNTY WIND FARM 115KV'	73	-0.02828	-0.58876	25
WEPL	GREENLEAF 115KV	14.2	-0.61704	WEPL	'JUDSON LARGE 115KV'	100.6043	-0.02824	-0.5888	25
WEPL	GREENLEAF 115KV	14.2	-0.61704	WEPL	'A. M. MULLERGREEN GENERATOR 115KV'	63	-0.05418	-0.56286	27
WEPL	CLIFTON 115KV	70	-0.54644	WEPL	'GRAY COUNTY WIND FARM 115KV'	73	-0.02828	-0.51816	29
WEPL	CLIFTON 115KV	70	-0.54644	WEPL	'JUDSON LARGE 115KV'	100.6043	-0.02824	-0.5182	29
WEPL	CLIFTON 115KV	70	-0.54644	WEPL	'A. M. MULLERGREEN GENERATOR 115KV'	63	-0.05418	-0.49226	30
WEPL	BELOIT 115KV	16.6	-0.38422	WEPL	'GRAY COUNTY WIND FARM 115KV'	73	-0.02828	-0.35594	42
WEPL	BELOIT 115KV	16.6	-0.38422	WEPL	'JUDSON LARGE 115KV'	100.6043	-0.02824	-0.35598	42
WEPL	BELOIT 115KV	16.6	-0.38422	WEPL	'A. M. MULLERGREEN GENERATOR 115KV'	63	-0.05418	-0.33004	45

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: CRESWELL - PARIS 69KV CKT 1  
 Limiting Facility: CRESWELL - PARIS 69KV CKT 1  
 Direction: From->To  
 Line Outage: CRESWELL - OAK 69KV CKT 1  
 Flowgate: 57543575481575435754713307SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.5	4.8
1090609	0.3	4.8

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1090609		0.7							4.8
1090609		0.3							4.8
1090609		2.9							4.8
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'ABILENE ENERGY CENTER 115KV'	40	-0.00218	-0.64974	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'BPU - CITY OF MCPHERSON 115KV'	135	-0.00198	-0.64994	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'CHANUTE 69KV'	56.723	-0.00233	-0.64959	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'CITY OF BURLINGTON 69KV'	10.12	-0.00407	-0.64785	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'CITY OF ERIE 69KV'	22.274	-0.00233	-0.64959	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'CITY OF FREDONIA 69KV'	5.225	-0.0027	-0.64922	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'CITY OF GIRARD 69KV'	4.789	-0.00114	-0.65078	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'CITY OF IOLA 69KV'	24.267	-0.00203	-0.64989	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'CITY OF MULVANE 69KV'	8.288	-0.0035	-0.64842	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.71062	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'CLAY CENTER JUNCTION 115KV'	28.875	-0.00224	-0.64968	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	-0.00407	-0.64785	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'EVANS ENERGY CENTER 138KV'	394.978	-0.00394	-0.64798	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'GILL ENERGY CENTER 138KV'	155	-0.00265	-0.64927	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'HOLTON 115KV'	12.2	-0.00269	-0.64923	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'HUTCHINSON ENERGY CENTER 115KV'	120	-0.00191	-0.65001	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'JEFFREY ENERGY CENTER 230KV'	470	-0.00229	-0.64963	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'JEFFREY ENERGY CENTER 345KV'	940	-0.00228	-0.64964	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'LAWRENCE ENERGY CENTER 115KV'	85	-0.00223	-0.64969	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'LAWRENCE ENERGY CENTER 230KV'	234.5685	-0.00227	-0.64965	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'SOUTH SENECA 115KV'	8.5	-0.00314	-0.64878	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'TECUMSEH ENERGY CENTER 115KV'	128	-0.00232	-0.6496	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'WACO 138KV'	17.96	-0.00278	-0.64914	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.65192	WERE	'CITY OF AUGUSTA 69KV'	25.12	-0.05262	-0.5993	8
WERE	GETTY 69KV	35	-0.01732	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.07602	63
WERE	EVANS ENERGY CENTER 138KV	178.022	-0.00394	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06264	76
WERE	LATHAM1234.0 345KV	150	-0.00442	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06312	76
WERE	CHANUTE 69KV	31.077	-0.00233	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06103	78
WERE	JEFFREY ENERGY CENTER 345KV	42	-0.00228	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06098	78
WERE	LAWRENCE ENERGY CENTER 115KV	28	-0.00223	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06093	78
WERE	LAWRENCE ENERGY CENTER 230KV	34.43155	-0.00227	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06097	78
WERE	TECUMSEH ENERGY CENTER 115KV	33	-0.00232	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06102	78
WERE	TECUMSEH ENERGY CENTER 69KV	41	-0.00232	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06102	78
WERE	BPU - CITY OF MCPHERSON 115KV	39	-0.00198	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06068	79
WERE	HUTCHINSON ENERGY CENTER 115KV	263	-0.00191	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06061	79
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.00191	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06061	79
WERE	NEOSHO ENERGY CENTER 138KV	47	-0.00161	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06031	79
WERE	SMOKYHIL 230 230KV	72	-0.00195	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.06065	79
WERE	GILL ENERGY CENTER 69KV	118	-0.00061	WERE	'CITY OF WELLINGTON 69KV'	41.45	0.0587	-0.05931	81

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

CURRY COUNTY INTERCHANGE -  
ROOSEVELT COUNTY INTERCHANGE 115KV  
CKT 2 & ROOSEVELT COUNTY  
INTERCHANGE 230/115KV TRANSFORMER  
CKT 1 & Potter - Roosevelt 345KV

Upgrade:  
Limiting Facility:  
Direction:  
Line Outage:  
Flowgate:  
Date Redispatch Needed:  
Season Flowgate Identified:

NICHOLS STATION 230-115KV TRANSFORMER CKT 1  
From->To  
NICHOLS STATION 230-115KV TRANSFORMER CKT 2  
50914509151509155091421408SP  
Starting 2008 6/1 - 10/1 Until EOC  
2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090270	0.1	0.5
1090315	0.1	0.5
1090454	0.2	0.5
1090456	0.1	0.5
1090767	0.1	0.5
1090789	0.1	0.5

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'BLACKHAWK 115KV'	220	-0.0498	-0.20546	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'CAPROCK 115KV'	8	0.00003	-0.25529	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'CUNNINGHAM 115KV'	110	0.00116	-0.25642	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'CUNNINGHAM 115KV'	71	0.00116	-0.25642	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'CUNNINGHAM 230KV'	306	0.00118	-0.25644	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'HARRINGTON 230KV'	1066	0.0412	-0.29646	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'HUBRCO 69KV'	11	-0.05529	-0.19997	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'JONES 230KV'	486	-0.00006	-0.2552	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'LP-BRNDZ 69KV'	80	-0.00012	-0.25514	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'MADDOX 115KV'	183	0.00115	-0.25641	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'MOORE COUNTY 115KV'	48	-0.05569	-0.19957	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'MUSTANG 115KV'	300	0.00107	-0.25633	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'MUSTG5 118.0 230KV'	360	0.00116	-0.25642	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'NICHOLS 230KV'	147	0.04614	-0.3014	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'PLANTX 115KV'	216.5015	0.00011	-0.25537	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'PLANTX 230KV'	189	0.00237	-0.25763	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'SAN JUAN 230KV'	12	0.00118	-0.25644	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'SIDRCH 69KV'	20	-0.05529	-0.19997	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'TOLK 230KV'	1039.601	0.00187	-0.25713	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'WILWIND 230KV'	16	0.00681	-0.26207	2
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'CZ 69KV'	39	-0.11997	-0.13529	4
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'HARRINGTON 230KV'	1066	0.0412	-0.09695	5
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'NICHOLS 115KV'	147	0.04614	-0.10189	5
SPS	'NICHOLS 115KV'	66.00001	-0.25528	SPS	'STEER WATER 115KV'	8	-0.18929	-0.06597	7
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'CUNNINGHAM 115KV'	71	0.00116	-0.05691	8
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'CUNNINGHAM 115KV'	110	0.00116	-0.05691	8
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'CUNNINGHAM 230KV'	306	0.00118	-0.05693	8
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'MADDOX 115KV'	183	0.00115	-0.0569	8
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'MUSTANG 115KV'	300	0.00107	-0.05682	8
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'MUSTG5 118.0 230KV'	360	0.00116	-0.05691	8
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'PLANTX 230KV'	189	0.00237	-0.05812	8
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'SAN JUAN 230KV'	12	0.00118	-0.05693	8
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'TOLK 230KV'	1039.601	0.00187	-0.05762	8
SPS	RIVERVIEW 69KV	23	-0.05575	SPS	'WILWIND 230KV'	16	0.00681	-0.06256	8

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	RIVERVIEW 69KV'	23	-0.05575	SPS	CAPROCK 115KV'	8	0.00003	-0.05578	9
SPS	RIVERVIEW 69KV'	23	-0.05575	SPS	JONES 230KV'	486	-0.00006	-0.05569	9
SPS	RIVERVIEW 69KV'	23	-0.05575	SPS	LP-BRND2 69KV'	80	-0.00012	-0.05563	9
SPS	RIVERVIEW 69KV'	23	-0.05575	SPS	PLANTX 115KV'	216.5015	0.00011	-0.05586	9
SPS	JONES 230KV'	243	-0.00006	SPS	NICHOLS 230KV'	147	0.04614	-0.0462	10
SPS	LP-BRND2 69KV'	152	-0.00012	SPS	NICHOLS 230KV'	147	0.04614	-0.04626	10
SPS	PLANTX 115KV'	36.49854	0.00011	SPS	NICHOLS 230KV'	147	0.04614	-0.04603	10
SPS	TUCUMCARI 115KV'	15	0.00003	SPS	NICHOLS 230KV'	147	0.04614	-0.04611	10
SPS	CARLSBAD 69KV'	18	0.00127	SPS	NICHOLS 230KV'	147	0.04614	-0.04487	11
SPS	MADDOX 115KV'	10	0.00115	SPS	NICHOLS 230KV'	147	0.04614	-0.04499	11
SPS	TOLK 230KV'	580.3989	0.00187	SPS	NICHOLS 230KV'	147	0.04614	-0.04427	11
SPS	TOLK 345KV'	540	0.00178	SPS	NICHOLS 230KV'	147	0.04614	-0.04436	11
SPS	CARLSBAD 69KV'	18	0.00127	SPS	HARRINGTON 230KV'	1066	0.0412	-0.03993	12
SPS	JONES 230KV'	243	-0.00006	SPS	HARRINGTON 230KV'	1066	0.0412	-0.04126	12
SPS	LP-BRND2 69KV'	152	-0.00012	SPS	HARRINGTON 230KV'	1066	0.0412	-0.04132	12
SPS	MADDOX 115KV'	10	0.00115	SPS	HARRINGTON 230KV'	1066	0.0412	-0.04005	12
SPS	PLANTX 115KV'	36.49854	0.00011	SPS	HARRINGTON 230KV'	1066	0.0412	-0.04109	12
SPS	TOLK 230KV'	580.3989	0.00187	SPS	HARRINGTON 230KV'	1066	0.0412	-0.03933	12
SPS	TOLK 345KV'	540	0.00178	SPS	HARRINGTON 230KV'	1066	0.0412	-0.03942	12
SPS	TUCUMCARI 115KV'	15	0.00003	SPS	HARRINGTON 230KV'	1066	0.0412	-0.04117	12

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

CURRY COUNTY INTERCHANGE -  
ROOSEVELT COUNTY INTERCHANGE 115KV  
CKT 2 & ROOSEVELT COUNTY  
INTERCHANGE 230/115KV TRANSFORMER  
CKT 1 & Potter - Roosevelt 345KV

Upgrade:

Limiting Facility:

Direction:

Line Outage:

Flowgate:

Date Redispatch Needed:

Season Flowgate Identified:

NICHOLS STATION 230-115KV TRANSFORMER CKT 2  
From->To  
NICHOLS STATION 230-115KV TRANSFORMER CKT 1  
50914509152509155091411408SP  
Starting 2008 6/1 - 10/1 Until EOC  
2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090270	0.5	2.6
1090315	0.7	2.6
1090454	0.8	2.6
1090456	0.2	2.6
1090767	0.4	2.6
1090789	0.2	2.6

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	HARRINGTON 230KV'	1066	0.04045	-0.29108	9
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	NICHOLS 230KV'	147	0.0453	-0.29593	9
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	CUNNINGHAM 115KV'	110	0.00113	-0.25176	10
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	CUNNINGHAM 115KV'	71	0.00113	-0.25176	10
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	CUNNINGHAM 230KV'	306	0.00116	-0.25179	10
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	MADDOX 115KV'	183	0.00113	-0.25176	10
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	MUSTANG 115KV'	300	0.00105	-0.25168	10
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	MUSTG5 118.0 230KV'	360	0.00114	-0.25177	10
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	PLANTX 230KV'	189	0.00233	-0.25296	10
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	SAN JUAN 230KV'	12	0.00116	-0.25179	10
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	TOLK 230KV'	1039.601	0.00184	-0.25247	10
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	WILWIND 230KV'	16	0.00669	-0.25732	10
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	CAPROCK 115KV'	8	0.00003	-0.25066	11
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	JONES 230KV'	486	-0.00006	-0.25057	11
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	LP-BRND2 69KV'	80	-0.00012	-0.25051	11
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	PLANTX 115KV'	216.5015	0.00011	-0.25074	11
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	BLACKHAWK 115KV'	220	-0.04889	-0.20174	13
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	HUBRCO2 69KV'	11	-0.05429	-0.19634	13
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	MOORE COUNTY 115KV'	48	-0.05468	-0.19595	13
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	SIDRCH 69KV'	20	-0.05429	-0.19634	13
SPS	NICHOLS 115KV'	66.00001	-0.25063	SPS	CZ 69KV'	39	-0.11779	-0.13284	20
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	NICHOLS 230KV'	147	0.0453	-0.10004	26
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	HARRINGTON 230KV'	1066	0.04045	-0.09519	28
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	WILWIND 230KV'	16	0.00669	-0.06143	43
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	PLANTX 230KV'	189	0.00233	-0.05707	46
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	CUNNINGHAM 115KV'	110	0.00113	-0.05587	47
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	CUNNINGHAM 115KV'	71	0.00113	-0.05587	47
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	CUNNINGHAM 230KV'	306	0.00116	-0.05599	47
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	MADDOX 115KV'	183	0.00113	-0.05587	47
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	MUSTANG 115KV'	300	0.00105	-0.05579	47
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	MUSTG5 118.0 230KV'	360	0.00114	-0.05588	47
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	TOLK 230KV'	1039.601	0.00184	-0.05658	47
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	JONES 230KV'	486	-0.00006	-0.05468	48
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	LP-BRND2 69KV'	80	-0.00012	-0.05462	48
SPS	RIVERVIEW 69KV'	23	-0.05474	SPS	PLANTX 115KV'	216.5015	0.00011	-0.05485	48
SPS	JONES 230KV'	243	-0.00006	SPS	NICHOLS 230KV'	147	0.0453	-0.04536	58
SPS	LP-BRND2 69KV'	152	-0.00012	SPS	NICHOLS 230KV'	147	0.0453	-0.04542	58
SPS	PLANTX 115KV'	36.49854	0.00011	SPS	NICHOLS 230KV'	147	0.0453	-0.04519	58
SPS	TOLK 230KV'	580.3989	0.00184	SPS	NICHOLS 230KV'	147	0.0453	-0.04346	61
SPS	TOLK 345KV'	540	0.00175	SPS	NICHOLS 230KV'	147	0.0453	-0.04355	61
SPS	JONES 230KV'	243	-0.00006	SPS	HARRINGTON 230KV'	1066	0.04045	-0.04051	65
SPS	LP-BRND2 69KV'	152	-0.00012	SPS	HARRINGTON 230KV'	1066	0.04045	-0.04057	65
SPS	PLANTX 115KV'	36.49854	0.00011	SPS	HARRINGTON 230KV'	1066	0.04045	-0.04034	65
SPS	TOLK 230KV'	580.3989	0.00184	SPS	HARRINGTON 230KV'	1066	0.04045	-0.03861	68
SPS	TOLK 345KV'	540	0.00175	SPS	HARRINGTON 230KV'	1066	0.04045	-0.0387	68

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

CURRY COUNTY INTERCHANGE -  
ROOSEVELT COUNTY INTERCHANGE 115KV  
CKT 2 & ROOSEVELT COUNTY  
INTERCHANGE 230/115KV TRANSFORMER  
CKT 1 & Potter - Roosevelt 345KV

Upgrade:

Limiting Facility:

Direction:

Line Outage:

CANYON EAST - OSAGE SWITCHING STATION 115KV CKT 1  
To->From  
BUSHLAND INTERCHANGE - DEAF SMITH INTERCHANGE 230KV CKT 1

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Flowgate: 5108051014150993511114407AP  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount										
1090301		1.2										8.0
1090680		4.3										8.0
1090695		2.5										8.0
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)			
SPS	PLANTX 115KV'	253	-0.10435	SPS	'STEER WATER 115KV'	36	0.04732	-0.15167	53			
SPS	PLANTX 115KV'	253	-0.10435	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.14711	54			
SPS	PLANTX 115KV'	253	-0.10435	SPS	'CZ 69KV'	35	0.04297	-0.14732	54			
SPS	PLANTX 230KV'	189	-0.10013	SPS	'STEER WATER 115KV'	36	0.04732	-0.14745	54			
SPS	PLANTX 115KV'	253	-0.10435	SPS	'HARRINGTON 230KV'	706	0.04113	-0.14548	55			
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'STEER WATER 115KV'	36	0.04732	-0.14522	55			
SPS	TOLK 345KV'	540	-0.09745	SPS	'STEER WATER 115KV'	36	0.04732	-0.14477	55			
SPS	PLANTX 115KV'	253	-0.10435	SPS	'WILWIND 230KV'	72	0.03907	-0.14342	56			
SPS	PLANTX 230KV'	189	-0.10013	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.14289	56			
SPS	PLANTX 230KV'	189	-0.10013	SPS	'CZ 69KV'	35	0.04297	-0.1431	56			
SPS	PLANTX 230KV'	189	-0.10013	SPS	'HARRINGTON 230KV'	706	0.04113	-0.14126	56			
SPS	PLANTX 230KV'	189	-0.10013	SPS	'WILWIND 230KV'	72	0.03907	-0.1392	57			
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.14066	57			
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'CZ 69KV'	35	0.04297	-0.14087	57			
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13903	57			
SPS	TOLK 345KV'	540	-0.09745	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.14021	57			
SPS	TOLK 345KV'	540	-0.09745	SPS	'CZ 69KV'	35	0.04297	-0.14042	57			
SPS	TOLK 345KV'	540	-0.09745	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13858	57			
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'STEER WATER 115KV'	36	0.04732	-0.13672	58			
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'STEER WATER 115KV'	36	0.04732	-0.13672	58			
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'STEER WATER 115KV'	36	0.04732	-0.1373	58			
SPS	MADOX 115KV'	193	-0.08928	SPS	'STEER WATER 115KV'	36	0.04732	-0.1366	58			
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'WILWIND 230KV'	72	0.03907	-0.13697	58			
SPS	TOLK 345KV'	540	-0.09745	SPS	'WILWIND 230KV'	72	0.03907	-0.13652	58			
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'STEER WATER 115KV'	36	0.04732	-0.13421	59			
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'STEER WATER 115KV'	36	0.04732	-0.13519	59			
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13216	60			
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13216	60			
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'CZ 69KV'	35	0.04297	-0.13237	60			
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'CZ 69KV'	35	0.04297	-0.13237	60			
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13274	60			
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'CZ 69KV'	35	0.04297	-0.13295	60			
SPS	MADOX 115KV'	193	-0.08928	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13204	60			
SPS	MADOX 115KV'	193	-0.08928	SPS	'CZ 69KV'	35	0.04297	-0.13225	60			
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13053	61			
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13053	61			
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13111	61			
SPS	MADOX 115KV'	193	-0.08928	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13041	61			
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.12965	61			
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'CZ 69KV'	35	0.04297	-0.12986	61			
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13063	61			
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'CZ 69KV'	35	0.04297	-0.13084	61			
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'WILWIND 230KV'	72	0.03907	-0.12847	62			
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'WILWIND 230KV'	72	0.03907	-0.12847	62			
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'WILWIND 230KV'	72	0.03907	-0.12905	62			
SPS	MADOX 115KV'	193	-0.08928	SPS	'WILWIND 230KV'	72	0.03907	-0.12835	62			
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'HARRINGTON 230KV'	706	0.04113	-0.12802	62			
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'HARRINGTON 230KV'	706	0.04113	-0.129	62			
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'WILWIND 230KV'	72	0.03907	-0.12596	63			
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'WILWIND 230KV'	72	0.03907	-0.12694	63			
SPS	JONES 230KV'	625	-0.06697	SPS	'STEER WATER 115KV'	36	0.04732	-0.11429	70			
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'STEER WATER 115KV'	36	0.04732	-0.11324	70			
SPS	JONES 230KV'	625	-0.06697	SPS	'CZ 69KV'	35	0.04297	-0.10994	72			
SPS	JONES 230KV'	625	-0.06697	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.10973	73			
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.10868	73			
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'CZ 69KV'	35	0.04297	-0.10889	73			
SPS	JONES 230KV'	625	-0.06697	SPS	'HARRINGTON 230KV'	706	0.04113	-0.1081	74			
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'HARRINGTON 230KV'	706	0.04113	-0.10705	74			
SPS	JONES 230KV'	625	-0.06697	SPS	'WILWIND 230KV'	72	0.03907	-0.10604	75			
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'WILWIND 230KV'	72	0.03907	-0.10499	76			
SPS	PLANTX 115KV'	253	-0.10435	SPS	'JONES 230KV'	104	-0.06697	-0.03738	213			
SPS	PLANTX 230KV'	189	-0.10013	SPS	'JONES 230KV'	104	-0.06697	-0.03316	240			
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'JONES 230KV'	104	-0.06697	-0.03093	257			
SPS	TOLK 345KV'	540	-0.09745	SPS	'JONES 230KV'	104	-0.06697	-0.03048	261			

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

CURRY COUNTY INTERCHANGE -  
 ROOSEVELT COUNTY INTERCHANGE 115KV  
 CKT 2 & ROOSEVELT COUNTY  
 INTERCHANGE 230V/115KV TRANSFORMER

Upgrade:  
 Limiting Facility: CKT 1 & Potter - Roosevelt 345KV  
 Direction: CANYON EAST - OSAGE SWITCHING STATION 115KV CKT 1  
 To->From:  
 Line Outage: BUSHLAND INTERCHANGE - DEAF SMITH INTERCHANGE 230KV CKT 1  
 Flowgate: 5108051014150993511114407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount										
1090301		1.8										8.8
1090680		4.4										8.8
1090695		2.6										8.8
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)			
SPS	PLANTX 115KV'	48	-0.10442	SPS	'NICHOLS 115KV'	147	0.05132	-0.15574	57			
SPS	TOLK 230KV'	588.766	-0.09797	SPS	'NICHOLS 115KV'	147	0.05132	-0.14929	59			
SPS	TOLK 345KV'	540	-0.09753	SPS	'NICHOLS 115KV'	147	0.05132	-0.14885	59			
SPS	PLANTX 115KV'	48	-0.10442	SPS	'BLACKHAWK 115KV'	220	0.04264	-0.14706	60			
SPS	PLANTX 115KV'	48	-0.10442	SPS	'CZ 69KV'	39	0.04285	-0.14727	60			
SPS	PLANTX 115KV'	48	-0.10442	SPS	'SIDRCH 69KV'	20	0.04292	-0.14734	60			
SPS	PLANTX 115KV'	48	-0.10442	SPS	'HARRINGTON 230KV'	1066	0.04102	-0.14544	61			



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	PLANTX 115KV'	48	-0.10442	SPS	'MOORE COUNTY 115KV'	48	0.04003	-0.14445	61
SPS	PLANTX 115KV'	48	-0.10442	SPS	'NICHOLS 230KV'	147	0.04104	-0.14546	61
SPS	MUSTG5 118.0 230KV'	150	-0.08794	SPS	'NICHOLS 115KV'	147	0.05132	-0.13926	63
SPS	TOLK 230KV'	588,766	-0.09797	SPS	'BLACKHAWK 115KV'	220	0.04264	-0.14061	63
SPS	TOLK 230KV'	588,766	-0.09797	SPS	'CZ 69KV'	39	0.04285	-0.14082	63
SPS	TOLK 345KV'	540	-0.09753	SPS	'BLACKHAWK 115KV'	220	0.04264	-0.14017	63
SPS	TOLK 345KV'	540	-0.09753	SPS	'CZ 69KV'	39	0.04285	-0.14038	63
SPS	TOLK 230KV'	588,766	-0.09797	SPS	'HARRINGTON 230KV'	1066	0.04102	-0.13899	64
SPS	TOLK 230KV'	588,766	-0.09797	SPS	'MOORE COUNTY 115KV'	48	0.04003	-0.138	64
SPS	TOLK 230KV'	588,766	-0.09797	SPS	'NICHOLS 230KV'	147	0.04104	-0.13901	64
SPS	TOLK 345KV'	540	-0.09753	SPS	'HARRINGTON 230KV'	1066	0.04102	-0.13855	64
SPS	TOLK 345KV'	540	-0.09753	SPS	'MOORE COUNTY 115KV'	48	0.04003	-0.13756	64
SPS	TOLK 345KV'	540	-0.09753	SPS	'NICHOLS 230KV'	147	0.04104	-0.13857	64
SPS	MUSTG5 118.0 230KV'	150	-0.08794	SPS	'BLACKHAWK 115KV'	220	0.04264	-0.13058	68
SPS	MUSTG5 118.0 230KV'	150	-0.08794	SPS	'CZ 69KV'	39	0.04285	-0.13079	68
SPS	MUSTG5 118.0 230KV'	150	-0.08794	SPS	'HARRINGTON 230KV'	1066	0.04102	-0.12896	69
SPS	MUSTG5 118.0 230KV'	150	-0.08794	SPS	'MOORE COUNTY 115KV'	48	0.04003	-0.12797	69
SPS	MUSTG5 118.0 230KV'	150	-0.08794	SPS	'NICHOLS 230KV'	147	0.04104	-0.12898	69
SPS	JONES 230KV'	243	-0.06704	SPS	'NICHOLS 115KV'	147	0.05132	-0.11836	75
SPS	LP-BRND2 69KV'	152	-0.06598	SPS	'NICHOLS 115KV'	147	0.05132	-0.1173	75
SPS	JONES 230KV'	243	-0.06704	SPS	'CZ 69KV'	39	0.04285	-0.10989	80
SPS	JONES 230KV'	243	-0.06704	SPS	'BLACKHAWK 115KV'	220	0.04264	-0.10968	81
SPS	LP-BRND2 69KV'	152	-0.06598	SPS	'BLACKHAWK 115KV'	220	0.04264	-0.10862	81
SPS	LP-BRND2 69KV'	152	-0.06598	SPS	'CZ 69KV'	39	0.04285	-0.10883	81
SPS	JONES 230KV'	243	-0.06704	SPS	'HARRINGTON 230KV'	1066	0.04102	-0.10806	82
SPS	JONES 230KV'	243	-0.06704	SPS	'NICHOLS 230KV'	147	0.04104	-0.10808	82
SPS	JONES 230KV'	243	-0.06704	SPS	'MOORE COUNTY 115KV'	48	0.04003	-0.10707	83
SPS	LP-BRND2 69KV'	152	-0.06598	SPS	'HARRINGTON 230KV'	1066	0.04102	-0.107	83
SPS	LP-BRND2 69KV'	152	-0.06598	SPS	'MOORE COUNTY 115KV'	48	0.04003	-0.10601	83
SPS	LP-BRND2 69KV'	152	-0.06598	SPS	'NICHOLS 230KV'	147	0.04104	-0.10702	83
SPS	TOLK 230KV'	588,766	-0.09797	SPS	'JONES 230KV'	486	-0.06704	-0.03093	286
SPS	TOLK 345KV'	540	-0.09753	SPS	'JONES 230KV'	486	-0.06704	-0.03049	290

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

CURRY COUNTY INTERCHANGE -  
 ROOSEVELT COUNTY INTERCHANGE 115KV  
 CKT 2 & ROOSEVELT COUNTY  
 INTERCHANGE 230/115KV TRANSFORMER  
 CKT 1 & Potter - Roosevelt 345KV  
 Upgrade:  
 Limiting Facility:  
 Direction:  
 Line Outage:  
 Flowgate:  
 Date Redispatch Needed:  
 Season Flowgate Identified:

Reservation	Relief Amount	Aggregate Relief Amount
1090680	0.6	1.0
1090695	0.4	1.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'BLACKHAWK 115KV'	220	0.04241	-0.16884	6
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'CZ 69KV'	39	0.04251	-0.16894	6
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'HARRINGTON 230KV'	1066	0.04079	-0.16722	6
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'HUBRCO2 69KV'	11	0.04268	-0.16911	6
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'MOORE COUNTY 115KV'	48	0.03981	-0.16624	6
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'NICHOLS 115KV'	147	0.05107	-0.1775	6
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'NICHOLS 230KV'	147	0.04081	-0.16724	6
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'SIDRCH 69KV'	20	0.04268	-0.16911	6
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'STEER WATER 115KV'	8	0.04689	-0.17332	6
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'WILWIND 230KV'	16	0.03873	-0.16516	6
SPS	CARLSBAD 69KV'	18	-0.09297	SPS	'BLACKHAWK 115KV'	220	0.04241	-0.13538	7
SPS	CARLSBAD 69KV'	18	-0.09297	SPS	'CZ 69KV'	39	0.04251	-0.13548	7
SPS	CARLSBAD 69KV'	18	-0.09297	SPS	'HARRINGTON 230KV'	1066	0.04079	-0.13376	7
SPS	CARLSBAD 69KV'	18	-0.09297	SPS	'HUBRCO2 69KV'	11	0.04268	-0.13565	7
SPS	CARLSBAD 69KV'	18	-0.09297	SPS	'MOORE COUNTY 115KV'	48	0.03981	-0.13278	7
SPS	CARLSBAD 69KV'	18	-0.09297	SPS	'NICHOLS 115KV'	147	0.05107	-0.14404	7
SPS	CARLSBAD 69KV'	18	-0.09297	SPS	'NICHOLS 230KV'	147	0.04081	-0.13378	7
SPS	CARLSBAD 69KV'	18	-0.09297	SPS	'SIDRCH 69KV'	20	0.04268	-0.13565	7
SPS	CARLSBAD 69KV'	18	-0.09297	SPS	'STEER WATER 115KV'	8	0.04689	-0.13986	7
SPS	CARLSBAD 69KV'	18	-0.09297	SPS	'WILWIND 230KV'	16	0.03873	-0.1317	7
SPS	MADOX 115KV'	10	-0.08927	SPS	'BLACKHAWK 115KV'	220	0.04241	-0.13168	7
SPS	MADOX 115KV'	10	-0.08927	SPS	'CZ 69KV'	39	0.04251	-0.13178	7
SPS	MADOX 115KV'	10	-0.08927	SPS	'HUBRCO2 69KV'	11	0.04268	-0.13195	7
SPS	MADOX 115KV'	10	-0.08927	SPS	'NICHOLS 115KV'	147	0.05107	-0.14034	7
SPS	MADOX 115KV'	10	-0.08927	SPS	'SIDRCH 69KV'	20	0.04268	-0.13195	7
SPS	MADOX 115KV'	10	-0.08927	SPS	'STEER WATER 115KV'	8	0.04689	-0.13616	7
SPS	MUSTG5 118.0 230KV'	150	-0.08785	SPS	'BLACKHAWK 115KV'	220	0.04241	-0.13026	7
SPS	MUSTG5 118.0 230KV'	150	-0.08785	SPS	'CZ 69KV'	39	0.04251	-0.13036	7
SPS	MUSTG5 118.0 230KV'	150	-0.08785	SPS	'HUBRCO2 69KV'	11	0.04268	-0.13053	7
SPS	MUSTG5 118.0 230KV'	150	-0.08785	SPS	'NICHOLS 115KV'	147	0.05107	-0.13892	7
SPS	MUSTG5 118.0 230KV'	150	-0.08785	SPS	'SIDRCH 69KV'	20	0.04268	-0.13053	7
SPS	MUSTG5 118.0 230KV'	150	-0.08785	SPS	'STEER WATER 115KV'	8	0.04689	-0.13474	7
SPS	TOLK 230KV'	589,3699	-0.09797	SPS	'BLACKHAWK 115KV'	220	0.04241	-0.14038	7
SPS	TOLK 230KV'	589,3699	-0.09797	SPS	'CZ 69KV'	39	0.04251	-0.14048	7
SPS	TOLK 230KV'	589,3699	-0.09797	SPS	'HARRINGTON 230KV'	1066	0.04079	-0.13876	7
SPS	TOLK 230KV'	589,3699	-0.09797	SPS	'HUBRCO2 69KV'	11	0.04268	-0.14065	7
SPS	TOLK 230KV'	589,3699	-0.09797	SPS	'MOORE COUNTY 115KV'	48	0.03981	-0.13778	7
SPS	TOLK 230KV'	589,3699	-0.09797	SPS	'NICHOLS 115KV'	147	0.05107	-0.14904	7
SPS	TOLK 230KV'	589,3699	-0.09797	SPS	'NICHOLS 230KV'	147	0.04081	-0.13878	7
SPS	TOLK 230KV'	589,3699	-0.09797	SPS	'SIDRCH 69KV'	20	0.04268	-0.14065	7
SPS	TOLK 230KV'	589,3699	-0.09797	SPS	'STEER WATER 115KV'	8	0.04689	-0.14486	7
SPS	TOLK 230KV'	589,3699	-0.09797	SPS	'WILWIND 230KV'	16	0.03873	-0.1367	7
SPS	TOLK 345KV'	540	-0.09751	SPS	'BLACKHAWK 115KV'	220	0.04241	-0.13992	7
SPS	TOLK 345KV'	540	-0.09751	SPS	'CZ 69KV'	39	0.04251	-0.14002	7
SPS	TOLK 345KV'	540	-0.09751	SPS	'HARRINGTON 230KV'	1066	0.04079	-0.1383	7
SPS	TOLK 345KV'	540	-0.09751	SPS	'HUBRCO2 69KV'	11	0.04268	-0.14019	7
SPS	TOLK 345KV'	540	-0.09751	SPS	'MOORE COUNTY 115KV'	48	0.03981	-0.13732	7
SPS	TOLK 345KV'	540	-0.09751	SPS	'NICHOLS 115KV'	147	0.05107	-0.14858	7
SPS	TOLK 345KV'	540	-0.09751	SPS	'NICHOLS 230KV'	147	0.04081	-0.13832	7
SPS	TOLK 345KV'	540	-0.09751	SPS	'SIDRCH 69KV'	20	0.04268	-0.14019	7
SPS	TOLK 345KV'	540	-0.09751	SPS	'STEER WATER 115KV'	8	0.04689	-0.1444	7

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	TOLK 345KV'	540	-0.09751	SPS	'WILWIND 230KV'	16	0.03873	-0.13624	7
SPS	JONES 230KV'	243	-0.06688	SPS	'NICHOLS 115KV'	147	0.05107	-0.11795	8
SPS	LP-BRND2 69KV'	110.0703	-0.06585	SPS	'NICHOLS 115KV'	147	0.05107	-0.11692	8
SPS	MADOX 115KV'	10	-0.08927	SPS	'HARRINGTON 230KV'	1066	0.04079	-0.13006	8
SPS	MADOX 115KV'	10	-0.08927	SPS	'MOORE COUNTY 115KV'	48	0.03981	-0.12908	8
SPS	MADOX 115KV'	10	-0.08927	SPS	'NICHOLS 230KV'	147	0.04081	-0.13008	8
SPS	MADOX 115KV'	10	-0.08927	SPS	'WILWIND 230KV'	16	0.03873	-0.128	8
SPS	MUSTG5 118.0 230KV'	150	-0.08785	SPS	'HARRINGTON 230KV'	1066	0.04079	-0.12864	8
SPS	MUSTG5 118.0 230KV'	150	-0.08785	SPS	'MOORE COUNTY 115KV'	48	0.03981	-0.12766	8
SPS	MUSTG5 118.0 230KV'	150	-0.08785	SPS	'NICHOLS 230KV'	147	0.04081	-0.12866	8
SPS	MUSTG5 118.0 230KV'	150	-0.08785	SPS	'WILWIND 230KV'	16	0.03873	-0.12658	8
SPS	JONES 230KV'	243	-0.06688	SPS	'BLACKHAWK 115KV'	220	0.04241	-0.10929	9
SPS	JONES 230KV'	243	-0.06688	SPS	'CZ 69KV'	39	0.04251	-0.10939	9
SPS	JONES 230KV'	243	-0.06688	SPS	'HARRINGTON 230KV'	1066	0.04079	-0.10767	9
SPS	JONES 230KV'	243	-0.06688	SPS	'HUBRCO2 69KV'	11	0.04268	-0.10956	9
SPS	JONES 230KV'	243	-0.06688	SPS	'MOORE COUNTY 115KV'	48	0.03981	-0.10669	9
SPS	JONES 230KV'	243	-0.06688	SPS	'NICHOLS 230KV'	147	0.04081	-0.10769	9
SPS	JONES 230KV'	243	-0.06688	SPS	'SIDRCH 69KV'	20	0.04268	-0.10956	9
SPS	JONES 230KV'	243	-0.06688	SPS	'STEER WATER 115KV'	8	0.04689	-0.11377	9
SPS	JONES 230KV'	243	-0.06688	SPS	'WILWIND 230KV'	16	0.03873	-0.10561	9
SPS	LP-BRND2 69KV'	110.0703	-0.06585	SPS	'BLACKHAWK 115KV'	220	0.04241	-0.10826	9
SPS	LP-BRND2 69KV'	110.0703	-0.06585	SPS	'CZ 69KV'	39	0.04251	-0.10836	9
SPS	LP-BRND2 69KV'	110.0703	-0.06585	SPS	'HARRINGTON 230KV'	1066	0.04079	-0.10664	9
SPS	LP-BRND2 69KV'	110.0703	-0.06585	SPS	'HUBRCO2 69KV'	11	0.04268	-0.10853	9
SPS	LP-BRND2 69KV'	110.0703	-0.06585	SPS	'MOORE COUNTY 115KV'	48	0.03981	-0.10666	9
SPS	LP-BRND2 69KV'	110.0703	-0.06585	SPS	'NICHOLS 230KV'	147	0.04081	-0.10666	9
SPS	LP-BRND2 69KV'	110.0703	-0.06585	SPS	'SIDRCH 69KV'	20	0.04268	-0.10853	9
SPS	LP-BRND2 69KV'	110.0703	-0.06585	SPS	'STEER WATER 115KV'	8	0.04689	-0.11274	9
SPS	LP-BRND2 69KV'	110.0703	-0.06585	SPS	'WILWIND 230KV'	16	0.03873	-0.10458	9
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'JONES 230KV'	486	-0.06688	-0.05955	16
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'LP-BRND2 69KV'	121.9297	-0.06585	-0.06058	16
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'MUSTANG 115KV'	300	-0.08866	-0.03957	25
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'MUSTG5 118.0 230KV'	310	-0.08785	-0.03858	25
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'CUNNINGHAM 115KV'	110	-0.08939	-0.03704	26
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'CUNNINGHAM 115KV'	71	-0.08939	-0.03704	26
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'MADOX 115KV'	183	-0.08927	-0.03716	26
SPS	TUCUMCARI 115KV'	15	-0.12643	SPS	'CUNNINGHAM 230KV'	306	-0.08998	-0.03645	27
SPS	TOLK 230KV'	589.3699	-0.09797	SPS	'LP-BRND2 69KV'	121.9297	-0.06585	-0.03212	30
SPS	TOLK 230KV'	589.3699	-0.09797	SPS	'JONES 230KV'	486	-0.06688	-0.03109	31
SPS	TOLK 345KV'	540	-0.09751	SPS	'LP-BRND2 69KV'	121.9297	-0.06585	-0.03166	31
SPS	TOLK 345KV'	540	-0.09751	SPS	'JONES 230KV'	486	-0.06688	-0.03063	32

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

CURRY COUNTY INTERCHANGE -  
ROOSEVELT COUNTY INTERCHANGE 115KV  
CKT 2 & ROOSEVELT COUNTY  
INTERCHANGE 230V/115KV TRANSFORMER  
CKT 1 & Potter - Roosevelt 345KV

Upgrade:  
Limiting Facility: CANYON EAST - CANYON WEST 115KV CKT 1  
Direction: From->To  
Line Outage: BUSHLAND INTERCHANGE - DEAF SMITH INTERCHANGE 230KV CKT 1  
Flowgate: 5108051078150993511114407AP  
Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount
1090301	0.3	1.8
1090680	0.9	1.8
1090695	0.6	1.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	TUCUMCARI 115KV'	15	-0.12636	SPS	'STEER WATER 115KV'	36	0.04732	-0.17368	10
SPS	TUCUMCARI 115KV'	15	-0.12636	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.16912	11
SPS	TUCUMCARI 115KV'	15	-0.12636	SPS	'CZ 69KV'	35	0.04297	-0.16933	11
SPS	TUCUMCARI 115KV'	15	-0.12636	SPS	'HARRINGTON 230KV'	706	0.04113	-0.16749	11
SPS	TUCUMCARI 115KV'	15	-0.12636	SPS	'HUBRCO2 69KV'	5	0.04303	-0.16939	11
SPS	TUCUMCARI 115KV'	15	-0.12636	SPS	'SIDRCH 69KV'	14	0.04303	-0.16939	11
SPS	TUCUMCARI 115KV'	15	-0.12636	SPS	'WILWIND 230KV'	72	0.03907	-0.16543	11
SPS	PLANTX 115KV'	253	-0.10435	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.14711	12
SPS	PLANTX 115KV'	253	-0.10435	SPS	'CZ 69KV'	35	0.04297	-0.14732	12
SPS	PLANTX 115KV'	253	-0.10435	SPS	'HUBRCO2 69KV'	5	0.04303	-0.14738	12
SPS	PLANTX 115KV'	253	-0.10435	SPS	'SIDRCH 69KV'	14	0.04303	-0.14738	12
SPS	PLANTX 115KV'	253	-0.10435	SPS	'STEER WATER 115KV'	36	0.04732	-0.15167	12
SPS	PLANTX 230KV'	189	-0.10013	SPS	'STEER WATER 115KV'	36	0.04732	-0.14745	12
SPS	CARLSBAD 69KV'	18	-0.09296	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13572	13
SPS	CARLSBAD 69KV'	18	-0.09296	SPS	'CZ 69KV'	35	0.04297	-0.13593	13
SPS	CARLSBAD 69KV'	18	-0.09296	SPS	'HUBRCO2 69KV'	5	0.04303	-0.13599	13
SPS	CARLSBAD 69KV'	18	-0.09296	SPS	'SIDRCH 69KV'	14	0.04303	-0.13599	13
SPS	CARLSBAD 69KV'	18	-0.09296	SPS	'STEER WATER 115KV'	36	0.04732	-0.14028	13
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'STEER WATER 115KV'	36	0.04732	-0.13672	13
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'STEER WATER 115KV'	36	0.04732	-0.13672	13
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'STEER WATER 115KV'	36	0.04732	-0.1373	13
SPS	MADOX 115KV'	193	-0.08928	SPS	'STEER WATER 115KV'	36	0.04732	-0.1366	13
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'STEER WATER 115KV'	36	0.04732	-0.13519	13
SPS	PLANTX 115KV'	253	-0.10435	SPS	'HARRINGTON 230KV'	706	0.04113	-0.14548	13
SPS	PLANTX 115KV'	253	-0.10435	SPS	'WILWIND 230KV'	72	0.03907	-0.14342	13
SPS	PLANTX 230KV'	189	-0.10013	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.14289	13
SPS	PLANTX 230KV'	189	-0.10013	SPS	'CZ 69KV'	35	0.04297	-0.1431	13
SPS	PLANTX 230KV'	189	-0.10013	SPS	'HARRINGTON 230KV'	706	0.04113	-0.14126	13
SPS	PLANTX 230KV'	189	-0.10013	SPS	'HUBRCO2 69KV'	5	0.04303	-0.14316	13
SPS	PLANTX 230KV'	189	-0.10013	SPS	'SIDRCH 69KV'	14	0.04303	-0.14316	13
SPS	PLANTX 230KV'	189	-0.10013	SPS	'WILWIND 230KV'	72	0.03907	-0.1392	13
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.14066	13
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'CZ 69KV'	35	0.04297	-0.14087	13
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13903	13
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'HUBRCO2 69KV'	5	0.04303	-0.14093	13
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'SIDRCH 69KV'	14	0.04303	-0.14093	13
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'STEER WATER 115KV'	36	0.04732	-0.14522	13
SPS	TOLK 230KV'	595.2405	-0.0979	SPS	'WILWIND 230KV'	72	0.03907	-0.13697	13
SPS	TOLK 345KV'	540	-0.09745	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.14021	13
SPS	TOLK 345KV'	540	-0.09745	SPS	'CZ 69KV'	35	0.04297	-0.14042	13
SPS	TOLK 345KV'	540	-0.09745	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13858	13

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	TOLK 345KV'	540	-0.09745	SPS	HUBRCO2 69KV'	5	0.04303	-0.14048	13
SPS	TOLK 345KV'	540	-0.09745	SPS	'SIDRCH 69KV'	14	0.04303	-0.14048	13
SPS	TOLK 345KV'	540	-0.09745	SPS	'STEER WATER 115KV'	36	0.04732	-0.14477	13
SPS	TOLK 345KV'	540	-0.09745	SPS	'WILWIND 230KV'	72	0.03907	-0.13652	13
SPS	CARLSBAD 69KV'	18	-0.09296	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13409	14
SPS	CARLSBAD 69KV'	18	-0.09296	SPS	'CZ 69KV'	72	0.03907	-0.13203	14
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13216	14
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13216	14
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'CZ 69KV'	35	0.04297	-0.13237	14
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'CZ 69KV'	35	0.04297	-0.13237	14
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13053	14
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13053	14
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'HUBRCO2 69KV'	5	0.04303	-0.13243	14
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'HUBRCO2 69KV'	5	0.04303	-0.13243	14
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'SIDRCH 69KV'	14	0.04303	-0.13243	14
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'SIDRCH 69KV'	14	0.04303	-0.13243	14
SPS	CUNNINGHAM 115KV'	71	-0.0894	SPS	'WILWIND 230KV'	72	0.03907	-0.12847	14
SPS	CUNNINGHAM 115KV'	110	-0.0894	SPS	'WILWIND 230KV'	72	0.03907	-0.12847	14
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13274	14
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'CZ 69KV'	35	0.04297	-0.13295	14
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13111	14
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'HUBRCO2 69KV'	5	0.04303	-0.13301	14
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'SIDRCH 69KV'	14	0.04303	-0.13301	14
SPS	CUNNINGHAM 230KV'	250	-0.08998	SPS	'WILWIND 230KV'	72	0.03907	-0.12905	14
SPS	MADOX 115KV'	193	-0.08928	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13204	14
SPS	MADOX 115KV'	193	-0.08928	SPS	'CZ 69KV'	35	0.04297	-0.13225	14
SPS	MADOX 115KV'	193	-0.08928	SPS	'HARRINGTON 230KV'	706	0.04113	-0.13041	14
SPS	MADOX 115KV'	193	-0.08928	SPS	'HUBRCO2 69KV'	5	0.04303	-0.13231	14
SPS	MADOX 115KV'	193	-0.08928	SPS	'SIDRCH 69KV'	14	0.04303	-0.13231	14
SPS	MADOX 115KV'	193	-0.08928	SPS	'WILWIND 230KV'	72	0.03907	-0.12835	14
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.12965	14
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'CZ 69KV'	35	0.04297	-0.12986	14
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'HARRINGTON 230KV'	706	0.04113	-0.12802	14
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'HUBRCO2 69KV'	5	0.04303	-0.12992	14
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'SIDRCH 69KV'	14	0.04303	-0.12992	14
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'STEER WATER 115KV'	36	0.04732	-0.13421	14
SPS	MUSTANG 115KV'	81.8074	-0.08689	SPS	'WILWIND 230KV'	72	0.03907	-0.12596	14
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.13063	14
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'CZ 69KV'	35	0.04297	-0.13084	14
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'HARRINGTON 230KV'	706	0.04113	-0.129	14
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'HUBRCO2 69KV'	5	0.04303	-0.1309	14
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'SIDRCH 69KV'	14	0.04303	-0.1309	14
SPS	MUSTG5 118.0 230KV'	385	-0.08787	SPS	'WILWIND 230KV'	72	0.03907	-0.12694	14
SPS	JONES 230KV'	625	-0.06697	SPS	'STEER WATER 115KV'	36	0.04732	-0.11429	16
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'STEER WATER 115KV'	36	0.04732	-0.11324	16
SPS	JONES 230KV'	625	-0.06697	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.10973	17
SPS	JONES 230KV'	625	-0.06697	SPS	'CZ 69KV'	35	0.04297	-0.10994	17
SPS	JONES 230KV'	625	-0.06697	SPS	'HARRINGTON 230KV'	706	0.04113	-0.1081	17
SPS	JONES 230KV'	625	-0.06697	SPS	'SIDRCH 69KV'	14	0.04303	-0.11	17
SPS	JONES 230KV'	625	-0.06697	SPS	'WILWIND 230KV'	72	0.03907	-0.10604	17
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'BLACKHAWK 115KV'	220	0.04276	-0.10868	17
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'CZ 69KV'	35	0.04297	-0.10889	17
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'HARRINGTON 230KV'	706	0.04113	-0.10705	17
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'SIDRCH 69KV'	14	0.04303	-0.10895	17
SPS	LP-BRND2 69KV'	172	-0.06592	SPS	'WILWIND 230KV'	72	0.03907	-0.10499	17
SPS	TUCUMCARI 115KV'	15	-0.12636	SPS	'LP-BRND2 69KV'	60	-0.06592	-0.06044	30
SPS	TUCUMCARI 115KV'	15	-0.12636	SPS	'JONES 230KV'	104	-0.06697	-0.05939	31
SPS	PLANTX 115KV'	253	-0.10435	SPS	'LP-BRND2 69KV'	60	-0.06592	-0.03843	47
SPS	PLANTX 115KV'	253	-0.10435	SPS	'JONES 230KV'	104	-0.06697	-0.03738	49

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

CURRY COUNTY INTERCHANGE -  
ROOSEVELT COUNTY INTERCHANGE 115KV  
CKT 2 & ROOSEVELT COUNTY  
INTERCHANGE 230/115KV TRANSFORMER  
CKT 1 & Potter - Roosevelt 345KV

Upgrade:  
Limiting Facility: POTTER COUNTY INTERCHANGE (POTTR CO) 345-230-13.2KV TRANSFORMER CKT 1  
Direction: From->To  
Line Outage: GEN:51442 1  
Flowgate: POTTTRCO2761GEN5144214407G  
Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount
1040980	0.7	14.0
1087085	0.1	14.0
1090270	0.2	14.0
1090454	0.1	14.0
1090609	0.1	14.0
1090613	0.2	14.0
1090662	0.1	14.0
1090680	2.5	14.0
1090695	1.4	14.0
1090699	4.2	14.0
1090705	4.2	14.0
1090767	0.2	14.0
1090789	0.2	14.0
1090808	0.1	14.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WEPL	CLIFTON 115KV'	70	0.04649	WEPL	'JUDSON LARGE 115KV'	77.8153	0.15286	-0.10637	132
WERE	'NEOSHO ENERGY CENTER 138KV'	67	-0.00409	WERE	'HUTCHINSON ENERGY CENTER 115KV'	120	0.07733	-0.08142	173
WERE	'LATHAM1234.0 345KV'	150	0.00033	WERE	'HUTCHINSON ENERGY CENTER 115KV'	120	0.07733	-0.077	182
WERE	'EVANS ENERGY CENTER 138KV'	313	0.00129	WERE	'HUTCHINSON ENERGY CENTER 115KV'	120	0.07733	-0.07604	185
WERE	'GILL ENERGY CENTER 69KV'	118	0.00317	WERE	'HUTCHINSON ENERGY CENTER 115KV'	120	0.07733	-0.07416	189
WERE	'NEOSHO ENERGY CENTER 138KV'	67	-0.00409	WERE	'BPU - CITY OF MCPHERSON 115KV'	127.0369	0.06835	-0.07244	194
WERE	'LATHAM1234.0 345KV'	150	0.00033	WERE	'BPU - CITY OF MCPHERSON 115KV'	127.0369	0.06835	-0.06802	207
WERE	'EVANS ENERGY CENTER 138KV'	313	0.00129	WERE	'BPU - CITY OF MCPHERSON 115KV'	127.0369	0.06835	-0.06706	209
SPS	'HARRINGTON 230KV'	360	-0.33164	SPS	'LP-BRND2 69KV'	80	-0.26507	-0.06657	211
AEPW	'SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	'FLINT CREEK 161KV'	400	-0.01434	-0.06665	211
AEPW	'SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	'FLINT CREEK 161KV'	400	-0.01434	-0.06665	211
AEPW	'SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	'FITZHUGH 161KV'	79	-0.01504	-0.06595	213

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	FITZHUGH 161KV'	79	-0.01504	-0.06595	213
SPS	HARRINGTON 230KV'	360	-0.33164	SPS	JONES 230KV'	486	-0.26592	-0.06572	214
SPS	NICHOLS 230KV'	191.4756	-0.3304	SPS	LP-BRNDZ 69KV'	80	-0.26507	-0.06533	215
WERE	GILL ENERGY CENTER 69KV'	118	0.00317	WERE	BPU - CITY OF MCPHERSON 115KV'	127.0369	0.06835	-0.06518	216
SPS	NICHOLS 230KV'	191.4756	-0.3304	SPS	JONES 230KV'	486	-0.26592	-0.06448	218
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	NORTHEASTERN STATION 345KV'	550	-0.01757	-0.06342	221
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	NORTHEASTERN STATION 345KV'	550	-0.01757	-0.06342	221
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	NORTHEASTERN STATION 138KV'	95	-0.01877	-0.06222	226
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	NORTHEASTERN STATION 138KV'	304	-0.01877	-0.06222	226
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	NORTHEASTERN STATION 138KV'	304	-0.01877	-0.06222	226
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	NORTHEASTERN STATION 138KV'	95	-0.01877	-0.06222	226
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	EASTMAN 138KV'	355	-0.02046	-0.06053	232
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	EASTMAN 138KV'	355	-0.02046	-0.06053	232
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	LEBROCK 345KV'	515	-0.02042	-0.06057	232
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	LEBROCK 345KV'	515	-0.02042	-0.06057	232
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	LEBROCK 345KV'	440	-0.02039	-0.0606	232
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	LEBROCK 345KV'	440	-0.02039	-0.0606	232
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	PIRKEY GENERATION 138KV'	440	-0.02039	-0.0606	232
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	PIRKEY GENERATION 138KV'	440	-0.02039	-0.0606	232
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	WILKES 345KV'	143.5563	-0.02081	-0.06018	233
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	WILKES 345KV'	143.5563	-0.02081	-0.06018	233
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	OEC 345KV'	219	-0.02278	-0.05821	241
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	OEC 345KV'	219	-0.02278	-0.05821	241
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	WELSH 345KV'	1012	-0.0226	-0.05839	241
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	WELSH 345KV'	1012	-0.0226	-0.05839	241
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	RIVERSIDE STATION 138KV'	250	-0.02449	-0.0565	249
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	RIVERSIDE STATION 138KV'	250	-0.02449	-0.0565	249
SPS	NICHOLS 115KV'	107	-0.32208	SPS	JONES 230KV'	486	-0.26592	-0.05616	250
AEPW	SOUTHWESTERN STATION 138KV'	337	-0.08099	AEPW	COGENTRIX 345KV'	200	-0.02575	-0.05524	254
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08099	AEPW	COGENTRIX 345KV'	200	-0.02575	-0.05524	254
SPS	HARRINGTON 230KV'	360	-0.33164	SPS	MUSTANG 115KV'	300	-0.28067	-0.05097	276
WERE	TECUMSEH ENERGY CENTER 115KV'	123	0.02651	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	0.07733	-0.05082	276
SPS	HARRINGTON 230KV'	360	-0.33164	SPS	MUSTG5 118.0 230KV'	160	-0.28147	-0.05017	280
SPS	NICHOLS 230KV'	191.4756	-0.3304	SPS	MUSTANG 115KV'	300	-0.28067	-0.04973	282
SPS	HARRINGTON 230KV'	360	-0.33164	SPS	MADDOX 115KV'	118	-0.28203	-0.04961	283
SPS	HARRINGTON 230KV'	360	-0.33164	SPS	CUNNINGHAM 115KV'	110	-0.2821	-0.04954	284
SPS	HARRINGTON 230KV'	360	-0.33164	SPS	CUNNINGHAM 230KV'	306	-0.28244	-0.0492	286
SPS	NICHOLS 230KV'	191.4756	-0.3304	SPS	MUSTG5 118.0 230KV'	160	-0.28147	-0.04893	287
SPS	NICHOLS 230KV'	191.4756	-0.3304	SPS	MADDOX 115KV'	118	-0.28203	-0.04837	290
SPS	NICHOLS 230KV'	191.4756	-0.3304	SPS	CUNNINGHAM 115KV'	110	-0.2821	-0.0483	291
SPS	NICHOLS 230KV'	191.4756	-0.3304	SPS	CUNNINGHAM 230KV'	306	-0.28244	-0.04796	293
WFEC	BLUCAN14 138 138KV'	151.2	-0.0814	WFEC	HUGO 138KV'	450	-0.03635	-0.04505	312
SPS	HARRINGTON 230KV'	360	-0.33164	SPS	TOLK 230KV'	1022.238	-0.28913	-0.04251	330
WERE	TECUMSEH ENERGY CENTER 115KV'	123	0.02651	WERE	BPU - CITY OF MCPHERSON 115KV'	127.0369	0.06835	-0.04184	336
SPS	NICHOLS 230KV'	191.4756	-0.3304	SPS	TOLK 230KV'	1022.238	-0.28913	-0.04127	340
SPS	HARRINGTON 230KV'	360	-0.33164	SPS	PLANTX 115KV'	205	-0.29122	-0.04042	348
SPS	NICHOLS 230KV'	191.4756	-0.3304	SPS	PLANTX 115KV'	205	-0.29122	-0.03918	359
SPS	HARRINGTON 230KV'	360	-0.33164	SPS	PLANTX 230KV'	189	-0.29259	-0.03905	360
WFEC	MORLND 138KV'	320	-0.07476	WFEC	HUGO 138KV'	450	-0.03635	-0.03841	366
SPS	NICHOLS 230KV'	191.4756	-0.3304	SPS	PLANTX 230KV'	189	-0.29259	-0.03781	372
OKGE	MUSTANG 138KV'	365.5	-0.04936	OKGE	AES 161KV'	280	-0.01722	-0.03214	437
OKGE	SEMINOLE 138KV'	354.5783	-0.04736	OKGE	AES 161KV'	280	-0.01722	-0.03014	466

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

CURRY COUNTY INTERCHANGE -  
ROOSEVELT COUNTY INTERCHANGE 115KV  
CKT 2 & ROOSEVELT COUNTY  
INTERCHANGE 230/115KV TRANSFORMER  
CKT 1 & Potter - Roosevelt 345KV

Upgrade:  
Limiting Facility:  
Direction:  
Line Outage:  
Flowgate:  
Date Redispatch Needed:  
Season Flowgate Identified:

Reservation	Relief Amount	Aggregate Relief Amount
1040980	1.4	21.2
1087085	0.1	21.2
1090270	0.4	21.2
1090454	0.1	21.2
1090613	0.4	21.2
1090662	0.2	21.2
1090680	3.4	21.2
1090695	1.9	21.2
1090699	5.8	21.2
1090705	5.8	21.2
1090767	0.4	21.2
1090789	0.2	21.2
1090808	0.1	21.2
1103355	0.8	21.2
1103357	0.4	21.2

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	LATHAM1234.0 345KV'	150	0.00018	WERE	HUTCHINSON ENERGY CENTER 115KV'	210	0.07544	-0.07526	281
WERE	LATHAM1234.0 345KV'	150	0.00018	WERE	BPU - CITY OF MCPHERSON 115KV'	135	0.06784	-0.06766	313
AEPW	SOUTHWESTERN STATION 138KV'	151	-0.08128	AEPW	FLINT CREEK 161KV'	420	-0.0147	-0.06658	318
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08128	AEPW	FLINT CREEK 161KV'	420	-0.0147	-0.06658	318
AEPW	SOUTHWESTERN STATION 138KV'	151	-0.08128	AEPW	FITZHUGH 161KV'	126	-0.015	-0.06628	319
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08128	AEPW	FITZHUGH 161KV'	126	-0.015	-0.06628	319
AEPW	SOUTHWESTERN STATION 138KV'	151	-0.08128	AEPW	NORTHEASTERN STATION 345KV'	645	-0.01811	-0.06317	335
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08128	AEPW	NORTHEASTERN STATION 345KV'	645	-0.01811	-0.06317	335
AEPW	SOUTHWESTERN STATION 138KV'	151	-0.08128	AEPW	NORTHEASTERN STATION 138KV'	405	-0.01943	-0.06185	342
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08128	AEPW	NORTHEASTERN STATION 138KV'	405	-0.01943	-0.06185	342
AEPW	SOUTHWESTERN STATION 138KV'	151	-0.08128	AEPW	KNOXLEE 138KV'	225	-0.0203	-0.06098	347
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08128	AEPW	KNOXLEE 138KV'	225	-0.0203	-0.06098	347
AEPW	SOUTHWESTERN STATION 138KV'	151	-0.08128	AEPW	EASTMAN 138KV'	355	-0.02044	-0.06084	348
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08128	AEPW	EASTMAN 138KV'	355	-0.02044	-0.06084	348
AEPW	SOUTHWESTERN STATION 138KV'	151	-0.08128	AEPW	LEBROCK 345KV'	515	-0.0204	-0.06088	348
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08128	AEPW	LEBROCK 345KV'	515	-0.0204	-0.06088	348
AEPW	SOUTHWESTERN STATION 138KV'	151	-0.08128	AEPW	PIRKEY GENERATION 138KV'	475	-0.02036	-0.06092	348
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08128	AEPW	PIRKEY GENERATION 138KV'	475	-0.02036	-0.06092	348
AEPW	SOUTHWESTERN STATION 138KV'	151	-0.08128	AEPW	WILKES 345KV'	311	-0.02077	-0.06051	350
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.08128	AEPW	WILKES 345KV'	311	-0.02077	-0.06051	350

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	SOUTHWESTERN STATION 138KV	151	-0.08128	AEPW	WILKES 138KV	319.9135	-0.02108	-0.0602	352
AEPW	SOUTHWESTERN STATION 138KV	336	-0.08128	AEPW	WILKES 138KV	319.9135	-0.02108	-0.0602	352
AEPW	SOUTHWESTERN STATION 138KV	151	-0.08128	AEPW	OEC 345KV	219	-0.02253	-0.05875	360
AEPW	SOUTHWESTERN STATION 138KV	336	-0.08128	AEPW	OEC 345KV	219	-0.02253	-0.05875	360
AEPW	SOUTHWESTERN STATION 138KV	151	-0.08128	AEPW	WELSH 345KV	990	-0.02257	-0.05871	361
AEPW	SOUTHWESTERN STATION 138KV	336	-0.08128	AEPW	WELSH 345KV	990	-0.02257	-0.05871	361
AEPW	SOUTHWESTERN STATION 138KV	151	-0.08128	AEPW	TULSA POWER STATION 138KV	124	-0.02407	-0.05721	370
AEPW	SOUTHWESTERN STATION 138KV	336	-0.08128	AEPW	TULSA POWER STATION 138KV	124	-0.02407	-0.05721	370
AEPW	SOUTHWESTERN STATION 138KV	151	-0.08128	AEPW	RIVERSIDE STATION 138KV	646	-0.02464	-0.05664	374
AEPW	SOUTHWESTERN STATION 138KV	336	-0.08128	AEPW	RIVERSIDE STATION 138KV	646	-0.02464	-0.05664	374
AEPW	SOUTHWESTERN STATION 138KV	151	-0.08128	AEPW	COGENTRIX 345KV	200	-0.02474	-0.05654	375
AEPW	SOUTHWESTERN STATION 138KV	336	-0.08128	AEPW	COGENTRIX 345KV	200	-0.02474	-0.05654	375

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

CURRY COUNTY INTERCHANGE -  
 ROOSEVELT COUNTY INTERCHANGE 115KV  
 CKT 2 & ROOSEVELT COUNTY  
 INTERCHANGE 230/115KV TRANSFORMER  
 CKT 1 & Potter - Roosevelt 345KV  
 Upgrade:  
 Limiting Facility: POTTER COUNTY INTERCHANGE (POTTR CO) 345-230-13.2KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51442 1  
 Flowgate: POTTTRCO2761GEN5144214408SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1040980	2.0	33.6
1087085	0.1	33.6
1089950	0.5	33.6
1090244	0.1	33.6
1090245	0.3	33.6
1090270	0.6	33.6
1090454	0.1	33.6
1090613	1.0	33.6
1090662	0.3	33.6
1090680	4.8	33.6
1090695	2.6	33.6
1090699	8.1	33.6
1090705	8.1	33.6
1090729	0.2	33.6
1090767	0.6	33.6
1090789	0.4	33.6
1090808	0.1	33.6
1090958	0.1	33.6
1091026	0.2	33.6
1091027	0.2	33.6
1091028	0.1	33.6
1091032	0.3	33.6
1091034	0.1	33.6
1091035	0.1	33.6
1091036	0.1	33.6
1091041	0.1	33.6
1091043	0.1	33.6
1091044	0.1	33.6
1091045	0.1	33.6
1091066	0.7	33.6
1103355	1.1	33.6
1103357	0.6	33.6

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
MIDW	LYONS 115KV	999	-0.00286	MIDW	KNOLL 3 115 115KV	117	0.10651	-0.10937	307
WERE	EVANS ENERGY CENTER 138KV	197	0.00131	WERE	HUTCHINSON ENERGY CENTER 115KV	191.4863	0.07606	-0.07475	450
AEPW	SOUTHWESTERN STATION 138KV	173	-0.08104	AEPW	FLINT CREEK 161KV	428	-0.01471	-0.06633	507

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1  
 FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1  
 Upgrade:  
 Limiting Facility:  
 Direction: From->To  
 Line Outage: SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1  
 Flowgate: 57236572771572715727711107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090729	0.9	1.2
1090808	0.2	1.2
1090823	0.1	1.2

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CHANUTE 69KV	31.077	0.00048	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.10248	12
WERE	CITY OF ERIE 69KV	4.255999	0.00048	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.10248	12
WERE	CITY OF FREDONIA 69KV	5.069	0.0013	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.10166	12
WERE	CITY OF GIRARD 69KV	5.911	-0.00003	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.10299	12
WERE	CITY OF IOLA 69KV	13.361	-0.00017	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.10313	12
WERE	CITY OF MULVANE 69KV	7.502	0.00563	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.09733	12
WERE	CITY OF NEODESHA 69KV	4.5	0.00125	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.10171	12
WERE	CITY OF WINFIELD 69KV	29.38998	0.00472	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.09824	12
WERE	EVANS ENERGY CENTER 138KV	8	0.00653	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.09643	12
WERE	GETTY 69KV	35	0.00625	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.09771	12
WERE	GILL ENERGY CENTER 69KV	8	0.006	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.09696	12
WERE	LATHAM1234.0 345KV	150	0.00368	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.09928	12
WERE	NEOSHO ENERGY CENTER 138KV	47	0.00077	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.10219	12
WERE	BROWN COUNTY 115KV	5.5	0.01127	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.09169	13
WERE	SOUTH SENECA 115KV	8.2	0.01206	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.0909	13
WERE	ST JOHN 115KV	7.5	0.01407	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.08889	13
WERE	BPU - CITY OF MCPHERSON 115KV	15.93311	0.01879	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.08417	14
WERE	HOLTON 115KV	7.6	0.01839	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.10296	-0.08457	14

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	HUTCHINSON ENERGY CENTER 115KV'	133	0.01797	WERE	LAWRENCE ENERGY CENTER 115KV'	105	0.10296	-0.08499	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	12	0.01796	WERE	LAWRENCE ENERGY CENTER 115KV'	105	0.10296	-0.085	14
WERE	JEFFREY ENERGY CENTER 345KV'	42	0.01969	WERE	LAWRENCE ENERGY CENTER 115KV'	105	0.10296	-0.08327	14
WERE	SMOKYHIL 230 230KV'	72	0.01847	WERE	LAWRENCE ENERGY CENTER 115KV'	105	0.10296	-0.08449	14
WERE	ABILENE ENERGY CENTER 115KV'	5.999996	0.0221	WERE	LAWRENCE ENERGY CENTER 115KV'	105	0.10296	-0.08086	15
WERE	CHANUTE 69KV'	31.077	0.00048	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.07711	15
WERE	CITY OF GIRARD 69KV'	5.911	-0.00003	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.07762	15
WERE	CITY OF IOLA 69KV'	13.361	-0.00017	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.07776	15
WERE	CLAY CENTER JUNCTION 115KV'	9.225	0.02333	WERE	LAWRENCE ENERGY CENTER 115KV'	105	0.10296	-0.07963	15
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.02219	WERE	LAWRENCE ENERGY CENTER 115KV'	105	0.10296	-0.08077	15
WERE	CITY OF OSAGE CITY 115KV'	8.85	0.029	WERE	LAWRENCE ENERGY CENTER 115KV'	105	0.10296	-0.07396	16
WERE	CITY OF WINFIELD 69KV'	29.38998	0.00472	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.07287	16
WERE	GETTY 69KV'	35	0.00525	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.07234	16
WERE	LATHAM1234.0 345KV'	150	0.00368	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.07391	16
WERE	NEOSHO ENERGY CENTER 138KV'	47	0.00077	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.07682	16
WERE	CITY OF MULVANE 69KV'	7.502	0.00563	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.07196	17
WERE	EVANS ENERGY CENTER 138KV'	8	0.00653	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.07106	17
WERE	GILL ENERGY CENTER 69KV'	8	0.006	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.07159	17
WERE	SOUTH SENECA 115KV'	8.2	0.01206	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.06553	18
WERE	ST JOHN 115KV'	7.5	0.01407	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.06352	19
WERE	TECUMSEH ENERGY CENTER 69KV'	41	0.03953	WERE	LAWRENCE ENERGY CENTER 115KV'	105	0.10296	-0.06343	19
WERE	BPU - CITY OF MCPHERSON 115KV'	15.93311	0.01879	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.0588	20
WERE	HOLTON 115KV'	7.6	0.01839	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.0592	20
WERE	HUTCHINSON ENERGY CENTER 115KV'	133	0.01797	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.05962	20
WERE	HUTCHINSON ENERGY CENTER 69KV'	12	0.01796	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.05963	20
WERE	SMOKYHIL 230 230KV'	72	0.01847	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.05912	20
WERE	JEFFREY ENERGY CENTER 345KV'	42	0.01969	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.0579	21
WERE	CLAY CENTER JUNCTION 115KV'	9.225	0.02333	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.05426	22
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.02219	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.0554	22
WERE	CITY OF OSAGE CITY 115KV'	8.85	0.029	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.04859	25
WERE	CHANUTE 69KV'	31.077	0.00048	WERE	TECUMSEH ENERGY CENTER 115KV'	158	0.04111	-0.04063	29
WERE	CITY OF IOLA 69KV'	13.361	-0.00017	WERE	TECUMSEH ENERGY CENTER 115KV'	158	0.04111	-0.04128	29
WERE	NEOSHO ENERGY CENTER 138KV'	47	0.00077	WERE	TECUMSEH ENERGY CENTER 115KV'	158	0.04111	-0.04034	30
WERE	TECUMSEH ENERGY CENTER 69KV'	41	0.03953	WERE	LAWRENCE ENERGY CENTER 230KV'	233.864	0.07759	-0.03806	31
WERE	LATHAM1234.0 345KV'	150	0.00368	WERE	TECUMSEH ENERGY CENTER 115KV'	158	0.04111	-0.03743	32
WERE	CITY OF WINFIELD 69KV'	29.38998	0.00472	WERE	TECUMSEH ENERGY CENTER 115KV'	158	0.04111	-0.03639	33
WERE	GETTY 69KV'	35	0.00525	WERE	TECUMSEH ENERGY CENTER 115KV'	158	0.04111	-0.03586	33

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 WFEC & OKGE  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: DEWEY - IODINE 138KV CKT 1  
 Flowgate: 5578555991547875479614407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086238	0.4	0.4
1086238	0.4	0.4

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	AES 161KV'	78.99999	0.00003	OKGE	FPLWND2 34KV'	102	0.97308	-0.97305	0
OKGE	AES 161KV'	78.99999	0.00003	OKGE	FPLWND2 34KV'	102	0.97308	-0.97305	0
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	FPLWND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	FPLWND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	FPLWND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	FPLWND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	FPLWND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	FPLWND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 69KV'	16	0.00021	OKGE	FPLWND2 34KV'	102	0.97308	-0.97287	0
OKGE	HORSESHOE LAKE 69KV'	16	0.00021	OKGE	FPLWND2 34KV'	102	0.97308	-0.97287	0
OKGE	MCCLAIN 138KV'	42	0.00035	OKGE	FPLWND2 34KV'	102	0.97308	-0.97273	0
OKGE	MCCLAIN 138KV'	42	0.00035	OKGE	FPLWND2 34KV'	102	0.97308	-0.97273	0
OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	FPLWND2 34KV'	102	0.97308	-0.97305	0
OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	FPLWND2 34KV'	102	0.97308	-0.97305	0
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	FPLWND2 34KV'	102	0.97308	-0.97305	0
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	FPLWND2 34KV'	102	0.97308	-0.97305	0
OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	FPLWND2 34KV'	102	0.97308	-0.97304	0
OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	FPLWND2 34KV'	102	0.97308	-0.97304	0
OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	FPLWND2 34KV'	102	0.97308	-0.97273	0
OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	FPLWND2 34KV'	102	0.97308	-0.97273	0
OKGE	MUSTANG 69KV'	106	0.00039	OKGE	FPLWND2 34KV'	102	0.97308	-0.97269	0
OKGE	MUSTANG 69KV'	106	0.00039	OKGE	FPLWND2 34KV'	102	0.97308	-0.97269	0
OKGE	ONE OAK 345KV'	334	0.00012	OKGE	FPLWND2 34KV'	102	0.97308	-0.97296	0
OKGE	ONE OAK 345KV'	334	0.00012	OKGE	FPLWND2 34KV'	102	0.97308	-0.97296	0
OKGE	REDBUD 345KV'	870	0.00014	OKGE	FPLWND2 34KV'	102	0.97308	-0.97294	0
OKGE	REDBUD 345KV'	870	0.00014	OKGE	FPLWND2 34KV'	102	0.97308	-0.97294	0
OKGE	REDBUD 345KV'	300	0.00014	OKGE	FPLWND2 34KV'	102	0.97308	-0.97294	0
OKGE	REDBUD 345KV'	300	0.00014	OKGE	FPLWND2 34KV'	102	0.97308	-0.97294	0
OKGE	SEMINOLE 138KV'	320.4242	0.00018	OKGE	FPLWND2 34KV'	102	0.97308	-0.9729	0
OKGE	SEMINOLE 138KV'	320.4242	0.00018	OKGE	FPLWND2 34KV'	102	0.97308	-0.9729	0
OKGE	SEMINOLE 345KV'	507.6	0.00018	OKGE	FPLWND2 34KV'	102	0.97308	-0.9729	0
OKGE	SEMINOLE 345KV'	507.6	0.00018	OKGE	FPLWND2 34KV'	102	0.97308	-0.9729	0
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	FPLWND2 34KV'	102	0.97308	-0.97339	0
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	FPLWND2 34KV'	102	0.97308	-0.97339	0
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	FPLWND2 34KV'	102	0.97308	-0.9747	0
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	FPLWND2 34KV'	102	0.97308	-0.9747	0
OKGE	TINKER 5G 138KV'	62	0.00023	OKGE	FPLWND2 34KV'	102	0.97308	-0.97285	0
OKGE	TINKER 5G 138KV'	62	0.00023	OKGE	FPLWND2 34KV'	102	0.97308	-0.97285	0
OKGE	AES 161KV'	78.99999	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	AES 161KV'	78.99999	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 69KV'	16	0.00021	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81237	1
OKGE	HORSESHOE LAKE 69KV'	16	0.00021	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81237	1
OKGE	MCCLAIN 138KV'	42	0.00035	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81223	1
OKGE	MCCLAIN 138KV'	42	0.00035	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81223	1
OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81254	1
OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81254	1
OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81223	1
OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81223	1
OKGE	MUSTANG 69KV'	106	0.00039	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81219	1
OKGE	MUSTANG 69KV'	106	0.00039	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81219	1
OKGE	ONE OAK 345KV'	334	0.00012	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81246	1
OKGE	ONE OAK 345KV'	334	0.00012	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81246	1
OKGE	REDBUD 345KV'	870	0.00014	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81244	1
OKGE	REDBUD 345KV'	870	0.00014	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81244	1
OKGE	REDBUD 345KV'	300	0.00014	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81244	1
OKGE	REDBUD 345KV'	300	0.00014	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81244	1
OKGE	SEMINOLE 138KV'	320.4242	0.00018	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8124	1
OKGE	SEMINOLE 138KV'	320.4242	0.00018	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8124	1
OKGE	SEMINOLE 345KV'	507.6	0.00018	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8124	1
OKGE	SEMINOLE 345KV'	507.6	0.00018	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8124	1
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81289	1
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81289	1
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8142	1
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8142	1
OKGE	TINKER 5G 138KV'	62	0.00023	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81235	1
OKGE	TINKER 5G 138KV'	62	0.00023	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81235	1
OKGE	WOODWARD 24KV'	9.3	0.81258	OKGE	FPLWIND2 34KV'	102	0.97308	-0.1605	3
OKGE	WOODWARD 24KV'	9.3	0.81258	OKGE	FPLWIND2 34KV'	102	0.97308	-0.1605	3
WFEC	MORLND 138KV'	148.952	-0.02454	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.07792	5
WFEC	MORLND 138KV'	148.952	-0.02454	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.07792	5
WFEC	ANADARKO 138KV'	90	0.00024	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05314	8
WFEC	ANADARKO 138KV'	90	0.00024	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05314	8
WFEC	ANADARKO 69KV'	76	0.00046	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05292	8
WFEC	ANADARKO 69KV'	76	0.00046	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05292	8
WFEC	BLUCAN14 138 138KV'	151.2	0.00019	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05319	8
WFEC	BLUCAN14 138 138KV'	151.2	0.00019	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05319	8

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FPL SWITCH - MOORELAND 138KV CKT 1 WFEC & OKGE  
 Limiting Facility: FPL SWITCH - MOORELAND 138KV CKT 1  
 Direction: From->To  
 Line Outage: IODINE - WOODWARD 138KV CKT 1  
 Flowgate: 5578555991547965478514407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086238	0.4	0.4
1086238	0.4	0.4

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	AES 161KV'	78.99999	0.00003	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97305	0
OKGE	AES 161KV'	78.99999	0.00003	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97305	0
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97286	0
OKGE	HORSESHOE LAKE 69KV'	16	0.00021	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97287	0
OKGE	HORSESHOE LAKE 69KV'	16	0.00021	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97287	0
OKGE	MCCLAIN 138KV'	42	0.00035	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97273	0
OKGE	MCCLAIN 138KV'	42	0.00035	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97273	0
OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97305	0
OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97305	0
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97305	0
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97305	0
OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97304	0
OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97304	0
OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97273	0
OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97273	0
OKGE	MUSTANG 69KV'	106	0.00039	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97269	0
OKGE	MUSTANG 69KV'	106	0.00039	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97269	0
OKGE	ONE OAK 345KV'	334	0.00012	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97296	0
OKGE	ONE OAK 345KV'	334	0.00012	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97296	0
OKGE	REDBUD 345KV'	870	0.00014	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97294	0
OKGE	REDBUD 345KV'	870	0.00014	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97294	0
OKGE	REDBUD 345KV'	300	0.00014	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97294	0
OKGE	REDBUD 345KV'	300	0.00014	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97294	0
OKGE	SEMINOLE 138KV'	320.4242	0.00018	OKGE	FPLWIND2 34KV'	102	0.97308	-0.9729	0
OKGE	SEMINOLE 138KV'	320.4242	0.00018	OKGE	FPLWIND2 34KV'	102	0.97308	-0.9729	0
OKGE	SEMINOLE 345KV'	507.6	0.00018	OKGE	FPLWIND2 34KV'	102	0.97308	-0.9729	0
OKGE	SEMINOLE 345KV'	507.6	0.00018	OKGE	FPLWIND2 34KV'	102	0.97308	-0.9729	0
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97339	0
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97339	0
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	FPLWIND2 34KV'	102	0.97308	-0.9747	0
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	FPLWIND2 34KV'	102	0.97308	-0.9747	0
OKGE	TINKER 5G 138KV'	62	0.00023	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97285	0
OKGE	TINKER 5G 138KV'	62	0.00023	OKGE	FPLWIND2 34KV'	102	0.97308	-0.97285	0
OKGE	AES 161KV'	78.99999	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	AES 161KV'	78.99999	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 138KV'	380	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 138KV'	91	0.00022	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81236	1
OKGE	HORSESHOE LAKE 69KV'	16	0.00021	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81237	1
OKGE	HORSESHOE LAKE 69KV'	16	0.00021	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81237	1
OKGE	MCCLAIN 138KV'	42	0.00035	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81223	1
OKGE	MCCLAIN 138KV'	42	0.00035	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81223	1
OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	MUSKOGEE 161KV'	166	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	MUSKOGEE 161KV'	31	0.00003	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81255	1
OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81254	1
OKGE	MUSKOGEE 345KV'	20	0.00004	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81254	1
OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81223	1
OKGE	MUSTANG 138KV'	365.5	0.00035	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81223	1
OKGE	MUSTANG 69KV'	106	0.00039	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81219	1
OKGE	MUSTANG 69KV'	106	0.00039	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81219	1
OKGE	ONE OAK 345KV'	334	0.00012	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81246	1
OKGE	ONE OAK 345KV'	334	0.00012	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81246	1
OKGE	REDBUD 345KV'	870	0.00014	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81244	1
OKGE	REDBUD 345KV'	870	0.00014	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81244	1
OKGE	REDBUD 345KV'	300	0.00014	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81244	1
OKGE	REDBUD 345KV'	300	0.00014	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81244	1
OKGE	SEMINOLE 138KV'	320.4242	0.00018	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8124	1
OKGE	SEMINOLE 138KV'	320.4242	0.00018	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8124	1
OKGE	SEMINOLE 345KV'	507.6	0.00018	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8124	1
OKGE	SEMINOLE 345KV'	507.6	0.00018	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8124	1
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81289	1
OKGE	SOONER 138KV'	24.99997	-0.00031	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81289	1
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8142	1
OKGE	SOUTH 4TH ST 69KV'	42.7	-0.00162	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.8142	1
OKGE	TINKER 5G 138KV'	62	0.00023	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81235	1
OKGE	TINKER 5G 138KV'	62	0.00023	OKGE	SLEEPING BEAR 34KV'	120	0.81258	-0.81235	1
OKGE	WOODWARD 24KV'	9.3	0.81258	OKGE	FPLWND2 34KV'	102	0.97308	-0.1605	3
OKGE	WOODWARD 24KV'	9.3	0.81258	OKGE	FPLWND2 34KV'	102	0.97308	-0.1605	3
WFEC	MORLND 138KV'	148.952	-0.02454	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.07792	5
WFEC	MORLND 138KV'	148.952	-0.02454	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.07792	5
WFEC	ANADARKO 138KV'	90	0.00024	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05314	8
WFEC	ANADARKO 138KV'	90	0.00024	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05314	8
WFEC	ANADARKO 69KV'	76	0.00046	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05292	8
WFEC	ANADARKO 69KV'	76	0.00046	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05292	8
WFEC	BLUCAN14 138 138KV'	151.2	0.00019	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05319	8
WFEC	BLUCAN14 138 138KV'	151.2	0.00019	WFEC	SLEEPING BEAR 138KV'	96	0.05338	-0.05319	8

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 55919559201559205595711107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1086238	8.0	8.0							
1086238	8.0	8.0							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV'	39.77038	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	ANADARKO 138KV'	39.77038	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	ANADARKO 138KV'	90	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	ANADARKO 138KV'	90	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	ANADARKO 69KV'	76	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	ANADARKO 69KV'	76	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	BLUCAN14 138 138KV'	151.2	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	BLUCAN14 138 138KV'	151.2	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	MORLND 138KV'	320	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	MORLND 138KV'	320	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 55919559201559205595711407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount							
1086238	8.0	8.0							
1086238	8.0	8.0							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV'	3.104965	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	ANADARKO 138KV'	3.104965	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	ANADARKO 138KV'	90	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	ANADARKO 138KV'	90	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	ANADARKO 69KV'	76	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	ANADARKO 69KV'	76	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	BLUCAN14 138 138KV'	151.2	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	BLUCAN14 138 138KV'	151.2	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	MORLND 138KV'	174.1555	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8
WFEC	MORLND 138KV'	174.1555	0	WFEC	SLEEPING BEAR 138KV'	96	1	-1	8

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 55919559201559205595711407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086238	8.0	8.0
1086238	8.0	8.0



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV	90	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 138KV	90	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 69KV	76	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 69KV	76	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	BLUCAN14 138 138KV	151.2	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	BLUCAN14 138 138KV	151.2	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	MORLND 138KV	148.952	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	MORLND 138KV	148.952	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SUPPLY - IODINE 138KV CKT 1  
 Flowgate: 5919559201559205595714407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086238	8.0	8.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV	90	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 69KV	76	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	BLUCAN14 138 138KV	151.2	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	MORLND 138KV	39.51605	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 5919559201559575599911107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086238	8.0	8.0
1086238	8.0	8.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV	90	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 138KV	90	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 69KV	76	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 69KV	76	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	BLUCAN14 138 138KV	151.2	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	BLUCAN14 138 138KV	151.2	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	MORLND 138KV	25.26624	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	MORLND 138KV	25.26624	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 5919559201559575599911407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1086238	8.0	8.0
1086238	8.0	8.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV	3.104965	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 138KV	3.104965	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 138KV	90	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 138KV	90	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 69KV	76	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 69KV	76	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	BLUCAN14 138 138KV	151.2	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	BLUCAN14 138 138KV	151.2	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	MORLND 138KV	174.1555	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	MORLND 138KV	174.1555	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 5919559201559575599914107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086238	8.0	8.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
---------------------	--------	-----------------------	-----	-------------------	------	-----------------------	-----	--------	------------------------

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WFEC	ANADARKO 138KV	42.90496	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 138KV	90	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 69KV	76	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	BLUCAN14 138 138KV	151.2	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	MORLND 138KV	320	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Limiting Facility: FT SUPPLY 138-69KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: IODINE - MOORELAND 138KV CKT 1  
 Flowgate: 55919559201559575599914107WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086238	8.0	8.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV	90	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	ANADARKO 69KV	76	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	BLUCAN14 138 138KV	151.2	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8
WFEC	MORLND 138KV	133.0715	0	WFEC	SLEEPING BEAR 138KV	96	1	-1	8

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1  
 Limiting Facility: GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1  
 Direction: From->To  
 Line Outage: GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1  
 Flowgate: 577955779815779557811107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090612	0.5	7.3
1090808	0.4	7.3
1090817	2.1	7.3
1090823	0.2	7.3
1090825	0.4	7.3
1090964	2.9	7.3
1090965	0.8	7.3

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CHANUTE 69KV	31.077	-0.00115	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.23391	31
WERE	CITY OF IOLA 69KV	13.361	-0.00105	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.23381	31
WERE	GETTY 69KV	35	-0.00429	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.23705	31
WERE	JEFFREY ENERGY CENTER 230KV	24	-0.00001	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.23277	31
WERE	JEFFREY ENERGY CENTER 345KV	42	-0.00002	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.23278	31
WERE	LATHAM1234.0 345KV	150	-0.00298	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.23574	31
WERE	LAWRENCE ENERGY CENTER 230KV	35.13602	-0.00042	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.23318	31
WERE	NEOSHO ENERGY CENTER 138KV	47	-0.00104	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.2338	31
WERE	TECUMSEH ENERGY CENTER 69KV	41	-0.00029	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.23305	31
WERE	BPU - CITY OF MCPHERSON 115KV	15.93311	0.00281	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.22995	32
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00376	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.229	32
WERE	HUTCHINSON ENERGY CENTER 69KV	12	0.00376	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.229	32
WERE	SMOKYHIL 230 230KV	72	0.00242	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.23034	32
WERE	CITY OF WINFIELD 69KV	29.38998	0.02492	WERE	GILL ENERGY CENTER 69KV	75	0.23276	-0.20784	35
WERE	GETTY 69KV	35	-0.00429	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.11523	64
WERE	LATHAM1234.0 345KV	150	-0.00298	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.11392	64
WERE	CHANUTE 69KV	31.077	-0.00115	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.11209	65
WERE	NEOSHO ENERGY CENTER 138KV	47	-0.00104	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.11198	65
WERE	JEFFREY ENERGY CENTER 230KV	24	-0.00001	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.11095	66
WERE	JEFFREY ENERGY CENTER 345KV	42	-0.00002	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.11096	66
WERE	LAWRENCE ENERGY CENTER 230KV	35.13602	-0.00042	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.11136	66
WERE	TECUMSEH ENERGY CENTER 69KV	41	-0.00029	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.11123	66
WERE	SMOKYHIL 230 230KV	72	0.00242	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.10852	67
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00376	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.10718	68
WERE	CITY OF WINFIELD 69KV	29.38998	0.02492	WERE	CITY OF WELLINGTON 69KV	41.45	0.11094	-0.08602	85
WERE	GETTY 69KV	35	-0.00429	WERE	GILL ENERGY CENTER 138KV	171	0.07579	-0.08008	91
WERE	LATHAM1234.0 345KV	150	-0.00298	WERE	GILL ENERGY CENTER 138KV	171	0.07579	-0.07877	93
WERE	NEOSHO ENERGY CENTER 138KV	47	-0.00104	WERE	GILL ENERGY CENTER 138KV	171	0.07579	-0.07683	95
WERE	LAWRENCE ENERGY CENTER 230KV	35.13602	-0.00042	WERE	GILL ENERGY CENTER 138KV	171	0.07579	-0.07621	96
WERE	TECUMSEH ENERGY CENTER 69KV	41	-0.00029	WERE	GILL ENERGY CENTER 138KV	171	0.07579	-0.07608	96
WERE	JEFFREY ENERGY CENTER 345KV	42	-0.00002	WERE	GILL ENERGY CENTER 138KV	171	0.07579	-0.07581	97
WERE	SMOKYHIL 230 230KV	72	0.00242	WERE	GILL ENERGY CENTER 138KV	171	0.07579	-0.07337	100
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00376	WERE	GILL ENERGY CENTER 138KV	171	0.07579	-0.07203	102

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1  
 Limiting Facility: GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1  
 Direction: From->To  
 Line Outage: HOOVER NORTH (HOOVER1X) 138-69-13.2KV TRANSFORMER CKT 1  
 Flowgate: 57795577981HOOVER1X4211107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090612	0.4	5.0
1090808	0.2	5.0
1090817	1.4	5.0
1090823	0.1	5.0
1090825	0.3	5.0
1090964	2.0	5.0
1090965	0.6	5.0

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CHANUTE 69KV'	31.077	-0.00115	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.15992	31
WERE	CITY OF IOLA 69KV'	13.361	-0.00102	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.15979	31
WERE	GETTY 69KV'	35	-0.00454	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.16331	31
WERE	LATHAM1234.0 345KV'	150	-0.00278	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.16155	31
WERE	NEOSHO ENERGY CENTER 138KV'	47	-0.001	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.15977	31
WERE	BPU - CITY OF MCPHERSON 115KV'	15.93311	0.00237	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.1564	32
WERE	HUTCHINSON ENERGY CENTER 115KV'	133	0.00309	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.15568	32
WERE	HUTCHINSON ENERGY CENTER 69KV'	12	0.0031	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.15567	32
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.00024	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.15853	32
WERE	JEFFREY ENERGY CENTER 345KV'	42	0.00023	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.15854	32
WERE	LAWRENCE ENERGY CENTER 230KV'	35.13602	-0.0001	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.15887	32
WERE	SMOKYHIL 230 230KV'	72	0.00207	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.1567	32
WERE	TECUMSEH ENERGY CENTER 69KV'	41	0.00002	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.15875	32
WERE	CITY OF WINFIELD 69KV'	29.38998	0.01598	WERE	GILL ENERGY CENTER 69KV'	75	0.15877	-0.14279	35
WERE	GETTY 69KV'	35	-0.00454	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.07968	63
WERE	LATHAM1234.0 345KV'	150	-0.00278	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.07792	64
WERE	CHANUTE 69KV'	31.077	-0.00115	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.07629	66
WERE	NEOSHO ENERGY CENTER 138KV'	47	-0.001	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.07614	66
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.00024	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.0749	67
WERE	JEFFREY ENERGY CENTER 345KV'	42	0.00023	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.07491	67
WERE	LAWRENCE ENERGY CENTER 230KV'	35.13602	-0.0001	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.07524	67
WERE	TECUMSEH ENERGY CENTER 69KV'	41	0.00002	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.07512	67
WERE	SMOKYHIL 230 230KV'	72	0.00207	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.07307	69
WERE	HUTCHINSON ENERGY CENTER 115KV'	133	0.00309	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.07205	70
WERE	GETTY 69KV'	35	-0.00454	WERE	GILL ENERGY CENTER 138KV'	171	0.05751	-0.06205	81
WERE	LATHAM1234.0 345KV'	150	-0.00278	WERE	GILL ENERGY CENTER 138KV'	171	0.05751	-0.06029	83
WERE	CHANUTE 69KV'	31.077	-0.00115	WERE	GILL ENERGY CENTER 138KV'	171	0.05751	-0.05866	85
WERE	CITY OF WINFIELD 69KV'	29.38998	0.01598	WERE	CITY OF WELLINGTON 69KV'	41.45	0.07514	-0.05916	85
WERE	NEOSHO ENERGY CENTER 138KV'	47	-0.001	WERE	GILL ENERGY CENTER 138KV'	171	0.05751	-0.05851	86
WERE	JEFFREY ENERGY CENTER 345KV'	42	0.00023	WERE	GILL ENERGY CENTER 138KV'	171	0.05751	-0.05728	87
WERE	LAWRENCE ENERGY CENTER 230KV'	35.13602	-0.0001	WERE	GILL ENERGY CENTER 138KV'	171	0.05751	-0.05761	87
WERE	TECUMSEH ENERGY CENTER 69KV'	41	0.00002	WERE	GILL ENERGY CENTER 138KV'	171	0.05751	-0.05749	87
WERE	SMOKYHIL 230 230KV'	72	0.00207	WERE	GILL ENERGY CENTER 138KV'	171	0.05751	-0.05544	90
WERE	HUTCHINSON ENERGY CENTER 115KV'	133	0.00309	WERE	GILL ENERGY CENTER 138KV'	171	0.05751	-0.05442	92

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1  
 Limiting Facility: GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1  
 Direction: From->To  
 Line Outage: SPP-WERE-36  
 Flowgate: 57795577981SPP-WERE-361107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090612	0.6	5.6
1090808	0.3	5.6
1090817	1.5	5.6
1090823	0.1	5.6
1090825	0.3	5.6
1090964	2.1	5.6
1090965	0.6	5.6

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	GETTY 69KV'	35	-0.00293	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17828	31
WERE	BPU - CITY OF MCPHERSON 115KV'	15.93311	0.00308	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17227	32
WERE	CHANUTE 69KV'	31.077	-0.00087	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17622	32
WERE	CITY OF IOLA 69KV'	13.361	-0.00081	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17616	32
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.00001	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17534	32
WERE	JEFFREY ENERGY CENTER 345KV'	42	0	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17535	32
WERE	LATHAM1234.0 345KV'	150	-0.00228	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17763	32
WERE	LAWRENCE ENERGY CENTER 230KV'	35.13602	-0.00041	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17576	32
WERE	NEOSHO ENERGY CENTER 138KV'	47	-0.00081	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17616	32
WERE	SMOKYHIL 230 230KV'	72	0.00265	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.1727	32
WERE	TECUMSEH ENERGY CENTER 69KV'	41	-0.00028	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17563	32
WERE	HUTCHINSON ENERGY CENTER 115KV'	133	0.00412	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17123	33
WERE	HUTCHINSON ENERGY CENTER 69KV'	12	0.00413	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.17122	33
WERE	CITY OF WINFIELD 69KV'	29.38998	0.02086	WERE	GILL ENERGY CENTER 69KV'	75	0.17535	-0.15449	36
WERE	GETTY 69KV'	35	-0.00293	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.08784	64
WERE	LATHAM1234.0 345KV'	150	-0.00228	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.08719	64
WERE	CHANUTE 69KV'	31.077	-0.00087	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.08578	65
WERE	GETTY 69KV'	35	-0.00293	WERE	GILL ENERGY CENTER 138KV'	171	0.08372	-0.08665	65
WERE	LATHAM1234.0 345KV'	150	-0.00228	WERE	GILL ENERGY CENTER 138KV'	171	0.08372	-0.086	65
WERE	NEOSHO ENERGY CENTER 138KV'	47	-0.00081	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.08572	65
WERE	CHANUTE 69KV'	31.077	-0.00087	WERE	GILL ENERGY CENTER 138KV'	171	0.08372	-0.08459	66
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.00001	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.0849	66
WERE	JEFFREY ENERGY CENTER 345KV'	42	0	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.08491	66
WERE	LAWRENCE ENERGY CENTER 230KV'	35.13602	-0.00041	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.08532	66
WERE	NEOSHO ENERGY CENTER 138KV'	47	-0.00081	WERE	GILL ENERGY CENTER 138KV'	171	0.08372	-0.08453	66
WERE	TECUMSEH ENERGY CENTER 69KV'	41	-0.00028	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.08519	66
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.00001	WERE	GILL ENERGY CENTER 138KV'	171	0.08372	-0.08371	67
WERE	JEFFREY ENERGY CENTER 345KV'	42	0	WERE	GILL ENERGY CENTER 138KV'	171	0.08372	-0.08372	67
WERE	LAWRENCE ENERGY CENTER 230KV'	35.13602	-0.00041	WERE	GILL ENERGY CENTER 138KV'	171	0.08372	-0.08413	67
WERE	TECUMSEH ENERGY CENTER 69KV'	41	-0.00028	WERE	GILL ENERGY CENTER 138KV'	171	0.08372	-0.084	67
WERE	SMOKYHIL 230 230KV'	72	0.00265	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.08226	68
WERE	HUTCHINSON ENERGY CENTER 115KV'	133	0.00412	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.08079	69
WERE	SMOKYHIL 230 230KV'	72	0.00265	WERE	GILL ENERGY CENTER 138KV'	171	0.08372	-0.08107	69
WERE	HUTCHINSON ENERGY CENTER 115KV'	133	0.00412	WERE	GILL ENERGY CENTER 138KV'	171	0.08372	-0.0796	70
WERE	CITY OF WINFIELD 69KV'	29.38998	0.02086	WERE	CITY OF WELLINGTON 69KV'	41.45	0.08491	-0.06405	87

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1  
 Limiting Facility: GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1  
 Direction: From->To  
 Line Outage: GILL ENERGY CENTER EAST - GILLJCT269.0 69KV CKT 1  
 Flowgate: 57795578131577955779811107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Season Flowgate Identified: 2007 Summer Peak		Aggregate Relief Amount							
Reservation	Relief Amount	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1090612	0.4	7.502	-0.08355	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.28339	22
1090808	0.3	31.077	-0.00107	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.20091	31
1090817	1.8	13.361	-0.00097	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.20081	31
1090823	0.2	35	-0.00407	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.20391	31
1090825	0.4	24	0.00006	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.19978	31
1090964	2.5	42	0.00005	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.19979	31
1090965	0.7	150	-0.00272	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.20256	31
WERE	CITY OF MULVANE 69KV	7.502	-0.08355	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.20014	31
WERE	NEOSHO ENERGY CENTER 138KV	35.13602	-0.0003	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.20079	31
WERE	TECUMSEH ENERGY CENTER 69KV	41	-0.00018	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.20002	31
WERE	BPU - CITY OF MCPHERSON 115KV	15.93311	0.00251	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.19733	32
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00334	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.1965	32
WERE	HUTCHINSON ENERGY CENTER 69KV	12	0.00335	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.19649	32
WERE	SMOKYHIL 230 230KV	72	0.00217	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.19767	32
WERE	CITY OF WINFIELD 69KV	29.38998	0.02085	WERE	GILL ENERGY CENTER 69KV	75	0.19984	-0.17899	35
WERE	GETTY 69KV	35	-0.00407	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.09901	64
WERE	LATHAM1234.0 345KV	150	-0.00272	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.09766	64
WERE	CHANUTE 69KV	31.077	-0.00107	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.09601	66
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00006	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.09488	66
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00005	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.09489	66
WERE	LAWRENCE ENERGY CENTER 230KV	35.13602	-0.0003	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.09524	66
WERE	NEOSHO ENERGY CENTER 138KV	47	-0.00095	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.09589	66
WERE	TECUMSEH ENERGY CENTER 69KV	41	-0.00018	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.09512	66
WERE	SMOKYHIL 230 230KV	72	0.00217	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.09277	68
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00334	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.0916	69
WERE	CITY OF WINFIELD 69KV	29.38998	0.02085	WERE	CITY OF WELLINGTON 69KV	41.45	0.09494	-0.07409	85
WERE	GETTY 69KV	35	-0.00407	WERE	GILL ENERGY CENTER 138KV	171	0.066	-0.07007	90
WERE	LATHAM1234.0 345KV	150	-0.00272	WERE	GILL ENERGY CENTER 138KV	171	0.066	-0.06872	92
WERE	NEOSHO ENERGY CENTER 138KV	47	-0.00095	WERE	GILL ENERGY CENTER 138KV	171	0.066	-0.06695	94
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00005	WERE	GILL ENERGY CENTER 138KV	171	0.066	-0.06595	95
WERE	LAWRENCE ENERGY CENTER 230KV	35.13602	-0.0003	WERE	GILL ENERGY CENTER 138KV	171	0.066	-0.0663	95
WERE	TECUMSEH ENERGY CENTER 69KV	41	-0.00018	WERE	GILL ENERGY CENTER 138KV	171	0.066	-0.06618	95
WERE	SMOKYHIL 230 230KV	72	0.00217	WERE	GILL ENERGY CENTER 138KV	171	0.066	-0.06383	99
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00334	WERE	GILL ENERGY CENTER 138KV	171	0.066	-0.06266	100

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1  
 Limiting Facility: GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1  
 Direction: From->To  
 Line Outage: GILLJCT269.0 - OATVILLE 69KV CKT 1  
 Flowgate: 57795678131577985782511107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Season Flowgate Identified: 2007 Summer Peak		Aggregate Relief Amount							
Reservation	Relief Amount	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1090612	0.4	7.502	-0.09766	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.25206	19
1090808	0.2	31.077	-0.00102	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15542	31
1090817	1.4	13.361	-0.00091	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15531	31
1090823	0.1	35	-0.00405	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15845	31
1090825	0.3	150	-0.00246	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15686	31
1090964	1.9	35.13602	-0.0001	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.1545	31
1090965	0.6	47	-0.00089	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15529	31
WERE	CITY OF MULVANE 69KV	7.502	-0.09766	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15222	32
WERE	NEOSHO ENERGY CENTER 138KV	35.13602	-0.0001	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15156	32
WERE	TECUMSEH ENERGY CENTER 69KV	41	-0.00018	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15155	32
WERE	BPU - CITY OF MCPHERSON 115KV	15.93311	0.00218	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15419	32
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00284	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15155	32
WERE	HUTCHINSON ENERGY CENTER 69KV	12	0.00285	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15419	32
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00021	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15419	32
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00021	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15419	32
WERE	SMOKYHIL 230 230KV	72	0.0019	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.1525	32
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00001	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.15439	32
WERE	CITY OF WINFIELD 69KV	29.38998	0.01485	WERE	GILL ENERGY CENTER 69KV	75	0.1544	-0.13955	35
WERE	GETTY 69KV	35	-0.00405	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.07667	63
WERE	LATHAM1234.0 345KV	150	-0.00246	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.07508	65
WERE	CHANUTE 69KV	31.077	-0.00102	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.07364	66
WERE	NEOSHO ENERGY CENTER 138KV	47	-0.00089	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.07351	66
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00021	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.07241	67
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00021	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.07241	67
WERE	LAWRENCE ENERGY CENTER 230KV	35.13602	-0.0001	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.07272	67
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00001	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.07261	67
WERE	SMOKYHIL 230 230KV	72	0.0019	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.07072	69
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00284	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.06978	70
WERE	CITY OF WINFIELD 69KV	29.38998	0.01485	WERE	CITY OF WELLINGTON 69KV	41.45	0.07262	-0.05777	84
WERE	GETTY 69KV	35	-0.00405	WERE	GILL ENERGY CENTER 138KV	171	0.05317	-0.05722	85
WERE	LATHAM1234.0 345KV	150	-0.00246	WERE	GILL ENERGY CENTER 138KV	171	0.05317	-0.05563	87
WERE	CHANUTE 69KV	31.077	-0.00102	WERE	GILL ENERGY CENTER 138KV	171	0.05317	-0.05419	90
WERE	NEOSHO ENERGY CENTER 138KV	47	-0.00089	WERE	GILL ENERGY CENTER 138KV	171	0.05317	-0.05406	90
WERE	LAWRENCE ENERGY CENTER 230KV	35.13602	-0.0001	WERE	GILL ENERGY CENTER 138KV	171	0.05317	-0.05327	91
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00021	WERE	GILL ENERGY CENTER 138KV	171	0.05317	-0.05296	92
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00001	WERE	GILL ENERGY CENTER 138KV	171	0.05317	-0.05316	92
WERE	SMOKYHIL 230 230KV	72	0.0019	WERE	GILL ENERGY CENTER 138KV	171	0.05317	-0.05127	95
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00284	WERE	GILL ENERGY CENTER 138KV	171	0.05317	-0.05033	97

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Factor = Source GSF - Sink GSF  
 Redispatch Amount = Relief Amount / Factor

Upgrade: GILL ENERGY CENTER WEST - PECK 69KV  
 Limiting Facility: GILL ENERGY CENTER WEST - PECK 69KV CKT 1  
 Direction: From->To  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57796578301570395704211408SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.5	2.9
1090609	1.1	2.9
1090609	0.3	2.9
1090609	1.0	2.9
1090609	0.5	2.9
1090609	1.1	2.9
1090609	0.3	2.9
1090609	1.0	2.9

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.53598	5
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	ABILENE ENERGY CENTER 115KV	40	0.00595	-0.49559	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	BPU - CITY OF MCPHERSON 115KV	165	0.00596	-0.4956	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	BROWN COUNTY 115KV	3.3	0.00528	-0.49492	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	CHANUTE 69KV	55.637	0.00233	-0.49197	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	CITY OF AUGUSTA 69KV	25.12	0.00209	-0.49173	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	CITY OF BURLINGTON 69KV	10.12	0.00879	-0.49843	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	CITY OF ERIE 69KV	22.378	0.00233	-0.49197	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	CITY OF FREDONIA 69KV	5.225	0.0023	-0.49194	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	CITY OF GIRARD 69KV	4.592	0.0017	-0.49134	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	CITY OF IOLA 69KV	24.471	0.00236	-0.492	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	CITY OF MULVANE 69KV	8.29	0.02429	-0.51393	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	CITY OF OSAGE CITY 115KV	6.45	0.00636	-0.496	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.00597	-0.49561	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.98	0.00879	-0.49843	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	EVANS ENERGY CENTER 138KV	565	0.01685	-0.50649	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	GILL ENERGY CENTER 138KV	171	0.029	-0.51864	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	HOLTON 115KV	12.2	0.00544	-0.49508	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.00607	-0.49571	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	HUTCHINSON ENERGY CENTER 69KV	45	0.00607	-0.49571	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	JEFFREY ENERGY CENTER 230KV	470	0.0058	-0.49544	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00579	-0.49543	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	LATHAM1234.0 345KV	100	0.0092	-0.49884	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00547	-0.49511	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	LAWRENCE ENERGY CENTER 230KV	234.5897	0.0056	-0.49524	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	NEOSHO ENERGY CENTER 138KV	8.821289	0.00214	-0.49178	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	SOUTH SENECA 115KV	8.5	0.00531	-0.49495	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	ST JOHN 115KV	2.9	0.00804	-0.49768	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.00576	-0.4954	6
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.48964	WERE	WACO 138KV	17.967	0.02776	-0.5174	6
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.19629	15
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	GILL ENERGY CENTER 138KV	171	0.029	-0.17895	16
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	CITY OF MULVANE 69KV	8.29	0.02429	-0.17424	17
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	WACO 138KV	17.967	0.02776	-0.17771	17
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	EVANS ENERGY CENTER 138KV	565	0.01685	-0.1668	18
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	ABILENE ENERGY CENTER 115KV	40	0.00595	-0.1559	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	BPU - CITY OF MCPHERSON 115KV	165	0.00596	-0.15591	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	CHANUTE 69KV	55.637	0.00233	-0.15228	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	CITY OF AUGUSTA 69KV	25.12	0.00209	-0.15204	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	CITY OF BURLINGTON 69KV	10.12	0.00879	-0.15874	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	CITY OF ERIE 69KV	22.378	0.00233	-0.15228	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	CITY OF IOLA 69KV	24.471	0.00236	-0.15231	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	CITY OF OSAGE CITY 115KV	6.45	0.00636	-0.15631	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.00597	-0.15592	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.98	0.00879	-0.15874	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	HOLTON 115KV	12.2	0.00544	-0.15539	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.00607	-0.15602	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	HUTCHINSON ENERGY CENTER 69KV	45	0.00607	-0.15602	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	JEFFREY ENERGY CENTER 230KV	470	0.0058	-0.15575	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00579	-0.15574	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	LATHAM1234.0 345KV	100	0.0092	-0.15915	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00547	-0.15542	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	LAWRENCE ENERGY CENTER 230KV	234.5897	0.0056	-0.15555	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	NEOSHO ENERGY CENTER 138KV	8.821289	0.00214	-0.15209	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	SOUTH SENECA 115KV	8.5	0.00531	-0.15526	19
WERE	CITY OF WINFIELD 69KV	25.222	-0.14995	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.00576	-0.15571	19
WERE	CHANUTE 69KV	32.163	0.00233	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.04401	67
WERE	NEOSHO ENERGY CENTER 138KV	38.17871	0.00214	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.0442	67
WERE	LAWRENCE ENERGY CENTER 230KV	34.41034	0.0056	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.04074	72
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00607	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.04027	73
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00579	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.04055	73
WERE	SMOKYHIL 230 230KV	72	0.00573	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.04061	73
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00575	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.04059	73
WERE	LATHAM1234.0 345KV	50	0.0092	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.03714	79
WERE	GETTY 69KV	35	0.01006	WERE	GILL ENERGY CENTER 69KV	75	0.04634	-0.03628	81

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF  
 Redispatch Amount = Relief Amount / Factor

Upgrade: GILL ENERGY CENTER WEST - PECK 69KV  
 Limiting Facility: GILL ENERGY CENTER WEST - PECK 69KV CKT 1  
 Direction: From->To  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57796578301570395704214407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.3	1.4
1090609	0.5	1.4
1090609	0.2	1.4
1090609	0.4	1.4

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00598	-0.49561	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'BPU - CITY OF MCPHERSON 115KV'	135	0.00598	-0.49561	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'CHANUTE 69KV'	56.723	0.00228	-0.49191	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.00211	-0.49174	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'CITY OF BURLINGTON 69KV'	10.12	0.00883	-0.49846	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'CITY OF ERIE 69KV'	22.274	0.00228	-0.49191	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00228	-0.49191	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'CITY OF GIRARD 69KV'	4.789	0.00166	-0.49129	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'CITY OF IOLA 69KV'	24.267	0.00228	-0.49191	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'CITY OF MULVANE 69KV'	8.288	0.02431	-0.51394	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'CLAY CENTER JUNCTION 115KV'	28.875	0.006	-0.49563	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00883	-0.49846	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'EVANS ENERGY CENTER 138KV'	544.001	0.01687	-0.5065	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'GILL ENERGY CENTER 138KV'	171	0.02902	-0.51865	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.53599	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'HOLTON 115KV'	12.2	0.00547	-0.4951	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'HUTCHINSON ENERGY CENTER 115KV'	210	0.00609	-0.49572	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'HUTCHINSON ENERGY CENTER 69KV'	40	0.00609	-0.49572	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.00584	-0.49547	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.00582	-0.49545	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'LAWRENCE ENERGY CENTER 115KV'	105	0.00549	-0.49512	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'LAWRENCE ENERGY CENTER 230KV'	232.7283	0.00562	-0.49525	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'SOUTH SENECA 115KV'	8.5	0.00535	-0.49498	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'TECUMSEH ENERGY CENTER 115KV'	158	0.00578	-0.49541	3
WERE	CITY OF WELLINGTON 69KV	2.04999	-0.48963	WERE	'WACO 138KV'	17.96	0.02778	-0.51741	3
WERE	CITY OF WINFIELD 69KV	2.04999	-0.48963	WERE	'CITY OF WINFIELD 69KV'	10.61002	-0.14994	-0.33969	4
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.1963	7
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'CITY OF MULVANE 69KV'	8.288	0.02431	-0.17425	8
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'GILL ENERGY CENTER 138KV'	171	0.02902	-0.17896	8
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'WACO 138KV'	17.96	0.02778	-0.17772	8
WERE	OXFORD 138KV	3	-0.14354	WERE	'GILL ENERGY CENTER 138KV'	171	0.02902	-0.17256	8
WERE	OXFORD 138KV	3	-0.14354	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.1899	8
WERE	OXFORD 138KV	3	-0.14354	WERE	'WACO 138KV'	17.96	0.02778	-0.17132	8
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00598	-0.15592	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'BPU - CITY OF MCPHERSON 115KV'	135	0.00598	-0.15592	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'CHANUTE 69KV'	56.723	0.00228	-0.15222	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.00211	-0.15205	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'CITY OF BURLINGTON 69KV'	10.12	0.00883	-0.15877	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'CITY OF ERIE 69KV'	22.274	0.00228	-0.15222	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00228	-0.15222	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'CITY OF IOLA 69KV'	24.267	0.00228	-0.15222	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'CLAY CENTER JUNCTION 115KV'	28.875	0.006	-0.15594	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00883	-0.15877	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'EVANS ENERGY CENTER 138KV'	544.001	0.01687	-0.16681	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'HOLTON 115KV'	12.2	0.00547	-0.15541	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'HUTCHINSON ENERGY CENTER 115KV'	210	0.00609	-0.15603	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'HUTCHINSON ENERGY CENTER 69KV'	40	0.00609	-0.15603	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.00584	-0.15578	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.00582	-0.15576	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'LAWRENCE ENERGY CENTER 115KV'	105	0.00549	-0.15543	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'LAWRENCE ENERGY CENTER 230KV'	232.7283	0.00562	-0.15556	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'SOUTH SENECA 115KV'	8.5	0.00535	-0.15529	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'TECUMSEH ENERGY CENTER 115KV'	158	0.00578	-0.15572	9
WERE	OXFORD 138KV	3	-0.14354	WERE	'CITY OF BURLINGTON 69KV'	10.12	0.00883	-0.15237	9
WERE	OXFORD 138KV	3	-0.14354	WERE	'CITY OF MULVANE 69KV'	8.288	0.02431	-0.16785	9
WERE	OXFORD 138KV	3	-0.14354	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00883	-0.15237	9
WERE	OXFORD 138KV	3	-0.14354	WERE	'EVANS ENERGY CENTER 138KV'	544.001	0.01687	-0.16041	9
WERE	CITY OF WINFIELD 69KV	29.38998	-0.14994	WERE	'CITY OF GIRARD 69KV'	4.789	0.00166	-0.1516	10
WERE	CHANUTE 69KV	31.077	0.00228	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.04408	33
WERE	CITY OF IOLA 69KV	13.361	0.00228	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.04408	33
WERE	NEOSHO ENERGY CENTER 138KV	47	0.00213	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.04423	33
WERE	LAWRENCE ENERGY CENTER 230KV	36.2717	0.00562	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.04074	35
WERE	BPU - CITY OF MCPHERSON 115KV	39	0.00598	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.04038	36
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.00609	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.04027	36
WERE	HUTCHINSON ENERGY CENTER 69KV	12	0.00609	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.04027	36
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00584	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.04052	36
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00582	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.04054	36
WERE	SMOKYHIL 230 230KV	72	0.00578	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.0406	36
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00578	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.04058	36
WERE	LATHAM1234.0 345KV	150	0.00922	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.03714	39
WERE	GETTY 69KV	35	0.01008	WERE	'GILL ENERGY CENTER 69KV'	45	0.04636	-0.03628	40
OMPA	OMPA-PONCA CITY 69KV	45.15614	-0.04058	OMPA	OMPA-KINGFISHER BOWMAN 69KV	19.7	-0.01047	-0.03011	48

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: GREENSBURG - JUDSON LARGE 115KV CKT 1  
 Limiting Facility: GREENSBURG - JUDSON LARGE 115KV CKT 1  
 Direction: To->From  
 Line Outage: MULLERGREEN - SPEARVILLE 230KV CKT 1  
 Flowgate: 58764587711587795879513106FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090613	0.4	4.0
1090662	0.4	4.0
1090699	1.6	4.0
1090705	1.6	4.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WEPL	HARPER 138KV	17.21	-0.1293	WEPL	'GRAY COUNTY WIND FARM 115KV'	63	0.22689	-0.35619	11
WEPL	HARPER 138KV	17.21	-0.1293	WEPL	'JUDSON LARGE 115KV'	59.91905	0.22848	-0.35778	11
WEPL	A. M. MULLERGREEN GENERATOR 115KV	38	-0.04309	WEPL	'GRAY COUNTY WIND FARM 115KV'	63	0.22689	-0.26998	15
WEPL	A. M. MULLERGREEN GENERATOR 115KV	38	-0.04309	WEPL	'JUDSON LARGE 115KV'	59.91905	0.22848	-0.27157	15
WEPL	NORTH WEST GREAT BEND 115KV	14.24	-0.04309	WEPL	'GRAY COUNTY WIND FARM 115KV'	63	0.22689	-0.26998	15
WEPL	NORTH WEST GREAT BEND 115KV	14.24	-0.04309	WEPL	'JUDSON LARGE 115KV'	59.91905	0.22848	-0.27157	15
WEPL	RUSSELL 115KV	27.9	-0.03377	WEPL	'GRAY COUNTY WIND FARM 115KV'	63	0.22689	-0.26066	15

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WEPL	RUSSELL 115KV'	27.9	-0.03377	WEPL	JUDSON LARGE 115KV'	59.91905	0.22848	-0.26225	15
WEPL	HARPER 138KV'	17.21	-0.1293	WEPL	SPEARVILLE WIND 34KV'	100	0.12117	-0.25047	16
WEPL	SMITH CENTER 115KV'	6.15	-0.01798	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22689	-0.24487	16
WEPL	SMITH CENTER 115KV'	6.15	-0.01798	WEPL	JUDSON LARGE 115KV'	59.91905	0.22848	-0.24646	16
WEPL	BELOIT 115KV'	16.6	-0.01449	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22689	-0.24138	17
WEPL	BELOIT 115KV'	16.6	-0.01449	WEPL	JUDSON LARGE 115KV'	59.91905	0.22848	-0.24297	17
WEPL	CLIFTON 115KV'	70	-0.0106	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22689	-0.23749	17
WEPL	CLIFTON 115KV'	70	-0.0106	WEPL	JUDSON LARGE 115KV'	59.91905	0.22848	-0.23908	17
WEPL	GREENLEAF 115KV'	14.2	-0.00927	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22689	-0.23616	17
WEPL	GREENLEAF 115KV'	14.2	-0.00927	WEPL	JUDSON LARGE 115KV'	59.91905	0.22848	-0.23775	17
WEPL	PLAINVILLE 115KV'	5.79	-0.0124	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22689	-0.23929	17
WEPL	PLAINVILLE 115KV'	5.79	-0.0124	WEPL	JUDSON LARGE 115KV'	59.91905	0.22848	-0.24088	17
WEPL	A. M. MULLERGREEN GENERATOR 115KV'	38	-0.04309	WEPL	SPEARVILLE WIND 34KV'	100	0.12117	-0.16426	25
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.04309	WEPL	GRAY COUNTY WIND FARM 115KV'	100	0.12117	-0.16426	25
WEPL	RUSSELL 115KV'	27.9	-0.03377	WEPL	SPEARVILLE WIND 34KV'	100	0.12117	-0.15494	26
WEPL	BELOIT 115KV'	16.6	-0.01449	WEPL	GRAY COUNTY WIND FARM 115KV'	100	0.12117	-0.13566	30
WEPL	CLIFTON 115KV'	70	-0.0106	WEPL	SPEARVILLE WIND 34KV'	100	0.12117	-0.13177	31
WEPL	GREENLEAF 115KV'	14.2	-0.00927	WEPL	SPEARVILLE WIND 34KV'	100	0.12117	-0.13044	31
WEPL	CIMARRON RIVER 115KV'	72	0.12087	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22689	-0.10602	38
WEPL	CIMARRON RIVER 115KV'	72	0.12087	WEPL	JUDSON LARGE 115KV'	59.91905	0.22848	-0.10761	38
WEPL	HARPER 138KV'	17.21	-0.1293	WEPL	A. M. MULLERGREEN GENERATOR 115KV'	25	-0.04309	-0.08621	47

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: GREENSBURG - JUDSON LARGE 115KV CKT 1  
 Limiting Facility: GREENSBURG - JUDSON LARGE 115KV CKT 1  
 Direction: To->From  
 Line Outage: MULLERGREEN - SPEARVILLE 230KV CKT 1  
 Flowgate: 58764587711587795879513106WP  
 Date Redispatch Needed: 12/1/06 - 4/1/07  
 Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090613	0.5	5.9							
1090662	0.7	5.9							
1090699	2.3	5.9							
1090705	2.3	5.9							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WEPL	HARPER 138KV'	17.21	-0.12937	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22676	-0.35613	17
WEPL	HARPER 138KV'	17.21	-0.12937	WEPL	JUDSON LARGE 115KV'	55.32903	0.22835	-0.35772	17
WEPL	A. M. MULLERGREEN GENERATOR 115KV'	46.01582	-0.04318	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22676	-0.26994	22
WEPL	A. M. MULLERGREEN GENERATOR 115KV'	46.01582	-0.04318	WEPL	JUDSON LARGE 115KV'	55.32903	0.22835	-0.27153	22
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.04318	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22676	-0.26994	22
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.04318	WEPL	JUDSON LARGE 115KV'	55.32903	0.22835	-0.27153	22
WEPL	RUSSELL 115KV'	27.9	-0.03385	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22676	-0.26061	23
WEPL	RUSSELL 115KV'	27.9	-0.03385	WEPL	JUDSON LARGE 115KV'	55.32903	0.22835	-0.26222	23
WEPL	BELOIT 115KV'	16.6	-0.01458	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22676	-0.24134	24
WEPL	BELOIT 115KV'	16.6	-0.01458	WEPL	JUDSON LARGE 115KV'	55.32903	0.22835	-0.24293	24
WEPL	HARPER 138KV'	17.21	-0.12937	WEPL	SPEARVILLE WIND 34KV'	100	0.12105	-0.25042	24
WEPL	CLIFTON 115KV'	70	-0.01069	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22676	-0.23745	25
WEPL	CLIFTON 115KV'	70	-0.01069	WEPL	JUDSON LARGE 115KV'	55.32903	0.22835	-0.23904	25
WEPL	GREENLEAF 115KV'	14.2	-0.00936	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22676	-0.23612	25
WEPL	GREENLEAF 115KV'	14.2	-0.00936	WEPL	JUDSON LARGE 115KV'	55.32903	0.22835	-0.23771	25
WEPL	A. M. MULLERGREEN GENERATOR 115KV'	46.01582	-0.04318	WEPL	SPEARVILLE WIND 34KV'	100	0.12105	-0.16423	36
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.04318	WEPL	SPEARVILLE WIND 34KV'	100	0.12105	-0.16423	36
WEPL	RUSSELL 115KV'	27.9	-0.03385	WEPL	SPEARVILLE WIND 34KV'	100	0.12105	-0.1549	38
WEPL	BELOIT 115KV'	16.6	-0.01458	WEPL	SPEARVILLE WIND 34KV'	100	0.12105	-0.13563	44
WEPL	CLIFTON 115KV'	70	-0.01069	WEPL	SPEARVILLE WIND 34KV'	100	0.12105	-0.13174	45
WEPL	CIMARRON RIVER 115KV'	72	0.12068	WEPL	JUDSON LARGE 115KV'	55.32903	0.22835	-0.10767	55
WEPL	CIMARRON RIVER 115KV'	72	0.12068	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22676	-0.10608	56

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: GREENSBURG - JUDSON LARGE 115KV CKT 1  
 Limiting Facility: GREENSBURG - JUDSON LARGE 115KV CKT 1  
 Direction: To->From  
 Line Outage: MULLERGREEN - SPEARVILLE 230KV CKT 1  
 Flowgate: 58764587711587795879513107G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090613	0.3	4.3							
1090662	0.4	4.3							
1090674	0.1	4.3							
1090699	1.7	4.3							
1090705	1.7	4.3							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WEPL	HARPER 138KV'	17.21	-0.12869	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22672	-0.35541	12
WEPL	HARPER 138KV'	17.21	-0.12869	WEPL	JUDSON LARGE 115KV'	89.53949	0.22832	-0.35701	12
WEPL	A. M. MULLERGREEN GENERATOR 115KV'	19.71292	-0.0351	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22672	-0.26182	16
WEPL	A. M. MULLERGREEN GENERATOR 115KV'	19.71292	-0.0351	WEPL	JUDSON LARGE 115KV'	89.53949	0.22832	-0.26342	16
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.0351	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22672	-0.26182	16
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.0351	WEPL	JUDSON LARGE 115KV'	89.53949	0.22832	-0.26342	16
WEPL	HARPER 138KV'	17.21	-0.12869	WEPL	SPEARVILLE WIND 34KV'	100	0.12069	-0.24938	17
WEPL	RUSSELL 115KV'	27.9	-0.02815	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22672	-0.25487	17
WEPL	RUSSELL 115KV'	27.9	-0.02815	WEPL	JUDSON LARGE 115KV'	89.53949	0.22832	-0.25647	17
WEPL	SMITH CENTER 115KV'	6.15	-0.01637	WEPL	JUDSON LARGE 115KV'	89.53949	0.22832	-0.24469	17
WEPL	BELOIT 115KV'	16.6	-0.01346	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22672	-0.24018	18
WEPL	BELOIT 115KV'	16.6	-0.01346	WEPL	JUDSON LARGE 115KV'	89.53949	0.22832	-0.24178	18
WEPL	CLIFTON 115KV'	70	-0.01001	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22672	-0.23673	18
WEPL	CLIFTON 115KV'	70	-0.01001	WEPL	JUDSON LARGE 115KV'	89.53949	0.22832	-0.23833	18
WEPL	GREENLEAF 115KV'	14.2	-0.00877	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22672	-0.23549	18
WEPL	GREENLEAF 115KV'	14.2	-0.00877	WEPL	JUDSON LARGE 115KV'	89.53949	0.22832	-0.23709	18
WEPL	SMITH CENTER 115KV'	6.15	-0.01637	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22672	-0.24309	18
WEPL	A. M. MULLERGREEN GENERATOR 115KV'	19.71292	-0.0351	WEPL	SPEARVILLE WIND 34KV'	100	0.12069	-0.15579	27
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.0351	WEPL	SPEARVILLE WIND 34KV'	100	0.12069	-0.15579	27
WEPL	RUSSELL 115KV'	27.9	-0.02815	WEPL	SPEARVILLE WIND 34KV'	100	0.12069	-0.14884	29
MIDW	PAWNEE 115KV'	999	-0.09465	MIDW	COLBY 115KV'	13.3778	0.04507	-0.13972	30

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

MIDW	RICE 115KV'	999	-0.09465	MIDW	COLBY 115KV'	13.3778	0.04507	-0.13972	30
WEPL	BELOIT 115KV'	16.6	-0.01346	WEPL	SPEARVILLE WIND 34KV'	100	0.12069	-0.13415	32
WEPL	CLIFTON 115KV'	70	-0.01001	WEPL	SPEARVILLE WIND 34KV'	100	0.12069	-0.1307	33
WEPL	GREENLEAF 115KV'	14.2	-0.00877	WEPL	SPEARVILLE WIND 34KV'	100	0.12069	-0.12946	33
WEPL	CIMARRON RIVER 115KV'	72	0.12053	WEPL	JUDSON LARGE 115KV'	89.53949	0.22832	-0.10779	39
WEPL	CIMARRON RIVER 115KV'	72	0.12053	WEPL	GRAY COUNTY WIND FARM 115KV'	63	0.22672	-0.10619	40
WEPL	HARPER 138KV'	17.21	-0.12869	WEPL	A. M. MULLEGRGEN GENERATOR 115KV'	43.28708	-0.0351	-0.09359	45

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Limiting Facility: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Direction: From->To  
 Line Outage: MOORELAND - MOREWOOD SW 138KV CKT 1  
 Flowgate: 55942560001559995600112407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086238	0.7	1.3
1090270	0.2	1.3
1090767	0.2	1.3
1090789	0.1	1.3

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV'	90	-0.01306	WFEC	MORLND 138KV'	280.4839	0.08457	-0.09763	13
WFEC	ANADARKO 138KV'	90	-0.01306	WFEC	SLEEPING BEAR 138KV'	80	0.0862	-0.09926	13
WFEC	ANADARKO 69KV'	76	-0.01142	WFEC	MORLND 138KV'	280.4839	0.08457	-0.09599	13
WFEC	ANADARKO 69KV'	76	-0.01142	WFEC	SLEEPING BEAR 138KV'	80	0.0862	-0.09762	13
WFEC	BLUCAN14 138 138KV'	151.2	-0.01552	WFEC	MORLND 138KV'	280.4839	0.08457	-0.10009	13
WFEC	BLUCAN14 138 138KV'	151.2	-0.01552	WFEC	SLEEPING BEAR 138KV'	80	0.0862	-0.10172	13
OKGE	MUSKOGEE 161KV'	166	0.00099	OKGE	FPLWIND2 34KV'	102	0.08465	-0.08366	15
OKGE	MUSKOGEE 161KV'	31	0.00099	OKGE	FPLWIND2 34KV'	102	0.08465	-0.08366	15
OKGE	MUSKOGEE 345KV'	20	0.00098	OKGE	FPLWIND2 34KV'	102	0.08465	-0.08367	15
OKGE	SEMINOLE 138KV'	16.57095	0.00043	OKGE	FPLWIND2 34KV'	102	0.08465	-0.08422	15
OKGE	TINKER 5G 138KV'	62	0.00145	OKGE	FPLWIND2 34KV'	102	0.08465	-0.0832	15
OKGE	HORSESHOE LAKE 138KV'	191.938	0.00198	OKGE	FPLWIND2 34KV'	102	0.08465	-0.08267	16
OKGE	MCCLAIN 138KV'	42	0.00175	OKGE	FPLWIND2 34KV'	102	0.08465	-0.0829	16
OKGE	ONE OAK 345KV'	36	0.00295	OKGE	FPLWIND2 34KV'	102	0.08465	-0.0817	16
OKGE	REDBUD 345KV'	870	0.00224	OKGE	FPLWIND2 34KV'	102	0.08465	-0.08241	16
OKGE	REDBUD 345KV'	300	0.00224	OKGE	FPLWIND2 34KV'	102	0.08465	-0.08241	16
OKGE	SOONER 138KV'	24.99997	0.0068	OKGE	FPLWIND2 34KV'	102	0.08465	-0.07785	17
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02149	OKGE	FPLWIND2 34KV'	102	0.08465	-0.06316	20

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Limiting Facility: HAMON BUTLER - MOREWOOD 69KV CKT 1  
 Direction: From->To  
 Line Outage: MOORELAND - MOREWOOD SW 138KV CKT 1  
 Flowgate: 55942560001559995600114407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086238	0.7	1.1
1086238	0.7	1.1
1090270	0.2	1.1
1090270	0.2	1.1
1090767	0.1	1.1
1090767	0.1	1.1
1090789	0.1	1.1
1090789	0.1	1.1

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WFEC	ANADARKO 138KV'	90	-0.01307	WFEC	SLEEPING BEAR 138KV'	96	0.08619	-0.09926	11
WFEC	ANADARKO 138KV'	90	-0.01307	WFEC	SLEEPING BEAR 138KV'	96	0.08619	-0.09926	11
WFEC	BLUCAN14 138 138KV'	151.2	-0.01553	WFEC	MORLND 138KV'	171.048	0.08456	-0.10009	11
WFEC	BLUCAN14 138 138KV'	151.2	-0.01553	WFEC	MORLND 138KV'	171.048	0.08456	-0.10009	11
WFEC	BLUCAN14 138 138KV'	151.2	-0.01553	WFEC	SLEEPING BEAR 138KV'	96	0.08619	-0.10172	11
WFEC	BLUCAN14 138 138KV'	151.2	-0.01553	WFEC	SLEEPING BEAR 138KV'	96	0.08619	-0.10172	11
WFEC	ANADARKO 138KV'	90	-0.01307	WFEC	MORLND 138KV'	171.048	0.08456	-0.09763	12
WFEC	ANADARKO 138KV'	90	-0.01307	WFEC	MORLND 138KV'	171.048	0.08456	-0.09763	12
WFEC	ANADARKO 69KV'	76	-0.01144	WFEC	MORLND 138KV'	171.048	0.08456	-0.096	12
WFEC	ANADARKO 69KV'	76	-0.01144	WFEC	MORLND 138KV'	171.048	0.08456	-0.096	12
WFEC	ANADARKO 69KV'	76	-0.01144	WFEC	SLEEPING BEAR 138KV'	96	0.08619	-0.09763	12
WFEC	ANADARKO 69KV'	76	-0.01144	WFEC	SLEEPING BEAR 138KV'	96	0.08619	-0.09763	12
OKGE	AES 161KV'	78.99999	0.00058	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.0897	13
OKGE	AES 161KV'	78.99999	0.00058	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.0897	13
OKGE	HORSESHOE LAKE 138KV'	380	0.00196	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08832	13
OKGE	HORSESHOE LAKE 138KV'	380	0.00196	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08832	13
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00196	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08832	13
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00196	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08832	13
OKGE	HORSESHOE LAKE 138KV'	91	0.00196	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08832	13
OKGE	HORSESHOE LAKE 138KV'	91	0.00196	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08832	13
OKGE	HORSESHOE LAKE 69KV'	16	0.00174	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08854	13
OKGE	HORSESHOE LAKE 69KV'	16	0.00174	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08854	13
OKGE	MCCLAIN 138KV'	42	0.00174	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08854	13
OKGE	MCCLAIN 138KV'	42	0.00174	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08854	13
OKGE	MUSKOGEE 161KV'	166	0.00098	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.0893	13
OKGE	MUSKOGEE 161KV'	166	0.00098	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.0893	13
OKGE	MUSKOGEE 161KV'	31	0.00098	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.0893	13
OKGE	MUSKOGEE 161KV'	31	0.00098	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.0893	13
OKGE	MUSKOGEE 345KV'	20	0.00098	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08932	13
OKGE	MUSKOGEE 345KV'	20	0.00098	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08932	13
OKGE	MUSTANG 138KV'	365.5	0.00244	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08784	13
OKGE	MUSTANG 138KV'	365.5	0.00244	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08784	13
OKGE	MUSTANG 69KV'	106	0.00321	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08707	13
OKGE	MUSTANG 69KV'	106	0.00321	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08707	13
OKGE	ONE OAK 345KV'	334	0.00294	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08734	13
OKGE	ONE OAK 345KV'	334	0.00294	OKGE	SLEEPING BEAR 34KV'	120	0.09028	-0.08734	13



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

OKGE	REDBUD 345KV'	870	0.00223	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08805	13
OKGE	REDBUD 345KV'	870	0.00223	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08805	13
OKGE	REDBUD 345KV'	300	0.00223	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08805	13
OKGE	REDBUD 345KV'	300	0.00223	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08805	13
OKGE	SEMINOLE 138KV'	320.4242	0.00042	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08422	13
OKGE	SEMINOLE 138KV'	320.4242	0.00042	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08422	13
OKGE	SEMINOLE 138KV'	320.4242	0.00042	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08986	13
OKGE	SEMINOLE 138KV'	320.4242	0.00042	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08986	13
OKGE	SEMINOLE 345KV'	507.6	0.0009	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08938	13
OKGE	SEMINOLE 345KV'	507.6	0.0009	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08938	13
OKGE	TINKER 5G 138KV'	62	0.00143	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08885	13
OKGE	TINKER 5G 138KV'	62	0.00143	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.08885	13
OKGE	AES 161KV'	78.99999	0.00058	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08406	14
OKGE	AES 161KV'	78.99999	0.00058	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08406	14
OKGE	HORSESHOE LAKE 138KV'	380	0.00196	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08268	14
OKGE	HORSESHOE LAKE 138KV'	380	0.00196	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08268	14
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00196	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08268	14
OKGE	HORSESHOE LAKE 138KV'	380.5	0.00196	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08268	14
OKGE	HORSESHOE LAKE 138KV'	91	0.00196	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08268	14
OKGE	HORSESHOE LAKE 138KV'	91	0.00196	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08268	14
OKGE	HORSESHOE LAKE 69KV'	16	0.00174	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0829	14
OKGE	HORSESHOE LAKE 69KV'	16	0.00174	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0829	14
OKGE	MCCLAIN 138KV'	42	0.00174	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0829	14
OKGE	MCCLAIN 138KV'	42	0.00174	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0829	14
OKGE	MUSKOGEE 161KV'	166	0.00098	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08366	14
OKGE	MUSKOGEE 161KV'	166	0.00098	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08366	14
OKGE	MUSKOGEE 161KV'	31	0.00098	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08366	14
OKGE	MUSKOGEE 161KV'	31	0.00098	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08366	14
OKGE	MUSKOGEE 345KV'	20	0.00096	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08368	14
OKGE	MUSKOGEE 345KV'	20	0.00096	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08368	14
OKGE	MUSTANG 138KV'	365.5	0.00244	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0822	14
OKGE	MUSTANG 138KV'	365.5	0.00244	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0822	14
OKGE	MUSTANG 69KV'	106	0.00321	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08143	14
OKGE	MUSTANG 69KV'	106	0.00321	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08143	14
OKGE	ONE OAK 345KV'	334	0.00294	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0817	14
OKGE	ONE OAK 345KV'	334	0.00294	OKGE	'FPLWND2 34KV'	102	0.08464	-0.0817	14
OKGE	REDBUD 345KV'	870	0.00223	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08241	14
OKGE	REDBUD 345KV'	870	0.00223	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08241	14
OKGE	REDBUD 345KV'	300	0.00223	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08241	14
OKGE	REDBUD 345KV'	300	0.00223	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08241	14
OKGE	SEMINOLE 345KV'	507.6	0.0009	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08374	14
OKGE	SEMINOLE 345KV'	507.6	0.0009	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08374	14
OKGE	SOONER 138KV'	24.99997	0.00678	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.0835	14
OKGE	SOONER 138KV'	24.99997	0.00678	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.0835	14
OKGE	TINKER 5G 138KV'	62	0.00143	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08321	14
OKGE	TINKER 5G 138KV'	62	0.00143	OKGE	'FPLWND2 34KV'	102	0.08464	-0.08321	14
OKGE	SOONER 138KV'	24.99997	0.00678	OKGE	'FPLWND2 34KV'	102	0.08464	-0.07786	15
OKGE	SOONER 138KV'	24.99997	0.00678	OKGE	'FPLWND2 34KV'	102	0.08464	-0.07786	15
OMPA	OMPA-MANGUM 69KV'	6.3	-0.04897	OMPA	'OMPA-KINGFISHER BOWMAN 69KV'	9.704967	0.02411	-0.07308	16
OMPA	OMPA-MANGUM 69KV'	6.3	-0.04897	OMPA	'OMPA-KINGFISHER BOWMAN 69KV'	9.704967	0.02411	-0.07308	16
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02148	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.0688	17
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02148	OKGE	'SLEEPING BEAR 34KV'	120	0.09028	-0.0688	17
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02148	OKGE	'FPLWND2 34KV'	102	0.08464	-0.06316	18
OKGE	SOUTH 4TH ST 69KV'	42.7	0.02148	OKGE	'FPLWND2 34KV'	102	0.08464	-0.06316	18

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: HOLCOMB - PLYMELL - PIONEER TAP 115KV CKT 1  
 Limiting Facility: HOLCOMB - PLYMELL 115KV CKT 1  
 Direction: From->To  
 Line Outage: FLETCHER - HOLCOMB 115KV CKT 1  
 Flowgate: 56448563931564205644812107SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090310	2.3	3.8
1090456	0.4	3.8
1090613	1.1	3.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SUNC	CITY OF HUGOTON 69KV'	17.07	-0.40929	SUNC	'HOLCOMB 115KV'	271.4685	0.10163	-0.51092	7
SUNC	CITY OF HUGOTON 69KV'	17.07	-0.40929	SUNC	'GARDEN CITY 115KV'	22.85419	0.09328	-0.50257	8
SUNC	CITY OF LAKIN 115KV'	4.25	-0.3506	SUNC	'HOLCOMB 115KV'	271.4685	0.10163	-0.45223	8
SUNC	JOHNSON 69KV'	5.2	-0.37177	SUNC	'GARDEN CITY 115KV'	22.85419	0.09328	-0.46505	8
SUNC	JOHNSON 69KV'	5.2	-0.37177	SUNC	'HOLCOMB 115KV'	271.4685	0.10163	-0.4734	8
SUNC	CITY OF LAKIN 115KV'	4.25	-0.3506	SUNC	'GARDEN CITY 115KV'	22.85419	0.09328	-0.44388	9
WEPL	CIMARRON RIVER 115KV'	72	-0.36638	WEPL	'A. M. MULLERGREEN GENERATOR 115KV'	63	0.004	-0.37038	10
WEPL	CIMARRON RIVER 115KV'	72	-0.36638	WEPL	'CLIFTON 115KV'	41.49945	0.00187	-0.36825	10
WEPL	CIMARRON RIVER 115KV'	72	-0.36638	WEPL	'GRAY COUNTY WIND FARM 115KV'	63	-0.0779	-0.28848	13
WEPL	CIMARRON RIVER 115KV'	72	-0.36638	WEPL	'JUDSON LARGE 115KV'	114.131	-0.07921	-0.28717	13
SUNC	CITY OF GOODLAND 115KV'	13.9	-0.01659	SUNC	'HOLCOMB 115KV'	271.4685	0.10163	-0.11822	32
SUNC	CITY OF GOODLAND 115KV'	13.9	-0.01659	SUNC	'GARDEN CITY 115KV'	22.85419	0.09328	-0.10987	35

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: LINWOOD - MCWILLIE STREET 138KV CKT 1  
 Limiting Facility: LINWOOD - MCWILLIE STREET 138KV CKT 1  
 Direction: From->To  
 Line Outage: HARTS ISLAND - SOUTH SHREVEPORT 138KV CKT 1  
 Flowgate: 53422534281534145344614407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086238	0.6	9.0
1087745	8.5	9.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
AEPW	'ARSENAL HILL 69KV'	99	-0.36077	AEPW	'COGENTRIX 345KV'	200	-0.00424	-0.35653	25
AEPW	'ARSENAL HILL 69KV'	99	-0.36077	AEPW	'COMANCHE 138KV'	160	-0.00563	-0.35514	25

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	COMANCHE 69KV	63	-0.00565	-0.35512	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	FITZHUGH 161KV	126	-0.00242	-0.35835	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	FLINT CREEK 161KV	420	-0.00352	-0.35725	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	L&D13 69KV	11	-0.0028	-0.35797	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	NORTHEASTERN STATION 138KV	95	-0.00392	-0.35685	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	NORTHEASTERN STATION 138KV	405	-0.00392	-0.35685	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	NORTHEASTERN STATION 345KV	645	-0.00391	-0.35686	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	OEC 345KV	219	-0.00411	-0.35666	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	RIVERSIDE STATION 138KV	646	-0.00425	-0.35652	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	SOUTHWESTERN STATION 138KV	272	-0.00558	-0.35519	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	TULSA POWER STATION 138KV	124	-0.00421	-0.35656	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	TULSA POWER STATION 138KV	75	-0.00421	-0.35656	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	WEATHERFORD 34KV	148	-0.00528	-0.35549	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	WELEETKA 138KV	70	-0.00512	-0.35565	25
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	EASTMAN 138KV	355	-0.01316	-0.34761	26
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	KNOXLEE 138KV	225	-0.00927	-0.3515	26
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	LEBROCK 345KV	515	-0.01836	-0.34241	26
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	NARROWS 69KV	22	-0.01322	-0.34755	26
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	WELSH 345KV	990	-0.01278	-0.34799	26
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	WILKES 345KV	311	-0.01661	-0.34416	26
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	PIRKEY GENERATION 138KV	475	-0.02464	-0.33613	27
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	WILKES 138KV	319.9135	-0.0287	-0.33207	27
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	COGENTRIX 345KV	200	-0.00424	-0.20772	43
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	FITZHUGH 161KV	126	-0.00242	-0.20954	43
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	FLINT CREEK 161KV	420	-0.00352	-0.20844	43
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	NORTHEASTERN STATION 138KV	95	-0.00392	-0.20804	43
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	NORTHEASTERN STATION 138KV	405	-0.00392	-0.20804	43
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	NORTHEASTERN STATION 345KV	645	-0.00391	-0.20805	43
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	OEC 345KV	219	-0.00411	-0.20785	43
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	RIVERSIDE STATION 138KV	646	-0.00425	-0.20771	43
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	TULSA POWER STATION 138KV	75	-0.00421	-0.20775	43
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	TULSA POWER STATION 138KV	124	-0.00421	-0.20775	43
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	COMANCHE 138KV	160	-0.00563	-0.20633	44
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	COMANCHE 69KV	63	-0.00565	-0.20631	44
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	SOUTHWESTERN STATION 138KV	272	-0.00558	-0.20638	44
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	WEATHERFORD 34KV	148	-0.00528	-0.20668	44
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	WELEETKA 138KV	70	-0.00512	-0.20684	44
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	EASTMAN 138KV	355	-0.01316	-0.1988	45
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	KNOXLEE 138KV	225	-0.00927	-0.20269	45
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	NARROWS 69KV	22	-0.01322	-0.19874	45
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	WELSH 345KV	990	-0.01278	-0.19918	45
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	WILKES 345KV	311	-0.01661	-0.19535	46
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	LEBROCK 345KV	515	-0.01836	-0.1936	47
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	PIRKEY GENERATION 138KV	475	-0.02464	-0.18732	48
AEPW	LIEBERMAN 138KV	154	-0.21196	AEPW	WILKES 138KV	319.9135	-0.0287	-0.18326	49
AEPW	ARSENAL HILL 69KV	99	-0.36077	AEPW	LIEBERMAN 138KV	73.99999	-0.21196	-0.14881	61

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1  
 Limiting Facility: MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1  
 Direction: To->From  
 Line Outage: REDEL - STILWELL 161KV CKT 1  
 Flowgate: 59210592591580535796911307SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1089952	1.2	1.2								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
MIPU	ARIES 161KV	595	-0.02927	MIPU	SOUTH HARPER 161KV	315	0.32799	-0.35726	3	
MIPU	GREENWOOD 161KV	217.2393	-0.03697	MIPU	SOUTH HARPER 161KV	315	0.32799	-0.36496	3	
MIPU	LAKE ROAD 161KV	91	-0.01318	MIPU	SOUTH HARPER 161KV	315	0.32799	-0.34117	3	
MIPU	NEVADA 69KV	20.3	-0.00723	MIPU	SOUTH HARPER 161KV	315	0.32799	-0.33522	3	
MIPU	SIBLEY 161KV	18.44836	-0.02002	MIPU	SOUTH HARPER 161KV	315	0.32799	-0.34801	3	
MIPU	SIBLEY 69KV	1.200012	-0.0216	MIPU	SOUTH HARPER 161KV	315	0.32799	-0.34959	3	
MIPU	TWA 161KV	32.1	-0.02378	MIPU	SOUTH HARPER 161KV	315	0.32799	-0.35177	3	
MIPU	RALPH GREEN 69KV	73.7	0.06077	MIPU	SOUTH HARPER 161KV	315	0.32799	-0.26722	4	
KACP	GRAND AVENUE 161KV	65	-0.02786	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.0466	25	
KACP	NORTHEAST 13KV	56	-0.02775	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.04649	25	
KACP	NORTHEAST 13KV	56	-0.02775	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.04649	25	
KACP	NORTHEAST 13KV	58	-0.02775	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.04649	25	
KACP	NORTHEAST 13KV	59	-0.02775	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.04649	25	
KACP	NORTHEAST 161KV	55	-0.02775	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.04649	25	
KACP	NORTHEAST 161KV	58	-0.02775	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.04649	25	
KACP	NORTHEAST 161KV	58	-0.02775	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.04649	25	
KACP	NORTHEAST 161KV	58	-0.02775	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.04649	25	
KACP	MONTROSE 161KV	25.34082	-0.01882	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.03756	31	
KACP	BULL CREEK 161KV	111.8596	-0.0141	KACP	LACYGNE UNIT 345KV	958	0.01874	-0.03284	36	

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1  
 Limiting Facility: MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1  
 Direction: To->From  
 Line Outage: REDEL - STILWELL 161KV CKT 1  
 Flowgate: 59210592591580535796911308SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1089950	0.1	0.3							
1089952	0.2	0.3							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
MIPU	ARIES 161KV	595	-0.02915	MIPU	SOUTH HARPER 161KV	315	0.32814	-0.35729	1
MIPU	GREENWOOD 161KV	193.0817	-0.03686	MIPU	SOUTH HARPER 161KV	315	0.32814	-0.365	1
MIPU	LAKE ROAD 161KV	91	-0.0135	MIPU	SOUTH HARPER 161KV	315	0.32814	-0.34164	1
MIPU	NEVADA 69KV	20.3	-0.00711	MIPU	SOUTH HARPER 161KV	315	0.32814	-0.33525	1
MIPU	RALPH GREEN 69KV	73.7	0.06089	MIPU	SOUTH HARPER 161KV	315	0.32814	-0.26725	1

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

MIPU	SIBLEY 161KV'	18.38968	-0.01997	MIPU	SOUTH HARPER 161KV'	315	0.32814	-0.34811	1
MIPU	SIBLEY 69KV'	1.200012	-0.02156	MIPU	SOUTH HARPER 161KV'	315	0.32814	-0.3497	1
MIPU	TWA 161KV'	32.1	-0.02361	MIPU	SOUTH HARPER 161KV'	315	0.32814	-0.35175	1
KACP	GRAND AVENUE 161KV'	65	-0.02786	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.04689	7
KACP	NORTHEAST 13KV'	56	-0.02774	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.04677	7
KACP	NORTHEAST 13KV'	56	-0.02774	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.04677	7
KACP	NORTHEAST 13KV'	58	-0.02774	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.04677	7
KACP	NORTHEAST 13KV'	59	-0.02774	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.04677	7
KACP	NORTHEAST 161KV'	55	-0.02774	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.04677	7
KACP	NORTHEAST 161KV'	58	-0.02774	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.04677	7
KACP	NORTHEAST 161KV'	58	-0.02774	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.04677	7
KACP	NORTHEAST 161KV'	58	-0.02774	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.04677	7
KACP	NORTHEAST 161KV'	58	-0.02774	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.04677	7
KACP	MONTROSE 161KV'	24.39473	-0.0187	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.03773	8
KACP	BULL CREEK 161KV'	124.343	-0.01463	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.03366	9
KACP	GARDNER 161KV'	11	-0.01614	KACP	LACYGNE UNIT 345KV'	958	0.01903	-0.03517	9

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1  
 Limiting Facility: MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1  
 Direction: To->From  
 Line Outage: GRD OAK - PLEASANT HILL 345KV CKT 1  
 Flowgate: 59210592591591985920011308SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1089950		1.1							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
MIPU	ARIES 161KV'	595	-0.04476	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.44312	2
MIPU	GREENWOOD 161KV'	193.0817	-0.04777	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.44613	2
MIPU	LAKE ROAD 161KV'	91	-0.01621	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.41457	3
MIPU	NEVADA 69KV'	20.3	-0.01018	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.40854	3
MIPU	RALPH GREEN 69KV'	73.7	0.07409	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.32427	3
MIPU	SIBLEY 161KV'	18.38968	-0.0334	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.43176	3
MIPU	SIBLEY 69KV'	1.200012	-0.0327	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.43106	3
MIPU	TWA 161KV'	32.1	-0.0244	MIPU	SOUTH HARPER 161KV'	315	0.39836	-0.42276	3
KACP	NORTHEAST 13KV'	56	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 13KV'	56	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 13KV'	58	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 13KV'	59	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 161KV'	55	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 161KV'	58	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 161KV'	58	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 161KV'	58	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	NORTHEAST 161KV'	58	-0.02908	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.07008	15
KACP	GRAND AVENUE 161KV'	65	-0.02874	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.06974	16
KACP	MONTROSE 161KV'	24.39473	-0.02035	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.06135	18
KACP	MARSHALL 161KV'	54.1	-0.01561	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.05661	19
KACP	GARDNER 161KV'	11	-0.0068	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.0478	23
KACP	BULL CREEK 161KV'	124.343	-0.00436	KACP	LACYGNE UNIT 345KV'	958	0.041	-0.04536	24
MIPU	GREENWOOD 161KV'	193.0817	-0.04777	MIPU	LAKE ROAD 161KV'	35	-0.01621	-0.03156	34
MIPU	GREENWOOD 161KV'	193.0817	-0.04777	MIPU	LAKE ROAD 34KV'	92	-0.01621	-0.03156	34

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1  
 Limiting Facility: MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1  
 Direction: To->From  
 Line Outage: GRD OAK - PLEASANT HILL 345KV CKT 1  
 Flowgate: 59210592591591985920011406WP  
 Date Redispatch Needed: 12/1/06 - 4/1/07  
 Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090699		17.9							
1090705		17.9							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
MIPU	GREENWOOD 161KV'	247.3994	-0.04812	MIPU	SOUTH HARPER 161KV'	315	0.398	-0.44612	80
MIPU	ARIES 161KV'	595	-0.04512	MIPU	SOUTH HARPER 161KV'	315	0.398	-0.44312	81
MIPU	TWA 161KV'	32.1	-0.02452	MIPU	SOUTH HARPER 161KV'	315	0.398	-0.42252	85
MIPU	LAKE ROAD 161KV'	91	-0.01577	MIPU	SOUTH HARPER 161KV'	315	0.398	-0.41377	87
MIPU	RALPH GREEN 69KV'	73.7	0.07369	MIPU	SOUTH HARPER 161KV'	315	0.398	-0.32431	111
KACP	HAWTHORN 161KV'	423	-0.03185	KACP	LACYGNE UNIT 345KV'	962	0.04174	-0.07359	487
KACP	BULL CREEK 161KV'	308	-0.00386	KACP	LACYGNE UNIT 345KV'	962	0.04174	-0.0456	786

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1  
 Limiting Facility: MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1  
 Direction: To->From  
 Line Outage: GRD OAK - PLEASANT HILL 345KV CKT 1  
 Flowgate: 59210592591591985920011407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090699		3.8							
1090705		3.8							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
MIPU	ARIES 161KV'	595	-0.04491	MIPU	SOUTH HARPER 161KV'	315	0.39809	-0.443	17
MIPU	GREENWOOD 161KV'	15.8	-0.04792	MIPU	SOUTH HARPER 161KV'	315	0.39809	-0.44601	17
MIPU	SIBLEY 161KV'	18.67337	-0.03334	MIPU	SOUTH HARPER 161KV'	315	0.39809	-0.43143	17
MIPU	LAKE ROAD 161KV'	81	-0.01559	MIPU	SOUTH HARPER 161KV'	315	0.39809	-0.41368	18
MIPU	NEVADA 69KV'	20.3	-0.01053	MIPU	SOUTH HARPER 161KV'	315	0.39809	-0.40862	18
MIPU	TWA 161KV'	14.26904	-0.02429	MIPU	SOUTH HARPER 161KV'	315	0.39809	-0.42238	18

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

MIPU	ARIES 161KV'	595	-0.04491	MIPU	RALPH GREEN 69KV'	71.7	0.07387	-0.11878	63
MIPU	LAKE ROAD 161KV'	81	-0.01559	MIPU	RALPH GREEN 69KV'	71.7	0.07387	-0.08946	84
KACP	GRAND AVENUE 161KV'	65	-0.02853	KACP	LACYGNE UNIT 345KV'	958	0.04177	-0.0703	107
KACP	NORTHEAST 13KV'	58	-0.02888	KACP	LACYGNE UNIT 345KV'	958	0.04177	-0.07065	107
KACP	NORTHEAST 13KV'	59	-0.02888	KACP	LACYGNE UNIT 345KV'	958	0.04177	-0.07065	107
KACP	NORTHEAST 161KV'	58	-0.02888	KACP	LACYGNE UNIT 345KV'	958	0.04177	-0.07065	107
KACP	NORTHEAST 161KV'	58	-0.02888	KACP	LACYGNE UNIT 345KV'	958	0.04177	-0.07065	107

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1  
 Limiting Facility: MOCKINGBIRD HILL SWITCHING STATION - STULL SWITCHING STATION 115KV CKT 1  
 Direction: To->From  
 Line Outage: HOYT - STRANGER CREEK 345KV CKT 1  
 Flowgate: 57253572701567655677211107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1089950	1.7	3.6
1090609	0.4	3.6
1090699	0.6	3.6
1090705	0.6	3.6
1090729	0.3	3.6

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.31907	11
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.25173	14
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	HOLTON 115KV'	8.2	0.07498	-0.22993	16
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.2229	16
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.22326	16
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	ABILENE ENERGY CENTER 115KV'	40	0.06019	-0.21514	17
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.06312	-0.21807	17
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	0.04874	-0.20369	18
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	'SOUTH SENECA 115KV'	8.5	0.04144	-0.19639	19
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	EVANS ENERGY CENTER 138KV'	323.8247	0.01446	-0.16941	21
WERE	CITY OF GIRARD 69KV'	8.909	0.00179	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.16233	22
WERE	CITY OF IOLA 69KV'	13.372	0.00202	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.1621	22
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	CITY OF AUGUSTA 69KV'	20.02	0.01224	-0.16719	22
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	CITY OF WELLINGTON 69KV'	20	0.01184	-0.16679	22
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	GILL ENERGY CENTER 138KV'	155	0.01383	-0.16878	22
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	'WACO 138KV'	17.946	0.01389	-0.16884	22
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	HOLTON 115KV'	8.2	0.07498	-0.16259	22
WERE	CHANUTE 69KV'	31.504	0.00296	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.16116	23
WERE	CITY OF BURLINGTON 69KV'	7.7	0.00537	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.15875	23
WERE	CITY OF ERIE 69KV'	24.231	0.00296	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.16116	23
WERE	LATHAM1234.0 345KV'	150	0.00863	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.15549	23
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	CHANUTE 69KV'	56.296	0.00296	-0.15791	23
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	CITY OF IOLA 69KV'	24.256	0.00202	-0.15697	23
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00537	-0.16032	23
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.15556	23
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.15592	23
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00294	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.16118	23
WERE	CITY OF MULVANE 69KV'	10.899	0.01275	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.15137	24
WERE	CITY OF WELLINGTON 69KV'	23.5	0.01184	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.15228	24
WERE	CITY OF WINFIELD 69KV'	40	0.0109	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.15322	24
WERE	EVANS ENERGY CENTER 138KV'	419.1753	0.01446	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.14966	24
WERE	GETTY 69KV'	35	0.01244	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.15168	24
WERE	GILL ENERGY CENTER 138KV'	17.99999	0.01383	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.15029	24
WERE	GILL ENERGY CENTER 69KV'	118	0.01356	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.15056	24
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.06312	-0.15073	24
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	ABILENE ENERGY CENTER 115KV'	40	0.06019	-0.1478	25
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	0.04874	-0.13635	27
WERE	BPU - CITY OF MCPHERSON 115KV'	259	0.05151	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.11261	32
WERE	HUTCHINSON ENERGY CENTER 115KV'	263	0.04874	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.11538	32
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	0.04873	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.11539	32
WERE	SMOKYHILL 230 230KV'	72	0.05104	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.11308	32
WERE	CLAY CENTER JUNCTION 115KV'	29.516	0.06312	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.101	36
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	CITY OF AUGUSTA 69KV'	20.02	0.01224	-0.09985	36
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	EVANS ENERGY CENTER 138KV'	323.8247	0.01446	-0.10207	36
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	GILL ENERGY CENTER 138KV'	155	0.01383	-0.10144	36
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	'WACO 138KV'	17.946	0.01389	-0.1015	36
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	CITY OF WELLINGTON 69KV'	20	0.01184	-0.09945	37
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.06795	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.09617	38
WERE	JEFFREY ENERGY CENTER 345KV'	42	0.06831	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.16412	-0.09581	38
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00537	-0.09298	39
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	CHANUTE 69KV'	56.296	0.00296	-0.09057	40
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.08761	WERE	CITY OF IOLA 69KV'	24.256	0.00202	-0.08963	41
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.15495	WERE	LAWRENCE ENERGY CENTER 230KV'	228.5818	-0.08761	-0.06734	54
WERE	CHANUTE 69KV'	31.504	0.00296	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.06499	56
WERE	CHANUTE 69KV'	31.504	0.00296	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.06535	56
WERE	CITY OF ERIE 69KV'	24.231	0.00296	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.06499	56
WERE	CITY OF ERIE 69KV'	24.231	0.00296	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.06535	56
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00294	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.06501	56
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00294	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.06537	56
WERE	LATHAM1234.0 345KV'	150	0.00863	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.05932	61
WERE	LATHAM1234.0 345KV'	150	0.00863	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.05968	61
WERE	CITY OF WINFIELD 69KV'	40	0.0109	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.05741	63
WERE	CHANUTE 69KV'	31.504	0.00296	WERE	ABILENE ENERGY CENTER 115KV'	40	0.06019	-0.05723	64
WERE	CITY OF ERIE 69KV'	24.231	0.00296	WERE	ABILENE ENERGY CENTER 115KV'	40	0.06019	-0.05723	64
WERE	CITY OF WELLINGTON 69KV'	23.5	0.01184	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.05647	64
WERE	CITY OF WINFIELD 69KV'	40	0.0109	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.05705	64
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00294	WERE	ABILENE ENERGY CENTER 115KV'	40	0.06019	-0.05725	64
WERE	CITY OF WELLINGTON 69KV'	23.5	0.01184	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.05611	65
WERE	GETTY 69KV'	35	0.01244	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.05587	65
WERE	GETTY 69KV'	35	0.01244	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.05551	66
WERE	GILL ENERGY CENTER 69KV'	118	0.01356	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.05475	66
WERE	GILL ENERGY CENTER 69KV'	118	0.01356	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.05439	67
WERE	EVANS ENERGY CENTER 138KV'	419.1753	0.01446	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.06795	-0.05349	68
WERE	EVANS ENERGY CENTER 138KV'	419.1753	0.01446	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.06831	-0.05385	68
WERE	LATHAM1234.0 345KV'	150	0.00863	WERE	ABILENE ENERGY CENTER 115KV'	40	0.06019	-0.05156	71
WERE	CITY OF WINFIELD 69KV'	40	0.0109	WERE	ABILENE ENERGY CENTER 115KV'	40	0.06019	-0.04929	74
WERE	GETTY 69KV'	35	0.01244	WERE	ABILENE ENERGY CENTER 115KV'	40	0.06019	-0.04775	76
WERE	GILL ENERGY CENTER 69KV'	118	0.01356	WERE	ABILENE ENERGY CENTER 115KV'	40	0.06019	-0.04663	78



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WINFIELD 69KV'	40	0.00487	WERE	HOLTON 115KV'	8.2	0.04206	-0.03719	24
WERE	GETTY 69KV'	35	0.00572	WERE	HOLTON 115KV'	8.2	0.04206	-0.03634	24

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: YOAKUM COUNTY INTERCHANGE 230-115KV TRANSFORMER CKT 1  
 Flowgate: 51966519691518915189013407AP  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount					Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1090487	25.0	25.0								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.68696	36	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	TOLK 230KV'	1016.223	0.01764	-0.46041	54	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	CAPROCK 115KV'	36	0.01241	-0.45518	55	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	BLACKHAWK 115KV'	220	0.00507	-0.44784	56	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	CZ 69KV'	35	0.00466	-0.44743	56	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	HARRINGTON 230KV'	683.9658	0.00523	-0.448	56	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	SAN JUAN 230KV'	54	0.00289	-0.44566	56	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	STEER WATER 115KV'	36	0.00485	-0.44762	56	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	WILWIND 230KV'	72	0.00728	-0.45005	56	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	JONES 230KV'	104	-0.01215	-0.43062	58	
SPS	MUSTANG 115KV'	150	-0.44277	SPS	CUNNINGHAM 230KV'	56	-0.02586	-0.41691	60	
SPS	CUNNINGHAM 115KV'	71	-0.12228	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.36647	68	
SPS	CUNNINGHAM 115KV'	110	-0.12228	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.36647	68	
SPS	MADOX 115KV'	193	-0.12526	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.36945	68	
SPS	CUNNINGHAM 230KV'	250	-0.02586	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.27005	93	
SPS	LP-BRND2 69KV'	232	-0.01335	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.25754	97	
SPS	JONES 230KV'	625	-0.01215	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.25634	98	
SPS	HARRINGTON 230KV'	382.0342	0.00523	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.23896	105	
SPS	MOORE COUNTY 115KV'	48	0.00534	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.23885	105	
SPS	NICHOLS 115KV'	213	0.00502	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.23917	105	
SPS	NICHOLS 230KV'	244	0.00517	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.23902	105	
SPS	PLANTX 115KV'	253	0.00747	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.23672	106	
SPS	TOLK 345KV'	540	0.01211	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.23208	108	
SPS	PLANTX 230KV'	189	0.01597	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.22822	110	
SPS	TOLK 230KV'	603.777	0.01764	SPS	MUSTG5 118.0 230KV'	125	0.24419	-0.22655	110	
SPS	MADOX 115KV'	193	-0.12526	SPS	TOLK 230KV'	1016.223	0.01764	-0.1429	175	
SPS	CUNNINGHAM 115KV'	71	-0.12228	SPS	TOLK 230KV'	1016.223	0.01764	-0.13992	179	
SPS	CUNNINGHAM 115KV'	110	-0.12228	SPS	TOLK 230KV'	1016.223	0.01764	-0.13992	179	
SPS	MADOX 115KV'	193	-0.12526	SPS	WILWIND 230KV'	72	0.00728	-0.13254	189	
SPS	MADOX 115KV'	193	-0.12526	SPS	BLACKHAWK 115KV'	220	0.00507	-0.13033	192	
SPS	MADOX 115KV'	193	-0.12526	SPS	HARRINGTON 230KV'	683.9658	0.00523	-0.13049	192	
SPS	CUNNINGHAM 115KV'	71	-0.12228	SPS	WILWIND 230KV'	72	0.00728	-0.12956	193	
SPS	CUNNINGHAM 115KV'	110	-0.12228	SPS	WILWIND 230KV'	72	0.00728	-0.12956	193	
SPS	CUNNINGHAM 115KV'	71	-0.12228	SPS	BLACKHAWK 115KV'	220	0.00507	-0.12735	196	
SPS	CUNNINGHAM 115KV'	110	-0.12228	SPS	BLACKHAWK 115KV'	220	0.00507	-0.12735	196	
SPS	CUNNINGHAM 115KV'	71	-0.12228	SPS	HARRINGTON 230KV'	683.9658	0.00523	-0.12751	196	
SPS	CUNNINGHAM 115KV'	110	-0.12228	SPS	HARRINGTON 230KV'	683.9658	0.00523	-0.12751	196	
SPS	MADOX 115KV'	193	-0.12526	SPS	JONES 230KV'	104	-0.01215	-0.11311	221	
SPS	CUNNINGHAM 115KV'	110	-0.12228	SPS	JONES 230KV'	104	-0.01215	-0.11013	227	
SPS	CUNNINGHAM 230KV'	250	-0.02586	SPS	TOLK 230KV'	1016.223	0.01764	-0.0435	575	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: LEA COUNTY INTERCHANGE - YOAKUM COUNTY INTERCHANGE 230KV CKT 1  
 Flowgate: 51966519691522055189113407AP  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 April Minimum

Reservation	Relief Amount	Aggregate Relief Amount					Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1090487	41.8	53.3								
1090695	11.5	53.3								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
SPS	MUSTANG 115KV'	150	-0.3891	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.64601	82	
SPS	MADOX 115KV'	193	-0.21305	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.46996	113	
SPS	CUNNINGHAM 115KV'	71	-0.21043	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.46734	114	
SPS	CUNNINGHAM 115KV'	110	-0.21043	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.46734	114	
SPS	CUNNINGHAM 230KV'	250	-0.16709	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.424	126	
SPS	MUSTANG 115KV'	150	-0.3891	SPS	TOLK 230KV'	1016.223	0.00804	-0.39714	134	
SPS	MUSTANG 115KV'	150	-0.3891	SPS	BLACKHAWK 115KV'	220	0.00272	-0.39182	136	
SPS	MUSTANG 115KV'	150	-0.3891	SPS	HARRINGTON 230KV'	683.9658	0.0028	-0.3919	136	
SPS	MUSTANG 115KV'	150	-0.3891	SPS	WILWIND 230KV'	72	0.00385	-0.39295	136	
SPS	MUSTANG 115KV'	150	-0.3891	SPS	JONES 230KV'	104	-0.00553	-0.38357	139	
SPS	MUSTANG 115KV'	150	-0.3891	SPS	SAN JUAN 230KV'	54	-0.03782	-0.35128	152	
SPS	TOLK 345KV'	540	-0.01011	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.26702	199	
SPS	LP-BRND2 69KV'	232	-0.00613	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.26304	202	
SPS	JONES 230KV'	625	-0.00553	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.26244	203	
SPS	NICHOLS 115KV'	213	0.00267	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.25424	209	
SPS	HARRINGTON 230KV'	382.0342	0.0028	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.25411	210	
SPS	NICHOLS 230KV'	244	0.00277	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.25414	210	
SPS	PLANTX 115KV'	253	0.00492	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.25199	211	
SPS	TOLK 230KV'	603.777	0.00804	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.24887	214	
SPS	PLANTX 230KV'	189	0.00947	SPS	MUSTG5 118.0 230KV'	125	0.25691	-0.24744	215	
SPS	MADOX 115KV'	193	-0.21305	SPS	TOLK 230KV'	1016.223	0.00804	-0.22109	241	
SPS	CUNNINGHAM 115KV'	110	-0.21043	SPS	TOLK 230KV'	1016.223	0.00804	-0.21847	244	
SPS	MADOX 115KV'	193	-0.21305	SPS	BLACKHAWK 115KV'	220	0.00272	-0.21577	247	
SPS	MADOX 115KV'	193	-0.21305	SPS	HARRINGTON 230KV'	683.9658	0.0028	-0.21585	247	
SPS	CUNNINGHAM 115KV'	110	-0.21043	SPS	BLACKHAWK 115KV'	220	0.00272	-0.21315	250	
SPS	CUNNINGHAM 115KV'	110	-0.21043	SPS	HARRINGTON 230KV'	683.9658	0.0028	-0.21323	250	
SPS	MADOX 115KV'	193	-0.21305	SPS	JONES 230KV'	104	-0.00553	-0.20752	257	
SPS	CUNNINGHAM 115KV'	110	-0.21043	SPS	JONES 230KV'	104	-0.00553	-0.2049	260	

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	CUNNINGHAM 230KV'	250	-0.16709	SPS	TOLK 230KV'	1016.223	0.00804	-0.17513	304
SPS	CUNNINGHAM 230KV'	250	-0.16709	SPS	HARRINGTON 230KV'	683.9658	0.0028	-0.16989	313
SPS	CUNNINGHAM 230KV'	250	-0.16709	SPS	BLACKHAWK 115KV'	220	0.00272	-0.16981	314

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: LEA COUNTY INTERCHANGE - YOAKUM COUNTY INTERCHANGE 230KV CKT 1  
 Flowgate: 51966519691522055189113407FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1090487	42.2	46.5								
1090695	4.3	46.5								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
SPS	CUNNINGHAM 115KV'	71	-0.21041	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.46734	99	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.46734	99	
SPS	MADOX 115KV'	126.6467	-0.21303	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.46996	99	
SPS	CUNNINGHAM 230KV'	306	-0.16708	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.42401	110	
SPS	TOLK 345KV'	540	-0.01016	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.26709	174	
SPS	JONES 230KV'	243	-0.00537	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.2623	177	
SPS	LP-BRND2 69KV'	172	-0.00597	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.2629	177	
SPS	NICHOLS 115KV'	213	0.00259	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.25434	183	
SPS	NICHOLS 230KV'	244	0.00269	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.25424	183	
SPS	PLANTX 115KV'	253	0.0047	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.25223	184	
SPS	TOLK 230KV'	600.877	0.00799	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.24894	187	
SPS	PLANTX 230KV'	189	0.0094	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.24753	188	
SPS	MADOX 115KV'	126.6467	-0.21303	SPS	TOLK 230KV'	1019.123	0.00799	-0.22102	210	
SPS	CUNNINGHAM 115KV'	71	-0.21041	SPS	TOLK 230KV'	1019.123	0.00799	-0.2184	213	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	TOLK 230KV'	1019.123	0.00799	-0.2184	213	
SPS	MADOX 115KV'	126.6467	-0.21303	SPS	HARRINGTON 230KV'	1066	0.00272	-0.21575	215	
SPS	MADOX 115KV'	126.6467	-0.21303	SPS	BLACKHAWK 115KV'	220	0.00263	-0.21566	216	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	BLACKHAWK 115KV'	220	0.00263	-0.21304	218	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	HARRINGTON 230KV'	1066	0.00272	-0.21313	218	
SPS	MADOX 115KV'	126.6467	-0.21303	SPS	JONES 230KV'	486	-0.00537	-0.20766	224	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	JONES 230KV'	486	-0.00537	-0.20504	227	
SPS	CUNNINGHAM 230KV'	306	-0.16708	SPS	TOLK 230KV'	1019.123	0.00799	-0.17507	266	
SPS	CUNNINGHAM 230KV'	306	-0.16708	SPS	BLACKHAWK 115KV'	220	0.00263	-0.16971	274	
SPS	CUNNINGHAM 230KV'	306	-0.16708	SPS	HARRINGTON 230KV'	1066	0.00272	-0.1698	274	
SPS	CUNNINGHAM 230KV'	306	-0.16708	SPS	JONES 230KV'	486	-0.00537	-0.16171	287	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: LEA COUNTY INTERCHANGE - YOAKUM COUNTY INTERCHANGE 230KV CKT 1  
 Flowgate: 51966519691522055189113407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1090487	21.1	22.8								
1090695	1.6	22.8								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.646	35	
SPS	MADOX 115KV'	104.8643	-0.21303	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.46996	48	
SPS	CUNNINGHAM 115KV'	71	-0.21041	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.46734	49	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.46734	49	
SPS	CUNNINGHAM 230KV'	110	-0.16708	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.42401	54	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	TOLK 230KV'	1022.867	0.00799	-0.39706	57	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	BLACKHAWK 115KV'	220	0.00263	-0.3917	58	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	CZ 69KV'	35	0.00241	-0.39148	58	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	HARRINGTON 230KV'	1066	0.00272	-0.39179	58	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	STEER WATER 115KV'	24	0.0025	-0.39157	58	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	WILWIND 230KV'	48	0.00376	-0.39283	58	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	CAPROCK 115KV'	24	-0.00496	-0.38411	59	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	JONES 230KV'	243	-0.00537	-0.3837	59	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	LP-BRND2 69KV'	60	-0.00597	-0.3831	59	
SPS	MUSTANG 115KV'	29	-0.38907	SPS	SAN JUAN 230KV'	36	-0.03785	-0.35122	65	
SPS	TOLK 345KV'	540	-0.01015	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.26708	85	
SPS	JONES 230KV'	486	-0.00537	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.2623	87	
SPS	LP-BRND2 69KV'	172	-0.00597	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.2629	87	
SPS	NICHOLS 115KV'	213	0.00259	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.25434	89	
SPS	NICHOLS 230KV'	244	0.00269	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.25424	89	
SPS	MOORE COUNTY 115KV'	48	0.00279	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.25414	90	
SPS	PLANTX 115KV'	253	0.0047	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.25223	90	
SPS	TOLK 230KV'	597.1328	0.00799	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.24894	91	
SPS	PLANTX 230KV'	189	0.0094	SPS	MUSTG5 118.0 230KV'	210	0.25693	-0.24752	92	
SPS	MADOX 115KV'	104.8643	-0.21303	SPS	TOLK 230KV'	1022.867	0.00799	-0.22102	103	
SPS	CUNNINGHAM 115KV'	71	-0.21041	SPS	TOLK 230KV'	1022.867	0.00799	-0.2184	104	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	TOLK 230KV'	1022.867	0.00799	-0.2184	104	
SPS	MADOX 115KV'	104.8643	-0.21303	SPS	HARRINGTON 230KV'	1066	0.00272	-0.21575	105	
SPS	MADOX 115KV'	104.8643	-0.21303	SPS	WILWIND 230KV'	48	0.00376	-0.21679	105	
SPS	CUNNINGHAM 115KV'	71	-0.21041	SPS	WILWIND 230KV'	48	0.00376	-0.21417	106	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	WILWIND 230KV'	48	0.00376	-0.21417	106	
SPS	MADOX 115KV'	104.8643	-0.21303	SPS	BLACKHAWK 115KV'	220	0.00263	-0.21566	106	
SPS	CUNNINGHAM 115KV'	71	-0.21041	SPS	BLACKHAWK 115KV'	220	0.00263	-0.21304	107	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	BLACKHAWK 115KV'	220	0.00263	-0.21304	107	
SPS	CUNNINGHAM 115KV'	71	-0.21041	SPS	HARRINGTON 230KV'	1066	0.00272	-0.21313	107	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	HARRINGTON 230KV'	1066	0.00272	-0.21313	107	
SPS	MADOX 115KV'	104.8643	-0.21303	SPS	JONES 230KV'	243	-0.00537	-0.20766	110	
SPS	MADOX 115KV'	104.8643	-0.21303	SPS	LP-BRND2 69KV'	60	-0.00597	-0.20706	110	
SPS	CUNNINGHAM 115KV'	71	-0.21041	SPS	JONES 230KV'	243	-0.00537	-0.20504	111	
SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	JONES 230KV'	243	-0.00537	-0.20504	111	
SPS	CUNNINGHAM 115KV'	71	-0.21041	SPS	LP-BRND2 69KV'	60	-0.00597	-0.20444	111	

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	CUNNINGHAM 115KV'	110	-0.21041	SPS	LP-BRND2 69KV'	60	-0.00597	-0.20444	111
SPS	CUNNINGHAM 230KV'	110	-0.16708	SPS	TOLK 230KV'	1022.867	0.00799	-0.17507	130
SPS	CUNNINGHAM 230KV'	110	-0.16708	SPS	WILWIND 230KV'	48	0.00376	-0.17084	133
SPS	CUNNINGHAM 230KV'	110	-0.16708	SPS	BLACKHAWK 115KV'	220	0.00263	-0.16971	134
SPS	CUNNINGHAM 230KV'	110	-0.16708	SPS	HARRINGTON 230KV'	1066	0.00272	-0.1698	134
SPS	CUNNINGHAM 230KV'	110	-0.16708	SPS	JONES 230KV'	243	-0.00537	-0.16171	141
SPS	CUNNINGHAM 230KV'	110	-0.16708	SPS	LP-BRND2 69KV'	60	-0.00597	-0.16111	141

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51971 1  
 Flowgate: 51966519691GEN5197111107G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090487	17.3	17.3							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	MADOX 115KV'	75	-0.11884	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.32991	52
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.32732	53
SPS	JONES 230KV'	243	-0.00782	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.21889	79
SPS	LP-BRND2 69KV'	152	-0.00865	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.21972	79
SPS	HARRINGTON 230KV'	360	0.00348	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.20759	83
SPS	MOORE COUNTY 115KV'	48	0.00355	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.20752	83
SPS	NICHOLS 115KV'	107	0.00334	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.20773	83
SPS	NICHOLS 230KV'	107.5938	0.00344	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.20763	83
SPS	PLANTX 115KV'	48	0.00542	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.20565	84
SPS	TOLK 345KV'	540	0.00563	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.20544	84
SPS	TOLK 230KV'	594.5684	0.01138	SPS	MUSTG5 118.0 230KV'	210	0.21107	-0.19969	86
SPS	MADOX 115KV'	75	-0.11884	SPS	PLANTX 230KV'	189	0.01071	-0.12955	133
SPS	MADOX 115KV'	75	-0.11884	SPS	TOLK 230KV'	1025.432	0.01138	-0.13022	133
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	TOLK 230KV'	1025.432	0.01138	-0.12763	135
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	PLANTX 230KV'	189	0.01071	-0.12696	136
SPS	MADOX 115KV'	75	-0.11884	SPS	CAPROCK 115KV'	79.98182	0.00653	-0.12537	138
SPS	MADOX 115KV'	75	-0.11884	SPS	PLANTX 115KV'	205	0.00542	-0.12426	139
SPS	MADOX 115KV'	75	-0.11884	SPS	WILWIND 230KV'	159.9636	0.00484	-0.12368	140
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	CAPROCK 115KV'	79.98182	0.00653	-0.12278	141
SPS	MADOX 115KV'	75	-0.11884	SPS	BLACKHAWK 115KV'	220	0.00338	-0.12222	141
SPS	MADOX 115KV'	75	-0.11884	SPS	HARRINGTON 230KV'	706	0.00348	-0.12232	141
SPS	MADOX 115KV'	75	-0.11884	SPS	NICHOLS 115KV'	106	0.00334	-0.12218	141
SPS	MADOX 115KV'	75	-0.11884	SPS	NICHOLS 230KV'	136.4062	0.00344	-0.12228	141
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	PLANTX 115KV'	205	0.00542	-0.12167	142
SPS	MADOX 115KV'	75	-0.11884	SPS	STEER WATER 115KV'	79.98182	0.00323	-0.12207	142
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	WILWIND 230KV'	159.9636	0.00484	-0.12109	143
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	BLACKHAWK 115KV'	220	0.00338	-0.11963	144
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	HARRINGTON 230KV'	706	0.00348	-0.11973	144
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	NICHOLS 115KV'	106	0.00334	-0.11959	144
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	NICHOLS 230KV'	136.4062	0.00344	-0.11969	144
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	STEER WATER 115KV'	79.98182	0.00323	-0.11948	145
SPS	MADOX 115KV'	75	-0.11884	SPS	SAN JUAN 230KV'	119.9727	-0.00368	-0.11516	150
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	SAN JUAN 230KV'	119.9727	-0.00368	-0.11257	153
SPS	MADOX 115KV'	75	-0.11884	SPS	JONES 230KV'	486	-0.00782	-0.11102	156
SPS	MADOX 115KV'	75	-0.11884	SPS	LP-BRND2 69KV'	80	-0.00865	-0.11019	157
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	JONES 230KV'	486	-0.00782	-0.10843	159
SPS	CUNNINGHAM 115KV'	71	-0.11625	SPS	LP-BRND2 69KV'	80	-0.00865	-0.10776	161
SPS	MADOX 115KV'	75	-0.11884	SPS	CUNNINGHAM 230KV'	306	-0.03619	-0.08265	209

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51971 1  
 Flowgate: 51966519691GEN5197111107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090487	35.6	35.6							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	MADOX 115KV'	75	-0.11885	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.32991	108
SPS	LP-BRND2 69KV'	152	-0.00866	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.21972	162
SPS	JONES 230KV'	243	-0.00783	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.21889	163
SPS	NICHOLS 115KV'	66.00001	0.00333	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.20773	171
SPS	NICHOLS 230KV'	97	0.00343	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.20763	171
SPS	TOLK 345KV'	540	0.00562	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.20544	173
SPS	TOLK 230KV'	583.782	0.01137	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.19969	178

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51971 1  
 Flowgate: 51966519691GEN5197113107SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount							
1090487	28.0	28.0							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	MADOX 115KV'	75	-0.11885	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.32991	85



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	CUNNINGHAM 115KV'	71	-0.11627	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.32733	86
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.32733	86
SPS	CUNNINGHAM 230KV'	88	-0.0362	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.24726	113
SPS	LP-BRND2 69KV'	152	-0.00866	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.21972	127
SPS	JONES 230KV'	243	-0.00783	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.21889	128
SPS	MOORE COUNTY 115KV'	48	0.00354	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.20752	135
SPS	NICHOLS 115KV'	131	0.00333	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.20773	135
SPS	NICHOLS 230KV'	244	0.00343	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.20763	135
SPS	PLANTX 115KV'	64.2373	0.00541	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.20565	136
SPS	TOLK 345KV'	540	0.00562	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.20544	136
SPS	TOLK 230KV'	597.9482	0.01137	SPS	MUSTG5 118.0 230KV'	210	0.21106	-0.19969	140
SPS	MADOX 115KV'	75	-0.11885	SPS	TOLK 230KV'	1022.052	0.01137	-0.13022	215
SPS	MADOX 115KV'	75	-0.11885	SPS	PLANTX 230KV'	189	0.0107	-0.12955	216
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	TOLK 230KV'	1022.052	0.01137	-0.12764	219
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	PLANTX 230KV'	189	0.0107	-0.12697	220
SPS	MADOX 115KV'	75	-0.11885	SPS	CAPROCK 115KV'	79.98182	0.00652	-0.12537	223
SPS	MADOX 115KV'	75	-0.11885	SPS	PLANTX 115KV'	188.7627	0.00541	-0.12426	225
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	CAPROCK 115KV'	79.98182	0.00652	-0.12279	228
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	PLANTX 115KV'	188.7627	0.00541	-0.12168	230
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	WILWIND 230KV'	159.9636	0.00482	-0.12109	231
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	BLACKHAWK 115KV'	220	0.00336	-0.11963	234
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	HARRINGTON 230KV'	1066	0.00347	-0.11974	234
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	NICHOLS 115KV'	82	0.00333	-0.1196	234
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	STEER WATER 115KV'	79.98182	0.00321	-0.11948	234
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	SAN JUAN 230KV'	119.9727	-0.00369	-0.11258	249
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	JONES 230KV'	486	-0.00783	-0.10844	258

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51971 1  
 Flowgate: 51966519691GEN5197113407FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1090487	35.6	35.6								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
SPS	MADOX 115KV'	126.6467	-0.11882	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32992	108	
SPS	CUNNINGHAM 115KV'	71	-0.11623	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32733	109	
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32733	109	
SPS	CUNNINGHAM 230KV'	306	-0.03618	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.24728	144	
SPS	LP-BRND2 69KV'	172	-0.00846	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.21956	162	
SPS	JONES 230KV'	243	-0.00762	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.21872	163	
SPS	NICHOLS 115KV'	213	0.00324	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20786	171	
SPS	NICHOLS 230KV'	244	0.00334	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20776	171	
SPS	PLANTX 115KV'	253	0.00515	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20595	173	
SPS	TOLK 345KV'	540	0.00558	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20552	173	
SPS	PLANTX 230KV'	189	0.01063	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20047	178	
SPS	TOLK 230KV'	600.877	0.01133	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.19977	178	
SPS	MADOX 115KV'	126.6467	-0.11882	SPS	TOLK 230KV'	1019.123	0.01133	-0.13015	273	
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	TOLK 230KV'	1019.123	0.01133	-0.12756	279	
SPS	MADOX 115KV'	126.6467	-0.11882	SPS	BLACKHAWK 115KV'	220	0.00328	-0.1221	291	
SPS	MADOX 115KV'	126.6467	-0.11882	SPS	HARRINGTON 230KV'	1066	0.00338	-0.1222	291	
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	BLACKHAWK 115KV'	220	0.00328	-0.11951	298	
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	HARRINGTON 230KV'	1066	0.00338	-0.11961	298	
SPS	MADOX 115KV'	126.6467	-0.11882	SPS	JONES 230KV'	486	-0.00762	-0.1112	320	
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	JONES 230KV'	486	-0.00762	-0.10861	328	
SPS	CUNNINGHAM 230KV'	306	-0.03618	SPS	TOLK 230KV'	1019.123	0.01133	-0.04751	749	
SPS	CUNNINGHAM 230KV'	306	-0.03618	SPS	HARRINGTON 230KV'	1066	0.00338	-0.03956	900	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51971 1  
 Flowgate: 51966519691GEN5197113407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount								
1090487	23.1	23.1								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.60911	38	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	TOLK 230KV'	1022.867	0.01133	-0.40934	56	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	CAPROCK 115KV'	24	0.00647	-0.40448	57	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	HARRINGTON 230KV'	1066	0.00338	-0.40139	57	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	WILWIND 230KV'	48	0.00474	-0.40275	57	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	BLACKHAWK 115KV'	220	0.00328	-0.40129	58	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	CZ 69KV'	35	0.00301	-0.40102	58	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	STEER WATER 115KV'	24	0.00313	-0.40114	58	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	JONES 230KV'	243	-0.00762	-0.39039	59	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	LP-BRND2 69KV'	60	-0.00846	-0.38955	59	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	SAN JUAN 230KV'	36	-0.00372	-0.39429	59	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	CUNNINGHAM 230KV'	196	-0.03617	-0.36184	64	
SPS	MADOX 115KV'	104.8643	-0.11882	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32992	70	
SPS	CUNNINGHAM 115KV'	71	-0.11623	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32733	71	
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32733	71	
SPS	MUSTANG 115KV'	29	-0.39801	SPS	MADOX 115KV'	88.13574	-0.11882	-0.27919	83	
SPS	CUNNINGHAM 230KV'	110	-0.03617	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.24727	93	
SPS	LP-BRND2 69KV'	172	-0.00846	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.21956	105	
SPS	JONES 230KV'	486	-0.00762	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.21872	106	
SPS	MOORE COUNTY 115KV'	48	0.00346	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20764	111	
SPS	NICHOLS 115KV'	213	0.00324	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20786	111	
SPS	NICHOLS 230KV'	244	0.00334	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20776	111	
SPS	PLANTX 115KV'	253	0.00516	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20594	112	

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	TOLK 345KV	540	0.00558	SPS	MUSTG5 118.0 230KV	210	0.2111	-0.20552	112
SPS	PLANTX 230KV	189	0.01064	SPS	MUSTG5 118.0 230KV	210	0.2111	-0.20046	115
SPS	TOLK 230KV	597.1328	0.01133	SPS	MUSTG5 118.0 230KV	210	0.2111	-0.19977	116
SPS	MADOX 115KV	104.8643	-0.11882	SPS	TOLK 230KV	1022.867	0.01133	-0.13015	177
SPS	CUNNINGHAM 115KV	71	-0.11623	SPS	TOLK 230KV	1022.867	0.01133	-0.12756	181
SPS	CUNNINGHAM 115KV	110	-0.11623	SPS	TOLK 230KV	1022.867	0.01133	-0.12756	181
SPS	MADOX 115KV	104.8643	-0.11882	SPS	BLACKHAWK 115KV	220	0.00328	-0.1221	189
SPS	MADOX 115KV	104.8643	-0.11882	SPS	HARRINGTON 230KV	1066	0.00338	-0.1222	189
SPS	CUNNINGHAM 115KV	71	-0.11623	SPS	BLACKHAWK 115KV	220	0.00328	-0.11951	193
SPS	CUNNINGHAM 115KV	110	-0.11623	SPS	BLACKHAWK 115KV	220	0.00328	-0.11951	193
SPS	CUNNINGHAM 115KV	71	-0.11623	SPS	HARRINGTON 230KV	1066	0.00338	-0.11961	193
SPS	CUNNINGHAM 115KV	110	-0.11623	SPS	HARRINGTON 230KV	1066	0.00338	-0.11961	193
SPS	MADOX 115KV	104.8643	-0.11882	SPS	JONES 230KV	243	-0.00762	-0.1112	208
SPS	CUNNINGHAM 115KV	71	-0.11623	SPS	JONES 230KV	243	-0.00762	-0.10861	212
SPS	CUNNINGHAM 115KV	110	-0.11623	SPS	JONES 230KV	243	-0.00762	-0.10861	212
SPS	MADOX 115KV	104.8643	-0.11882	SPS	CUNNINGHAM 230KV	196	-0.03617	-0.08265	279
SPS	CUNNINGHAM 115KV	110	-0.11623	SPS	CUNNINGHAM 230KV	196	-0.03617	-0.08006	288

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51972 1  
 Flowgate: 51966519691GEN5197211107G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount										
1090487	16.3	16.3	Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.32732	50			
SPS	MADOX 115KV	75	-0.11884	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.32991	50			
SPS	LP-BRND2 69KV	152	-0.00865	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.21972	74			
SPS	JONES 230KV	243	-0.00782	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.21889	75			
SPS	HARRINGTON 230KV	360	0.00348	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.20759	79			
SPS	MOORE COUNTY 115KV	48	0.00355	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.20752	79			
SPS	NICHOLS 115KV	107	0.00334	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.20773	79			
SPS	NICHOLS 230KV	107.5938	0.00344	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.20763	79			
SPS	PLANTX 115KV	48	0.00542	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.20565	79			
SPS	TOLK 345KV	540	0.00563	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.20544	80			
SPS	TOLK 230KV	594.5684	0.01138	SPS	MUSTG5 118.0 230KV	210	0.21107	-0.19969	82			
SPS	MADOX 115KV	75	-0.11884	SPS	TOLK 230KV	1025.432	0.01138	-0.13022	125			
SPS	MADOX 115KV	75	-0.11884	SPS	PLANTX 230KV	189	0.01071	-0.12955	126			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	TOLK 230KV	1025.432	0.01138	-0.12763	128			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	PLANTX 230KV	189	0.01071	-0.12696	129			
SPS	MADOX 115KV	75	-0.11884	SPS	CAPROCK 115KV	79.98182	0.00653	-0.12537	130			
SPS	MADOX 115KV	75	-0.11884	SPS	PLANTX 115KV	205	0.00542	-0.12426	131			
SPS	MADOX 115KV	75	-0.11884	SPS	WILWIND 230KV	159.9636	0.00484	-0.12368	132			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	CAPROCK 115KV	79.98182	0.00653	-0.12278	133			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	PLANTX 115KV	205	0.00542	-0.12167	134			
SPS	MADOX 115KV	75	-0.11884	SPS	BLACKHAWK 115KV	220	0.00338	-0.12222	134			
SPS	MADOX 115KV	75	-0.11884	SPS	HARRINGTON 230KV	706	0.00348	-0.12232	134			
SPS	MADOX 115KV	75	-0.11884	SPS	NICHOLS 115KV	106	0.00334	-0.12218	134			
SPS	MADOX 115KV	75	-0.11884	SPS	NICHOLS 230KV	136.4062	0.00344	-0.12228	134			
SPS	MADOX 115KV	75	-0.11884	SPS	STEER WATER 115KV	79.98182	0.00323	-0.12207	134			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	WILWIND 230KV	159.9636	0.00484	-0.12109	135			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	HARRINGTON 230KV	706	0.00348	-0.11973	136			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	BLACKHAWK 115KV	220	0.00338	-0.11963	137			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	NICHOLS 115KV	106	0.00334	-0.11959	137			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	NICHOLS 230KV	136.4062	0.00344	-0.11969	137			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	STEER WATER 115KV	79.98182	0.00323	-0.11948	137			
SPS	MADOX 115KV	75	-0.11884	SPS	SAN JUAN 230KV	119.9727	-0.00368	-0.11516	142			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	SAN JUAN 230KV	119.9727	-0.00368	-0.11257	145			
SPS	MADOX 115KV	75	-0.11884	SPS	JONES 230KV	486	-0.00782	-0.11102	147			
SPS	MADOX 115KV	75	-0.11884	SPS	LP-BRND2 69KV	80	-0.00865	-0.11019	148			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	JONES 230KV	486	-0.00782	-0.10843	151			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	LP-BRND2 69KV	80	-0.00865	-0.1076	152			
SPS	MADOX 115KV	75	-0.11884	SPS	CUNNINGHAM 230KV	306	-0.03619	-0.08265	198			
SPS	CUNNINGHAM 115KV	71	-0.11625	SPS	CUNNINGHAM 230KV	306	-0.03619	-0.08006	204			

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51972 1  
 Flowgate: 51966519691GEN5197213107SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount										
1090487	27.3	27.3	Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	CUNNINGHAM 115KV	71	-0.11627	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.32733	83			
SPS	CUNNINGHAM 115KV	110	-0.11627	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.32733	83			
SPS	MADOX 115KV	75	-0.11885	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.32991	83			
SPS	CUNNINGHAM 230KV	88	-0.0362	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.24726	110			
SPS	LP-BRND2 69KV	152	-0.00866	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.21972	124			
SPS	JONES 230KV	243	-0.00783	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.21889	125			
SPS	MOORE COUNTY 115KV	48	0.00354	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.20752	131			
SPS	NICHOLS 115KV	131	0.00333	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.20773	131			
SPS	NICHOLS 230KV	244	0.00343	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.20763	131			
SPS	PLANTX 115KV	64.2373	0.00541	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.20565	133			
SPS	TOLK 345KV	540	0.00562	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.20544	133			
SPS	TOLK 230KV	597.9482	0.01137	SPS	MUSTG5 118.0 230KV	210	0.21106	-0.19969	137			
SPS	MADOX 115KV	75	-0.11885	SPS	TOLK 230KV	1022.052	0.01137	-0.13022	210			
SPS	MADOX 115KV	75	-0.11885	SPS	PLANTX 230KV	189	0.0107	-0.12955	211			
SPS	CUNNINGHAM 115KV	110	-0.11627	SPS	TOLK 230KV	1022.052	0.01137	-0.12764	214			

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	PLANTX 230KV'	189	0.0107	-0.12697	215
SPS	MADOX 115KV'	75	-0.11885	SPS	CAPROCK 115KV'	79.98182	0.00652	-0.12537	218
SPS	MADOX 115KV'	75	-0.11885	SPS	PLANTX 115KV'	188.7627	0.00541	-0.12426	220
SPS	MADOX 115KV'	75	-0.11885	SPS	WILWIND 230KV'	159.9636	0.00482	-0.12367	221
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	CAPROCK 115KV'	79.98182	0.00652	-0.12279	222
SPS	MADOX 115KV'	75	-0.11885	SPS	BLACKHAWK 115KV'	220	0.00336	-0.12221	223
SPS	MADOX 115KV'	75	-0.11885	SPS	HARRINGTON 230KV'	1066	0.00347	-0.12232	223
SPS	MADOX 115KV'	75	-0.11885	SPS	NICHOLS 115KV'	82	0.00333	-0.12218	223
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	PLANTX 115KV'	188.7627	0.00541	-0.12168	224
SPS	MADOX 115KV'	75	-0.11885	SPS	STEER WATER 115KV'	79.98182	0.00321	-0.12206	224
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	WILWIND 230KV'	159.9636	0.00482	-0.12109	225
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	BLACKHAWK 115KV'	220	0.00336	-0.11963	228
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	HARRINGTON 230KV'	1066	0.00347	-0.11974	228
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	NICHOLS 115KV'	82	0.00333	-0.1196	228
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	STEER WATER 115KV'	79.98182	0.00321	-0.11948	228
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	SAN JUAN 230KV'	119.9727	-0.00369	-0.11258	242
SPS	CUNNINGHAM 115KV'	110	-0.11627	SPS	JONES 230KV'	486	-0.00783	-0.10844	252

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51972 1  
 Flowgate: 51966519691GEN5197213107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090487	35.6	35.6							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	MADOX 115KV'	75	-0.11885	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.32991	108
SPS	CUNNINGHAM 115KV'	71	-0.11626	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.32732	109
SPS	LP-BRND2 69KV'	152	-0.00866	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.21972	162
SPS	JONES 230KV'	243	-0.00783	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.21889	163
SPS	NICHOLS 115KV'	66.00001	0.00333	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.20773	171
SPS	NICHOLS 230KV'	134.6729	0.00343	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.20763	171
SPS	TOLK 345KV'	540	0.00562	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.20544	173
SPS	TOLK 230KV'	591.5715	0.01137	SPS	MUSTG5 118.0 230KV'	360	0.21106	-0.19969	178

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51972 1  
 Flowgate: 51966519691GEN5197213407FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090487	35.6	35.6							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	MADOX 115KV'	126.6467	-0.11882	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32992	108
SPS	CUNNINGHAM 115KV'	71	-0.11623	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32733	109
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32733	109
SPS	CUNNINGHAM 230KV'	306	-0.03618	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.24728	144
SPS	LP-BRND2 69KV'	172	-0.00846	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.21956	162
SPS	JONES 230KV'	243	-0.00762	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.21872	163
SPS	NICHOLS 115KV'	213	0.00324	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20786	171
SPS	NICHOLS 230KV'	244	0.00334	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20776	171
SPS	PLANTX 115KV'	253	0.00515	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20595	173
SPS	TOLK 345KV'	540	0.00558	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20552	173
SPS	PLANTX 230KV'	189	0.01063	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20047	178
SPS	TOLK 230KV'	600.877	0.01133	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.19977	178
SPS	MADOX 115KV'	126.6467	-0.11882	SPS	TOLK 230KV'	1019.123	0.01133	-0.13015	273
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	TOLK 230KV'	1019.123	0.01133	-0.12756	279
SPS	MADOX 115KV'	126.6467	-0.11882	SPS	BLACKHAWK 115KV'	220	0.00328	-0.1221	291
SPS	MADOX 115KV'	126.6467	-0.11882	SPS	HARRINGTON 230KV'	1066	0.00338	-0.1222	291
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	BLACKHAWK 115KV'	220	0.00328	-0.11951	298
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	HARRINGTON 230KV'	1066	0.00338	-0.11961	298
SPS	MADOX 115KV'	126.6467	-0.11882	SPS	JONES 230KV'	486	-0.00762	-0.1112	320
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	JONES 230KV'	486	-0.00762	-0.10861	328
SPS	CUNNINGHAM 230KV'	306	-0.03618	SPS	TOLK 230KV'	1019.123	0.01133	-0.04751	749
SPS	CUNNINGHAM 230KV'	306	-0.03618	SPS	HARRINGTON 230KV'	1066	0.00338	-0.03956	900

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: GEN:51972 1  
 Flowgate: 51966519691GEN5197213407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090487	22.4	22.4							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	MUSTANG 115KV'	29	-0.39801	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.60911	37
SPS	MUSTANG 115KV'	29	-0.39801	SPS	CAPROCK 115KV'	24	0.00647	-0.40448	55
SPS	MUSTANG 115KV'	29	-0.39801	SPS	TOLK 230KV'	1022.867	0.01133	-0.40934	55
SPS	MUSTANG 115KV'	29	-0.39801	SPS	BLACKHAWK 115KV'	220	0.00328	-0.40129	56
SPS	MUSTANG 115KV'	29	-0.39801	SPS	CZ 69KV'	35	0.00301	-0.40102	56
SPS	MUSTANG 115KV'	29	-0.39801	SPS	HARRINGTON 230KV'	1066	0.00338	-0.40139	56

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	MUSTANG 115KV'	29	-0.39801	SPS	STEER WATER 115KV'	24	0.00313	-0.40114	56
SPS	MUSTANG 115KV'	29	-0.39801	SPS	WILWIND 230KV'	48	0.00474	-0.40275	56
SPS	MUSTANG 115KV'	29	-0.39801	SPS	JONES 230KV'	243	-0.00762	-0.39039	57
SPS	MUSTANG 115KV'	29	-0.39801	SPS	LP-BRND2 69KV'	60	-0.00846	-0.38955	57
SPS	MUSTANG 115KV'	29	-0.39801	SPS	SAN JUAN 230KV'	36	-0.00372	-0.39429	57
SPS	MUSTANG 115KV'	29	-0.39801	SPS	CUNNINGHAM 230KV'	196	-0.03617	-0.36184	62
SPS	CUNNINGHAM 115KV'	71	-0.11623	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32733	68
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32733	68
SPS	MADOX 115KV'	104.8643	-0.11882	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.32992	68
SPS	MUSTANG 115KV'	29	-0.39801	SPS	MADOX 115KV'	88.13574	-0.11882	-0.27919	80
SPS	CUNNINGHAM 230KV'	110	-0.03617	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.24727	90
SPS	JONES 230KV'	486	-0.00762	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.21872	102
SPS	LP-BRND2 69KV'	172	-0.00846	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.21956	102
SPS	MOORE COUNTY 115KV'	48	0.00346	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20764	108
SPS	NICHOLS 115KV'	213	0.00324	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20786	108
SPS	NICHOLS 230KV'	244	0.00334	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20776	108
SPS	PLANTX 115KV'	253	0.00516	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20594	109
SPS	TOLK 345KV'	540	0.00558	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20552	109
SPS	PLANTX 230KV'	189	0.01064	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.20046	112
SPS	TOLK 230KV'	597.1328	0.01133	SPS	MUSTG5 118.0 230KV'	210	0.2111	-0.19977	112
SPS	MADOX 115KV'	104.8643	-0.11882	SPS	TOLK 230KV'	1022.867	0.01133	-0.13015	172
SPS	CUNNINGHAM 115KV'	71	-0.11623	SPS	TOLK 230KV'	1022.867	0.01133	-0.12756	175
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	TOLK 230KV'	1022.867	0.01133	-0.12756	175
SPS	MADOX 115KV'	104.8643	-0.11882	SPS	BLACKHAWK 115KV'	220	0.00328	-0.1221	183
SPS	MADOX 115KV'	104.8643	-0.11882	SPS	HARRINGTON 230KV'	1066	0.00338	-0.1222	183
SPS	CUNNINGHAM 115KV'	71	-0.11623	SPS	BLACKHAWK 115KV'	220	0.00328	-0.11951	187
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	BLACKHAWK 115KV'	220	0.00328	-0.11951	187
SPS	CUNNINGHAM 115KV'	71	-0.11623	SPS	HARRINGTON 230KV'	1066	0.00338	-0.11961	187
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	HARRINGTON 230KV'	1066	0.00338	-0.11961	187
SPS	MADOX 115KV'	104.8643	-0.11882	SPS	JONES 230KV'	243	-0.00762	-0.1112	201
SPS	CUNNINGHAM 115KV'	71	-0.11623	SPS	JONES 230KV'	243	-0.00762	-0.10861	206
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	JONES 230KV'	243	-0.00762	-0.10861	206
SPS	MADOX 115KV'	104.8643	-0.11882	SPS	CUNNINGHAM 230KV'	196	-0.03617	-0.08265	271
SPS	CUNNINGHAM 115KV'	110	-0.11623	SPS	CUNNINGHAM 230KV'	196	-0.03617	-0.08006	279

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Mustang-San Andr-Amerada Hess 115KV  
 Limiting Facility: DENVER CITY INTERCHANGE N - MUSTANG STATION 115KV CKT 1  
 Direction: To->From  
 Line Outage: DENVER CITY INTERCHANGE S - MUSTANG STATION 115KV CKT 1  
 Flowgate: 51960519661519625196811407G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090487	1.9	1.9
1090695	0.1	1.9

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	MUSTANG 115KV'	300	0.4299	-0.59149	3
SPS	MADOX 115KV'	75	-0.16457	SPS	MUSTANG 115KV'	300	0.4299	-0.59447	3
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	MUSTANG 115KV'	300	0.4299	-0.50646	4
SPS	CZ 69KV'	4	0.00112	SPS	MUSTANG 115KV'	300	0.4299	-0.42878	4
SPS	HARRINGTON 230KV'	360	0.00127	SPS	MUSTANG 115KV'	300	0.4299	-0.42863	4
SPS	HUBRCO2 69KV'	6	0.00123	SPS	MUSTANG 115KV'	300	0.4299	-0.42867	4
SPS	JONES 230KV'	243	-0.00227	SPS	MUSTANG 115KV'	300	0.4299	-0.43217	4
SPS	LP-BRND2 69KV'	152	-0.00262	SPS	MUSTANG 115KV'	300	0.4299	-0.43252	4
SPS	MOORE COUNTY 115KV'	48	0.00129	SPS	MUSTANG 115KV'	300	0.4299	-0.42861	4
SPS	NICHOLS 115KV'	129.5491	0.0012	SPS	MUSTANG 115KV'	300	0.4299	-0.4287	4
SPS	NICHOLS 230KV'	244	0.00125	SPS	MUSTANG 115KV'	300	0.4299	-0.42865	4
SPS	PLANTX 115KV'	48	0.00215	SPS	MUSTANG 115KV'	300	0.4299	-0.42775	4
SPS	RIVERVIEW 69KV'	23	0.00123	SPS	MUSTANG 115KV'	300	0.4299	-0.42867	4
SPS	SIDRCH 69KV'	6	0.00123	SPS	MUSTANG 115KV'	300	0.4299	-0.42867	4
SPS	TOLK 230KV'	594.7025	0.00364	SPS	MUSTANG 115KV'	300	0.4299	-0.42626	4
SPS	TOLK 345KV'	540	-0.00516	SPS	MUSTANG 115KV'	300	0.4299	-0.43506	4
SPS	TUCUMCARI 115KV'	15	-0.00271	SPS	MUSTANG 115KV'	300	0.4299	-0.43261	4
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.31213	6
SPS	MADOX 115KV'	75	-0.16457	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.31511	6
SPS	MUSTG5 118.0 230KV'	150	0.15054	SPS	MUSTANG 115KV'	300	0.4299	-0.27936	7
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.2271	8
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	PLANTX 230KV'	189	0.00434	-0.16593	11
SPS	MADOX 115KV'	75	-0.16457	SPS	HARRINGTON 230KV'	706	0.00127	-0.16584	11
SPS	MADOX 115KV'	75	-0.16457	SPS	PLANTX 115KV'	205	0.00215	-0.16672	11
SPS	MADOX 115KV'	75	-0.16457	SPS	PLANTX 230KV'	189	0.00434	-0.16891	11
SPS	MADOX 115KV'	75	-0.16457	SPS	TOLK 230KV'	1025.297	0.00364	-0.16821	11
SPS	MADOX 115KV'	75	-0.16457	SPS	WILWIND 230KV'	72	0.00174	-0.16631	11
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	BLACKHAWK 115KV'	220	0.00123	-0.16282	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	CAPROCK 115KV'	36	-0.00271	-0.15888	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	CZ 69KV'	35	0.00112	-0.16271	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	HARRINGTON 230KV'	706	0.00127	-0.16286	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	HUBRCO2 69KV'	5	0.00123	-0.16282	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	JONES 230KV'	486	-0.00227	-0.15932	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	LP-BRND2 69KV'	80	-0.00262	-0.15897	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	NICHOLS 115KV'	83.45093	0.0012	-0.16279	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	PLANTX 115KV'	205	0.00215	-0.16374	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	SIDRCH 69KV'	14	0.00123	-0.16282	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	STEER WATER 115KV'	36	0.00116	-0.16275	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	TOLK 230KV'	1025.297	0.00364	-0.16523	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	WILWIND 230KV'	72	0.00174	-0.16333	12
SPS	JONES 230KV'	243	-0.00227	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.15281	12
SPS	LP-BRND2 69KV'	152	-0.00262	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.15316	12
SPS	MADOX 115KV'	75	-0.16457	SPS	BLACKHAWK 115KV'	220	0.00123	-0.1658	12
SPS	MADOX 115KV'	75	-0.16457	SPS	CAPROCK 115KV'	36	-0.00271	-0.16186	12
SPS	MADOX 115KV'	75	-0.16457	SPS	CZ 69KV'	35	0.00112	-0.16569	12
SPS	MADOX 115KV'	75	-0.16457	SPS	HUBRCO2 69KV'	5	0.00123	-0.1658	12
SPS	MADOX 115KV'	75	-0.16457	SPS	JONES 230KV'	486	-0.00227	-0.1623	12
SPS	MADOX 115KV'	75	-0.16457	SPS	LP-BRND2 69KV'	80	-0.00262	-0.16195	12
SPS	MADOX 115KV'	75	-0.16457	SPS	NICHOLS 115KV'	83.45093	0.0012	-0.16577	12
SPS	MADOX 115KV'	75	-0.16457	SPS	SIDRCH 69KV'	14	0.00123	-0.1658	12
SPS	MADOX 115KV'	75	-0.16457	SPS	STEER WATER 115KV'	36	0.00116	-0.16573	12
SPS	TOLK 345KV'	540	-0.00516	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.1557	12
SPS	TUCUMCARI 115KV'	15	-0.00271	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.15325	12
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	SAN JUAN 230KV'	54	-0.01891	-0.14268	13

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	HARRINGTON 230KV'	360	0.00127	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.14927	13
SPS	HUBRC02 69KV'	6	0.00123	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.14931	13
SPS	MADOX 115KV'	75	-0.16457	SPS	SAN JUAN 230KV'	54	-0.01891	-0.14566	13
SPS	MOORE COUNTY 115KV'	48	0.00129	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.14925	13
SPS	NICHOLS 115KV'	129.5491	0.0012	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.14934	13
SPS	NICHOLS 230KV'	244	0.00125	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.14929	13
SPS	PLANTX 115KV'	48	0.00215	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.14839	13
SPS	RIVERVIEW 69KV'	23	0.00123	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.14931	13
SPS	SIDRCH 69KV'	6	0.00123	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.14931	13
SPS	TOLK 230KV'	594.7025	0.00364	SPS	MUSTG5 118.0 230KV'	210	0.15054	-0.1469	13
SPS	MADOX 115KV'	75	-0.16457	SPS	CUNNINGHAM 230KV'	306	-0.07305	-0.09152	21
SPS	CUNNINGHAM 115KV'	71	-0.16159	SPS	CUNNINGHAM 230KV'	306	-0.07305	-0.08854	22
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	PLANTX 115KV'	205	0.00215	-0.07871	24
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	PLANTX 230KV'	189	0.00434	-0.0809	24
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	TOLK 230KV'	1025.297	0.00364	-0.0802	24
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	WILWIND 230KV'	72	0.00174	-0.0783	24
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	BLACKHAWK 115KV'	220	0.00123	-0.07779	25
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	CZ 69KV'	35	0.00112	-0.07768	25
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	HARRINGTON 230KV'	706	0.00127	-0.07783	25
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	NICHOLS 115KV'	83.45093	0.0012	-0.07776	25
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	SIDRCH 69KV'	14	0.00123	-0.07779	25
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	STEER WATER 115KV'	36	0.00116	-0.07772	25
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	CAPROCK 115KV'	36	-0.00271	-0.07385	26
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	JONES 230KV'	486	-0.00227	-0.07429	26
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	LP-BRND2 69KV'	80	-0.00262	-0.07394	26
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	SAN JUAN 230KV'	54	-0.01891	-0.05765	33

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Mustang-San Andr-Amerada Hess 115KV  
 Limiting Facility: DENVER CITY INTERCHANGE N - MUSTANG STATION 115KV CKT 1  
 Direction: To->From  
 Line Outage: DENVER CITY INTERCHANGE S - MUSTANG STATION 115KV CKT 1  
 Flowgate: 51960519661519625196813407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090487	13.0	15.1
1090695	2.1	15.1

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	MUSTANG 115KV'	300	0.42989	-0.59149	25
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	MUSTANG 115KV'	300	0.42989	-0.59149	25
SPS	MADOX 115KV'	75	-0.16457	SPS	MUSTANG 115KV'	300	0.42989	-0.59446	25
SPS	CARLSBAD 69KV'	18	-0.07657	SPS	MUSTANG 115KV'	300	0.42989	-0.50646	30
SPS	CUNNINGHAM 230KV'	88	-0.07306	SPS	MUSTANG 115KV'	300	0.42989	-0.50295	30
SPS	JONES 230KV'	243	-0.00227	SPS	MUSTANG 115KV'	300	0.42989	-0.43216	35
SPS	LP-BRND2 69KV'	152	-0.00262	SPS	MUSTANG 115KV'	300	0.42989	-0.43251	35
SPS	MOORE COUNTY 115KV'	48	0.00129	SPS	MUSTANG 115KV'	300	0.42989	-0.4286	35
SPS	NICHOLS 115KV'	131	0.0012	SPS	MUSTANG 115KV'	300	0.42989	-0.42869	35
SPS	NICHOLS 230KV'	244	0.00124	SPS	MUSTANG 115KV'	300	0.42989	-0.42865	35
SPS	PLANTX 115KV'	61.33887	0.00215	SPS	MUSTANG 115KV'	300	0.42989	-0.42774	35
SPS	RIVERVIEW 69KV'	23	0.00122	SPS	MUSTANG 115KV'	300	0.42989	-0.42867	35
SPS	TOLK 230KV'	595.5511	0.00363	SPS	MUSTANG 115KV'	300	0.42989	-0.42626	35
SPS	TOLK 345KV'	540	-0.00517	SPS	MUSTANG 115KV'	300	0.42989	-0.43506	35
SPS	TUCUMCARI 115KV'	15	-0.00272	SPS	MUSTANG 115KV'	300	0.42989	-0.43261	35
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.31213	48
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.31213	48
SPS	MADOX 115KV'	75	-0.16457	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.3151	48
SPS	MUSTG5 118.0 230KV'	150	0.15053	SPS	MUSTANG 115KV'	300	0.42989	-0.27936	54
SPS	CUNNINGHAM 230KV'	88	-0.07306	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.22359	67
SPS	MADOX 115KV'	75	-0.16457	SPS	PLANTX 230KV'	189	0.00433	-0.1689	89
SPS	MADOX 115KV'	75	-0.16457	SPS	PLANTX 115KV'	191.6611	0.00215	-0.16672	90
SPS	MADOX 115KV'	75	-0.16457	SPS	TOLK 230KV'	1024.449	0.00363	-0.1682	90
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	PLANTX 230KV'	189	0.00433	-0.16593	91
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	PLANTX 230KV'	189	0.00433	-0.16593	91
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	TOLK 230KV'	1024.449	0.00363	-0.16523	91
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	TOLK 230KV'	1024.449	0.00363	-0.16523	91
SPS	MADOX 115KV'	75	-0.16457	SPS	BLACKHAWK 115KV'	220	0.00122	-0.16579	91
SPS	MADOX 115KV'	75	-0.16457	SPS	CZ 69KV'	35	0.00112	-0.16569	91
SPS	MADOX 115KV'	75	-0.16457	SPS	HARRINGTON 230KV'	1066	0.00126	-0.16583	91
SPS	MADOX 115KV'	75	-0.16457	SPS	NICHOLS 115KV'	82	0.0012	-0.16577	91
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	PLANTX 115KV'	191.6611	0.00215	-0.16375	92
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	PLANTX 115KV'	191.6611	0.00215	-0.16375	92
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	BLACKHAWK 115KV'	220	0.00122	-0.16282	93
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	BLACKHAWK 115KV'	220	0.00122	-0.16282	93
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	CZ 69KV'	35	0.00112	-0.16272	93
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	CZ 69KV'	35	0.00112	-0.16272	93
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	HARRINGTON 230KV'	1066	0.00126	-0.16286	93
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	HARRINGTON 230KV'	1066	0.00126	-0.16286	93
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	NICHOLS 115KV'	82	0.0012	-0.1628	93
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	NICHOLS 115KV'	82	0.0012	-0.1628	93
SPS	MADOX 115KV'	75	-0.16457	SPS	JONES 230KV'	486	-0.00227	-0.1623	93
SPS	MADOX 115KV'	75	-0.16457	SPS	LP-BRND2 69KV'	80	-0.00262	-0.16195	93
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	JONES 230KV'	486	-0.00227	-0.15933	95
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	JONES 230KV'	486	-0.00227	-0.15933	95
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	LP-BRND2 69KV'	80	-0.00262	-0.15898	95
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	LP-BRND2 69KV'	80	-0.00262	-0.15898	95
SPS	TOLK 345KV'	540	-0.00517	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.1557	97
SPS	LP-BRND2 69KV'	152	-0.00262	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.15315	98
SPS	JONES 230KV'	243	-0.00227	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.1528	99
SPS	MOORE COUNTY 115KV'	48	0.00129	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.14924	101
SPS	NICHOLS 115KV'	131	0.0012	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.14933	101
SPS	NICHOLS 230KV'	244	0.00124	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.14929	101
SPS	PLANTX 115KV'	61.33887	0.00215	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.14838	102
SPS	TOLK 230KV'	595.5511	0.00363	SPS	MUSTG5 118.0 230KV'	210	0.15053	-0.1469	103
SPS	MADOX 115KV'	75	-0.16457	SPS	CUNNINGHAM 230KV'	218	-0.07306	-0.09151	165
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	CUNNINGHAM 230KV'	218	-0.07306	-0.08854	170
SPS	CUNNINGHAM 115KV'	110	-0.1616	SPS	CUNNINGHAM 230KV'	218	-0.07306	-0.08854	170
SPS	CUNNINGHAM 230KV'	88	-0.07306	SPS	PLANTX 230KV'	189	0.00433	-0.07739	195
SPS	CUNNINGHAM 230KV'	88	-0.07306	SPS	TOLK 230KV'	1024.449	0.00363	-0.07669	197
SPS	CUNNINGHAM 230KV'	88	-0.07306	SPS	PLANTX 115KV'	191.6611	0.00215	-0.07521	200
SPS	CUNNINGHAM 230KV'	88	-0.07306	SPS	BLACKHAWK 115KV'	220	0.00122	-0.07428	203

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	CUNNINGHAM 230KV'	88	-0.07306	SPS	HARRINGTON 230KV'	1066	0.00126	-0.07432	203
SPS	CUNNINGHAM 230KV'	88	-0.07306	SPS	NICHOLS 115KV'	82	0.0012	-0.07426	203
SPS	CUNNINGHAM 230KV'	88	-0.07306	SPS	JONES 230KV'	486	-0.00227	-0.07079	213
SPS	CUNNINGHAM 230KV'	88	-0.07306	SPS	LP-BRND2 69KV'	80	-0.00262	-0.07044	214

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Mustang-San Andr-Amerada Hess 115KV  
 Limiting Facility: DENVER CITY INTERCHANGE N - MUSTANG STATION 115KV CKT 1  
 Direction: To->From  
 Line Outage: DENVER CITY INTERCHANGE S - MUSTANG STATION 115KV CKT 1  
 Flowgate: 51960519661519625196813407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090487	23.8	26.9							
1090695	3.0	26.9							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	MUSTANG 115KV'	300	0.42989	-0.59149	45
SPS	MADOX 115KV'	75	-0.16457	SPS	MUSTANG 115KV'	300	0.42989	-0.59446	45
SPS	CARLSBAD 69KV'	18	-0.07656	SPS	MUSTANG 115KV'	300	0.42989	-0.50645	53
SPS	JONES 230KV'	243	-0.00227	SPS	MUSTANG 115KV'	300	0.42989	-0.43216	62
SPS	LP-BRND2 69KV'	152	-0.00262	SPS	MUSTANG 115KV'	300	0.42989	-0.43251	62
SPS	TOLK 345KV'	540	-0.00517	SPS	MUSTANG 115KV'	300	0.42989	-0.43506	62
SPS	NICHOLS 115KV'	66.00001	0.0012	SPS	MUSTANG 115KV'	300	0.42989	-0.42869	63
SPS	NICHOLS 230KV'	127.6196	0.00125	SPS	MUSTANG 115KV'	300	0.42989	-0.42864	63
SPS	PLANTX 115KV'	48	0.00215	SPS	MUSTANG 115KV'	300	0.42989	-0.42774	63
SPS	RIVERVIEW 69KV'	23	0.00122	SPS	MUSTANG 115KV'	300	0.42989	-0.42867	63
SPS	TOLK 230KV'	587.1002	0.00363	SPS	MUSTANG 115KV'	300	0.42989	-0.42626	63
SPS	MADOX 115KV'	75	-0.16457	SPS	MUSTG5 118.0 230KV'	360	0.15053	-0.3151	85
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	MUSTG5 118.0 230KV'	360	0.15053	-0.31213	86
SPS	MADOX 115KV'	75	-0.16457	SPS	PLANTX 230KV'	189	0.00433	-0.1689	159
SPS	MADOX 115KV'	75	-0.16457	SPS	TOLK 230KV'	1032.9	0.00363	-0.1682	160
SPS	MADOX 115KV'	75	-0.16457	SPS	PLANTX 115KV'	205	0.00215	-0.16672	161
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	PLANTX 230KV'	189	0.00433	-0.16593	162
SPS	MADOX 115KV'	75	-0.16457	SPS	BLACKHAWK 115KV'	220	0.00122	-0.16579	162
SPS	MADOX 115KV'	75	-0.16457	SPS	HARRINGTON 230KV'	1066	0.00126	-0.16583	162
SPS	MADOX 115KV'	75	-0.16457	SPS	NICHOLS 115KV'	147	0.0012	-0.16577	162
SPS	MADOX 115KV'	75	-0.16457	SPS	NICHOLS 230KV'	116.3804	0.00125	-0.16582	162
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	TOLK 230KV'	1032.9	0.00363	-0.16523	163
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	PLANTX 115KV'	205	0.00215	-0.16375	164
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	BLACKHAWK 115KV'	220	0.00122	-0.16282	165
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	HARRINGTON 230KV'	1066	0.00126	-0.16286	165
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	NICHOLS 115KV'	147	0.0012	-0.1628	165
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	NICHOLS 230KV'	116.3804	0.00125	-0.16285	165
SPS	MADOX 115KV'	75	-0.16457	SPS	JONES 230KV'	486	-0.00227	-0.1623	165
SPS	MADOX 115KV'	75	-0.16457	SPS	LP-BRND2 69KV'	80	-0.00262	-0.16195	166
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	JONES 230KV'	486	-0.00227	-0.15933	169
SPS	CUNNINGHAM 115KV'	71	-0.1616	SPS	LP-BRND2 69KV'	80	-0.00262	-0.15898	169
SPS	TOLK 345KV'	540	-0.00517	SPS	MUSTG5 118.0 230KV'	360	0.15053	-0.1557	172
SPS	LP-BRND2 69KV'	152	-0.00262	SPS	MUSTG5 118.0 230KV'	360	0.15053	-0.15315	175
SPS	JONES 230KV'	243	-0.00227	SPS	MUSTG5 118.0 230KV'	360	0.15053	-0.1528	176
SPS	NICHOLS 115KV'	66.00001	0.0012	SPS	MUSTG5 118.0 230KV'	360	0.15053	-0.14933	180
SPS	NICHOLS 230KV'	127.6196	0.00125	SPS	MUSTG5 118.0 230KV'	360	0.15053	-0.14928	180
SPS	TOLK 230KV'	587.1002	0.00363	SPS	MUSTG5 118.0 230KV'	360	0.15053	-0.1469	183

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Mustang-San Andr-Amerada Hess 115KV  
 Limiting Facility: DENVER CITY INTERCHANGE S - MUSTANG STATION 115KV CKT 1  
 Direction: To->From  
 Line Outage: DENVER CITY INTERCHANGE N - MUSTANG STATION 115KV CKT 1  
 Flowgate: 51962519681519605196613407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount							
1090487	9.5	11.0							
1090695	1.5	11.0							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	MUSTANG 115KV'	300	0.4299	-0.59061	19
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	MUSTANG 115KV'	300	0.4299	-0.59061	19
SPS	MADOX 115KV'	75	-0.16388	SPS	MUSTANG 115KV'	300	0.4299	-0.59378	19
SPS	CARLSBAD 69KV'	18	-0.07641	SPS	MUSTANG 115KV'	300	0.4299	-0.50631	22
SPS	CUNNINGHAM 230KV'	88	-0.07309	SPS	MUSTANG 115KV'	300	0.4299	-0.50299	22
SPS	JONES 230KV'	243	-0.00213	SPS	MUSTANG 115KV'	300	0.4299	-0.43203	25
SPS	LP-BRND2 69KV'	152	-0.00246	SPS	MUSTANG 115KV'	300	0.4299	-0.43236	25
SPS	TOLK 345KV'	540	-0.00535	SPS	MUSTANG 115KV'	300	0.4299	-0.43525	25
SPS	TUCUMCARI 115KV'	15	-0.00289	SPS	MUSTANG 115KV'	300	0.4299	-0.43279	25
SPS	MOORE COUNTY 115KV'	48	0.00122	SPS	MUSTANG 115KV'	300	0.4299	-0.42868	26
SPS	NICHOLS 115KV'	131	0.00114	SPS	MUSTANG 115KV'	300	0.4299	-0.42876	26
SPS	NICHOLS 230KV'	244	0.00118	SPS	MUSTANG 115KV'	300	0.4299	-0.42872	26
SPS	PLANTX 115KV'	61.33887	0.00205	SPS	MUSTANG 115KV'	300	0.4299	-0.42785	26
SPS	RIVERVIEW 69KV'	23	0.00116	SPS	MUSTANG 115KV'	300	0.4299	-0.42874	26
SPS	TOLK 230KV'	595.5511	0.00342	SPS	MUSTANG 115KV'	300	0.4299	-0.42648	26
SPS	MADOX 115KV'	75	-0.16388	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.31137	35
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.3082	36
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.3082	36
SPS	MUSTG5 118.0 230KV'	150	0.14749	SPS	MUSTANG 115KV'	300	0.4299	-0.28241	39
SPS	CARLSBAD 69KV'	18	-0.07641	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.2239	49
SPS	CUNNINGHAM 230KV'	88	-0.07309	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.22058	50
SPS	MADOX 115KV'	75	-0.16388	SPS	PLANTX 115KV'	191.6611	0.00205	-0.16593	66
SPS	MADOX 115KV'	75	-0.16388	SPS	PLANTX 230KV'	189	0.00415	-0.16803	66
SPS	MADOX 115KV'	75	-0.16388	SPS	TOLK 230KV'	1024.449	0.00342	-0.1673	66
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	PLANTX 230KV'	189	0.00415	-0.16486	67
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	PLANTX 230KV'	189	0.00415	-0.16486	67
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	TOLK 230KV'	1024.449	0.00342	-0.16413	67
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	TOLK 230KV'	1024.449	0.00342	-0.16413	67

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	MADOX 115KV'	75	-0.16388	SPS	BLACKHAWK 115KV'	220	0.00116	-0.16504	67
SPS	MADOX 115KV'	75	-0.16388	SPS	CZ 69KV'	35	0.00106	-0.16494	67
SPS	MADOX 115KV'	75	-0.16388	SPS	HARRINGTON 230KV'	1066	0.0012	-0.16508	67
SPS	MADOX 115KV'	75	-0.16388	SPS	NICHOLS 115KV'	82	0.00114	-0.16502	67
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	BLACKHAWK 115KV'	220	0.00116	-0.16187	68
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	BLACKHAWK 115KV'	220	0.00116	-0.16187	68
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	CZ 69KV'	35	0.00106	-0.16177	68
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	CZ 69KV'	35	0.00106	-0.16177	68
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	HARRINGTON 230KV'	1066	0.0012	-0.16191	68
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	HARRINGTON 230KV'	1066	0.0012	-0.16191	68
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	NICHOLS 115KV'	82	0.00114	-0.16185	68
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	NICHOLS 115KV'	82	0.00114	-0.16185	68
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	PLANTX 115KV'	191.6611	0.00205	-0.16276	68
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	PLANTX 115KV'	191.6611	0.00205	-0.16276	68
SPS	MADOX 115KV'	75	-0.16388	SPS	JONES 230KV'	486	-0.00213	-0.16175	68
SPS	MADOX 115KV'	75	-0.16388	SPS	LP-BRND2 69KV'	80	-0.00246	-0.16142	68
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	JONES 230KV'	486	-0.00213	-0.15858	69
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	JONES 230KV'	486	-0.00213	-0.15858	69
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	LP-BRND2 69KV'	80	-0.00246	-0.15825	70
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	LP-BRND2 69KV'	80	-0.00246	-0.15825	70
SPS	TOLK 345KV'	540	-0.00535	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.15284	72
SPS	LP-BRND2 69KV'	152	-0.00246	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.14995	73
SPS	JONES 230KV'	243	-0.00213	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.14962	74
SPS	MOORE COUNTY 115KV'	48	0.00122	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.14627	75
SPS	NICHOLS 115KV'	131	0.00114	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.14635	75
SPS	NICHOLS 230KV'	244	0.00118	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.14631	75
SPS	PLANTX 115KV'	61.33887	0.00205	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.14544	76
SPS	TOLK 230KV'	595.5511	0.00342	SPS	MUSTG5 118.0 230KV'	210	0.14749	-0.14407	76
SPS	MADOX 115KV'	75	-0.16388	SPS	CUNNINGHAM 230KV'	218	-0.07309	-0.09079	121
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	CUNNINGHAM 230KV'	218	-0.07309	-0.08762	126
SPS	CUNNINGHAM 115KV'	110	-0.16071	SPS	CUNNINGHAM 230KV'	218	-0.07309	-0.08762	126
SPS	CUNNINGHAM 230KV'	88	-0.07309	SPS	PLANTX 230KV'	189	0.00415	-0.07724	143
SPS	CUNNINGHAM 230KV'	88	-0.07309	SPS	TOLK 230KV'	1024.449	0.00342	-0.07651	144
SPS	CUNNINGHAM 230KV'	88	-0.07309	SPS	PLANTX 115KV'	191.6611	0.00205	-0.07514	147
SPS	CUNNINGHAM 230KV'	88	-0.07309	SPS	BLACKHAWK 115KV'	220	0.00116	-0.07425	148
SPS	CUNNINGHAM 230KV'	88	-0.07309	SPS	HARRINGTON 230KV'	1066	0.0012	-0.07429	148
SPS	CUNNINGHAM 230KV'	88	-0.07309	SPS	NICHOLS 115KV'	82	0.00114	-0.07423	148
SPS	CUNNINGHAM 230KV'	88	-0.07309	SPS	JONES 230KV'	486	-0.00213	-0.07096	155
SPS	CUNNINGHAM 230KV'	88	-0.07309	SPS	LP-BRND2 69KV'	80	-0.00246	-0.07063	156

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Mustang-San Andr-Amerada Hess 115KV  
 Limiting Facility: DENVER CITY INTERCHANGE S - MUSTANG STATION 115KV CKT 1  
 Direction: To->From  
 Line Outage: DENVER CITY INTERCHANGE N - MUSTANG STATION 115KV CKT 1  
 Flowgate: 51962519681519605196613407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090487	23.3	26.3
1090695	3.0	26.3

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	MADOX 115KV'	75	-0.16388	SPS	MUSTANG 115KV'	300	0.4299	-0.59378	44
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	MUSTANG 115KV'	300	0.4299	-0.59061	45
SPS	CARLSBAD 69KV'	18	-0.07641	SPS	MUSTANG 115KV'	300	0.4299	-0.50631	52
SPS	TOLK 345KV'	540	-0.00535	SPS	MUSTANG 115KV'	300	0.4299	-0.43525	60
SPS	JONES 230KV'	243	-0.00213	SPS	MUSTANG 115KV'	300	0.4299	-0.43203	61
SPS	LP-BRND2 69KV'	152	-0.00246	SPS	MUSTANG 115KV'	300	0.4299	-0.43236	61
SPS	NICHOLS 115KV'	66.00001	0.00114	SPS	MUSTANG 115KV'	300	0.4299	-0.42876	61
SPS	NICHOLS 230KV'	127.6196	0.00118	SPS	MUSTANG 115KV'	300	0.4299	-0.42872	61
SPS	RIVERVIEW 69KV'	23	0.00116	SPS	MUSTANG 115KV'	300	0.4299	-0.42874	61
SPS	PLANTX 115KV'	48	0.00205	SPS	MUSTANG 115KV'	300	0.4299	-0.42785	62
SPS	TOLK 230KV'	587.1002	0.00342	SPS	MUSTANG 115KV'	300	0.4299	-0.42648	62
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	MUSTG5 118.0 230KV'	360	0.14749	-0.3082	85
SPS	MADOX 115KV'	75	-0.16388	SPS	MUSTG5 118.0 230KV'	360	0.14749	-0.31137	85
SPS	MADOX 115KV'	75	-0.16388	SPS	PLANTX 230KV'	189	0.00415	-0.16803	157
SPS	MADOX 115KV'	75	-0.16388	SPS	TOLK 230KV'	1032.9	0.00342	-0.1673	157
SPS	MADOX 115KV'	75	-0.16388	SPS	PLANTX 115KV'	205	0.00205	-0.16593	159
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	PLANTX 230KV'	189	0.00415	-0.16486	160
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	TOLK 230KV'	1032.9	0.00342	-0.16413	160
SPS	MADOX 115KV'	75	-0.16388	SPS	BLACKHAWK 115KV'	220	0.00116	-0.16504	160
SPS	MADOX 115KV'	75	-0.16388	SPS	HARRINGTON 230KV'	1066	0.0012	-0.16508	160
SPS	MADOX 115KV'	75	-0.16388	SPS	NICHOLS 115KV'	147	0.00114	-0.16502	160
SPS	MADOX 115KV'	75	-0.16388	SPS	NICHOLS 230KV'	116.3804	0.00118	-0.16506	160
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	PLANTX 115KV'	205	0.00205	-0.16276	162
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	BLACKHAWK 115KV'	220	0.00116	-0.16187	163
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	HARRINGTON 230KV'	1066	0.0012	-0.16191	163
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	NICHOLS 115KV'	147	0.00114	-0.16185	163
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	NICHOLS 230KV'	116.3804	0.00118	-0.16189	163
SPS	MADOX 115KV'	75	-0.16388	SPS	JONES 230KV'	486	-0.00213	-0.16175	163
SPS	MADOX 115KV'	75	-0.16388	SPS	LP-BRND2 69KV'	80	-0.00246	-0.16142	163
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	JONES 230KV'	486	-0.00213	-0.15858	166
SPS	CUNNINGHAM 115KV'	71	-0.16071	SPS	LP-BRND2 69KV'	80	-0.00246	-0.15825	166
SPS	TOLK 345KV'	540	-0.00535	SPS	MUSTG5 118.0 230KV'	360	0.14749	-0.15284	172
SPS	JONES 230KV'	243	-0.00213	SPS	MUSTG5 118.0 230KV'	360	0.14749	-0.14962	176
SPS	LP-BRND2 69KV'	152	-0.00246	SPS	MUSTG5 118.0 230KV'	360	0.14749	-0.14995	176
SPS	NICHOLS 115KV'	66.00001	0.00114	SPS	MUSTG5 118.0 230KV'	360	0.14749	-0.14635	180
SPS	NICHOLS 230KV'	127.6196	0.00118	SPS	MUSTG5 118.0 230KV'	360	0.14749	-0.14631	180
SPS	TOLK 230KV'	587.1002	0.00342	SPS	MUSTG5 118.0 230KV'	360	0.14749	-0.14407	183

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: OAK - RAINBOW 69KV CKT 1  
 Limiting Facility: OAK - RAINBOW 69KV CKT 1  
 Direction: From->To  
 Line Outage: OAK - STROTHER FIELD (CITY OF WINFIELD) 69KV CKT 1  
 Flowgate: 57547575491575475755613307SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Reservation	Relief Amount	Aggregate Relief Amount							
1090609	6.0	8.8							
1090609	0.9	8.8							
1090609	0.4	8.8							
1090609	1.1	8.8							
1090609	0.5	8.8							

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	CITY OF WELLINGTON 69KV	41.45	0.06309	-0.76383	12
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'ABILENE ENERGY CENTER 115KV'	6.757809	-0.00235	-0.69839	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'CHANUTE 69KV'	46.617	-0.0025	-0.69824	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'CITY OF BURLINGTON 69KV'	7.8	-0.00437	-0.69637	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'CITY OF ERIE 69KV'	22.264	-0.0025	-0.69824	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'CITY OF FREDONIA 69KV'	5.225	-0.0029	-0.69784	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'CITY OF IOLA 69KV'	19.865	-0.00219	-0.69855	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'CITY OF MULVANE 69KV'	6.189	-0.00377	-0.69697	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'CLAY CENTER JUNCTION 115KV'	17.01001	-0.0024	-0.69834	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	-0.00437	-0.69637	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'EVANS ENERGY CENTER 138KV'	305	-0.00424	-0.6965	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'GILL ENERGY CENTER 138KV'	77	-0.00285	-0.69789	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'HOLTON 115KV'	12.2	-0.0029	-0.69784	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.00206	-0.69868	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'JEFFREY ENERGY CENTER 230KV'	470	-0.00246	-0.69828	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'JEFFREY ENERGY CENTER 345KV'	940	-0.00246	-0.69828	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'LAWRENCE ENERGY CENTER 115KV'	60	-0.0024	-0.69834	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'LAWRENCE ENERGY CENTER 230KV'	232.5762	-0.0024	-0.6983	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'SOUTH SENECA 115KV'	8.5	-0.00338	-0.69736	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'TECUMSEH ENERGY CENTER 115KV'	108	-0.00249	-0.69825	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'WACO 138KV'	17.947	-0.00299	-0.69775	13
WERE	CITY OF WINFIELD 69KV	40	-0.70074	WERE	'CITY OF AUGUSTA 69KV'	20.02	-0.05656	-0.64418	14

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: OAK - RAINBOW 69KV CKT 1  
 Limiting Facility: OAK - RAINBOW 69KV CKT 1  
 Direction: From->To  
 Line Outage: OAK - STROTHER FIELD (CITY OF WINFIELD) 69KV CKT 1  
 Flowgate: 57547575491575475755613307SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090609	1.1	9.1							
1090609	0.5	9.1							
1090609	1.1	9.1							
1090609	0.5	9.1							
1090609	5.9	9.1							

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	CITY OF WELLINGTON 69KV	41.45	0.06309	-0.76383	12
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'ABILENE ENERGY CENTER 115KV'	40	-0.00235	-0.69839	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'BPU - CITY OF MCPHERSON 115KV'	135	-0.00213	-0.69861	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'CHANUTE 69KV'	56.723	-0.0025	-0.69824	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'CITY OF BURLINGTON 69KV'	10.12	-0.00438	-0.69636	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'CITY OF ERIE 69KV'	22.274	-0.0025	-0.69824	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'CITY OF FREDONIA 69KV'	5.225	-0.0029	-0.69784	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'CITY OF GIRARD 69KV'	4.789	-0.00123	-0.69951	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'CITY OF IOLA 69KV'	24.267	-0.00219	-0.69855	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'CITY OF MULVANE 69KV'	8.288	-0.00377	-0.69697	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'CLAY CENTER JUNCTION 115KV'	28.875	-0.0024	-0.69834	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	-0.00438	-0.69636	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'EVANS ENERGY CENTER 138KV'	394.978	-0.00424	-0.6965	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'GILL ENERGY CENTER 138KV'	155	-0.00285	-0.69789	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'HOLTON 115KV'	12.2	-0.0029	-0.69784	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'HUTCHINSON ENERGY CENTER 115KV'	120	-0.00206	-0.69868	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'JEFFREY ENERGY CENTER 230KV'	470	-0.00246	-0.69828	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'JEFFREY ENERGY CENTER 345KV'	940	-0.00246	-0.69828	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'LAWRENCE ENERGY CENTER 115KV'	85	-0.0024	-0.69834	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'LAWRENCE ENERGY CENTER 230KV'	234.5685	-0.0024	-0.6983	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'SOUTH SENECA 115KV'	8.5	-0.00338	-0.69736	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'TECUMSEH ENERGY CENTER 115KV'	128	-0.00249	-0.69825	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'WACO 138KV'	17.96	-0.00299	-0.69775	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.70074	WERE	'CITY OF AUGUSTA 69KV'	25.12	-0.05656	-0.64418	14

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: PECAN CREEK (PECANCK1) 345-161-13.8KV TRANSFORMER CKT 1, 5TRIBES-PECAN CREEK 161KV CKT 1  
 Limiting Facility: PECAN CREEK (PECANCK1) 345-161-13.8KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FT SMITH - MUSKOGEE 345KV CKT 1  
 Flowgate: PECCANCK12751553025522413108SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1087757	0.6	0.7							
1087908	0.1	0.7							

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	'MUSKOGEE 161KV'	166	-0.2979	OKGE	'FPLWIND2 34KV'	102	0.036	-0.3339	2
OKGE	'MUSKOGEE 161KV'	31	-0.2979	OKGE	'FPLWIND2 34KV'	102	0.036	-0.3339	2
OKGE	'MUSKOGEE 161KV'	166	-0.2979	OKGE	'HORSESHOE LAKE 138KV'	380	0.03318	-0.33108	2
OKGE	'MUSKOGEE 161KV'	166	-0.2979	OKGE	'HORSESHOE LAKE 138KV'	202.4424	0.03318	-0.33108	2
OKGE	'MUSKOGEE 161KV'	166	-0.2979	OKGE	'HORSESHOE LAKE 138KV'	91	0.03318	-0.33108	2
OKGE	'MUSKOGEE 161KV'	31	-0.2979	OKGE	'HORSESHOE LAKE 138KV'	380	0.03318	-0.33108	2
OKGE	'MUSKOGEE 161KV'	31	-0.2979	OKGE	'HORSESHOE LAKE 138KV'	202.4424	0.03318	-0.33108	2
OKGE	'MUSKOGEE 161KV'	31	-0.2979	OKGE	'HORSESHOE LAKE 138KV'	91	0.03318	-0.33108	2
OKGE	'MUSKOGEE 161KV'	166	-0.2979	OKGE	'HORSESHOE LAKE 69KV'	16	0.03025	-0.32815	2
OKGE	'MUSKOGEE 161KV'	31	-0.2979	OKGE	'HORSESHOE LAKE 69KV'	16	0.03025	-0.32815	2



Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	MCCLAIN 138KV	478	0.03706	-0.33496	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	MCCLAIN 138KV	478	0.03706	-0.33496	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	MUSKOGEE 345KV	1516	0.14386	-0.44176	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	MUSKOGEE 345KV	1516	0.14386	-0.44176	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	MUSTANG 138KV	365.5	0.03699	-0.33489	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	MUSTANG 138KV	365.5	0.03699	-0.33489	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	MUSTANG 69KV	106	0.0368	-0.3347	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	MUSTANG 69KV	106	0.0368	-0.3347	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	ONE OAK 345KV	336	0.03892	-0.33682	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	ONE OAK 345KV	336	0.03892	-0.33682	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	REDBUD 345KV	94	0.04311	-0.34101	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	REDBUD 345KV	94	0.04311	-0.34101	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	SEMINOLE 138KV	475.9826	0.03928	-0.33718	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	SEMINOLE 138KV	475.9826	0.03928	-0.33718	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	SEMINOLE 345KV	996	0.04276	-0.34066	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	SEMINOLE 345KV	996	0.04276	-0.34066	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	SLEEPING BEAR 34KV	120	0.03607	-0.33397	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	SLEEPING BEAR 34KV	120	0.03607	-0.33397	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	SMITH COGEN 138KV	110	0.03691	-0.33481	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	SMITH COGEN 138KV	110	0.03691	-0.33481	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	SOONER 138KV	505	0.03462	-0.33252	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	SOONER 138KV	505	0.03462	-0.33252	2
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	SOONER 345KV	513	0.03616	-0.33406	2
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	SOONER 345KV	513	0.03616	-0.33406	2
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	BEAVER 161KV	103.9511	0.01948	-0.21795	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	BROKEN BOW 138KV	93.65855	0.02131	-0.21978	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	BULL SHOALS 161KV	294.1839	0.00486	-0.20333	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	CARTHAGE 69KV	32	0.01821	-0.21668	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	CLARENCE CANNON DAM 69KV	39.4309	0.01129	-0.20976	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	DENISON 138KV	59.63728	0.03199	-0.23046	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	KENNETT 69KV	7.5	-0.00036	-0.19811	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	KEYSTONE DAM 161KV	59.63728	0.04145	-0.23992	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	MALDEN 69KV	7	0.00041	-0.19888	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	NORFORK 161KV	20.01251	0.00311	-0.20158	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	SIKESTON 161KV	235	0.00175	-0.20022	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	STOCKTON 161KV	44.32771	0.0171	-0.21557	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	TABLE ROCK 161KV	187.3171	0.01342	-0.21189	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	TRUMAN 161KV	102.0638	0.01568	-0.21415	3
OKGE	MUSKOGEE 161KV	166	-0.2979	OKGE	AES 161KV	320	-0.06247	-0.23543	3
OKGE	MUSKOGEE 161KV	31	-0.2979	OKGE	AES 161KV	320	-0.06247	-0.23543	3
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	DARDANELLE 161KV	105.2658	-0.02737	-0.1711	4
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	GREERS FERRY 161KV	93.65855	-0.01041	-0.18806	4
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	JONESBORO 161KV	63	-0.00251	-0.19596	4
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	PARAGOULD 69KV	5.5	-0.0016	-0.19687	4
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	BEAVER 161KV	103.9511	0.01948	-0.16917	4
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	BROKEN BOW 138KV	93.65855	0.02131	-0.171	4
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	BULL SHOALS 161KV	294.1839	0.00486	-0.15455	4
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	CARTHAGE 69KV	32	0.01821	-0.1679	4
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	CLARENCE CANNON DAM 69KV	39.4309	0.01129	-0.16098	4
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	DENISON 138KV	59.63728	0.03199	-0.18168	4
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	KEYSTONE DAM 161KV	59.63728	0.04145	-0.19114	4
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	STOCKTON 161KV	44.32771	0.0171	-0.16679	4
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	TABLE ROCK 161KV	187.3171	0.01342	-0.16311	4
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	TRUMAN 161KV	102.0638	0.01568	-0.16537	4
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	BEAVER 161KV	103.9511	0.01948	-0.16917	4
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	BROKEN BOW 138KV	93.65855	0.02131	-0.171	4
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	BULL SHOALS 161KV	294.1839	0.00486	-0.15455	4
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	CARTHAGE 69KV	32	0.01821	-0.1679	4
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	CLARENCE CANNON DAM 69KV	39.4309	0.01129	-0.16098	4
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	DENISON 138KV	59.63728	0.03199	-0.18168	4
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	KEYSTONE DAM 161KV	59.63728	0.04145	-0.19114	4
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	STOCKTON 161KV	44.32771	0.0171	-0.16679	4
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	TABLE ROCK 161KV	187.3171	0.01342	-0.16311	4
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	TRUMAN 161KV	102.0638	0.01568	-0.16537	4
SWPA	EUFULA 138KV	8.968105	-0.09213	SWPA	KEYSTONE DAM 161KV	59.63728	0.04145	-0.13358	5
SWPA	EUFULA 161KV	4.484053	-0.09225	SWPA	KEYSTONE DAM 161KV	59.63728	0.04145	-0.1337	5
SWPA	FORT GIBSON 161KV	7.573475	-0.19847	SWPA	OZARK 161KV	98.06131	-0.05713	-0.14134	5
AEPW	L&D13 69KV	13	-0.06348	AEPW	COGENTRIX 345KV	665	0.06579	-0.12927	5
AEPW	L&D13 69KV	13	-0.06348	AEPW	OEC 345KV	206	0.07001	-0.13349	5
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	GREERS FERRY 161KV	93.65855	-0.01041	-0.13928	5
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	JONESBORO 161KV	63	-0.00251	-0.14718	5
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	KENNETT 69KV	7.5	-0.00036	-0.14933	5
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	MALDEN 69KV	7	0.00041	-0.1501	5
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	NORFORK 161KV	20.01251	0.00311	-0.1528	5
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	PARAGOULD 69KV	5.5	-0.0016	-0.14809	5
SWPA	TENKILLER FERRY 161KV	25.98999	-0.14969	SWPA	SIKESTON 161KV	235	0.00175	-0.15144	5
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	GREERS FERRY 161KV	93.65855	-0.01041	-0.13928	5
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	JONESBORO 161KV	63	-0.00251	-0.14718	5
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	KENNETT 69KV	7.5	-0.00036	-0.14933	5
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	MALDEN 69KV	7	0.00041	-0.1501	5
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	NORFORK 161KV	20.01251	0.00311	-0.1528	5
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	PARAGOULD 69KV	5.5	-0.0016	-0.14809	5
SWPA	WEBBERS FALLS 161KV	29.77548	-0.14969	SWPA	SIKESTON 161KV	235	0.00175	-0.15144	5
OKGE	CONTINENTAL EMPIRE 138KV	32	0.03462	OKGE	MUSKOGEE 345KV	1516	0.14386	-0.10924	6
SWPA	EUFULA 138KV	8.968105	-0.09213	SWPA	BEAVER 161KV	103.9511	0.01948	-0.11161	6
SWPA	EUFULA 138KV	8.968105	-0.09213	SWPA	BROKEN BOW 138KV	93.65855	0.02131	-0.11344	6
SWPA	EUFULA 138KV	8.968105	-0.09213	SWPA	CARTHAGE 69KV	32	0.01821	-0.11034	6
SWPA	EUFULA 138KV	8.968105	-0.09213	SWPA	DENISON 138KV	59.63728	0.03199	-0.12412	6
SWPA	EUFULA 138KV	8.968105	-0.09213	SWPA	STOCKTON 161KV	44.32771	0.0171	-0.10923	6
SWPA	EUFULA 138KV	8.968105	-0.09213	SWPA	TRUMAN 161KV	102.0638	0.01568	-0.10781	6

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Limiting Facility: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57550578371570395704214407FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.2	2.0
1090609	0.3	2.0
1090609	0.2	2.0

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.35582	5
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF MULVANE 69KV	4.891	0.01378	-0.3048	6
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	EVANS ENERGY CENTER 138KV	305	0.0102	-0.30122	6
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	GILL ENERGY CENTER 138KV	155	0.01043	-0.30145	6
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	WACO 138KV	17.946	0.0104	-0.30142	6
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	ABILENE ENERGY CENTER 115KV	40	0.00495	-0.29597	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CHANUTE 69KV	56.296	0.00402	-0.29504	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF BURLINGTON 69KV	4.8	0.00896	-0.29998	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF FREDONIA 69KV	5.225	0.0045	-0.29552	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF IOLA 69KV	24.256	0.00363	-0.29465	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CLAY CENTER JUNCTION 115KV	8.584003	0.00505	-0.29607	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00896	-0.29998	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	HOLTON 115KV	8.2	0.00553	-0.29655	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	HUTCHINSON ENERGY CENTER 115KV	72.17331	0.00451	-0.29553	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00511	-0.29613	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00509	-0.29611	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	LAWRENCE ENERGY CENTER 230KV	231.115	0.00504	-0.29606	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	SOUTH SENECA 115KV	8.5	0.00607	-0.29709	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00515	-0.29617	7
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF WELLINGTON 69KV	20	-0.09964	-0.19138	10
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.16444	12
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00896	-0.1086	18
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	EVANS ENERGY CENTER 138KV	305	0.0102	-0.10984	18
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	GILL ENERGY CENTER 138KV	155	0.01043	-0.11007	18
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	SOUTH SENECA 115KV	8.5	0.00607	-0.10571	18
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	WACO 138KV	17.946	0.0104	-0.11004	18
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	ABILENE ENERGY CENTER 115KV	40	0.00495	-0.10459	19
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	CHANUTE 69KV	56.296	0.00402	-0.10366	19
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	CITY OF IOLA 69KV	24.256	0.00363	-0.10327	19
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	CLAY CENTER JUNCTION 115KV	8.584003	0.00505	-0.10469	19
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	HOLTON 115KV	8.2	0.00553	-0.10517	19
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	HUTCHINSON ENERGY CENTER 115KV	72.17331	0.00451	-0.10415	19
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00511	-0.10475	19
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00509	-0.10473	19
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	LAWRENCE ENERGY CENTER 230KV	231.115	0.00504	-0.10468	19
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00515	-0.10479	19
WERE	BPU - CITY OF MCPHERSON 115KV	259	0.00461	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.06019	32
WERE	CHANUTE 69KV	31.504	0.00402	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.06078	32
WERE	CITY OF ERIE 69KV	24.231	0.00402	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.06078	32
WERE	CITY OF IOLA 69KV	13.372	0.00363	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.06117	32
WERE	HUTCHINSON ENERGY CENTER 115KV	310.8267	0.00451	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.06029	32
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.00451	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.06029	32
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00305	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.06175	32
WERE	SMOKYHIL 230 230KV	72	0.0045	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.0603	32
WERE	CLAY CENTER JUNCTION 115KV	29.516	0.00505	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05975	33
WERE	HOLTON 115KV	11.6	0.00553	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05927	33
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00511	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05969	33
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00509	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05971	33
WERE	LAWRENCE ENERGY CENTER 115KV	178	0.00495	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05985	33
WERE	LAWRENCE ENERGY CENTER 230KV	37.88498	0.00504	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05976	33
WERE	TECUMSEH ENERGY CENTER 115KV	52.99999	0.00515	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05965	33
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00514	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05966	33
WERE	GILL ENERGY CENTER 69KV	118	0.00661	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05819	34
WERE	LATHAM1234.0 345KV	150	0.00982	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05498	35
WERE	EVANS ENERGY CENTER 138KV	438	0.0102	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.0546	36
WERE	GILL ENERGY CENTER 138KV	17.99999	0.01043	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.05437	36
WERE	GETTY 69KV	35	0.026	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.0388	50
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.0375	OKGE	AES 161KV	320	-0.00249	-0.03501	56
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.0375	OKGE	MUSKOGEE 345KV	1516	-0.0036	-0.0339	58
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.0375	OKGE	SEMINOLE 138KV	461.789	-0.00691	-0.03059	64
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.0375	OKGE	SEMINOLE 345KV	590.52	-0.00701	-0.03049	64

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Limiting Facility: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57550578371570395704214407G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.1	1.1
1090609	0.3	1.1
1090609	0.1	1.1
1090609	0.2	1.1
1090609	0.4	1.1

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.35584	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00499	-0.29602	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	127.0369	0.00462	-0.29565	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CHANUTE 69KV	40.39	0.00405	-0.29508	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF BURLINGTON 69KV	4.8	0.00898	-0.30001	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF ERIE 69KV	2.301	0.00405	-0.29508	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF FREDONIA 69KV	5.225	0.00454	-0.29557	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF GIRARD 69KV	2.526	0.00228	-0.29331	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF IOLA 69KV	17.08	0.00367	-0.2947	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF MULVANE 69KV	4.922	0.01379	-0.30482	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	20.09	0.00898	-0.30001	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	EVANS ENERGY CENTER 138KV	340	0.01021	-0.30124	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	GILL ENERGY CENTER 138KV	155	0.01044	-0.30147	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HOLTON 115KV	12.2	0.00556	-0.29659	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0045	-0.29553	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00514	-0.29617	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00513	-0.29616	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00498	-0.29601	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	232.9228	0.00507	-0.2961	4

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV'	68.00001	0.00518	-0.29621	4
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	'WACO 138KV'	18	0.01042	-0.30145	4
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	CITY OF WELLINGTON 69KV'	27.198	-0.09964	-0.19139	6
WERE	OXFORD 138KV'	3	-0.13758	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.20239	6
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.16445	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	CITY OF MULVANE 69KV'	4.922	0.01379	-0.15137	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00499	-0.14257	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	'BPU - CITY OF MCPHERSON 115KV'	127.0369	0.00462	-0.1422	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	CHANUTE 69KV'	40.39	0.00405	-0.14163	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00898	-0.14656	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	CITY OF FREDONIA 69KV'	5.225	0.00454	-0.14212	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	CITY OF IOLA 69KV'	17.08	0.00367	-0.14125	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	20.09	0.00898	-0.14656	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	'EVANS ENERGY CENTER 138KV'	340	0.01021	-0.14779	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	'GILL ENERGY CENTER 138KV'	155	0.01044	-0.14802	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	HOLTON 115KV'	12.2	0.00556	-0.14314	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	0.0045	-0.14208	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00514	-0.14272	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.00513	-0.14271	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	'EVANS ENERGY CENTER 115KV'	60	0.00498	-0.14256	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	LAWRENCE ENERGY CENTER 230KV'	232.9228	0.00507	-0.14265	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	TECUMSEH ENERGY CENTER 115KV'	68.00001	0.00518	-0.14276	8
WERE	OXFORD 138KV'	3	-0.13758	WERE	'WACO 138KV'	18	0.01042	-0.148	8
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00898	-0.10862	10
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	CITY OF MULVANE 69KV'	4.922	0.01379	-0.11343	10
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	20.09	0.00898	-0.10862	10
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	'EVANS ENERGY CENTER 138KV'	340	0.01021	-0.10985	10
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	'GILL ENERGY CENTER 138KV'	155	0.01044	-0.11008	10
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	'WACO 138KV'	18	0.01042	-0.11006	10
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00499	-0.10463	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	'BPU - CITY OF MCPHERSON 115KV'	127.0369	0.00462	-0.10426	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	CHANUTE 69KV'	40.39	0.00405	-0.10369	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	CITY OF FREDONIA 69KV'	5.225	0.00454	-0.10418	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	CITY OF IOLA 69KV'	17.08	0.00367	-0.10331	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	HOLTON 115KV'	12.2	0.00556	-0.1052	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	0.0045	-0.10414	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00514	-0.10478	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.00513	-0.10477	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.00498	-0.10462	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	LAWRENCE ENERGY CENTER 230KV'	232.9228	0.00507	-0.10471	11
WERE	CITY OF WELLINGTON 69KV'	16.302	-0.09964	WERE	TECUMSEH ENERGY CENTER 115KV'	68.00001	0.00518	-0.10482	11
WERE	CITY OF GIRARD 69KV'	8.174	0.00228	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.06253	18
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00309	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.06172	18
WERE	BPU - CITY OF MCPHERSON 115KV'	46.96313	0.00462	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.06019	19
WERE	CHANUTE 69KV'	47.41	0.00405	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.06076	19
WERE	CITY OF ERIE 69KV'	24.229	0.00405	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.06076	19
WERE	CITY OF IOLA 69KV'	20.548	0.00367	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.06114	19
WERE	CITY OF OSAGE CITY 115KV'	8.85	0.00554	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05927	19
WERE	CLAY CENTER JUNCTION 115KV'	28.7	0.00509	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05972	19
WERE	GILL ENERGY CENTER 69KV'	118	0.00662	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05819	19
WERE	HOLTON 115KV'	7.6	0.00556	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05925	19
WERE	HUTCHINSON ENERGY CENTER 115KV'	263	0.0045	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.06031	19
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	0.0045	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.06031	19
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.00514	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05967	19
WERE	JEFFREY ENERGY CENTER 345KV'	42	0.00513	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05968	19
WERE	LAWRENCE ENERGY CENTER 115KV'	78	0.00498	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05983	19
WERE	LAWRENCE ENERGY CENTER 230KV'	36.07718	0.00507	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05974	19
WERE	SMOKYHIL 230 230KV'	72	0.00465	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.06016	19
WERE	SOUTH SENECA 115KV'	16.7	0.00609	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05872	19
WERE	ST JOHN 115KV'	7.5	0.00441	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.0604	19
WERE	TECUMSEH ENERGY CENTER 115KV'	123	0.00518	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05963	19
WERE	TECUMSEH ENERGY CENTER 69KV'	41	0.00517	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05964	19
WERE	CITY OF BURLINGTON 69KV'	7.7	0.00898	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05583	20
WERE	EVANS ENERGY CENTER 138KV'	313	0.01021	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.0546	21
WERE	GILL ENERGY CENTER 138KV'	17.99999	0.01044	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05437	21
WERE	LATHAM1234.0 345KV'	150	0.00984	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05497	21
WERE	CITY OF MULVANE 69KV'	10.868	0.01379	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05102	22
WERE	GETTY 69KV'	35	0.02601	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.0388	29

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Limiting Facility: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57550578371570395704214407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.4	5.8
1090609	0.9	5.8
1090609	0.3	5.8
1090609	0.7	5.8
1090609	3.5	5.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06479	-0.35582	16
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	CITY OF BURLINGTON 69KV'	7.8	0.00895	-0.29998	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00895	-0.29998	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	'EVANS ENERGY CENTER 138KV'	340	0.01018	-0.30121	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	'GILL ENERGY CENTER 138KV'	155	0.01042	-0.30145	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	HOLTON 115KV'	12.2	0.00551	-0.29654	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00509	-0.29612	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.00508	-0.29611	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	'SOUTH SENECA 115KV'	8.5	0.00604	-0.29707	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.00513	-0.29616	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	'WACO 138KV'	17.947	0.01039	-0.30142	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00494	-0.29597	20
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	'BPU - CITY OF MCPHERSON 115KV'	77.13525	0.0046	-0.29563	20
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	CHANUTE 69KV'	46.617	0.004	-0.29503	20
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	CITY OF ERIE 69KV'	22.264	0.004	-0.29503	20
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	CITY OF IOLA 69KV'	19.865	0.00362	-0.29465	20
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	CLAY CENTER JUNCTION 115KV'	17.01001	0.00503	-0.29606	20

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0045	-0.29553	20
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00494	-0.29597	20
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	231.9843	0.00502	-0.29605	20
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF WELLINGTON 69KV	41.45	-0.09965	-0.19138	30

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Limiting Facility: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57550578371570395704214407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.7	10.6
1090609	1.6	10.6
1090609	0.5	10.6
1090609	1.3	10.6
1090609	6.5	10.6

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF AUGUSTA 69KV	25.12	0.06479	-0.35582	30
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00895	-0.29998	35
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	EVANS ENERGY CENTER 138KV	544.001	0.01018	-0.30121	35
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	GILL ENERGY CENTER 138KV	171	0.01042	-0.30145	35
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	WACO 138KV	17.96	0.01039	-0.30142	35
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00494	-0.29597	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	135	0.0046	-0.29563	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CHANUTE 69KV	56.723	0.004	-0.29503	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF ERIE 69KV	22.274	0.004	-0.29503	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF IOLA 69KV	24.267	0.00362	-0.29465	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.00503	-0.29606	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	GILL ENERGY CENTER 69KV	45	0.00659	-0.29762	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HOLTON 115KV	12.2	0.00551	-0.29654	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.0045	-0.29553	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HUTCHINSON ENERGY CENTER 69KV	40	0.0045	-0.29553	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00509	-0.29612	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00508	-0.29611	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00494	-0.29597	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	232.7283	0.00502	-0.29605	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.00513	-0.29616	36
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF WELLINGTON 69KV	41.45	-0.09965	-0.19138	56

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Limiting Facility: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Direction: To->From  
 Line Outage: FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1  
 Flowgate: 57550578371570425706314407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.2	2.8
1090609	0.4	2.8
1090609	0.2	2.8
1090609	0.3	2.8
1090609	1.6	2.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.35582	8
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00494	-0.29597	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	77.13525	0.0046	-0.29563	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CHANUTE 69KV	46.617	0.004	-0.29503	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF BURLINGTON 69KV	7.8	0.00895	-0.29998	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF ERIE 69KV	22.264	0.004	-0.29503	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF FREDONIA 69KV	5.225	0.00449	-0.29552	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF IOLA 69KV	19.865	0.00362	-0.29465	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF MULVANE 69KV	6.189	0.01377	-0.3048	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CLAY CENTER JUNCTION 115KV	17.01001	0.00503	-0.29606	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00895	-0.29998	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	EVANS ENERGY CENTER 138KV	340	0.01018	-0.30121	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	GILL ENERGY CENTER 138KV	155	0.01042	-0.30145	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HOLTON 115KV	12.2	0.00551	-0.29654	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0045	-0.29553	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00509	-0.29612	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00508	-0.29611	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00494	-0.29597	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	231.9843	0.00502	-0.29605	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	SOUTH SENeca 115KV	8.5	0.00604	-0.29707	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00513	-0.29616	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	WACO 138KV	17.947	0.01039	-0.30142	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF WELLINGTON 69KV	41.45	-0.09965	-0.19138	14
WERE	CITY OF IOLA 69KV	17.763	0.00362	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06117	45
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00304	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06175	45
WERE	BPU - CITY OF MCPHERSON 115KV	136.8647	0.0046	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06019	46
WERE	CHANUTE 69KV	41.183	0.004	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06079	46
WERE	CLAY CENTER JUNCTION 115KV	21.08999	0.00503	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05976	46
WERE	HUTCHINSON ENERGY CENTER 115KV	263	0.0045	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06029	46
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.0045	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06029	46
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00509	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.0597	46
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00508	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05971	46
WERE	LAWRENCE ENERGY CENTER 115KV	78	0.00494	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05985	46
WERE	LAWRENCE ENERGY CENTER 230KV	37.01572	0.00502	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05977	46
WERE	SMOKYHIL 230 230KV	72	0.00449	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.0603	46
WERE	TECUMSEH ENERGY CENTER 115KV	52.99999	0.00513	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05966	46
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00513	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05966	46
WERE	GILL ENERGY CENTER 69KV	118	0.00659	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.0582	48

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	LATHAM1234.0 345KV'	150	0.0098	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06479	-0.05499	50
WERE	EVANS ENERGY CENTER 138KV'	313	0.01018	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06479	-0.05461	51
WERE	GILL ENERGY CENTER 138KV'	17.99999	0.01042	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06479	-0.05437	51

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Limiting Facility: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Direction: To->From  
 Line Outage: FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1  
 Flowgate: 57550578371570425706314407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.5	6.9
1090609	1.1	6.9
1090609	0.4	6.9
1090609	0.8	6.9
1090609	4.2	6.9

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.35582	19
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00494	-0.29597	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'BPU - CITY OF MCPHERSON 115KV'	135	0.0046	-0.29563	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'CHANUTE 69KV'	56.723	0.004	-0.29503	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'CITY OF BURLINGTON 69KV'	10.12	0.00895	-0.29998	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'CITY OF ERIE 69KV'	22.274	0.004	-0.29503	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'CITY OF MULVANE 69KV'	8.288	0.01377	-0.3048	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'CLAY CENTER JUNCTION 115KV'	28.875	0.00503	-0.29606	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00895	-0.29998	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'EVANS ENERGY CENTER 138KV'	544.001	0.01018	-0.30121	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'GILL ENERGY CENTER 138KV'	171	0.01042	-0.30145	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'GILL ENERGY CENTER 69KV'	45	0.00659	-0.29762	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'HOLTON 115KV'	12.2	0.00551	-0.29654	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'HUTCHINSON ENERGY CENTER 115KV'	210	0.0045	-0.29553	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'HUTCHINSON ENERGY CENTER 69KV'	40	0.0045	-0.29553	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.00509	-0.29612	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.00508	-0.29611	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'LAWRENCE ENERGY CENTER 115KV'	105	0.00494	-0.29597	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'LAWRENCE ENERGY CENTER 230KV'	232.7283	0.00502	-0.29605	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'SOUTH SENeca 115KV'	8.5	0.00604	-0.29707	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'TECUMSEH ENERGY CENTER 115KV'	158	0.00513	-0.29616	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'WACO 138KV'	17.96	0.01039	-0.30142	23
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'CITY OF IOLA 69KV'	24.267	0.00362	-0.29465	24
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	'CITY OF WELLINGTON 69KV'	41.45	-0.09965	-0.19138	36

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Limiting Facility: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-40  
 Flowgate: 57550578371SPP-WERE-404407FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.1	0.5
1090609	0.1	0.5
1090609	0.1	0.5
1090609	0.1	0.5
1090609	0.1	0.5

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.0627	-0.37126	1
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00461	-0.31317	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'CHANUTE 69KV'	56.296	0.00382	-0.31238	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'CITY OF BURLINGTON 69KV'	4.8	0.0084	-0.31696	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'CITY OF ERIE 69KV'	2.299	0.00382	-0.31238	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00429	-0.31285	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'CITY OF GIRARD 69KV'	1.791	0.00212	-0.31068	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'CITY OF IOLA 69KV'	24.256	0.00344	-0.312	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'CITY OF MULVANE 69KV'	4.891	0.01258	-0.32114	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'CITY OF WELLINGTON 69KV'	20	-0.11253	-0.19603	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'CLAY CENTER JUNCTION 115KV'	8.584003	0.0047	-0.31326	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.0084	-0.31696	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'EVANS ENERGY CENTER 138KV'	305	0.00935	-0.31791	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'GILL ENERGY CENTER 138KV'	155	0.00919	-0.31775	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'HOLTON 115KV'	8.2	0.00518	-0.31374	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'HUTCHINSON ENERGY CENTER 115KV'	72.17331	0.00418	-0.31274	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.00477	-0.31333	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.00475	-0.31331	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'LAWRENCE ENERGY CENTER 230KV'	231.115	0.0047	-0.31326	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'SOUTH SENeca 115KV'	8.5	0.00571	-0.31427	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'TECUMSEH ENERGY CENTER 115KV'	108	0.0048	-0.31336	2
WERE	CITY OF WINFIELD 69KV'	40	-0.30856	WERE	'WACO 138KV'	17.946	0.00921	-0.31777	2
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.0627	-0.17523	3
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00461	-0.11714	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'CHANUTE 69KV'	56.296	0.00382	-0.11635	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'CITY OF BURLINGTON 69KV'	4.8	0.0084	-0.12093	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'CITY OF ERIE 69KV'	2.299	0.00382	-0.11635	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00429	-0.11682	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'CITY OF GIRARD 69KV'	1.791	0.00212	-0.11465	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'CITY OF IOLA 69KV'	24.256	0.00344	-0.11597	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'CITY OF MULVANE 69KV'	4.891	0.01258	-0.12511	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'CLAY CENTER JUNCTION 115KV'	8.584003	0.0047	-0.11723	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.0084	-0.12093	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'EVANS ENERGY CENTER 138KV'	305	0.00935	-0.12188	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'GILL ENERGY CENTER 138KV'	155	0.00919	-0.12172	4
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.11253	WERE	'HOLTON 115KV'	8.2	0.00518	-0.11771	4

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	HUTCHINSON ENERGY CENTER 115KV	72.17331	0.00418	-0.11671	4
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00477	-0.1173	4
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00475	-0.11728	4
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	LAWRENCE ENERGY CENTER 230KV	231.115	0.0047	-0.11723	4
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	SOUTH SENECA 115KV	8.5	0.00571	-0.11824	4
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0048	-0.11733	4
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	WACO 138KV	17.946	0.00921	-0.12174	4
WERE	ABILENE ENERGY CENTER 115KV	5.999996	0.00461	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05809	8
WERE	BPU - CITY OF MCPHERSON 115KV	259	0.00428	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05842	8
WERE	CHANUTE 69KV	31.504	0.00382	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05888	8
WERE	CITY OF ERIE 69KV	24.231	0.00382	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05888	8
WERE	CITY OF FREDONIA 69KV	5.069	0.00429	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05841	8
WERE	CITY OF GIRARD 69KV	8.909	0.00212	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.06058	8
WERE	CITY OF IOLA 69KV	13.372	0.00344	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05926	8
WERE	CITY OF NEODESHA 69KV	4.5	0.00333	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05937	8
WERE	CITY OF OSAGE CITY 115KV	8.85	0.00514	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05756	8
WERE	CLAY CENTER JUNCTION 115KV	29.516	0.0047	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.058	8
WERE	GILL ENERGY CENTER 69KV	118	0.00494	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05776	8
WERE	HOLTON 115KV	11.6	0.00518	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05752	8
WERE	HUTCHINSON ENERGY CENTER 115KV	310.8267	0.00418	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05852	8
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.00418	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05852	8
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00477	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05793	8
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00475	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05795	8
WERE	LAWRENCE ENERGY CENTER 115KV	178	0.00462	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05808	8
WERE	LAWRENCE ENERGY CENTER 230KV	37.88498	0.0047	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.058	8
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00288	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05982	8
WERE	SMOKYHIL 230 230KV	72	0.00418	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05852	8
WERE	ST JOHN 115KV	7.5	0.00408	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05862	8
WERE	TECUMSEH ENERGY CENTER 115KV	52.99999	0.0048	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.0579	8
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.0048	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.0579	8
WERE	BROWN COUNTY 115KV	5.5	0.00583	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05687	9
WERE	CITY OF BURLINGTON 69KV	7.7	0.0084	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.0543	9
WERE	EVANS ENERGY CENTER 138KV	438	0.00935	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05335	9
WERE	GILL ENERGY CENTER 138KV	17.99999	0.00919	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05351	9
WERE	LATHAM1234.0 345KV	150	0.00922	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05348	9
WERE	SOUTH SENECA 115KV	8.2	0.00571	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05699	9
WERE	CITY OF MULVANE 69KV	10.899	0.01258	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.05012	10
WERE	GETTY 69KV	35	0.02486	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.03784	13
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.03511	OKGE	AES 161KV	320	-0.00233	-0.03278	15
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.03511	OKGE	MUSKOGEE 345KV	1516	-0.00337	-0.03174	15

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Limiting Facility: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-40  
 Flowgate: 57550578371SPP-WERE-404407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.3	3.8
1090609	0.6	3.8
1090609	0.2	3.8
1090609	0.4	3.8
1090609	2.2	3.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF AUGUSTA 69KV	20.02	0.06269	-0.37126	10
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	ABILENE ENERGY CENTER 115KV	40	0.00459	-0.31316	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	BPU - CITY OF MCPHERSON 115KV	77.13525	0.00426	-0.31283	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CHANUTE 69KV	46.617	0.00381	-0.31238	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF BURLINGTON 69KV	7.8	0.00839	-0.31696	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF ERIE 69KV	22.264	0.00381	-0.31238	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF FREDONIA 69KV	5.225	0.00428	-0.31285	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF IOLA 69KV	19.865	0.00343	-0.312	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF MULVANE 69KV	6.189	0.01257	-0.32114	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CLAY CENTER JUNCTION 115KV	17.01001	0.00469	-0.31326	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00839	-0.31696	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	EVANS ENERGY CENTER 138KV	340	0.00934	-0.31791	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	GILL ENERGY CENTER 138KV	155	0.00918	-0.31775	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	HOLTON 115KV	12.2	0.00516	-0.31373	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.00416	-0.31273	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00475	-0.31332	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00474	-0.31331	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00461	-0.31318	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	LAWRENCE ENERGY CENTER 230KV	231.9843	0.00469	-0.31326	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	SOUTH SENECA 115KV	8.5	0.00569	-0.31426	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00479	-0.31336	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	WACO 138KV	17.947	0.00919	-0.31776	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF WELLINGTON 69KV	41.45	-0.11254	-0.19603	19

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Limiting Facility: RICHLAND - ROSE HILL JUNCTION 69KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-40  
 Flowgate: 57550578371SPP-WERE-404407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.6	8.0
1090609	1.2	8.0
1090609	0.4	8.0
1090609	0.9	8.0
1090609	4.9	8.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
---------------------	--------	-----------------------	-----	-------------------	------	-----------------------	-----	--------	------------------------

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CITY OF AUGUSTA 69KV	25.12	0.06269	-0.37126	22
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CITY OF BURLINGTON 69KV	10.12	0.00839	-0.31696	25
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00839	-0.31696	25
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	EVANS ENERGY CENTER 138KV	544.001	0.00934	-0.31791	25
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	GILL ENERGY CENTER 138KV	171	0.00918	-0.31775	25
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	WACO 138KV	17.96	0.00919	-0.31776	25
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	ABILENE ENERGY CENTER 115KV	40	0.00459	-0.31316	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	BPU - CITY OF MCPHERSON 115KV	135	0.00426	-0.31283	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CHANUTE 69KV	56.723	0.00381	-0.31238	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CITY OF ERIE 69KV	22.274	0.00381	-0.31238	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CITY OF IOLA 69KV	24.267	0.00343	-0.312	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.00469	-0.31326	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	GILL ENERGY CENTER 69KV	45	0.00493	-0.3135	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	HOLTON 115KV	12.2	0.00516	-0.31373	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.00417	-0.31274	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	HUTCHINSON ENERGY CENTER 69KV	40	0.00417	-0.31274	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00475	-0.31332	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00474	-0.31331	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00461	-0.31318	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	LAWRENCE ENERGY CENTER 230KV	232.7283	0.00469	-0.31326	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.00479	-0.31336	26
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CITY OF WELLINGTON 69KV	41.45	-0.11254	-0.19603	41

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - UDALL 69KV CKT 1  
 Limiting Facility: RICHLAND - UDALL 69KV CKT 1  
 Direction: From->To  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57550575591570395704214407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.1	0.8
1090609	0.1	0.8
1090609	0.1	0.8
1090609	0.1	0.8
1090609	0.4	0.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.35582	2
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00494	-0.29597	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	77.13525	0.0046	-0.29563	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CHANUTE 69KV	46.617	0.004	-0.29503	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF BURLINGTON 69KV	7.8	0.00895	-0.29998	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF ERIE 69KV	22.264	0.004	-0.29503	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF FREDONIA 69KV	5.225	0.00449	-0.29552	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF GIRARD 69KV	2.989	0.00223	-0.29326	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF IOLA 69KV	19.865	0.00362	-0.29465	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF MULVANE 69KV	6.189	0.01377	-0.3048	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CLAY CENTER JUNCTION 115KV	17.01001	0.00503	-0.29606	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00895	-0.29998	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	EVANS ENERGY CENTER 138KV	340	0.01018	-0.30121	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	GILL ENERGY CENTER 138KV	155	0.01042	-0.30145	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HOLTON 115KV	12.2	0.00551	-0.29654	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0045	-0.29553	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00509	-0.29612	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00508	-0.29611	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00494	-0.29597	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	231.9843	0.00502	-0.29605	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	SOUTH SENeca 115KV	8.5	0.00604	-0.29707	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00513	-0.29616	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	WACO 138KV	17.947	0.01039	-0.30142	3
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF WELLINGTON 69KV	41.45	-0.09965	-0.19138	4
WERE	OXFORD 138KV	3	-0.13758	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.20237	4
WERE	CITY OF WELLINGTON 69KV	2.049999	-0.09965	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.16444	5
WERE	OXFORD 138KV	3	-0.13758	WERE	CITY OF MULVANE 69KV	6.189	0.01377	-0.15135	5
WERE	OXFORD 138KV	3	-0.13758	WERE	ABILENE ENERGY CENTER 115KV	40	0.00494	-0.14252	6
WERE	OXFORD 138KV	3	-0.13758	WERE	BPU - CITY OF MCPHERSON 115KV	77.13525	0.0046	-0.14218	6
WERE	OXFORD 138KV	3	-0.13758	WERE	CHANUTE 69KV	46.617	0.004	-0.14158	6
WERE	OXFORD 138KV	3	-0.13758	WERE	CITY OF BURLINGTON 69KV	7.8	0.00895	-0.14653	6
WERE	OXFORD 138KV	3	-0.13758	WERE	CITY OF ERIE 69KV	22.264	0.004	-0.14158	6
WERE	OXFORD 138KV	3	-0.13758	WERE	CITY OF FREDONIA 69KV	5.225	0.00449	-0.14207	6
WERE	OXFORD 138KV	3	-0.13758	WERE	CITY OF GIRARD 69KV	2.989	0.00223	-0.13981	6
WERE	OXFORD 138KV	3	-0.13758	WERE	CITY OF IOLA 69KV	19.865	0.00362	-0.1412	6
WERE	OXFORD 138KV	3	-0.13758	WERE	CLAY CENTER JUNCTION 115KV	17.01001	0.00503	-0.14261	6
WERE	OXFORD 138KV	3	-0.13758	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00895	-0.14653	6
WERE	OXFORD 138KV	3	-0.13758	WERE	EVANS ENERGY CENTER 138KV	340	0.01018	-0.14776	6
WERE	OXFORD 138KV	3	-0.13758	WERE	GILL ENERGY CENTER 138KV	155	0.01042	-0.148	6
WERE	OXFORD 138KV	3	-0.13758	WERE	HOLTON 115KV	12.2	0.00551	-0.14309	6
WERE	OXFORD 138KV	3	-0.13758	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0045	-0.14208	6
WERE	OXFORD 138KV	3	-0.13758	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00509	-0.14267	6
WERE	OXFORD 138KV	3	-0.13758	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00508	-0.14266	6
WERE	OXFORD 138KV	3	-0.13758	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00494	-0.14252	6
WERE	OXFORD 138KV	3	-0.13758	WERE	LAWRENCE ENERGY CENTER 230KV	231.9843	0.00502	-0.1426	6
WERE	OXFORD 138KV	3	-0.13758	WERE	SOUTH SENeca 115KV	8.5	0.00604	-0.14362	6
WERE	OXFORD 138KV	3	-0.13758	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00513	-0.14271	6
WERE	OXFORD 138KV	3	-0.13758	WERE	WACO 138KV	17.947	0.01039	-0.14797	6
WERE	CITY OF GIRARD 69KV	7.711	0.00223	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06256	13
WERE	CITY OF IOLA 69KV	17.763	0.00362	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06117	13
WERE	CITY OF NEODESHA 69KV	4.5	0.00348	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06131	13
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00304	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06175	13
WERE	ABILENE ENERGY CENTER 115KV	5.999996	0.00494	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05985	14
WERE	BPU - CITY OF MCPHERSON 115KV	136.8647	0.0046	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06019	14
WERE	BROWN COUNTY 115KV	5.5	0.00617	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05862	14
WERE	CHANUTE 69KV	41.183	0.004	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06079	14
WERE	CITY OF FREDONIA 69KV	5.069	0.00449	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.0603	14
WERE	CITY OF OSAGE CITY 115KV	8.85	0.00549	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.0593	14
WERE	CLAY CENTER JUNCTION 115KV	21.08999	0.00503	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05976	14
WERE	GILL ENERGY CENTER 69KV	118	0.00659	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.0582	14
WERE	HOLTON 115KV	7.6	0.00551	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05928	14
WERE	HUTCHINSON ENERGY CENTER 115KV	263	0.0045	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06029	14
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.0045	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06029	14

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	JEFFREY ENERGY CENTER 230KV	24	0.00509	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.0597	14
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00508	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05971	14
WERE	LAWRENCE ENERGY CENTER 115KV	78	0.00494	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05985	14
WERE	LAWRENCE ENERGY CENTER 230KV	37.01572	0.00502	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05977	14
WERE	SMOKYHIL 230 230KV	72	0.00449	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.0603	14
WERE	SOUTH SENECA 115KV	8.2	0.00604	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05875	14
WERE	ST JOHN 115KV	7.5	0.00445	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.06034	14
WERE	TECUMSEH ENERGY CENTER 115KV	52.99999	0.00513	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05966	14
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00513	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05966	14
WERE	EVANS ENERGY CENTER 138KV	313	0.01018	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05461	15
WERE	GILL ENERGY CENTER 138KV	17.99999	0.01042	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05437	15
WERE	LATHAM1234.0 345KV	150	0.0098	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05499	15
WERE	CITY OF MULVANE 69KV	9.601001	0.01377	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.05102	16
WERE	GETTY 69KV	35	0.02598	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.03881	21

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - UDALL 69KV CKT 1  
 Limiting Facility: RICHLAND - UDALL 69KV CKT 1  
 Direction: From->To  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57550575591570395704214407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.3	4.8
1090609	0.7	4.8
1090609	0.3	4.8
1090609	0.6	4.8
1090609	2.8	4.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF AUGUSTA 69KV	25.12	0.06479	-0.35582	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00494	-0.29597	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	135	0.0046	-0.29563	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CHANUTE 69KV	56.723	0.004	-0.29503	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF BURLINGTON 69KV	10.12	0.00895	-0.29998	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF ERIE 69KV	22.274	0.004	-0.29503	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF IOLA 69KV	24.267	0.00362	-0.29465	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF MULVANE 69KV	8.288	0.01377	-0.3048	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.00503	-0.29606	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00895	-0.29998	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	EVANS ENERGY CENTER 138KV	544.001	0.01018	-0.30121	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	GILL ENERGY CENTER 138KV	171	0.01042	-0.30145	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	GILL ENERGY CENTER 69KV	45	0.00659	-0.29762	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HOLTON 115KV	12.2	0.00551	-0.29654	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.0045	-0.29553	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HUTCHINSON ENERGY CENTER 69KV	40	0.0045	-0.29553	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00509	-0.29612	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00508	-0.29611	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00494	-0.29597	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	232.7283	0.00502	-0.29605	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	SOUTH SENECA 115KV	8.5	0.00604	-0.29707	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.00513	-0.29616	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	WACO 138KV	17.96	0.01039	-0.30142	16
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF WELLINGTON 69KV	41.45	-0.09965	-0.19138	25

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - UDALL 69KV CKT 1  
 Limiting Facility: RICHLAND - UDALL 69KV CKT 1  
 Direction: From->To  
 Line Outage: FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1  
 Flowgate: 57550575591570425706314407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.1	1.0
1090609	0.2	1.0
1090609	0.1	1.0
1090609	0.1	1.0
1090609	0.5	1.0

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00494	-0.29597	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	135	0.0046	-0.29563	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CHANUTE 69KV	56.723	0.004	-0.29503	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF AUGUSTA 69KV	25.12	0.06479	-0.35582	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF BURLINGTON 69KV	10.12	0.00895	-0.29998	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF ERIE 69KV	22.274	0.004	-0.29503	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF FREDONIA 69KV	5.225	0.00449	-0.29552	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF IOLA 69KV	24.267	0.00362	-0.29465	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF MULVANE 69KV	8.288	0.01377	-0.3048	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.00503	-0.29606	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00895	-0.29998	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	EVANS ENERGY CENTER 138KV	544.001	0.01018	-0.30121	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	GILL ENERGY CENTER 138KV	171	0.01042	-0.30145	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	GILL ENERGY CENTER 69KV	45	0.00659	-0.29762	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HOLTON 115KV	12.2	0.00551	-0.29654	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.0045	-0.29553	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HUTCHINSON ENERGY CENTER 69KV	40	0.0045	-0.29553	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00509	-0.29612	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00508	-0.29611	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00494	-0.29597	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	232.7283	0.00502	-0.29605	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	SOUTH SENECA 115KV	8.5	0.00604	-0.29707	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.00513	-0.29616	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	WACO 138KV	17.96	0.01039	-0.30142	3
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF GIRARD 69KV	4.789	0.00223	-0.29326	4



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WINFIELD 69KV'	29.38998	-0.29103	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.09965	-0.19138	5
WERE	OXFORD 138KV'	3	-0.13758	WERE	CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.20237	5
WERE	CITY OF WELLINGTON 69KV'	2.049999	-0.09965	WERE	CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.16444	6
WERE	OXFORD 138KV'	3	-0.13758	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00494	-0.14252	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'BPU - CITY OF MCPHERSON 115KV'	135	0.0046	-0.14218	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'CHANUTE 69KV'	56.723	0.00381	-0.14158	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'CITY OF BURLINGTON 69KV'	10.12	0.00895	-0.14653	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'CITY OF ERIE 69KV'	22.274	0.004	-0.14158	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00449	-0.14207	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'CITY OF GIRARD 69KV'	4.789	0.00223	-0.13981	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'CITY OF IOLA 69KV'	24.267	0.00362	-0.1412	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'CITY OF MULVANE 69KV'	8.288	0.01377	-0.15135	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'CLAY CENTER JUNCTION 115KV'	28.875	0.00503	-0.14261	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00895	-0.14653	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'EVANS ENERGY CENTER 138KV'	544.001	0.01018	-0.14776	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'GILL ENERGY CENTER 138KV'	171	0.01042	-0.148	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'GILL ENERGY CENTER 69KV'	45	0.00659	-0.14417	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'HOLTON 115KV'	12.2	0.00551	-0.14309	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'HUTCHINSON ENERGY CENTER 115KV'	210	0.0045	-0.14208	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'HUTCHINSON ENERGY CENTER 69KV'	40	0.0045	-0.14208	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.00509	-0.14267	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.00508	-0.14266	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'LAWRENCE ENERGY CENTER 115KV'	105	0.00494	-0.14252	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'LAWRENCE ENERGY CENTER 230KV'	232.7283	0.00502	-0.1426	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'SOUTH SENECA 115KV'	8.5	0.00604	-0.14362	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'TECUMSEH ENERGY CENTER 115KV'	158	0.00513	-0.14271	7
WERE	OXFORD 138KV'	3	-0.13758	WERE	'WACO 138KV'	17.96	0.01039	-0.14797	7
WERE	CITY OF GIRARD 69KV'	5.911	0.00223	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.06256	16
WERE	'ABILENE ENERGY CENTER 115KV'	5.999996	0.00494	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05985	17
WERE	'BPU - CITY OF MCPHERSON 115KV'	39	0.0046	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.06019	17
WERE	'CHANUTE 69KV'	31.077	0.004	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.06079	17
WERE	'CITY OF IOLA 69KV'	13.361	0.00362	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.06117	17
WERE	'CITY OF OSAGE CITY 115KV'	8.85	0.00549	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.0593	17
WERE	'CLAY CENTER JUNCTION 115KV'	9.225	0.00503	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05976	17
WERE	'HOLTON 115KV'	7.6	0.00551	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05928	17
WERE	'HUTCHINSON ENERGY CENTER 115KV'	133	0.0045	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.06029	17
WERE	'HUTCHINSON ENERGY CENTER 69KV'	12	0.0045	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.06029	17
WERE	'JEFFREY ENERGY CENTER 230KV'	24	0.00509	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.0597	17
WERE	'JEFFREY ENERGY CENTER 345KV'	42	0.00508	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05971	17
WERE	'LAWRENCE ENERGY CENTER 115KV'	8.000004	0.00494	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05985	17
WERE	'LAWRENCE ENERGY CENTER 230KV'	36.2717	0.00502	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05977	17
WERE	'NEOSHO ENERGY CENTER 138KV'	47	0.00304	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.06175	17
WERE	'SMOKYHILL 230 230KV'	72	0.00449	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.0603	17
WERE	'SOUTH SENECA 115KV'	8.2	0.00604	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05875	17
WERE	'ST JOHN 115KV'	7.5	0.00446	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.06033	17
WERE	'TECUMSEH ENERGY CENTER 69KV'	41	0.00513	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05966	17
WERE	'GILL ENERGY CENTER 69KV'	38	0.00659	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.0582	18
WERE	'EVANS ENERGY CENTER 138KV'	28.99902	0.01018	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05461	19
WERE	'LATHAM1234.0 345KV'	150	0.0098	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05499	19
WERE	'CITY OF MULVANE 69KV'	7.502	0.01377	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.05102	20
WERE	'GETTY 69KV'	35	0.02598	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06479	-0.03881	26

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: RICHLAND - UDALL 69KV CKT 1  
 Limiting Facility: RICHLAND - UDALL 69KV CKT 1  
 Direction: From->To  
 Line Outage: SPP-WERE-40  
 Flowgate: 57550575591SPP-WERE-404407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.2	2.2
1090609	0.3	2.2
1090609	0.1	2.2
1090609	0.3	2.2
1090609	1.2	2.2

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.37126	6
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00459	-0.31316	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'BPU - CITY OF MCPHERSON 115KV'	135	0.00426	-0.31283	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'CHANUTE 69KV'	56.723	0.00381	-0.31238	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'CITY OF BURLINGTON 69KV'	10.12	0.00839	-0.31696	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'CITY OF ERIE 69KV'	22.274	0.00381	-0.31238	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00428	-0.31285	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'CITY OF GIRARD 69KV'	4.789	0.00211	-0.31068	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'CITY OF IOLA 69KV'	24.267	0.00343	-0.312	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'CITY OF MULVANE 69KV'	8.288	0.01257	-0.32114	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'CLAY CENTER JUNCTION 115KV'	28.875	0.00469	-0.31326	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00839	-0.31696	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'EVANS ENERGY CENTER 138KV'	544.001	0.00934	-0.31791	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'GILL ENERGY CENTER 138KV'	171	0.00918	-0.31775	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'GILL ENERGY CENTER 69KV'	45	0.00493	-0.3135	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'HOLTON 115KV'	12.2	0.00516	-0.31373	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'HUTCHINSON ENERGY CENTER 115KV'	210	0.00417	-0.31274	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'HUTCHINSON ENERGY CENTER 69KV'	40	0.00417	-0.31274	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.00475	-0.31332	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.00474	-0.31331	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'LAWRENCE ENERGY CENTER 115KV'	105	0.00461	-0.31318	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'LAWRENCE ENERGY CENTER 230KV'	232.7283	0.00469	-0.31326	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'SOUTH SENECA 115KV'	8.5	0.00569	-0.31426	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'TECUMSEH ENERGY CENTER 115KV'	158	0.00479	-0.31336	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'WACO 138KV'	17.96	0.00919	-0.31776	7
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.30857	WERE	'CITY OF WELLINGTON 69KV'	41.45	-0.11254	-0.19603	11
WERE	CITY OF IOLA 69KV'	13.361	0.00343	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05926	37
WERE	'NEOSHO ENERGY CENTER 138KV'	47	0.00287	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05982	37
WERE	'BPU - CITY OF MCPHERSON 115KV'	39	0.00426	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05843	38
WERE	'CHANUTE 69KV'	31.077	0.00381	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05888	38
WERE	'GILL ENERGY CENTER 69KV'	38	0.00493	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05776	38
WERE	'HUTCHINSON ENERGY CENTER 115KV'	133	0.00417	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05852	38
WERE	'JEFFREY ENERGY CENTER 230KV'	24	0.00475	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05794	38
WERE	'JEFFREY ENERGY CENTER 345KV'	42	0.00474	WERE	'CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05795	38

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	LAWRENCE ENERGY CENTER 230KV'	36.2717	0.00469	WERE	CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.058	38
WERE	SMOKYHILL 230 230KV'	72	0.00417	WERE	CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05852	38
WERE	TECUMSEH ENERGY CENTER 69KV'	41	0.00478	WERE	CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05791	38
WERE	LATHAM1234.0 345KV'	150	0.00921	WERE	CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05348	41
WERE	EVANS ENERGY CENTER 138KV'	28.99902	0.00934	WERE	CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.05335	42
WERE	GETTY 69KV'	35	0.02485	WERE	CITY OF AUGUSTA 69KV'	25.12	0.06269	-0.03784	59

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL (ROSEHL1X) 345-138-13.8KV TRANSFORMER  
 Limiting Facility: ROSE HILL (ROSEHL1X) 345-138-13.8KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: ROSE HILL (ROSEHL3X) 345-138-13.8KV TRANSFORMER CKT 1  
 Flowgate: ROSSEHL1X2741ROSEHL3X7412207SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086655	1.4	2.8
1086656	0.5	2.8
1090609	0.4	2.8
1090609	0.1	2.8
1090609	0.2	2.8
1090609	0.1	2.8
1090674	0.1	2.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	CITY OF BURLINGTON 69KV'	10.12	0.0451	-0.32927	8
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.0451	-0.32927	8
WERE	OXFORD 138KV'	3	-0.25228	WERE	CITY OF BURLINGTON 69KV'	10.12	0.0451	-0.29738	9
WERE	OXFORD 138KV'	3	-0.25228	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.0451	-0.29738	9
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	ABILENE ENERGY CENTER 115KV'	40	-0.00745	-0.27672	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	BPU - CITY OF MCPHERSON 115KV'	135	-0.01232	-0.27185	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	CHANUTE 69KV'	56.723	-0.01127	-0.2729	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	CITY OF IOLA 69KV'	22.274	-0.01127	-0.2729	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	CITY OF GIRARD 69KV'	4.789	0.00966	-0.29383	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	CITY OF IOLA 69KV'	24.267	-0.00508	-0.27909	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	CLAY CENTER JUNCTION 115KV'	28.875	-0.00634	-0.27783	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	HOLTON 115KV'	12.2	-0.0102	-0.27397	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	-0.01512	-0.26905	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	JEFFREY ENERGY CENTER 230KV'	470	-0.00308	-0.28109	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	JEFFREY ENERGY CENTER 345KV'	940	-0.00293	-0.28124	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	LAWRENCE ENERGY CENTER 115KV'	85	0.00124	-0.28541	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	LAWRENCE ENERGY CENTER 230KV'	236.3199	0.00053	-0.2847	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	TECUMSEH ENERGY CENTER 115KV'	128	-0.00156	-0.28261	10
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	CITY OF FREDONIA 69KV'	5.225	-0.01906	-0.26511	11
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	'SOUTH SENECA 115KV'	8.5	-0.02064	-0.26353	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	CITY OF BURLINGTON 69KV'	10.12	0.0451	-0.25957	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.0451	-0.25957	11
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	CITY OF BURLINGTON 69KV'	10.12	0.0451	-0.25418	11
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.0451	-0.25418	11
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	CITY OF BURLINGTON 69KV'	10.12	0.0451	-0.25674	11
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.0451	-0.25674	11
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	CITY OF GIRARD 69KV'	4.789	0.00966	-0.22413	12
WERE	GETTY 69KV'	35	-0.19057	WERE	CITY OF BURLINGTON 69KV'	10.12	0.0451	-0.23567	12
WERE	GETTY 69KV'	35	-0.19057	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.0451	-0.23567	12
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	CITY OF IOLA 69KV'	24.267	-0.00508	-0.20939	13
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	CLAY CENTER JUNCTION 115KV'	28.875	-0.00634	-0.20813	13
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	JEFFREY ENERGY CENTER 230KV'	470	-0.00308	-0.21139	13
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	JEFFREY ENERGY CENTER 345KV'	940	-0.00293	-0.21154	13
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	LAWRENCE ENERGY CENTER 115KV'	85	0.00124	-0.21571	13
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	LAWRENCE ENERGY CENTER 230KV'	236.3199	0.00053	-0.215	13
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	TECUMSEH ENERGY CENTER 115KV'	128	-0.00156	-0.21291	13
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	CITY OF GIRARD 69KV'	4.789	0.00966	-0.21874	13
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	LAWRENCE ENERGY CENTER 115KV'	85	0.00124	-0.21032	13
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	LAWRENCE ENERGY CENTER 230KV'	236.3199	0.00053	-0.20961	13
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	TECUMSEH ENERGY CENTER 115KV'	128	-0.00156	-0.20752	13
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	CITY OF GIRARD 69KV'	4.789	0.00966	-0.2213	13
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	JEFFREY ENERGY CENTER 230KV'	470	-0.00308	-0.20856	13
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	JEFFREY ENERGY CENTER 345KV'	940	-0.00293	-0.20871	13
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	LAWRENCE ENERGY CENTER 115KV'	85	0.00124	-0.21288	13
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	LAWRENCE ENERGY CENTER 230KV'	236.3199	0.00053	-0.21217	13
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	TECUMSEH ENERGY CENTER 115KV'	128	-0.00156	-0.21008	13
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	ABILENE ENERGY CENTER 115KV'	40	-0.00745	-0.20702	14
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	BPU - CITY OF MCPHERSON 115KV'	135	-0.01232	-0.20215	14
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	CHANUTE 69KV'	56.723	-0.01127	-0.2032	14
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	CITY OF ERIE 69KV'	22.274	-0.01127	-0.2032	14
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	CITY OF FREDONIA 69KV'	5.225	-0.01906	-0.19541	14
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	HOLTON 115KV'	12.2	-0.0102	-0.20427	14
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	-0.01512	-0.19935	14
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21447	WERE	'SOUTH SENECA 115KV'	8.5	-0.02064	-0.19383	14
WERE	GETTY 69KV'	35	-0.19057	WERE	CITY OF GIRARD 69KV'	4.789	0.00966	-0.20023	14
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	ABILENE ENERGY CENTER 115KV'	40	-0.00745	-0.20163	14
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	BPU - CITY OF MCPHERSON 115KV'	135	-0.01232	-0.19676	14
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	CHANUTE 69KV'	56.723	-0.01127	-0.19781	14
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	CITY OF ERIE 69KV'	22.274	-0.01127	-0.19781	14
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	CITY OF IOLA 69KV'	24.267	-0.00508	-0.204	14
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	CLAY CENTER JUNCTION 115KV'	28.875	-0.00634	-0.20274	14
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	HOLTON 115KV'	12.2	-0.0102	-0.19888	14
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	-0.01512	-0.19396	14
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	JEFFREY ENERGY CENTER 230KV'	470	-0.00308	-0.206	14
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20908	WERE	JEFFREY ENERGY CENTER 345KV'	940	-0.00293	-0.20615	14
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	ABILENE ENERGY CENTER 115KV'	40	-0.00745	-0.20419	14
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	BPU - CITY OF MCPHERSON 115KV'	135	-0.01232	-0.19932	14
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	CHANUTE 69KV'	56.723	-0.01127	-0.20037	14
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	CITY OF ERIE 69KV'	22.274	-0.01127	-0.20037	14
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	CITY OF IOLA 69KV'	24.267	-0.00508	-0.20656	14
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	CLAY CENTER JUNCTION 115KV'	28.875	-0.00634	-0.2053	14
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	HOLTON 115KV'	12.2	-0.0102	-0.20144	14
WERE	GILL ENERGY CENTER 69KV'	118	-0.21164	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	-0.01512	-0.19652	14
WERE	CITY OF MULVANE 69KV'	7.502	-0.28417	WERE	EVANS ENERGY CENTER 138KV'	373.2803	-0.09869	-0.18548	15
WERE	GETTY 69KV'	35	-0.19057	WERE	ABILENE ENERGY CENTER 115KV'	40	-0.00745	-0.18312	15
WERE	GETTY 69KV'	35	-0.19057	WERE	CITY OF IOLA 69KV'	24.267	-0.00508	-0.18549	15
WERE	GETTY 69KV'	35	-0.19057	WERE	CLAY CENTER JUNCTION 115KV'	28.875	-0.00634	-0.18423	15

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	GETTY 69KV	35	-0.19057	WERE	JEFFREY ENERGY CENTER 230KV	470	-0.00308	-0.18749	15
WERE	GETTY 69KV	35	-0.19057	WERE	JEFFREY ENERGY CENTER 345KV	940	-0.00293	-0.18764	15
WERE	GETTY 69KV	35	-0.19057	WERE	LAWRENCE ENERGY CENTER 115KV	85	0.00124	-0.19181	15
WERE	GETTY 69KV	35	-0.19057	WERE	LAWRENCE ENERGY CENTER 230KV	236.3199	0.00053	-0.1911	15
WERE	GETTY 69KV	35	-0.19057	WERE	TECUMSEH ENERGY CENTER 115KV	128	-0.00156	-0.18901	15
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20908	WERE	CITY OF FREDONIA 69KV	5.225	-0.01906	-0.19002	15
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20908	WERE	SOUTH SENeca 115KV	8.5	-0.02064	-0.18844	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21164	WERE	CITY OF FREDONIA 69KV	5.225	-0.01906	-0.19258	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21164	WERE	SOUTH SENeca 115KV	8.5	-0.02064	-0.191	15
WERE	GETTY 69KV	35	-0.19057	WERE	BPU - CITY OF MCPHERSON 115KV	135	-0.01232	-0.17825	16
WERE	GETTY 69KV	35	-0.19057	WERE	CHANUTE 69KV	56.723	-0.01127	-0.1793	16
WERE	GETTY 69KV	35	-0.19057	WERE	CITY OF ERIE 69KV	22.274	-0.01127	-0.1793	16
WERE	GETTY 69KV	35	-0.19057	WERE	HOLTON 115KV	12.2	-0.0102	-0.18037	16
WERE	GETTY 69KV	35	-0.19057	WERE	HUTCHINSON ENERGY CENTER 115KV	120	-0.01512	-0.17545	16
WERE	GETTY 69KV	35	-0.19057	WERE	SOUTH SENeca 115KV	8.5	-0.02064	-0.16993	16
WERE	EVANS ENERGY CENTER 138KV	249.7197	-0.09869	WERE	CITY OF BURLINGTON 69KV	10.12	0.0451	-0.14379	19
WERE	EVANS ENERGY CENTER 138KV	249.7197	-0.09869	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.0451	-0.14379	19
WEPL	HARPER 138KV	17.21	-0.15491	WEPL	CLIFFTON 115KV	43.35043	-0.01309	-0.14182	20
WEPL	HARPER 138KV	17.21	-0.15491	WEPL	A. M. MULLERGREEN GENERATOR 115KV	63	-0.02153	-0.13338	21
WEPL	HARPER 138KV	17.21	-0.15491	WEPL	GRAY COUNTY WIND FARM 115KV	73	-0.03373	-0.12118	23
WEPL	HARPER 138KV	17.21	-0.15491	WEPL	JUDSON LARGE 115KV	109.0593	-0.03391	-0.121	23
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21447	WERE	EVANS ENERGY CENTER 138KV	373.2803	-0.09869	-0.11578	24
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20908	WERE	EVANS ENERGY CENTER 138KV	373.2803	-0.09869	-0.11039	25

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL (ROSEHL1X) 345-138-13.8KV TRANSFORMER  
 Limiting Facility: ROSE HILL (ROSEHL3X) 345-138-13.8KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: ROSE HILL (ROSEHL1X) 345-138-13.8KV TRANSFORMER CKT 1  
 Flowgate: ROSSEHL3X2741ROSEHL1X7412207SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086655	1.6	3.1
1086656	0.5	3.1
1090609	0.4	3.1
1090609	0.1	3.1
1090609	0.2	3.1
1090609	0.2	3.1
1090674	0.1	3.1

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	CITY OF BURLINGTON 69KV	10.12	0.04512	-0.32942	9
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.04512	-0.32942	9
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	ABILENE ENERGY CENTER 115KV	40	-0.00745	-0.27685	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	BPU - CITY OF MCPHERSON 115KV	135	-0.01232	-0.27198	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	CHANUTE 69KV	56.723	-0.01127	-0.27303	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	CITY OF ERIE 69KV	22.274	-0.01127	-0.27303	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	CITY OF GIRARD 69KV	4.789	0.00966	-0.29396	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	CITY OF IOLA 69KV	24.267	-0.00508	-0.27922	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	CLAY CENTER JUNCTION 115KV	28.875	-0.00634	-0.27796	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	HOLTON 115KV	12.2	-0.0102	-0.2741	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	HUTCHINSON ENERGY CENTER 115KV	120	-0.01512	-0.26918	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	JEFFREY ENERGY CENTER 230KV	470	-0.00308	-0.28122	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	JEFFREY ENERGY CENTER 345KV	940	-0.00293	-0.28137	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	LAWRENCE ENERGY CENTER 115KV	85	0.00124	-0.28554	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	LAWRENCE ENERGY CENTER 230KV	236.3199	0.00053	-0.28483	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	TECUMSEH ENERGY CENTER 115KV	128	-0.00156	-0.28274	11
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	CITY OF FREDONIA 69KV	5.225	-0.01907	-0.26523	12
WERE	CITY OF MULVANE 69KV	7.502	-0.2843	WERE	SOUTH SENeca 115KV	8.5	-0.02065	-0.26365	12
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	CITY OF BURLINGTON 69KV	10.12	0.04512	-0.25969	12
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.04512	-0.25969	12
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	CITY OF BURLINGTON 69KV	10.12	0.04512	-0.2543	12
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.04512	-0.2543	12
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	CITY OF BURLINGTON 69KV	10.12	0.04512	-0.25686	12
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.04512	-0.25686	12
WERE	GETTY 69KV	35	-0.19065	WERE	CITY OF BURLINGTON 69KV	10.12	0.04512	-0.23577	13
WERE	GETTY 69KV	35	-0.19065	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.04512	-0.23577	13
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	CITY OF GIRARD 69KV	4.789	0.00966	-0.22423	14
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	LAWRENCE ENERGY CENTER 115KV	85	0.00124	-0.21581	14
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	LAWRENCE ENERGY CENTER 230KV	236.3199	0.00053	-0.2151	14
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	CITY OF GIRARD 69KV	4.789	0.00966	-0.21884	14
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	CITY OF GIRARD 69KV	4.789	0.00966	-0.2214	14
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	ABILENE ENERGY CENTER 115KV	40	-0.00745	-0.20712	15
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	BPU - CITY OF MCPHERSON 115KV	135	-0.01232	-0.20225	15
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	CHANUTE 69KV	56.723	-0.01127	-0.2033	15
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	CITY OF ERIE 69KV	22.274	-0.01127	-0.2033	15
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	CITY OF IOLA 69KV	24.267	-0.00508	-0.20949	15
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	CLAY CENTER JUNCTION 115KV	28.875	-0.00634	-0.20823	15
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	HOLTON 115KV	12.2	-0.0102	-0.20437	15
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	JEFFREY ENERGY CENTER 230KV	470	-0.00308	-0.21149	15
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	JEFFREY ENERGY CENTER 345KV	940	-0.00293	-0.21164	15
WERE	CITY OF WINFIELD 69KV	29.38998	-0.21457	WERE	TECUMSEH ENERGY CENTER 115KV	128	-0.00156	-0.21301	15
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	ABILENE ENERGY CENTER 115KV	40	-0.00745	-0.20173	15
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	CITY OF IOLA 69KV	24.267	-0.00508	-0.2041	15
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	CLAY CENTER JUNCTION 115KV	28.875	-0.00634	-0.20284	15
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	JEFFREY ENERGY CENTER 230KV	470	-0.00308	-0.2061	15
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	JEFFREY ENERGY CENTER 345KV	940	-0.00293	-0.20625	15
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	LAWRENCE ENERGY CENTER 115KV	85	0.00124	-0.21042	15
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	LAWRENCE ENERGY CENTER 230KV	236.3199	0.00053	-0.20971	15
WERE	GILL ENERGY CENTER 138KV	17.99999	-0.20918	WERE	TECUMSEH ENERGY CENTER 115KV	128	-0.00156	-0.20762	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	ABILENE ENERGY CENTER 115KV	40	-0.00745	-0.20429	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	CHANUTE 69KV	56.723	-0.01127	-0.20047	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	CITY OF ERIE 69KV	22.274	-0.01127	-0.20047	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	CITY OF IOLA 69KV	24.267	-0.00508	-0.20666	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	CLAY CENTER JUNCTION 115KV	28.875	-0.00634	-0.2054	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	HOLTON 115KV	12.2	-0.0102	-0.20154	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	JEFFREY ENERGY CENTER 230KV	470	-0.00308	-0.20866	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	JEFFREY ENERGY CENTER 345KV	940	-0.00293	-0.20881	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	LAWRENCE ENERGY CENTER 115KV	85	0.00124	-0.21298	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	LAWRENCE ENERGY CENTER 230KV	236.3199	0.00053	-0.21227	15
WERE	GILL ENERGY CENTER 69KV	118	-0.21174	WERE	TECUMSEH ENERGY CENTER 115KV	128	-0.00156	-0.21018	15

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21457	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	-0.01512	-0.19945	16
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21457	WERE	'SOUTH SENECA 115KV'	8.5	-0.02065	-0.19392	16
WERE	GETTY 69KV'	35	-0.19065	WERE	JEFFREY ENERGY CENTER 230KV'	470	-0.00308	-0.18757	16
WERE	GETTY 69KV'	35	-0.19065	WERE	JEFFREY ENERGY CENTER 345KV'	940	-0.00293	-0.18772	16
WERE	GETTY 69KV'	35	-0.19065	WERE	LAWRENCE ENERGY CENTER 115KV'	85	0.00124	-0.19189	16
WERE	GETTY 69KV'	35	-0.19065	WERE	LAWRENCE ENERGY CENTER 230KV'	236.3199	0.00053	-0.19118	16
WERE	GETTY 69KV'	35	-0.19065	WERE	TECUMSEH ENERGY CENTER 115KV'	128	-0.00156	-0.18909	16
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20918	WERE	BPU - CITY OF MCPHERSON 115KV'	135	-0.01232	-0.19686	16
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20918	WERE	CHANUTE 69KV'	56.723	-0.01127	-0.19791	16
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20918	WERE	CITY OF ERIE 69KV'	22.274	-0.01127	-0.19791	16
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20918	WERE	HOLTON 115KV'	12.2	-0.0102	-0.19898	16
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20918	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	-0.01512	-0.19406	16
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20918	WERE	'SOUTH SENECA 115KV'	8.5	-0.02065	-0.18853	16
WERE	GILL ENERGY CENTER 69KV'	118	-0.21174	WERE	BPU - CITY OF MCPHERSON 115KV'	135	-0.01232	-0.19942	16
WERE	GILL ENERGY CENTER 69KV'	118	-0.21174	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	-0.01512	-0.19662	16
WERE	GILL ENERGY CENTER 69KV'	118	-0.21174	WERE	'SOUTH SENECA 115KV'	8.5	-0.02065	-0.19109	16
WERE	CITY OF MULVANE 69KV'	7.502	-0.2843	WERE	EVANS ENERGY CENTER 138KV'	373.2803	-0.09874	-0.18556	17
WERE	GETTY 69KV'	35	-0.19065	WERE	'ABILENE ENERGY CENTER 115KV'	40	-0.00745	-0.1832	17
WERE	GETTY 69KV'	35	-0.19065	WERE	BPU - CITY OF MCPHERSON 115KV'	135	-0.01232	-0.17833	17
WERE	GETTY 69KV'	35	-0.19065	WERE	CHANUTE 69KV'	56.723	-0.01127	-0.17938	17
WERE	GETTY 69KV'	35	-0.19065	WERE	CITY OF ERIE 69KV'	22.274	-0.01127	-0.17938	17
WERE	GETTY 69KV'	35	-0.19065	WERE	CITY OF IOLA 69KV'	24.267	-0.00508	-0.18557	17
WERE	GETTY 69KV'	35	-0.19065	WERE	CLAY CENTER JUNCTION 115KV'	28.875	-0.00634	-0.18431	17
WERE	GETTY 69KV'	35	-0.19065	WERE	HOLTON 115KV'	12.2	-0.0102	-0.18045	17
WERE	GETTY 69KV'	35	-0.19065	WERE	HUTCHINSON ENERGY CENTER 115KV'	120	-0.01512	-0.17553	18
WERE	GETTY 69KV'	35	-0.19065	WERE	'SOUTH SENECA 115KV'	8.5	-0.02065	-0.17	18
WERE	EVANS ENERGY CENTER 138KV'	249.7197	-0.09874	WERE	CITY OF BURLINGTON 69KV'	10.12	0.04512	-0.14386	22
WERE	EVANS ENERGY CENTER 138KV'	249.7197	-0.09874	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.04512	-0.14386	22
WEPL	HARPER 138KV'	17.21	-0.15498	WEPL	CLIFTON 115KV'	43.35043	-0.0131	-0.14188	22
WEPL	HARPER 138KV'	17.21	-0.15498	WEPL	'A. M. MULLERGEN GENERATOR 115KV'	63	-0.02154	-0.13344	23
WEPL	HARPER 138KV'	17.21	-0.15498	WEPL	GRAY COUNTY WIND FARM 115KV'	73	-0.03375	-0.12123	26
WEPL	HARPER 138KV'	17.21	-0.15498	WEPL	JUDSON LARGE 115KV'	109.0593	-0.03393	-0.12105	26
WERE	CITY OF WINFIELD 69KV'	29.38998	-0.21457	WERE	EVANS ENERGY CENTER 138KV'	373.2803	-0.09874	-0.11583	27
WERE	GILL ENERGY CENTER 69KV'	118	-0.21174	WERE	EVANS ENERGY CENTER 138KV'	373.2803	-0.09874	-0.113	27
WERE	GILL ENERGY CENTER 138KV'	17.99999	-0.20918	WERE	EVANS ENERGY CENTER 138KV'	373.2803	-0.09874	-0.11044	28
WERE	EVANS ENERGY CENTER 138KV'	249.7197	-0.09874	WERE	LAWRENCE ENERGY CENTER 115KV'	85	0.00124	-0.09998	31
WERE	EVANS ENERGY CENTER 138KV'	249.7197	-0.09874	WERE	LAWRENCE ENERGY CENTER 230KV'	236.3199	0.00053	-0.09927	31
WERE	EVANS ENERGY CENTER 138KV'	249.7197	-0.09874	WERE	JEFFREY ENERGY CENTER 230KV'	470	-0.00308	-0.09566	32
WERE	EVANS ENERGY CENTER 138KV'	249.7197	-0.09874	WERE	JEFFREY ENERGY CENTER 345KV'	940	-0.00293	-0.09581	32
WERE	EVANS ENERGY CENTER 138KV'	249.7197	-0.09874	WERE	TECUMSEH ENERGY CENTER 115KV'	128	-0.00156	-0.09718	32

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57837576041570395704211408SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.8	12.2
1090609	1.8	12.2
1090609	0.6	12.2
1090609	1.8	12.2
1090609	7.3	12.2
1090609	0.8	12.2
1090609	1.8	12.2
1090609	0.6	12.2
1090609	1.8	12.2
1090609	7.3	12.2

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	CITY OF AUGUSTA 69KV'	25.12	0.06477	-0.35581	34
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.00491	-0.29595	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	BPU - CITY OF MCPHERSON 115KV'	165	0.00457	-0.29561	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	CLAY CENTER JUNCTION 115KV'	28.875	0.005	-0.29604	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.98	0.00891	-0.29995	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	EVANS ENERGY CENTER 138KV'	565	0.01017	-0.30121	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	GILL ENERGY CENTER 138KV'	171	0.0104	-0.30144	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	GILL ENERGY CENTER 69KV'	75	0.00657	-0.29761	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	HUTCHINSON ENERGY CENTER 115KV'	210	0.00447	-0.29551	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	HUTCHINSON ENERGY CENTER 69KV'	45	0.00447	-0.29551	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00506	-0.2961	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.00505	-0.29609	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	LATHAM1234.0 345KV'	100	0.00979	-0.30083	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	LAWRENCE ENERGY CENTER 115KV'	105	0.00491	-0.29595	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	LAWRENCE ENERGY CENTER 230KV'	234.5897	0.005	-0.29604	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	TECUMSEH ENERGY CENTER 115KV'	158	0.0051	-0.29614	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	'WACO 138KV'	17.967	0.01037	-0.30141	41
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	CHANUTE 69KV'	55.637	0.00405	-0.29509	42
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	CITY OF ERIE 69KV'	22.378	0.00405	-0.29509	42
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	CITY OF IOLA 69KV'	24.471	0.00369	-0.29473	42
WERE	CITY OF WINFIELD 69KV'	25.222	-0.29104	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.09966	-0.19138	64

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57837576041570395704211408WP  
 Date Redispatch Needed: Starting 2008 12/1 - 4/1 Until EOC  
 Season Flowgate Identified: 2008 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.3	5.0
1090609	0.8	5.0
1090609	0.3	5.0
1090609	0.7	5.0
1090609	2.9	5.0

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
		0.3	5.0						
		0.8	5.0						
		0.3	5.0						
		0.7	5.0						
		2.9	5.0						
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.35581	14
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	EVANS ENERGY CENTER 138KV	195	0.01022	-0.3012	16
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	GILL ENERGY CENTER 138KV	38.0459	0.01045	-0.30143	16
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	LATHAM1234.0 345KV	100	0.00985	-0.30083	16
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	WACO 138KV	17.414	0.01043	-0.30141	16
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CHANUTE 69KV	34.903	0.00411	-0.29509	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CITY OF IOLA 69KV	19.902	0.00375	-0.29473	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CLAY CENTER JUNCTION 115KV	10.632	0.00505	-0.29603	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.61	0.00896	-0.29994	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	HOLTON 115KV	8.2	0.00552	-0.2965	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00452	-0.2955	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00511	-0.29609	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	JEFFREY ENERGY CENTER 345KV	940	0.0051	-0.29608	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00496	-0.29594	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	LAWRENCE ENERGY CENTER 230KV	227.2658	0.00505	-0.29603	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	SOUTH SENECA 115KV	8.5	0.00605	-0.29703	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	TECUMSEH ENERGY CENTER 115KV	68.00001	0.00515	-0.29613	17
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CITY OF WELLINGTON 69KV	20	-0.0996	-0.19138	26
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.16443	30
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	EVANS ENERGY CENTER 138KV	195	0.01022	-0.10982	45
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	GILL ENERGY CENTER 138KV	38.0459	0.01045	-0.11005	45
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	LATHAM1234.0 345KV	100	0.00985	-0.10945	45
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	WACO 138KV	17.414	0.01043	-0.11003	45
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.61	0.00896	-0.10856	46
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00511	-0.10471	47
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	JEFFREY ENERGY CENTER 345KV	940	0.0051	-0.1047	47
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00496	-0.10456	47
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	LAWRENCE ENERGY CENTER 230KV	227.2658	0.00505	-0.10465	47
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	TECUMSEH ENERGY CENTER 115KV	68.00001	0.00515	-0.10475	47
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	CHANUTE 69KV	34.903	0.00411	-0.10371	48
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	CITY OF IOLA 69KV	19.902	0.00375	-0.10335	48
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00452	-0.10412	48

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57837576041570395704214406FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.2	1.7
1090609	0.5	1.7
1090609	0.1	1.7
1090609	0.3	1.7
1090609	0.7	1.7
1090609	0.2	1.7
1090609	0.5	1.7
1090609	0.1	1.7
1090609	0.3	1.7
1090609	0.7	1.7

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.35584	5
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	ABILENE ENERGY CENTER 115KV	40	0.00506	-0.29603	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	BPU - CITY OF MCPHERSON 115KV	135	0.00469	-0.29566	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CHANUTE 69KV	39.541	0.00411	-0.29508	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF BURLINGTON 69KV	4.8	0.00904	-0.30001	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF ERIE 69KV	22.171	0.00411	-0.29508	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF GIRARD 69KV	4.788	0.00233	-0.2933	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF IOLA 69KV	16.275	0.00372	-0.29469	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF MULVANE 69KV	4.793	0.01385	-0.30482	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00904	-0.30001	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	EVANS ENERGY CENTER 138KV	340	0.01027	-0.30124	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	GILL ENERGY CENTER 138KV	155	0.0105	-0.30147	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.00457	-0.29554	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00521	-0.29618	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00519	-0.29616	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00505	-0.29602	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	LAWRENCE ENERGY CENTER 230KV	230.6211	0.00514	-0.29611	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	TECUMSEH ENERGY CENTER 115KV	121.3477	0.00524	-0.29621	6
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	WACO 138KV	17.957	0.01048	-0.30145	6
WERE	OXFORD 138KV	3	-0.13752	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.20239	8
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF WELLINGTON 69KV	20	-0.09958	-0.19139	9
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.16445	10
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	EVANS ENERGY CENTER 138KV	340	0.01027	-0.10985	15
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	GILL ENERGY CENTER 138KV	155	0.0105	-0.11008	15
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	WACO 138KV	17.957	0.01048	-0.11006	15
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	ABILENE ENERGY CENTER 115KV	40	0.00506	-0.10464	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	BPU - CITY OF MCPHERSON 115KV	135	0.00469	-0.10427	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	CHANUTE 69KV	39.541	0.00411	-0.10369	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	CITY OF ERIE 69KV	22.171	0.00411	-0.10369	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	CITY OF IOLA 69KV	16.275	0.00372	-0.1033	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00904	-0.10862	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.00457	-0.10415	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00521	-0.10479	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00519	-0.10477	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00505	-0.10463	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	LAWRENCE ENERGY CENTER 230KV	230.6211	0.00514	-0.10472	16
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09958	WERE	TECUMSEH ENERGY CENTER 115KV	121.3477	0.00524	-0.10482	16
WERE	BPU - CITY OF MCPHERSON 115KV	39	0.00469	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.06018	28
WERE	CHANUTE 69KV	48.259	0.00411	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.06076	28
WERE	CITY OF FREDONIA 69KV	9.668992	0.0046	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.06027	28

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	CITY OF IOLA 69KV	21.353	0.00372	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.06115	28
WERE	CLAY CENTER JUNCTION 115KV	28.7	0.00515	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05972	28
WERE	HUTCHINSON ENERGY CENTER 115KV	263	0.00457	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.0603	28
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.00457	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.0603	28
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00519	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05968	28
WERE	LAWRENCE ENERGY CENTER 115KV	78	0.00505	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05982	28
WERE	LAWRENCE ENERGY CENTER 230KV	38.37894	0.00514	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05973	28
WERE	NEOSHO ENERGY CENTER 138KV	47	0.00314	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.06173	28
WERE	SMOKYHIL 230 230KV	72	0.00471	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.06016	28
WERE	GILL ENERGY CENTER 69KV	118	0.00668	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05819	29
WERE	HOLTON 115KV	19.8	0.00562	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05925	29
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00521	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05966	29
WERE	SOUTH SENECA 115KV	16.7	0.00616	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05871	29
WERE	TECUMSEH ENERGY CENTER 115KV	39.6523	0.00524	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05963	29
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00524	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05963	29
WERE	EVANS ENERGY CENTER 138KV	283	0.01027	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.0546	31
WERE	GILL ENERGY CENTER 138KV	17.99999	0.0105	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05437	31
WERE	LATHAM1234.0 345KV	150	0.0099	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.05497	31
WERE	GETTY 69KV	35	0.02607	WERE	CITY OF AUGUSTA 69KV	20.02	0.06487	-0.0388	44
OKGE	CONTINENTAL EMPIRE 138KV	63	-0.03747	OKGE	AES 161KV	320	-0.00242	-0.03505	49
OKGE	CONTINENTAL EMPIRE 138KV	63	-0.03747	OKGE	MUSKOGEE 345KV	1516	-0.00358	-0.03389	50
OKGE	CONTINENTAL EMPIRE 138KV	63	-0.03747	OKGE	SEMINOLE 138KV	385.4342	-0.00688	-0.03059	56
OKGE	CONTINENTAL EMPIRE 138KV	63	-0.03747	OKGE	SEMINOLE 345KV	489	-0.00698	-0.03049	56

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57837576041570395704214406WP  
 Date Redispatch Needed: 12/1/06 - 4/1/07  
 Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.2	1.4
1090609	0.4	1.4
1090609	0.2	1.4
1090609	0.2	1.4
1090609	0.5	1.4
1090609	0.2	1.4
1090609	0.4	1.4
1090609	0.2	1.4
1090609	0.2	1.4
1090609	0.5	1.4

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.35584	4
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CHANUTE 69KV	35.344	0.00405	-0.29508	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF BURLINGTON 69KV	4.8	0.00898	-0.30001	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF ERIE 69KV	2.2	0.00405	-0.29508	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF FREDONIA 69KV	5.225	0.00454	-0.29557	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF IOLA 69KV	13.978	0.00367	-0.2947	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF MULVANE 69KV	3.694	0.01379	-0.30482	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00898	-0.30001	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	EVANS ENERGY CENTER 138KV	156.8254	0.01021	-0.30124	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.0045	-0.29553	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00514	-0.29617	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00513	-0.29616	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00499	-0.29602	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	231.3021	0.00507	-0.2961	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	48	0.00518	-0.29621	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	WACO 138KV	17.953	0.01042	-0.30145	5
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF WELLINGTON 69KV	24.10302	-0.09964	-0.19139	7
WERE	OXFORD 138KV	3	-0.13758	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.20239	7
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.16445	9
WERE	OXFORD 138KV	3	-0.13758	WERE	CITY OF MULVANE 69KV	3.694	0.01379	-0.15137	9
WERE	OXFORD 138KV	3	-0.13758	WERE	EVANS ENERGY CENTER 138KV	156.8254	0.01021	-0.14779	9
WERE	OXFORD 138KV	3	-0.13758	WERE	WACO 138KV	17.953	0.01042	-0.148	9
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	CHANUTE 69KV	35.344	0.00405	-0.10369	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	CITY OF BURLINGTON 69KV	4.8	0.00898	-0.10862	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	CITY OF FREDONIA 69KV	5.225	0.00454	-0.10418	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00898	-0.10862	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	EVANS ENERGY CENTER 138KV	156.8254	0.01021	-0.10985	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.0045	-0.10414	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00514	-0.10478	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00513	-0.10477	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00499	-0.10463	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	LAWRENCE ENERGY CENTER 230KV	231.3021	0.00507	-0.10471	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	TECUMSEH ENERGY CENTER 115KV	48	0.00518	-0.10482	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	WACO 138KV	17.953	0.01042	-0.11006	13
WERE	CITY OF WELLINGTON 69KV	19.39698	-0.09964	WERE	CITY OF IOLA 69KV	13.978	0.00367	-0.10331	14
WERE	CITY OF GIRARD 69KV	9.207	0.00228	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06253	22
WERE	ABILENE ENERGY CENTER 115KV	66	0.00499	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05982	23
WERE	BPU - CITY OF MCPHERSON 115KV	259	0.00462	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06019	23
WERE	CHANUTE 69KV	52.456	0.00405	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06076	23
WERE	CITY OF ERIE 69KV	24.33	0.00405	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06076	23
WERE	CITY OF IOLA 69KV	23.65	0.00367	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06114	23
WERE	CLAY CENTER JUNCTION 115KV	28.7	0.00508	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05973	23
WERE	HUTCHINSON ENERGY CENTER 115KV	343	0.0045	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06031	23
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.0045	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06031	23
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00514	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05967	23
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00513	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05968	23
WERE	LAWRENCE ENERGY CENTER 115KV	78	0.00499	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05982	23
WERE	LAWRENCE ENERGY CENTER 230KV	37.69791	0.00507	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05974	23
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00308	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06173	23
WERE	SMOKYHIL 230 230KV	72	0.00464	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06017	23
WERE	TECUMSEH ENERGY CENTER 115KV	143	0.00518	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05963	23
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00517	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05964	23
WERE	CITY OF OSAGE CITY 115KV	8.85	0.00554	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05927	24
WERE	GILL ENERGY CENTER 69KV	118	0.00662	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05819	24
WERE	HOLTON 115KV	19.8	0.00555	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05926	24
WERE	SOUTH SENECA 115KV	16.7	0.00608	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05873	24
WERE	LATHAM1234.0 345KV	150	0.00984	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05497	25

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	EVANS ENERGY CENTER 138KV'	636.1746	0.01021	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.0546	26
WERE	GILL ENERGY CENTER 138KV'	218	0.01044	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05437	26
WERE	CITY OF MULVANE 69KV'	12.096	0.01379	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.05102	27
WERE	GETTY 69KV'	35	0.02601	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.0388	36
OKGE	CONTINENTAL EMPIRE 138KV'	63	-0.03752	OKGE	AES 161KV'	310	-0.00252	-0.035	40
OKGE	CONTINENTAL EMPIRE 138KV'	63	-0.03752	OKGE	MUSKOGEE 345KV'	1516	-0.00366	-0.03386	41
OKGE	CONTINENTAL EMPIRE 138KV'	63	-0.03752	OKGE	SEMINOLE 138KV'	160.6768	-0.00696	-0.03056	46
OKGE	CONTINENTAL EMPIRE 138KV'	63	-0.03752	OKGE	SEMINOLE 345KV'	489	-0.00706	-0.03046	46

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57837576041570395704214407FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.5	6.4
1090609	1.1	6.4
1090609	0.4	6.4
1090609	0.9	6.4
1090609	3.6	6.4
1090609	0.5	6.4
1090609	1.1	6.4
1090609	0.4	6.4
1090609	0.9	6.4
1090609	3.6	6.4

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	CITY OF AUGUSTA 69KV'	20.02	0.0648	-0.35582	18
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.00505	-0.29607	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00896	-0.29998	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	EVANS ENERGY CENTER 138KV'	305	0.0102	-0.30122	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	GILL ENERGY CENTER 138KV'	155	0.01043	-0.30145	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	HOLTON 115KV'	8.2	0.00553	-0.29655	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00511	-0.29613	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.00509	-0.29611	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	LAWRENCE ENERGY CENTER 230KV'	231.115	0.00504	-0.29606	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	SOUTH SENECA 115KV'	8.5	0.00607	-0.29709	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.00515	-0.29617	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	WACO 138KV'	17.946	0.0104	-0.30142	21
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	ABILENE ENERGY CENTER 115KV'	40	0.00495	-0.29597	22
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	CHANUTE 69KV'	56.296	0.00402	-0.29504	22
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	CITY OF IOLA 69KV'	24.256	0.00363	-0.29465	22
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	HUTCHINSON ENERGY CENTER 115KV'	72.17331	0.00451	-0.29553	22
WERE	CITY OF WINFIELD 69KV'	40	-0.29102	WERE	CITY OF WELLINGTON 69KV'	20	-0.09964	-0.19138	33
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	CITY OF AUGUSTA 69KV'	20.02	0.0648	-0.16444	39
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	EVANS ENERGY CENTER 138KV'	305	0.0102	-0.10984	58
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	GILL ENERGY CENTER 138KV'	155	0.01043	-0.11007	58
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00896	-0.1086	59
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	ABILENE ENERGY CENTER 115KV'	40	0.00495	-0.10459	61
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	CHANUTE 69KV'	56.296	0.00402	-0.10366	61
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	HUTCHINSON ENERGY CENTER 115KV'	72.17331	0.00451	-0.10415	61
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00511	-0.10475	61
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.00509	-0.10473	61
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	LAWRENCE ENERGY CENTER 230KV'	231.115	0.00504	-0.10468	61
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.00515	-0.10479	61
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.09964	WERE	CITY OF IOLA 69KV'	24.256	0.00363	-0.10327	62
OKGE	CONTINENTAL EMPIRE 138KV'	64	-0.0375	OKGE	AES 161KV'	320	-0.00249	-0.03501	182
OKGE	CONTINENTAL EMPIRE 138KV'	64	-0.0375	OKGE	MUSKOGEE 345KV'	1516	-0.0036	-0.0339	188

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57837576041570395704214407G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.6	5.8
1090609	1.3	5.8
1090609	0.5	5.8
1090609	1.0	5.8
1090609	2.4	5.8
1090609	0.6	5.8
1090609	1.3	5.8
1090609	0.5	5.8
1090609	1.0	5.8
1090609	2.4	5.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	CITY OF AUGUSTA 69KV'	20.02	0.06481	-0.35584	16
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	ABILENE ENERGY CENTER 115KV'	40	0.00499	-0.29602	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	20.09	0.00898	-0.30001	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	EVANS ENERGY CENTER 138KV'	340	0.01021	-0.30124	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	GILL ENERGY CENTER 138KV'	155	0.01044	-0.30147	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	HOLTON 115KV'	12.2	0.00556	-0.29659	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00514	-0.29617	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.00513	-0.29616	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.00498	-0.29601	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV'	232.9228	0.00507	-0.2961	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV'	68.00001	0.00518	-0.29621	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	WACO 138KV'	18	0.01042	-0.30145	19
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV'	127.0369	0.00462	-0.29565	20
WERE	CITY OF WINFIELD 69KV'	40	-0.29103	WERE	CHANUTE 69KV'	40.39	0.00405	-0.29508	20

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF IOLA 69KV	17.08	0.00367	-0.2947	20
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0045	-0.29553	20
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF WELLINGTON 69KV	27.198	-0.09964	-0.19139	30
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.16445	35

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57837576041570395704214407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.8	11.1
1090609	1.6	11.1
1090609	0.6	11.1
1090609	1.3	11.1
1090609	6.8	11.1
1090609	0.8	11.1
1090609	1.6	11.1
1090609	0.6	11.1
1090609	1.3	11.1
1090609	6.8	11.1

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.35582	31
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00494	-0.29597	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	77.13525	0.0046	-0.29563	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CLAY CENTER JUNCTION 115KV	17.01001	0.00503	-0.29606	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00895	-0.29998	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	EVANS ENERGY CENTER 138KV	340	0.01018	-0.30121	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	GILL ENERGY CENTER 138KV	155	0.01042	-0.30145	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0045	-0.29553	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00509	-0.29612	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00508	-0.29611	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00494	-0.29597	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	231.9843	0.00502	-0.29605	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00513	-0.29616	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	WACO 138KV	17.947	0.01039	-0.30142	37
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CHANUTE 69KV	46.617	0.004	-0.29503	38
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF IOLA 69KV	22.264	0.004	-0.29503	38
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF ERIE 69KV	19.865	0.00362	-0.29465	38
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF WELLINGTON 69KV	41.45	-0.09965	-0.19138	58

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57837576041570395704214407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	1.0	14.6
1090609	2.1	14.6
1090609	0.7	14.6
1090609	1.7	14.6
1090609	9.1	14.6
1090609	1.0	14.6
1090609	2.1	14.6
1090609	0.7	14.6
1090609	1.7	14.6
1090609	9.1	14.6

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF AUGUSTA 69KV	25.12	0.06479	-0.35582	41
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	EVANS ENERGY CENTER 138KV	544.001	0.01018	-0.30121	48
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	GILL ENERGY CENTER 138KV	171	0.01042	-0.30145	48
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	WACO 138KV	17.96	0.01039	-0.30142	48
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00494	-0.29597	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	135	0.0046	-0.29563	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CHANUTE 69KV	56.723	0.004	-0.29503	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF ERIE 69KV	22.274	0.004	-0.29503	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF IOLA 69KV	24.267	0.00362	-0.29465	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.00503	-0.29606	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00895	-0.29998	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	GILL ENERGY CENTER 69KV	45	0.00659	-0.29762	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.0045	-0.29553	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HUTCHINSON ENERGY CENTER 69KV	40	0.0045	-0.29553	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00509	-0.29612	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00508	-0.29611	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00494	-0.29597	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	232.7283	0.00502	-0.29605	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.00513	-0.29616	49
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF WELLINGTON 69KV	41.45	-0.09965	-0.19138	76

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: EL PASO - FARBER 138KV CKT 1  
 Flowgate: 57837576041570395704214407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Season Flowgate Identified: 2007 Winter Peak		Aggregate Relief Amount	
Reservation	Relief Amount		
1090609	0.4	4.2	
1090609	0.8	4.2	
1090609	0.2	4.2	
1090609	0.6	4.2	
1090609	2.3	4.2	
1090609	0.4	4.2	
1090609	0.8	4.2	
1090609	0.2	4.2	
1090609	0.6	4.2	
1090609	2.3	4.2	

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.35581	12
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CHANUTE 69KV	34.818	0.00407	-0.29504	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF BURLINGTON 69KV	4.8	0.009	-0.29997	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF FREDONIA 69KV	5.225	0.00456	-0.29553	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF IOLA 69KV	14.565	0.00368	-0.29465	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CLAY CENTER JUNCTION 115KV	8.375996	0.00508	-0.29605	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.95	0.009	-0.29997	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	EVANS ENERGY CENTER 138KV	149.2939	0.01024	-0.30121	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	HOLTON 115KV	8.2	0.00555	-0.29652	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00455	-0.29552	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00514	-0.29611	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00513	-0.29611	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	LATHAM1234.0 345KV	100	0.00986	-0.30083	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00498	-0.29595	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	LAWRENCE ENERGY CENTER 230KV	231.1585	0.00507	-0.29604	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	SOUTH SENECA 115KV	8.5	0.00609	-0.29706	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	TECUMSEH ENERGY CENTER 115KV	88	0.00518	-0.29615	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	WACO 138KV	17.93	0.01045	-0.30142	14
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF WELLINGTON 69KV	20	-0.09959	-0.19138	22
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.16443	26
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.95	0.009	-0.10859	39
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	EVANS ENERGY CENTER 138KV	149.2939	0.01024	-0.10983	39
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	LATHAM1234.0 345KV	100	0.00986	-0.10945	39
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	WACO 138KV	17.93	0.01045	-0.11004	39
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00514	-0.10473	40
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00513	-0.10472	40
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	LAWRENCE ENERGY CENTER 230KV	231.1585	0.00507	-0.10466	40
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	TECUMSEH ENERGY CENTER 115KV	88	0.00518	-0.10477	40
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	CHANUTE 69KV	34.818	0.00407	-0.10366	41
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	CITY OF IOLA 69KV	14.565	0.00368	-0.10327	41
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00455	-0.10414	41
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00498	-0.10457	41

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: FARMER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1  
 Flowgate: 57837576041570425706311408SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Season Flowgate Identified: 2008 Summer Peak		Aggregate Relief Amount	
Reservation	Relief Amount		
1090609	0.8	12.2	
1090609	1.8	12.2	
1090609	0.6	12.2	
1090609	1.8	12.2	
1090609	7.3	12.2	
1090609	0.8	12.2	
1090609	1.8	12.2	
1090609	0.6	12.2	
1090609	1.8	12.2	
1090609	7.3	12.2	

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	CITY OF AUGUSTA 69KV	25.12	0.06477	-0.35581	34
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	ABILENE ENERGY CENTER 115KV	40	0.00491	-0.29595	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	BPU - CITY OF MCPHERSON 115KV	165	0.00457	-0.29561	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.005	-0.29604	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.98	0.00891	-0.29995	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	EVANS ENERGY CENTER 138KV	565	0.01017	-0.30121	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	GILL ENERGY CENTER 138KV	171	0.0104	-0.30144	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	GILL ENERGY CENTER 69KV	75	0.00657	-0.29761	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.00447	-0.29551	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	HUTCHINSON ENERGY CENTER 69KV	45	0.00447	-0.29551	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	470	0.00506	-0.29611	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00505	-0.29609	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	LATHAM1234.0 345KV	100	0.00979	-0.30083	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00491	-0.29595	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	LAWRENCE ENERGY CENTER 230KV	234.5897	0.005	-0.29604	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.0051	-0.29614	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	WACO 138KV	17.967	0.01037	-0.30141	41
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	CHANUTE 69KV	55.637	0.00405	-0.29509	42
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	CITY OF ERIE 69KV	22.378	0.00405	-0.29509	42
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	CITY OF IOLA 69KV	24.471	0.00369	-0.29473	42
WERE	CITY OF WINFIELD 69KV	25.222	-0.29104	WERE	CITY OF WELLINGTON 69KV	41.45	-0.09966	-0.19138	64

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: FARMER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1  
 Flowgate: 57837576041570425706311408WP  
 Date Redispatch Needed: Starting 2008 12/1 - 4/1 Until EOC

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Reservation		Relief Amount	Aggregate Relief Amount	
1090609		0.2	2.8	
1090609		0.4	2.8	
1090609		0.2	2.8	
1090609		0.4	2.8	
1090609		1.6	2.8	
1090609		0.2	2.8	
1090609		0.4	2.8	
1090609		0.2	2.8	
1090609		0.4	2.8	
1090609		1.6	2.8	

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.35581	8
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CITY OF BURLINGTON 69KV	4.8	0.00896	-0.29994	9
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CITY OF MULVANE 69KV	3.921	0.0138	-0.30478	9
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.61	0.00896	-0.29994	9
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	EVANS ENERGY CENTER 138KV	195	0.01022	-0.3012	9
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	GILL ENERGY CENTER 138KV	38.0459	0.01045	-0.30143	9
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	LATHAM1234.0 345KV	100	0.00985	-0.30083	9
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	WACO 138KV	17.414	0.01043	-0.30141	9
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CHANUTE 69KV	34.903	0.00411	-0.29509	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CITY OF FREDONIA 69KV	5.225	0.00457	-0.29555	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CITY OF IOLA 69KV	19.902	0.00375	-0.29473	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CLAY CENTER JUNCTION 115KV	10.632	0.00505	-0.29603	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	HOLTON 115KV	8.2	0.00552	-0.2965	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00452	-0.2955	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00511	-0.29609	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	JEFFREY ENERGY CENTER 345KV	940	0.0051	-0.29608	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00496	-0.29594	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	LAWRENCE ENERGY CENTER 230KV	227.2658	0.00505	-0.29603	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	SOUTH SENeca 115KV	8.5	0.00605	-0.29703	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	TECUMSEH ENERGY CENTER 115KV	68.00001	0.00515	-0.29613	10
WERE	CITY OF WINFIELD 69KV	40	-0.29098	WERE	CITY OF WELLINGTON 69KV	20	-0.0996	-0.19138	15
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.16443	17
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.61	0.00896	-0.10856	26
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	EVANS ENERGY CENTER 138KV	195	0.01022	-0.10982	26
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	GILL ENERGY CENTER 138KV	38.0459	0.01045	-0.11005	26
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	LATHAM1234.0 345KV	100	0.00985	-0.10945	26
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	WACO 138KV	17.414	0.01043	-0.11003	26
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	CHANUTE 69KV	34.903	0.00411	-0.10371	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	CITY OF IOLA 69KV	19.902	0.00375	-0.10335	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	CLAY CENTER JUNCTION 115KV	10.632	0.00505	-0.10465	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00452	-0.10412	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00511	-0.10471	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	JEFFREY ENERGY CENTER 345KV	940	0.0051	-0.1047	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00496	-0.10456	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	LAWRENCE ENERGY CENTER 230KV	227.2658	0.00505	-0.10465	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.0996	WERE	TECUMSEH ENERGY CENTER 115KV	68.00001	0.00515	-0.10475	27
WERE	CITY OF IOLA 69KV	17.726	0.00375	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.06108	46
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00311	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.06172	46
WERE	ABILENE ENERGY CENTER 115KV	66	0.00496	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05987	47
WERE	BPU - CITY OF MCPHERSON 115KV	259	0.00462	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.06021	47
WERE	CHANUTE 69KV	52.897	0.00411	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.06072	47
WERE	CITY OF ERIE 69KV	24.138	0.00411	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.06072	47
WERE	CLAY CENTER JUNCTION 115KV	27.468	0.00505	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05978	47
WERE	HUTCHINSON ENERGY CENTER 115KV	343	0.00452	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.06031	47
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.00452	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.06031	47
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00511	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05972	47
WERE	JEFFREY ENERGY CENTER 345KV	42	0.0051	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05973	47
WERE	LAWRENCE ENERGY CENTER 115KV	78	0.00496	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05987	47
WERE	LAWRENCE ENERGY CENTER 230KV	41.73422	0.00505	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05978	47
WERE	SMOKYHIL 230 230KV	72	0.00451	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.06032	47
WERE	TECUMSEH ENERGY CENTER 115KV	123	0.00515	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05968	48
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00515	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05968	48
WERE	GILL ENERGY CENTER 69KV	118	0.00663	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.0582	49
WERE	EVANS ENERGY CENTER 138KV	752	0.01022	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05461	52
WERE	GILL ENERGY CENTER 138KV	156.9541	0.01045	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05438	52
WERE	LATHAM1234.0 345KV	50	0.00985	WERE	CITY OF AUGUSTA 69KV	20.02	0.06483	-0.05498	52

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: FARMER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1  
 Flowgate: 57837576041570425706314407FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation		Relief Amount	Aggregate Relief Amount	
1090609		0.3	4.0	
1090609		0.7	4.0	
1090609		0.3	4.0	
1090609		0.5	4.0	
1090609		2.2	4.0	
1090609		0.3	4.0	
1090609		0.7	4.0	
1090609		0.3	4.0	
1090609		0.5	4.0	
1090609		2.2	4.0	

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.35582	11
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	ABILENE ENERGY CENTER 115KV	40	0.00495	-0.29597	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CHANUTE 69KV	56.296	0.00402	-0.29504	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF BURLINGTON 69KV	4.8	0.00896	-0.29998	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF FREDONIA 69KV	5.225	0.0045	-0.29552	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF MULVANE 69KV	4.891	0.01378	-0.3048	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CLAY CENTER JUNCTION 115KV	8.584003	0.00505	-0.29607	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00896	-0.29998	13

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	EVANS ENERGY CENTER 138KV	305	0.0102	-0.30122	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	GILL ENERGY CENTER 138KV	155	0.01043	-0.30145	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	HOLTON 115KV	8.2	0.00553	-0.29655	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	HUTCHINSON ENERGY CENTER 115KV	72.17331	0.00451	-0.29553	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00511	-0.29613	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00509	-0.29611	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	LAWRENCE ENERGY CENTER 230KV	231.115	0.00504	-0.29606	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	SOUTH SENECA 115KV	8.5	0.00607	-0.29709	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00515	-0.29617	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	WACO 138KV	17.946	0.0104	-0.30142	13
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF IOLA 69KV	24.256	0.00363	-0.29465	14
WERE	CITY OF WINFIELD 69KV	40	-0.29102	WERE	CITY OF WELLINGTON 69KV	20	-0.09964	-0.19138	21
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	CITY OF AUGUSTA 69KV	20.02	0.0648	-0.16444	24
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	EVANS ENERGY CENTER 138KV	305	0.0102	-0.10984	36
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	GILL ENERGY CENTER 138KV	155	0.01043	-0.11007	36
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	WACO 138KV	17.946	0.0104	-0.11004	36
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00896	-0.1086	37
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	ABILENE ENERGY CENTER 115KV	40	0.00495	-0.10459	38
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	CHANUTE 69KV	56.296	0.00402	-0.10366	38
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	HUTCHINSON ENERGY CENTER 115KV	72.17331	0.00451	-0.10415	38
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00511	-0.10475	38
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00509	-0.10473	38
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	LAWRENCE ENERGY CENTER 230KV	231.115	0.00504	-0.10468	38
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00515	-0.10479	38
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09964	WERE	CITY OF IOLA 69KV	24.256	0.00363	-0.10327	39
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.0375	OKGE	AES 161KV	320	-0.00249	-0.03501	114
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.0375	OKGE	MUSKOGEE 345KV	1516	-0.0036	-0.0339	117
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.0375	OKGE	SEMINOLE 138KV	461.789	-0.00691	-0.03059	130
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.0375	OKGE	SEMINOLE 345KV	590.52	-0.00701	-0.03049	131

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1  
 Flowgate: 57837576041570425706314407G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.4	3.2
1090609	0.6	3.2
1090609	0.2	3.2
1090609	0.6	3.2
1090609	1.3	3.2
1090609	0.4	3.2
1090609	0.6	3.2
1090609	0.2	3.2
1090609	0.6	3.2
1090609	1.3	3.2

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.35584	9
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00499	-0.29602	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	127.0369	0.00462	-0.29565	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CHANUTE 69KV	40.39	0.00405	-0.29508	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF BURLINGTON 69KV	4.8	0.00898	-0.30001	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF FREDONIA 69KV	5.225	0.00454	-0.29557	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF IOLA 69KV	17.08	0.00367	-0.2947	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF MULVANE 69KV	4.922	0.01379	-0.30482	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	20.09	0.00898	-0.30001	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	EVANS ENERGY CENTER 138KV	340	0.01021	-0.30124	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	GILL ENERGY CENTER 138KV	155	0.01044	-0.30147	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HOLTON 115KV	12.2	0.00556	-0.29659	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0045	-0.29553	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00514	-0.29617	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00513	-0.29616	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00498	-0.29601	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	232.9228	0.00507	-0.2961	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	68.00001	0.00518	-0.29621	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	WACO 138KV	18	0.01042	-0.30145	11
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF WELLINGTON 69KV	27.198	-0.09964	-0.19139	17
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.16445	20
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	EVANS ENERGY CENTER 138KV	340	0.01021	-0.10985	29
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	GILL ENERGY CENTER 138KV	155	0.01044	-0.11008	29
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	WACO 138KV	18	0.01042	-0.11006	29
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	20.09	0.00898	-0.10862	30
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	ABILENE ENERGY CENTER 115KV	40	0.00499	-0.10463	31
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	BPU - CITY OF MCPHERSON 115KV	127.0369	0.00462	-0.10426	31
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	CHANUTE 69KV	40.39	0.00405	-0.10369	31
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	CITY OF IOLA 69KV	17.08	0.00367	-0.10331	31
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	HOLTON 115KV	12.2	0.00556	-0.1052	31
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0045	-0.10414	31
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00514	-0.10478	31
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00513	-0.10477	31
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00498	-0.10462	31
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	LAWRENCE ENERGY CENTER 230KV	232.9228	0.00507	-0.10471	31
WERE	CITY OF WELLINGTON 69KV	16.302	-0.09964	WERE	TECUMSEH ENERGY CENTER 115KV	68.00001	0.00518	-0.10482	31
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00309	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06172	52
WERE	BPU - CITY OF MCPHERSON 115KV	46.96313	0.00462	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06019	53
WERE	CHANUTE 69KV	47.41	0.00405	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06076	53
WERE	CITY OF ERIE 69KV	24.229	0.00405	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06076	53
WERE	CITY OF IOLA 69KV	20.548	0.00367	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06114	53
WERE	HUTCHINSON ENERGY CENTER 115KV	263	0.0045	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06031	53
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.0045	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06031	53
WERE	SMOKYHIL 230 230KV	72	0.00465	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.06016	53
WERE	CLAY CENTER JUNCTION 115KV	28.7	0.00509	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05972	54
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00514	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05967	54
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00513	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05968	54
WERE	LAWRENCE ENERGY CENTER 115KV	78	0.00498	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05983	54
WERE	LAWRENCE ENERGY CENTER 230KV	36.07718	0.00507	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05974	54
WERE	TECUMSEH ENERGY CENTER 115KV	123	0.00518	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05963	54
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00517	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05964	54

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	GILL ENERGY CENTER 69KV	118	0.00662	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05819	55
WERE	LATHAM1234.0 345KV	150	0.00984	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.05497	58
WERE	EVANS ENERGY CENTER 138KV	313	0.01021	WERE	CITY OF AUGUSTA 69KV	20.02	0.06481	-0.0546	59

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1  
 Flowgate: 57837576041570425706314407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.5	8.1
1090609	1.2	8.1
1090609	0.4	8.1
1090609	1.0	8.1
1090609	4.9	8.1
1090609	0.5	8.1
1090609	1.2	8.1
1090609	0.4	8.1
1090609	1.0	8.1
1090609	4.9	8.1

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF AUGUSTA 69KV	20.02	0.06479	-0.35582	23
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00494	-0.29597	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	77.13525	0.0046	-0.29563	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CHANUTE 69KV	46.617	0.004	-0.29503	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF ERIE 69KV	22.264	0.004	-0.29503	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF IOLA 69KV	19.865	0.00362	-0.29465	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CLAY CENTER JUNCTION 115KV	17.01001	0.00503	-0.29606	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00895	-0.29998	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	EVANS ENERGY CENTER 138KV	340	0.01018	-0.30121	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	GILL ENERGY CENTER 138KV	155	0.01042	-0.30145	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HOLTON 115KV	12.2	0.00551	-0.29654	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0045	-0.29553	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00509	-0.29612	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00508	-0.29611	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00494	-0.29597	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	231.9843	0.00502	-0.29605	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00513	-0.29616	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	WACO 138KV	17.947	0.01039	-0.30142	27
WERE	CITY OF WINFIELD 69KV	40	-0.29103	WERE	CITY OF WELLINGTON 69KV	41.45	-0.09965	-0.19138	42

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1  
 Flowgate: 57837576041570425706314407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	1.0	13.5
1090609	2.0	13.5
1090609	0.7	13.5
1090609	1.6	13.5
1090609	8.3	13.5
1090609	1.0	13.5
1090609	2.0	13.5
1090609	0.7	13.5
1090609	1.6	13.5
1090609	8.3	13.5

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF AUGUSTA 69KV	25.12	0.06479	-0.35582	38
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00895	-0.29998	45
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	EVANS ENERGY CENTER 138KV	544.001	0.01018	-0.30121	45
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	GILL ENERGY CENTER 138KV	171	0.01042	-0.30145	45
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	GILL ENERGY CENTER 69KV	45	0.00659	-0.29762	45
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	WACO 138KV	17.96	0.01039	-0.30142	45
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	ABILENE ENERGY CENTER 115KV	40	0.00494	-0.29597	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	BPU - CITY OF MCPHERSON 115KV	135	0.0046	-0.29563	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CHANUTE 69KV	56.723	0.004	-0.29503	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF ERIE 69KV	22.274	0.004	-0.29503	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF IOLA 69KV	24.267	0.00362	-0.29465	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.00503	-0.29606	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.0045	-0.29553	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 69KV	40	0.0045	-0.29553	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00509	-0.29612	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00508	-0.29611	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00494	-0.29597	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	LAWRENCE ENERGY CENTER 230KV	232.7283	0.00502	-0.29605	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.00513	-0.29616	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.29103	WERE	CITY OF WELLINGTON 69KV	41.45	-0.09965	-0.19138	70

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1  
 Flowgate: 57837576041570425706314407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Season Flowgate Identified: 2007 Winter Peak		Aggregate Relief Amount								
Reservation	Relief Amount									
1090609	0.3	2.1								
1090609	0.4	2.1								
1090609	0.1	2.1								
1090609	0.4	2.1								
1090609	1.0	2.1								
1090609	0.3	2.1								
1090609	0.4	2.1								
1090609	0.1	2.1								
1090609	0.4	2.1								
1090609	1.0	2.1								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.35581	6	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CHANUTE 69KV	34.818	0.00407	-0.29504	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF BURLINGTON 69KV	4.8	0.009	-0.29997	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF FREDONIA 69KV	5.225	0.00456	-0.29553	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF IOLA 69KV	14.565	0.00368	-0.29465	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF MULVANE 69KV	3.791	0.01383	-0.3048	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CLAY CENTER JUNCTION 115KV	8.375996	0.00508	-0.29605	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.95	0.009	-0.29997	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	EVANS ENERGY CENTER 138KV	149.2939	0.01024	-0.30121	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	HOLTON 115KV	8.2	0.00555	-0.29652	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00455	-0.29552	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00514	-0.29611	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00513	-0.2961	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	LATHAM1234.0 345KV	100	0.00986	-0.30083	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00498	-0.29595	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	LAWRENCE ENERGY CENTER 230KV	231.1585	0.00507	-0.29604	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	SOUTH SENeca 115KV	8.5	0.00609	-0.29706	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	TECUMSEH ENERGY CENTER 115KV	88	0.00518	-0.29615	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	WACO 138KV	17.93	0.01045	-0.30142	7	
WERE	CITY OF WINFIELD 69KV	40	-0.29097	WERE	CITY OF WELLINGTON 69KV	20	-0.09959	-0.19138	11	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.16443	13	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	EVANS ENERGY CENTER 138KV	149.2939	0.01024	-0.10983	19	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	LATHAM1234.0 345KV	100	0.00986	-0.10945	19	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	WACO 138KV	17.93	0.01045	-0.11004	19	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	CLAY CENTER JUNCTION 115KV	8.375996	0.00508	-0.10467	20	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.95	0.009	-0.10859	20	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	HOLTON 115KV	8.2	0.00555	-0.10514	20	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00455	-0.10414	20	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00514	-0.10473	20	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00513	-0.10472	20	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00498	-0.10457	20	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	LAWRENCE ENERGY CENTER 230KV	231.1585	0.00507	-0.10466	20	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	SOUTH SENeca 115KV	8.5	0.00609	-0.10568	20	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	TECUMSEH ENERGY CENTER 115KV	88	0.00518	-0.10477	20	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	CHANUTE 69KV	34.818	0.00407	-0.10366	21	
WERE	CITY OF WELLINGTON 69KV	23.5	-0.09959	WERE	CITY OF IOLA 69KV	14.565	0.00368	-0.10327	21	
WERE	NEOSHO ENERGY CENTER 138KV	67	0.0031	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.06174	34	
WERE	BPU - CITY OF MCPHERSON 115KV	259	0.00464	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.0602	35	
WERE	CHANUTE 69KV	52.982	0.00407	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.06077	35	
WERE	CITY OF ERIE 69KV	24.231	0.00407	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.06077	35	
WERE	CITY OF IOLA 69KV	23.063	0.00368	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.06116	35	
WERE	HUTCHINSON ENERGY CENTER 115KV	343	0.00455	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.06029	35	
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.00455	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.06029	35	
WERE	SMOKYHIL 230 230KV	72	0.00453	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.06031	35	
WERE	ABILENE ENERGY CENTER 115KV	66	0.00499	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.05985	36	
WERE	CLAY CENTER JUNCTION 115KV	29.72401	0.00508	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.05976	36	
WERE	JEFFREY ENERGY CENTER 230KV	24	0.00514	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.0597	36	
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00513	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.05971	36	
WERE	LAWRENCE ENERGY CENTER 115KV	78	0.00498	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.05986	36	
WERE	LAWRENCE ENERGY CENTER 230KV	37.94149	0.00507	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.05977	36	
WERE	TECUMSEH ENERGY CENTER 115KV	73	0.00518	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.05966	36	
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00517	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.05967	36	
WERE	GILL ENERGY CENTER 69KV	118	0.00665	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.05819	37	
WERE	EVANS ENERGY CENTER 138KV	643.7061	0.01024	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.0546	39	
WERE	GILL ENERGY CENTER 138KV	218	0.01047	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.05437	39	
WERE	LATHAM1234.0 345KV	50	0.00986	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.05498	39	
WERE	GETTY 69KV	35	0.02604	WERE	CITY OF AUGUSTA 69KV	20.02	0.06484	-0.0388	55	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-40  
 Flowgate: 57837576041SPP-WERE-401408SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Season Flowgate Identified: 2008 Summer Peak		Aggregate Relief Amount								
Reservation	Relief Amount									
1090609	0.9	12.6								
1090609	1.9	12.6								
1090609	0.6	12.6								
1090609	1.9	12.6								
1090609	7.3	12.6								
1090609	0.9	12.6								
1090609	1.9	12.6								
1090609	0.6	12.6								
1090609	1.9	12.6								
1090609	7.3	12.6								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
WERE	CITY OF WINFIELD 69KV	25.222	-0.30858	WERE	CITY OF AUGUSTA 69KV	25.12	0.06267	-0.37125	34	
WERE	CITY OF WINFIELD 69KV	25.222	-0.30858	WERE	ABILENE ENERGY CENTER 115KV	40	0.00457	-0.31315	40	
WERE	CITY OF WINFIELD 69KV	25.222	-0.30858	WERE	BPU - CITY OF MCPHERSON 115KV	165	0.00424	-0.31282	40	
WERE	CITY OF WINFIELD 69KV	25.222	-0.30858	WERE	CHANUTE 69KV	55.637	0.00385	-0.31243	40	
WERE	CITY OF WINFIELD 69KV	25.222	-0.30858	WERE	CITY OF ERIE 69KV	22.378	0.00385	-0.31243	40	
WERE	CITY OF WINFIELD 69KV	25.222	-0.30858	WERE	CITY OF IOLA 69KV	24.471	0.0035	-0.31208	40	
WERE	CITY OF WINFIELD 69KV	25.222	-0.30858	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.00466	-0.31324	40	

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.98	0.00835	-0.31693	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	EVANS ENERGY CENTER 138KV	565	0.00932	-0.3179	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	GILL ENERGY CENTER 138KV	171	0.00916	-0.31774	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	GILL ENERGY CENTER 69KV	75	0.00491	-0.31349	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.00414	-0.31272	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	HUTCHINSON ENERGY CENTER 69KV	45	0.00414	-0.31272	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00472	-0.3133	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00471	-0.31329	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	LATHAM1234.0 345KV	100	0.00919	-0.31777	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00459	-0.31317	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	LAWRENCE ENERGY CENTER 230KV	234.5897	0.00467	-0.31325	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.00476	-0.31334	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	WACO 138KV	17,967	0.00918	-0.31776	40
WERE	CITY OF WINFIELD 69KV	25,222	-0.30858	WERE	CITY OF WELLINGTON 69KV	41.45	-0.11255	-0.19603	64

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-40  
 Flowgate: 57837576041SPP-WERE-401408WP  
 Date Redispatch Needed: Starting 2008 12/1 - 4/1 Until EOC  
 Season Flowgate Identified: 2008 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.3	3.9
1090609	0.6	3.9
1090609	0.2	3.9
1090609	0.6	3.9
1090609	2.1	3.9
1090609	0.3	3.9
1090609	0.6	3.9
1090609	0.2	3.9
1090609	0.6	3.9
1090609	2.1	3.9

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	CITY OF AUGUSTA 69KV	20.02	0.06272	-0.37124	10
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	CHANUTE 69KV	34.903	0.00391	-0.31243	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	CITY OF BURLINGTON 69KV	4.8	0.00841	-0.31693	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	CITY OF FREDONIA 69KV	5.225	0.00435	-0.31287	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	CITY OF IOLA 69KV	19.902	0.00356	-0.31208	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	CLAY CENTER JUNCTION 115KV	10.632	0.00471	-0.31323	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.61	0.00841	-0.31693	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	EVANS ENERGY CENTER 138KV	195	0.00937	-0.31789	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	GILL ENERGY CENTER 138KV	38.0459	0.00921	-0.31773	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	HOLTON 115KV	8.2	0.00518	-0.3137	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00419	-0.31271	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00477	-0.31329	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00475	-0.31327	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	LATHAM1234.0 345KV	100	0.00925	-0.31777	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00463	-0.31315	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	LAWRENCE ENERGY CENTER 230KV	227.2658	0.00471	-0.31323	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	SOUTH SENECA 115KV	8.5	0.00569	-0.31421	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	TECUMSEH ENERGY CENTER 115KV	68.00001	0.00481	-0.31333	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	WACO 138KV	17.414	0.00923	-0.31775	12
WERE	CITY OF WINFIELD 69KV	40	-0.30852	WERE	CITY OF WELLINGTON 69KV	20	-0.11249	-0.19603	20
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	CITY OF AUGUSTA 69KV	20.02	0.06272	-0.17521	22
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.61	0.00841	-0.1209	32
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	EVANS ENERGY CENTER 138KV	195	0.00937	-0.12186	32
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	GILL ENERGY CENTER 138KV	38.0459	0.00921	-0.1217	32
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	LATHAM1234.0 345KV	100	0.00925	-0.12174	32
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	WACO 138KV	17.414	0.00923	-0.12172	32
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	CHANUTE 69KV	34.903	0.00391	-0.1164	33
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00419	-0.11668	33
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00477	-0.11726	33
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00475	-0.11724	33
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00463	-0.11712	33
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	LAWRENCE ENERGY CENTER 230KV	227.2658	0.00471	-0.1172	33
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	TECUMSEH ENERGY CENTER 115KV	68.00001	0.00481	-0.1173	33
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11249	WERE	CITY OF IOLA 69KV	19.902	0.00356	-0.11605	34

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-40  
 Flowgate: 57837576041SPP-WERE-404407FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.4	4.7
1090609	0.8	4.7
1090609	0.3	4.7
1090609	0.7	4.7
1090609	2.5	4.7
1090609	0.4	4.7
1090609	0.8	4.7
1090609	0.3	4.7
1090609	0.7	4.7
1090609	2.5	4.7

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.37126	13
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	ABILENE ENERGY CENTER 115KV	40	0.00461	-0.31317	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	CHANUTE 69KV	56.296	0.00382	-0.31238	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	CITY OF FREDONIA 69KV	5.225	0.00429	-0.31285	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	CITY OF IOLA 69KV	24.256	0.00344	-0.312	15

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	CLAY CENTER JUNCTION 115KV	8.584003	0.0047	-0.31326	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.0084	-0.31696	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	EVANS ENERGY CENTER 138KV	305	0.00935	-0.31791	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	GILL ENERGY CENTER 138KV	155	0.00919	-0.31775	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	HOLTON 115KV	8.2	0.00518	-0.31374	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	HUTCHINSON ENERGY CENTER 115KV	72.17331	0.00418	-0.31274	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00477	-0.31333	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00475	-0.31331	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	LAWRENCE ENERGY CENTER 230KV	231.115	0.0047	-0.31326	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	SOUTH SENECA 115KV	8.5	0.00571	-0.31427	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0048	-0.31336	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	WACO 138KV	17.946	0.00921	-0.31777	15
WERE	CITY OF WINFIELD 69KV	40	-0.30856	WERE	CITY OF WELLINGTON 69KV	20	-0.11253	-0.19603	24
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	CITY OF AUGUSTA 69KV	20.02	0.0627	-0.17523	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.0084	-0.12093	39
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	EVANS ENERGY CENTER 138KV	305	0.00935	-0.12188	39
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	GILL ENERGY CENTER 138KV	155	0.00919	-0.12172	39
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	WACO 138KV	17.946	0.00921	-0.12174	39
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	ABILENE ENERGY CENTER 115KV	40	0.00461	-0.11714	40
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00477	-0.1173	40
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00475	-0.11728	40
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	LAWRENCE ENERGY CENTER 230KV	231.115	0.0047	-0.11723	40
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.0048	-0.11733	40
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	CHANUTE 69KV	56.296	0.00382	-0.11635	41
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	CITY OF IOLA 69KV	24.256	0.00344	-0.11597	41
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11253	WERE	HUTCHINSON ENERGY CENTER 115KV	72.17331	0.00418	-0.11671	41
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.03511	OKGE	AES 161KV	320	-0.00233	-0.03278	144
OKGE	CONTINENTAL EMPIRE 138KV	64	-0.03511	OKGE	MUSKOGEE 345KV	1516	-0.00337	-0.03174	149

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-40  
 Flowgate: 57837576041SPP-WERE-404407G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.4	3.8
1090609	0.8	3.8
1090609	0.4	3.8
1090609	0.7	3.8
1090609	1.6	3.8
1090609	0.4	3.8
1090609	0.8	3.8
1090609	0.4	3.8
1090609	0.7	3.8
1090609	1.6	3.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF AUGUSTA 69KV	20.02	0.06271	-0.37128	10
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	ABILENE ENERGY CENTER 115KV	40	0.00465	-0.31322	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	BPU - CITY OF MCPHERSON 115KV	127.0369	0.00429	-0.31286	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CHANUTE 69KV	40.39	0.00385	-0.31242	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF BURLINGTON 69KV	4.8	0.00842	-0.31699	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF FREDONIA 69KV	5.225	0.00433	-0.3129	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF IOLA 69KV	17.08	0.00348	-0.31205	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF MULVANE 69KV	4.922	0.0126	-0.32117	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	20.09	0.00842	-0.31699	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	EVANS ENERGY CENTER 138KV	340	0.00936	-0.31793	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	GILL ENERGY CENTER 138KV	155	0.0092	-0.31777	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	HOLTON 115KV	12.2	0.00521	-0.31378	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.00416	-0.31273	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	JEFFREY ENERGY CENTER 230KV	470	0.0048	-0.31337	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00478	-0.31335	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00465	-0.31322	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	LAWRENCE ENERGY CENTER 230KV	232.9228	0.00473	-0.3133	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	TECUMSEH ENERGY CENTER 115KV	68.00001	0.00483	-0.3134	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	WACO 138KV	18	0.00922	-0.31779	12
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF WELLINGTON 69KV	27.198	-0.11253	-0.19604	20
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	CITY OF AUGUSTA 69KV	20.02	0.06271	-0.17524	22
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	20.09	0.00842	-0.12095	32
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	EVANS ENERGY CENTER 138KV	340	0.00936	-0.12189	32
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	GILL ENERGY CENTER 138KV	155	0.0092	-0.12173	32
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	WACO 138KV	18	0.00922	-0.12175	32
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	ABILENE ENERGY CENTER 115KV	40	0.00465	-0.11718	33
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	BPU - CITY OF MCPHERSON 115KV	127.0369	0.00429	-0.11682	33
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	CHANUTE 69KV	40.39	0.00385	-0.11638	33
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	CITY OF IOLA 69KV	17.08	0.00348	-0.11601	33
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	HOLTON 115KV	12.2	0.00521	-0.11774	33
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.00416	-0.11669	33
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	JEFFREY ENERGY CENTER 230KV	470	0.0048	-0.11733	33
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00478	-0.11731	33
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00465	-0.11718	33
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	LAWRENCE ENERGY CENTER 230KV	232.9228	0.00473	-0.11726	33
WERE	CITY OF WELLINGTON 69KV	16.302	-0.11253	WERE	TECUMSEH ENERGY CENTER 115KV	68.00001	0.00483	-0.11736	33

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-40  
 Flowgate: 57837576041SPP-WERE-404407SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.7	9.2
1090609	1.4	9.2

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

1090609		0.5								9.2
1090609		1.1								9.2
1090609		5.5								9.2
1090609		0.7								9.2
1090609		1.4								9.2
1090609		0.5								9.2
1090609		1.1								9.2
1090609		5.5								9.2
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF AUGUSTA 69KV	20.02	0.06269	-0.37126	25	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	ABILENE ENERGY CENTER 115KV	40	0.00459	-0.31316	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	BPU - CITY OF MCPHERSON 115KV	77.13525	0.00426	-0.31283	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CHANUTE 69KV	46.617	0.00381	-0.31238	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF ERIE 69KV	22.264	0.00381	-0.31238	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF IOLA 69KV	19.865	0.00343	-0.312	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CLAY CENTER JUNCTION 115KV	17.01001	0.00469	-0.31326	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00839	-0.31696	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	EVANS ENERGY CENTER 138KV	340	0.00934	-0.31791	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	GILL ENERGY CENTER 138KV	155	0.00918	-0.31775	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	HOLTON 115KV	12.2	0.00516	-0.31373	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.00416	-0.31273	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00475	-0.31332	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00474	-0.31331	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00461	-0.31318	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	LAWRENCE ENERGY CENTER 230KV	231.9843	0.00469	-0.31326	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.00479	-0.31336	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	WACO 138KV	17.947	0.00919	-0.31776	29	
WERE	CITY OF WINFIELD 69KV	40	-0.30857	WERE	CITY OF WELLINGTON 69KV	41.45	-0.11254	-0.19603	47	

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-40  
 Flowgate: 57837576041SPP-WERE-404407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	1.0	14.7
1090609	2.2	14.7
1090609	0.7	14.7
1090609	1.8	14.7
1090609	8.9	14.7
1090609	1.0	14.7
1090609	2.2	14.7
1090609	0.7	14.7
1090609	1.8	14.7
1090609	8.9	14.7

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CITY OF AUGUSTA 69KV	25.12	0.06269	-0.37126	40
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00839	-0.31696	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	EVANS ENERGY CENTER 138KV	544.001	0.00934	-0.31791	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	GILL ENERGY CENTER 138KV	171	0.00918	-0.31775	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	WACO 138KV	17.96	0.00919	-0.31776	46
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	ABILENE ENERGY CENTER 115KV	40	0.00459	-0.31316	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	BPU - CITY OF MCPHERSON 115KV	135	0.00426	-0.31283	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CHANUTE 69KV	56.723	0.00381	-0.31238	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CITY OF ERIE 69KV	22.274	0.00381	-0.31238	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CITY OF IOLA 69KV	24.267	0.00343	-0.312	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CLAY CENTER JUNCTION 115KV	28.875	0.00469	-0.31326	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	GILL ENERGY CENTER 69KV	45	0.00493	-0.3135	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	HUTCHINSON ENERGY CENTER 115KV	210	0.00417	-0.31274	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	HUTCHINSON ENERGY CENTER 69KV	40	0.00417	-0.31274	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00475	-0.31332	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00474	-0.31331	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.00461	-0.31318	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	LAWRENCE ENERGY CENTER 230KV	232.7283	0.00469	-0.31326	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.00479	-0.31336	47
WERE	CITY OF WINFIELD 69KV	29.38998	-0.30857	WERE	CITY OF WELLINGTON 69KV	41.45	-0.11254	-0.19603	75

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Limiting Facility: ROSE HILL JUNCTION - WEAVER 69KV CKT 1  
 Direction: To->From  
 Line Outage: SPP-WERE-40  
 Flowgate: 57837576041SPP-WERE-404407WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.3	3.3
1090609	0.5	3.3
1090609	0.3	3.3
1090609	0.5	3.3
1090609	1.8	3.3
1090609	0.3	3.3
1090609	0.5	3.3
1090609	0.3	3.3
1090609	0.5	3.3
1090609	1.8	3.3

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.37125	9
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	CITY OF BURLINGTON 69KV	4.8	0.00844	-0.31695	10
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	CITY OF MULVANE 69KV	3.791	0.01263	-0.32114	10



Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.95	0.00844	-0.31695	10
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	EVANS ENERGY CENTER 138KV	149.2939	0.00939	-0.3179	10
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	LATHAM1234.0 345KV	100	0.00926	-0.31777	10
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	WACO 138KV	17.93	0.00925	-0.31776	10
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	CHANUTE 69KV	34.818	0.00387	-0.31238	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	CITY OF FREDONIA 69KV	5.225	0.00434	-0.31285	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	CITY OF IOLA 69KV	14.565	0.00349	-0.312	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	CLAY CENTER JUNCTION 115KV	8.375996	0.00473	-0.31324	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	HOLTON 115KV	8.2	0.00521	-0.31372	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00421	-0.31272	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	JEFFREY ENERGY CENTER 230KV	470	0.0048	-0.31331	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00478	-0.31329	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00465	-0.31316	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	LAWRENCE ENERGY CENTER 230KV	231.1585	0.00473	-0.31324	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	SOUTH SENECA 115KV	8.5	0.00573	-0.31424	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	TECUMSEH ENERGY CENTER 115KV	88	0.00483	-0.31334	11
WERE	CITY OF WINFIELD 69KV	40	-0.30851	WERE	CITY OF WELLINGTON 69KV	20	-0.11248	-0.19603	17
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.17522	19
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.95	0.00844	-0.12092	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	EVANS ENERGY CENTER 138KV	149.2939	0.00939	-0.12187	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	LATHAM1234.0 345KV	100	0.00926	-0.12174	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	WACO 138KV	17.93	0.00925	-0.12173	27
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	CHANUTE 69KV	34.818	0.00387	-0.11635	28
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	CITY OF IOLA 69KV	14.565	0.00349	-0.11597	28
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	HUTCHINSON ENERGY CENTER 115KV	40	0.00421	-0.11669	28
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	JEFFREY ENERGY CENTER 230KV	470	0.0048	-0.11728	28
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	JEFFREY ENERGY CENTER 345KV	940	0.00478	-0.11726	28
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.00465	-0.11713	28
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	LAWRENCE ENERGY CENTER 230KV	231.1585	0.00473	-0.11721	28
WERE	CITY OF WELLINGTON 69KV	23.5	-0.11248	WERE	TECUMSEH ENERGY CENTER 115KV	88	0.00483	-0.11731	28
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00293	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05981	55
WERE	CHANUTE 69KV	52.982	0.00387	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05887	56
WERE	CITY OF ERIE 69KV	24.231	0.00387	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05887	56
WERE	CITY OF IOLA 69KV	23.063	0.00349	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05925	56
WERE	HUTCHINSON ENERGY CENTER 115KV	343	0.00421	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05853	56
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.00421	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05853	56
WERE	SMOKYHIL 230 230KV	72	0.00421	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05853	56
WERE	ABILENE ENERGY CENTER 115KV	66	0.00464	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.0581	57
WERE	BPU - CITY OF MCPHERSON 115KV	259	0.00431	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05843	57
WERE	CLAY CENTER JUNCTION 115KV	29.72401	0.00473	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05801	57
WERE	GILL ENERGY CENTER 69KV	118	0.00499	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05775	57
WERE	JEFFREY ENERGY CENTER 230KV	24	0.0048	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05794	57
WERE	JEFFREY ENERGY CENTER 345KV	42	0.00478	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05796	57
WERE	LAWRENCE ENERGY CENTER 115KV	78	0.00465	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05809	57
WERE	LAWRENCE ENERGY CENTER 230KV	37.84149	0.00473	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05801	57
WERE	TECUMSEH ENERGY CENTER 115KV	73	0.00483	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05791	57
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.00483	WERE	CITY OF AUGUSTA 69KV	20.02	0.06274	-0.05791	57

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Seven Rivers to Pecos to Potash Junction 230kV  
 Limiting Facility: CARLSBAD PLANT - POTASH JUNCTION INTERCHANGE 115KV CKT 1  
 Direction: To->From  
 Line Outage: CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1  
 Flowgate: 52310522521522095218511207SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090487	3.1	3.8
1090695	0.7	3.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	CARLSBAD 69KV	18	-0.26518	SPS	CUNNINGHAM 115KV	110	0.10078	-0.36596	10
SPS	CARLSBAD 69KV	18	-0.26518	SPS	CUNNINGHAM 115KV	71	0.10078	-0.36596	10
SPS	CARLSBAD 69KV	18	-0.26518	SPS	CUNNINGHAM 230KV	306	0.10412	-0.3693	10
SPS	CARLSBAD 69KV	18	-0.26518	SPS	MADDOX 115KV	183	0.09795	-0.36313	10
SPS	CARLSBAD 69KV	18	-0.26518	SPS	MUSTANG 115KV	300	0.05555	-0.32073	12
SPS	CARLSBAD 69KV	18	-0.26518	SPS	MUSTG5 118.0 230KV	360	0.04864	-0.31382	12
SPS	CARLSBAD 69KV	18	-0.26518	SPS	BLACKHAWK 115KV	220	-0.00345	-0.26173	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	CZ 69KV	39	-0.00318	-0.262	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	HARRINGTON 230KV	1066	-0.00354	-0.26164	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	HUBRCO2 69KV	11	-0.00345	-0.26173	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	JONES 230KV	486	0.01408	-0.27926	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	LP-BRND2 69KV	174.3398	0.01314	-0.27832	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	MOORE COUNTY 115KV	48	-0.0036	-0.26158	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	NICHOLS 115KV	213	-0.00345	-0.26173	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	NICHOLS 230KV	244	-0.0035	-0.26168	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	SIDRCH 69KV	20	-0.00345	-0.26173	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	STEER WATER 115KV	9.818184	-0.00332	-0.26186	14
SPS	CARLSBAD 69KV	18	-0.26518	SPS	PLANTX 115KV	253	-0.00574	-0.25944	15
SPS	CARLSBAD 69KV	18	-0.26518	SPS	PLANTX 230KV	189	-0.00895	-0.25623	15
SPS	CARLSBAD 69KV	18	-0.26518	SPS	TOLK 230KV	1035.277	-0.01282	-0.25236	15
SPS	CARLSBAD 69KV	18	-0.26518	SPS	WILWIND 230KV	19.63637	-0.00498	-0.2602	15
SPS	CARLSBAD 69KV	18	-0.26518	SPS	CAPROCK 115KV	9.818184	-0.02589	-0.23929	16
SPS	CARLSBAD 69KV	18	-0.26518	SPS	SAN JUAN 230KV	14.72727	-0.06407	-0.20111	19
SPS	TOLK 345KV	540	-0.0321	SPS	CUNNINGHAM 115KV	71	0.10078	-0.13288	28
SPS	TOLK 345KV	540	-0.0321	SPS	CUNNINGHAM 115KV	110	0.10078	-0.13288	28
SPS	TOLK 345KV	540	-0.0321	SPS	CUNNINGHAM 230KV	306	0.10412	-0.13622	28
SPS	TOLK 345KV	540	-0.0321	SPS	MADDOX 115KV	183	0.09795	-0.13005	29
SPS	TUCUMCARI 115KV	15	-0.02589	SPS	CUNNINGHAM 230KV	306	0.10412	-0.13001	29
SPS	TUCUMCARI 115KV	15	-0.02589	SPS	CUNNINGHAM 115KV	110	0.10078	-0.12667	30
SPS	TUCUMCARI 115KV	15	-0.02589	SPS	CUNNINGHAM 115KV	71	0.10078	-0.12667	30
SPS	TUCUMCARI 115KV	15	-0.02589	SPS	MADDOX 115KV	183	0.09795	-0.12384	31
SPS	TOLK 230KV	584.7234	-0.01282	SPS	CUNNINGHAM 230KV	306	0.10412	-0.11694	32
SPS	TOLK 230KV	584.7234	-0.01282	SPS	CUNNINGHAM 115KV	110	0.10078	-0.1136	33
SPS	TOLK 230KV	584.7234	-0.01282	SPS	CUNNINGHAM 115KV	71	0.10078	-0.1136	33
SPS	TOLK 230KV	584.7234	-0.01282	SPS	MADDOX 115KV	183	0.09795	-0.11077	34
SPS	RIVERVIEW 69KV	23	-0.00345	SPS	CUNNINGHAM 230KV	306	0.10412	-0.10757	35
SPS	RIVERVIEW 69KV	23	-0.00345	SPS	CUNNINGHAM 115KV	71	0.10078	-0.10423	36
SPS	RIVERVIEW 69KV	23	-0.00345	SPS	CUNNINGHAM 115KV	110	0.10078	-0.10423	36
SPS	RIVERVIEW 69KV	23	-0.00345	SPS	MADDOX 115KV	183	0.09795	-0.1014	37
SPS	JONES 230KV	243	0.01408	SPS	CUNNINGHAM 230KV	306	0.10412	-0.09004	42
SPS	LP-BRND2 69KV	57.66016	0.01314	SPS	CUNNINGHAM 230KV	306	0.10412	-0.09098	42

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

SPS	LP-BRND2 69KV'	57.66016	0.01314	SPS	CUNNINGHAM 115KV'	71	0.10078	-0.08764	43
SPS	LP-BRND2 69KV'	57.66016	0.01314	SPS	CUNNINGHAM 115KV'	110	0.10078	-0.08764	43
SPS	TOLK 345KV'	540	-0.0321	SPS	MUSTANG 115KV'	300	0.05555	-0.08765	43
SPS	JONES 230KV'	243	0.01408	SPS	CUNNINGHAM 115KV'	110	0.10078	-0.0867	44
SPS	JONES 230KV'	243	0.01408	SPS	CUNNINGHAM 115KV'	71	0.10078	-0.0867	44
SPS	JONES 230KV'	243	0.01408	SPS	MADDOX 115KV'	183	0.09795	-0.0837	45
SPS	LP-BRND2 69KV'	57.66016	0.01314	SPS	MADDOX 115KV'	183	0.09795	-0.08481	45
SPS	TOLK 345KV'	540	-0.0321	SPS	MUSTG5 118.0 230KV'	360	0.04864	-0.08074	47
SPS	TOLK 230KV'	584.7234	-0.01282	SPS	MUSTANG 115KV'	300	0.05555	-0.06837	55
SPS	TOLK 230KV'	584.7234	-0.01282	SPS	MUSTG5 118.0 230KV'	360	0.04864	-0.06146	62
SPS	RIVERVIEW 69KV'	23	-0.00345	SPS	MUSTANG 115KV'	300	0.05555	-0.059	64
SPS	TOLK 345KV'	540	-0.0321	SPS	JONES 230KV'	486	0.01408	-0.04618	82
SPS	TOLK 345KV'	540	-0.0321	SPS	LP-BRND2 69KV'	174.3398	0.01314	-0.04524	84
SPS	LP-BRND2 69KV'	57.66016	0.01314	SPS	MUSTANG 115KV'	300	0.05555	-0.04241	89
SPS	JONES 230KV'	243	0.01408	SPS	MUSTANG 115KV'	300	0.05555	-0.04147	91
SPS	LP-BRND2 69KV'	57.66016	0.01314	SPS	MUSTG5 118.0 230KV'	360	0.04864	-0.0355	106
SPS	JONES 230KV'	243	0.01408	SPS	MUSTG5 118.0 230KV'	360	0.04864	-0.03456	109

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Seven Rivers to Pecos to Potash Junction 230kV  
 Limiting Facility: CARLSBAD PLANT - POTASH JUNCTION INTERCHANGE 115KV CKT 1  
 Direction: To->From  
 Line Outage: CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1  
 Flowgate: 52310522521522095218511208SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount	Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1090487	0.2	0.2	SPS	CARLSBAD 69KV'	18	-0.26527	SPS	BLACKHAWK 115KV'	220	-0.00338	-0.26189	1
1090695	0.1	0.2	SPS	CARLSBAD 69KV'	18	-0.26527	SPS	CAPROCK 115KV'	18.90909	-0.02589	-0.23938	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	CUNNINGHAM 115KV'	71	0.10063	-0.3659	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	CUNNINGHAM 115KV'	110	0.10063	-0.3659	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	CUNNINGHAM 230KV'	306	0.10397	-0.36924	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	CZ 69KV'	39	-0.0031	-0.26217	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	HARRINGTON 230KV'	1066	-0.00347	-0.2618	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	HUBRCOZ 69KV'	11	-0.00338	-0.26189	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	JONES 230KV'	486	0.01371	-0.27898	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	LP-BRND2 69KV'	214.4087	0.01279	-0.27806	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	MADDOX 115KV'	183	0.0978	-0.36307	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	MOORE COUNTY 115KV'	48	-0.00354	-0.26173	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	MUSTANG 115KV'	300	0.05538	-0.32065	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	MUSTG5 118.0 230KV'	360	0.04848	-0.31375	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	NICHOLS 115KV'	213	-0.00338	-0.26189	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	NICHOLS 230KV'	244	-0.00343	-0.26184	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	PLANTX 115KV'	253	-0.00558	-0.25969	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	PLANTX 230KV'	189	-0.00895	-0.25632	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	SAN JUAN 230KV'	28.36363	-0.0641	-0.20117	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	SIDRCH 69KV'	20	-0.00338	-0.26189	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	STEER WATER 115KV'	18.90909	-0.00324	-0.26203	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	TOLK 230KV'	1037.926	-0.01283	-0.25244	1
			SPS	CARLSBAD 69KV'	18	-0.26527	SPS	WILWIND 230KV'	37.81818	-0.00493	-0.26034	1
			SPS	TOLK 345KV'	540	-0.03212	SPS	CUNNINGHAM 115KV'	110	0.10063	-0.13275	1
			SPS	TOLK 345KV'	540	-0.03212	SPS	CUNNINGHAM 115KV'	71	0.10063	-0.13275	1
			SPS	TOLK 345KV'	540	-0.03212	SPS	CUNNINGHAM 230KV'	306	0.10397	-0.13609	1
			SPS	JONES 230KV'	243	0.01371	SPS	CUNNINGHAM 115KV'	110	0.10063	-0.08692	2
			SPS	JONES 230KV'	243	0.01371	SPS	CUNNINGHAM 115KV'	71	0.10063	-0.08692	2
			SPS	JONES 230KV'	243	0.01371	SPS	CUNNINGHAM 230KV'	306	0.10397	-0.09026	2
			SPS	JONES 230KV'	243	0.01371	SPS	MADDOX 115KV'	183	0.0978	-0.08409	2
			SPS	LP-BRND2 69KV'	17.59131	0.01279	SPS	CUNNINGHAM 115KV'	110	0.10063	-0.08784	2
			SPS	LP-BRND2 69KV'	17.59131	0.01279	SPS	CUNNINGHAM 115KV'	71	0.10063	-0.08784	2
			SPS	LP-BRND2 69KV'	17.59131	0.01279	SPS	CUNNINGHAM 230KV'	306	0.10397	-0.09118	2
			SPS	LP-BRND2 69KV'	17.59131	0.01279	SPS	MADDOX 115KV'	183	0.0978	-0.08501	2
			SPS	RIVERVIEW 69KV'	23	-0.00338	SPS	CUNNINGHAM 115KV'	71	0.10063	-0.10401	2
			SPS	RIVERVIEW 69KV'	23	-0.00338	SPS	CUNNINGHAM 115KV'	110	0.10063	-0.10401	2
			SPS	RIVERVIEW 69KV'	23	-0.00338	SPS	CUNNINGHAM 230KV'	306	0.10397	-0.10735	2
			SPS	RIVERVIEW 69KV'	23	-0.00338	SPS	MADDOX 115KV'	183	0.0978	-0.10118	2
			SPS	TOLK 230KV'	582.0739	-0.01283	SPS	CUNNINGHAM 115KV'	71	0.10063	-0.11346	2
			SPS	TOLK 230KV'	582.0739	-0.01283	SPS	CUNNINGHAM 115KV'	110	0.10063	-0.11346	2
			SPS	TOLK 230KV'	582.0739	-0.01283	SPS	CUNNINGHAM 230KV'	306	0.10397	-0.1168	2
			SPS	TOLK 230KV'	582.0739	-0.01283	SPS	MADDOX 115KV'	183	0.0978	-0.11063	2
			SPS	TOLK 345KV'	540	-0.03212	SPS	MADDOX 115KV'	183	0.0978	-0.12992	2
			SPS	TOLK 345KV'	540	-0.03212	SPS	MUSTANG 115KV'	300	0.05538	-0.0875	2
			SPS	TOLK 345KV'	540	-0.03212	SPS	MUSTG5 118.0 230KV'	360	0.04848	-0.0806	2
			SPS	TUCUMCARI 115KV'	15	-0.02589	SPS	CUNNINGHAM 115KV'	110	0.10063	-0.12652	2
			SPS	TUCUMCARI 115KV'	15	-0.02589	SPS	CUNNINGHAM 115KV'	71	0.10063	-0.12652	2
			SPS	TUCUMCARI 115KV'	15	-0.02589	SPS	CUNNINGHAM 230KV'	306	0.10397	-0.12986	2
			SPS	TUCUMCARI 115KV'	15	-0.02589	SPS	MADDOX 115KV'	183	0.0978	-0.12369	2
			SPS	TUCUMCARI 115KV'	15	-0.02589	SPS	MUSTANG 115KV'	300	0.05538	-0.08127	2
			SPS	RIVERVIEW 69KV'	23	-0.00338	SPS	MUSTANG 115KV'	300	0.05538	-0.05876	3
			SPS	TOLK 230KV'	582.0739	-0.01283	SPS	MUSTANG 115KV'	300	0.05538	-0.06821	3
			SPS	TOLK 230KV'	582.0739	-0.01283	SPS	MUSTG5 118.0 230KV'	360	0.04848	-0.06131	3
			SPS	TUCUMCARI 115KV'	15	-0.02589	SPS	MUSTG5 118.0 230KV'	360	0.04848	-0.07437	3
			SPS	RIVERVIEW 69KV'	23	-0.00338	SPS	MUSTG5 118.0 230KV'	360	0.04848	-0.05186	4
			SPS	TOLK 345KV'	540	-0.03212	SPS	JONES 230KV'	486	0.01371	-0.04583	4
			SPS	TOLK 345KV'	540	-0.03212	SPS	LP-BRND2 69KV'	214.4087	0.01279	-0.04491	4
			SPS	JONES 230KV'	243	0.01371	SPS	MUSTANG 115KV'	300	0.05538	-0.04167	5
			SPS	LP-BRND2 69KV'	17.59131	0.01279	SPS	MUSTANG 115KV'	300	0.05538	-0.04259	5
			SPS	TUCUMCARI 115KV'	15	-0.02589	SPS	JONES 230KV'	486	0.01371	-0.0396	5
			SPS	TUCUMCARI 115KV'	15	-0.02589	SPS	LP-BRND2 69KV'	214.4087	0.01279	-0.03868	5
			SPS	JONES 230KV'	243	0.01371	SPS	MUSTG5 118.0 230KV'	360	0.04848	-0.03477	6
			SPS	LP-BRND2 69KV'	17.59131	0.01279	SPS	MUSTG5 118.0 230KV'	360	0.04848	-0.03569	6

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1  
 Limiting Facility: SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1  
 Direction: From->To

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Line Outage: FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1  
 Flowgate: 5721572771572365727711107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation		Relief Amount	Aggregate Relief Amount									
		1090729	0.8	1.0								
		1090808	0.2	1.0								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)			
WERE	CHANUTE 69KV	31.077	0.00049	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09639	11			
WERE	CITY OF ERIE 69KV	4.255999	0.00049	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09639	11			
WERE	CITY OF FREDONIA 69KV	5.069	0.00129	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09559	11			
WERE	CITY OF GIRARD 69KV	5.911	-0.00001	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09689	11			
WERE	CITY OF IOLA 69KV	13.361	-0.00014	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09702	11			
WERE	CITY OF MULVANE 69KV	7.502	0.00554	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09134	11			
WERE	CITY OF NEODESHA 69KV	4.5	0.00124	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09564	11			
WERE	CITY OF WINFIELD 69KV	29.38998	0.00464	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09224	11			
WERE	EVANS ENERGY CENTER 138KV	8	0.00641	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09047	11			
WERE	GETTY 69KV	35	0.00518	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09177	11			
WERE	GILL ENERGY CENTER 69KV	8	0.0059	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09098	11			
WERE	LATHAM1234.0 345KV	150	0.00362	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09326	11			
WERE	NEOSHO ENERGY CENTER 138KV	47	0.00077	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.09611	11			
WERE	BROWN COUNTY 115KV	5.5	0.01138	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.0855	12			
WERE	SOUTH SENECA 115KV	8.2	0.01216	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.08472	12			
WERE	BPU - CITY OF MCPHERSON 115KV	15.93311	0.01859	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.07829	13			
WERE	HOLTON 115KV	7.6	0.01876	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.07812	13			
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.01777	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.07911	13			
WERE	HUTCHINSON ENERGY CENTER 69KV	12	0.01776	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.07912	13			
WERE	JEFFREY ENERGY CENTER 345KV	42	0.01951	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.07737	13			
WERE	SMOKYHIL 230 230KV	72	0.01826	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.07862	13			
WERE	ST JOHN 115KV	7.5	0.0139	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.08298	13			
WERE	ABILENE ENERGY CENTER 115KV	5.99996	0.02194	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.07494	14			
WERE	CLAY CENTER JUNCTION 115KV	9.225	0.0232	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.07368	14			
WERE	JEFFREY ENERGY CENTER 230KV	24	0.02199	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.07489	14			
WERE	CHANUTE 69KV	31.077	0.00049	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.0703	15			
WERE	CITY OF FREDONIA 69KV	5.069	0.00129	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.0695	15			
WERE	CITY OF GIRARD 69KV	5.911	-0.00001	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.0708	15			
WERE	CITY OF IOLA 69KV	13.361	-0.00014	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.07093	15			
WERE	CITY OF OSAGE CITY 115KV	8.85	0.02976	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.06712	15			
WERE	LATHAM1234.0 345KV	150	0.00362	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.06717	15			
WERE	NEOSHO ENERGY CENTER 138KV	47	0.00077	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.07002	15			
WERE	CITY OF MULVANE 69KV	7.502	0.00554	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.06525	16			
WERE	CITY OF WINFIELD 69KV	29.38998	0.00464	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.06615	16			
WERE	EVANS ENERGY CENTER 138KV	8	0.00641	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.06438	16			
WERE	GETTY 69KV	35	0.00518	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.06561	16			
WERE	GILL ENERGY CENTER 69KV	8	0.0059	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.06489	16			
WERE	SOUTH SENECA 115KV	8.2	0.01216	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.05863	18			
WERE	ST JOHN 115KV	7.5	0.0139	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.05689	18			
WERE	TECUMSEH ENERGY CENTER 69KV	41	0.04149	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.09688	-0.05539	19			
WERE	BPU - CITY OF MCPHERSON 115KV	15.93311	0.01859	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.0522	20			
WERE	HOLTON 115KV	7.6	0.01876	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.05203	20			
WERE	HUTCHINSON ENERGY CENTER 115KV	133	0.01777	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.05302	20			
WERE	HUTCHINSON ENERGY CENTER 69KV	12	0.01776	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.05303	20			
WERE	JEFFREY ENERGY CENTER 345KV	42	0.01951	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.05128	20			
WERE	SMOKYHIL 230 230KV	72	0.01826	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.05253	20			
WERE	JEFFREY ENERGY CENTER 230KV	24	0.02199	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.0488	21			
WERE	CLAY CENTER JUNCTION 115KV	9.225	0.0232	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.04759	22			
WERE	CHANUTE 69KV	31.077	0.00049	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.04331	-0.04282	24			
WERE	CITY OF IOLA 69KV	13.361	-0.00014	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.04331	-0.04345	24			
WERE	NEOSHO ENERGY CENTER 138KV	47	0.00077	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.04331	-0.04254	24			
WERE	CITY OF OSAGE CITY 115KV	8.85	0.02976	WERE	LAWRENCE ENERGY CENTER 230KV	233.864	0.07079	-0.04103	25			
WERE	LATHAM1234.0 345KV	150	0.00362	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.04331	-0.03969	26			
WERE	CITY OF WINFIELD 69KV	29.38998	0.00464	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.04331	-0.03867	27			
WERE	GETTY 69KV	35	0.00518	WERE	TECUMSEH ENERGY CENTER 115KV	158	0.04331	-0.03813	27			

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.  
 Factor = Source GSF - Sink GSF  
 Redispatch Amount = Relief Amount / Factor

Upgrade: STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1  
 Limiting Facility: STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1  
 Direction: To->From  
 Line Outage: HOYT - STRANGER CREEK 345KV CKT 1  
 Flowgate: 5727057182156765567211107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation		Relief Amount	Aggregate Relief Amount									
		1089950	1.7	3.6								
		1090609	0.4	3.6								
		1090699	0.6	3.6								
		1090705	0.6	3.6								
		1090729	0.3	3.6								
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.31907	11			
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.25173	14			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	HOLTON 115KV	8.2	0.07498	-0.22993	16			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.2229	16			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.22326	16			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	ABILENE ENERGY CENTER 115KV	40	0.06019	-0.21514	17			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	CLAY CENTER JUNCTION 115KV	8.584003	0.06312	-0.21807	17			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.04874	-0.20369	18			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	SOUTH SENECA 115KV	8.5	0.04144	-0.19639	19			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	EVANS ENERGY CENTER 138KV	323.8247	0.01446	-0.16941	21			
WERE	CITY OF GIRARD 69KV	8.909	0.00179	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.16233	22			
WERE	CITY OF IOLA 69KV	13.372	0.00202	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.1621	22			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	CITY OF AUGUSTA 69KV	20.02	0.01224	-0.16719	22			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	CITY OF WELLINGTON 69KV	20	0.01184	-0.16679	22			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	GILL ENERGY CENTER 138KV	155	0.01383	-0.16878	22			
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	WACCA 138KV	17.946	0.01389	-0.16894	22			
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	HOLTON 115KV	8.2	0.07498	-0.16259	22			
WERE	CHANUTE 69KV	31.504	0.00298	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.16116	23			
WERE	CITY OF BURLINGTON 69KV	7.7	0.00537	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.15875	23			

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	CITY OF ERIE 69KV	24.231	0.00298	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.16116	23
WERE	LATHAM1234.0 345KV	150	0.00863	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.15549	23
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	CHANUTE 69KV	56.296	0.00296	-0.15791	23
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	CITY OF IOLA 69KV	24.256	0.00202	-0.15697	23
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00537	-0.16032	23
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.15556	23
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.15592	23
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00294	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.16118	23
WERE	CITY OF MULVANE 69KV	10.899	0.01275	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.15137	24
WERE	CITY OF WELLINGTON 69KV	23.5	0.01184	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.15228	24
WERE	CITY OF WINFIELD 69KV	40	0.0109	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.15322	24
WERE	EVANS ENERGY CENTER 138KV	419.1753	0.01446	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.14966	24
WERE	GETTY 69KV	35	0.01244	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.15168	24
WERE	GILL ENERGY CENTER 138KV	17.99999	0.01383	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.15029	24
WERE	GILL ENERGY CENTER 69KV	118	0.01356	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.15056	24
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	CLAY CENTER JUNCTION 115KV	8.584003	0.06312	-0.15073	24
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	ABILENE ENERGY CENTER 115KV	40	0.06019	-0.1478	25
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.04874	-0.13635	27
WERE	BPU - CITY OF MCPHERSON 115KV	259	0.05151	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.11261	32
WERE	HUTCHINSON ENERGY CENTER 115KV	263	0.04874	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.11538	32
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.04873	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.11539	32
WERE	SMOKYHIL 230 230KV	72	0.05104	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.11308	32
WERE	CLAY CENTER JUNCTION 115KV	29.516	0.06312	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.101	36
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	CITY OF AUGUSTA 69KV	20.02	0.01224	-0.09985	36
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	EVANS ENERGY CENTER 138KV	323.8247	0.01446	-0.10207	36
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	GILL ENERGY CENTER 138KV	155	0.01383	-0.10144	36
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	WACO 138KV	17.946	0.01389	-0.1015	36
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	CITY OF WELLINGTON 69KV	20	0.01184	-0.09945	37
WERE	JEFFREY ENERGY CENTER 230KV	24	0.06795	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.09617	38
WERE	JEFFREY ENERGY CENTER 345KV	42	0.06831	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.16412	-0.09581	38
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00537	-0.09298	39
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	CHANUTE 69KV	56.296	0.00296	-0.09057	40
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.08761	WERE	CITY OF IOLA 69KV	24.256	0.00202	-0.08963	41
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.15495	WERE	LAWRENCE ENERGY CENTER 230KV	228.5818	-0.08761	-0.06734	54
WERE	CHANUTE 69KV	31.504	0.00296	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.06499	56
WERE	CHANUTE 69KV	31.504	0.00296	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.06535	56
WERE	CITY OF ERIE 69KV	24.231	0.00296	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.06499	56
WERE	CITY OF ERIE 69KV	24.231	0.00296	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.06535	56
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00294	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.06501	56
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00294	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.06537	56
WERE	LATHAM1234.0 345KV	150	0.00863	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.05932	61
WERE	LATHAM1234.0 345KV	150	0.00863	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.05968	61
WERE	CITY OF WINFIELD 69KV	40	0.0109	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.05741	63
WERE	CHANUTE 69KV	31.504	0.00296	WERE	ABILENE ENERGY CENTER 115KV	40	0.06019	-0.05723	64
WERE	CITY OF ERIE 69KV	24.231	0.00296	WERE	ABILENE ENERGY CENTER 115KV	40	0.06019	-0.05723	64
WERE	CITY OF WELLINGTON 69KV	23.5	0.01184	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.05647	64
WERE	CITY OF WINFIELD 69KV	40	0.0109	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.05705	64
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00294	WERE	ABILENE ENERGY CENTER 115KV	40	0.06019	-0.05725	64
WERE	CITY OF WELLINGTON 69KV	23.5	0.01184	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.05611	65
WERE	GETTY 69KV	35	0.01244	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.05587	65
WERE	GETTY 69KV	35	0.01244	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.05551	66
WERE	GILL ENERGY CENTER 69KV	118	0.01356	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.05475	66
WERE	GILL ENERGY CENTER 69KV	118	0.01356	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.05439	67
WERE	EVANS ENERGY CENTER 138KV	419.1753	0.01446	WERE	JEFFREY ENERGY CENTER 230KV	470	0.06795	-0.05349	68
WERE	EVANS ENERGY CENTER 138KV	419.1753	0.01446	WERE	JEFFREY ENERGY CENTER 345KV	940	0.06831	-0.05385	68
WERE	LATHAM1234.0 345KV	150	0.00863	WERE	ABILENE ENERGY CENTER 115KV	40	0.06019	-0.05156	71
WERE	CITY OF WINFIELD 69KV	40	0.0109	WERE	ABILENE ENERGY CENTER 115KV	40	0.06019	-0.04929	74
WERE	GETTY 69KV	35	0.01244	WERE	ABILENE ENERGY CENTER 115KV	40	0.06019	-0.04775	76
WERE	GILL ENERGY CENTER 69KV	118	0.01356	WERE	ABILENE ENERGY CENTER 115KV	40	0.06019	-0.04663	78
WERE	CHANUTE 69KV	31.504	0.00296	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.04874	-0.04578	79
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00294	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.04874	-0.0458	79
WERE	EVANS ENERGY CENTER 138KV	419.1753	0.01446	WERE	ABILENE ENERGY CENTER 115KV	40	0.06019	-0.04573	80
WERE	LATHAM1234.0 345KV	150	0.00863	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.04874	-0.04011	91
WERE	CITY OF WINFIELD 69KV	40	0.0109	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.04874	-0.03784	96
WERE	GETTY 69KV	35	0.01244	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.04874	-0.0363	100
WERE	GILL ENERGY CENTER 69KV	118	0.01356	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.04874	-0.03518	103
WERE	EVANS ENERGY CENTER 138KV	419.1753	0.01446	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.04874	-0.03428	106

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1  
 Limiting Facility: STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1  
 Direction: To->From  
 Line Outage: GEN:56663 1  
 Flowgate: 57270571821GEN5666311107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount											
1089950		0.9	0.9										
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13706	-0.30215	3				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	CLAY CENTER JUNCTION 115KV	8.584003	0.03309	-0.19818	4				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	HOLTON 115KV	8.2	0.04206	-0.20715	4				
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.10091	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13706	-0.23797	4				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	ABILENE ENERGY CENTER 115KV	40	0.03019	-0.19528	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	CHANUTE 69KV	56.296	0.00084	-0.16593	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	CITY OF AUGUSTA 69KV	20.02	0.00556	-0.17065	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	CITY OF BURLINGTON 69KV	4.8	0.00209	-0.16718	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	CITY OF ERIE 69KV	2.299	0.00084	-0.16593	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	CITY OF FREDONIA 69KV	5.225	0.00152	-0.16661	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	CITY OF GIRARD 69KV	1.791	0.00028	-0.16537	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	CITY OF IOLA 69KV	24.256	0.0003	-0.16539	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	CITY OF MULVANE 69KV	4.891	0.00573	-0.17082	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	CITY OF WELLINGTON 69KV	20	0.0053	-0.17039	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00209	-0.16718	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	EVANS ENERGY CENTER 138KV	323.8247	0.00653	-0.17162	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	GILL ENERGY CENTER 138KV	155	0.00624	-0.17133	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.02245	-0.18754	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	JEFFREY ENERGY CENTER 230KV	470	0.02951	-0.1946	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	JEFFREY ENERGY CENTER 345KV	940	0.02635	-0.19144	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	SOUTH SENECA 115KV	8.5	0.02291	-0.188	5				
WERE	LAWRENCE ENERGY CENTER 115KV	178	-0.16509	WERE	WACO 138KV	17.946	0.00627	-0.17136	5				

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	CITY OF GIRARD 69KV'	8.909	0.00028	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13678	6
WERE	CITY OF IOLA 69KV'	13.372	0.0003	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13676	6
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	HOLTON 115KV'	8.2	0.04206	-0.14297	6
WERE	CHANUTE 69KV'	31.504	0.00084	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13622	7
WERE	CITY OF AUGUSTA 69KV'	7.320001	0.00556	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.1315	7
WERE	CITY OF BURLINGTON 69KV'	7.7	0.00209	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13497	7
WERE	CITY OF ERIE 69KV'	24.231	0.00084	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13622	7
WERE	CITY OF FREDONIA 69KV'	5.069	0.00152	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13554	7
WERE	CITY OF MULVANE 69KV'	10.899	0.00573	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13133	7
WERE	CITY OF NEODESHA 69KV'	4.5	0.00146	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.1356	7
WERE	CITY OF WELLINGTON 69KV'	23.5	0.0053	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13176	7
WERE	CITY OF WINFIELD 69KV'	40	0.00487	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13219	7
WERE	EVANS ENERGY CENTER 138KV'	419.1753	0.00653	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13053	7
WERE	GETTY 69KV'	35	0.00572	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13134	7
WERE	GILL ENERGY CENTER 138KV'	17.99999	0.00624	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13082	7
WERE	GILL ENERGY CENTER 69KV'	118	0.00611	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13095	7
WERE	LATHAM1234.0 345KV'	150	0.0037	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13336	7
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.03019	-0.1311	7
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'CLAY CENTER JUNCTION 115KV'	8.584003	0.03309	-0.134	7
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'HUTCHINSON ENERGY CENTER 115KV'	120	0.02245	-0.12336	7
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.02951	-0.13042	7
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.02635	-0.12726	7
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'SOUTH SENECA 115KV'	8.5	0.02291	-0.12382	7
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00092	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13614	7
WERE	OXFORD 138KV'	3	0.005	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.13206	7
WERE	ST JOHN 115KV'	7.5	0.01739	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.11967	7
WERE	'ABILENE ENERGY CENTER 115KV'	5.999996	0.03019	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.10687	8
WERE	BPU - CITY OF MCPHERSON 115KV'	259	0.02349	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.11357	8
WERE	BROWN COUNTY 115KV'	5.5	0.02245	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.11461	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	263	0.02245	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.11461	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	0.02244	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.11462	8
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.02951	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.10755	8
WERE	JEFFREY ENERGY CENTER 345KV'	42	0.02635	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.11071	8
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00556	-0.10647	8
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'CITY OF MULVANE 69KV'	4.891	0.00573	-0.10664	8
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'CITY OF WELLINGTON 69KV'	20	0.0053	-0.10621	8
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'EVANS ENERGY CENTER 138KV'	323.8247	0.00653	-0.10744	8
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'GILL ENERGY CENTER 138KV'	155	0.00624	-0.10715	8
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'WACO 138KV'	17.946	0.00627	-0.10718	8
WERE	SMOKYHILL 230 230KV'	72	0.02286	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.1142	8
WERE	SOUTH SENECA 115KV'	8.2	0.02291	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.11415	8
WERE	CLAY CENTER JUNCTION 115KV'	29.516	0.03309	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.10397	9
WERE	HOLTON 115KV'	11.6	0.04206	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.095	9
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	CHANUTE 69KV'	56.296	0.00084	-0.10175	9
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'CITY OF BURLINGTON 69KV'	4.8	0.00209	-0.103	9
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00152	-0.10243	9
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'CITY OF IOLA 69KV'	24.256	0.0003	-0.10121	9
WERE	LAWRENCE ENERGY CENTER 230KV'	40.41815	-0.10091	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00209	-0.103	9
WERE	CITY OF OSAGE CITY 115KV'	8.85	0.071	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13706	-0.06606	13
WERE	LAWRENCE ENERGY CENTER 115KV'	178	-0.16509	WERE	'LAWRENCE ENERGY CENTER 230KV'	228.5818	-0.10091	-0.06418	14
WERE	CITY OF GIRARD 69KV'	8.909	0.00028	WERE	HOLTON 115KV'	8.2	0.04206	-0.04178	21
WERE	CITY OF IOLA 69KV'	13.372	0.0003	WERE	HOLTON 115KV'	8.2	0.04206	-0.04176	21
WERE	CHANUTE 69KV'	31.504	0.00084	WERE	HOLTON 115KV'	8.2	0.04206	-0.04122	22
WERE	CITY OF BURLINGTON 69KV'	7.7	0.00209	WERE	HOLTON 115KV'	8.2	0.04206	-0.03997	22
WERE	CITY OF ERIE 69KV'	24.231	0.00084	WERE	HOLTON 115KV'	8.2	0.04206	-0.04122	22
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00092	WERE	HOLTON 115KV'	8.2	0.04206	-0.04114	22
WERE	LATHAM1234.0 345KV'	150	0.0037	WERE	HOLTON 115KV'	8.2	0.04206	-0.03836	23
WERE	CITY OF MULVANE 69KV'	10.899	0.00573	WERE	HOLTON 115KV'	8.2	0.04206	-0.03633	24
WERE	CITY OF WELLINGTON 69KV'	23.5	0.0053	WERE	HOLTON 115KV'	8.2	0.04206	-0.03676	24
WERE	CITY OF WINFIELD 69KV'	40	0.00487	WERE	HOLTON 115KV'	8.2	0.04206	-0.03719	24
WERE	GETTY 69KV'	35	0.00572	WERE	HOLTON 115KV'	8.2	0.04206	-0.03634	24

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1  
 Limiting Facility: STULL SWITCHING STATION - TECUMSEH HILL 115KV CKT 1  
 Direction: To->From  
 Line Outage: LAWRENCE HILL (LAWHL29X) 230-115-13.8KV TRANSFORMER CKT 1  
 Flowgate: 57270571821LAWHWHL29X6311107FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1089950	1.0	1.0								
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13701	-0.342	3
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'ABILENE ENERGY CENTER 115KV'	40	0.03385	-0.23884	4
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'CLAY CENTER JUNCTION 115KV'	8.584003	0.03693	-0.24192	4
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	HOLTON 115KV'	8.2	0.04259	-0.24758	4
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'HUTCHINSON ENERGY CENTER 115KV'	120	0.0255	-0.23049	4
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.03282	-0.23781	4
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.02885	-0.23384	4
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'SOUTH SENECA 115KV'	8.5	0.02357	-0.22856	4
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	CHANUTE 69KV'	56.296	0.0013	-0.20629	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.0069	-0.21189	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'CITY OF BURLINGTON 69KV'	4.8	0.00294	-0.20793	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'CITY OF ERIE 69KV'	2.299	0.0013	-0.20629	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00209	-0.20708	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'CITY OF GIRARD 69KV'	1.791	0.00062	-0.20561	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'CITY OF IOLA 69KV'	24.256	0.00066	-0.20565	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'CITY OF MULVANE 69KV'	4.891	0.00719	-0.21218	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'CITY OF WELLINGTON 69KV'	20	0.00664	-0.21163	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00294	-0.20793	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'EVANS ENERGY CENTER 138KV'	323.8247	0.0082	-0.21319	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'GILL ENERGY CENTER 138KV'	155	0.00778	-0.21277	5
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'WACO 138KV'	17.946	0.00783	-0.21282	5
WERE	LAWRENCE ENERGY CENTER 230KV'		40.41815	-0.06261	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13701	-0.19962	5
WERE	CITY OF GIRARD 69KV'		8.909	0.00062	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13701	-0.13639	7
WERE	CITY OF IOLA 69KV'		13.372	0.00066	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13701	-0.13635	7
WERE	LAWRENCE ENERGY CENTER 115KV'		178	-0.20499	WERE	'LAWRENCE ENERGY CENTER 230KV'	228.5818	-0.06261	-0.14238	7
WERE	CHANUTE 69KV'		31.504	0.0013	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13701	-0.13571	8
WERE	CITY OF AUGUSTA 69KV'		7.320001	0.0069	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13701	-0.13011	8
WERE	CITY OF BURLINGTON 69KV'		7.7	0.00294	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.13701	-0.13407	8

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	CITY OF ERIE 69KV	24.231	0.0013	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.13571	8
WERE	CITY OF FREDONIA 69KV	5.069	0.00209	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.13492	8
WERE	CITY OF MULVANE 69KV	10.899	0.00719	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.12982	8
WERE	WERE OF NEODESHA 69KV	4.5	0.00202	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.13499	8
WERE	CITY OF WELLINGTON 69KV	23.5	0.00664	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.13037	8
WERE	CITY OF WINFIELD 69KV	40	0.00611	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.1309	8
WERE	EVANS ENERGY CENTER 138KV	419.1753	0.0082	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.12881	8
WERE	GETTY 69KV	35	0.00702	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.12999	8
WERE	GILL ENERGY CENTER 138KV	17.99999	0.00778	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.12923	8
WERE	GILL ENERGY CENTER 69KV	118	0.00764	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.12937	8
WERE	LATHAM1234.0 345KV	150	0.00479	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.13222	8
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00139	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.13562	8
WERE	OXFORD 138KV	3	0.00628	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.13073	8
WERE	BPU - CITY OF MCPHERSON 115KV	259	0.02667	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.11034	9
WERE	BROWN COUNTY 115KV	5.5	0.02287	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.11414	9
WERE	HUTCHINSON ENERGY CENTER 115KV	263	0.0255	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.11151	9
WERE	HUTCHINSON ENERGY CENTER 69KV	67	0.02549	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.11152	9
WERE	JEFFREY ENERGY CENTER 345KV	42	0.02885	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.10816	9
WERE	SMOKYHILL 230 230KV	72	0.02595	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.11106	9
WERE	SOUTH SENECA 115KV	8.2	0.02357	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.11344	9
WERE	ST JOHN 115KV	7.5	0.01976	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.11725	9
WERE	ABILENE ENERGY CENTER 115KV	5.999996	0.03385	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.10316	10
WERE	CLAY CENTER JUNCTION 115KV	29.516	0.03693	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.10008	10
WERE	JEFFREY ENERGY CENTER 230KV	24	0.03282	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.10419	10
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	CLAY CENTER JUNCTION 115KV	8.584003	0.03693	-0.09954	10
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	HOLTON 115KV	8.2	0.04259	-0.1052	10
WERE	HOLTON 115KV	11.6	0.04259	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.09442	11
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	ABILENE ENERGY CENTER 115KV	40	0.03385	-0.09646	11
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	JEFFREY ENERGY CENTER 230KV	470	0.03282	-0.09543	11
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	JEFFREY ENERGY CENTER 345KV	940	0.02885	-0.09146	11
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	HUTCHINSON ENERGY CENTER 115KV	120	0.0255	-0.08811	12
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	'SOUTH SENECA 115KV	8.5	0.02357	-0.08618	12
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	EVANS ENERGY CENTER 138KV	323.8247	0.0082	-0.07081	14
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	CITY OF AUGUSTA 69KV	20.02	0.0069	-0.06951	15
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	CITY OF WELLINGTON 69KV	20	0.00664	-0.06925	15
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	GILL ENERGY CENTER 138KV	155	0.00778	-0.07039	15
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	'WACO 138KV	17.946	0.00783	-0.07044	15
WERE	CITY OF OSAGE CITY 115KV	8.85	0.07352	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.13701	-0.06349	16
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	CHANUTE 69KV	56.296	0.0013	-0.06391	16
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	CITY OF IOLA 69KV	24.256	0.00066	-0.06327	16
WERE	LAWRENCE ENERGY CENTER 230KV	40.41815	-0.06261	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	0.00294	-0.06555	16
WERE	CITY OF GIRARD 69KV	8.909	0.00062	WERE	HOLTON 115KV	8.2	0.04259	-0.04197	24
WERE	CITY OF IOLA 69KV	13.372	0.00068	WERE	HOLTON 115KV	8.2	0.04259	-0.04193	24
WERE	CHANUTE 69KV	31.504	0.0013	WERE	ABILENE ENERGY CENTER 115KV	40	0.03385	-0.03255	31
WERE	CITY OF ERIE 69KV	24.231	0.0013	WERE	ABILENE ENERGY CENTER 115KV	40	0.03385	-0.03255	31
WERE	CITY OF IOLA 69KV	13.372	0.00068	WERE	ABILENE ENERGY CENTER 115KV	40	0.03385	-0.03319	31
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00139	WERE	ABILENE ENERGY CENTER 115KV	40	0.03385	-0.03246	31
WERE	CHANUTE 69KV	31.504	0.0013	WERE	JEFFREY ENERGY CENTER 230KV	470	0.03282	-0.03152	32
WERE	CITY OF ERIE 69KV	24.231	0.0013	WERE	JEFFREY ENERGY CENTER 230KV	470	0.03282	-0.03152	32
WERE	CITY OF IOLA 69KV	13.372	0.00068	WERE	JEFFREY ENERGY CENTER 230KV	470	0.03282	-0.03216	32
WERE	NEOSHO ENERGY CENTER 138KV	67	0.00139	WERE	JEFFREY ENERGY CENTER 230KV	470	0.03282	-0.03143	33

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: SW SHREVEPORT EXPANSION  
 Limiting Facility: SOUTHWEST SHREVEPORT (SW SHV 1) 345-138-13.8KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: SOUTHWEST SHREVEPORT (SW SHV 2) 345-138-13.8KV TRANSFORMER CKT 2  
 Flowgate: SWSHV12741SWSHV27424108SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1085305	3.6	8.7
1086238	0.3	8.7
1087745	2.8	8.7
1087757	2.1	8.7

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	COGENTRIX 345KV	665	-0.00269	-0.38903	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	FITZHUGH 161KV	75.99999	-0.00081	-0.39091	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	FLINT CREEK 161KV	428	-0.00211	-0.38961	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	L&D13 69KV	11	-0.0012	-0.39052	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	NORTHEASTERN STATION 138KV	95	-0.00245	-0.38927	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	NORTHEASTERN STATION 138KV	405	-0.00245	-0.38927	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	NORTHEASTERN STATION 345KV	645	-0.00244	-0.38928	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	OEC 345KV	156	-0.00258	-0.38914	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	RIVERSIDE STATION 138KV	569	-0.0027	-0.38902	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	TULSA POWER STATION 138KV	75	-0.00267	-0.38905	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	TULSA POWER STATION 138KV	88	-0.00267	-0.38905	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	'WEATHERFORD 34KV	148	-0.00366	-0.38806	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	'WELTEKA 138KV	84	-0.00349	-0.38823	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	'WILKES 345KV	311	-0.00148	-0.39024	22
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	COMANCHE 138KV	160	-0.00394	-0.38778	23
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	COMANCHE 69KV	63	-0.00396	-0.38776	23
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	NARROWS 69KV	22	-0.01198	-0.37974	23
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	'SOUTHWESTERN STATION 138KV	257	-0.0039	-0.38782	23
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	'SOUTHWESTERN STATION 138KV	168	-0.0039	-0.38782	23
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	'WELSH 345KV	1044	-0.00874	-0.38298	23
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	'WILKES 138KV	306.4586	-0.03061	-0.36111	24
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	LEBROCK 345KV	315	-0.04683	-0.34489	25
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	PIRKEY GENERATION 138KV	490	-0.07081	-0.32091	27
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	EASTMAN 138KV	155	-0.08902	-0.3027	29
AEPW	ARSENAL HILL 69KV	99	-0.39172	AEPW	KNOXLEE 138KV	183.8252	-0.10916	-0.28256	31
AEPW	LIEBERMAN 138KV	154	-0.22447	AEPW	COGENTRIX 345KV	665	-0.00269	-0.22178	39
AEPW	LIEBERMAN 138KV	154	-0.22447	AEPW	FITZHUGH 161KV	75.99999	-0.00081	-0.22366	39
AEPW	LIEBERMAN 138KV	154	-0.22447	AEPW	FLINT CREEK 161KV	428	-0.00211	-0.22236	39
AEPW	LIEBERMAN 138KV	154	-0.22447	AEPW	NORTHEASTERN STATION 138KV	405	-0.00245	-0.22202	39
AEPW	LIEBERMAN 138KV	154	-0.22447	AEPW	NORTHEASTERN STATION 138KV	95	-0.00245	-0.22202	39
AEPW	LIEBERMAN 138KV	154	-0.22447	AEPW	NORTHEASTERN STATION 345KV	645	-0.00244	-0.22203	39
AEPW	LIEBERMAN 138KV	154	-0.22447	AEPW	OEC 345KV	156	-0.00258	-0.22189	39
AEPW	LIEBERMAN 138KV	154	-0.22447	AEPW	RIVERSIDE STATION 138KV	569	-0.0027	-0.22177	39
AEPW	LIEBERMAN 138KV	154	-0.22447	AEPW	TULSA POWER STATION 138KV	75	-0.00267	-0.2218	39
AEPW	LIEBERMAN 138KV	154	-0.22447	AEPW	TULSA POWER STATION 138KV	88	-0.00267	-0.2218	39

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	WILKES 345KV'	311	-0.00148	-0.22299	39
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	COMANCHE 138KV'	160	-0.00394	-0.22053	40
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	COMANCHE 69KV'	63	-0.00396	-0.22051	40
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'SOUTHWESTERN STATION 138KV'	257	-0.0039	-0.22057	40
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'SOUTHWESTERN STATION 138KV'	168	-0.0039	-0.22057	40
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'WEATHERFORD 34KV'	148	-0.00366	-0.22081	40
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'WELEETKA 138KV'	84	-0.00349	-0.22098	40
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'WELSH 345KV'	1044	-0.00874	-0.21573	40
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'NARROWS 69KV'	22	-0.01198	-0.21249	41
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'WILKES 138KV'	306.4586	-0.03061	-0.19386	45
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'LEBROCK 345KV'	315	-0.04683	-0.17764	49
AEPW	'ARSENAL HILL 69KV'	99	-0.39172	AEPW	'LIEBERMAN 138KV'	73.99999	-0.22447	-0.16725	52
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'PIRKEY GENERATION 138KV'	490	-0.07081	-0.15366	57
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'EASTMAN 138KV'	155	-0.08902	-0.13545	64
AEPW	LIEBERMAN 138KV'	154	-0.22447	AEPW	'KNOXLEE 138KV'	183.8252	-0.10916	-0.11531	76
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'FITZHUGH 161KV'	75.99999	-0.00081	-0.10835	81
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'FITZHUGH 161KV'	75.99999	-0.00081	-0.10835	81
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'WILKES 345KV'	311	-0.00148	-0.10768	81
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'WILKES 345KV'	311	-0.00148	-0.10768	81
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'COGENTRIX 345KV'	665	-0.00269	-0.10647	82
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'COGENTRIX 345KV'	665	-0.00269	-0.10647	82
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'FLINT CREEK 161KV'	428	-0.00211	-0.10705	82
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'FLINT CREEK 161KV'	428	-0.00211	-0.10705	82
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'NORTHEASTERN STATION 138KV'	405	-0.00245	-0.10671	82
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'NORTHEASTERN STATION 138KV'	95	-0.00245	-0.10671	82
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'NORTHEASTERN STATION 138KV'	95	-0.00245	-0.10671	82
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'NORTHEASTERN STATION 138KV'	405	-0.00245	-0.10671	82
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'NORTHEASTERN STATION 345KV'	645	-0.00244	-0.10672	82
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'NORTHEASTERN STATION 345KV'	645	-0.00244	-0.10672	82
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'OEC 345KV'	156	-0.00258	-0.10658	82
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'OEC 345KV'	156	-0.00258	-0.10658	82
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'RIVERSIDE STATION 138KV'	569	-0.0027	-0.10646	82
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'RIVERSIDE STATION 138KV'	569	-0.0027	-0.10646	82
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'TULSA POWER STATION 138KV'	88	-0.00267	-0.10649	82
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'TULSA POWER STATION 138KV'	75	-0.00267	-0.10649	82
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'TULSA POWER STATION 138KV'	75	-0.00267	-0.10649	82
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'TULSA POWER STATION 138KV'	88	-0.00267	-0.10649	82
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'COMANCHE 138KV'	160	-0.00394	-0.10522	83
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'COMANCHE 138KV'	160	-0.00394	-0.10522	83
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'COMANCHE 69KV'	63	-0.00396	-0.1052	83
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'COMANCHE 69KV'	63	-0.00396	-0.1052	83
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'SOUTHWESTERN STATION 138KV'	257	-0.0039	-0.10526	83
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'SOUTHWESTERN STATION 138KV'	168	-0.0039	-0.10526	83
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'SOUTHWESTERN STATION 138KV'	168	-0.0039	-0.10526	83
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'SOUTHWESTERN STATION 138KV'	257	-0.0039	-0.10526	83
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'WEATHERFORD 34KV'	148	-0.00366	-0.1055	83
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'WEATHERFORD 34KV'	148	-0.00366	-0.1055	83
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'WELEETKA 138KV'	84	-0.00349	-0.10567	83
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'WELEETKA 138KV'	84	-0.00349	-0.10567	83
AEPW	KNOXLEE 138KV'	179.1748	-0.10916	AEPW	'WELSH 345KV'	1044	-0.00874	-0.10042	87
AEPW	KNOXLEE 138KV'	60	-0.10916	AEPW	'WELSH 345KV'	1044	-0.00874	-0.10042	87
CELE	'ACADIA 138KV'	1072	-0.00235	CELE	'DOLET HILLS 345KV'	360	0.08607	-0.08842	99
AEPW	EASTMAN 138KV'	330.01	-0.08902	AEPW	'FITZHUGH 161KV'	75.99999	-0.00081	-0.08821	99
CELE	EVANGELINE 138KV'	157	-0.0018	CELE	'DOLET HILLS 345KV'	360	0.08607	-0.08787	99
CELE	TECHE 138KV'	82.1189	-0.00188	CELE	'DOLET HILLS 345KV'	360	0.08607	-0.08795	99
AEPW	EASTMAN 138KV'	330.01	-0.08902	AEPW	'FLINT CREEK 161KV'	428	-0.00211	-0.08691	100
AEPW	EASTMAN 138KV'	330.01	-0.08902	AEPW	'WILKES 345KV'	311	-0.00148	-0.08754	100
CELE	EVANGELINE 230KV'	231	-0.00163	CELE	'DOLET HILLS 345KV'	360	0.08607	-0.0877	100
CELE	RODEMACHER 230KV'	66	-0.00108	CELE	'DOLET HILLS 345KV'	360	0.08607	-0.08715	100
AEPW	EASTMAN 138KV'	330.01	-0.08902	AEPW	'COGENTRIX 345KV'	665	-0.00269	-0.08633	101
AEPW	EASTMAN 138KV'	330.01	-0.08902	AEPW	'NORTHEASTERN STATION 138KV'	405	-0.00245	-0.08657	101
AEPW	EASTMAN 138KV'	330.01	-0.08902	AEPW	'NORTHEASTERN STATION 138KV'	95	-0.00245	-0.08657	101
AEPW	EASTMAN 138KV'	330.01	-0.08902	AEPW	'NORTHEASTERN STATION 345KV'	645	-0.00244	-0.08658	101
AEPW	EASTMAN 138KV'	330.01	-0.08902	AEPW	'OEC 345KV'	156	-0.00258	-0.08644	101
AEPW	EASTMAN 138KV'	330.01	-0.08902	AEPW	'RIVERSIDE STATION 138KV'	569	-0.0027	-0.08632	101

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Tex-Hitchland-Sherman Tap 115 kV ckt & Hitchland 345 and 115 kV Interchange  
 Limiting Facility: PRINGLE INTERCHANGE - SPEARMAN INTERCHANGE 115KV CKT 2  
 Direction: From->To  
 Line Outage: PRINGLE INTERCHANGE - SPEARMAN INTERCHANGE 115KV CKT 1  
 Flowgate: 50652506282506525062814208SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090310	2.0	7.8
1090315	1.8	7.8
1090454	0.1	7.8
1090456	1.4	7.8
1090487	2.5	7.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WEPL	CIMARRON RIVER 115KV'	72	-0.12536	WEPL	'CLIFTON 115KV'	64.61148	-0.00612	-0.11924	65
WEPL	CIMARRON RIVER 115KV'	72	-0.12536	WEPL	'RUSSELL 115KV'	25.23501	-0.01342	-0.11194	70
WEPL	CIMARRON RIVER 115KV'	72	-0.12536	WEPL	'A. M. MULLERGREEN GENERATOR 115KV'	63	-0.01535	-0.11001	71
WEPL	CIMARRON RIVER 115KV'	72	-0.12536	WEPL	'GRAY COUNTY WIND FARM 115KV'	60	-0.04681	-0.07855	99
WEPL	CIMARRON RIVER 115KV'	72	-0.12536	WEPL	'JUDSON LARGE 115KV'	106.2386	-0.04716	-0.0782	99
SPS	JONES 230KV'	243	0.02869	SPS	'BLACKHAWK 115KV'	220	0.08188	-0.05319	146
SPS	MUSTGS 118.0 230KV'	150	0.02983	SPS	'BLACKHAWK 115KV'	220	0.08188	-0.05205	149
SPS	TOLK 230KV'	573.877	0.03038	SPS	'BLACKHAWK 115KV'	220	0.08188	-0.0515	151
SPS	TOLK 345KV'	540	0.03034	SPS	'BLACKHAWK 115KV'	220	0.08188	-0.05154	151

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Tex-Hitchland-Sherman Tap 115 kV ckt & Hitchland 345 and 115 kV Interchange  
 Limiting Facility: MOORE COUNTY INTERCHANGE 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: FAIN - NICHOLS STATION 115KV CKT 1  
 Flowgate: 50669506681506785091411108SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Reservation		Relief Amount	Aggregate Relief Amount
1090310		0.2	1.7
1090315		0.4	1.7
1090454		0.5	1.7
1090456		0.2	1.7
1090487		0.4	1.7

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'WILWIND 230KV'	159.9636	0.02476	-0.11442	15
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'CAPROCK 115KV'	79.98182	0.01761	-0.10727	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'CUNNINGHAM 115KV'	110	0.01652	-0.10618	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'CUNNINGHAM 115KV'	71	0.01652	-0.10618	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'CUNNINGHAM 230KV'	306	0.01657	-0.10623	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'JONES 230KV'	486	0.01428	-0.10394	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'LP-BRND2 69KV'	80	0.01417	-0.10383	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'MADDOX 115KV'	177.1353	0.01651	-0.10617	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'MUSTANG 115KV'	300	0.01632	-0.10598	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'MUSTG5 118.0 230KV'	360	0.01644	-0.1061	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'PLANTX 115KV'	214.6	0.01712	-0.10678	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'PLANTX 230KV'	189	0.01809	-0.10775	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'SAN JUAN 230KV'	119.9727	0.01734	-0.107	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'TOLK 230KV'	1040.965	0.01755	-0.10721	16
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'HARRINGTON 230KV'	1066	0.01034	-0.1	17
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'NICHOLS 230KV'	147	0.00908	-0.09874	17
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'NICHOLS 115KV'	147	-0.00607	-0.08359	20
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'STEER WATER 115KV'	79.98182	-0.01727	-0.07239	23
SPS	RIVERVIEW 69KV'	23	-0.08966	SPS	'CZ 69KV'	39	-0.02903	-0.06063	28
WEPL	CIMARRON RIVER 115KV'	20.20224	-0.05749	WEPL	'CLIFTON 115KV'	65	-0.00176	-0.05573	30
WEPL	CIMARRON RIVER 115KV'	20.20224	-0.05749	WEPL	'HARPER 139KV'	16.86	-0.00372	-0.05377	31
WEPL	CIMARRON RIVER 115KV'	20.20224	-0.05749	WEPL	'RUSSELL 115KV'	25.23501	-0.00393	-0.05356	31
WEPL	CIMARRON RIVER 115KV'	20.20224	-0.05749	WEPL	'A. M. MULLERGEN GENERATOR 115KV'	63	-0.00454	-0.05295	32
WEPL	CIMARRON RIVER 115KV'	20.20224	-0.05749	WEPL	'NORTH WEST GREAT BEND 115KV'	11.048	-0.00454	-0.05295	32
WEPL	CIMARRON RIVER 115KV'	20.20224	-0.05749	WEPL	'SPEARVILLE WIND 34KV'	100	-0.00686	-0.05063	33
WEPL	CIMARRON RIVER 115KV'	20.20224	-0.05749	WEPL	'GRAY COUNTY WIND FARM 115KV'	76	-0.01885	-0.03864	43
WEPL	CIMARRON RIVER 115KV'	20.20224	-0.05749	WEPL	'JUDSON LARGE 115KV'	110.5181	-0.01903	-0.03846	44
SPS	'NICHOLS 115KV'	66.00001	-0.00607	SPS	'WILWIND 230KV'	159.9636	0.02476	-0.03083	54

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Tex-Hitchland-Sherman Tap 115 kV ckt & Hitchland 345 and 115 kV Interchange  
 Limiting Facility: MOORE COUNTY INTERCHANGE 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: HERRNT3 - RB-SNEE3 115KV CKT 1  
 Flowgate: 50669506681506865069013407G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation		Relief Amount	Aggregate Relief Amount
1090454		0.9	7.3
1090487		6.4	7.3

  

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'CAPROCK 115KV'	36	0.01595	-0.59065	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'CUNNINGHAM 115KV'	108.7676	0.01504	-0.58974	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'CUNNINGHAM 230KV'	306	0.01509	-0.58979	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'JONES 230KV'	486	0.01295	-0.58765	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'LP-BRND2 69KV'	80	0.01284	-0.58754	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'MADDOX 115KV'	118	0.01503	-0.58973	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'MUSTANG 115KV'	300	0.01486	-0.58956	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'MUSTG5 118.0 230KV'	210	0.01497	-0.58967	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'PLANTX 115KV'	205	0.01552	-0.59022	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'PLANTX 230KV'	189	0.01652	-0.59122	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'SAN JUAN 230KV'	54	0.01578	-0.59048	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'TOLK 230KV'	1020.127	0.01601	-0.59071	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'WILWIND 230KV'	72	0.02282	-0.59752	12
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'BLACKHAWK 115KV'	220	-0.02371	-0.55099	13
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'CZ 69KV'	35	-0.01303	-0.56167	13
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'HARRINGTON 230KV'	706	0.01179	-0.58649	13
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'HUBRCO2 69KV'	5	-0.02071	-0.55399	13
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'SIDRCH 69KV'	14	-0.02071	-0.55399	13
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'STEER WATER 115KV'	36	-0.01704	-0.55766	13
WEPL	CIMARRON RIVER 115KV'	72	-0.05688	WEPL	'SPEARVILLE WIND 34KV'	100	-0.00674	-0.04894	150
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'WILWIND 230KV'	72	0.02282	-0.04367	168
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'PLANTX 230KV'	189	0.01652	-0.03737	196
WEPL	CIMARRON RIVER 115KV'	72	-0.05688	WEPL	'JUDSON LARGE 115KV'	82.32194	-0.01849	-0.03719	197
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'TOLK 230KV'	1020.127	0.01601	-0.03686	199
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'PLANTX 115KV'	205	0.01552	-0.03637	202
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'CUNNINGHAM 115KV'	108.7676	0.01504	-0.03589	204
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'CUNNINGHAM 230KV'	306	0.01509	-0.03594	204
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'MADDOX 115KV'	118	0.01503	-0.03588	204
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'MUSTANG 115KV'	300	0.01486	-0.03571	205
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'MUSTG5 118.0 230KV'	210	0.01497	-0.03582	205
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'JONES 230KV'	486	0.01295	-0.0338	217
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'LP-BRND2 69KV'	80	0.01284	-0.03369	218
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'HARRINGTON 230KV'	706	0.01179	-0.03264	225

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Tex-Hitchland-Sherman Tap 115 kV ckt & Hitchland 345 and 115 kV Interchange  
 Limiting Facility: MOORE COUNTY INTERCHANGE 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: HERRNT3 - RB-SNEE3 115KV CKT 1  
 Flowgate: 50669506681506865069013408SP  
 Date Redispatch Needed: Starting 2008 6/1 - 10/1 Until EOC  
 Season Flowgate Identified: 2008 Summer Peak

Reservation		Relief Amount	Aggregate Relief Amount
1090310		0.1	1.4
1090315		0.4	1.4



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1090454		0.3	1.4						
1090456		0.2	1.4						
1090487		0.3	1.4						
WEPL	CIMARRON RIVER 115KV'	47	-0.05404	WEPL	'CLIFTON 115KV'	63.43616	-0.00162	-0.05242	26
WEPL	CIMARRON RIVER 115KV'	47	-0.05404	WEPL	'HARPER 138KV'	16.26	-0.00347	-0.05057	27
WEPL	CIMARRON RIVER 115KV'	47	-0.05404	WEPL	'RUSSELL 115KV'	19.4	-0.00363	-0.05041	27
WEPL	CIMARRON RIVER 115KV'	47	-0.05404	WEPL	'A. M. MULLERGREY GENERATOR 115KV'	63	-0.00419	-0.04985	28
WEPL	CIMARRON RIVER 115KV'	47	-0.05404	WEPL	'SPEARVILLE WIND 34KV'	100	-0.00633	-0.04771	29
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'WILWIND 230KV'	16	0.02266	-0.04373	31
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'WILWIND 230KV'	16	0.02266	-0.04433	31
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'PLANTX 230KV'	189	0.01637	-0.03804	36
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'PLANTX 230KV'	189	0.01637	-0.03744	37
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'TOLK 230KV'	1033.618	0.01586	-0.03693	37
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'CUNNINGHAM 230KV'	306	0.01493	-0.0366	37
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'PLANTX 115KV'	205	0.01535	-0.03702	37
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'TOLK 230KV'	1033.618	0.01586	-0.03753	37
WEPL	CIMARRON RIVER 115KV'	47	-0.05404	WEPL	'GRAY COUNTY WIND FARM 115KV'	36	-0.01764	-0.0364	38
WEPL	CIMARRON RIVER 115KV'	47	-0.05404	WEPL	'JUDSON LARGE 115KV'	112.1395	-0.01781	-0.03623	38
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'CUNNINGHAM 115KV'	110	0.01488	-0.03595	38
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'CUNNINGHAM 115KV'	64.56738	0.01488	-0.03595	38
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'CUNNINGHAM 230KV'	306	0.01493	-0.036	38
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'MADDOX 115KV'	118	0.01487	-0.03594	38
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'MUSTANG 115KV'	300	0.0147	-0.03577	38
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'MUSTG5 118.0 230KV'	360	0.01481	-0.03588	38
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'PLANTX 115KV'	205	0.01535	-0.03642	38
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'CUNNINGHAM 115KV'	64.56738	0.01488	-0.03655	38
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'CUNNINGHAM 115KV'	110	0.01488	-0.03655	38
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'MADDOX 115KV'	118	0.01487	-0.03654	38
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'MUSTANG 115KV'	300	0.0147	-0.03637	38
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'MUSTG5 118.0 230KV'	360	0.01481	-0.03648	38
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'JONES 230KV'	486	0.01279	-0.03446	40
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'LP-BRND2 69KV'	80	0.01268	-0.03435	40
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'JONES 230KV'	486	0.01279	-0.03386	41
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'LP-BRND2 69KV'	80	0.01268	-0.03375	41
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'HARRINGTON 230KV'	1066	0.01162	-0.03329	41
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'HARRINGTON 230KV'	1066	0.01162	-0.03269	42
SPS	'NICHOLS 115KV'	66.00001	-0.02107	SPS	'NICHOLS 230KV'	147	0.01052	-0.03159	43
SPS	RIVERVIEW 69KV'	23	-0.02167	SPS	'NICHOLS 230KV'	147	0.01052	-0.03219	43

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: Tex-Hitchland-Sherman Tap 115 kV ckt & Hitchland 345 and 115 kV Interchange  
 Limiting Facility: MOORE COUNTY INTERCHANGE 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: HERRINT3 - RIVERVIEW INTERCHANGE 115KV CKT 1  
 Flowgate: 50669506681506865069413407G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090454	0.9	9.4
1090487	8.5	9.4

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'CAPROCK 115KV'	36	0.01595	-0.59065	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'CUNNINGHAM 115KV'	108.7676	0.01504	-0.58974	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'CUNNINGHAM 230KV'	306	0.01509	-0.58979	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'HARRINGTON 230KV'	706	0.01179	-0.58649	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'JONES 230KV'	486	0.01295	-0.58765	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'LP-BRND2 69KV'	80	0.01284	-0.58754	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'MADDOX 115KV'	118	0.01503	-0.58973	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'MUSTANG 115KV'	300	0.01486	-0.58956	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'MUSTG5 118.0 230KV'	210	0.01497	-0.58967	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'PLANTX 115KV'	205	0.01552	-0.59022	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'PLANTX 230KV'	189	0.01652	-0.59122	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'SAN JUAN 230KV'	54	0.01578	-0.59048	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'TOLK 230KV'	1020.127	0.01601	-0.59071	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'WILWIND 230KV'	72	0.02282	-0.59752	16
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'BLACKHAWK 115KV'	220	-0.02371	-0.55099	17
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'CZ 69KV'	35	-0.01303	-0.56167	17
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'SIDRCH 69KV'	14	-0.02071	-0.55399	17
SPS	'MOORE COUNTY 115KV'	48	-0.5747	SPS	'STEER WATER 115KV'	36	-0.01704	-0.55766	17
WEPL	CIMARRON RIVER 115KV'	72	-0.05688	WEPL	'SPEARVILLE WIND 34KV'	100	-0.00674	-0.04894	193
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'WILWIND 230KV'	72	0.02282	-0.04367	216
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'PLANTX 230KV'	189	0.01652	-0.03737	252
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'TOLK 230KV'	1020.127	0.01601	-0.03686	256
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'PLANTX 115KV'	205	0.01552	-0.03637	259
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'CUNNINGHAM 230KV'	306	0.01509	-0.03594	262
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'CUNNINGHAM 115KV'	108.7676	0.01504	-0.03589	263
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'MADDOX 115KV'	118	0.01503	-0.03588	263
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'MUSTG5 118.0 230KV'	210	0.01497	-0.03582	263
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'MUSTANG 115KV'	300	0.01486	-0.03571	264
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'JONES 230KV'	486	0.01295	-0.0338	279
SPS	'NICHOLS 115KV'	213	-0.02085	SPS	'HARRINGTON 230KV'	706	0.01179	-0.03264	289

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WEATHERFORD SOUTHEAST (WTH\_SE) 138-69-13.8KV TRANSFORMER CKT 1  
 Limiting Facility: WEATHERFORD SOUTHEAST (WTH\_SE) 138-69-13.8KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: CLINTON NATURAL GAS TAP - WTH WF 4 138KV CKT 1  
 Flowgate: WTHWTH\_SE2421541975416912407SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090270	0.2	0.2

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
AEPW	ARSENAL HILL 69KV'	99	0.00036	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23026	1
AEPW	COGENTRIX 345KV'	694	0.00161	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22901	1
AEPW	EASTMAN 138KV'	130.01	0.00038	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23024	1
AEPW	FLINT CREEK 161KV'	8	0.00098	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22964	1
AEPW	FULTON 115KV'	153	0.00031	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23031	1
AEPW	KIOWA 345KV'	1348	0.00098	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22964	1
AEPW	KNOXLEE 138KV'	138	0.00037	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23025	1
AEPW	KNOXLEE 138KV'	60	0.00037	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23025	1
AEPW	L&D13 69KV'	13	0.00083	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22979	1
AEPW	LEBROCK 345KV'	182	0.00037	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23025	1
AEPW	LIEBERMAN 138KV'	154	0.00036	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23026	1
AEPW	LONESTAR POWER PLANT 69KV'	50	0.00038	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23024	1
AEPW	MID-CONTINENT 138KV'	142.11	0.00118	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22944	1
AEPW	NARROWS 69KV'	3	0.00033	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23029	1
AEPW	NORTH MARSHALL 69KV'	5	0.00037	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23025	1
AEPW	OEC 345KV'	991	0.00142	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.2292	1
AEPW	PIRKEY GENERATION 138KV'	40	0.00037	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23025	1
AEPW	RIVERSIDE STATION 138KV'	76.00003	0.00156	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22906	1
AEPW	RVRSIDEG13.8 138KV'	172	0.00156	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22906	1
AEPW	SOUTHWESTERN STATION 138KV'	151	-0.02002	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.25064	1
AEPW	SOUTHWESTERN STATION 138KV'	336	-0.02002	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.25064	1
AEPW	TENASKA GATEWAY 345KV'	937.03	0.00036	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23026	1
AEPW	TULSA POWER STATION 138KV'	72	0.00155	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22907	1
AEPW	TULSA POWER STATION 138KV'	5	0.00155	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22907	1
AEPW	TULSA POWER STATION 69KV'	24	0.00155	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22907	1
AEPW	TULSA POWER STATION 69KV'	33	0.00155	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22907	1
AEPW	TULSA POWER STATION 69KV'	23	0.00155	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22907	1
AEPW	WEELETKA 138KV'	72	0.00116	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.22946	1
AEPW	WELSH 345KV'	54	0.0004	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23022	1
AEPW	WILKES 138KV'	133.7834	0.00038	AEPW	'WEATHERFORD 34KV'	148	0.23062	-0.23024	1

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: EXIDE JUNCTION - SUMMIT 115KV CKT 1  
 Direction: To->From  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57368573811568725687312207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1086655	5.6	10.9
1086656	1.9	10.9
1090609	0.2	10.9
1090662	0.8	10.9
1090674	0.1	10.9
1090817	0.8	10.9
1090823	0.1	10.9
1090964	1.1	10.9
1090965	0.3	10.9

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.02006	-0.30399	36
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.01438	-0.29831	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'LAWRENCE ENERGY CENTER 115KV'	60	0.00737	-0.2913	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'LAWRENCE ENERGY CENTER 230KV'	235.9986	0.00765	-0.29158	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'TECUMSEH ENERGY CENTER 115KV'	108	0.00696	-0.29089	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'CHANUTE 69KV'	46.617	0.00115	-0.28508	38
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00007	-0.284	38
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'CITY OF ERIE 69KV'	22.264	0.00115	-0.28508	38
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'CITY OF IOLA 69KV'	19.865	0.00138	-0.28531	38
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00226	-0.28619	38
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'EVANS ENERGY CENTER 138KV'	262.1094	-0.00007	-0.28386	38
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'CITY OF WELLINGTON 69KV'	41.45	-0.00155	-0.28238	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'GILL ENERGY CENTER 138KV'	77	-0.0028	-0.28113	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	'WACO 138KV'	17.947	-0.00253	-0.2814	39
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.02006	-0.24234	45
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.02006	-0.24223	45
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.01438	-0.23666	46
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.01438	-0.23655	46
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'LAWRENCE ENERGY CENTER 115KV'	60	0.00737	-0.22965	47
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'LAWRENCE ENERGY CENTER 230KV'	235.9986	0.00765	-0.22993	47
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'LAWRENCE ENERGY CENTER 115KV'	60	0.00737	-0.22954	47
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'LAWRENCE ENERGY CENTER 230KV'	235.9986	0.00765	-0.22982	47
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'TECUMSEH ENERGY CENTER 115KV'	108	0.00696	-0.22924	48
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'TECUMSEH ENERGY CENTER 115KV'	108	0.00696	-0.22913	48
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'CHANUTE 69KV'	46.617	0.00115	-0.22343	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00007	-0.22235	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'CITY OF ERIE 69KV'	22.264	0.00115	-0.22343	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'CITY OF IOLA 69KV'	19.865	0.00138	-0.22366	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'CITY OF WELLINGTON 69KV'	41.45	-0.00155	-0.22073	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00226	-0.22454	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'EVANS ENERGY CENTER 138KV'	262.1094	-0.00007	-0.22221	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'CHANUTE 69KV'	46.617	0.00115	-0.22332	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00007	-0.22224	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'CITY OF ERIE 69KV'	22.264	0.00115	-0.22332	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'CITY OF IOLA 69KV'	19.865	0.00138	-0.22355	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'CITY OF WELLINGTON 69KV'	41.45	-0.00155	-0.22062	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00226	-0.22443	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'EVANS ENERGY CENTER 138KV'	262.1094	-0.00007	-0.22221	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'GILL ENERGY CENTER 138KV'	77	-0.0028	-0.21948	50
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.22228	WERE	'WACO 138KV'	17.947	-0.00253	-0.21975	50
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'GILL ENERGY CENTER 138KV'	77	-0.0028	-0.21937	50
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22217	WERE	'WACO 138KV'	17.947	-0.00253	-0.21964	50
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16101	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.02006	-0.18107	60
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16101	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.01438	-0.17539	62
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16101	WERE	'LAWRENCE ENERGY CENTER 115KV'	60	0.00737	-0.16838	65
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16101	WERE	'LAWRENCE ENERGY CENTER 230KV'	235.9986	0.00765	-0.16866	65
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16101	WERE	'TECUMSEH ENERGY CENTER 115KV'	108	0.00696	-0.16797	65
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16101	WERE	'CHANUTE 69KV'	46.617	0.00115	-0.16216	67

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16101	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.00155	-0.15946	68
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16101	WERE	EVANS ENERGY CENTER 138KV'	262.1094	-0.00007	-0.16094	68
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16101	WERE	GILL ENERGY CENTER 138KV'	77	-0.0028	-0.15821	69
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28393	WERE	HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.22228	-0.06165	177

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: EXIDE JUNCTION - SUMMIT 115KV CKT 1  
 Direction: To->From  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57368573811568725687312208WP  
 Date Redispatch Needed: Starting 2008 12/1 - 4/1 Until EOC  
 Season Flowgate Identified: 2008 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1086655	0.3	3.4
1086656	0.1	3.4
1089950	0.1	3.4
1090325	0.1	3.4
1090327	0.1	3.4
1090609	0.1	3.4
1090612	0.1	3.4
1090612	0.1	3.4
1090662	0.1	3.4
1090674	0.1	3.4
1090817	0.1	3.4
1090823	0.1	3.4
1090826	0.1	3.4
1090839	0.1	3.4
1090841	0.1	3.4
1090844	0.1	3.4
1090852	0.1	3.4
1090853	0.1	3.4
1090854	0.1	3.4
1090917	0.1	3.4
1090919	0.1	3.4
1090920	0.1	3.4
1090921	0.1	3.4
1090922	0.3	3.4
1090923	0.2	3.4
1090934	0.1	3.4
1090935	0.1	3.4
1090964	0.1	3.4
1090965	0.1	3.4
1091028	0.1	3.4
1091036	0.1	3.4
1091045	0.1	3.4
1091052	0.1	3.4
1091053	0.1	3.4
1091055	0.1	3.4
1091057	0.1	3.4

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.34656	10
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'SMOKEYHIL 230 230KV'	30	0.06272	-0.34656	10
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0144	-0.29824	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.02009	-0.30393	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'CHANUTE 69KV'	34.903	0.00117	-0.28501	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00006	-0.2839	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'CITY OF BURLINGTON 69KV'	4.8	0.00224	-0.28608	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00087	-0.28471	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'CITY OF IOLA 69KV'	19.902	0.00142	-0.28526	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00156	-0.28228	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.00224	-0.28608	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'EVANS ENERGY CENTER 138KV'	15.14941	-0.00008	-0.28376	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'HOLTON 115KV'	8.2	0.00712	-0.29096	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.00768	-0.29152	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'SOUTH SENECA 115KV'	8.5	-0.00012	-0.28372	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'WACO 138KV'	17.414	-0.00254	-0.2813	12
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.28491	12
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'SMOKEYHIL 230 230KV'	30	0.06272	-0.28491	12
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.28468	12
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'SMOKEYHIL 230 230KV'	30	0.06272	-0.28468	12
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0144	-0.23659	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.02009	-0.24228	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0144	-0.23636	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.02009	-0.24205	14
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.22369	15
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'SMOKEYHIL 230 230KV'	30	0.06272	-0.22369	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'CHANUTE 69KV'	34.903	0.00117	-0.22336	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00006	-0.22225	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00087	-0.22306	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'CITY OF IOLA 69KV'	19.902	0.00142	-0.22361	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00156	-0.22063	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.00224	-0.22443	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'EVANS ENERGY CENTER 138KV'	15.14941	-0.00008	-0.22211	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'HOLTON 115KV'	8.2	0.00712	-0.22931	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.00768	-0.22987	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'SOUTH SENECA 115KV'	8.5	-0.00012	-0.22207	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'WACO 138KV'	17.414	-0.00254	-0.21965	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'CHANUTE 69KV'	34.903	0.00117	-0.22313	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00006	-0.22202	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'CITY OF FREDONIA 69KV'	5.225	0.00087	-0.22283	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'CITY OF IOLA 69KV'	19.902	0.00142	-0.22338	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00156	-0.2204	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.00224	-0.2242	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'EVANS ENERGY CENTER 138KV'	15.14941	-0.00008	-0.22188	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'HOLTON 115KV'	8.2	0.00712	-0.22908	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.00768	-0.22964	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'SOUTH SENECA 115KV'	8.5	-0.00012	-0.22184	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'WACO 138KV'	17.414	-0.00254	-0.21942	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.28384	WERE	'CLAY CENTER JUNCTION 115KV'	10.632	-0.10172	-0.18212	18
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0144	-0.17537	19

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.02009	-0.18106	19
WERE	ST JOHN 115KV'	7.5	-0.11363	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.17635	19
WERE	ST JOHN 115KV'	7.5	-0.11363	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.17635	19
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'HOLTON 115KV'	8.2	0.00712	-0.16809	20
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.00768	-0.16865	20
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.16444	20
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.16444	20
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'CHANUTE 69KV'	34.903	0.00117	-0.16214	21
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00006	-0.16103	21
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'CITY OF IOLA 69KV'	19.902	0.00142	-0.16239	21
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00156	-0.15941	21
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.00224	-0.16321	21
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'EVANS ENERGY CENTER 138KV'	15.14941	-0.00008	-0.16089	21
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'SOUTH SENECA 115KV'	8.5	-0.00012	-0.16085	21
WERE	ABILENE ENERGY CENTER 115KV'	66	-0.16097	WERE	'WACO 138KV'	17.414	-0.00254	-0.15843	21
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.02009	-0.12181	28
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.22219	WERE	'CLAY CENTER JUNCTION 115KV'	10.632	-0.10172	-0.12047	28
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.22196	WERE	'CLAY CENTER JUNCTION 115KV'	10.632	-0.10172	-0.12024	28
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.0144	-0.11612	29
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.00768	-0.1094	31
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.00224	-0.10396	32
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'CHANUTE 69KV'	34.903	0.00117	-0.10289	33
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00006	-0.10178	33
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'CITY OF IOLA 69KV'	19.902	0.00142	-0.10314	33
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'EVANS ENERGY CENTER 138KV'	15.14941	-0.00008	-0.10164	33
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00156	-0.10016	34
WERE	CLAY CENTER JUNCTION 115KV'	27.468	-0.10172	WERE	'WACO 138KV'	17.414	-0.00254	-0.09918	34
MIDW	PAWNEE 115KV'	999	-0.11363	MIDW	'KNOLL 3 115 115KV'	71	-0.03092	-0.08271	41
MIDW	RICE 115KV'	999	-0.11363	MIDW	'KNOLL 3 115 115KV'	71	-0.03092	-0.08271	41
WERE	GILL ENERGY CENTER 138KV'	218	-0.00282	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.06554	51
WERE	GILL ENERGY CENTER 138KV'	218	-0.00282	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.06554	51
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.00156	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.06428	52
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.00156	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.06428	52
WERE	GILL ENERGY CENTER 69KV'	118	-0.00212	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.06484	52
WERE	GILL ENERGY CENTER 69KV'	118	-0.00212	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.06484	52
WERE	CITY OF WINFIELD 69KV'	40	-0.001	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.06372	53
WERE	CITY OF WINFIELD 69KV'	40	-0.001	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.06372	53
WERE	EVANS ENERGY CENTER 138KV'	931.8506	-0.00008	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.0628	53
WERE	EVANS ENERGY CENTER 138KV'	931.8506	-0.00008	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.0628	53
WERE	GETTY 69KV'	35	0.00025	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.06247	54
WERE	GETTY 69KV'	35	0.00025	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.06247	54
WERE	LATHAM1234.0 345KV'	150	0.00092	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.0618	54
WERE	LATHAM1234.0 345KV'	150	0.00092	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.0618	54
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00113	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.06159	54
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00113	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.06159	54
WERE	CHANUTE 69KV'	52.897	0.00117	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.06155	55
WERE	CHANUTE 69KV'	52.897	0.00117	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.06155	55
WERE	CITY OF ERIE 69KV'	24.138	0.00117	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.06155	55
WERE	CITY OF ERIE 69KV'	24.138	0.00117	WERE	'SMOKEY HILLS 230 230KV'	30	0.06272	-0.06155	55
WERE	TECUMSEH ENERGY CENTER 115KV'	243	0.00698	WERE	'SMOKEY HILLS 34KV'	25	0.06272	-0.05574	60

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: EXIDE JUNCTION - SUMMIT 115KV CKT 1  
 Direction: To->From  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57368573811568725687312211WP  
 Date Redispatch Needed: 12/1/11 - 4/1/12  
 Season Flowgate Identified:

Reservation	Relief Amount	Aggregate Relief Amount
1086655	0.7	10.1
1086656	0.2	10.1
1089950	0.2	10.1
1090325	0.3	10.1
1090327	0.1	10.1
1090329	0.4	10.1
1090331	0.1	10.1
1090332	0.6	10.1
1090334	0.2	10.1
1090377	0.4	10.1
1090378	0.2	10.1
1090382	0.3	10.1
1090383	0.1	10.1
1090416	0.2	10.1
1090612	0.1	10.1
1090612	0.1	10.1
1090662	0.1	10.1
1090674	0.1	10.1
1090676	0.1	10.1
1090817	0.2	10.1
1090823	0.1	10.1
1090826	0.4	10.1
1090829	0.1	10.1
1090839	0.4	10.1
1090841	0.4	10.1
1090844	0.1	10.1
1090852	0.1	10.1
1090853	0.1	10.1
1090854	0.1	10.1
1090917	0.2	10.1
1090919	0.1	10.1
1090920	0.3	10.1
1090921	0.1	10.1
1090922	0.9	10.1
1090923	0.3	10.1
1090934	0.4	10.1
1090935	0.1	10.1
1090964	0.3	10.1
1090965	0.1	10.1
1091028	0.1	10.1
1091036	0.1	10.1
1091045	0.1	10.1
1091052	0.1	10.1

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
	1091053	0.2							10.1
	1091055	0.3							10.1
	1091057	0.1							10.1
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	'SMOKEY HILLS 34KV'	25	0.06275	-0.34654	29
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	'SMOKYHILL 230 230KV'	24	0.06275	-0.34654	29
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	JEFFREY ENERGY CENTER 345KV	940	0.02008	-0.30387	33
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	JEFFREY ENERGY CENTER 230KV	470	0.01439	-0.29818	34
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	CITY OF IOLA 69KV	16.378	0.00141	-0.2852	35
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.00768	-0.29147	35
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.00698	-0.29077	35
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	CHANUTE 69KV	56.697	0.00117	-0.28496	36
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	CITY OF AUGUSTA 69KV	20.02	0.00007	-0.28386	36
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	CITY OF WELLINGTON 69KV	20	-0.00157	-0.28222	36
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	EVANS ENERGY CENTER 138KV	55	-0.00007	-0.28372	36
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.28379	WERE	'WACO 138KV'	17.96	-0.00253	-0.28126	36
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	'SMOKEY HILLS 34KV'	25	0.06275	-0.28488	36
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	'SMOKYHILL 230 230KV'	24	0.06275	-0.28488	36
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	'SMOKEY HILLS 34KV'	25	0.06275	-0.28465	36
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	'SMOKYHILL 230 230KV'	24	0.06275	-0.28465	36
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	JEFFREY ENERGY CENTER 345KV	940	0.02008	-0.24221	42
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	JEFFREY ENERGY CENTER 345KV	940	0.02008	-0.24198	42
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	JEFFREY ENERGY CENTER 230KV	470	0.01439	-0.23652	43
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	JEFFREY ENERGY CENTER 230KV	470	0.01439	-0.23629	43
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.00768	-0.22981	44
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.00698	-0.22911	44
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.00768	-0.22958	44
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.00698	-0.22888	44
WERE	ABILENE ENERGY CENTER 115KV	66	-0.16095	WERE	'SMOKEY HILLS 34KV'	25	0.06275	-0.2237	45
WERE	ABILENE ENERGY CENTER 115KV	66	-0.16095	WERE	'SMOKYHILL 230 230KV'	24	0.06275	-0.2237	45
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	CHANUTE 69KV	56.697	0.00117	-0.2233	45
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	CITY OF IOLA 69KV	16.378	0.00141	-0.22354	45
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	CHANUTE 69KV	56.697	0.00117	-0.22307	45
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	CITY OF IOLA 69KV	16.378	0.00141	-0.22331	45
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	CITY OF AUGUSTA 69KV	20.02	0.00007	-0.2222	46
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	CITY OF WELLINGTON 69KV	20	-0.00157	-0.22056	46
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	EVANS ENERGY CENTER 138KV	55	-0.00007	-0.22206	46
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.22213	WERE	'WACO 138KV'	17.96	-0.00253	-0.2196	46
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	CITY OF AUGUSTA 69KV	20.02	0.00007	-0.22197	46
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	CITY OF WELLINGTON 69KV	20	-0.00157	-0.22033	46
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	EVANS ENERGY CENTER 138KV	55	-0.00007	-0.22183	46
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.2219	WERE	'WACO 138KV'	17.96	-0.00253	-0.21937	46
WERE	ABILENE ENERGY CENTER 115KV	66	-0.16095	WERE	JEFFREY ENERGY CENTER 345KV	940	0.02008	-0.18103	56
WERE	ABILENE ENERGY CENTER 115KV	66	-0.16095	WERE	JEFFREY ENERGY CENTER 230KV	470	0.01439	-0.17534	58
WERE	ABILENE ENERGY CENTER 115KV	66	-0.16095	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.00768	-0.18663	60
WERE	ABILENE ENERGY CENTER 115KV	66	-0.16095	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.00698	-0.16793	60
WERE	ABILENE ENERGY CENTER 115KV	66	-0.16095	WERE	CHANUTE 69KV	56.697	0.00117	-0.16212	62
WERE	CLAY CENTER JUNCTION 115KV	31.4	-0.10172	WERE	'SMOKEY HILLS 34KV'	25	0.06275	-0.16447	62
WERE	CLAY CENTER JUNCTION 115KV	31.4	-0.10172	WERE	'SMOKYHILL 230 230KV'	24	0.06275	-0.16447	62
WERE	ABILENE ENERGY CENTER 115KV	66	-0.16095	WERE	EVANS ENERGY CENTER 138KV	55	-0.00007	-0.16088	63
WERE	CLAY CENTER JUNCTION 115KV	31.4	-0.10172	WERE	JEFFREY ENERGY CENTER 345KV	940	0.02008	-0.1218	83
WERE	CLAY CENTER JUNCTION 115KV	31.4	-0.10172	WERE	JEFFREY ENERGY CENTER 230KV	470	0.01439	-0.11611	87
WERE	CLAY CENTER JUNCTION 115KV	31.4	-0.10172	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.00768	-0.1094	93
WERE	CLAY CENTER JUNCTION 115KV	31.4	-0.10172	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.00698	-0.1087	93
MIDW	PAWNEE 115KV	999	-0.11355	MIDW	'KNOLL 3 115 115KV'	48	-0.03084	-0.08271	122
MIDW	RICE 115KV	999	-0.11355	MIDW	'KNOLL 3 115 115KV'	48	-0.03084	-0.08271	122

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: EXIDE JUNCTION - SUMMIT 115KV CKT 1  
 Direction: To->From  
 Line Outage: NORTHVIEW - SUMMIT 115KV CKT 1  
 Flowgate: 57368573811573715738112207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1086655	4.3	6.3
1086656	1.5	6.3
1090662	0.2	6.3
1090674	0.1	6.3
1090823	0.2	6.3
1090825	0.2	6.3

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	JEFFREY ENERGY CENTER 345KV	940	0.01085	-0.36644	17
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	CHANUTE 69KV	46.617	-0.00008	-0.35551	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	CITY OF AUGUSTA 69KV	20.02	-0.00065	-0.35494	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	CITY OF BURLINGTON 69KV	7.8	-0.00002	-0.35557	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	CITY OF ERIE 69KV	22.264	-0.00008	-0.35551	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	CITY OF IOLA 69KV	19.865	-0.00002	-0.35557	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	CITY OF MULVANE 69KV	6.189	-0.00093	-0.35466	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00098	-0.35461	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	-0.00002	-0.35557	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	EVANS ENERGY CENTER 138KV	262.1094	-0.00074	-0.35485	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	GILL ENERGY CENTER 138KV	77	-0.00147	-0.35412	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	HOLTEN 115KV	12.2	0.00051	-0.3561	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	JEFFREY ENERGY CENTER 230KV	470	0.00219	-0.35778	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	LAWRENCE ENERGY CENTER 115KV	60	-0.00132	-0.35427	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	LAWRENCE ENERGY CENTER 230KV	235.9986	-0.00157	-0.35402	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	SOUTH SENECA 115KV	8.5	-0.00279	-0.3528	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	TECUMSEH ENERGY CENTER 115KV	108	-0.00495	-0.35064	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	'WACO 138KV'	17.947	-0.0014	-0.35419	18
WERE	ABILENE ENERGY CENTER 115KV	66	-0.35559	WERE	HUTCHINSON ENERGY CENTER 115KV	80.00001	-0.09475	-0.26084	24
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.23412	WERE	JEFFREY ENERGY CENTER 345KV	940	0.01085	-0.24497	26
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.23412	WERE	CHANUTE 69KV	46.617	-0.00008	-0.23404	27
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.23412	WERE	CITY OF AUGUSTA 69KV	20.02	-0.00065	-0.23347	27
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.23412	WERE	CITY OF ERIE 69KV	22.264	-0.00008	-0.23404	27
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.23412	WERE	CITY OF IOLA 69KV	19.865	-0.00002	-0.2341	27
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.23412	WERE	CITY OF WELLINGTON 69KV	41.45	-0.00098	-0.23314	27
WERE	CLAY CENTER JUNCTION 115KV	21.08999	-0.23412	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.96	-0.00002	-0.2341	27

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	CLAY CENTER JUNCTION 115KV'	21.08999	-0.23412	WERE	EVANS ENERGY CENTER 138KV'	262.1094	-0.00074	-0.23388	27
WERE	CLAY CENTER JUNCTION 115KV'	21.08999	-0.23412	WERE	GILL ENERGY CENTER 138KV'	77	-0.00147	-0.23265	27
WERE	CLAY CENTER JUNCTION 115KV'	21.08999	-0.23412	WERE	HOLTON 115KV'	12.2	0.00051	-0.23463	27
WERE	CLAY CENTER JUNCTION 115KV'	21.08999	-0.23412	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00219	-0.23631	27
WERE	CLAY CENTER JUNCTION 115KV'	21.08999	-0.23412	WERE	LAWRENCE ENERGY CENTER 115KV'	60	-0.00132	-0.23288	27
WERE	CLAY CENTER JUNCTION 115KV'	21.08999	-0.23412	WERE	LAWRENCE ENERGY CENTER 230KV'	235.9986	-0.00157	-0.23255	27
WERE	CLAY CENTER JUNCTION 115KV'	21.08999	-0.23412	WERE	WACO 138KV'	17.947	-0.0014	-0.23272	27
WERE	CLAY CENTER JUNCTION 115KV'	21.08999	-0.23412	WERE	TECUMSEH ENERGY CENTER 115KV'	108	-0.00495	-0.22917	28
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01085	-0.17356	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00219	-0.1649	38
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	CHANUTE 69KV'	46.617	-0.00008	-0.16263	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	CITY OF AUGUSTA 69KV'	20.02	-0.00065	-0.16206	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	CITY OF ERIE 69KV'	22.264	-0.00008	-0.16263	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	CITY OF IOLA 69KV'	19.865	-0.00002	-0.16269	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.00098	-0.16173	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	-0.00002	-0.16269	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	EVANS ENERGY CENTER 138KV'	262.1094	-0.00074	-0.16197	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	GILL ENERGY CENTER 138KV'	77	-0.00147	-0.16124	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	LAWRENCE ENERGY CENTER 115KV'	60	-0.00132	-0.16139	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	LAWRENCE ENERGY CENTER 230KV'	235.9986	-0.00157	-0.16114	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	WACO 138KV'	17.947	-0.0014	-0.16131	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	TECUMSEH ENERGY CENTER 115KV'	108	-0.00495	-0.15776	40
WERE	CLAY CENTER JUNCTION 115KV'	21.08999	-0.23412	WERE	HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.09475	-0.13937	45
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.09475	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01085	-0.1056	60
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.09469	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01085	-0.10564	60
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.09475	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00219	-0.09694	65
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.09469	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.00219	-0.09688	65
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.09475	WERE	CHANUTE 69KV'	46.617	-0.00008	-0.09467	67
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.09469	WERE	EVANS ENERGY CENTER 138KV'	262.1094	-0.00074	-0.09401	67
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.09469	WERE	CHANUTE 69KV'	46.617	-0.00008	-0.09461	67
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.09469	WERE	EVANS ENERGY CENTER 138KV'	262.1094	-0.00074	-0.09395	67
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.09475	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.00098	-0.09377	68
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.09475	WERE	GILL ENERGY CENTER 138KV'	77	-0.00147	-0.09328	68
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.09475	WERE	LAWRENCE ENERGY CENTER 115KV'	60	-0.00132	-0.09343	68
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.09475	WERE	LAWRENCE ENERGY CENTER 230KV'	235.9986	-0.00157	-0.09318	68
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.09469	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.00098	-0.09371	68
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.09469	WERE	GILL ENERGY CENTER 138KV'	77	-0.00147	-0.09322	68
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.09469	WERE	LAWRENCE ENERGY CENTER 115KV'	60	-0.00132	-0.09337	68
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.09469	WERE	LAWRENCE ENERGY CENTER 230KV'	235.9986	-0.00157	-0.09312	68
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.09475	WERE	TECUMSEH ENERGY CENTER 115KV'	108	-0.00495	-0.0898	71
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.09469	WERE	TECUMSEH ENERGY CENTER 115KV'	108	-0.00495	-0.08974	71
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.16271	WERE	HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.09475	-0.06796	93

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS - NORTH AMERICAN PHILIPS JUNCTION (SOUTH) 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 5732573741568725687312206FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090609	0.3	3.5
1090612	0.4	3.5
1090662	1.0	3.5
1090680	1.7	3.5

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.64582	5
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.03466	-0.55664	6
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03598	-0.55796	6
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.02165	-0.54363	6
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	LAWRENCE ENERGY CENTER 230KV'	231.6643	0.02272	-0.5447	6
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.02612	-0.5481	6
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.54678	6
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.54659	6
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	CHANUTE 69KV'	39.541	0.00315	-0.52513	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00112	-0.5231	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00597	-0.52795	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	CITY OF ERIE 69KV'	22.171	0.00315	-0.52513	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	CITY OF GIRARD 69KV'	4.788	0.00325	-0.52523	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	CITY OF IOLA 69KV'	16.275	0.00366	-0.52564	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	CITY OF MULVANE 69KV'	4.793	-0.00109	-0.52089	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	CITY OF WELLINGTON 69KV'	20	-0.00273	-0.51925	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00597	-0.52795	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	EVANS ENERGY CENTER 138KV'	305	0.00085	-0.52283	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	GILL ENERGY CENTER 138KV'	99.9731	-0.00531	-0.51667	7
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52198	WERE	WACO 138KV'	17.957	-0.00468	-0.5173	7
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	CHANUTE 69KV'	39.541	0.00315	-0.42609	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00112	-0.42406	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00597	-0.42891	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	CITY OF ERIE 69KV'	22.171	0.00315	-0.42609	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	CITY OF GIRARD 69KV'	4.788	0.00325	-0.42619	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	CITY OF IOLA 69KV'	16.275	0.00366	-0.4266	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	CITY OF MULVANE 69KV'	4.793	-0.00109	-0.42185	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	CITY OF WELLINGTON 69KV'	20	-0.00273	-0.42021	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00597	-0.42891	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	EVANS ENERGY CENTER 138KV'	305	0.00085	-0.42379	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	GILL ENERGY CENTER 138KV'	99.9731	-0.00531	-0.41763	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.03466	-0.4576	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03598	-0.45892	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.02165	-0.44459	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	LAWRENCE ENERGY CENTER 230KV'	231.6643	0.02272	-0.44566	8
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.42294	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.02612	-0.44906	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	WACO 138KV'	17.957	-0.00468	-0.41826	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	CHANUTE 69KV'	39.541	0.00315	-0.4259	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00112	-0.42387	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00597	-0.42872	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	CITY OF ERIE 69KV'	22.171	0.00315	-0.4259	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	CITY OF GIRARD 69KV'	4.788	0.00325	-0.426	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	CITY OF IOLA 69KV'	16.275	0.00366	-0.42641	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	CITY OF MULVANE 69KV'	4.793	-0.00109	-0.42166	8

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	CITY OF WELLINGTON 69KV'	20	-0.00273	-0.42002	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00597	-0.42872	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	EVANS ENERGY CENTER 138KV'	305	0.00085	-0.4236	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	GILL ENERGY CENTER 138KV'	99.9731	-0.00531	-0.41744	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.03466	-0.45741	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03598	-0.45873	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.02165	-0.4444	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	LAWRENCE ENERGY CENTER 230KV'	231.6643	0.02272	-0.44547	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.02612	-0.44887	8
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.42275	WERE	WACO 138KV'	17.957	-0.00468	-0.41807	8
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.36907	9
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.03466	-0.27989	12
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03598	-0.28121	12
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.02165	-0.26688	13
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	LAWRENCE ENERGY CENTER 230KV'	231.6643	0.02272	-0.26795	13
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.02612	-0.27135	13
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	CHANUTE 69KV'	39.541	0.00315	-0.24838	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00114	-0.24635	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00597	-0.2512	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	CITY OF ERIE 69KV'	22.171	0.00315	-0.24838	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	CITY OF GIRARD 69KV'	4.788	0.00325	-0.24848	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	CITY OF IOLA 69KV'	16.275	0.00366	-0.24889	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	CITY OF MULVANE 69KV'	4.793	-0.00109	-0.24414	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	CITY OF WELLINGTON 69KV'	20	-0.00273	-0.2425	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00597	-0.2512	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	EVANS ENERGY CENTER 138KV'	305	0.00085	-0.24608	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	GILL ENERGY CENTER 138KV'	99.9731	-0.00531	-0.23992	14
WERE	ST JOHN 115KV'	7.5	-0.24523	WERE	WACO 138KV'	17.957	-0.00468	-0.24055	14
MIDW	PAWNEE 115KV'	999	-0.24523	MIDW	COLBY 115KV'	10.82559	-0.07452	-0.17071	20
MIDW	RICE 115KV'	999	-0.24523	MIDW	COLBY 115KV'	10.82559	-0.07452	-0.17071	20
MIDW	GREAT BEND PLANT 69KV'	10	-0.20778	MIDW	COLBY 115KV'	10.82559	-0.07452	-0.13326	26
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.00273	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12657	27
WERE	GILL ENERGY CENTER 138KV'	73.02685	-0.00531	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12915	27
WERE	GILL ENERGY CENTER 69KV'	118	-0.00375	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12759	27
WERE	CITY OF MULVANE 69KV'	10.997	-0.00109	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12493	28
WERE	CITY OF WINFIELD 69KV'	40	-0.00158	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12542	28
WERE	EVANS ENERGY CENTER 138KV'	488	0.00085	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12299	28
WERE	GETTY 69KV'	35	0.0016	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12224	28
WERE	CHANUTE 69KV'	48.259	0.00315	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12069	29
WERE	CITY OF FREDONIA 69KV'	9.668992	0.0025	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12134	29
WERE	CITY OF IOLA 69KV'	21.353	0.00366	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12018	29
WERE	LATHAM1234.0 345KV'	150	0.00291	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12093	29
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00305	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.12079	29
WERE	SOUTH SENECA 115KV'	16.7	0.00587	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.11797	29
WERE	HOLTON 115KV'	19.8	0.01846	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.10538	33
WERE	LAWRENCE ENERGY CENTER 115KV'	78	0.02165	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.10219	34
WERE	LAWRENCE ENERGY CENTER 230KV'	37.33572	0.02272	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.10112	34
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.42294	-0.09904	35
WERE	TECUMSEH ENERGY CENTER 115KV'	52.99999	0.02612	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.09772	36
WERE	TECUMSEH ENERGY CENTER 69KV'	41	0.02657	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.09727	36
WERE	JEFFREY ENERGY CENTER 230KV'	24	0.03466	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.08918	39
WERE	JEFFREY ENERGY CENTER 345KV'	42	0.03598	WERE	ABILENE ENERGY CENTER 115KV'	40	0.12384	-0.08786	39
WEPL	A. M. MULLERGREIN GENERATOR 115KV'	63	-0.22221	WEPL	GRAY COUNTY WIND FARM 115KV'	73	-0.13628	-0.08593	40
WEPL	A. M. MULLERGREIN GENERATOR 115KV'	63	-0.22221	WEPL	JUDSON LARGE 115KV'	21.29843	-0.13613	-0.08608	40
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.22221	WEPL	GRAY COUNTY WIND FARM 115KV'	73	-0.13628	-0.08593	40
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.22221	WEPL	JUDSON LARGE 115KV'	21.29843	-0.13613	-0.08608	40

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS - NORTH AMERICAN PHILIPS JUNCTION (SOUTH) 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57372573741568725687312206WP  
 Date Redispatch Needed: 12/1/06 - 4/1/07  
 Season Flowgate Identified: 2006 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount										
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)			
1090270		0.2	0.9									
1090609		0.3	0.9									
1090612		0.3	0.9									
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	CHANUTE 69KV'	35.344	0.00317	-0.5251	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00114	-0.52307	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	CITY OF BURLINGTON 69KV'	4.8	0.006	-0.52793	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	CITY OF ERIE 69KV'	2.2	0.00317	-0.5251	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	CITY OF FREDONIA 69KV'	5.225	0.00252	-0.52445	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	CITY OF GIRARD 69KV'	1.493	0.00327	-0.5252	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	CITY OF IOLA 69KV'	13.978	0.00368	-0.52561	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	CITY OF MULVANE 69KV'	3.694	-0.00106	-0.52087	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	CITY OF WELLINGTON 69KV'	24.10302	-0.00271	-0.51922	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.006	-0.52793	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.55663	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.55794	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	LAWRENCE ENERGY CENTER 230KV'	137.2661	0.02275	-0.54468	2			
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.52193	WERE	WACO 138KV'	17.953	-0.00465	-0.51728	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	CHANUTE 69KV'	35.344	0.00317	-0.42606	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00114	-0.42403	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	CITY OF BURLINGTON 69KV'	4.8	0.006	-0.42889	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	CITY OF ERIE 69KV'	2.2	0.00317	-0.42606	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	CITY OF FREDONIA 69KV'	5.225	0.00252	-0.42541	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	CITY OF GIRARD 69KV'	1.493	0.00327	-0.42616	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	CITY OF IOLA 69KV'	13.978	0.00368	-0.42657	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	CITY OF MULVANE 69KV'	3.694	-0.00106	-0.42183	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	CITY OF WELLINGTON 69KV'	24.10302	-0.00271	-0.42018	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.006	-0.42889	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.45759	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.4589	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	LAWRENCE ENERGY CENTER 230KV'	137.2661	0.02275	-0.44564	2			
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.42289	WERE	WACO 138KV'	17.953	-0.00465	-0.41824	2			
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	CHANUTE 69KV'	35.344	0.00317	-0.42587	2			
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00114	-0.42384	2			
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	CITY OF BURLINGTON 69KV'	4.8	0.006	-0.4287	2			

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	CITY OF ERIE 69KV'	2.2	0.00317	-0.42587	2
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	CITY OF FREDONIA 69KV'	5.225	0.00252	-0.42522	2
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	CITY OF GIRARD 69KV'	1.493	0.00327	-0.42597	2
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	CITY OF IOLA 69KV'	13.978	0.00368	-0.42638	2
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	CITY OF MULVANE 69KV'	3.694	-0.00106	-0.42164	2
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	CITY OF WELLINGTON 69KV'	24.10302	-0.00271	-0.41999	2
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.006	-0.4287	2
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.4574	2
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.45871	2
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	LAWRENCE ENERGY CENTER 230KV'	137.2661	0.02275	-0.44545	2
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.4227	WERE	WACO 138KV'	17.953	-0.00465	-0.41805	2
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.27987	3
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.28118	3
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	LAWRENCE ENERGY CENTER 230KV'	137.2661	0.02275	-0.26792	3
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	CHANUTE 69KV'	35.344	0.00317	-0.24834	4
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00114	-0.24631	4
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	CITY OF BURLINGTON 69KV'	4.8	0.006	-0.25117	4
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	CITY OF ERIE 69KV'	2.2	0.00317	-0.24834	4
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	CITY OF FREDONIA 69KV'	5.225	0.00252	-0.24769	4
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	CITY OF GIRARD 69KV'	1.493	0.00327	-0.24844	4
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	CITY OF IOLA 69KV'	13.978	0.00368	-0.24885	4
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	CITY OF MULVANE 69KV'	3.694	-0.00106	-0.24411	4
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	CITY OF WELLINGTON 69KV'	24.10302	-0.00271	-0.24246	4
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.006	-0.25117	4
WERE	ST JOHN 115KV'	7.5	-0.24517	WERE	WACO 138KV'	17.953	-0.00465	-0.24052	4
MIDW	PAWNEE 115KV'	999	-0.24517	MIDW	COLBY 115KV'	11.9039	-0.07445	-0.17072	5
MIDW	RICE 115KV'	999	-0.24517	MIDW	COLBY 115KV'	11.9039	-0.07445	-0.17072	5
MIDW	GREAT BEND PLANT 69KV'	10	-0.20772	MIDW	COLBY 115KV'	11.9039	-0.07445	-0.13327	7
WEPL	A. M. MULLERGEN GENERATOR 115KV'	63	-0.22216	WEPL	GRAY COUNTY WIND FARM 115KV'	73	-0.1362	-0.08596	10
WEPL	A. M. MULLERGEN GENERATOR 115KV'	63	-0.22216	WEPL	JUDSON LARGE 115KV'	8.238958	-0.13605	-0.08611	10
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.22216	WEPL	GRAY COUNTY WIND FARM 115KV'	73	-0.1362	-0.08596	10
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.22216	WEPL	JUDSON LARGE 115KV'	8.238958	-0.13605	-0.08611	10
WERE	GILL ENERGY CENTER 138KV'	218	-0.00528	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.04129	21
WERE	GILL ENERGY CENTER 138KV'	218	-0.00528	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03998	22
WERE	GILL ENERGY CENTER 69KV'	118	-0.00373	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03974	22
WERE	CITY OF WELLINGTON 69KV'	19.39698	-0.00271	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03872	23
WERE	GILL ENERGY CENTER 69KV'	118	-0.00373	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03843	23
WERE	CITY OF MULVANE 69KV'	12.096	-0.00106	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03707	24
WERE	CITY OF WELLINGTON 69KV'	19.39698	-0.00271	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03741	24
WERE	CITY OF WINFIELD 69KV'	40	-0.00156	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03626	24
WERE	CITY OF WINFIELD 69KV'	40	-0.00156	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03757	24
WERE	CITY OF MULVANE 69KV'	12.096	-0.00106	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03576	25
WERE	EVANS ENERGY CENTER 138KV'	793	0.00088	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03513	25
WERE	EVANS ENERGY CENTER 138KV'	793	0.00088	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03382	26
WERE	GETTY 69KV'	35	0.00162	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03439	26
WERE	CHANUTE 69KV'	52.456	0.00317	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03284	27
WERE	CITY OF ERIE 69KV'	24.33	0.00317	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03284	27
WERE	CITY OF GIRARD 69KV'	9.207	0.00327	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03274	27
WERE	CITY OF IOLA 69KV'	23.65	0.00368	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03233	27
WERE	GETTY 69KV'	35	0.00162	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03308	27
WERE	LATHAM1234.0 345KV'	150	0.00293	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03308	27
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00307	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03294	27
WERE	CHANUTE 69KV'	52.456	0.00317	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03153	28
WERE	CITY OF ERIE 69KV'	24.33	0.00317	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03153	28
WERE	CITY OF IOLA 69KV'	23.65	0.00368	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03102	28
WERE	LATHAM1234.0 345KV'	150	0.00293	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03177	28
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00307	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0347	-0.03163	28
WERE	SOUTH SENECA 115KV'	16.7	0.00593	WERE	JEFFREY ENERGY CENTER 345KV'	926.9392	0.03601	-0.03008	29

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS - NORTH AMERICAN PHILIPS JUNCTION (SOUTH) 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57372573741568725687312207FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090270	0.2	5.8
1090310	0.3	5.8
1090609	0.3	5.8
1090612	0.3	5.8
1090612	0.4	5.8
1090662	1.0	5.8
1090674	0.2	5.8
1090680	2.0	5.8
1090695	1.1	5.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.08669	-0.59138	10
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	CHANUTE 69KV'	56.296	0.00259	-0.50728	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00079	-0.50548	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00495	-0.50964	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	CITY OF FREDONIA 69KV'	5.225	0.00204	-0.50673	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	CITY OF IOLA 69KV'	24.256	0.00303	-0.50772	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00495	-0.50964	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	HOLTON 115KV'	8.2	0.01531	-0.52	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02953	-0.53422	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.53535	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	LAWRENCE ENERGY CENTER 230KV'	233.8593	0.01924	-0.52393	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	S'MOKEY HILLS 34KV'	25	0.03108	-0.53577	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	SOUTH SENECA 115KV'	8.5	0.00358	-0.50827	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	TECUMSEH ENERGY CENTER 115KV'	88	0.02222	-0.52691	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	CITY OF MULVANE 69KV'	4.891	-0.00108	-0.50361	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	CITY OF WELLINGTON 69KV'	20	-0.00243	-0.50226	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	EVANS ENERGY CENTER 138KV'	125.0474	0.00057	-0.50526	12
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50469	WERE	WACO 138KV'	17.946	-0.00417	-0.50052	12
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.08669	-0.48599	12
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.08669	-0.4858	12
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	CHANUTE 69KV'	56.296	0.00259	-0.40189	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00495	-0.40425	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	CITY OF FREDONIA 69KV'	5.225	0.00204	-0.40134	14



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	CITY OF IOLA 69KV'	24.256	0.00303	-0.40233	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00495	-0.40425	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	HOLTON 115KV'	8.2	0.01531	-0.41461	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02953	-0.42883	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.42996	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	LAWRENCE ENERGY CENTER 230KV'	233.8593	0.01924	-0.41854	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	'SMOKEY HILLS 34KV'	25	0.03108	-0.43038	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	'SOUTH SENECA 115KV'	8.5	0.00358	-0.40288	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	TECUMSEH ENERGY CENTER 115KV'	88	0.02222	-0.42152	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	CHANUTE 69KV'	56.296	0.00259	-0.4017	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00495	-0.40406	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	CITY OF FREDONIA 69KV'	5.225	0.00204	-0.40115	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	CITY OF IOLA 69KV'	24.256	0.00303	-0.40214	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00495	-0.40406	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	HOLTON 115KV'	8.2	0.01531	-0.41442	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02953	-0.42864	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.42977	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	LAWRENCE ENERGY CENTER 230KV'	233.8593	0.01924	-0.41835	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	'SMOKEY HILLS 34KV'	25	0.03108	-0.43019	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	'SOUTH SENECA 115KV'	8.5	0.00358	-0.40269	14
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	TECUMSEH ENERGY CENTER 115KV'	88	0.02222	-0.42133	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00079	-0.40009	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	CITY OF WELLINGTON 69KV'	20	-0.00243	-0.39687	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	EVANS ENERGY CENTER 138KV'	125.0474	0.00057	-0.39987	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.3993	WERE	'WACO 138KV'	17.946	-0.00417	-0.39513	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00079	-0.3999	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00243	-0.39668	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	EVANS ENERGY CENTER 138KV'	125.0474	0.00057	-0.39968	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39911	WERE	'WACO 138KV'	17.946	-0.00417	-0.39494	15
WERE	ST JOHN 115KV'	7.5	-0.21395	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.08669	-0.30064	19
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	HUTCHINSON ENERGY CENTER 115KV'	40	-0.3993	-0.10539	55
WEPL	A. M. MULLERGEN GENERATOR 115KV'	63	-0.17551	WEPL	GRAY COUNTY WIND FARM 115KV'	60	-0.11056	-0.06495	89
WERE	GILL ENERGY CENTER 138KV'	218	-0.0047	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.03536	164
WERE	GILL ENERGY CENTER 138KV'	218	-0.0047	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02953	-0.03423	170
WERE	GILL ENERGY CENTER 69KV'	118	-0.00337	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.03403	171
WERE	GILL ENERGY CENTER 69KV'	118	-0.00337	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02953	-0.0329	177
WERE	EVANS ENERGY CENTER 138KV'	667.9526	0.00057	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.03009	193

Maximum Decrement and Maximum Increment were determine from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS - NORTH AMERICAN PHILIPS JUNCTION (SOUTH) 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 5732573741568725687312207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090270	0.1	7.4
1090310	0.2	7.4
1090609	0.2	7.4
1090612	0.3	7.4
1090662	1.0	7.4
1090674	0.2	7.4
1090680	1.1	7.4
1090695	0.7	7.4
1090817	1.3	7.4
1090964	1.8	7.4
1090965	0.6	7.4

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	CLAY CENTER JUNCTION 115KV'	17.01001	0.08672	-0.59138	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	HOLTON 115KV'	12.2	0.01534	-0.52	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02955	-0.53421	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03069	-0.53535	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.01833	-0.52299	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	LAWRENCE ENERGY CENTER 230KV'	235.9986	0.01927	-0.52393	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.02225	-0.52691	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	CHANUTE 69KV'	46.617	0.00261	-0.50727	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00081	-0.50547	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	CITY OF BURLINGTON 69KV'	7.8	0.00497	-0.50963	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	CITY OF ERIE 69KV'	22.264	0.00261	-0.50727	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	CITY OF FREDONIA 69KV'	5.225	0.00206	-0.50672	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	CITY OF IOLA 69KV'	19.865	0.00304	-0.5077	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	CITY OF MULVANE 69KV'	6.189	-0.00106	-0.5036	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.00241	-0.50225	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00497	-0.50963	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	EVANS ENERGY CENTER 138KV'	262.1094	0.00059	-0.50525	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	GILL ENERGY CENTER 138KV'	77	-0.00468	-0.49998	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	'SOUTH SENECA 115KV'	8.5	0.00362	-0.50828	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50468	WERE	'WACO 138KV'	17.947	-0.00414	-0.50052	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	CLAY CENTER JUNCTION 115KV'	17.01001	0.08672	-0.48599	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	CLAY CENTER JUNCTION 115KV'	17.01001	0.08672	-0.4858	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02955	-0.42882	17
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03069	-0.42996	17
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02955	-0.42863	17
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03069	-0.42977	17
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	CHANUTE 69KV'	46.617	0.00261	-0.40188	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	CITY OF BURLINGTON 69KV'	7.8	0.00497	-0.40424	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	CITY OF ERIE 69KV'	22.264	0.00261	-0.40188	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	CITY OF IOLA 69KV'	19.865	0.00304	-0.40231	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00497	-0.40424	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	HOLTON 115KV'	12.2	0.01534	-0.41461	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.01833	-0.4176	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	LAWRENCE ENERGY CENTER 230KV'	235.9986	0.01927	-0.41854	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	'SOUTH SENECA 115KV'	8.5	0.00362	-0.40289	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.02225	-0.42152	18
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	CHANUTE 69KV'	46.617	0.00261	-0.40169	18
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	CITY OF BURLINGTON 69KV'	7.8	0.00497	-0.40405	18
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	CITY OF ERIE 69KV'	22.264	0.00261	-0.40169	18
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	CITY OF IOLA 69KV'	19.865	0.00304	-0.40212	18
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00497	-0.40405	18
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	HOLTON 115KV'	12.2	0.01534	-0.41442	18

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.01833	-0.41741	18
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	LAWRENCE ENERGY CENTER 230KV'	235.9986	0.01927	-0.41835	18
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	SOUTH SENECA 115KV'	8.5	0.00362	-0.4027	18
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.00225	-0.42133	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00081	-0.40008	19
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.00241	-0.39686	19
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	EVANS ENERGY CENTER 138KV'	262.1094	0.00059	-0.39986	19
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	GILL ENERGY CENTER 138KV'	77	-0.00468	-0.39459	19
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.39927	WERE	WACO 138KV'	17.947	-0.00414	-0.39513	19
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00081	-0.39989	19
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.00241	-0.39667	19
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	EVANS ENERGY CENTER 138KV'	262.1094	0.00059	-0.39967	19
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	GILL ENERGY CENTER 138KV'	77	-0.00468	-0.3944	19
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39908	WERE	WACO 138KV'	17.947	-0.00414	-0.39494	19
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50466	WERE	HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.39927	-0.10539	70
WERE	GILL ENERGY CENTER 138KV'	118	-0.00468	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03069	-0.03537	209
WERE	GILL ENERGY CENTER 138KV'	118	-0.00468	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02955	-0.03423	216
WERE	GILL ENERGY CENTER 69KV'	118	-0.00335	WERE	EVANS ENERGY CENTER 345KV'	940	0.03069	-0.03404	217
WERE	GILL ENERGY CENTER 69KV'	118	-0.00335	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02955	-0.0329	225
WERE	EVANS ENERGY CENTER 138KV'	530.8906	0.00059	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03069	-0.0301	246

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS - NORTH AMERICAN PHILIPS JUNCTION (SOUTH) 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57372573741568725687312207WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090270	0.2	19.8
1090310	0.3	19.8
1090609	0.3	19.8
1090612	0.3	19.8
1090612	0.3	19.8
1090662	1.0	19.8
1090674	0.2	19.8
1090680	1.9	19.8
1090695	1.1	19.8
1090817	5.0	19.8
1090964	7.0	19.8
1090965	2.0	19.8

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02957	-0.5342	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03071	-0.53534	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	SMOKEY HILLS 34KV'	25	0.03114	-0.53577	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	LAWRENCE ENERGY CENTER 230KV'	135.5514	0.01929	-0.52392	38
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	CHANUTE 69KV'	34.818	0.00262	-0.50725	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00083	-0.50546	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	CITY OF IOLA 69KV'	14.565	0.00306	-0.50769	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	CITY OF WELLINGTON 69KV'	20	-0.00239	-0.50224	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.95	0.00499	-0.50962	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	EVANS ENERGY CENTER 138KV'	46.5664	0.00061	-0.50524	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50463	WERE	WACO 138KV'	17.93	-0.00412	-0.50051	39
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39925	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02957	-0.42882	46
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39925	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03071	-0.42996	46
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39925	WERE	SMOKEY HILLS 34KV'	25	0.03114	-0.43039	46
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39905	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02957	-0.42862	46
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39905	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03071	-0.42976	46
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39905	WERE	SMOKEY HILLS 34KV'	25	0.03114	-0.43019	46
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39925	WERE	LAWRENCE ENERGY CENTER 230KV'	135.5514	0.01929	-0.41854	47
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39905	WERE	LAWRENCE ENERGY CENTER 230KV'	135.5514	0.01929	-0.41834	47
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39925	WERE	CHANUTE 69KV'	34.818	0.00262	-0.40187	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39925	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00083	-0.40008	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39925	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.95	0.00499	-0.40424	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39925	WERE	EVANS ENERGY CENTER 138KV'	46.5664	0.00061	-0.39986	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39905	WERE	CHANUTE 69KV'	34.818	0.00262	-0.40167	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39905	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00083	-0.39988	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39905	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.95	0.00499	-0.40404	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39905	WERE	EVANS ENERGY CENTER 138KV'	46.5664	0.00061	-0.39966	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39925	WERE	CITY OF WELLINGTON 69KV'	20	-0.00239	-0.39686	50
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39925	WERE	WACO 138KV'	17.93	-0.00412	-0.39513	50
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39905	WERE	CITY OF WELLINGTON 69KV'	20	-0.00239	-0.39666	50
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39905	WERE	WACO 138KV'	17.93	-0.00412	-0.39493	50
WERE	GILL ENERGY CENTER 138KV'	218	-0.00466	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03071	-0.03537	559
WERE	GILL ENERGY CENTER 138KV'	218	-0.00466	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.02957	-0.03423	577
WERE	EVANS ENERGY CENTER 138KV'	746.4336	0.00061	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03071	-0.0301	657

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS - NORTH AMERICAN PHILIPS JUNCTION (SOUTH) 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57372573741568725687312208WP  
 Date Redispatch Needed: Starting 2008 12/1 - 4/1 Until EOC  
 Season Flowgate Identified: 2008 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090310	0.1	19.9
1090325	1.3	19.9
1090327	0.4	19.9
1090609	0.1	19.9
1090612	0.1	19.9
1090612	0.1	19.9
1090662	0.3	19.9
1090674	0.2	19.9
1090680	0.4	19.9
1090695	0.2	19.9

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
	1090817	0.8	19.9						
	1090826	1.3	19.9						
	1090839	1.3	19.9						
	1090841	1.3	19.9						
	1090844	0.4	19.9						
	1090852	0.4	19.9						
	1090853	0.7	19.9						
	1090854	0.3	19.9						
	1090917	0.4	19.9						
	1090919	0.2	19.9						
	1090920	0.8	19.9						
	1090921	0.3	19.9						
	1090922	2.3	19.9						
	1090923	0.6	19.9						
	1090934	1.2	19.9						
	1090935	0.4	19.9						
	1090964	1.1	19.9						
	1090965	0.4	19.9						
	1091052	0.4	19.9						
	1091053	0.7	19.9						
	1091055	1.0	19.9						
	1091057	0.4	19.9						
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0295	-0.53403	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.53519	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	'SMOKEY HILLS 34KV'	25	0.03122	-0.53575	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	'SMOKEYHIL 230 230KV'	30	0.03122	-0.53575	37
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.01926	-0.52379	38
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	'CHANUTE 69KV'	34.903	0.00262	-0.50715	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00077	-0.5053	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	'CITY OF IOLA 69KV'	19.902	0.00308	-0.50761	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.0049	-0.50943	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	'EVANS ENERGY CENTER 138KV'	15.14941	0.00054	-0.50507	39
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00244	-0.50209	40
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.50453	WERE	'WACO 138KV'	17.414	-0.00419	-0.50034	40
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0295	-0.42862	46
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.42978	46
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	'SMOKEY HILLS 34KV'	25	0.03122	-0.43034	46
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	'SMOKEYHIL 230 230KV'	30	0.03122	-0.43034	46
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0295	-0.42823	46
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.42939	46
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	'SMOKEY HILLS 34KV'	25	0.03122	-0.42995	46
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	'SMOKEYHIL 230 230KV'	30	0.03122	-0.42995	46
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.01926	-0.41838	48
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.01926	-0.41799	48
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	'CITY OF IOLA 69KV'	19.902	0.00308	-0.4022	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.0049	-0.40402	49
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.0049	-0.40363	49
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	'CHANUTE 69KV'	34.903	0.00262	-0.40174	50
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00077	-0.39989	50
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00244	-0.39668	50
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.39912	WERE	'WACO 138KV'	17.414	-0.00419	-0.39493	50
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	'CHANUTE 69KV'	34.903	0.00262	-0.40135	50
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00077	-0.3995	50
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	'CITY OF IOLA 69KV'	19.902	0.00308	-0.40181	50
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00244	-0.39629	50
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.39873	WERE	'WACO 138KV'	17.414	-0.00419	-0.39454	50
MIDW	PAWNEE 115KV'	999	-0.21381	MIDW	'KNOLL 3 115 115KV'	71	-0.09075	-0.12306	162
MIDW	RICE 115KV'	999	-0.21381	MIDW	'KNOLL 3 115 115KV'	71	-0.09075	-0.12306	162
WERE	GILL ENERGY CENTER 138KV'	218	-0.00473	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.03539	562
WERE	GILL ENERGY CENTER 138KV'	218	-0.00473	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0295	-0.03423	581
WERE	EVANS ENERGY CENTER 138KV'	931.8506	0.00054	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.03066	-0.03012	660

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS - NORTH AMERICAN PHILIPS JUNCTION (SOUTH) 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57372573741568725687312211WP  
 Date Redispatch Needed: 12/1/11 - 4/1/12  
 Season Flowgate Identified:

Reservation	Relief Amount	Aggregate Relief Amount
1090270	0.1	23.0
1090310	0.1	23.0
1090325	1.0	23.0
1090327	0.4	23.0
1090329	1.4	23.0
1090331	0.4	23.0
1090332	1.8	23.0
1090334	0.4	23.0
1090377	1.2	23.0
1090378	0.3	23.0
1090382	0.7	23.0
1090383	0.2	23.0
1090609	0.1	23.0
1090612	0.1	23.0
1090612	0.1	23.0
1090662	0.3	23.0
1090674	0.2	23.0
1090676	0.2	23.0
1090680	0.4	23.0
1090695	0.2	23.0
1090817	0.7	23.0
1090826	1.0	23.0
1090829	0.4	23.0
1090839	1.0	23.0
1090841	1.0	23.0
1090844	0.3	23.0
1090852	0.3	23.0
1090853	0.6	23.0
1090854	0.3	23.0

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
		0.3							23.0
		0.1							23.0
		0.6							23.0
		0.2							23.0
		1.8							23.0
		0.4							23.0
		0.9							23.0
		0.2							23.0
		0.9							23.0
		0.3							23.0
		0.3							23.0
		0.6							23.0
		0.9							23.0
		0.3							23.0
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	JEFFREY ENERGY CENTER 230KV	470	0.02947	-0.53391	43
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	JEFFREY ENERGY CENTER 345KV	940	0.03064	-0.53508	43
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	SMOKEY HILLS 34KV	25	0.03127	-0.53571	43
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	SMOKEYHILL 230 230KV	24	0.03127	-0.53571	43
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.01914	-0.52358	44
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.02217	-0.52661	44
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	CHANUTE 69KV	56.697	0.00262	-0.50706	45
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	CITY OF IOLA 69KV	16.378	0.00308	-0.50752	45
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	CITY OF AUGUSTA 69KV	20.02	0.0008	-0.50524	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	CITY OF WELLINGTON 69KV	20	-0.00246	-0.50198	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	EVANS ENERGY CENTER 138KV	55	0.00055	-0.50499	46
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.50444	WERE	WACO 138KV	17.96	-0.00418	-0.50026	46
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.39903	WERE	JEFFREY ENERGY CENTER 230KV	470	0.02947	-0.4285	54
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.39903	WERE	JEFFREY ENERGY CENTER 345KV	940	0.03064	-0.42967	54
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.39903	WERE	SMOKEY HILLS 34KV	25	0.03127	-0.43003	54
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.39903	WERE	SMOKEYHILL 230 230KV	24	0.03127	-0.43003	54
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.39864	WERE	JEFFREY ENERGY CENTER 230KV	470	0.02947	-0.42811	54
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.39864	WERE	JEFFREY ENERGY CENTER 345KV	940	0.03064	-0.42928	54
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.39864	WERE	SMOKEY HILLS 34KV	25	0.03127	-0.42991	54
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.39864	WERE	SMOKEYHILL 230 230KV	24	0.03127	-0.42991	54
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.39903	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.01914	-0.41817	55
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.39903	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.02217	-0.4212	55
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.39864	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.01914	-0.41778	55
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.39864	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.02217	-0.42081	55
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.39903	WERE	CHANUTE 69KV	56.697	0.00262	-0.40165	57
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.39864	WERE	CHANUTE 69KV	56.697	0.00262	-0.40126	57
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.39903	WERE	CITY OF AUGUSTA 69KV	20.02	0.0008	-0.39983	58
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.39903	WERE	CITY OF WELLINGTON 69KV	20	-0.00246	-0.39657	58
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.39903	WERE	EVANS ENERGY CENTER 138KV	55	0.00055	-0.39958	58
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.39864	WERE	CITY OF AUGUSTA 69KV	20.02	0.0008	-0.39944	58
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.39864	WERE	CITY OF WELLINGTON 69KV	20	-0.00246	-0.39618	58
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.39864	WERE	EVANS ENERGY CENTER 138KV	55	0.00055	-0.39919	58
WERE	GILL ENERGY CENTER 138KV	218	-0.00472	WERE	JEFFREY ENERGY CENTER 345KV	940	0.03064	-0.03536	652
WERE	EVANS ENERGY CENTER 138KV	892	0.00055	WERE	JEFFREY ENERGY CENTER 345KV	940	0.03064	-0.03009	766

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS JUNCTION (SOUTH) - WEST MCPHERSON 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57374574381568725687312206FA  
 Date Redispatch Needed: 10/1/06 - 12/1/06  
 Season Flowgate Identified: 2006 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount							
1090662	0.6	0.6							
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	ABILENE ENERGY CENTER 115KV	40	0.05759	-0.30033	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	CHANUTE 69KV	39.541	0.00146	-0.2442	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	CITY OF AUGUSTA 69KV	20.02	0.00052	-0.24326	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	CITY OF BURLINGTON 69KV	4.8	0.00278	-0.24552	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	CITY OF ERIE 69KV	22.171	0.00146	-0.2442	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	CITY OF GIRARD 69KV	4.788	0.00151	-0.24425	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	CITY OF IOLA 69KV	16.275	0.0017	-0.24444	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	CITY OF MULVANE 69KV	4.793	-0.00051	-0.24223	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	CITY OF WELLINGTON 69KV	20	-0.00127	-0.24147	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00278	-0.24552	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	EVANS ENERGY CENTER 138KV	305	0.0004	-0.24314	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	GILL ENERGY CENTER 138KV	99.9731	-0.00247	-0.24027	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	JEFFREY ENERGY CENTER 230KV	470	0.01612	-0.25886	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	JEFFREY ENERGY CENTER 345KV	940	0.01673	-0.25947	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.01007	-0.25281	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	LAWRENCE ENERGY CENTER 230KV	231.6643	0.01056	-0.2533	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.01215	-0.25489	2
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.24274	WERE	WACO 138KV	17.957	-0.00218	-0.24056	2
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	ABILENE ENERGY CENTER 115KV	40	0.05759	-0.25427	2
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.19659	WERE	ABILENE ENERGY CENTER 115KV	40	0.05759	-0.25418	2
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	CHANUTE 69KV	39.541	0.00146	-0.19814	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	CITY OF AUGUSTA 69KV	20.02	0.00052	-0.1972	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	CITY OF BURLINGTON 69KV	4.8	0.00278	-0.19946	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	CITY OF ERIE 69KV	22.171	0.00146	-0.19814	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	CITY OF GIRARD 69KV	4.788	0.00151	-0.19819	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	CITY OF IOLA 69KV	16.275	0.0017	-0.19838	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	CITY OF MULVANE 69KV	4.793	-0.00051	-0.19617	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	CITY OF WELLINGTON 69KV	20	-0.00127	-0.19541	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV	19.97	0.00278	-0.19946	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	EVANS ENERGY CENTER 138KV	305	0.0004	-0.19708	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	GILL ENERGY CENTER 138KV	99.9731	-0.00247	-0.19421	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	JEFFREY ENERGY CENTER 230KV	470	0.01612	-0.2128	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	JEFFREY ENERGY CENTER 345KV	940	0.01673	-0.21341	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	LAWRENCE ENERGY CENTER 115KV	60	0.01007	-0.20675	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	LAWRENCE ENERGY CENTER 230KV	231.6643	0.01056	-0.20724	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	TECUMSEH ENERGY CENTER 115KV	108	0.01215	-0.20883	3
WERE	HUTCHINSON ENERGY CENTER 115KV	303	-0.19668	WERE	WACO 138KV	17.957	-0.00218	-0.1945	3
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.19659	WERE	CHANUTE 69KV	39.541	0.00146	-0.19805	3

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00052	-0.19711	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00278	-0.19937	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	CITY OF ERIE 69KV'	22.171	0.00146	-0.19805	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	CITY OF GIRARD 69KV'	4.788	0.00151	-0.19813	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	CITY OF IOLA 69KV'	16.275	0.0017	-0.19829	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	CITY OF MULVANE 69KV'	4.793	-0.00051	-0.19608	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	CITY OF WELLINGTON 69KV'	20	-0.00127	-0.19532	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00278	-0.19937	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	EVANS ENERGY CENTER 138KV'	305	0.0004	-0.19699	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	GILL ENERGY CENTER 138KV'	99.9731	-0.00247	-0.19412	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01612	-0.21271	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01673	-0.21332	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.01007	-0.20666	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	LAWRENCE ENERGY CENTER 230KV'	231.6643	0.01056	-0.20715	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.01215	-0.20874	3
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19659	WERE	WACO 138KV'	17.957	-0.00218	-0.19441	3
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.17163	3
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01612	-0.13016	4
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01673	-0.13077	4
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.01007	-0.12411	4
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	LAWRENCE ENERGY CENTER 230KV'	231.6643	0.01056	-0.1246	4
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.01215	-0.12619	4
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	CHANUTE 69KV'	39.541	0.00146	-0.1155	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00052	-0.11456	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00278	-0.11682	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	CITY OF ERIE 69KV'	22.171	0.00146	-0.1155	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	CITY OF GIRARD 69KV'	4.788	0.00151	-0.11555	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	CITY OF IOLA 69KV'	16.275	0.0017	-0.11574	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	CITY OF MULVANE 69KV'	4.793	-0.00051	-0.11353	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	CITY OF WELLINGTON 69KV'	20	-0.00127	-0.11277	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.97	0.00278	-0.11682	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	EVANS ENERGY CENTER 138KV'	305	0.0004	-0.11444	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	GILL ENERGY CENTER 138KV'	99.9731	-0.00247	-0.11157	5
WERE	ST JOHN 115KV'	7.5	-0.11404	WERE	WACO 138KV'	17.957	-0.00218	-0.11186	5
MIDW	PAWNEE 115KV'	999	-0.11404	MIDW	COLBY 115KV'	10.82559	-0.03465	-0.07939	7
MIDW	RICE 115KV'	999	-0.11404	MIDW	COLBY 115KV'	10.82559	-0.03465	-0.07939	7
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.00127	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05886	9
WERE	GILL ENERGY CENTER 138KV'	73.02685	-0.00247	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.06006	9
WERE	GILL ENERGY CENTER 69KV'	118	-0.00174	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05933	9
MIDW	GREAT BEND PLANT 69KV'	10	-0.09662	MIDW	COLBY 115KV'	10.82559	-0.03465	-0.06197	9
WERE	BROWN COUNTY 115KV'	5.5	0.00325	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05434	10
WERE	CHANUTE 69KV'	48.259	0.00146	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05613	10
WERE	CITY OF AUGUSTA 69KV'	7.320001	0.00052	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05707	10
WERE	CITY OF BURLINGTON 69KV'	7.7	0.00278	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05481	10
WERE	CITY OF ERIE 69KV'	4.358999	0.00146	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05613	10
WERE	CITY OF FREDONIA 69KV'	9.668992	0.00116	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05643	10
WERE	CITY OF GIRARD 69KV'	5.912	0.00151	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05608	10
WERE	CITY OF IOLA 69KV'	21.353	0.0017	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05589	10
WERE	CITY OF MULVANE 69KV'	10.997	-0.00051	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.0581	10
WERE	CITY OF NEODESHA 69KV'	4.5	0.00106	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05653	10
WERE	CITY OF WINFIELD 69KV'	40	-0.00074	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05833	10
WERE	EVANS ENERGY CENTER 138KV'	488	0.0004	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05719	10
WERE	GETTY 69KV'	35	0.00074	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05685	10
WERE	LATHAM1234.0 345KV'	150	0.00135	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05624	10
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00142	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05617	10
WERE	SOUTH SENECA 115KV'	16.7	0.00273	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05486	10
WERE	CITY OF OSAGE CITY 115KV'	8.85	0.00654	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.05105	11
WERE	HOLTON 115KV'	19.8	0.00858	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.04901	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24274	WERE	HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.19668	-0.04606	12
WERE	LAWRENCE ENERGY CENTER 115KV'	78	0.01007	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.04752	12
WERE	LAWRENCE ENERGY CENTER 230KV'	37.33572	0.01056	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.04703	12
WERE	TECUMSEH ENERGY CENTER 115KV'	52.99999	0.01215	WERE	ABILENE ENERGY CENTER 115KV'	40	0.05759	-0.04544	12

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS JUNCTION (SOUTH) - WEST MCPHERSON 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57374574381568725687312207FA  
 Date Redispatch Needed: Starting 2007 10/1 - 12/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Fall Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090612	0.1	0.9
1090612	0.2	0.9
1090662	0.5	0.9
1090674	0.1	0.9

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.275	3
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	CHANUTE 69KV'	56.296	0.0012	-0.23589	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00037	-0.23506	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	CITY OF BURLINGTON 69KV'	4.8	0.0023	-0.23699	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	CITY OF ERIE 69KV'	2.299	0.0012	-0.23589	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	CITY OF FREDONIA 69KV'	5.225	0.00095	-0.23564	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	CITY OF GIRARD 69KV'	1.791	0.00125	-0.23594	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	CITY OF IOLA 69KV'	24.256	0.00141	-0.2361	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	CITY OF MULVANE 69KV'	4.891	-0.0005	-0.23419	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	CITY OF WELLINGTON 69KV'	20	-0.00113	-0.23356	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.0023	-0.23699	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	EVANS ENERGY CENTER 138KV'	125.0474	0.00026	-0.23495	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	HOLTON 115KV'	8.2	0.00712	-0.24181	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01373	-0.24842	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01426	-0.24895	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	LAWRENCE ENERGY CENTER 230KV'	233.8593	0.00895	-0.24364	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	'SMOKEY HILLS 34KV'	25	0.01445	-0.24914	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	'SOUTH SENECA 115KV'	8.5	0.00166	-0.23635	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	'TECUMSEH ENERGY CENTER 115KV'	88	0.01033	-0.24502	4
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	'WACO 138KV'	17.946	-0.00194	-0.23275	4
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.226	4
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01373	-0.19942	4
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01426	-0.19995	4
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	'SMOKEY HILLS 34KV'	25	0.01445	-0.20014	4

Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	TECUMSEH ENERGY CENTER 115KV'	88	0.01033	-0.19602	4
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.22591	4
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01373	-0.19933	4
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01426	-0.19986	4
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	'SMOKEY HILLS 34KV'	25	0.01445	-0.20005	4
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	TECUMSEH ENERGY CENTER 115KV'	88	0.01033	-0.19593	4
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	CHANUTE 69KV'	56.296	0.0012	-0.18689	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00037	-0.18606	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	CITY OF BURLINGTON 69KV'	4.8	0.0023	-0.18799	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	CITY OF ERIE 69KV'	2.299	0.0012	-0.18689	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	CITY OF FREDONIA 69KV'	5.225	0.00095	-0.18664	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	CITY OF GIRARD 69KV'	1.791	0.00125	-0.18694	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	CITY OF IOLA 69KV'	24.256	0.00141	-0.1871	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	CITY OF MULVANE 69KV'	4.891	-0.0005	-0.18519	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	CITY OF WELLINGTON 69KV'	20	-0.00113	-0.18456	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.0023	-0.18799	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	'EVANS ENERGY CENTER 138KV'	125.0474	0.00026	-0.18595	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	HOLTON 115KV'	8.2	0.00712	-0.19281	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	LAWRENCE ENERGY CENTER 230KV'	233.8593	0.00895	-0.19464	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	'SOUTH SENECA 115KV'	8.5	0.00166	-0.18735	5
WERE	HUTCHINSON ENERGY CENTER 115KV'	343	-0.18569	WERE	'WACO 138KV'	17.946	-0.00194	-0.18375	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	CHANUTE 69KV'	56.296	0.0012	-0.18689	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00037	-0.18597	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	CITY OF BURLINGTON 69KV'	4.8	0.0023	-0.18799	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	CITY OF ERIE 69KV'	2.299	0.0012	-0.18689	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	CITY OF FREDONIA 69KV'	5.225	0.00095	-0.18655	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	CITY OF GIRARD 69KV'	1.791	0.00125	-0.18685	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	CITY OF IOLA 69KV'	24.256	0.00141	-0.18701	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	CITY OF MULVANE 69KV'	4.891	-0.0005	-0.18519	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	CITY OF WELLINGTON 69KV'	20	-0.00113	-0.18447	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.0023	-0.18799	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	'EVANS ENERGY CENTER 138KV'	125.0474	0.00026	-0.18586	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	HOLTON 115KV'	8.2	0.00712	-0.19272	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	LAWRENCE ENERGY CENTER 230KV'	233.8593	0.00895	-0.19455	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	'SOUTH SENECA 115KV'	8.5	0.00166	-0.18726	5
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.1856	WERE	'WACO 138KV'	17.946	-0.00194	-0.18366	5
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.1398	8
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	HOLTON 115KV'	8.2	0.00712	-0.10661	8
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01373	-0.11322	8
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01426	-0.11375	8
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	LAWRENCE ENERGY CENTER 230KV'	233.8593	0.00895	-0.10844	8
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	'SMOKEY HILLS 34KV'	25	0.01445	-0.11394	8
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	TECUMSEH ENERGY CENTER 115KV'	88	0.01033	-0.10982	8
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	CHANUTE 69KV'	56.296	0.0012	-0.10689	9
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00037	-0.09986	9
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	CITY OF BURLINGTON 69KV'	4.8	0.0023	-0.10179	9
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	CITY OF FREDONIA 69KV'	5.225	0.00095	-0.10044	9
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	CITY OF IOLA 69KV'	24.256	0.00141	-0.10099	9
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	CITY OF MULVANE 69KV'	4.891	-0.0005	-0.09899	9
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	CITY OF WELLINGTON 69KV'	20	-0.00113	-0.09836	9
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.0023	-0.10179	9
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	'EVANS ENERGY CENTER 138KV'	125.0474	0.00026	-0.09975	9
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	'SOUTH SENECA 115KV'	8.5	0.00166	-0.10115	9
WERE	ST JOHN 115KV'	7.5	-0.09949	WERE	'WACO 138KV'	17.946	-0.00194	-0.09755	9
MIDW	PAWNEE 115KV'	999	-0.09949	MIDW	COLBY 115KV'	10.19004	-0.03448	-0.06501	13
MIDW	RICE 115KV'	999	-0.09949	MIDW	COLBY 115KV'	10.19004	-0.03448	-0.06501	13
WEPL	A. M. MULLERGEN GENERATOR 115KV'	63	-0.08162	WEPL	HARPER 138KV'	15.41	-0.02712	-0.0545	16
WEPL	NORTH WEST GREAT BEND 115KV'	14.24	-0.08162	WEPL	HARPER 138KV'	15.41	-0.02712	-0.0545	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23469	WERE	HUTCHINSON ENERGY CENTER 115KV'	40	-0.18569	-0.049	18
MIDW	GREAT BEND PLANT 69KV'	10	-0.08369	MIDW	COLBY 115KV'	10.19004	-0.03448	-0.04921	18
WERE	CITY OF MULVANE 69KV'	10.899	-0.0005	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.04081	21
WERE	CITY OF WELLINGTON 69KV'	23.5	-0.00113	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.04144	21
WERE	CITY OF WINFIELD 69KV'	40	-0.00068	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.04097	21
WERE	GILL ENERGY CENTER 138KV'	218	-0.00219	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.0425	21
WERE	GILL ENERGY CENTER 69KV'	118	-0.00157	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.04188	21
WERE	CHANUTE 69KV'	31.504	0.0012	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.03911	22
WERE	CITY OF ERIE 69KV'	24.231	0.0012	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.03911	22
WERE	CITY OF GIRARD 69KV'	8.909	0.00125	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.03906	22
WERE	EVANS ENERGY CENTER 138KV'	667.9526	0.00026	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.04005	22
WERE	GETTY 69KV'	35	0.00055	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.03976	22
WERE	LATHAM1234.0 345KV'	150	0.00109	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.03922	22
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00117	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.03914	22
WERE	CITY OF BURLINGTON 69KV'	7.7	0.0023	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.03801	23
WERE	CITY OF IOLA 69KV'	13.372	0.00141	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.0389	23
WERE	SOUTH SENECA 115KV'	8.2	0.00166	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.03865	23
WERE	CITY OF OSAGE CITY 115KV'	8.85	0.00508	WERE	CLAY CENTER JUNCTION 115KV'	8.584003	0.04031	-0.03523	25

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS JUNCTION (SOUTH) - WEST MCPHERSON 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57374574381568725687312207G  
 Date Redispatch Needed: Starting 2007 4/1 - 6/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Spring Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090662	0.3	3.3
1090674	0.1	3.3
1090808	0.1	3.3
1090964	2.2	3.3
1090965	0.6	3.3

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	'ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.30005	11
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	CHANUTE 69KV'	40.39	0.00149	-0.24394	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00057	-0.24302	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	CITY OF BURLINGTON 69KV'	4.8	0.00281	-0.24526	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	CITY OF FREDONIA 69KV'	5.225	0.00119	-0.24364	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	CITY OF IOLA 69KV'	17.08	0.00172	-0.24417	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	20.09	0.00281	-0.24526	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	HOLTON 115KV'	12.2	0.00862	-0.25107	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01615	-0.2586	13

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01674	-0.25919	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.01004	-0.25249	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	LAWRENCE ENERGY CENTER 230KV'	233.1803	0.01055	-0.253	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	TECUMSEH ENERGY CENTER 115KV'	68.00001	0.01215	-0.2546	13
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.25386	13
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.25377	13
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	CITY OF MULLVANE 69KV'	4.922	-0.00044	-0.24201	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	CITY OF WELLINGTON 69KV'	27.198	-0.00121	-0.24124	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	EVANS ENERGY CENTER 138KV'	305	0.00045	-0.2429	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	GILL ENERGY CENTER 138KV'	77	-0.00238	-0.24007	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	WACO 138KV'	18	-0.00209	-0.24036	14
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01615	-0.21241	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01674	-0.213	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01615	-0.21232	15
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01674	-0.21291	15
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	20.09	0.00281	-0.19907	16
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	HOLTON 115KV'	12.2	0.00862	-0.20488	16
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.01004	-0.2063	16
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	LAWRENCE ENERGY CENTER 230KV'	233.1803	0.01055	-0.20681	16
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	TECUMSEH ENERGY CENTER 115KV'	68.00001	0.01215	-0.20841	16
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	20.09	0.00281	-0.19898	16
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	HOLTON 115KV'	12.2	0.00862	-0.20479	16
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.01004	-0.20621	16
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	LAWRENCE ENERGY CENTER 230KV'	233.1803	0.01055	-0.20672	16
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	TECUMSEH ENERGY CENTER 115KV'	68.00001	0.01215	-0.20832	16
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	CHANUTE 69KV'	40.39	0.00149	-0.19775	17
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00057	-0.19683	17
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	CITY OF IOLA 69KV'	17.08	0.00172	-0.19798	17
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	CITY OF WELLINGTON 69KV'	27.198	-0.00121	-0.19505	17
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	EVANS ENERGY CENTER 138KV'	305	0.00045	-0.19671	17
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	GILL ENERGY CENTER 138KV'	77	-0.00238	-0.19388	17
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.19626	WERE	WACO 138KV'	18	-0.00209	-0.19417	17
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	CHANUTE 69KV'	40.39	0.00149	-0.19766	17
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00057	-0.19674	17
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	CITY OF IOLA 69KV'	17.08	0.00172	-0.19789	17
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	CITY OF WELLINGTON 69KV'	27.198	-0.00121	-0.19496	17
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	EVANS ENERGY CENTER 138KV'	305	0.00045	-0.19662	17
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	GILL ENERGY CENTER 138KV'	77	-0.00238	-0.19379	17
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.19617	WERE	WACO 138KV'	18	-0.00209	-0.19408	17
WERE	ST JOHN 115KV'	7.5	-0.11208	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.16968	19
WERE	GILL ENERGY CENTER 138KV'	118	-0.00238	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.05998	55
WERE	GILL ENERGY CENTER 69KV'	118	-0.00166	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.05926	55
WERE	CITY OF WINFIELD 69KV'	40	-0.00069	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.05829	56
WERE	EVANS ENERGY CENTER 138KV'	488	0.00045	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.05715	57
WERE	CHANUTE 69KV'	47.41	0.00149	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.05611	58
WERE	CITY OF ERIE 69KV'	24.229	0.00149	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.05611	58
WERE	GETTY 69KV'	35	0.00079	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.05681	58
WERE	LATHAM1234.0 345KV'	150	0.00139	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.05621	58
WERE	NEOSHO ENERGY CENTER 138KV'	67	0.00144	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.05616	58
WERE	CITY OF IOLA 69KV'	20.548	0.00172	WERE	ABILENE ENERGY CENTER 115KV'	21.88843	0.0576	-0.05588	59
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.24245	WERE	GRAY COUNTY ENERGY CENTER 115KV'	80.00001	-0.19626	-0.04619	71
WEPL	A. M. MULLERGREIN GENERATOR 115KV'	42.28732	-0.09786	WEPL	GRAY COUNTY WIND FARM 115KV'	73	-0.06325	-0.03461	95
WEPL	A. M. MULLERGREIN GENERATOR 115KV'	42.28732	-0.09786	WEPL	JUDSON LARGE 115KV'	48.12384	-0.06317	-0.03469	95

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS JUNCTION (SOUTH) - WEST MCPHERSON 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57374574381568725687312207SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1090662	0.8	3.9
1090674	0.1	3.9
1090817	1.1	3.9
1090964	1.5	3.9
1090965	0.4	3.9

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	CLAY CENTER JUNCTION 115KV'	17.01001	0.04033	-0.27501	14
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	CHANUTE 69KV'	46.617	0.00121	-0.23589	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	CITY OF BURLINGTON 69KV'	7.8	0.00231	-0.23699	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	CITY OF ERIE 69KV'	22.264	0.00121	-0.23589	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	CITY OF IOLA 69KV'	19.865	0.00142	-0.2361	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00231	-0.23699	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	HOLTON 115KV'	12.2	0.00714	-0.24182	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01374	-0.24842	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01427	-0.24895	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.00852	-0.2432	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	LAWRENCE ENERGY CENTER 230KV'	235.9986	0.00896	-0.24364	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	SOUTH SENeca 115KV'	8.5	0.00169	-0.23637	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.01035	-0.24503	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00038	-0.23506	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	CITY OF MULLVANE 69KV'	6.189	-0.00049	-0.23419	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.00112	-0.23356	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	EVANS ENERGY CENTER 138KV'	262.1094	0.00227	-0.23495	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	GILL ENERGY CENTER 138KV'	77	-0.00218	-0.2325	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	WACO 138KV'	17.947	-0.00193	-0.23275	17
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	CLAY CENTER JUNCTION 115KV'	17.01001	0.04033	-0.22601	17
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	CLAY CENTER JUNCTION 115KV'	17.01001	0.04033	-0.22592	17
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01374	-0.19942	19
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01427	-0.19995	19
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01374	-0.19933	19
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01427	-0.19986	19
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	HOLTON 115KV'	12.2	0.00714	-0.19282	20
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.00852	-0.1942	20
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	LAWRENCE ENERGY CENTER 230KV'	235.9986	0.00896	-0.19464	20
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.01035	-0.19603	20
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	HOLTON 115KV'	12.2	0.00714	-0.19273	20
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	LAWRENCE ENERGY CENTER 115KV'	60	0.00852	-0.19411	20
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	LAWRENCE ENERGY CENTER 230KV'	235.9986	0.00896	-0.19455	20

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	TECUMSEH ENERGY CENTER 115KV'	108	0.01035	-0.19594	20
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	CHANUTE 69KV'	46.617	0.00121	-0.18689	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00038	-0.18606	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	CITY OF BURLINGTON 69KV'	7.8	0.00231	-0.18799	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	CITY OF ERIE 69KV'	22.264	0.00121	-0.18689	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	CITY OF IOLA 69KV'	19.865	0.00142	-0.1871	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.00112	-0.18456	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00231	-0.18799	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	EVANS ENERGY CENTER 138KV'	262.1094	0.00027	-0.18595	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	GILL ENERGY CENTER 138KV'	77	-0.00218	-0.1835	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	SOUTH SENECA 115KV'	8.5	0.00169	-0.18737	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	303	-0.18568	WERE	WACO 138KV'	17.947	-0.00193	-0.18375	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	CHANUTE 69KV'	46.617	0.00121	-0.1868	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00038	-0.18597	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	CITY OF BURLINGTON 69KV'	7.8	0.00231	-0.1879	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	CITY OF IOLA 69KV'	22.264	0.00121	-0.1868	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	CITY OF IOLA 69KV'	19.865	0.00142	-0.18701	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	CITY OF WELLINGTON 69KV'	41.45	-0.00112	-0.18447	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.96	0.00231	-0.1879	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	EVANS ENERGY CENTER 138KV'	262.1094	0.00027	-0.18586	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	GILL ENERGY CENTER 138KV'	77	-0.00218	-0.18341	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	SOUTH SENECA 115KV'	8.5	0.00169	-0.18728	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18559	WERE	WACO 138KV'	17.947	-0.00193	-0.18366	21
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23468	WERE	HUTCHINSON ENERGY CENTER 115KV'	80.00001	-0.18568	-0.049	79

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS JUNCTION (SOUTH) - WEST MCPHERSON 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57374574381568725687312207WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090612	0.1	7.4
1090612	0.2	7.4
1090662	0.5	7.4
1090674	0.1	7.4
1090817	2.3	7.4
1090964	3.3	7.4
1090965	0.9	7.4

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01375	-0.24842	30
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01428	-0.24895	30
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	LAWRENCE ENERGY CENTER 230KV'	135.5514	0.00897	-0.24364	30
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	SMOKEY HILLS 34KV'	25	0.01448	-0.24915	30
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	CHANUTE 69KV'	34.818	0.00122	-0.23589	31
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	CITY OF IOLA 69KV'	14.565	0.00142	-0.23609	31
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.95	0.00232	-0.23699	31
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00039	-0.23506	32
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	CITY OF WELLINGTON 69KV'	20	-0.00111	-0.23356	32
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	EVANS ENERGY CENTER 138KV'	46.5664	0.00028	-0.23495	32
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23467	WERE	WACO 138KV'	17.93	-0.00192	-0.23275	32
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01375	-0.19941	37
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01428	-0.19904	37
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	SMOKEY HILLS 34KV'	25	0.01448	-0.20014	37
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01375	-0.19932	37
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01428	-0.19985	37
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	SMOKEY HILLS 34KV'	25	0.01448	-0.20005	37
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	LAWRENCE ENERGY CENTER 230KV'	135.5514	0.00897	-0.19463	38
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	LAWRENCE ENERGY CENTER 230KV'	135.5514	0.00897	-0.19454	38
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.95	0.00232	-0.18798	39
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.95	0.00232	-0.18789	39
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	CHANUTE 69KV'	34.818	0.00122	-0.18688	40
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00039	-0.18605	40
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	CITY OF IOLA 69KV'	14.565	0.00142	-0.18708	40
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	CITY OF WELLINGTON 69KV'	20	-0.00111	-0.18455	40
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	EVANS ENERGY CENTER 138KV'	46.5664	0.00028	-0.18594	40
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18566	WERE	WACO 138KV'	17.93	-0.00192	-0.18374	40
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	CHANUTE 69KV'	34.818	0.00122	-0.18679	40
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00039	-0.18596	40
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	CITY OF IOLA 69KV'	14.565	0.00142	-0.18699	40
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	CITY OF WELLINGTON 69KV'	20	-0.00111	-0.18446	40
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	EVANS ENERGY CENTER 138KV'	46.5664	0.00028	-0.18585	40
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18557	WERE	WACO 138KV'	17.93	-0.00192	-0.18365	40

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS JUNCTION (SOUTH) - WEST MCPHERSON 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57374574381568725687312208WP  
 Date Redispatch Needed: Starting 2008 12/1 - 4/1 Until EOC  
 Season Flowgate Identified: 2008 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090325	0.9	14.3
1090327	0.3	14.3
1090612	0.1	14.3
1090612	0.1	14.3
1090662	0.2	14.3
1090674	0.1	14.3
1090817	0.7	14.3
1090826	1.0	14.3
1090839	1.0	14.3
1090841	1.0	14.3
1090844	0.3	14.3
1090852	0.3	14.3



**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1090853		0.5							14.3
1090854		0.2							14.3
1090917		0.3							14.3
1090919		0.1							14.3
1090920		0.6							14.3
1090921		0.2							14.3
1090922		1.9							14.3
1090923		0.5							14.3
1090934		1.0							14.3
1090935		0.2							14.3
1090964		0.9							14.3
1090965		0.3							14.3
1091052		0.3							14.3
1091053		0.5							14.3
1091055		0.8							14.3
1091057		0.3							14.3
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23462	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01372	-0.24834	57
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23462	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01426	-0.24888	57
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23462	WERE	'SMOKEY HILLS 34KV'	25	0.01452	-0.24914	57
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23462	WERE	'SMOKEYHIL 230 230KV'	30	0.01452	-0.24914	57
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23462	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.00896	-0.24358	59
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23462	WERE	'CHANUTE 69KV'	34.903	0.00122	-0.23584	61
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18561	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01426	-0.19987	71
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18561	WERE	'SMOKEY HILLS 34KV'	25	0.01452	-0.20013	71
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18561	WERE	'SMOKEYHIL 230 230KV'	30	0.01452	-0.20013	71
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18542	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01426	-0.19968	71
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18542	WERE	'SMOKEY HILLS 34KV'	25	0.01452	-0.19994	71
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18542	WERE	'SMOKEYHIL 230 230KV'	30	0.01452	-0.19994	71
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18561	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01372	-0.19933	72
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18542	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01372	-0.19914	72
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18561	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.00896	-0.19457	73
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18542	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.00896	-0.19438	73
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.18561	WERE	'CHANUTE 69KV'	34.903	0.00122	-0.18683	76
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18542	WERE	'CHANUTE 69KV'	34.903	0.00122	-0.18664	76

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS JUNCTION (SOUTH) - WEST MCPHERSON 115KV CKT 1  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57374574381568725687312211WP  
 Date Redispatch Needed: 12/1/11 - 4/1/12  
 Season Flowgate Identified:

Reservation	Relief Amount	Aggregate Relief Amount	Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
1090325	0.7	15.6	WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23458	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0137	-0.24828	63
1090327	0.2	15.6	WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23458	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01425	-0.24883	63
1090329	0.9	15.6	WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23458	WERE	'SMOKEY HILLS 34KV'	25	0.01454	-0.24912	63
1090331	0.3	15.6	WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23458	WERE	'SMOKEYHIL 230 230KV'	24	0.01454	-0.24912	63
1090332	1.3	15.6	WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23458	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.24348	64
1090334	0.3	15.6	WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23458	WERE	'TECUMSEH ENERGY CENTER 115KV'	43.36816	0.01031	-0.24489	64
1090377	0.9	15.6	WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23458	WERE	'CHANUTE 69KV'	56.697	0.00122	-0.2358	66
1090378	0.2	15.6	WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.23458	WERE	'EVANS ENERGY CENTER 138KV'	55	0.00225	-0.23483	66
1090382	0.5	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0137	-0.19926	78
1090383	0.2	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01425	-0.19981	78
1090612	0.1	15.6	WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.0137	-0.19908	78
1090612	0.1	15.6	WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01425	-0.19963	78
1090662	0.1	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19446	80
1090674	0.1	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'TECUMSEH ENERGY CENTER 115KV'	43.36816	0.01031	-0.19587	80
1090676	0.1	15.6	WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090817	0.5	15.6	WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090826	0.8	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090829	0.3	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090839	0.8	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090841	0.8	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090844	0.2	15.6	WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090852	0.2	15.6	WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090853	0.4	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090854	0.1	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090917	0.2	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090919	0.1	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090920	0.4	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090921	0.1	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090922	1.3	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090923	0.3	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090934	0.6	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090935	0.2	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090964	0.7	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1090965	0.2	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1091052	0.2	15.6	WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1091053	0.4	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1091055	0.6	15.6	WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80
1091057	0.2	15.6	WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	'LAWRENCE ENERGY CENTER 230KV'	174.0622	0.0089	-0.19428	80

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	TECUMSEH ENERGY CENTER 115KV'	43.36816	0.01031	-0.19569	80
WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	CHANUTE 69KV'	56.697	0.00122	-0.18678	84
WERE	HUTCHINSON ENERGY CENTER 115KV'	383	-0.18556	WERE	EVANS ENERGY CENTER 138KV'	55	0.00025	-0.18581	84
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	CHANUTE 69KV'	56.697	0.00122	-0.1866	84
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.18538	WERE	EVANS ENERGY CENTER 138KV'	55	0.00025	-0.18563	84

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS JUNCTION (SOUTH) - WEST MCPHERSON 115KV CKT 2  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57374574382568725687312207WP  
 Date Redispatch Needed: 12/1/07 - 4/1/08  
 Season Flowgate Identified: 2007 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090612	0.2	6.2
1090612	0.1	6.2
1090662	0.4	6.2
1090674	0.1	6.2
1090817	1.9	6.2
1090964	2.7	6.2
1090965	0.8	6.2

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	CLAY CENTER JUNCTION 115KV'	8.375996	0.0464	-0.31636	20
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	HOLTON 115KV'	8.2	0.00822	-0.27818	22
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01582	-0.28578	22
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01643	-0.28639	22
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	LAWRENCE ENERGY CENTER 230KV'	135.5514	0.01032	-0.28028	22
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	'SMOKEY HILLS 34KV'	25	0.01666	-0.28662	22
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	CHANUTE 69KV'	34.818	0.0014	-0.27136	23
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00044	-0.2704	23
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	CITY OF IOLA 69KV'	14.565	0.00164	-0.2716	23
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	CITY OF WELLINGTON 69KV'	20	-0.00128	-0.26868	23
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.95	0.00267	-0.27263	23
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	EVANS ENERGY CENTER 138KV'	46.5664	0.00032	-0.27028	23
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	'SOUTH SENECA 115KV'	8.5	0.00195	-0.27191	23
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26998	WERE	'WACO 138KV'	17.93	-0.00221	-0.26775	23
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	CLAY CENTER JUNCTION 115KV'	8.375996	0.0464	-0.25998	24
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	CLAY CENTER JUNCTION 115KV'	8.375996	0.0464	-0.25988	24
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01582	-0.2294	27
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01643	-0.23001	27
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	'SMOKEY HILLS 34KV'	25	0.01666	-0.23024	27
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	JEFFREY ENERGY CENTER 230KV'	470	0.01582	-0.2293	27
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	JEFFREY ENERGY CENTER 345KV'	940	0.01643	-0.22991	27
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	'SMOKEY HILLS 34KV'	25	0.01666	-0.23014	27
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	LAWRENCE ENERGY CENTER 230KV'	135.5514	0.01032	-0.2239	28
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	LAWRENCE ENERGY CENTER 230KV'	135.5514	0.01032	-0.2238	28
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	CHANUTE 69KV'	34.818	0.0014	-0.21498	29
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00044	-0.21402	29
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	CITY OF IOLA 69KV'	14.565	0.00164	-0.21522	29
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	CITY OF WELLINGTON 69KV'	20	-0.00128	-0.2123	29
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.95	0.00267	-0.21625	29
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	EVANS ENERGY CENTER 138KV'	46.5664	0.00032	-0.2139	29
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21358	WERE	'WACO 138KV'	17.93	-0.00221	-0.21137	29
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	CHANUTE 69KV'	34.818	0.0014	-0.21488	29
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	CITY OF AUGUSTA 69KV'	20.02	0.00044	-0.21392	29
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	CITY OF IOLA 69KV'	14.565	0.00164	-0.21512	29
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	CITY OF WELLINGTON 69KV'	20	-0.00128	-0.2122	29
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	COFFEY COUNTY NO. 2 SHARPE 69KV'	19.95	0.00267	-0.21615	29
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	EVANS ENERGY CENTER 138KV'	46.5664	0.00032	-0.2138	29
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21348	WERE	'WACO 138KV'	17.93	-0.00221	-0.21127	29
WEPL	A. M. MULLEREGREN GENERATOR 115KV'	63	-0.09388	WEPL	'GRAY COUNTY WIND FARM 115KV'	60	-0.0591	-0.03476	178

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS JUNCTION (SOUTH) - WEST MCPHERSON 115KV CKT 2  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57374574382568725687312208WP  
 Date Redispatch Needed: Starting 2008 12/1 - 4/1 Until EOC  
 Season Flowgate Identified: 2008 Winter Peak

Reservation	Relief Amount	Aggregate Relief Amount
1090325	0.3	4.7
1090327	0.1	4.7
1090612	0.1	4.7
1090612	0.1	4.7
1090662	0.1	4.7
1090674	0.1	4.7
1090817	0.2	4.7
1090826	0.3	4.7
1090839	0.3	4.7
1090841	0.3	4.7
1090844	0.1	4.7
1090852	0.1	4.7
1090853	0.2	4.7
1090854	0.1	4.7
1090917	0.1	4.7
1090919	0.1	4.7
1090920	0.2	4.7
1090921	0.1	4.7
1090922	0.6	4.7
1090923	0.2	4.7
1090934	0.3	4.7
1090935	0.1	4.7
1090964	0.3	4.7
1090965	0.1	4.7
1091052	0.1	4.7

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
	1091053	0.2	4.7						
	1091055	0.2	4.7						
	1091057	0.1	4.7						
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'CLAY CENTER JUNCTION 115KV'	10.632	0.04638	-0.31629	15
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.01578	-0.28569	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.0164	-0.28631	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'SMOKEY HILLS 34KV'	25	0.0167	-0.28661	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'SMOKEYHIL 230 230KV'	30	0.0167	-0.28661	16
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'CHANUTE 69KV'	34.903	0.0014	-0.27131	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00041	-0.27032	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'CITY OF IOLA 69KV'	19.902	0.00165	-0.27156	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.00262	-0.27253	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'EVANS ENERGY CENTER 138KV'	15.14941	0.00029	-0.27022	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'HOLTON 115KV'	8.2	0.00818	-0.27809	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.0103	-0.28021	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'SOUTH SENECA 115KV'	8.5	0.00184	-0.27175	17
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00131	-0.2686	18
WERE	BPU - CITY OF MCPHERSON 115KV'	259	-0.26991	WERE	'WACO 138KV'	17.414	-0.00224	-0.26767	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'CLAY CENTER JUNCTION 115KV'	10.632	0.04638	-0.2599	18
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'CLAY CENTER JUNCTION 115KV'	10.632	0.04638	-0.25969	18
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.0164	-0.22992	20
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'SMOKEY HILLS 34KV'	25	0.0167	-0.23022	20
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'SMOKEYHIL 230 230KV'	30	0.0167	-0.23022	20
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'JEFFREY ENERGY CENTER 345KV'	940	0.0164	-0.22971	20
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'SMOKEY HILLS 34KV'	25	0.0167	-0.23001	20
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'SMOKEYHIL 230 230KV'	30	0.0167	-0.23001	20
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'HOLTON 115KV'	8.2	0.00818	-0.2217	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.01578	-0.2293	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.0103	-0.22382	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'HOLTON 115KV'	8.2	0.00818	-0.22149	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'JEFFREY ENERGY CENTER 230KV'	470	0.01578	-0.22909	21
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'LAWRENCE ENERGY CENTER 230KV'	136.1463	0.0103	-0.22361	21
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'CHANUTE 69KV'	34.903	0.0014	-0.21492	22
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00041	-0.21393	22
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'CITY OF IOLA 69KV'	19.902	0.00165	-0.21517	22
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00131	-0.21221	22
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.00262	-0.21614	22
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'EVANS ENERGY CENTER 138KV'	15.14941	0.00029	-0.21381	22
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'SOUTH SENECA 115KV'	8.5	0.00184	-0.21536	22
WERE	HUTCHINSON ENERGY CENTER 115KV'	423	-0.21352	WERE	'WACO 138KV'	17.414	-0.00224	-0.21128	22
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'CHANUTE 69KV'	34.903	0.0014	-0.21471	22
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'CITY OF AUGUSTA 69KV'	20.02	0.00041	-0.21372	22
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'CITY OF IOLA 69KV'	19.902	0.00165	-0.21496	22
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'CITY OF WELLINGTON 69KV'	20	-0.00131	-0.212	22
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'COFFEY COUNTY NO. 2 SHARPE 69KV'	19.61	0.00262	-0.21593	22
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'EVANS ENERGY CENTER 138KV'	15.14941	0.00029	-0.2136	22
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'SOUTH SENECA 115KV'	8.5	0.00184	-0.21515	22
WERE	HUTCHINSON ENERGY CENTER 69KV'	67	-0.21331	WERE	'WACO 138KV'	17.414	-0.00224	-0.21107	22
MIDW	PAWNEE 115KV'	999	-0.11438	MIDW	'KNOLL 3 115 115KV'	71	-0.04855	-0.06583	72
MIDW	RICE 115KV'	999	-0.11438	MIDW	'KNOLL 3 115 115KV'	71	-0.04855	-0.06583	72
WEPL	A. M. MULLERGEN GENERATOR 115KV'	63	-0.09374	WEPL	'GRAY COUNTY WIND FARM 115KV'	60	-0.05965	-0.03409	138

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WICHITA - RENO 345KV  
 Limiting Facility: NORTH AMERICAN PHILIPS JUNCTION (SOUTH) - WEST MCPHERSON 115KV CKT 2  
 Direction: From->To  
 Line Outage: EAST MCPHERSON - SUMMIT 230KV CKT 1  
 Flowgate: 57374574382568725687312211WP  
 Date Redispatch Needed: 12/1/11 - 4/1/12  
 Season Flowgate Identified:

Reservation	Relief Amount	Aggregate Relief Amount
1090325	0.3	8.5
1090327	0.1	8.5
1090329	0.4	8.5
1090331	0.1	8.5
1090332	0.6	8.5
1090334	0.2	8.5
1090377	0.5	8.5
1090378	0.2	8.5
1090382	0.3	8.5
1090383	0.1	8.5
1090612	0.1	8.5
1090612	0.1	8.5
1090662	0.1	8.5
1090674	0.1	8.5
1090676	0.1	8.5
1090817	0.2	8.5
1090826	0.4	8.5
1090829	0.2	8.5
1090839	0.4	8.5
1090841	0.4	8.5
1090844	0.2	8.5
1090852	0.2	8.5
1090853	0.2	8.5
1090854	0.1	8.5
1090917	0.1	8.5
1090919	0.1	8.5
1090920	0.2	8.5
1090921	0.1	8.5
1090922	0.7	8.5
1090923	0.2	8.5
1090934	0.3	8.5
1090935	0.1	8.5
1090964	0.3	8.5
1090965	0.2	8.5
1091052	0.2	8.5
1091053	0.2	8.5
1091055	0.3	8.5
1091057	0.2	8.5

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	JEFFREY ENERGY CENTER 230KV	470	0.01577	-0.28563	30
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	JEFFREY ENERGY CENTER 345KV	940	0.01639	-0.28625	30
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.01024	-0.2801	30
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	SMOKEY HILLS 34KV	25	0.01673	-0.28659	30
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	SMOKYHILL 230 230KV	24	0.01673	-0.28659	30
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.01186	-0.28172	30
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	CHANUTE 69KV	56.697	0.0014	-0.27126	31
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	CITY OF AUGUSTA 69KV	20.02	0.00043	-0.27029	31
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	CITY OF IOLA 69KV	16.378	0.00165	-0.27151	31
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	EVANS ENERGY CENTER 138KV	55	0.00029	-0.27015	31
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	CITY OF WELLINGTON 69KV	20	-0.00132	-0.26854	32
WERE	BPU - CITY OF MCPHERSON 115KV	259	-0.26986	WERE	WACO 138KV	17.96	-0.00224	-0.26762	32
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	JEFFREY ENERGY CENTER 230KV	470	0.01577	-0.22924	37
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	JEFFREY ENERGY CENTER 345KV	940	0.01639	-0.22986	37
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	SMOKEY HILLS 34KV	25	0.01673	-0.2302	37
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	SMOKYHILL 230 230KV	24	0.01673	-0.2302	37
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	JEFFREY ENERGY CENTER 230KV	470	0.01577	-0.22903	37
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	JEFFREY ENERGY CENTER 345KV	940	0.01639	-0.22965	37
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	SMOKEY HILLS 34KV	25	0.01673	-0.22999	37
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	SMOKYHILL 230 230KV	24	0.01673	-0.22999	37
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.01024	-0.22371	38
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.01186	-0.22533	38
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	LAWRENCE ENERGY CENTER 230KV	174.0622	0.01024	-0.2235	38
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	TECUMSEH ENERGY CENTER 115KV	43.36816	0.01186	-0.22512	38
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	CHANUTE 69KV	56.697	0.0014	-0.21487	39
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	CITY OF IOLA 69KV	16.378	0.00165	-0.21512	39
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	CHANUTE 69KV	56.697	0.0014	-0.21466	39
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	CITY OF IOLA 69KV	16.378	0.00165	-0.21491	39
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	CITY OF AUGUSTA 69KV	20.02	0.00043	-0.2139	40
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	CITY OF WELLINGTON 69KV	20	-0.00132	-0.21215	40
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	EVANS ENERGY CENTER 138KV	55	0.00029	-0.21376	40
WERE	HUTCHINSON ENERGY CENTER 115KV	383	-0.21347	WERE	WACO 138KV	17.96	-0.00224	-0.21123	40
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	CITY OF AUGUSTA 69KV	20.02	0.00043	-0.21369	40
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	CITY OF WELLINGTON 69KV	20	-0.00132	-0.21194	40
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	EVANS ENERGY CENTER 138KV	55	0.00029	-0.21355	40
WERE	HUTCHINSON ENERGY CENTER 69KV	67	-0.21326	WERE	WACO 138KV	17.96	-0.00224	-0.21102	40
MIDW	PAWNEE 115KV	999	-0.11431	MIDW	KNOLL 3 115 115KV	48	-0.04847	-0.06584	129
MIDW	RICE 115KV	999	-0.11431	MIDW	KNOLL 3 115 115KV	48	-0.04847	-0.06584	129

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WOODWARD - WOODWARD 69KV CKT 1  
 Limiting Facility: WOODWARD - WOODWARD 69KV CKT 1  
 Direction: From->To  
 Line Outage: FPL SWITCH - WOODWARD 138KV CKT 1  
 Flowgate: 56096547821557855478511107SH  
 Date Redispatch Needed: 6/1 - 10/1 Until EOC of Upgrade  
 Season Flowgate Identified: 2007 Summer Shoulder

Reservation	Relief Amount	Aggregate Relief Amount
1086238	0.7	0.7

Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	FPLWND2 34KV	102	0.04514	-0.49171	1
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	AES 161KV	320	-0.00021	-0.44636	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	HORSESHOE LAKE 138KV	91	-0.00148	-0.44509	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	HORSESHOE LAKE 69KV	16	-0.00141	-0.44516	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	MCCLAIN 138KV	478	-0.00231	-0.44426	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	MUSKOGEE 345KV	1516	-0.0003	-0.44627	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	MUSTANG 138KV	50	-0.00236	-0.44421	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	MUSTANG 69KV	98.87157	-0.00255	-0.44402	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	ONE OAK 345KV	100	-0.00097	-0.4456	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	SEMINOLE 138KV	476.2635	-0.0011	-0.44547	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	SEMINOLE 345KV	996	-0.00114	-0.44543	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	SMITH COGEN 138KV	110	-0.00223	-0.44434	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	SOONER 138KV	505	0.00148	-0.44805	2
OKGE	WOODWARD 24KV	9.3	-0.44657	OKGE	SOONER 345KV	513	0.00067	-0.44724	2
WFEC	ANADARKO 138KV	5.26828	0.0001	WFEC	SLEEPING BEAR 138KV	96	0.08953	-0.08943	8
WFEC	ANADARKO 138KV	90	0.0001	WFEC	SLEEPING BEAR 138KV	96	0.08953	-0.08943	8
WFEC	ANADARKO 69KV	76	0.00019	WFEC	SLEEPING BEAR 138KV	96	0.08953	-0.08934	8
WFEC	BLUCAN14 138 138KV	151.2	0.00032	WFEC	SLEEPING BEAR 138KV	96	0.08953	-0.08921	8
OKGE	HORSESHOE LAKE 138KV	380	-0.00148	OKGE	FPLWND2 34KV	102	0.04514	-0.04662	15
OKGE	HORSESHOE LAKE 138KV	380.5	-0.00148	OKGE	FPLWND2 34KV	102	0.04514	-0.04662	15
OKGE	MCCLAIN 138KV	42	-0.00231	OKGE	FPLWND2 34KV	102	0.04514	-0.04745	15
OKGE	MUSTANG 138KV	315.5	-0.00236	OKGE	FPLWND2 34KV	102	0.04514	-0.0475	15
OKGE	MUSTANG 69KV	7.128418	-0.00255	OKGE	FPLWND2 34KV	102	0.04514	-0.04769	15
OKGE	TINKER 5G 138KV	62	-0.00148	OKGE	FPLWND2 34KV	102	0.04514	-0.04662	15
WFEC	ANADARKO 138KV	90	0.0001	WFEC	MORLND 138KV	160.0176	0.04514	-0.04504	16
WFEC	ANADARKO 69KV	76	0.00019	WFEC	MORLND 138KV	160.0176	0.04514	-0.04495	16
WFEC	BLUCAN14 138 138KV	151.2	0.00032	WFEC	MORLND 138KV	160.0176	0.04514	-0.04482	16
WFEC	MORLND 138KV	159.9824	0.04514	WFEC	SLEEPING BEAR 138KV	96	0.08953	-0.04439	16
OKGE	MUSKOGEE 161KV	166	-0.00028	OKGE	FPLWND2 34KV	102	0.04514	-0.0454	16
OKGE	MUSKOGEE 161KV	31	-0.00028	OKGE	FPLWND2 34KV	102	0.04514	-0.0454	16
OKGE	MUSKOGEE 345KV	20	-0.0003	OKGE	FPLWND2 34KV	102	0.04514	-0.04544	16
OKGE	ONE OAK 345KV	236	-0.00097	OKGE	FPLWND2 34KV	102	0.04514	-0.04611	16
OKGE	REDBUD 345KV	900	-0.00099	OKGE	FPLWND2 34KV	102	0.04514	-0.04613	16
OKGE	REDBUD 345KV	300	-0.00099	OKGE	FPLWND2 34KV	102	0.04514	-0.04613	16
OKGE	SEMINOLE 138KV	28.73651	-0.0011	OKGE	FPLWND2 34KV	102	0.04514	-0.04624	16
OKGE	SOONER 138KV	24.99997	0.00148	OKGE	FPLWND2 34KV	102	0.04514	-0.04366	16
OKGE	SOUTH 4TH ST 69KV	42.7	0.00914	OKGE	FPLWND2 34KV	102	0.04514	-0.036	20

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: WOODWARD - WOODWARD 69KV CKT 1  
 Limiting Facility: WOODWARD - WOODWARD 69KV CKT 1  
 Direction: From->To  
 Line Outage: FPL SWITCH - WOODWARD 138KV CKT 1  
 Flowgate: 56096547821557855478511107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07

**Table 6 - Potential Redispatch Relief Pairs to Prevent Deferral of Service**

Reservation		Relief Amount		Aggregate Relief Amount					
1086238		0.7		0.7					
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	FPLWND2 34KV'	102	0.04514	-0.49171	1
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	AES 161KV'	320	-0.00021	-0.44636	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	HORSESHOE LAKE 138KV'	380	-0.00148	-0.44509	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	HORSESHOE LAKE 138KV'	91	-0.00148	-0.44509	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	HORSESHOE LAKE 138KV'	217.5508	-0.00148	-0.44509	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	HORSESHOE LAKE 69KV'	16	-0.00141	-0.44516	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	MCCLAIN 138KV'	478	-0.0023	-0.44427	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	MUSKOGEE 345KV'	1516	-0.0003	-0.44627	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	MUSTANG 138KV'	365.5	-0.00236	-0.44421	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	MUSTANG 69KV'	106	-0.00255	-0.44402	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	ONE OAK 345KV'	132	-0.00097	-0.4456	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	SEMINOLE 138KV'	476.7589	-0.0011	-0.44547	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	SEMINOLE 345KV'	996	-0.00114	-0.44543	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	SMITH COGEN 138KV'	110	-0.00223	-0.44434	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	SOONER 138KV'	505	-0.00148	-0.44805	2
OKGE	WOODWARD 24KV'	9.3	-0.44657	OKGE	SOONER 345KV'	513	0.00067	-0.44724	2
WFEC	ANADARKO 138KV'	90	0.00019	WFEC	SLEEPING BEAR 138KV'	96	0.08953	-0.08943	8
WFEC	ANADARKO 69KV'	76	0.00019	WFEC	SLEEPING BEAR 138KV'	96	0.08953	-0.08943	8
WFEC	BLUCAN14 138 138KV'	151.2	0.00032	WFEC	SLEEPING BEAR 138KV'	96	0.08953	-0.08921	8
OKGE	HORSESHOE LAKE 138KV'	162.9492	-0.00148	OKGE	FPLWND2 34KV'	102	0.04514	-0.04662	15
OKGE	MCCLAIN 138KV'	42	-0.0023	OKGE	FPLWND2 34KV'	102	0.04514	-0.04744	15
OKGE	TINKER 5G 138KV'	62	-0.00148	OKGE	FPLWND2 34KV'	102	0.04514	-0.04662	15
WFEC	ANADARKO 138KV'	90	0.00019	WFEC	MORLND 138KV'	294.7338	0.04514	-0.04504	16
WFEC	ANADARKO 69KV'	76	0.00019	WFEC	MORLND 138KV'	294.7338	0.04514	-0.04495	16
WFEC	BLUCAN14 138 138KV'	151.2	0.00032	WFEC	MORLND 138KV'	294.7338	0.04514	-0.04482	16
WFEC	MORLND 138KV'	25.26624	0.04514	WFEC	SLEEPING BEAR 138KV'	96	0.08953	-0.04439	16
OKGE	MUSKOGEE 161KV'	166	-0.00028	OKGE	FPLWND2 34KV'	102	0.04514	-0.0454	16
OKGE	MUSKOGEE 161KV'	31	-0.00028	OKGE	FPLWND2 34KV'	102	0.04514	-0.0454	16
OKGE	MUSKOGEE 345KV'	20	-0.0003	OKGE	FPLWND2 34KV'	102	0.04514	-0.04544	16
OKGE	ONE OAK 345KV'	204	-0.00097	OKGE	FPLWND2 34KV'	102	0.04514	-0.04611	16
OKGE	REDBUD 345KV'	900	-0.00099	OKGE	FPLWND2 34KV'	102	0.04514	-0.04613	16
OKGE	REDBUD 345KV'	300	-0.00099	OKGE	FPLWND2 34KV'	102	0.04514	-0.04613	16
OKGE	SEMINOLE 138KV'	28.24118	-0.0011	OKGE	FPLWND2 34KV'	102	0.04514	-0.04624	16
OKGE	SOONER 138KV'	24.99997	0.00148	OKGE	FPLWND2 34KV'	102	0.04514	-0.04366	16
OKGE	SOUTH 4TH ST 69KV'	42.7	0.00914	OKGE	FPLWND2 34KV'	102	0.04514	-0.036	20

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor

Upgrade: YOAKUM COUNTY INTERCHANGE 230-115KV TRANSFORMER CKT 1  
 Limiting Facility: YOAKUM COUNTY INTERCHANGE 230-115KV TRANSFORMER CKT 1  
 Direction: From->To  
 Line Outage: MUSTANG STATION 230-115KV TRANSFORMER CKT 1  
 Flowgate: 51890518911519695196613107SP  
 Date Redispatch Needed: 6/1/07 - 10/1/07  
 Season Flowgate Identified: 2007 Summer Peak

Reservation		Relief Amount		Aggregate Relief Amount					
1090487		23.6		23.6					
Source Control Area	Source	Maximum Increment(MW)	GSF	Sink Control Area	Sink	Maximum Decrement(MW)	GSF	Factor	Redispatch Amount (MW)
SPS	MADOX 115KV'	75	-0.06213	SPS	MUSTG5 118.0 230KV'	360	0.1552	-0.21733	108
SPS	CUNNINGHAM 115KV'	71	-0.06026	SPS	MUSTG5 118.0 230KV'	360	0.1552	-0.21546	109
SPS	LP-BRND2 69KV'	152	-0.01329	SPS	MUSTG5 118.0 230KV'	360	0.1552	-0.16849	140
SPS	JONES 230KV'	243	-0.01219	SPS	MUSTG5 118.0 230KV'	360	0.1552	-0.16739	141
SPS	NICHOLS 115KV'	66.00001	0.00483	SPS	MUSTG5 118.0 230KV'	360	0.1552	-0.15037	157
SPS	NICHOLS 230KV'	134.6729	0.00496	SPS	MUSTG5 118.0 230KV'	360	0.1552	-0.15024	157
SPS	TOLK 345KV'	540	0.01569	SPS	MUSTG5 118.0 230KV'	360	0.1552	-0.13951	169
SPS	TOLK 230KV'	591.5715	0.0176	SPS	MUSTG5 118.0 230KV'	360	0.1552	-0.1376	171

Maximum Decrement and Maximum Increment were determine from the Souce and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor