



Aggregate Facility Study
SPP-2007-AG3-AFS-4
For Transmission Service
Requested by
Aggregate Transmission Customers

SPP Engineering, SPP Tariff Studies

Table of Contents

| | | |
|----|--|----|
| 1. | Executive Summary | 3 |
| 2. | Introduction..... | 4 |
| A. | Financial Analysis..... | 7 |
| B. | Third Party Facilities..... | 9 |
| 3. | Study Methodology..... | 10 |
| A. | Description..... | 10 |
| B. | Model Development..... | 11 |
| C. | Transmission Request Modeling..... | 12 |
| D. | Transfer Analysis..... | 13 |
| E. | Curtailment and Redispatch Evaluation..... | 13 |
| 4. | Study Results | 14 |
| A. | Study Analysis Results | 14 |
| B. | Study Definitions | 17 |
| 5. | Conclusion | 18 |
| 6. | Appendix A..... | 19 |

1. Executive Summary

Pursuant to Attachment Z1 of the Southwest Power Pool Open Access Transmission Tariff (OATT), 1664 MW of long-term transmission service requests have been restudied in this Aggregate Facility Study (AFS). The first phase of the AFS consisted of a revision of the impact study to reflect the withdrawal of requests for which an Aggregate Facility Study Agreement was not executed. The principal objective of the AFS is to identify system problems and potential modifications necessary to facilitate these transfers while maintaining or improving system reliability as well as summarizing the operating limits and determination of the financial characteristics associated with facility upgrades. Facility upgrade costs are allocated on a prorated basis to all requests positively impacting any individual overloaded facility. Further, Attachment Z provides for facility upgrade cost recovery by stating that “[a]ny charges paid by a customer in excess of the transmission access charges in compensation for the revenue requirements for allocated facility upgrade(s) shall be recovered by such customer from future transmission service revenues until the customer has been fully compensated.”

The total assigned facility upgrade Engineering and Construction (E &C) cost determined by the AFS is \$59 Million. Additionally an indeterminate amount of assigned E & C cost for 3rd party facility upgrades are assignable to the customer. The total upgrade levelized revenue requirement for all transmission requests is \$ 185 Million. This is based on full allocation of levelized revenue requirements for upgrades to customers without consideration of base plan funding. AFS data table 3 reflects the allocation of upgrade costs to each request without potential base plan funding based on either the requested reservation period or the deferred reservation period if applicable. Total upgrade levelized revenue requirements for all transmission requests after consideration of potential base plan funding is \$113 Million.

Third-party facilities must be upgraded when it is determined they are constrained in order to accommodate the requested Transmission Service. These include both first-tier neighboring

facilities outside SPP and Transmission Owner facilities within SPP that are not under the SPP OATT. In this AFS, third-party facilities were identified. Total engineering and construction cost estimates for required third-party facility upgrades are indeterminate.

The Transmission Provider will tender a Letter of Intent on August 28th, 2008. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), the Transmission Provider must receive from the Transmission Customer (Customer) by September 12th, 2008, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to WITHDRAW the request or leave the request in STUDY mode.

At the conclusion of the ATSS, Service Agreements for each request for service will be tendered identifying the terms and conditions of the confirmed service.

If customers withdraw from the ATSS after posting of this AFS, the AFS will be re-performed to determine final cost allocation and Available Transmission Capability (ATC) in consideration of the remaining ATSS participants. All allocated revenue requirements for facility upgrades are assigned to the customer in the AFS data tables. Potential base plan funding allowable is contingent upon validation of designated resources meeting Attachment J, Section III B criteria.

2. Introduction

On January 21, 2005, the Federal Energy Regulatory Commission accepted Southwest Power Pool's proposed aggregate transmission study procedures in Docket ER05-109 to become effective February 1, 2005. In compliance with this Order, the third open season of 2007 commenced on June 1, 2007. All requests for long-term transmission service received prior to October 1, 2007 with a signed study agreement were then included in this third Aggregate Transmission Service Study (ATSS) of 2007.

Approximately 1664 MW of long-term transmission service has been restudied in this Aggregate Facility Study (AFS) with over \$59 Million in transmission upgrades being proposed. The results of the AFS are detailed in Tables 1 through 7. A highly tangible benefit of studying transmission requests aggregately under the SPP OATT Attachment Z is the sharing of costs among customers using the same facility. The detailed results show individual upgrade costs by study as well as potential base plan allowances as determined by Attachments J and Z. The following URL can be used to access the SPP OATT:

(http://www.spp.org/Publications/SPP_Tariff.pdf). In order to understand the extent to which base plan upgrades may be applied to both point-to-point and network transmission services, it is necessary to highlight the definition of Designated Resource. Per Section 1.9a of the SPP OATT, a Designated Resource is “[a]ny designated generation resource owned, purchased or leased by a Transmission Customer to serve load in the SPP Region. Designated Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Transmission Customer's load on a non-interruptible basis.” Therefore, not only network service, but also point-to-point service has potential for base plan funding if the conditions for classifying upgrades associated with designated resources as base plan upgrades as defined in Section III.B of Attachment J are met.

Pursuant to Attachment J, Section III B of the SPP OATT, the Transmission Customer must provide SPP information necessary to verify that the new or changed Designated Resource meets the following conditions:

1. Transmission Customer's commitment to the requested new or changed Designated Resource must have a duration of at least five years.
2. During the first year the Designated Resource is planned to be used by the Transmission Customer, the accredited capacity of the Transmission Customer's existing Designated Resources plus the lesser of (a) the planned maximum net

dependable capacity applicable to the Transmission Customer or (b) the requested capacity; shall not exceed 125% of the Transmission Customer's projected system peak responsibility determined pursuant to SPP Criteria 2.

According to Attachment Z Section VI.A, Point-to-Point customers pay the higher of the monthly transmission access charge (base rate) or the monthly revenue requirement associated with the assigned facility upgrades including any prepayments for redispatch required during construction.

Network Integration Service customers pay the total monthly transmission access charges and the monthly revenue requirement associated with the facility upgrades including any prepayments for redispatch during construction.

Transmission Customers paying for a directly assigned network upgrade shall receive credits for new transmission service using the facility as specified in Attachment **Z2** Section VII.

Facilities identified as limiting the requested Transmission Service have been reviewed to determine the required in-service date of each Network Upgrade. The year that each Network Upgrade is required to accommodate a request is determined by interpolating between the applicable model years given the respective loading data. Both previously assigned facilities and the facilities assigned to this request for Transmission Service were evaluated.

In some instances due to lead times for engineering and construction, Network Upgrades may not be available when required to accommodate a request for Transmission Service. When this occurs, the ATC with available Network Upgrades will be less than the capacity requested during either a portion of or all of the requested reservation period. As a result, the lowest seasonal allocated ATC within the requested reservation period will be offered to the Transmission Customer on an applicable annual basis as listed in Table 1. The ATC may be

limited by transmission owner planned projects, expansion plan projects, or customer assigned upgrades.

Some constraints identified in the AFS were not assigned to the Customer as the Transmission Provider determined that upgrades are not required due to various reasons or the Transmission Owner has construction plans pending for these upgrades. These facilities are listed by reservation in Table 3. This table also includes constrained facilities in the current planning horizon that limit the rollover rights of the Transmission Customer. Table 6 lists possible redispatch pairs to allow start of service prior to completion of assigned network upgrades. Table 7 (if applicable) lists deferment of expansion plan projects with different upgrades with the new required in service date as a result of this AFS.

A. Financial Analysis

The AFS utilizes the allocated customer E & C cost in a present worth analysis to determine the monthly levelized revenue requirement of each facility upgrade over the term of the reservation. In some cases, network upgrades cannot be completed within the requested reservation period, thus deferred reservation periods will be utilized in the present worth analysis. If the Customer chose Option 2, Redispatch, in the Letter of Intent sent coincident with the initial AFS, the present worth analysis of revenue requirements will be based on the deferred term with redispatch in the subsequent AFS. The upgrade levelized revenue requirement includes interest, depreciation, and carrying costs.

Each request for Transmission Service is evaluated independently as the cost associated with each Network Upgrade is assigned to a request. When facilities are upgraded throughout the reservation period, the Transmission Customer shall 1) pay the total E & C costs and other annual operating costs associated with the new facilities, and 2) receive credits associated with the depreciated book value of removed usable facilities, salvage value of removed non-usable

facilities, and the carrying charges, excluding depreciation, associated with all removed usable facilities based on their respective book values.

In the event that the engineering and construction of a previously assigned Network Upgrade may be expedited, with no additional upgrades, to accommodate a new request for Transmission Service, then the leveled present worth of only the incremental expenses though the reservation period of the new request, excluding depreciation, shall be assigned to the new request. These incremental expenses, excluding depreciation, include 1) the leveled difference in present worth of the engineering and construction expenses given the change in date to complete construction to account for additional interest expense and reduced engineering and construction expense due to inflation, 2) the leveled present worth of all expediting fees, and 3) the leveled present worth of the incremental annual carrying charges, excluding depreciation and interest, during the new reservation period taking into account both a) the reservation in which the project was originally assigned, and b) a reservation, if any, in which the project was previously expedited.

Achievable Base Plan Avoided Revenue Requirements in the case of a Base Plan upgrade being displaced or deferred by an earlier in service date for a Requested Upgrade shall be determined per Attachment J, Section VII.B methodology. A deferred Base Plan upgrade being defined as a different requested network upgrade needed at an earlier date that negates the need for the initial base plan upgrade within the planning horizon. A displaced Base Plan upgrade being defined as the same network upgrade being displaced by a requested upgrade needed at an earlier date. Assumption of a 40 year service life is utilized for Base Plan funded projects unless provided otherwise by the Transmission Owner. A present worth analysis of revenue requirements on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan revenue requirements due to the displacement or deferral of the Base Plan upgrade by the Requested Upgrade. The difference in present worth between the Base Plan and

Requested Upgrades is assigned to the transmission requests impacting this upgrade based on the displacement or deferral.

B. Third Party Facilities

For third-party facilities listed in Table 3 and Table 5, the Transmission Customer is responsible for funding the necessary upgrades of these facilities per Section 21.1 of the Transmission Provider's OATT. In this AFS, third-party facilities were identified. Total engineering and construction cost estimates for required third-party facility upgrades are indeterminate. The Transmission Provider will undertake reasonable efforts to assist the Transmission Customer in making arrangements for necessary engineering, permitting, and construction of the third-party facilities. Third-party facility upgrade engineering and construction cost estimates are not utilized to determine the present worth value of levelized revenue requirements for SPP system network upgrades.

All modeled facilities within the Transmission Provider system were monitored during the development of this Study as well as certain facilities in first-tier neighboring systems. Third-party facilities must be upgraded when it is determined that they are overloaded while accommodating the requested Transmission Service. An agreement between the Customer and 3rd Party Owner detailing the mitigation of the 3rd party impact must be provided to the Transmission Provider prior to tendering of a Transmission Service Agreement. These facilities also include those owned by members of the Transmission Provider who have not placed their facilities under the Transmission Provider's OATT. Upgrades on the Southwest Power Administration network requires prepayment of the upgrade cost prior to construction of the upgrade.

Third-party facilities are evaluated for only those requests whose load sinks within the SPP footprint. The Customer must arrange for study of 3rd party facilities for load that sinks outside the SPP footprint with the applicable Transmission Providers.

3. Study Methodology

A. Description

The system impact analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier Non - SPP control area systems. The steady-state analysis was done to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled. The Southwest Power Pool conforms to the NERC Reliability Standards, which provide the strictest requirements, related to voltage violations and thermal overloads during normal conditions and during a contingency. It requires that all facilities be within normal operating ratings for normal system conditions and within emergency ratings after a contingency. Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP MDWG models, respectively. The upper bound and lower bound of the normal voltage range monitored is 110% and 90%. The upper bound and lower bound of the emergency voltage range monitored is 110% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69kV and above, first tier Non - SPP control area branches and ties 115 kV and above, any defined contingencies for these control areas, and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier Non – SPP control area branches and ties 115 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier Non – SPP control area facilities, a 3 % TDF cutoff was applied to AECI, AMRN, and ENTR and a 2 % TDF cutoff was applied to MEC, NPPD, and OPPD. For voltage monitoring, a

0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

B. Model Development

SPP used twelve seasonal models to study the aggregate transfers of 16644 MW over a variety of requested service periods. The SPP MDWG 2007 Series Cases Update 2 2007/08 Winter Peak (07WP), 2008 April (08AP), 2008 Spring Peak (08G), 2008 Summer Peak (08SP), 2008 Summer Shoulder (08SH), 2008 Fall Peak (08FA), 2008/09 Winter Peak (08WP), 2009 Summer Peak (09SP), 2009/10 Winter Peak (09WP), 2012 Summer Peak (12SP), 2012/13 Winter Peak (12WP), and 2017 Summer Peak (17SP) were used to study the impact of the requested service on the transmission system. The Spring Peak models apply to April and May, the Summer Peak models apply to June through September, the Fall Peak models apply to October and November, and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the most current modeling information. Five groups of requests were developed from the aggregate of 2804 MW in order to minimize counter flows among requested service. Each request was included in at least two of the four groups depending on the requested path. All requests were included in group five. From the twelve seasonal models, five system scenarios were developed. Scenario 1 includes SWPP OASIS transmission requests not already included in the SPP 2007 Series Cases flowing in a West to East direction with ERCOTN HVDC Tie South to North, ERCOTE HVDC Tie East to West, SPS exporting, and SPS importing from the Lamar HVDC Tie. Scenario 2 includes transmission requests not already included in the SPP 2007 Series Cases flowing in an East to West direction with ERCOTN HVDC tie North to South, ERCOTE HVDC tie East to West, SPS importing, and SPS exporting to the Lamar HVDC Tie. Scenario 3 includes transmission requests not already included in the SPP 2007 Series Cases flowing in a South to North direction with ERCOTN HVDC tie South to North, ERCOTE HVDC tie East to West, SPS exporting, and

SPS exporting to the Lamar HVDC Tie. Scenario 4 includes transmission requests not already included in the SPP 2007 Series Cases flowing in a North to South direction with ERCOTN HVDC tie North to South, ERCOTE HVDC tie East to West, SPS importing, and SPS importing from the Lamar HVDC tie. Scenario 5 include all transmission not already included in the SPP 2007 Series Cases with ERCOTN North to South, ERCOTE East to West, SPS importing and SPS exporting to the Lamar HVDC tie. The system scenarios were developed to minimize counter flows from previously confirmed, higher priority requests not included in the MDWG Base Case.

C. Transmission Request Modeling

Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation transfers. The Generation to Load modeling is accomplished by developing a pre-transfer case by redispatching the existing designated network resource(s) down by the new designated network resource request amount and scaling down the applicable network load by the same amount proportionally. The post-transfer case for comparison is developed by scaling the network load back to the forecasted amount and dispatching the new designated network resource being requested. Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation because the requested Network Integration Transmission Service is a request to serve network load with the new designated network resource and the impacts on transmission system are determined accordingly. If the Network Integration Transmission Service request application clearly documents that the existing designated network resource(s) is being replaced or undesignated by the new designated network resource then MW impact credits will be given to the request as is done for a redirect of existing transmission service. Point-To-Point Transmission Service requests are modeled as Generation to Generation transfers. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the request source and redispatching the request sink.

D. Transfer Analysis

Using the selected cases both with and without the requested transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs (SPP and 1st-Tier) and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

E. Curtailment and Redispatch Evaluation

During any period when SPP determines that a transmission constraint exists on the Transmission System, and such constraint may impair the reliability of the Transmission System, SPP will take whatever actions that are reasonably necessary to maintain the reliability of the Transmission System. To the extent SPP determines that the reliability of the Transmission System can be maintained by redispatching resources, SPP will evaluate interim curtailment of existing confirmed service or interim redispatch of units to provide service prior to completion of any assigned network upgrades. Any redispatch may not unduly discriminate between the Transmission Owners' use of the Transmission System on behalf of their Native Load Customers and any Transmission Customer's use of the Transmission System to serve its designated load. Redispatch was evaluated to provide only interim service during the time frame prior to completion of any assigned network upgrades. Curtailment of existing confirmed service is evaluated to provide only interim service. Curtailment of existing confirmed service is only evaluated at the request of the transmission customer.

SPP determined potential relief pairs to relieve the incremental MW impact on limiting facilities as identified in Table 6. Using the selected cases where the limiting facilities were identified, potential incremental and decremental units were identified by determining the generation amount available for increasing and decreasing from the units generation amount, maximum generation amount, and minimum generation amount. If the incremental or decremental amount

was greater than 1 MW, the unit was considered as a potential incremental or decremental unit. Generation shift factors were calculated for the potential incremental and decremental units using Managing and Utilizing System Transmission (MUST). Relief pairs from the generation shift factors for the incremental and decremental units with a greater than 3% TDF on the limiting constraint were determined from the incremental units with the lowest generation shift factors and decremental units with highest generation shift factors. If the aggregate redispatch amount for the potential relief pair was determined to be three times greater than the lower of the increment or decrement then the pair was determined not to be feasible and is not included. If transmission customer would like to see additional relief pairs beyond the relief pairs determined, the transmission customer can request SPP to provide the additional pairs. The potential relief pairs **were not** evaluated to determine impacts on limiting facilities in the SPP and 1st-Tier systems. The redispatch requirements would be called upon prior to implementing NERC TLR Level 5a.

4. Study Results

A. Study Analysis Results

Tables 1 through 6 contain the steady-state analysis results of the AFS. Table 1 identifies the participating long-term transmission service requests included in the AFS. This table lists deferred start and stop dates both with and without redispatch (based on customer selection of redispatch if available), the minimum annual allocated ATC without upgrades and season of first impact. Table 2 identifies total E & C cost allocated to each Transmission Customer, letter of credit requirements, third party E & C cost assignments, potential base plan E & C funding (lower of allocated E & C or Attachment J Section III B criteria) , total revenue requirements for assigned upgrades without consideration of potential base plan funding, point-to-point base rate charge, total revenue requirements for assigned upgrades with consideration of potential base plan funding, and final total cost allocation to the Transmission Customer. Table 3 provides additional details for each request including all assigned facility upgrades required, allocated E &

C costs, allocated revenue requirements for upgrades, upgrades not assigned to customer but required for service to be confirmed, credits to be paid for previously assigned AFS facility upgrades, and any third party upgrades required. Table 4 lists all upgrade requirements with associated solutions needed to provide transmission service for the AFS, Minimum ATC per upgrade with season of impact, Earliest Date Upgrade is required (COD), Estimated Date of Upgrade Completion (EOC), and Estimated E & C cost. Table 5 lists identified Third-Party constrained facilities. Table 6 identifies potential redispatch pairs available to relieve the aggregate impacts on identified constraints to prevent deferral of start of service. Table 7 (if applicable) identifies deferred expansion plan projects that were replaced with requested upgrades at earlier dates.

The potential base plan funding allowable is contingent upon meeting each of the conditions for classifying upgrades associated with designated resources as base plan upgrades as defined in Section III.B of Attachment J. If the additional capacity of the new or changed designated resource exceeds the 125% resource to load forecast for the year of start of service, the requested resource is not eligible for base plan funding of required network upgrades and the full cost of the upgrades is assignable to the customer. If the 5 year term and 125% resource to load criteria are met, the lesser of the planned maximum net dependable capacity (NDC) or the requested capacity is multiplied by \$180,000 to determine the potential base plan funding allowable. When calculating Base Plan Funding amounts that include a wind farm, the amount used is 10% of the requested amount of service, or the NDC. The Maximum Potential Base Plan Funding Allowable may be less than the potential base plan funding allowable due to the E & C Cost allocated to the customer being lower than the potential amount allowable to the customer. The customer is responsible for any assigned upgrade costs in excess of Potential Base Plan Engineering and Construction Funding Allowable.

Regarding application of base plan funding for PTP requests, if PTP base rate exceeds upgrade revenue requirements without taking into effect the reduction of revenue requirements by potential base plan funding, then the base rate revenue pays back the Transmission Owner for upgrades and no base plan funding is applicable as the access charge must be paid as it is the higher of “OR” pricing.

However, if initially the upgrade revenue requirements exceed the PTP base rate, then potential base plan funding would be applicable. The test of the higher of “OR” pricing would then be made against the remaining assignable revenue requirements versus PTP base rate. Examples are as follows:

Example A:

E & C allocated for upgrades is 74 million with revenue requirements of 140 million and PTP base rate of 101 million. Potential base plan funding is 47 million with the difference of 27 million E & C assignable to the customer. If the revenue requirements for the assignable portion is 54 million and the PTP base rate is 101 million, the customer will pay the higher “OR” pricing of 101 million base rate of which 54 million revenue requirements will be paid back to the Transmission Owners for the upgrades and the remaining revenue requirements of (140-54) or 86 million will be paid by base plan funding.

Example B:

E & C allocated for upgrades is 74 million with revenue requirements of 140 million and PTP base rate of 101 million. Potential base plan funding is 10 million with the difference of 64 million E & C assignable to the customer. If the revenue requirements for this assignable portion is 128 million and the PTP base rate is 101 million the customer will pay the higher “OR”

pricing of 128 million revenue requirements to be paid back to the Transmission Owners and the remaining revenue requirements of (140-128) or 12 million will be paid by base plan funding.

Example C:

E & C allocated for upgrades is 25 million with revenue requirements of 50 million and PTP base rate of 101 million. Potential base plan funding is 10 million. Base plan funding is not applicable as the higher “OR” pricing of PTP base rate of 101 million must be paid and the 50 million revenue requirements will be paid from this.

The 125% resource to load determination is performed on a per request basis and is not based on a total of designated resource requests per Customer. A footnote will provide the maximum resource designation allowable for base plan funding consideration per Customer basis per year.

Base plan funding verification requires that each Transmission Customer with potential for base plan funding provide SPP attestation statements verifying that the firm capacity of the requested designated resource is committed for a minimum five year duration.

B. Study Definitions

The Commercial Operation Date (COD) is the earliest date the upgrade is required to alleviate a constraint considering all requests. End of Construction (EOC) is the estimated date the upgrade will be completed and in service. The Total Engineering and Construction Cost (E & C) is the upgrade solution cost as determined by the transmission owner. The Transmission Customer Allocation Cost is the estimated engineering and construction cost based upon the allocation of costs to all Transmission Customers in the AFS who positively impact facilities by at least 3% subsequently overloaded by the AFS. Minimum ATC is the portion of the requested capacity that can be accommodated without upgrading facilities. Annual ATC allocated to the Transmission

Customer is determined by the least amount of allocated seasonal ATC within each year of a reservation period.

5. Conclusion

The results of the AFS show that limiting constraints exist in many areas of the regional transmission system. Due to these constraints, transmission service cannot be granted unless noted in Table 3.

The Transmission Provider will tender a Letter of Intent on August 28th, 2008. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), the Transmission Provider must receive from the Transmission Customer (Customer) by September 12th, 2008, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to WITHDRAW the request or leave the request in STUDY mode.

The Transmission Provider must receive an unconditional and irrevocable letter of credit in the amount of the total allocated Engineering and Construction costs assigned to the Customer. This letter of credit is not required for those facilities that are base plan funded. This amount is for all assignable Network Upgrades less pre-payment requirements. The amount of the letter of credit will be adjusted down on an annual basis to reflect amortization of these costs. The Transmission Provider will issue letters of authorization to construct facility upgrades to the constructing Transmission Owner. This date is determined by the engineering and construction lead time provided for each facility upgrade.

6. Appendix A

PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

BASE CASES:

Solutions - Fixed slope decoupled Newton-Raphson solution (FDNS)

Tap adjustment – Stepping

Area interchange control – Tie lines and loads

Var limits – Apply immediately

Solution options - X Phase shift adjustment

_ Flat start

_ Lock DC taps

_ Lock switched shunts

ACCC CASES:

Solutions – AC contingency checking (ACCC)

MW mismatch tolerance – 0.5

Contingency case rating – Rate B

Percent of rating – 100

Output code – Summary

Min flow change in overload report – 3mw

Excl cases w/ no overloads form report – YES

Exclude interfaces from report – NO

Perform voltage limit check – YES

Elements in available capacity table – 60000

Cutoff threshold for available capacity table – 99999.0

Min. contng. case Vltg chng for report – 0.02

Sorted output – None

Newton Solution:

Tap adjustment – Stepping

Area interchange control – Tie lines and loads

Var limits - Apply automatically

Solution options - X Phase shift adjustment

_ Flat start

_ Lock DC taps

_ Lock switched shunts

Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study

| Customer | Study Number | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date without interim redispatch | Deferred Stop Date without interim redispatch | Start Date with interim redispatch | Stop Date with interim redispatch | Minimum Allocated ATC (MW) within reservation period | Season of Minimum Allocated ATC within reservation period |
|----------|---------------|-------------|------|------|------------------|----------------------|---------------------|--|---|------------------------------------|-----------------------------------|--|---|
| AEPM | AG3-2007-015 | 1337138 | CSWS | EES | 22 | 1/1/2009 | 1/1/2010 | 6/1/2011 | 6/1/2012 | 1/1/2009 | 1/1/2010 | 0 | 09SP |
| AEPM | AG3-2007-054 | 1352732 | CSWS | CSWS | 100 | 1/1/2010 | 1/1/2011 | 6/1/2011 | 6/1/2012 | 1/1/2010 | 1/1/2011 | 0 | 10SP |
| AEPM | AG3-2007-063 | 1352923 | CSWS | CSWS | 50 | 1/1/2009 | 1/1/2011 | 6/1/2011 | 6/1/2013 | 6/1/2010 | 6/1/2012 | 0 | 09SP |
| AEPM | AG3-2007-065 | 1352934 | CSWS | CSWS | 54 | 6/1/2010 | 6/1/2015 | 6/1/2010 | 6/1/2015 | 6/1/2010 | 6/1/2015 | 0 | 10SP |
| CMLP | AG3-2007-047 | 1352181 | GRDA | CSWS | 115 | 6/1/2008 | 6/1/2042 | 6/1/2011 | 6/1/2045 | 6/1/2010 | 6/1/2044 | 0 | 08SP |
| CMLP | AG3-2007-047 | 1352193 | GRDA | CSWS | 197 | 6/1/2008 | 6/1/2042 | 6/1/2011 | 6/1/2045 | 6/1/2010 | 6/1/2044 | 0 | 08SP |
| CRGL | AG3-2007-018 | 1340342 | KCPL | CLEC | 103 | 2/1/2008 | 2/1/2009 | 2/1/2011 | 2/1/2012 | 2/1/2011 | 2/1/2012 | 0 | 08SP |
| CRGL | AG3-2007-019 | 1340343 | OPPD | CLEC | 103 | 2/1/2008 | 2/1/2009 | 6/1/2010 | 6/1/2011 | 6/1/2010 | 6/1/2011 | 0 | 08SP |
| EDE | AG3-2007-037 | 1350960 | KCPL | EDE | 5 | 11/1/2008 | 11/1/2018 | 6/1/2010 | 6/1/2020 | 11/1/2008 | 11/1/2018 | 0 | 09SP |
| EDE | AG3-2007-046 | 1352109 | KCPL | EDE | 5 | 1/1/2010 | 1/1/2030 | 1/1/2010 | 1/1/2030 | 1/1/2010 | 1/1/2030 | 0 | 10SP |
| GRDA | AG3-2007-034 | 1350396 | OKGE | GRDA | 150 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2010 | 6/1/2015 | 0 | 08SP |
| KBPU | AG3-2007-017D | 1339117 | MPS | KACY | 5 | 2/1/2008 | 2/1/2009 | 6/1/2013 | 6/1/2014 | 6/1/2013 | 6/1/2014 | 0 | 08SP |
| KCPS | AG3-2007-074 | 1353013 | KCPL | KCPL | 45 | 11/1/2008 | 11/1/2018 | 2/1/2011 | 2/1/2021 | 10/1/2009 | 10/1/2019 | 0 | 09SP |
| KCPS | AG3-2007-075A | 1353028 | WPEK | KCPL | 50 | 6/1/2008 | 6/1/2009 | 6/1/2013 | 6/1/2014 | 6/1/2011 | 6/1/2012 | 0 | 08SP |
| KEPC | AG3-2007-064 | 1352933 | WR | KCPL | 15 | 6/1/2008 | 6/1/2040 | 6/1/2013 | 6/1/2045 | 10/1/2009 | 10/1/2041 | 0 | 08SP |
| KEPC | AG3-2007-066 | 1352938 | WR | WR | 68 | 6/1/2008 | 6/1/2040 | 6/1/2011 | 6/1/2043 | 6/1/2011 | 6/1/2043 | 0 | 08SP |
| KMEA | AG3-2007-104 | 1355377 | OPPD | KCPL | 20 | 1/1/2009 | 1/1/2013 | 6/1/2010 | 6/1/2014 | 10/1/2009 | 10/1/2013 | 0 | 09SP |
| KPP | AG3-2007-040 | 1351224 | WR | WR | 4 | 2/1/2008 | 2/1/2018 | 6/1/2011 | 6/1/2021 | 10/1/2009 | 10/1/2019 | 0 | 08SP |
| MIDW | AG3-2007-082 | 1353081 | WR | WR | 5 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-082 | 1353082 | WR | WR | 4 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-082 | 1353083 | WR | WR | 3 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-082 | 1353084 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-082 | 1353085 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-083 | 1353086 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-083 | 1353088 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-084 | 1353090 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-084 | 1353091 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-084 | 1353092 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-086 | 1353097 | WR | WR | 3 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-086 | 1353098 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-086 | 1353099 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-087 | 1353102 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-087 | 1353103 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | 6/1/2011 | 6/1/2016 | 0 | 08SP |
| MIDW | AG3-2007-090 | 1353110 | WR | WR | 25 | 3/1/2008 | 3/1/2027 | 6/1/2011 | 6/1/2030 | 10/1/2008 | 10/1/2027 | 0 | 08SP |
| MIDW | AG3-2007-091 | 1353111 | WR | WR | 25 | 1/1/2009 | 1/1/2029 | 6/1/2011 | 6/1/2031 | 1/1/2009 | 1/1/2029 | 0 | 09SP |
| OMPA | AG3-2007-035 | 1350945 | OKGE | OKGE | 23 | 5/1/2008 | 5/1/2017 | 6/1/2011 | 6/1/2020 | 10/1/2008 | 10/1/2017 | 0 | 08SP |
| PWX | AG3-2007-014 | 1331353 | BLKW | KCPL | 52 | 1/1/2010 | 1/1/2011 | 6/1/2013 | 6/1/2014 | 6/1/2013 | 6/1/2014 | 0 | 10SP |
| SPSM | AG3-2007-080 | 1353054 | WPEK | KCPL | 50 | 10/1/2008 | 6/1/2010 | 6/1/2013 | 2/1/2015 | 10/1/2009 | 6/1/2011 | 0 | 09SP |
| SPSM | AG3-2007-080 | 1353055 | WPEK | KCPL | 50 | 10/1/2008 | 6/1/2010 | 6/1/2013 | 2/1/2015 | 10/1/2009 | 6/1/2011 | 0 | 09SP |
| SPSM | AG3-2007-081 | 1353057 | WPEK | KCPL | 50 | 6/1/2010 | 1/1/2012 | 6/1/2013 | 1/1/2015 | 6/1/2010 | 1/1/2012 | 0 | 10SP |
| SPSM | AG3-2007-081 | 1353059 | WPEK | KCPL | 50 | 6/1/2010 | 1/1/2012 | 6/1/2013 | 1/1/2015 | 6/1/2010 | 1/1/2012 | 0 | 10SP |
| WRGS | AG3-2007-025 | 1346837 | SECI | WR | 96 | 11/1/2008 | 11/1/2018 | 6/1/2011 | 6/1/2021 | 6/1/2011 | 6/1/2021 | 0 | 09SP |
| WRGS | AG3-2007-026 | 1346842 | SECI | WR | 100 | 12/31/2008 | 12/31/2018 | 6/1/2011 | 6/1/2021 | 6/1/2011 | 6/1/2021 | 0 | 09SP |

Note 1: Disregard Redispatch shown in Table 6 for limitations identified earlier than the start date with redispatch with the exception of limitations identified in the 2008 Summer Shoulder, and 2008 Fall Peak

Note 2: Start and Stop Dates with interim redispatch are determined based on customers choosing option to pursue redispatch to start service at Requested Start and Stop Dates or earliest date possible.

Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

| Customer | Study Number | Reservation | Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements | 1 Letter of Credit Amount Required | 2 Potential Base Plan Engineering and Construction Funding Allowable | Notes | 4 Additional Engineering and Construction Cost for 3rd Party Upgrades | 3 Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITHOUT Potential Base Plan Funding Allocation | 3.5 Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITH Potential Base Plan Funding Allocation | Point-to-Point Base Rate Over Reservation Period | 4 Total Cost of Reservation Assignable to Customer Contingent Upon Base Plan Funding |
|----------|---------------|-------------|--|------------------------------------|--|-------|---|--|---|--|--|
| | | | | | | | | | | | |
| AEPM | AG3-2007-015 | 1337138 | \$ 1,130,731 | \$ - | \$ - | | Indeterminate | \$ - | \$ - | \$ - | Schedule 9 Charges |
| AEPM | AG3-2007-054 | 1352732 | \$ 3,959 | \$ 1,150 | \$ - | | Indeterminate | \$ 7,166 | \$ 7,166 | \$ - | \$ 7,166 |
| AEPM | AG3-2007-063 | 1352923 | \$ 3,575,407 | \$ - | \$ - | | Indeterminate | \$ 3,350,145 | \$ 3,350,145 | \$ - | \$ 3,350,145 |
| AEPM | AG3-2007-065 | 1352934 | \$ 504,825 | \$ - | \$ - | 6 | Indeterminate | \$ - | \$ - | \$ - | Schedule 9 Charges |
| CMLP | AG3-2007-047 | 1352181 | \$ 3,798,853 | \$ - | \$ 3,798,853 | | \$ - | \$ 18,838,946 | \$ - | \$ - | Schedule 9 Charges |
| CMLP | AG3-2007-047 | 1352193 | \$ 10,825,614 | \$ 6,325,614 | \$ 4,500,000 | | \$ - | \$ 53,684,318 | \$ 31,368,777 | \$ - | \$ 31,368,777 |
| CRGL | AG3-2007-018 | 1340342 | \$ 2,947,000 | \$ 2,947,000 | \$ - | | Indeterminate | \$ 5,134,293 | \$ 5,134,293 | \$ 1,909,839 | \$ 5,134,293 |
| CRGL | AG3-2007-019 | 1340343 | \$ - | \$ - | \$ - | | Indeterminate | \$ - | \$ - | \$ 1,909,839 | \$ 1,909,839 |
| EDE | AG3-2007-037 | 1350960 | \$ 72,420 | \$ - | \$ 27,902 | | Indeterminate | \$ 61,241 | \$ - | \$ - | Schedule 9 Charges |
| EDE | AG3-2007-046 | 1352109 | \$ 72,444 | \$ - | \$ 27,926 | | Indeterminate | \$ 95,978 | \$ - | \$ - | Schedule 9 Charges |
| GRDA | AG3-2007-034 | 1350396 | \$ - | \$ - | \$ - | | \$ - | \$ - | \$ - | \$ - | Schedule 9 Charges |
| KBPU | AG3-2007-017D | 1339117 | \$ 507,565 | \$ 507,565 | \$ - | | \$ - | \$ 1,082,811 | \$ 1,082,811 | \$ 52,800 | \$ 1,082,811 |
| KCPS | AG3-2007-074 | 1353013 | \$ 554,036 | \$ - | \$ 554,036 | | \$ - | \$ 1,393,397 | \$ - | \$ - | Schedule 9 Charges |
| KCPS | AG3-2007-075 | 1353028 | \$ 2,816,371 | \$ 2,688,890 | \$ - | | \$ - | \$ 4,668,905 | \$ 4,668,905 | \$ 528,000 | \$ 4,668,905 |
| KEPC | AG3-2007-064 | 1352933 | \$ 7,080,972 | \$ 4,380,972 | \$ 2,700,000 | | \$ - | \$ 31,302,442 | \$ 19,366,709 | \$ - | \$ 19,366,709 |
| KEPC | AG3-2007-066 | 1352938 | \$ 1,428,491 | \$ - | \$ 1,428,491 | | Indeterminate | \$ 7,985,889 | \$ - | \$ - | Schedule 9 Charges |
| KMEA | AG3-2007-104 | 1355377 | \$ 72,450 | \$ 72,450 | \$ - | | Indeterminate | \$ 139,557 | \$ 139,557 | \$ - | \$ 139,557 |
| KPP | AG3-2007-040 | 1351224 | \$ 22,975 | \$ - | \$ 22,975 | | Indeterminate | \$ 54,938 | \$ - | \$ - | Schedule 9 Charges |
| MIDW | AG3-2007-082 | 1353081 | \$ 64,018 | \$ 64,018 | \$ - | | Indeterminate | \$ 157,565 | \$ 157,565 | \$ 472,500 | \$ 472,500 |
| MIDW | AG3-2007-082 | 1353082 | \$ 51,213 | \$ 51,213 | \$ - | | Indeterminate | \$ 126,049 | \$ 126,049 | \$ 378,000 | \$ 378,000 |
| MIDW | AG3-2007-082 | 1353083 | \$ 38,409 | \$ 38,409 | \$ - | | Indeterminate | \$ 94,535 | \$ 94,535 | \$ 283,500 | \$ 283,500 |
| MIDW | AG3-2007-082 | 1353084 | \$ 25,607 | \$ 25,607 | \$ - | | Indeterminate | \$ 63,026 | \$ 63,026 | \$ 189,000 | \$ 189,000 |
| MIDW | AG3-2007-082 | 1353085 | \$ 12,804 | \$ 12,804 | \$ - | | Indeterminate | \$ 31,514 | \$ 31,514 | \$ 94,500 | \$ 94,500 |
| MIDW | AG3-2007-083 | 1353086 | \$ 16,118 | \$ 16,118 | \$ - | | Indeterminate | \$ 38,985 | \$ 38,985 | \$ 94,500 | \$ 94,500 |
| MIDW | AG3-2007-083 | 1353088 | \$ 32,236 | \$ 32,236 | \$ - | | Indeterminate | \$ 77,972 | \$ 77,972 | \$ 189,000 | \$ 189,000 |
| MIDW | AG3-2007-084 | 1353090 | \$ 14,857 | \$ 14,857 | \$ - | | Indeterminate | \$ 36,117 | \$ 36,117 | \$ 94,500 | \$ 94,500 |
| MIDW | AG3-2007-084 | 1353091 | \$ 29,712 | \$ 29,712 | \$ - | | Indeterminate | \$ 72,226 | \$ 72,226 | \$ 189,000 | \$ 189,000 |
| MIDW | AG3-2007-084 | 1353092 | \$ 29,712 | \$ 29,712 | \$ - | | Indeterminate | \$ 72,226 | \$ 72,226 | \$ 189,000 | \$ 189,000 |
| MIDW | AG3-2007-086 | 1353097 | \$ 205,263 | \$ 205,263 | \$ - | 7 | Indeterminate | \$ 420,493 | \$ 420,493 | \$ 283,500 | \$ 420,493 |
| MIDW | AG3-2007-086 | 1353098 | \$ 136,843 | \$ 136,843 | \$ - | 7 | Indeterminate | \$ 280,332 | \$ 280,332 | \$ 189,000 | \$ 280,332 |
| MIDW | AG3-2007-086 | 1353099 | \$ 68,423 | \$ 68,423 | \$ - | 7 | Indeterminate | \$ 140,168 | \$ 140,168 | \$ 94,500 | \$ 140,168 |
| MIDW | AG3-2007-087 | 1353102 | \$ 136,843 | \$ 136,843 | \$ - | 7 | Indeterminate | \$ 280,332 | \$ 280,332 | \$ 189,000 | \$ 280,332 |
| MIDW | AG3-2007-087 | 1353103 | \$ 68,423 | \$ 68,423 | \$ - | 7 | Indeterminate | \$ 140,168 | \$ 140,168 | \$ 94,500 | \$ 140,168 |
| MIDW | AG3-2007-090 | 1353110 | \$ 137,608 | \$ - | \$ 137,608 | | Indeterminate | \$ 410,193 | \$ - | \$ - | Schedule 9 Charges |
| MIDW | AG3-2007-091 | 1353111 | \$ 137,608 | \$ - | \$ 137,608 | | Indeterminate | \$ 433,230 | \$ - | \$ - | Schedule 9 Charges |

Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

| Customer | Study Number | Reservation | Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements | ¹Letter of Credit Amount Required | ²Potential Base Plan Engineering and Construction Funding Allowable | Notes | ⁴Additional Engineering and Construction Cost for 3rd Party Upgrades | ³ Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITHOUT Potential Base Plan Funding Allocation | ³⁵ Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITH Potential Base Plan Funding Allocation | Point-to-Point Base Rate Over Reservation Period | ⁴Total Cost of Reservation Assignable to Customer Contingent Upon Base Plan Funding |
|-------------|--------------|-------------|--|-----------------------------------|---|-------|--|--|--|--|---|
| | | | | | | | | | | | |
| OMPA | AG3-2007-035 | 1350945 | \$ 15,723 | \$ - | \$ 15,723 | | \$ - | \$ 31,824 | \$ - | \$ - | Schedule 9 Charges |
| PWX | AG3-2007-014 | 1331353 | \$ 442,382 | \$ 442,382 | \$ - | | \$ - | \$ 1,032,092 | \$ 1,032,092 | \$ 549,120 | \$ 1,032,092 |
| SPSM | AG3-2007-080 | 1353054 | \$ - | \$ - | \$ - | | \$ - | \$ - | \$ - | \$ - | \$ 880,000 |
| SPSM | AG3-2007-080 | 1353055 | \$ - | \$ - | \$ - | | \$ - | \$ - | \$ - | \$ - | \$ 880,000 |
| SPSM | AG3-2007-081 | 1353057 | \$ 375,359 | \$ 375,359 | \$ - | | \$ - | \$ 637,776 | \$ 637,776 | \$ 836,000 | \$ 836,000 |
| SPSM | AG3-2007-081 | 1353059 | \$ 375,359 | \$ 375,359 | \$ - | | \$ - | \$ 637,776 | \$ 637,776 | \$ 836,000 | \$ 836,000 |
| WRGS | AG3-2007-025 | 1346837 | \$ 2,447,083 | \$ 718,606 | \$ 1,728,000 | | \$ - | \$ 5,738,151 | \$ 1,686,173 | \$ - | \$ 1,686,173 |
| WRGS | AG3-2007-026 | 1346842 | \$ 19,322,281 | \$ 14,035,811 | \$ 1,800,000 | | \$ - | \$ 46,787,566 | \$ 42,428,991 | \$ - | \$ 42,428,991 |
| Grand Total | | | \$ 59,597,995 | | | | | \$ 185,540,338 | \$ 113,572,877 | | |

Note 1: Letter of Credit required for financial security for transmission owner for network upgrades is determined by allocated engineering and construction costs less engineering and construction costs for upgrades when network customer is the transmission owner less the E & C allocation of expedited projects. Letter of Credit is not required for base plan funded upgrades. The Letter Of Credit Amount listed is based on meeting OATT Attachment J requirements for base plan funding.

Note 2. If potential base plan funding is applicable, this value is the lesser of the Engineering and Construction costs of assignable upgrades or the value of base plan funding calculated pursuant to Attachment J, Section III B criteria. Allocation of base plan funding is contingent upon verification of customer agreements meeting Attachment J, Section II B criteria. Not applicable if Point-to-Point base rate exceeds revenue requirements.

Note 3: Revenue Requirements (RR) are based upon deferred end dates if applicable. Deferred dates are based upon customer's choice to pursue redispatch. Achievable Base Plan Avoided RR in the case of a Base Plan upgrade being displaced or deferred by an earlier in service date for a Requested Upgrade shall be determined per Attachment J, Section VII.C methodology. Assumption of a 40 year service life is utilized for Base Plan funded projects. A present worth analysis of RR on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan RR due to the displacement or deferral of the Base Plan upgrade by the Requested Upgrade. The incremental increase in present worth of a Requested Upgrade on a common year basis as a Base Plan upgrade is assigned to the transmission requests impacting the upgrade based on the displacement or deferral. If the displacement analysis results in lower RR due to the shorter amortization period of the requested upgrade when compared to a base plan amortization period, then no direct assignment of the upgrade cost is made due to the displacement to an earlier start date.

Note 4. For Point-to-Point requests, total cost is based on the higher of the base rate or assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirement. Allocation of base plan funding will be determined after verification of designated resource meeting Attachment J, Section II B Criteria. Additionally E & C of 3rd Party upgrades is assignable to Customer. This includes prepayments required for any SWPA upgrades. Revenue requirements for 3rd Party facilities are not calculated. Total cost to customer is based on assumption of Revenue Requirements with confirmation of base plan funding. Customer is responsible for negotiating redispatch costs if applicable. Customer is also responsible to pay credits for previously assigned upgrades that are impacted by their request. Credits can be paid from base plan funding if applicable.

Note 5: RR with base plan funding may increase or decrease even if no base plan funding is applicable to a particular request if another request that shares the upgrade is now full base plan funded resulting in a different amortization period for the upgrade and thus different RR.

Note 6: 2010 Maximum new resources capped at 10,693MW

Note 7: Lack of resource and load forecast data provided for base plan funding determination

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
AEPM AG3-2007-015

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|-----|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| AEPM | 1337138 | CSWS | EES | 22 | 1/1/2009 | 1/1/2010 | 6/1/2011 | 6/1/2012 | \$ - | \$ - | \$ 1,130,731 | \$ - |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--|-----|-----|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1337138 | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | | | 6/1/2009 | 6/1/2010 | Yes | \$ 1,130,731 | \$ 2,500,000 |
| | | | | | | Total | \$ 1,130,731 | \$ 2,500,000 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----|-----|-----------------------|----------------------|
| 1337138 | ARKOMA - FT SMITHW 161KV CKT 1 | | | 6/1/2009 | 6/1/2011 |
| | BONANZA - BONANZA TAP 161KV CKT 1 | | | 6/1/2011 | 6/1/2011 |
| | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | | | 1/1/2009 | 6/1/2009 |
| | COLONY - FT SMITH 161KV CKT 1 | | | 6/1/2009 | 6/1/2009 |
| | EAST CENTRAL HENRYETTA - OKMULGEE 138KV CKT 1 | | | 1/1/2009 | 6/1/2010 |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----|-----|-----------------------|----------------------|
| 1337138 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | | | 10/1/2008 | 6/1/2011 |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | | | 12/1/2008 | 6/1/2010 |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | | | 12/1/2008 | 6/1/2010 |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | | | 12/1/2008 | 6/1/2010 |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | | | 10/1/2008 | 6/1/2011 |
| | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 #2 | | | 6/1/2010 | 6/1/2010 |
| | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 AEPW | | | 6/1/2010 | 6/1/2010 |
| | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 OKGE | | | 6/1/2010 | 6/1/2010 |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|---|-----|-----|-----------------------------|----------------------|----------------------|------------------|
| 1337138 | 5BEE BR - QUITMAN 161KV CKT 1 | | | 6/1/2009 | 6/1/2009 | \$ - | \$ - |
| | ARKANSAS NUCLEAR ONE 161 - RUSSELLVILLE NORTH 161KV CKT 1 | | | 6/1/2009 | 6/1/2009 | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTR | | | 6/1/2009 | 6/1/2009 | \$ - | \$ - |
| | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 ENTR | | | 6/1/2010 | 6/1/2010 | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE NORTH 161KV CKT 1 | | | 6/1/2009 | 6/1/2009 | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | | | 11/1/2008 | 11/1/2008 | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
AEPM AG3-2007-054

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| AEPM | 1352732 | CSWS | CSWS | 100 | 1/1/2010 | 1/1/2011 | 6/1/2011 | 6/1/2012 | \$ - | \$ - | \$ 3,958 | \$ 7,166 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--------------------------------------|-----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1352732 | COFFEYVILLE FARMLAND 138KV CAP BANK | 6/1/2010 | 6/1/2010 | | | \$ 2,809 | \$ 250,000 | \$ 4,877 |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1,149 | \$ 85,922 | \$ 2,289 |
| | | | | Total | | \$ 3,958 | \$ 335,922 | \$ 7,166 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|----------|----------|-----------------------|----------------------|
| 1352732 | EAST CENTRAL HENRYETTA - OKMULGEE 138KV CKT 1 | 1/1/2009 | 6/1/2010 | | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|----------|-----------------------|----------------------|
| 1352732 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 12/1/2008 | 6/1/2010 | | Yes |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | 12/1/2008 | 6/1/2010 | | Yes |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | 12/1/2008 | 6/1/2010 | | Yes |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | SOUTHWEST SHREVEPORT (SW SHV 1) 345/138/13.8KV TRANSFORMER CKT 1 | 1/1/2009 | 6/1/2009 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--------------------------------------|----------|----------|-----------------------------|----------------------|----------------------|------------------|
| 1352732 | HARTBURG - INLAND-ORANGE 230KV CKT 1 | 1/1/2010 | 6/1/2011 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
AEPM AG3-2007-063

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| AEPM | 1352923 | CSWS | CSWS | 50 | 1/1/2009 | 1/1/2011 | 6/1/2011 | 6/1/2013 | \$ - | \$ - | \$ 3,575,407 | \$ 3,350,145 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--|----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1352923 | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | 6/1/2009 | 6/1/2010 | Yes | \$ 775,407 | \$ 2,500,000 | \$ - | \$ - |
| | TEXAS EASTMAN - WHITNEY 138KV CKT 1 | 6/1/2009 | 6/1/2011 | Yes | \$ 2,800,000 | \$ 2,800,000 | \$ 3,350,145 | \$ - |
| | | | | Total | \$ 3,575,407 | \$ 5,300,000 | \$ 3,350,145 | \$ - |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---------------------------------------|-----------|----------|-----------------------|----------------------|
| 1352923 | ARKOMA - FT SMITHW 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | BULL SHOALS - BULL SHOALS 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | SALLISAW CAP BANK | 10/1/2008 | 6/1/2010 | No | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--------------------------------------|----------|----------|-----------------------|----------------------|
| 1352923 | CLARKSVILLE - DARDANELLE 161KV CKT 1 | 6/1/2012 | 6/1/2012 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|----------|----------|-----------------------|----------------------|
| 1352923 | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 #2 | 6/1/2010 | 6/1/2010 | | |
| | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 AEPW | 6/1/2010 | 6/1/2010 | | |
| | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 OKGE | 6/1/2010 | 6/1/2010 | | |
| | SOUTHWEST SHREVEPORT (SW SHV 1) 345/138/13.8KV TRANSFORMER CKT 1 | 1/1/2009 | 6/1/2009 | Yes | |
| | SOUTHWEST SHREVEPORT (SW SHV 1) 345/138/13.8KV TRANSFORMER CKT 2 | 1/1/2009 | 6/1/2009 | Yes | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|---|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1352923 | 5BEE BR - QUITMAN 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | SST JOE - 161.00 - EVERTON 161KV CKT 1 | 12/1/2008 | 12/1/2008 | | | \$ - | \$ - |
| | ARKANSAS NUCLEAR ONE 161 - RUSSELLVILLE NORTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTR | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | EVERTON - HARRISON-EAST 161KV CKT 1 | 12/1/2008 | 12/1/2008 | | | \$ - | \$ - |
| | GRIMES - MT. ZION 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ - |
| | HARRISON-EAST - SUMMIT 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ - |
| | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 ENTR | 6/1/2010 | 6/1/2010 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE NORTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | 11/1/2008 | 11/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
AEPM AG3-2007-065

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| AEPM | 1352934 | CSWS | CSWS | 54 | 6/1/2010 | 6/1/2015 | | | \$ - | \$ - | \$ 504,825 | \$ - |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--|-----|-----|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1352934 | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | | | 6/1/2009 | 6/1/2010 | \$ 504,825 | \$ 2,500,000 | \$ - |
| | | | | | | Total | \$ 504,825 | \$ 2,500,000 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|----------|-----------------------|----------------------|
| 1352934 | ARKOMA - FT SMITHW 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | ARSENAL HILL - NORTH MARKET 69KV CKT 1 | 6/1/2010 | 6/1/2010 | | |
| | BULL SHOALS - BULL SHOALS 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | SALLISAW CAP BANK | 10/1/2008 | 6/1/2010 | | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--------------------------------------|----------|----------|-----------------------|----------------------|
| 1352934 | CLARKSVILLE - DARDANELLE 161KV CKT 1 | 6/1/2012 | 6/1/2012 | | |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|----------|----------|-----------------------|----------------------|
| 1352934 | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 #2 | 6/1/2010 | 6/1/2010 | | |
| | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 AEPW | 6/1/2010 | 6/1/2010 | | |
| | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 OKGE | 6/1/2010 | 6/1/2010 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|---|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1352934 | 5BEE BR - QUITMAN 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | 5CLINTN - CLINTON WEST (AECC) 161KV CKT 1 | 12/1/2012 | 12/1/2012 | | | \$ - | \$ - |
| | 5ST JOE 161.00 - EVERTON 161KV CKT 1 | 12/1/2008 | 12/1/2008 | | | \$ - | \$ - |
| | ARKANSAS NUCLEAR ONE 161 - RUSSELLVILLE NORTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTR | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | EVERTON - HARRISON-EAST 161KV CKT 1 | 12/1/2008 | 12/1/2008 | | | \$ - | \$ - |
| | HARRISON-EAST - SUMMIT 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ - |
| | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 ENTR | 6/1/2010 | 6/1/2010 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE NORTH 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | 11/1/2008 | 11/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
CMLP AG3-2007-047

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Available | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| CMLP | 1352181 | GRDA | CSWS | 115 | 6/1/2008 | 6/1/2042 | 6/1/2011 | 6/1/2045 | \$ 3,798,853 | \$ - | \$ 3,798,852 | \$ 18,838,946 |
| CMLP | 1352193 | GRDA | CSWS | 197 | 6/1/2008 | 6/1/2042 | 6/1/2011 | 6/1/2045 | \$ 4,500,000 | \$ - | \$ 10,825,614 | \$ 53,684,318 |
| | | | | | | | | | \$ 8,298,853 | \$ - | \$ 14,624,466 | \$ 72,523,264 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | |
|-------------|---|-----------|-----------|-----------------------|----------------------|----------------------|------------------|----------------------------|---------------|
| 1352181 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 107,815 | \$ 500,000 | \$ 523,415 | |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2014 | 6/1/2014 | | | \$ 24,655 | \$ 100,000 | \$ 102,362 | |
| | COFFEYVILLE FARMLAND - SOUTH COFFEYVILLE CITY 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 1,609,801 | \$ 6,200,000 | \$ 7,929,657 | |
| | COFFEYVILLE FARMLAND (COFAUTO1) 138/69/13.8KV TRANSFORMER CKT 1 | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - | \$ - | |
| | COFFEYVILLE FARMLAND (COFAUTO2) 138/69/13.8KV TRANSFORMER CKT 2 | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - | \$ - | |
| | COFFEYVILLE FARMLAND 138KV CAP BANK | 6/1/2010 | 6/1/2010 | | | \$ 61,167 | \$ 250,000 | \$ 314,425 | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 64,689 | \$ 300,000 | \$ 319,730 | |
| | COFFEYVILLE TAP - SOUTH COFFEYVILLE CITY 138KV CKT 1 | 6/1/2010 | 6/1/2011 | Yes | | \$ 1,557,872 | \$ 6,000,000 | \$ 7,673,862 | |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 318,881 | \$ 1,680,000 | \$ 1,700,856 | |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | No | | \$ 21,516 | \$ 85,922 | \$ 114,765 | |
| | NORTHEAST STATION - WATOVA 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 32,456 | \$ 125,000 | \$ 159,874 | |
| | | | | | | Total | \$ 3,798,852 | \$ 15,240,922 | \$ 18,838,946 |
| 1352193 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 307,419 | \$ 500,000 | \$ 1,492,443 | |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2014 | 6/1/2014 | | | \$ 70,299 | \$ 100,000 | \$ 291,866 | |
| | COFFEYVILLE FARMLAND - SOUTH COFFEYVILLE CITY 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 4,590,199 | \$ 6,200,000 | \$ 22,610,686 | |
| | COFFEYVILLE FARMLAND (COFAUTO1) 138/69/13.8KV TRANSFORMER CKT 1 | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - | \$ - | |
| | COFFEYVILLE FARMLAND (COFAUTO2) 138/69/13.8KV TRANSFORMER CKT 2 | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - | \$ - | |
| | COFFEYVILLE FARMLAND 138KV CAP BANK | 6/1/2010 | 6/1/2010 | | | \$ 167,854 | \$ 250,000 | \$ 862,844 | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 184,452 | \$ 300,000 | \$ 911,666 | |
| | COFFEYVILLE TAP - SOUTH COFFEYVILLE CITY 138KV CKT 1 | 6/1/2010 | 6/1/2011 | Yes | | \$ 4,442,128 | \$ 6,000,000 | \$ 21,881,309 | |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 909,368 | \$ 1,680,000 | \$ 4,850,410 | |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | No | | \$ 61,351 | \$ 85,922 | \$ 327,235 | |
| | NORTHEAST STATION - WATOVA 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 92,544 | \$ 125,000 | \$ 455,859 | |
| | | | | | | Total | \$ 10,825,614 | \$ 15,240,922 | \$ 53,684,318 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--------------------------|-----------|----------|-----------------------|----------------------|
| 1352181 | PRYAMID CORNERS CAPCITOR | 10/1/2008 | 6/1/2009 | No | |
| 1352193 | PRYAMID CORNERS CAPCITOR | 10/1/2008 | 6/1/2009 | No | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1352181 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEEVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| 1352193 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEEVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
CRGL AG3-2007-018

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| CRGL | 1340342 | KCPL | CLEC | 103 | 2/1/2008 | 2/1/2009 | 2/1/2011 | 2/1/2012 | \$ - | \$ 1,909,839 | \$ 2,947,000 | \$ 5,134,293 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | |
|-------------|---|----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|--------------|
| 1340342 | GRANDVIEW EAST - MARTIN CITY 161KV CKT 1 #2 | 6/1/2010 | 6/1/2010 | | | \$ 2,947,000 | \$ 4,700,000 | \$ 5,134,293 | |
| | | | | | | Total | \$ 2,947,000 | \$ 4,700,000 | \$ 5,134,293 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|-------------------|-----------|----------|-----------------------|----------------------|
| 1340342 | SALLISAW CAP BANK | 10/1/2008 | 6/1/2010 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1340342 | AVONDALE - GLADSTONE 161KV CKT 1 | 6/1/2010 | 6/1/2010 | | |
| | BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1 | 10/1/2008 | 6/1/2010 | | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---------------------------------|----------|----------|-----------------------|----------------------|
| 1340342 | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1340342 | 3GRENWD 115.00 - HUMPHREY 115KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | 3GRENWD 115.00 - TERREBONNE 115KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | 3RUSTNE 115.00 - DOWNSVILLE 115KV CKT 1 | 10/1/2008 | 10/1/2008 | 4/1/2008 | | \$ - | \$ - |
| | 3RUSTNE 115.00 - VIENNA 115KV CKT 1 | 10/1/2008 | 10/1/2008 | 4/1/2008 | | \$ - | \$ - |
| | 4EOPLOUS 138.00 - CHAMPAGNE 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | 4KSPRGS 138.00 - LINE 642 TAP 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | 4NCROWL 138.00 - SCOTT 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ - |
| | 4SCOTT 138.00 - 4SEMERE 138.00 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | 8WELLS 500.00 - WEBRE 500KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | 8WELLS 500.00/230KV TRANSFORMER CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | ADAMS CREEK - BOGALUSA 230KV CKT 2 | 10/1/2008 | 10/1/2008 | 4/1/2008 | | \$ - | \$ - |
| | CECELIA - DOC BONIN 138KV CKT 1 | 12/1/2009 | 12/1/2009 | | | \$ - | \$ - |
| | CECELIA - MORIL 138KV CKT 1 | 12/1/2009 | 12/1/2009 | | | \$ - | \$ - |
| | DOC BONIN - SCOTT 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | DOC BONIN 230/138KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | FRONT STREET - SLIDELL 230KV CKT 1 | 10/1/2008 | 10/1/2008 | 4/1/2008 | | \$ - | \$ - |
| | GIBSON - HUMPHREY 115KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | GIBSON - RAMOS 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | GIBSON 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | GRIMES - MT. ZION 138KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ - |
| | LINE 642 TAP - LIVONIA BULK 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | LIVONIA BULK - WILBERT 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | LOUISIANA STATION - WILBERT 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | \$ - | \$ - |
| | WATERFORD - WILLOW GLEN 500KV CKT 1 | 10/1/2008 | 10/1/2008 | 4/1/2008 | | \$ - | \$ - |
| | WATERFORD 500/230KV TRANSFORMER CKT 1 | 10/1/2008 | 10/1/2008 | 4/1/2008 | | \$ - | \$ - |

Total \$ - \$ - \$ -

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
CRGL AG3-2007-019

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| CRGL | 1340343 | OPPD | CLEC | 103 | 2/1/2008 | 2/1/2009 | 6/1/2010 | 6/1/2011 | \$ - | \$ 1,909,839 | \$ - | \$ - |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--------------|-----|-----|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1340343 | None | | | | | \$ - | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - | \$ - |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|-------------------|-----------|----------|-----------------------|----------------------|
| 1340343 | SALLISAW CAP BANK | 10/1/2008 | 6/1/2010 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---------------------------------------|----------|----------|-----------------------|----------------------|
| 1340343 | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|----------|----------|-----------------------|----------------------|
| 1340343 | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|---|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1340343 | 3GRENWD 115.00 - HUMPHREY 115KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | 3GRENWD 115.00 - TERREBONNE 115KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | 3RUSTNE 115.00 - DOWNSVILLE 115KV CKT 1 | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ - | \$ - | - |
| | 3RUSTNE 115.00 - VIENNA 115KV CKT 1 | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ - | \$ - | - |
| | 4EOPLOUS 138.00 - CHAMPAGNE 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | 4KSPRGS 138.00 - LINE 642 TAP 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | 4SCOTT2 138.00 - 4SEMERE 138.00 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | \$ - | \$ - | - |
| | 8WELLS 500.00 - WEBRE 500KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | 8WELLS 500.00 500/230KV TRANSFORMER CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | ADAMS CREEK - BOGALUSA 230KV CKT 2 | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ - | \$ - | - |
| | CECELIA - DOC BONIN 138KV CKT 1 | 12/1/2009 | 12/1/2009 | | \$ - | \$ - | - |
| | CECELIA - MORIL 138KV CKT 1 | 12/1/2009 | 12/1/2009 | | \$ - | \$ - | - |
| | DOC BONIN - SCOTT 138KV CKT 1 | 6/1/2009 | 6/1/2009 | | \$ - | \$ - | - |
| | DOC BONIN 230/138KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2009 | | \$ - | \$ - | - |
| | FRONT STREET - SLIDELL 230KV CKT 1 | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ - | \$ - | - |
| | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ - | \$ - | - |
| | GIBSON - HUMPHREY 115KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | GIBSON - RAMOS 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | GIBSON 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | LINE 642 TAP - LIVONIA BULK 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | LIVONIA BULK - WILBERT 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | LOUISIANA STATION - WILBERT 138KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | \$ - | \$ - | - |
| | WATERFORD - WILLOW GLEN 500KV CKT 1 | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ - | \$ - | - |
| | WATERFORD 500/230KV TRANSFORMER CKT 1 | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ - | \$ - | - |
| | | | | Total | \$ - | \$ - | - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
EDE AG3-2007-037

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|-----|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| EDE | 1350960 | KCPL | EDE | 5 | 11/1/2008 | 11/1/2018 | 6/1/2010 | 6/1/2020 | \$ 27,902 | \$ - | \$ 72,420 | \$ 61,240 |
| | | | | | | | | | \$ 27,902 | \$ - | \$ 72,420 | \$ 61,240 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|---|----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1350960 | Craig 161KV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 20,567 | \$ 900,000 | \$ 46,660 |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | 6/1/2009 | 6/1/2010 | | Yes | \$ 44,518 | \$ 2,500,000 | \$ - |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2012 | 6/1/2012 | | | \$ 5,639 | \$ 180,000 | \$ 10,871 |
| | SUB 124 - AURORA H.T. - SUB 152 - MONETT H.T. 69KV CKT 1 Displacement | 6/1/2005 | 6/1/2009 | | | \$ 106 | \$ 214 | \$ 232 |
| | SUB 152 - MONETT H.T. - SUB 383 - MONETT 69KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | | \$ 1,590 | \$ 3,202 | \$ 3,477 |
| | | | | | | Total | \$ 72,420 | \$ 3,583,416 |
| | | | | | | | | \$ 61,240 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|----------|----------|-----------------------|----------------------|
| 1350960 | AFTON (AFTAUT01) 161/69/13.8KV TRANSFORMER CKT 1 | 6/1/2009 | 6/1/2010 | | |
| | BULL SHOALS - BULL SHOALS 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | Craig 161kv 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1 EMDE | 6/1/2014 | 6/1/2014 | | |
| | SUB 383 - MONETT - SUB 376 - MONETT CITY SOUTH 161/69/12.5KV TRANSFORMER CKT 1 | 6/1/2017 | 6/1/2017 | | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1350960 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | JOPLIN 59 - SUB 439 - STATELINE 161KV CKT 1 | 6/1/2010 | 6/1/2012 | | |
| | JOPLIN 59 - SUB 59 - JOPLIN 26TH ST. 161/69KV TRANSFORMER CKT 1 | 6/1/2010 | 6/1/2012 | | |
| | MIDWAY - ST JOE 161KV CKT 1 | 12/1/2012 | 12/1/2012 | | |
| | SOUTHWEST - SOUTHWEST DISPOSAL 161KV CKT 1 | 6/1/2014 | 6/1/2014 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | | |
| | SUB 145 - JOPLIN WEST 7TH - SUB 439 - STATELINE 161KV CKT 1 | 6/1/2017 | 6/1/2017 | | |
| | SUB 145 - JOPLIN WEST 7TH - SUB 64 - JOPLIN 10TH ST. 69KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | SUB 170 - NICHOLS ST. - SUB 80 - MARSHFIELD JCT. 69KV CKT 1 | 6/1/2012 | 6/1/2012 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|----------|----------|-----------------------|----------------------|
| 1350960 | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2012 | 6/1/2012 | | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|---|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1350960 | 5BEE BR - QUITMAN 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | 5CLINTN - CLINTON WEST (AECC) 161KV CKT 1 | 12/1/2012 | 12/1/2012 | | | \$ - | \$ - |
| | 5ST JOE 161.00 - EVERTON 161KV CKT 1 | 12/1/2008 | 12/1/2008 | | | \$ - | \$ - |
| | CLINTON - HOLDEN 161KV CKT 1 | 6/1/2017 | 6/1/2017 | | | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTR | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | EVERTON - HARRISON-EAST 161KV CKT 1 | 12/1/2008 | 12/1/2008 | | | \$ - | \$ - |
| | HARRISON-EAST - SUMMIT 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ - |
| | HUBEN (HUBEN) 345/161/13.8KV TRANSFORMER CKT 1 | 12/1/2012 | 12/1/2012 | | | \$ - | \$ - |
| | JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1 AECI | 6/1/2014 | 6/1/2014 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | 11/1/2008 | 11/1/2008 | | | \$ - | \$ - |
| | | | | | | Total | \$ - |
| | | | | | | | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
EDE AG3-2007-046

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Available | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|-----|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| EDE | 1352109 | KCPL | EDE | 5 | 1/1/2010 | 1/1/2030 | | | \$ 27,926 | \$ - | \$ 72,444 | \$ 95,977 |
| | | | | | | | | | \$ 27,926 | \$ - | \$ 72,444 | \$ 95,977 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|---|----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1352109 | Craig 161KV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 20,567 | \$ 900,000 | \$ 73,180 |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | 6/1/2009 | 6/1/2010 | | | \$ 44,518 | \$ 2,500,000 | \$ - |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2012 | 6/1/2012 | | | \$ 5,639 | \$ 180,000 | \$ 16,933 |
| | SUB 124 - AURORA H.T. - SUB 152 - MONETT H.T. 69KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | | \$ 108 | \$ 214 | \$ 367 |
| | SUB 152 - MONETT H.T. - SUB 383 - MONETT 69KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | | \$ 1,612 | \$ 3,202 | \$ 5,497 |
| | | | | | | Total | \$ 72,444 | \$ 3,583,416 |
| | | | | | | | | \$ 95,977 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|----------|----------|-----------------------|----------------------|
| 1352109 | BULL SHOALS - BULL SHOALS 161KV CKT 1 | 6/1/2009 | 6/1/2011 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1 EMDE | 6/1/2014 | 6/1/2014 | | |
| | SUB 383 - MONETT - SUB 376 - MONETT CITY SOUTH 161/69/12.5KV TRANSFORMER CKT 1 | 6/1/2017 | 6/1/2017 | | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1352109 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | JOPLIN 59 - SUB 439 - STATELINE 161KV CKT 1 | 6/1/2010 | 6/1/2012 | | |
| | JOPLIN 59 - SUB 59 - JOPLIN 26TH ST. 161/69KV TRANSFORMER CKT 1 | 6/1/2010 | 6/1/2012 | | |
| | MIDWAY - ST. JOE 161KV CKT 1 | 12/1/2012 | 12/1/2012 | | |
| | SOUTHWEST - SOUTHWEST DISPOSAL 161KV CKT 1 | 6/1/2014 | 6/1/2014 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | | |
| | SUB 145 - JOPLIN WEST 7TH - SUB 439 - STATELINE 161KV CKT 1 | 6/1/2017 | 6/1/2017 | | |
| | SUB 145 - JOPLIN WEST 7TH - SUB 64 - JOPLIN 10TH ST. 69KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | SUB 170 - NICHOLS ST. - SUB 80 - MARSHFIELD JCT. 69KV CKT 1 | 6/1/2012 | 6/1/2012 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|----------|----------|-----------------------|----------------------|
| 1352109 | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2012 | 6/1/2012 | | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|---|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1352109 | 5BEE BR - QUITMAN 161KV CKT 1 | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | 5CLINTN - CLINTON WEST (AECC) 161KV CKT 1 | 12/1/2012 | 12/1/2012 | | | \$ - | \$ - |
| | 5ST JOE 161.00 - EVERTON 161KV CKT 1 | 12/1/2008 | 12/1/2008 | | | \$ - | \$ - |
| | CLINTON - HOLDEN 161KV CKT 1 | 6/1/2017 | 6/1/2017 | | | \$ - | \$ - |
| | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTR | 6/1/2009 | 6/1/2009 | | | \$ - | \$ - |
| | EVERTON - HARRISON-EAST 161KV CKT 1 | 12/1/2008 | 12/1/2008 | | | \$ - | \$ - |
| | HARRISON-EAST - SUMMIT 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ - | \$ - |
| | HUBEN (HUBEN) 345/161/13.8KV TRANSFORMER CKT 1 | 12/1/2012 | 12/1/2012 | | | \$ - | \$ - |
| | JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1 AECI | 6/1/2014 | 6/1/2014 | | | \$ - | \$ - |
| | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | 11/1/2008 | 11/1/2008 | | | \$ - | \$ - |
| | | | | | | Total | \$ - |
| | | | | | | | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
GRDA AG3-2007-034

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| GRDA | 1350396 | OKGE | GRDA | 150 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ - | \$ - | \$ - |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--------------|-----|-----|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1350396 | None | | | | | \$ - | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - | \$ - |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|----------|-----------------------|----------------------|
| 1350396 | CLAREMORE (CLRAUTO1) 161/69/13.8KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAREMORE (CLRAUTO2) 161/69/13.8KV TRANSFORMER CKT 2 | 10/1/2008 | 6/1/2011 | Yes | |
| | PRYAMID CORNERS CAPCITOR | 10/1/2008 | 6/1/2009 | No | |
| | SALLSAW CAP BANK | 10/1/2008 | 6/1/2010 | No | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---------------------------------------|----------|----------|-----------------------|----------------------|
| 1350396 | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | No |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
KBPUS AG3-2007-017D

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| KBPUS | 1339117 | MPS | KACY | 5 | 2/1/2008 | 2/1/2009 | 6/1/2013 | 6/1/2014 | \$ - | \$ 52,800 | \$ 507,565 | \$ 1,082,811 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|---|----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1339117 | Craig 161KV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 6,119 | \$ 900,000 | \$ 14,445 |
| | GRANDVIEW EAST - MARTIN CITY 161KV CKT 1 #2 | 6/1/2010 | 6/1/2010 | | | \$ 498,504 | \$ 4,700,000 | \$ 1,062,473 |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2012 | 6/1/2012 | | | \$ 2,942 | \$ 180,000 | \$ 5,893 |
| | | Total | | | | \$ 507,565 | \$ 5,780,000 | \$ 1,082,811 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1339117 | BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2009 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1339117 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1 | 10/1/2008 | 6/1/2010 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2013 | | |
| | SIBLEY 161/69KV TRANSFORMER CKT 2 | 10/1/2008 | 6/1/2010 | | |
| | South Harper - Freeman 69 kV | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|----------|----------|-----------------------|----------------------|
| 1339117 | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2012 | 6/1/2012 | | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KCPS AG3-2007-074

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Available | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| KCPS | 1353013 | KCPL | KCPL | 45 | 11/1/2008 | 11/1/2018 | 2/1/2011 | 2/1/2021 | \$ 554,036 | \$ - | \$ 554,036 | \$ 1,393,397 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|---|----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1353013 | Craig 161KV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 284,592 | \$ 900,000 | \$ 699,801 |
| | MERRIAM - ROELAND PARK 161KV CKT 1 Displacement | 6/1/2011 | 6/1/2011 | | | \$ 184,521 | \$ 669,819 | \$ 516,394 |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2012 | 6/1/2012 | | | \$ 84,923 | \$ 180,000 | \$ 177,202 |
| | | | | Total | | \$ 554,036 | \$ 1,749,819 | \$ 1,393,397 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1353013 | ANTIOCH - OXFORD 161KV CKT 1 | 6/1/2017 | 6/1/2017 | 12/1/2008 | |
| | BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2009 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|----------|-----------------------|----------------------|
| 1353013 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | AVONDALE - GLADSTONE 161KV CKT 1 | 6/1/2010 | 6/1/2010 | | |
| | BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1 | 10/1/2008 | 6/1/2010 | | Yes |
| | CRAIG - LENEXA SOUTH 161KV CKT 1 Displacement | 6/1/2017 | 6/1/2017 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2013 | | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|------------------------------------|----------|----------|-----------------------|----------------------|
| 1353013 | COOK - ST JOE 161KV CKT 1 | 6/1/2012 | 6/1/2012 | 6/1/2010 | |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2012 | 6/1/2012 | | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
 KCPS AG3-2007-075A

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements | |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|--------------|
| KCPS | 1353028 | WPEK | KCPL | 50 | 6/1/2008 | 6/1/2009 | 6/1/2013 | 6/1/2014 | \$ - | \$ 528,000 | \$ 2,816,371 | \$ 4,668,904 | |
| | | | | | | | | | | \$ - | \$ 528,000 | \$ 2,816,371 | \$ 4,668,904 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | |
|-------------|---|-----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|--------------|
| 1353028 | CLIFTON - GREENLEAF 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 1,389,339 | \$ 3,598,794 | \$ 2,184,896 | |
| | G06-21T 138.00 - HARPER 138KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 425,737 | \$ 6,035,477 | \$ 744,462 | |
| | GRANDVIEW EAST - MARTIN CITY 161KV CKT 1 #2 | 6/1/2010 | 6/1/2010 | | | \$ 334,292 | \$ 4,700,000 | \$ 597,630 | |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ 23,807 | \$ 337,500 | \$ 44,583 | |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 515,715 | \$ 6,497,822 | \$ 811,021 | |
| | MERRIAM - ROELAND PARK 161KV CKT 1 Displacement | 6/1/2011 | 6/1/2011 | | | \$ 127,481 | \$ 669,819 | \$ 286,312 | |
| | | | | | | Total | \$ 2,816,371 | \$ 21,839,412 | \$ 4,668,904 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1353028 | BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2009 | 6/1/2009 | Yes |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | NORTH CIMARRON 115KV Capacitor | 6/1/2009 | 6/1/2009 | 12/1/2008 | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|----------|-----------------------|----------------------|
| 1353028 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2013 | Yes | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1353028 | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | COOK - ST JOE 161KV CKT 1 | 6/1/2012 | 6/1/2012 | 6/1/2010 | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | Yes | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | Yes | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | Yes | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | Yes | |
| | GRANDVIEW EAST - SAMPSON 161KV CKT 1 #1 | 12/1/2012 | 12/1/2012 | 6/1/2010 | |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2012 | 6/1/2012 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LONGVIEW - SAMPSON 161KV CKT 1 #1 | 12/1/2012 | 12/1/2012 | 6/1/2010 | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
KEPC AG3-2007-064

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Available | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| KEPC | 1352933 | WR | KCPL | 15 | 6/1/2008 | 6/1/2040 | 6/1/2013 | 6/1/2045 | \$ 2,700,000 | \$ - | \$ 7,080,972 | \$ 31,302,441 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|---|-----------|-----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1352933 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 108,120 | \$ 550,000 | \$ 536,355 |
| | Craig 161kv /add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 38,869 | \$ 900,000 | \$ 190,547 |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 118,663 | \$ 1,680,000 | \$ 576,071 |
| | GRANDVIEW EAST - MARTIN CITY 161KV CKT 1 #2 | 6/1/2010 | 6/1/2010 | | | \$ 920,205 | \$ 4,700,000 | \$ 4,037,343 |
| | GRANDVIEW EAST - SAMPSION 161KV CKT 1 #2 | 12/1/2012 | 12/1/2012 | 6/1/2010 | | \$ 3,225,000 | \$ 3,225,000 | \$ 14,149,490 |
| | LONGVIEW - SAMPSION 161KV CKT 1 #2 | 12/1/2012 | 12/1/2012 | 6/1/2010 | | \$ 2,550,000 | \$ 2,550,000 | \$ 11,187,969 |
| | MERRIAM - ROELAND PARK 161KV CKT 1 Displacement | 6/1/2011 | 6/1/2011 | | | \$ 88,863 | \$ 669,819 | \$ 495,798 |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2012 | 6/1/2012 | | | \$ 31,252 | \$ 180,000 | \$ 128,868 |
| | | | | | Total | \$ 7,080,972 | \$ 14,454,819 | \$ 31,302,441 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1352933 | ANTIOCH - OXFORD 161KV CKT 1 | 6/1/2017 | 6/1/2017 | 12/1/2008 | |
| | BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2009 | | Yes |
| | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV /50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | LAWRENCE HILL - MOCKINGBIRD HILL SWITCHING STATION 115KV CKT 1 | 6/1/2017 | 6/1/2017 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 KV | 10/1/2008 | 12/1/2009 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|----------|-----------------------|----------------------|
| 1352933 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| | CRAIG - LENEXA SOUTH 161KV CKT 1 Displacement | 6/1/2017 | 6/1/2017 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #2 | 6/1/2016 | 6/1/2016 | | |
| | HOOVER NORTH - LAKERIDGE 138KV CKT 1 | 6/1/2016 | 6/1/2016 | | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | | |
| | MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2013 | Yes | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1352933 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COOK - ST JOE 161KV CKT 1 | 6/1/2012 | 6/1/2012 | 6/1/2010 | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | GRANDVIEW EAST - SAMPSION 161KV CKT 1 #1 | 12/1/2012 | 12/1/2012 | 6/1/2010 | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2012 | 6/1/2012 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | LONGVIEW - SAMPSION 161KV CKT 1 #1 | 12/1/2012 | 12/1/2012 | 6/1/2010 | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | Yes |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|----------------------|-----------|-----------|-----------------------|----------------------|
| 1352933 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
KEPC AG3-2007-066

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Available | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|-----|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| KEPC | 1352938 | WR | WR | 68 | 6/1/2008 | 6/1/2040 | 6/1/2011 | 6/1/2043 | \$ 1,428,491 | \$ - | \$ 1,428,491 | \$ 7,985,888 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | |
|-------------|---|-----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|--------------|
| 1352938 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 301,276 | \$ 550,000 | \$ 1,686,019 | |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 50,444 | \$ 900,000 | \$ 286,416 | |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 224,687 | \$ 1,680,000 | \$ 1,230,909 | |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 288,416 | \$ 2,011,826 | \$ 1,554,547 | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | | | \$ 547,033 | \$ 3,825,000 | \$ 3,143,961 | |
| | PLANT X STATION - TOLK STATION EAST 230KV CKT 2 | 12/1/2009 | 6/1/2010 | 4/1/2010 | Yes | \$ 8,369 | \$ 56,000 | \$ 42,278 | |
| | PLANT X STATION - TOLK STATION WEST 230KV CKT 1 | 12/1/2009 | 6/1/2010 | 4/1/2010 | Yes | \$ 8,266 | \$ 56,000 | \$ 41,758 | |
| | | | | | | Total | \$ 1,428,491 | \$ 9,078,826 | \$ 7,985,888 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1352938 | ANTIOCH - OXFORD 161KV CKT 1 | 6/1/2017 | 6/1/2017 | 12/1/2008 | |
| | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2016 | 6/1/2016 | | |
| | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161kV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | LAWRENCE HILL - MOCKINGBIRD HILL SWITCHING STATION 115KV CKT 1 | 6/1/2017 | 6/1/2017 | | |
| | NORTH CIMARRON 115KV Capacitor | 6/1/2009 | 6/1/2009 | 12/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | ST JOHN CAPACITOR | 6/1/2016 | 6/1/2016 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|----------|-----------------------|----------------------|
| 1352938 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| | Craig 161kV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #2 | 6/1/2016 | 6/1/2016 | | |
| | HOOVER NORTH - LAKERIDGE 138KV CKT 1 | 6/1/2016 | 6/1/2016 | | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|----------|----------|-----------------------|----------------------|
| 1352938 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|----------------------|-----------|-----------|-----------------------|----------------------|
| 1352938 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--------------|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1352938 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ - | \$ - | |
| | | | | Total | \$ - | \$ - | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
KMEA AG3-2007-104

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| KMEA | 1355377 | OPPD | KCPL | 20 | 1/1/2009 | 1/1/2013 | 6/1/2010 | 6/1/2014 | \$ - | \$ - | \$ 72,450 | \$ 139,557 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|---|----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1355377 | Craig 161KV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 69,078 | \$ 900,000 | \$ 133,988 |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2012 | 6/1/2012 | | | \$ 3,372 | \$ 180,000 | \$ 5,569 |
| | | | | | | Total | \$ 72,450 | \$ 1,080,000 |
| | | | | | | | | \$ 139,557 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|-----------------------------|----------|----------|-----------------------|----------------------|
| 1355377 | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1355377 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1 | 10/1/2008 | 6/1/2010 | | Yes |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|----------|----------|-----------------------|----------------------|
| 1355377 | COOK - ST JOE 161KV CKT 1 | 6/1/2012 | 6/1/2012 | 6/1/2010 | |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2012 | 6/1/2012 | | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--------------|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1355377 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | 4/1/2008 | | \$ - | \$ - |
| | | | | | | Total | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Study Number | KPP | Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|--|---|-----------|-----------|-----------------------|----------------------|----------------------|------------------|----------------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| KPP | | | | 1351224 | WR | WR | 4 | 2/1/2008 | 2/1/2018 | 6/1/2011 | 6/1/2021 | \$ 22,975 | \$ - | \$ 22,975 | \$ 54,940 |
| | | | | | | | | | | | | | | \$ 22,975 | \$ 54,940 |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | | | | | | | |
| 1351224 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 4,608 | \$ 500,000 | \$ 10,427 | | | | | | | |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2014 | 6/1/2014 | | | \$ 311 | \$ 100,000 | \$ 602 | | | | | | | |
| | COFFEYVILLE FARMLAND 138KV CAP BANK | 6/1/2010 | 6/1/2010 | | | \$ 894 | \$ 250,000 | \$ 2,141 | | | | | | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 2,765 | \$ 300,000 | \$ 6,370 | | | | | | | |
| | Craig 161KV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 4,913 | \$ 900,000 | \$ 12,081 | | | | | | | |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 272 | \$ 85,922 | \$ 720 | | | | | | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 9,212 | \$ 3,825,000 | \$ 22,599 | | | | | | | |
| | | | | Total | | \$ 22,975 | \$ 5,960,922 | \$ 54,940 | | | | | | | |
| Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | | | | | | | | | | |
| 1351224 | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | | | | | | | | | | | |
| | Fort Scott - SW Bourbon 161 KV | 6/1/2017 | 6/1/2017 | | | | | | | | | | | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | | | | | | | | | | | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | | | | | | | | | | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | | | | | | | | | | | |
| | ROSE HILL JUNCTION - WEAVER 69KV CKT 1 | 10/1/2008 | 12/1/2008 | | | | | | | | | | | | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | | | | | | | | | | | | |
| | Summit - NE Saline 115 kv | 10/1/2008 | 12/1/2009 | Yes | | | | | | | | | | | |
| Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | | | | | | | | | | |
| 1351224 | BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115kV | 6/1/2009 | 6/1/2011 | Yes | | | | | | | | | | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | | | | | | | | | | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes | | | | | | | | | | |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | | | | | | | | | | | | |
| Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | | | | | | | | | | |
| 1351224 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | | | | | | | | | | | |
| | ARKANSAS CITY - PARIS 69KV CKT 1 #1 Displacement | 6/1/2016 | 6/1/2016 | 6/1/2009 | | | | | | | | | | | |
| | ASH GROVE JCT2 - TIOGA 69KV CKT 1 | 6/1/2017 | 6/1/2017 | 6/1/2011 | | | | | | | | | | | |
| | Athens to Owl Creek 69 KV | 6/1/2011 | 6/1/2011 | | | | | | | | | | | | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | | | | | | | | | | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | | | | | | | | | | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | | | | | | | | | | | |
| | CHANUTE TAP - TIOGA 69KV CKT 1 | 6/1/2017 | 6/1/2017 | 6/1/2011 | | | | | | | | | | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | | | | | | | | | | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 12/1/2008 | 6/1/2010 | | | | | | | | | | | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | 12/1/2008 | 6/1/2010 | | | | | | | | | | | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | 12/1/2008 | 6/1/2010 | | | | | | | | | | | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | | | | | | | | | | | |
| | CRESWELL - OAK 69KV CKT 1 #1 Displacement | 6/1/2014 | 6/1/2014 | 6/1/2009 | | | | | | | | | | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | Yes | | | | | | | | | | | |
| | East Manhattan - SW Manhattan 115KV Displacement | 6/1/2009 | 6/1/2011 | Yes | | | | | | | | | | | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | Yes | | | | | | | | | | | |
| | East Manhattan to McDowell 230 KV Displacement | 6/1/2009 | 6/1/2011 | Yes | | | | | | | | | | | |
| | Green to Vernon 69 KV | 6/1/2011 | 6/1/2011 | | | | | | | | | | | | |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2012 | 6/1/2012 | | | | | | | | | | | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | | | | | | | | | | | |
| | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | 6/1/2014 | 6/1/2014 | | | | | | | | | | | | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | | | | | | | | | | | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 10/1/2008 | 6/1/2011 | | | | | | | | | | | | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | | | | | | | | | | | |
| | Vernon to Athens 69 KV | 6/1/2011 | 6/1/2011 | | | | | | | | | | | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | | | | | | | | | | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|----------------------|-----------|-----------|-----------------------|----------------------|
| 1351224 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--------------|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1351224 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | 4/1/2008 | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
MIDW AG3-2007-082

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|-----|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| MIDW | 1353081 | WR | WR | 5 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 472,500 | \$ 64,018 | \$ 157,566 |
| MIDW | 1353082 | WR | WR | 4 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 378,000 | \$ 51,213 | \$ 126,049 |
| MIDW | 1353083 | WR | WR | 3 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 283,500 | \$ 38,409 | \$ 94,536 |
| MIDW | 1353084 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 189,000 | \$ 25,607 | \$ 63,024 |
| MIDW | 1353085 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 94,500 | \$ 12,804 | \$ 31,514 |
| | | | | | | | | | \$ - | \$ 1,417,500 | \$ 192,051 | \$ 472,689 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--|-----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1353081 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 22,740 | \$ 550,000 | \$ 58,901 |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 2,906 | \$ 900,000 | \$ 6,801 |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 17,026 | \$ 1,680,000 | \$ 43,164 |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 7,369 | \$ 2,011,826 | \$ 16,106 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 13,977 | \$ 3,825,000 | \$ 32,594 |
| | | | | Total | | \$ 64,018 | \$ 8,966,826 | \$ 157,566 |
| 1353082 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 18,192 | \$ 550,000 | \$ 47,121 |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 2,324 | \$ 900,000 | \$ 5,439 |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 13,621 | \$ 1,680,000 | \$ 34,531 |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 5,695 | \$ 2,011,826 | \$ 12,884 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 11,181 | \$ 3,825,000 | \$ 26,074 |
| | | | | Total | | \$ 51,213 | \$ 8,966,826 | \$ 126,049 |
| 1353083 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 13,644 | \$ 550,000 | \$ 35,341 |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 1,743 | \$ 900,000 | \$ 4,079 |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 10,215 | \$ 1,680,000 | \$ 25,897 |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 4,421 | \$ 2,011,826 | \$ 9,663 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 8,386 | \$ 3,825,000 | \$ 19,556 |
| | | | | Total | | \$ 38,409 | \$ 8,966,826 | \$ 94,536 |
| 1353084 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 9,096 | \$ 550,000 | \$ 23,560 |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 1,162 | \$ 900,000 | \$ 2,719 |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 6,810 | \$ 1,680,000 | \$ 17,264 |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 2,948 | \$ 2,011,826 | \$ 6,443 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 5,591 | \$ 3,825,000 | \$ 13,038 |
| | | | | Total | | \$ 25,607 | \$ 8,966,826 | \$ 63,024 |
| 1353085 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 4,548 | \$ 550,000 | \$ 11,780 |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 581 | \$ 900,000 | \$ 1,360 |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 3,405 | \$ 1,680,000 | \$ 8,632 |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 1,474 | \$ 2,011,826 | \$ 3,222 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 2,796 | \$ 3,825,000 | \$ 6,520 |
| | | | | Total | | \$ 12,804 | \$ 8,966,826 | \$ 31,514 |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1353081 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PHILLIPSBURG - RHOADES 115 KV | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | Yes | |
| 1353082 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PHILLIPSBURG - RHOADES 115 KV | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | Yes | |
| 1353083 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PHILLIPSBURG - RHOADES 115 KV | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | Yes | |
| 1353084 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PHILLIPSBURG - RHOADES 115 KV | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | Yes | |
| 1353085 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PHILLIPSBURG - RHOADES 115 KV | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | Yes | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1353081 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |
| 1353082 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |
| 1353083 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |
| 1353084 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |
| 1353085 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1353081 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to McDowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | | Yes |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | Yes |
| 1353082 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to McDowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | | Yes |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | Yes |
| 1353083 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to McDowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | | Yes |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | Yes |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| | | | | | |
|---------|---|-----------|-----------|----------|-----|
| 1353084 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWell 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWell 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |
| 1353085 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWell 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWell 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|----------------------|-----------|-----------|-----------------------|----------------------|
| 1353081 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |
| 1353082 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |
| 1353083 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |
| 1353084 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |
| 1353085 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Potential reservation deferral and redispatch requirement on the following upgrades due to positive MW Impact on limitations that require upgrade. No cost assignment due to negative MW impact on defined upgrade.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available |
|-------------|--------------------------------------|-----------|----------|-----------------------------|----------------------|
| 1353081 | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | No | |
| 1353082 | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | No | |
| 1353083 | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | No | |
| 1353084 | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | No | |
| 1353085 | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | No | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service | Redispatch | Allocated E & | Total E & C |
|-------------|--------------|-----------|-----------|------------------|------------|---------------|-------------|
| | | | | Date | Available | C Cost | Cost |
| 1353081 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ | - | - |
| | | | | | Total | \$ | - |
| 1353082 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ | - | - |
| | | | | | Total | \$ | - |
| 1353083 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ | - | - |
| | | | | | Total | \$ | - |
| 1353084 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ | - | - |
| | | | | | Total | \$ | - |
| 1353085 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | 4/1/2008 | \$ | - | - |
| | | | | | Total | \$ | - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
MIDW AG3-2007-083

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|-----|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| MIDW | 1353086 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 94,500 | \$ 16,118 | \$ 38,985 |
| MIDW | 1353088 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 189,000 | \$ 32,236 | \$ 77,972 |
| | | | | | | | | | \$ - | \$ 283,500 | \$ 48,354 | \$ 116,957 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--|-----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1353086 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 4,270 | \$ 550,000 | \$ 11,060 |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 637 | \$ 900,000 | \$ 1,491 |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 3,378 | \$ 1,680,000 | \$ 8,564 |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1 | \$ 85,922 | \$ 2 |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 2,704 | \$ 2,011,826 | \$ 5,910 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 5,128 | \$ 3,825,000 | \$ 11,958 |
| | | | | | Total | \$ 16,118 | \$ 9,052,748 | \$ 38,985 |
| 1353088 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 8,541 | \$ 550,000 | \$ 22,123 |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 1,274 | \$ 900,000 | \$ 2,981 |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 6,757 | \$ 1,680,000 | \$ 17,130 |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1 | \$ 85,922 | \$ 3 |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 5,407 | \$ 2,011,826 | \$ 11,818 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 10,256 | \$ 3,825,000 | \$ 23,917 |
| | | | | | Total | \$ 32,236 | \$ 9,052,748 | \$ 77,972 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1353086 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161kV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 KV | 10/1/2008 | 12/1/2009 | Yes | |
| 1353088 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161kV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 KV | 10/1/2008 | 12/1/2009 | Yes | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1353086 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | Craig 161kV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |
| 1353088 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | Craig 161kV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1353086 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to McDowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |
| 1353088 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to McDowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|----------------------|-----------|-----------|-----------------------|----------------------|
| 1353086 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |
| 1353088 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--------------|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1353086 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |
| 1353088 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
MIDW AG3-2007-084

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|-------------|--|-----------|----------|-----------------------|----------------------|----------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| MIDW | 1353090 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 94,500 | \$ 14,858 | \$ 36,117 |
| MIDW | 1353091 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 189,000 | \$ 29,712 | \$ 72,226 |
| MIDW | 1353092 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 189,000 | \$ 29,712 | \$ 72,226 |
| | | | | | | | | | \$ - | \$ 472,500 | \$ 74,282 | \$ 180,569 |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | | | | |
| 1353090 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2013 | 6/1/2011 | | | \$ 4,281 | \$ 550,000 | \$ 11,115 | | | | |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 625 | \$ 900,000 | \$ 1,463 | | | | |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 3,384 | \$ 1,680,000 | \$ 8,579 | | | | |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1 | \$ 85,922 | \$ 1 | | | | |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 2,264 | \$ 2,011,826 | \$ 4,948 | | | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 4,293 | \$ 3,825,000 | \$ 10,011 | | | | |
| | | | | Total | | \$ 14,858 | \$ 9,052,748 | \$ 36,117 | | | | |
| 1353091 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 8,580 | \$ 550,000 | \$ 22,224 | | | | |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 1,250 | \$ 900,000 | \$ 2,925 | | | | |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 6,767 | \$ 1,680,000 | \$ 17,155 | | | | |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1 | \$ 85,922 | \$ 2 | | | | |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 4,527 | \$ 2,011,826 | \$ 9,895 | | | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 8,587 | \$ 3,825,000 | \$ 20,025 | | | | |
| | | | | Total | | \$ 29,712 | \$ 9,052,748 | \$ 72,226 | | | | |
| 1353092 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 8,580 | \$ 550,000 | \$ 22,224 | | | | |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 1,250 | \$ 900,000 | \$ 2,925 | | | | |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 6,767 | \$ 1,680,000 | \$ 17,155 | | | | |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1 | \$ 85,922 | \$ 2 | | | | |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 4,527 | \$ 2,011,826 | \$ 9,895 | | | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 8,587 | \$ 3,825,000 | \$ 20,025 | | | | |
| | | | | Total | | \$ 29,712 | \$ 9,052,748 | \$ 72,226 | | | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1353090 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | | Yes |
| 1353091 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | | Yes |
| 1353092 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | | Yes |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1353090 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |
| 1353091 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |
| 1353092 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | Yes |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1353090 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |
| 1353091 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |
| 1353092 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to Mcdowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|----------------------|-----------|-----------|-----------------------|----------------------|
| 1353090 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |
| 1353091 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |
| 1353092 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--------------|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1353090 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |
| 1353091 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |
| 1353092 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
MIDW AG3-2007-086

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|-------------|--|-----------|----------|-----------------------|----------------------|----------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| MIDW | 1353097 | WR | WR | 3 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 283,500 | \$ 205,263 | \$ 420,493 |
| MIDW | 1353098 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 189,000 | \$ 136,843 | \$ 280,332 |
| MIDW | 1353099 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 94,500 | \$ 68,423 | \$ 140,168 |
| <hr/> | | | | | | | | | | | | |
| <hr/> | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | | | | |
| 1353097 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2013 | 6/1/2011 | | | \$ 12,707 | \$ 550,000 | \$ 32,914 | | | | |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 2,186 | \$ 900,000 | \$ 5,116 | | | | |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 10,090 | \$ 1,680,000 | \$ 25,580 | | | | |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 2 | \$ 85,922 | \$ 5 | | | | |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 16,322 | \$ 2,011,826 | \$ 35,674 | | | | |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 132,998 | \$ 6,497,822 | \$ 249,011 | | | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 30,958 | \$ 3,825,000 | \$ 72,193 | | | | |
| | | | | Total | | \$ 205,263 | \$ 15,550,570 | \$ 420,493 | | | | |
| 1353098 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 8,471 | \$ 550,000 | \$ 21,942 | | | | |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 1,458 | \$ 900,000 | \$ 3,412 | | | | |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 6,727 | \$ 1,680,000 | \$ 17,054 | | | | |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1 | \$ 85,922 | \$ 3 | | | | |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 10,882 | \$ 2,011,826 | \$ 23,784 | | | | |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 88,665 | \$ 6,497,822 | \$ 166,007 | | | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 20,639 | \$ 3,825,000 | \$ 48,130 | | | | |
| | | | | Total | | \$ 136,843 | \$ 15,550,570 | \$ 280,332 | | | | |
| 1353099 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 4,236 | \$ 550,000 | \$ 10,972 | | | | |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 729 | \$ 900,000 | \$ 1,706 | | | | |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 3,364 | \$ 1,680,000 | \$ 8,528 | | | | |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1 | \$ 85,922 | \$ 2 | | | | |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 5,441 | \$ 2,011,826 | \$ 11,892 | | | | |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 44,333 | \$ 6,497,822 | \$ 83,004 | | | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 10,319 | \$ 3,825,000 | \$ 24,064 | | | | |
| | | | | Total | | \$ 68,423 | \$ 15,550,570 | \$ 140,168 | | | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1353097 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | | Yes |
| 1353098 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | | Yes |
| 1353099 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | | Yes |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1353097 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| 1353098 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| 1353099 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1353097 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to McDowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |
| 1353098 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to McDowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |
| 1353099 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to McDowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|----------------------|-----------|-----------|-----------------------|----------------------|
| 1353097 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |
| 1353098 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |
| 1353099 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--------------|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1353097 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |
| 1353098 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |
| 1353099 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
MIDW AG3-2007-087

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|-----|-----|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| MIDW | 1353102 | WR | WR | 2 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 189,000 | \$ 136,843 | \$ 280,332 |
| MIDW | 1353103 | WR | WR | 1 | 6/1/2008 | 6/1/2013 | 6/1/2011 | 6/1/2016 | \$ - | \$ 94,500 | \$ 68,423 | \$ 140,168 |
| | | | | | | | | | \$ - | \$ 283,500 | \$ 205,266 | \$ 420,500 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--|-----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1353102 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 8,471 | \$ 550,000 | \$ 21,942 |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 1,458 | \$ 900,000 | \$ 3,412 |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 6,727 | \$ 1,680,000 | \$ 17,054 |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1 | \$ 85,922 | \$ 3 |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 10,882 | \$ 2,011,826 | \$ 23,784 |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 88,665 | \$ 6,497,822 | \$ 166,007 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 20,639 | \$ 3,825,000 | \$ 48,130 |
| | | | | Total | | \$ 136,843 | \$ 15,550,570 | \$ 280,332 |
| 1353103 | 95TH & WAVERLY - EAST S.A.A.P. JCT 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 4,236 | \$ 550,000 | \$ 10,972 |
| | Craig 161kV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 729 | \$ 900,000 | \$ 1,706 |
| | DEARING 138KV Capacitor #2 | 6/1/2010 | 6/1/2010 | | | \$ 3,364 | \$ 1,680,000 | \$ 8,528 |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1 | \$ 85,922 | \$ 2 |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 5,441 | \$ 2,011,826 | \$ 11,892 |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 44,333 | \$ 6,497,822 | \$ 83,004 |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 10,319 | \$ 3,825,000 | \$ 24,064 |
| | | | | Total | | \$ 68,423 | \$ 15,550,570 | \$ 140,168 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1353102 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161kV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | Yes | |
| 1353103 | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | Craig 161kV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | 6/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | Yes | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1353102 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| 1353103 | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1353102 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 KV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kv Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to Mcdowell 230 KV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 KV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 KV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |
| 1353103 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Athens to Owl Creek 69 KV | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan - SW Manhattan 115kv Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | No | |
| | East Manhattan to Mcdowell 230 KV Displacement | 6/1/2009 | 6/1/2011 | No | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 KV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | Yes | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 KV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | Yes | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|----------------------|-----------|-----------|-----------------------|----------------------|
| 1353102 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |
| 1353103 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--------------|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1353102 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| 1353103 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Study Number | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Available | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|--|---|-----------|-----------|-----------------------|----------------------|----------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| MIDW | AG3-2007-090 | WR | WR | 25 | 3/1/2008 | 3/1/2027 | 6/1/2011 | 6/1/2030 | \$ 137,608 | \$ - | \$ 137,608 | \$ 410,193 |
| MIDW | 1353110 | | | | | | | | \$ 137,608 | \$ - | \$ 137,608 | \$ 410,193 |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | | | | |
| 1353110 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 3,762 | \$ 500,000 | \$ 10,573 | | | | |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2014 | 6/1/2014 | | | \$ 300 | \$ 100,000 | \$ 721 | | | | |
| | COFFEYVILLE FARMLAND 138KV CAP BANK | 6/1/2010 | 6/1/2010 | | | \$ 1,280 | \$ 250,000 | \$ 3,807 | | | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 2,257 | \$ 300,000 | \$ 6,458 | | | | |
| | Craig 161KV add 70MVar cap | 6/1/2013 | 6/1/2013 | | | \$ 20,576 | \$ 900,000 | \$ 63,461 | | | | |
| | G06-21T 138.00 - HARPER 138KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 20,541 | \$ 6,035,477 | \$ 56,644 | | | | |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 30,291 | \$ 2,011,826 | \$ 87,695 | | | | |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ 1,149 | \$ 337,500 | \$ 3,393 | | | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 57,452 | \$ 3,825,000 | \$ 177,441 | | | | |
| | | | | Total | | \$ 137,608 | \$ 14,259,803 | \$ 410,193 | | | | |
| Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | | | | | | | |
| 1353110 | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2016 | 6/1/2016 | | | | | | | | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | | | | | | | | |
| | Fort Scott - SW Bourbon 161 KV | 6/1/2017 | 6/1/2017 | | | | | | | | | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | | | | | | | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | | | | | | | | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | | | | | | | | |
| | ST JOHN CAPACITOR | 6/1/2016 | 6/1/2016 | | | | | | | | | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | | | | | | | | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | Yes | | | | | | | | |
| | WEST MCPHERSON - WHEATLAND 115KV CKT 1 | 6/1/2009 | 6/1/2010 | Yes | | | | | | | | |
| Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | | | | | | | |
| 1353110 | BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115kV | 6/1/2009 | 6/1/2011 | Yes | | | | | | | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | | | | | | | | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | | | | | | | | |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | | | | | | | | |
| | Craig 161KV 20MVar Upgrade | 6/1/2013 | 6/1/2013 | | | | | | | | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #2 | 6/1/2016 | 6/1/2016 | | | | | | | | | |
| | HOOVER NORTH - LAKERIDGE 138KV CKT 1 | 6/1/2016 | 6/1/2016 | | | | | | | | | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | | | | | | | | | |
| | LYONS - WHEATLAND 115KV CKT 1 MIDW | 6/1/2017 | 6/1/2017 | | | | | | | | | |
| | LYONS - WHEATLAND 115KV CKT 1 WERE | 6/1/2017 | 6/1/2017 | | | | | | | | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | | | | | | | | |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | | | | | | | | | |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | | | | | | | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1353110 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | ASH GROVE JCT2 - TIOGA 69KV CKT 1 | 6/1/2017 | 6/1/2017 | 6/1/2011 | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHANUTE TAP - TIOGA 69KV CKT 1 | 6/1/2017 | 6/1/2017 | 6/1/2011 | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | 6/1/2014 | 6/1/2014 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 10/1/2008 | 6/1/2011 | | Yes |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--------------|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1353110 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Study Number | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Available | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|--|---|------------|------------|------------------------------|-----------------------------|---------------------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| MIDW | AG3-2007-091 | | | | | | | | | | | |
| Customer | Reservation | WR | WR | 25 | 1/1/2009 | 1/1/2029 | 6/1/2011 | 6/1/2031 | \$ 137,608 | \$ - | \$ 137,608 | \$ 433,229 |
| MIDW | 1353111 | | | | | | | | | | | |
| | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | | | | |
| 1353111 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 3,762 | \$ 500,000 | \$ 11,132 | | | | |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2014 | 6/1/2014 | | | \$ 300 | \$ 100,000 | \$ 759 | | | | |
| | COFFEYVILLE FARMLAND 138KV CAP BANK | 6/1/2010 | 6/1/2010 | | | \$ 1,280 | \$ 250,000 | \$ 4,008 | | | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 2,257 | \$ 300,000 | \$ 6,799 | | | | |
| | Craig 161KV add 70MVar cap | 6/1/2013 | 6/1/2013 | | | \$ 20,576 | \$ 900,000 | \$ 67,038 | | | | |
| | G06-21T 138.00 - HARPER 138KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 20,541 | \$ 6,035,477 | \$ 59,835 | | | | |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 30,291 | \$ 2,011,826 | \$ 92,636 | | | | |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ 1,149 | \$ 337,500 | \$ 3,585 | | | | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | Yes | | \$ 57,452 | \$ 3,825,000 | \$ 187,437 | | | | |
| | | | | Total | | \$ 137,608 | \$ 14,259,803 | \$ 433,229 | | | | |
| Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | | | | | | | |
| 1353111 | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2016 | 6/1/2016 | | | | | | | | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | | | | | | | | |
| | Fort Scott - SW Bourbon 161 KV | 6/1/2017 | 6/1/2017 | | | | | | | | | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | | | | | | | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | | | | | | | | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | | | | | | | | |
| | ST JOHN CAPACITOR | 6/1/2016 | 6/1/2016 | | | | | | | | | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | | | | | | | | | |
| | Summit - NE Saline 115 kV | 10/1/2008 | 12/1/2009 | Yes | | | | | | | | |
| | WEST MCPHERSON - WHEATLAND 115KV CKT 1 | 6/1/2009 | 6/1/2010 | Yes | | | | | | | | |
| Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | | | | | | | |
| 1353111 | BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115kV | 6/1/2009 | 6/1/2011 | Yes | | | | | | | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | | | | | | | | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | Yes | | | | | | | | |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | | | | | | | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | | | | | | | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #2 | 6/1/2016 | 6/1/2016 | | | | | | | | | |
| | HOOVER NORTH - LAKERIDGE 138KV CKT 1 | 6/1/2016 | 6/1/2016 | | | | | | | | | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | | | | | | | | | |
| | LYONS - WHEATLAND 115KV CKT 1 MIDW | 6/1/2017 | 6/1/2017 | | | | | | | | | |
| | LYONS - WHEATLAND 115KV CKT 1 WERE | 6/1/2017 | 6/1/2017 | | | | | | | | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | | | | | | | | |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | | | | | | | | | |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | | | | | | | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1353111 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | ASH GROVE JCT2 - TIoga 69KV CKT 1 | 6/1/2017 | 6/1/2017 | 6/1/2011 | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHANUTE TAP - TIoga 69KV CKT 1 | 6/1/2017 | 6/1/2017 | 6/1/2011 | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | 6/1/2014 | 6/1/2014 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 10/1/2008 | 6/1/2011 | | Yes |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Third Party Limitations.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Start Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost |
|-------------|--------------|-----------|-----------|-----------------------------|----------------------|----------------------|------------------|
| 1353111 | GENTLMREDWIL | 10/1/2008 | 10/1/2008 | | | \$ - | \$ - |
| | | | | Total | | \$ - | \$ - |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
OMPA AG3-2007-035

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Available | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| OMPA | 1350945 | OKGE | OKGE | 23 | 5/1/2008 | 5/1/2017 | 6/1/2011 | 6/1/2020 | \$ 15,723 | \$ - | \$ 15,723 | \$ 31,824 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--|----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1350945 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 9,827 | \$ 500,000 | \$ 19,756 |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 5,896 | \$ 300,000 | \$ 12,068 |
| | | | | | | Total | \$ 15,723 | \$ 800,000 |
| | | | | | | | | \$ 31,824 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|-----------|-----------------------|----------------------|
| 1350945 | ROSE HILL JUNCTION - WEAVER 69KV CKT 1 | 10/1/2008 | 12/1/2008 | | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|----------|-----------------------|----------------------|
| 1350945 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | Yes |
| | RICHLAND - ROSE HILL JUNCTION 69KV CKT 1 Displacement | 10/1/2008 | 6/1/2011 | | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 10/1/2008 | 6/1/2011 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

| Customer | Study Number | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements | |
|--|--|-----------|----------|-----------------------|----------------------|----------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|--------------|
| PWX | AG3-2007-014 | BLKW | KCPL | 52 | 1/1/2010 | 1/1/2011 | 6/1/2013 | 6/1/2014 | \$ - | \$ 549,120 | \$ 442,382 | \$ 1,032,093 | |
| PWX | 1331353 | | | | | | | | | \$ - | \$ 549,120 | \$ 442,382 | \$ 1,032,093 |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | | | | | |
| 1331353 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 10,441 | \$ 500,000 | \$ 22,697 | | | | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 6,265 | \$ 300,000 | \$ 13,865 | | | | | |
| | Craig 161kV add 70MVar cap | 6/1/2013 | 6/1/2013 | | | \$ 152,160 | \$ 900,000 | \$ 359,213 | | | | | |
| | CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2 Displacement | 6/1/2013 | 6/1/2013 | | | \$ 15,794 | \$ 15,794 | \$ 20,102 | | | | | |
| | MERRIAM - ROELAND PARK 161KV CKT 1 Displacement | 6/1/2011 | 6/1/2011 | | | \$ 116,124 | \$ 669,819 | \$ 311,951 | | | | | |
| | PLANT X STATION - TOLK STATION EAST 230KV CKT 2 | 12/1/2009 | 6/1/2010 | 4/1/2010 | | \$ 47,631 | \$ 56,000 | \$ 105,715 | | | | | |
| | PLANT X STATION - TOLK STATION WEST 230KV CKT 1 | 12/1/2009 | 6/1/2010 | 4/1/2010 | | \$ 47,734 | \$ 56,000 | \$ 105,944 | | | | | |
| | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | 6/1/2012 | 6/1/2012 | | | \$ 46,233 | \$ 180,000 | \$ 92,606 | | | | | |
| | | | | | | Total | \$ 442,382 | \$ 2,677,613 | \$ 1,032,093 | | | | |
| Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | | | | | | | | |
| 1331353 | BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2009 | | | | | | | | | | |
| | Craig 161kV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | | | | | | | | | |
| | TERRY COUNTY INTERCHANGE - WOLFFORTH INTERCHANGE 115KV CKT 1 | 1/1/2010 | 6/1/2010 | | | | | | | | | | |
| Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | | | | | | | | |
| 1331353 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | | | | | | | | | |
| | Craig 161KV 20MVar Upgrade | 6/1/2013 | 6/1/2013 | | | | | | | | | | |
| | MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2013 | | | | | | | | | | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | | | | | | | | | |
| | SOUTH PLAINS REC-YUMA - WOLFFORTH INTERCHANGE 115KV CKT 1 | 1/1/2010 | 6/1/2012 | | | | | | | | | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | | | | | | | | | |
| Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer. | | | | | | | | | | | | | |
| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | | | | | | | | |
| 1331353 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | | | | | | | | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 12/1/2008 | 6/1/2010 | | | | | | | | | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | 12/1/2008 | 6/1/2010 | | | | | | | | | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | 12/1/2008 | 6/1/2010 | | | | | | | | | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | | | | | | | | | |
| | COOK - ST JOE 161KV CKT 1 | 6/1/2012 | 6/1/2012 | 6/1/2010 | | | | | | | | | |
| | IATAN - STRANGER CREEK 346KV CKT 2 | 6/1/2012 | 6/1/2012 | | | | | | | | | | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | | | | | | | | | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | | | | | | | | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
SPSM AG3-2007-080

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| SPSM | 1353054 | WPEK | KCPL | 50 | 10/1/2008 | 6/1/2010 | 6/1/2013 | 2/1/2015 | \$ - | \$ 880,000 | \$ - | \$ - |
| SPSM | 1353055 | WPEK | KCPL | 50 | 10/1/2008 | 6/1/2010 | 6/1/2013 | 2/1/2015 | \$ - | \$ 880,000 | \$ - | \$ - |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--------------|-----|-----|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1353054 | None | | | | | \$ - | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - | \$ - |
| 1353055 | None | | | | | \$ - | \$ - | \$ - |
| | | | | | Total | \$ - | \$ - | \$ - |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1353054 | BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2009 | | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| 1353055 | BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2009 | | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|----------|-----------------------|----------------------|
| 1353054 | MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2013 | Yes | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | No |
| 1353055 | MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2013 | Yes | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | No |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|----------|----------|-----------------------|----------------------|
| 1353054 | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| 1353055 | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer Study Number
SPSM AG3-2007-081

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Allowable | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|------|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| SPSM | 1353057 | WPEK | KCPL | 50 | 6/1/2010 | 1/1/2012 | 6/1/2013 | 1/1/2015 | \$ - | \$ 836,000 | \$ 375,359 | \$ 637,776 |
| SPSM | 1353059 | WPEK | KCPL | 50 | 6/1/2010 | 1/1/2012 | 6/1/2013 | 1/1/2015 | \$ - | \$ 836,000 | \$ 375,359 | \$ 637,776 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | |
|-------------|---|-----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|------------|
| 1353057 | CLIFTON - GREENLEAF 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 54,088 | \$ 3,598,794 | \$ 79,804 | |
| | G06-21T 138.00 - HARPER 138KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 195,694 | \$ 6,035,477 | \$ 321,054 | |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ 10,943 | \$ 337,500 | \$ 19,228 | |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 38,219 | \$ 6,497,822 | \$ 56,390 | |
| | MERRIAM - ROELAND PARK 161KV CKT 1 Displacement | 6/1/2011 | 6/1/2011 | | | \$ 76,415 | \$ 669,819 | \$ 161,300 | |
| | | | | | | Total | \$ 375,359 | \$ 17,139,412 | \$ 637,776 |
| 1353059 | CLIFTON - GREENLEAF 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 54,088 | \$ 3,598,794 | \$ 79,804 | |
| | G06-21T 138.00 - HARPER 138KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 195,694 | \$ 6,035,477 | \$ 321,054 | |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ 10,943 | \$ 337,500 | \$ 19,228 | |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 12/1/2008 | 6/1/2011 | Yes | | \$ 38,219 | \$ 6,497,822 | \$ 56,390 | |
| | MERRIAM - ROELAND PARK 161KV CKT 1 Displacement | 6/1/2011 | 6/1/2011 | | | \$ 76,415 | \$ 669,819 | \$ 161,300 | |
| | | | | | | Total | \$ 375,359 | \$ 17,139,412 | \$ 637,776 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1353057 | BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2009 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| 1353059 | BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2009 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|--|-----------|----------|-----------------------|----------------------|
| 1353057 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2013 | Yes | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| 1353059 | ALABAMA - LAKE ROAD 161KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1 | 10/1/2008 | 6/1/2013 | Yes | |
| | REDEL - STILWELL 161KV CKT 1 | 10/1/2008 | 6/1/2011 | 2/1/2011 | Yes |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|----------|----------|-----------------------|----------------------|
| 1353057 | COOK - ST JOE 161KV CKT 1 | 6/1/2012 | 6/1/2012 | 6/1/2010 | |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2012 | 6/1/2012 | | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| 1353059 | COOK - ST JOE 161KV CKT 1 | 6/1/2012 | 6/1/2012 | 6/1/2010 | |
| | IATAN - STRANGER CREEK 345KV CKT 2 | 6/1/2012 | 6/1/2012 | | |
| | MARTIN CITY - REDEL 161KV CKT 1 | 6/1/2009 | 6/1/2011 | 2/1/2011 | Yes |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
WRGS AG3-2007-025

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Available | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|-----|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| WRGS | 1346837 | SECI | WR | 96 | 11/1/2008 | 11/1/2018 | 6/1/2011 | 6/1/2021 | \$ 1,728,000 | \$ - | \$ 2,447,083 | \$ 5,738,151 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements |
|-------------|--|-----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|
| 1346837 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 21,209 | \$ 500,000 | \$ 55,050 |
| | CLIFTON - GREENLEAF 115KV CKT 1 | 6/1/2011 | 6/1/2011 | | | \$ 2,101,278 | \$ 3,598,794 | \$ 4,810,412 |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2014 | 6/1/2014 | | | \$ 1,860 | \$ 100,000 | \$ 4,128 |
| | COFFEYVILLE FARMLAND 138KV CAP BANK | 6/1/2010 | 6/1/2010 | | | \$ 6,284 | \$ 250,000 | \$ 17,259 |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 12,725 | \$ 300,000 | \$ 33,626 |
| | Craig 161KV add 70MVAR cap | 6/1/2013 | 6/1/2013 | | | \$ 139,721 | \$ 900,000 | \$ 397,926 |
| | DEARING 138KV Capacitor Displacement | 10/1/2008 | 6/1/2010 | | | \$ 1,624 | \$ 85,922 | \$ 4,857 |
| | G06-21T 138.00 - HARPER 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 153,783 | \$ 6,035,477 | \$ 391,459 |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ 8,599 | \$ 337,500 | \$ 23,434 |
| | | | | Total | | \$ 2,447,083 | \$ 12,107,693 | \$ 5,738,151 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1346837 | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2016 | 6/1/2016 | | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | 6/1/2009 | |
| | Fort Scott - SW Bourbon 161 KV | 6/1/2017 | 6/1/2017 | | |
| | GILL ENERGY CENTER EAST - INTERSTATE 138KV CKT 1 | 6/1/2015 | 6/1/2015 | | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | PLAINVILLE 115KV Capacitor | 6/1/2012 | 6/1/2012 | | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | 10/1/2008 | |
| | RUSSELL 115KV Capacitor | 6/1/2011 | 6/1/2011 | | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | | |
| | Summit - NE Saline 115 KV | 10/1/2008 | 12/1/2009 | | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|----------|-----------------------|----------------------|
| 1346837 | BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115kV | 6/1/2009 | 6/1/2011 | | |
| | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | |
| | CLAY CENTER - GREENLEAF 115KV CKT 1 | 10/1/2008 | 6/1/2011 | | |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #2 | 6/1/2016 | 6/1/2016 | | |
| | HOOVER NORTH - LAKERIDGE 138KV CKT 1 | 6/1/2016 | 6/1/2016 | | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | 10/1/2009 | |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | | |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|---|-----------|-----------|-----------------------|----------------------|
| 1346837 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | ASH GROVE JCT2 - TIOGA 69KV CKT 1 | 6/1/2017 | 6/1/2017 | 6/1/2011 | |
| | Athens to Owl Creek 69 kV | 6/1/2011 | 6/1/2011 | | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | CHANUTE TAP - TIOGA 69KV CKT 1 | 6/1/2017 | 6/1/2017 | 6/1/2011 | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | 12/1/2008 | 6/1/2010 | | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | | |
| | CONCORDIA - JEWELL 3 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | | |
| | East Manhattan - SW Manhattan 115kV Displacement | 6/1/2009 | 6/1/2011 | | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | | |
| | East Manhattan to McDowell 230 kV Displacement | 6/1/2009 | 6/1/2011 | | |
| | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | 6/1/2010 | 6/1/2010 | | |
| | Green to Vernon 69 kV | 6/1/2011 | 6/1/2011 | | |
| | JEWELL 3 - SMITH CENTER 115KV CKT 1 | 6/1/2013 | 6/1/2013 | | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | | |
| | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | 6/1/2014 | 6/1/2014 | | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | 6/1/2009 | |
| | RENO - SUMMIT 345KV | 10/1/2008 | 12/1/2009 | | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 10/1/2008 | 6/1/2011 | | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | | |
| | Vernon to Athens 69 kV | 6/1/2011 | 6/1/2011 | | |
| | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available |
|-------------|----------------------|-----------|-----------|-----------------------|----------------------|
| 1346837 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
WRGS AG3-2007-026

| Customer | Reservation | POR | POD | Requested Amount | Requested Start Date | Requested Stop Date | Deferred Start Date Without Redispatch | Deferred Stop Date Without Redispatch | Potential Base Plan Funding Available | Point-to-Point Base Rate | Allocated E & C Cost | Total Revenue Requirements |
|----------|-------------|------|-----|------------------|----------------------|---------------------|--|---------------------------------------|---------------------------------------|--------------------------|----------------------|----------------------------|
| WRGS | 1346842 | SECI | WR | 100 | 12/31/2008 | 12/31/2018 | 6/1/2011 | 6/1/2021 | \$ 1,800,000 | \$ - | \$ 19,322,281 | \$ 46,787,566 |

| Reservation | Upgrade Name | DUN | EOC | Earliest Service Date | Redispatch Available | Allocated E & C Cost | Total E & C Cost | Total Revenue Requirements | |
|-------------|---|-----------|----------|-----------------------|----------------------|----------------------|------------------|----------------------------|---------------|
| 1346842 | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 31,158 | \$ 500,000 | \$ 80,874 | |
| | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | 6/1/2014 | 6/1/2014 | | | \$ 2,274 | \$ 100,000 | \$ 5,047 | |
| | COFFEYVILLE FARMLAND 138KV CAP BANK | 6/1/2010 | 6/1/2010 | | | \$ 8,432 | \$ 250,000 | \$ 23,159 | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 #2 | 6/1/2011 | 6/1/2011 | | | \$ 18,695 | \$ 300,000 | \$ 49,402 | |
| | Craig 161KV add 70MVAR Cap | 6/1/2013 | 6/1/2013 | | | \$ 51,507 | \$ 900,000 | \$ 146,692 | |
| | G06-21T 138.00 - HARPER 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 5,023,487 | \$ 6,035,477 | \$ 12,787,416 | |
| | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 1,572,325 | \$ 2,011,826 | \$ 4,201,950 | |
| | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ 129,763 | \$ 129,763 | \$ 267,482 | |
| | HARPER - MILAN TAP 138KV CKT 1 | 12/1/2009 | 6/1/2010 | | | \$ 280,910 | \$ 337,500 | \$ 765,539 | |
| | HOOVER NORTH 138/69/13.2KV TRANSFORMER CKT 3 | 6/1/2013 | 6/1/2013 | | | \$ 3,712,500 | \$ 3,712,500 | \$ 7,349,663 | |
| | MACARTHUR - OATVILLE 69KV CKT 1 Displacement | 6/1/2013 | 6/1/2013 | | | \$ 2,359 | \$ 2,359 | \$ 4,803 | |
| | MEDICINE LODGE - PRATT 115KV CKT 1 | 12/1/2008 | 6/1/2011 | | | \$ 5,506,674 | \$ 6,497,822 | \$ 12,606,313 | |
| | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | 10/1/2008 | 6/1/2010 | | | \$ 2,982,197 | \$ 3,825,000 | \$ 8,499,226 | |
| | | | | | | Total | \$ 19,322,281 | \$ 24,602,247 | \$ 46,787,566 |

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Redispatch Available |
|-------------|---|-----------|-----------|----------------------|
| 1346842 | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | 6/1/2016 | 6/1/2016 | |
| | Craig 161KV 50MVar Cap Bank | 6/1/2013 | 6/1/2013 | |
| | Fort Scott - SW Bourbon 161 KV | 6/1/2017 | 6/1/2017 | |
| | GILL ENERGY CENTER EAST - INTERSTATE 138KV CKT 1 | 6/1/2015 | 6/1/2015 | |
| | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | 10/1/2008 | 10/1/2008 | |
| | HARPER 138KV Capacitor | 10/1/2008 | 6/1/2009 | |
| | NORTH CIMARRON 115KV Capacitor | 6/1/2009 | 6/1/2009 | |
| | PRATT 115KV Capacitor | 10/1/2008 | 6/1/2009 | |
| | ST JOHN CAPACITOR | 6/1/2016 | 6/1/2016 | |
| | SUB 438 - RIVERSIDE 161KV | 6/1/2013 | 6/1/2013 | |
| | Summit - NE Saline 115 KV | 10/1/2008 | 12/1/2009 | |

Reliability Upgrades - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Redispatch Available |
|-------------|---|----------|----------|----------------------|
| 1346842 | BPU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115KV | 6/1/2009 | 6/1/2011 | |
| | COWSKIN - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | |
| | Craig 161KV 20MVAR Upgrade | 6/1/2013 | 6/1/2013 | |
| | HOOVER SOUTH - TYLER 69KV | 6/1/2010 | 6/1/2010 | |
| | STRANGER CREEK - NW LEAVENWORTH 115KV | 6/1/2009 | 6/1/2010 | |
| | SUB 124 - AURORA H.T. 69KV | 6/1/2013 | 6/1/2013 | |
| | TYLER - WESTLINK 69KV | 6/1/2010 | 6/1/2010 | |

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Reservation | Upgrade Name | DUN | EOC | Redispatch Available |
|-------------|---|-----------|----------|----------------------|
| 1346842 | ALLEN - LEHIGH TAP 69KV CKT 1 | 6/1/2011 | 6/1/2011 | |
| | ASH GROVE JCT2 - TIOGA 69KV CKT 1 | 6/1/2017 | 6/1/2017 | |
| | Athens to Owl Creek 69 KV | 6/1/2011 | 6/1/2011 | |
| | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | |
| | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | 6/1/2011 | 6/1/2011 | |
| | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | |
| | CHANUTE TAP - TIOGA 69KV CKT 1 | 6/1/2017 | 6/1/2017 | |
| | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | 6/1/2011 | 6/1/2011 | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | 12/1/2008 | 6/1/2010 | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE | 12/1/2008 | 6/1/2010 | |
| | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | 12/1/2008 | 6/1/2010 | |
| | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | 10/1/2008 | 6/1/2011 | |
| | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | 6/1/2009 | 6/1/2011 | |
| | East Manhattan - SW Manhattan 115KV Displacement | 6/1/2009 | 6/1/2011 | |
| | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | 6/1/2009 | 6/1/2011 | |
| | East Manhattan to Mcdowell 230 KV Displacement | 6/1/2009 | 6/1/2011 | |
| | Green to Vernon 69 KV | 6/1/2011 | 6/1/2011 | |
| | LEHIGH TAP - OWL CREEK 69KV CKT 1 | 6/1/2011 | 6/1/2011 | |
| | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | 6/1/2014 | 6/1/2014 | |
| | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | 6/1/2010 | 6/1/2010 | |
| | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | 10/1/2008 | 6/1/2011 | |
| | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | 6/1/2009 | 6/1/2009 | |
| | Vernon to Athens 69 KV | 6/1/2011 | 6/1/2011 | |

Credits may be required for the following network upgrades directly assigned to transmission customers in previous aggregate study.

| Reservation | Upgrade Name | DUN | EOC | Redispatch Available |
|-------------|----------------------|-----------|-----------|----------------------|
| 1346842 | WICHITA - RENO 345KV | 10/1/2008 | 12/1/2008 | |

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) | Estimated Engineering & Construction Cost |
|---|---|--|--------------------------------------|--|---|
| AEPW | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 #2 | Replace terminal equipment at SE Bartlesville Southeast | 6/1/2011 | 6/1/2011 | \$ 500,000 |
| AEPW | COFFEYVILLE FARMLAND - DELAWARE 138KV CKT 1 | Replace Delaware Switches | 6/1/2014 | 6/1/2014 | \$ 100,000 |
| AEPW | COFFEYVILLE FARMLAND - SOUTH COFFEYVILLE CITY 138KV CKT 1 | Rebuild 6.22 miles of 795 ACSR with 1590 ACSR, add additional cap banks at Coffeyville | 6/1/2011 | 6/1/2011 | \$ 6,200,000 |
| AEPW | COFFEYVILLE FARMLAND 138KV CAP BANK | Replace line switches 5062 & 5072 | 6/1/2010 | 6/1/2010 | \$ 250,000 |
| AEPW | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 #2 | Rebuild 6 miles of 556 ACSR with 1590 ACSR. | 6/1/2011 | 6/1/2011 | \$ 300,000 |
| AEPW | COFFEYVILLE TAP - SOUTH COFFEYVILLE CITY 138KV CKT 1 | Replace Northeastern Station Wavetrap | 6/1/2010 | 6/1/2011 | \$ 6,000,000 |
| AEPW | NORTHEAST STATION - WATOVA 138KV CKT 1 | Rebuild 2.49 miles with 1590 ACSR, Replace wavetrap & jumpers @ Whitney, Replace metering CT @ Texas Eastman | 6/1/2009 | 6/1/2011 | \$ 2,800,000 |
| EMDE | SUB 124 - AURORA H.T. - SUB 152 - MONETT H.T. 69KV CKT 1 Displacement | Change CT Ratios on breaker #6936 at Aurora #124 | 6/1/2009 | 6/1/2009 | \$ 214 |
| EMDE | SUB 152 - MONETT H.T. - SUB 383 - MONETT 69KV CKT 1 Displacement | Replace 4/0 Cu jumpers with 500 MCM Cu, new rate: 54 / 65 | 6/1/2009 | 6/1/2009 | \$ 3,202 |
| GRDA | COFFEYVILLE FARMLAND (COFAUTO1) 138/69/13.8KV TRANSFORMER CKT 1 | Indeterminate | 10/1/2008 | 10/1/2008 | Indeterminate |
| GRDA | COFFEYVILLE FARMLAND (COFAUTO2) 138/69/13.8KV TRANSFORMER CKT 2 | Indeterminate | 10/1/2008 | 10/1/2008 | Indeterminate |
| KACP | Craig 161kV add 70MVAR cap | Add an additional 70 MVAR at Craig 161kV | 6/1/2013 | 6/1/2013 | \$ 900,000 |
| KACP | MERRIAM - ROELAND PARK 161KV CKT 1 Displacement | reconductor with 1192 aCSR; upgrade term equip 1200 A | 6/1/2011 | 6/1/2011 | \$ 669,819 |
| MIPU | GRANDVIEW EAST - MARTIN CITY 161KV CKT 1 #2 | Reconductor to Bundled Drake | 6/1/2010 | 6/1/2010 | \$ 4,700,000 |
| MIPU | GRANDVIEW EAST - SAMPSON 161KV CKT 1 #2 | Reconductor | 12/1/2012 | 12/1/2012 | \$ 3,225,000 |
| MIPU | LONGVIEW - SAMPSON 161KV CKT 1 #2 | Reconductor | 12/1/2012 | 12/1/2012 | \$ 2,550,000 |
| MIPU | PLATTE CITY - SMITHVILLE 161KV CKT 1 #1 | Increase the normal/emergency ratings to 233/265 MVA by replacing wave traps | 6/1/2012 | 6/1/2012 | \$ 180,000 |
| MKEC | CLIFTON - GREENLEAF 115KV CKT 1 | Rebuild 14.4 mile line | 6/1/2011 | 6/1/2011 | \$ 3,598,794 |
| MKEC | G06-21T 138.00 - HARPER 138KV CKT 1 | Rebuild 24.15 mile line | 12/1/2008 | 6/1/2011 | \$ 6,035,477 |
| MKEC | G06-21T 138.00 - MEDICINE LODGE 138KV CKT 1 | Rebuild 8.05 mile line | 12/1/2008 | 6/1/2011 | \$ 2,011,826 |
| MKEC | HARPER - MILAN TAP 138KV CKT 1 | Replace Terminal Equipment | 12/1/2009 | 6/1/2010 | \$ 337,500 |
| MKEC | MEDICINE LODGE - PRATT 115KV CKT 1 | Rebuild 26 mile line | 12/1/2008 | 6/1/2011 | \$ 6,497,822 |
| MKEC | MEDICINE LODGE 138/115KV TRANSFORMER CKT 1 | Upgrade to 100/147/170MVA transformer | 10/1/2008 | 6/1/2010 | \$ 3,825,000 |
| CURRY COUNTY INTERCHANGE - ROOSEVELT COUNTY INTERCHANGE 115KV CKT 2 | Displacement | Upgrade terminal equipment, Rate A & B 185 MVA | 6/1/2013 | 6/1/2013 | \$ 15,794 |
| SPS | PLANT X STATION - TOLK STATION EAST 230KV CKT 2 | Replace 800 A wavetraps at Plant X and Tolk with new 1600 A | 12/1/2009 | 6/1/2010 | \$ 56,000 |
| SPS | PLANT X STATION - TOLK STATION WEST 230KV CKT 1 | Replace 800 A wavetraps at Plant X and Tolk with new 1600 A | 12/1/2009 | 6/1/2010 | \$ 56,000 |
| SWPA | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 SWPA | Replace wave trap, disconnect switches, current transformers, and breaker, Replace bus, | 6/1/2009 | 6/1/2010 | \$ 2,500,000 |
| WERE | 95TH & WAVERLY - EAST S.A.P. JCT 115KV CKT 1 | Rebuild 1.97 miles from 95th & Waverly-East SAAP Jct 115 kV line. | 6/1/2011 | 6/1/2011 | \$ 550,000 |
| WERE | DEARING 138KV Capacitor #2 | Dearing 138 KV 2-20 MVAR Capacitor Addition | 6/1/2010 | 6/1/2010 | \$ 1,680,000 |
| WERE | DEARING 138KV Capacitor Displacement | Dearing 138 KV 20 MVAR Capacitor Addition | 10/1/2008 | 6/1/2010 | \$ 85,922 |
| WERE | GILL ENERGY CENTER EAST - MACARTHUR 69KV CKT 1 Displacement | Rebuild 5.56-mile line, 954 ACSR | 6/1/2013 | 6/1/2013 | \$ 129,763 |
| WERE | HOOVER NORTH 138/69/13.2KV TRANSFORMER CKT 3 | Install 3rd transformer at Hoover | 6/1/2013 | 6/1/2013 | \$ 3,712,500 |
| WERE | MACARTHUR - OATVILLE 69KV CKT 1 Displacement | Replace the 69 kV bus and jumpers on the Oatville-Mac Arthur 69 kV line. | 6/1/2013 | 6/1/2013 | \$ 2,359 |

Construction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|--------------------|---|--|--------------------------------------|--|
| AEPW | BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1 | Rebuild 8.37 miles of 795 ACSR with 1590 ACSR & reset relays @ BSE | 10/1/2008 | 6/1/2011 |
| AEPW | COFFEYVILLE TAP - DEARING 138KV CKT 1 AEPW | Tie Line, Reconductor 1.09 miles of 795 ACSR with 1590 ACSR. | 12/1/2008 | 6/1/2010 |
| AEPW | COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1 | Rebuild 13.11 miles of 795 ACSR with 1590 ACSR. | 10/1/2008 | 6/1/2011 |
| AEPW | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 #2 | Replace Jumpers @ N. Magazine | 6/1/2010 | 6/1/2010 |
| AEPW | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 AEPW | Rebuild 7.43 miles of 250 CWC with 795 ACSR | 6/1/2010 | 6/1/2010 |
| AEPW | SOUTHWEST SHREVEPORT (SW SHV 1) 345/138/13.8KV TRANSFORMER CKT 1 | Using IEEE Guide for Loading of Mineral-Oil Immersed Power Transformers (C57.91-2000) Re-rate the autos. Replace .two 138 KV breakers and five 138 KV switches. Reset relays and CTs | 1/1/2009 | 6/1/2009 |
| AEPW | SOUTHWEST SHREVEPORT (SW SHV 1) 345/138/13.8KV TRANSFORMER CKT 2 | Replace Auto, two 138 KV breakers and five 138 KV switches. Reset relays and CTs | 1/1/2009 | 6/1/2009 |
| KACP | IATAN - STRANGER CREEK 345KV CKT 2 | Convert Iatan-Stranger Creek 161kV line to 345kV | 6/1/2012 | 6/1/2012 |
| KACP | MARTIN CITY - REDEL 161KV CKT 1 | reconductor 1192 aCSR upgrade terminal equip 2000 amp | 6/1/2009 | 6/1/2011 |
| MIPU | COOK - ST JOE 161KV CKT 1 | Conductor, Switch, Relay | 6/1/2012 | 6/1/2012 |
| MIPU | GRANDVIEW EAST - SAMPSON 161KV CKT 1 #1 | Replace wavetraps | 12/1/2012 | 12/1/2012 |
| MIPU | LONGVIEW - SAMPSON 161KV CKT 1 #1 | replace wavetraps | 12/1/2012 | 12/1/2012 |
| MKEC | CONCORDIA - JEWELL 3 115KV CKT 1 | Rebuild 25.8 mile line | 6/1/2013 | 6/1/2013 |
| MKEC | JEWELL 3 - SMITH CENTER 115KV CKT 1 | Rebuild 33.9 mile line | 6/1/2013 | 6/1/2013 |
| OKGE | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 OKGE | Rebuild 7.43 miles of 250 CWC with 795 ACSR | 6/1/2010 | 6/1/2010 |
| WERE | ALLEN - LEHIGH TAP 69KV CKT 1 | Tear down / Rebuild 5.69-mile line; 954 kcmil ACSR | 6/1/2011 | 6/1/2011 |
| WERE | ARKANSAS CITY - PARIS 69KV CKT 1 #1 Displacement | Replace Disconnect Switches and Bus Jumpers at Paris and Ark City 69 kV substations | 6/1/2016 | 6/1/2016 |
| WERE | ASH GROVE JCT2 - TIoga 69KV CKT 1 | Rebuild 2.13 miles | 6/1/2017 | 6/1/2017 |
| WERE | Athens to Owl Creek 69 kV | Rebuild Athens to Owl Creek. (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WERE | BURLINGTON JUNCTION - COFFEY COUNTY NO. 3 WESTPHALIA 69KV CKT 1 | Rebuild 7.2 miles (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WERE | BURLINGTON JUNCTION - WOLF CREEK 69KV CKT 1 | Rebuild 4.1 miles (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WERE | CHANUTE TAP - TIoga 69KV CKT 1 | Replace Jumpers | 6/1/2017 | 6/1/2017 |
| WERE | COFFEY COUNTY NO. 3 WESTPHALIA - GREEN 69KV CKT 1 | Rebuild 9.22 miles (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WERE | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #1 | Tie Line, Rebuild 3.93 miles of 795 ACSR with 1590 ACSR. | 12/1/2008 | 6/1/2010 |
| WERE | COFFEYVILLE TAP - DEARING 138KV CKT 1 WERE #2 | Replace Disconnect Switches, Wavetrap, Breaker, Jumpers | 12/1/2008 | 6/1/2010 |
| WERE | CRESWELL - OAK 69KV CKT 1 #1 Displacement | Replace jumpers and bus, and reset CTs and relaying. Rebuild substations. | 6/1/2014 | 6/1/2014 |
| WERE | EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1 Displacement | Rebuild 27 miles 345kV construction operated as 230kV | 6/1/2009 | 6/1/2011 |
| WERE | East Manhattan - SW Manhattan 115kV Displacement | Build new 115kV line from East Manhattan to new SW Manhattan substation | 6/1/2009 | 6/1/2011 |
| WERE | EAST MANHATTAN (EMANHT3X) 230/115/18.0KV TRANSFORMER CKT 2 Displacement | Add second parallel 230-115kV transformer at E Manhattan | 6/1/2009 | 6/1/2011 |
| WERE | East Manhattan to McDowell 230 KV Displacement | The East Manhattan-McDowell 115 KV is built as a 230 KV line, but is operated at 115 KV. Substation work will have to be performed in order to convert this line. | 6/1/2009 | 6/1/2011 |
| WERE | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #1 Displacement | Replace Disconnect Switches, Wavetrap, Breaker, Jumpers | 6/1/2010 | 6/1/2010 |
| WERE | Green to Vernon 69 kV | Rebuild 7.19 miles Green to Vernon 69 kV (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WERE | LEHIGH TAP - OWL CREEK 69KV CKT 1 | Tear down / Rebuild 8.47-mile 69 kV line; 954 kcmil ACSR | 6/1/2011 | 6/1/2011 |
| WERE | LITCHFIELD - AQUARIUS - HUDSON JUNCTION 69KV CKT 1 Displacement | Replace 69 kV disconnect switches at Aquarius. | 6/1/2014 | 6/1/2014 |
| WERE | NEOSHO - NORTHEAST PARSONS 138KV CKT 1 | Replace bus and jumpers at NE Parsons 138 kV substation | 6/1/2010 | 6/1/2010 |
| WERE | RENO - SUMMIT 345KV | Install new 50.55-mile 345 kV line from Reno County to Summit; 31 miles of 115 kV line between Circle and S Phillips would be rebuilt as double circuit with the 345 kV line to minimize ROW impacts; Substation work required at Summit for new 345 kV terminal | 10/1/2008 | 12/1/2009 |
| WERE | RICHLAND - ROSE HILL JUNCTION 69KV CKT 1 Displacement | Rebuild 5.43 mile Rose Hill Junction-Richland as a 138 kV line but operate at 69 kV | 10/1/2008 | 6/1/2011 |
| WERE | ROSE HILL (ROSEHL1X) 345/138/13.8KV TRANSFORMER CKT 3 Displacement | Add third 345-138 kV transformer at Rose Hill | 10/1/2008 | 6/1/2011 |
| WERE | TECUMSEH ENERGY CENTER - MIDLAND 115KV CKT 1 Displacement | Convert 161 KV Line to 115 KV Operation | 6/1/2009 | 6/1/2009 |
| WERE | Vernon to Athens 69 kV | Rebuild 5.17 miles Green to Vernon 69 kV (138kV/69kV Operation) | 6/1/2011 | 6/1/2011 |
| WERE | WICHITA - RENO 345KV | 40 mile 345 kV transmission line from existing Wichita 345 kV substation to a new 345-115 kV substation in Reno County east northeast of Hutchinson (Wichita to Reno) | 10/1/2008 | 12/1/2008 |
| WERE | WICHITA - RENO 345KV | Build 345kV from Wichita to Reno Co | 10/1/2008 | 12/1/2008 |

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Expansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|--------------------|--|---|--------------------------------------|--|
| AEPW | ARSENAL HILL - NORTH MARKET 69KV CKT 1 | Rebuild 2.3 miles of 666 ACSR with 1272 ACSR | 6/1/2010 | 6/1/2010 |
| AEPW | BONANZA - BONANZA TAP 161KV CKT 1 | Rebuild 0.06 miles of 397 ACSR with 1272 ACSR & reset relay & CTs @ Bonanza or Bonanza T-Excelsior-Midland-N. Huntington 161kV loop | 6/1/2011 | 6/1/2011 |
| AEPW | BROKEN BOW - CRAIG JUNCTION 138KV CKT 1 | Rebuild 7.66 miles of 310 CW CU with 725 ACSR | 1/1/2009 | 6/1/2009 |
| AEPW | EAST CENTRAL HENRYETTA - OKMULGEE 138KV CKT 1 | Reconductor 12.79 miles with 1272 ACSR & reset CTs | 1/1/2008 | 6/1/2010 |
| EMDE | JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1 EMDE | Replace Jumpers to breaker #6950 at Blackhawk Jct. | 6/1/2014 | 6/1/2014 |
| EMDE | SUB 383 - MONETT - SUB 376 - MONETT CITY SOUTH 161/69/12.5KV TRANSFORMER CKT 1 | Install new line from Sub #383 to new Sub MONETT 5. Install 3-wind transformer from 161 kV new bus to Monett city south 69kV | 6/1/2017 | 6/1/2017 |
| EMDE | SUB 438 - RIVERSIDE 161KV | Install 3 - stages of 22 MVAR each for a total of 66 MVAR capacitor bank at Riverside Sub #438 547497 | 6/1/2013 | 6/1/2013 |
| GRDA | AFTON (AFTAUT01) 161/69/13.8KV TRANSFORMER CKT 1 | Add a second 50 MVA Transformer at Alton Substation. | 6/1/2009 | 6/1/2010 |
| GRDA | CLAREMORE (CLRAUT01) 161/69/13.8KV TRANSFORMER CKT 1 | Replace existing transformer | 10/1/2008 | 6/1/2011 |
| GRDA | CLAREMORE (CLRAUT02) 161/69/13.8KV TRANSFORMER CKT 2 | Replace existing transformer | 10/1/2008 | 6/1/2011 |
| GRDA | PRYAMID CORNERS CAPCITOR | Install 2 - 3.6 Mvar capacitors at Pyramid Corners 69 kV bus | 10/1/2008 | 6/1/2009 |
| GRDA | SALLISAW CAP BANK | Install cap bank | 10/1/2008 | 6/1/2010 |
| KACP | ANTIOCH - OXFORD 161KV CKT 1 | Reconductor 5 miles with 1192.5 ACSS, 558 normal/emergency rating | 6/1/2017 | 6/1/2017 |
| KACP | Craig 161KV 50MVar Cap Bank | New Craig 542978.50 MVAR cap bank. | 6/1/2013 | 6/1/2013 |
| MIDW | ST JOHN CAPACITOR | Install 20MVAR capacitors at St John | 6/1/2016 | 6/1/2016 |
| MIPU | BELTON SOUTH - TURNER ROAD SUBSTATION 161KV CKT 1 | Reconductor to Bundled Drake | 10/3/2008 | 6/1/2009 |
| MKEC | HARPER 138KV Capacitor | Install 1 - 20 MVar capacitor bank | 10/1/2008 | 6/1/2009 |
| MKEC | PHILLIPSBURG - RHOADES 115 KV | Install 35 miles 115 kV from Phillipsburgsubstation to Rhoades | 10/1/2008 | 6/1/2009 |
| MKEC | PLAINVILLE 115KV Capacitor | 20 Mvar cap bank at Plainville 115KV | 6/1/2012 | 6/1/2012 |
| MKEC | PRATT 115KV Capacitor | Install (2) 12 Mvar cap banks at Pratt 115KV | 10/1/2008 | 6/1/2009 |
| MKEC | RUSSELL 115KV Capacitor | Add 9.6 Mvar capacitor at Russell 115 KV | 6/1/2011 | 6/1/2011 |
| OKGE | ARKOMA - FT SMITHW 161KV CKT 1 | Replace 1200A terminal equipment at Arkoma to 2000A and rebuild 4.47 miles of line to 1590AS2. | 6/1/2009 | 6/1/2011 |
| OKGE | COLONY - FT SMITH 161KV CKT 1 | Reconductor 2.2 miles to Drake ACC/TW and change terminal equipment at Ft. Smith & Colony to 2000A. | 6/1/2009 | 6/1/2009 |
| SPRM | SOUTHWEST - SOUTHWEST DISPOSAL 161KV CKT 1 | Reconductor 161KV Line 1192 MCCM AAC to 954 kmil ACSS/TW 0.67 miles and Upgrade Terminal Equipment | 6/1/2014 | 6/1/2014 |
| SPS | TERRY COUNTY INTERCHANGE - WOLFFORTH INTERCHANGE 115KV CKT 1 | Upgrade jumper at Terry Co. to a higher rating. Replace 4/0 with 397.5 ACSR cable | 1/1/2010 | 6/1/2010 |
| SUNC | NORTH CIMARRON 115KV Capacitor | Install 24 MVAR Capacitor bank at North Cimarron | 6/1/2009 | 6/1/2009 |
| SWPA | BULL SHOALS - BULL SHOALS 161KV CKT 1 | Replace buswork in Bull Shoals switchyard. | 6/1/2009 | 6/1/2011 |
| WERE | AUBURN ROAD (AUBRN77X) 230/115/13.8KV TRANSFORMER CKT 2 | Add second Auburn 230-115 KV transformer. | 6/1/2016 | 6/1/2016 |
| WERE | BISMARCK JUNCTION SWITCHING STATION - FARMERS CONSUMER CO-OP 115KV CKT 1 | Rebuild line | 6/1/2015 | 6/1/2015 |
| WERE | BISMARCK JUNCTION SWITCHING STATION - MIDLAND JUNCTION 115KV CKT 1 | Rebuild 5.2 miles Bismarck to Midland 115 kV line | 6/1/2015 | 6/1/2015 |
| WERE | FARMERS CONSUMER CO-OP - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | Rebuild 1.53-mile Co-op-Wakarusa 115 kV line. | 6/1/2011 | 6/1/2011 |
| WERE | Fort Scott - SW Bourbon 161 KV | Tap Litchfield-Marmaton 161 KV with new SW Bourbon Sub to Ft Scott, and new 161/69 kV transformer at Ft Scott. | 6/1/2017 | 6/1/2017 |
| WERE | GILL ENERGY CENTER EAST - INTERSTATE 138KV CKT 1 | Replace wave trap | 6/1/2015 | 6/1/2015 |
| WERE | GILL ENERGY CENTER EAST - OATVILLE 69KV CKT 1 | Tear down / Rebuild 3.69-mile Gill-Gill Junction-Oatville 69 KV line using 1192.5 kmil ACSR | 10/1/2008 | 10/1/2008 |
| WERE | LAWRENCE HILL - MOCKINGBIRD HILL SWITCHING STATION 115KV CKT 1 | Rebuild 5.49 mile line | 6/1/2017 | 6/1/2017 |
| WERE | ROSE HILL JUNCTION - WEAVER 69KV CKT 1 | Rebuild 5.73 mile Weaver-Rose Hill Junction as a 138 kV line but operate at 69 kV. | 10/1/2008 | 12/1/2008 |
| WERE | SOUTHWEST LAWRENCE - WAKARUSA JUNCTION SWITCHING STATION 115KV CKT 1 | Rebuild 4.09 mile SW Lawrence-Wakarusa 115 kV line | 6/1/2011 | 6/1/2011 |
| WERE | Summit - NE Saline 115 KV | Build 6.5-mile Summit-Southgate 115 KV, 1192.5 kmil ACSS Tear down Northview-South Gate 115 KV | 10/1/2008 | 12/1/2009 |
| WERE | WEST MCPHERSON - WHEATLAND 115KV CKT 1 | Tear down and rebuild 7.88 mile West McPherson-Wheatland 115 kV line. | 6/1/2009 | 6/1/2010 |

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|--------------------|--|---|--------------------------------------|--|
| EMDE | JOPLIN 59 - SUB 439 - STATELINE 161KV CKT 1 | Install new line from Sub #439 to new Sub Joplin 59. | 6/1/2010 | 6/1/2012 |
| EMDE | JOPLIN 59 - SUB 59 - JOPLIN 26TH ST. 161/69KV TRANSFORMER CKT 1 | Install 3-wind transformer from 161 KV Joplin 59 bus to Sub #59 Joplin 26th St. | 6/1/2010 | 6/1/2012 |
| EMDE | SUB 124 - AURORA H.T. 69KV | Install 3 - stages of 22 MVAR each for total of 66 MVAR capacitor bank at Aurora Sub #124 bus# 547537 | 6/1/2013 | 6/1/2013 |
| EMDE | SUB 145 - JOPLIN WEST 7TH - SUB 439 - STATELINE 161KV CKT 1 | Reconductor 161KV Line | 6/1/2017 | 6/1/2017 |
| EMDE | SUB 145 - JOPLIN WEST 7TH - SUB 64 - JOPLIN 10TH ST. 69KV CKT 1 | Replace Disconnect Switches and Leads on Breaker #6965 at Sub #64 and #6932 at Sub #145 | 6/1/2013 | 6/1/2013 |
| EMDE | SUB 170 - NICHOLS ST. - SUB 80 - MARSHFIELD JCT. 69KV CKT 1 | Reconductor line from Sub #80 to Sub #170 from 1/0 CU to 556 ACSR and replace Jumpers in Sub #80 | 6/1/2012 | 6/1/2012 |
| KACP | AVONDALE - GLADSTONE 161KV CKT 1 | Upgrade Wavetrap at Gladstone from 800 amps to 1200 amps | 6/1/2010 | 6/1/2010 |
| KACP | CRAIG - LENEXA SOUTH 161KV CKT 1 Displacement | Replace Lenexa R1-4 breaker | 6/1/2017 | 6/1/2017 |
| KACP | Craig 161KV 20MVAR Upgrade | Increase the size of the Craig 161kV cap bank by 20 MVar from 50MVar to 70MVar. | 6/1/2013 | 6/1/2013 |
| KACP | REDEL - STILWELL 161KV CKT 1 | Reconductor line with 1192 ACSS and upgrade terminal equipment for 2000 amps | 10/1/2008 | 6/1/2011 |
| MIDW | LYONS - WHEATLAND 115KV CKT 1 MIDW | Rebuild 98.5% ownership of 19.4 miles | 6/1/2017 | 6/1/2017 |
| MIPU | ALABAMA - LAKE ROAD 161KV CKT 1 | re-set the over current relay to trip the Lake Road-Alabama section when flow goes above 161 MVA | 6/1/2011 | 6/1/2011 |
| MIPU | BLUE SPRINGS EAST - DUNCAN ROAD 161KV CKT 1 | Upgrade to conductor: Bundled Drake | 10/1/2008 | 6/1/2010 |
| MIPU | MARTIN CITY - TURNER ROAD SUBSTATION 161KV CKT 1 | Upgrade to bundled 795 26/7 ACSR conductor | 10/1/2008 | 6/1/2013 |
| MIPU | SIBLEY 161/69KV TRANSFORMER CKT 2 | Add the 2nd parallel 161/69kV Transformer at Sibley plant | 10/1/2008 | 6/1/2010 |
| MIPU | South Harper - Freeman 69 kV | re-set the existing over current relay unit installed at South Harper 69 kV Sub to trip South Harper - Freeman 69 kV line | 10/1/2008 | 10/1/2008 |
| MKEC | CLAY CENTER - GREENLEAF 115KV CKT 1 | Building a new 115 KV tie with Westar from Greenleaf to Clay Center | 10/1/2008 | 6/1/2011 |
| SJLP | MIDWAY - ST JOE 161KV CKT 1 | Upgrade to 795 26/7 ACSR Conductor | 12/1/2012 | 12/1/2012 |
| SPS | SOUTH PLAINS REC-YUMA - WOLFFORTH INTERCHANGE 115KV CKT 1 | Replace Terminal Equipment | 1/1/2010 | 6/1/2012 |
| SWPA | CLARKSVILLE - DARDANELLE 161KV CKT 1 | Reconductor Clarksville-Dardanelle line | 6/1/2012 | 6/1/2012 |
| WERE | 95TH & WAVERLY - CAPTAIN JUNCTION 115KV CKT 1 | Rebuild 7.61 miles from 95th & Waverly-Captain Junction 115 KV line. | 6/1/2011 | 6/1/2011 |
| WERE | BU - CITY OF MCPHERSON JOHNS-MANVILLE - EAST MCPHERSON SWITCHING STATION 115KV CKT 1 | Rebuild Line | 6/1/2009 | 6/1/2011 |
| WERE | CHAPMAN - CLAY CENTER JUNCTION 115KV CKT 1 | Reset terminal equipment | 10/1/2008 | 6/1/2011 |
| WERE | COWSKIN - WESTLINK 69KV | Rebuild 2.11 miles | 6/1/2010 | 6/1/2010 |
| WERE | EVANS ENERGY CENTER SOUTH - LAKERIDGE 138KV CKT 1 #2 | Reconductor 8.02 miles with Bundled 1192.5 ACSR | 6/1/2016 | 6/1/2016 |
| WERE | HOOVER NORTH - LAKERIDGE 138KV CKT 1 | Replace Disconnect Switches, Wavetrap, Breaker, Jumpers | 6/1/2016 | 6/1/2016 |
| WERE | HOOVER SOUTH - TYLER 69KV | Rebuild 1.94 miles | 6/1/2010 | 6/1/2010 |
| WERE | LYONS - WHEATLAND 115KV CKT 1 WERE | Rebuild 1.5% ownership of 19.4 miles | 6/1/2017 | 6/1/2017 |
| WERE | STRANGER CREEK - NW LEAVENWORTH 115KV | Rebuild 11.62-mile Jarbalo-NW Leavenworth 115 kV line and tap in & out of Stranger 115 kV | 6/1/2009 | 6/1/2010 |
| WERE | TYLER - WESTLINK 69KV | Rebuild 2.66 miles and operate line normally closed | 6/1/2010 | 6/1/2010 |

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Previously Assigned Aggregate Study Upgrades requiring credits to Previous Aggregate Study Customers.

| Transmission Owner | Upgrade | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) |
|--------------------|----------------------|---|--------------------------------------|--|
| WERE | WICHITA - RENO 345KV | 40 mile 345 kV transmission line from existing Wichita 345 kV substation to a new 345-115 kV substation in Reno County east northeast of Hutchinson (Wichita to Reno) | 10/1/2008 | 12/1/2008 |
| WERE | WICHITA - RENO 345KV | Build 345kV from Wichita to Reno Co | 10/1/2008 | 12/1/2008 |

Table 5 - Third Party Facility Constraints

| Transmission Owner | UpgradeName | Solution | Earliest Date Upgrade Required (DUN) | Estimated Date of Upgrade Completion (EOC) | Estimated Engineering & Construction Cost |
|--------------------|---|---|--------------------------------------|--|---|
| AECI | CLINTON - HOLDEN 161KV CKT 1 | Indeterminate | 06/01/17 | 06/01/17 | Indeterminate |
| AECI | HUBEN (HUBEN) 345/161/13.8KV TRANSFORMER CKT 1 | Indeterminate | 12/01/12 | 12/01/12 | Indeterminate |
| AECI | JAMESVILLE - SUB 415 - BLACKHAWK JCT. 69KV CKT 1 AECI | Indeterminate | 06/01/14 | 06/01/14 | Indeterminate |
| ENTR | 3GRENWD 115.00 - HUMPHREY 115KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | 3GRENWD 115.00 - TERREBONNE 115KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | 3RUSTNE 115.00 - DOWNSVILLE 115KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | 3RUSTNE 115.00 - VIENNA 115KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | 4EOPLOUS 138.00 - CHAMPAGNE 138KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | 4KSPRGs 138.00 - LINE 642 TAP 138KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | 4NCROWL 138.00 - SCOTT 138KV CKT 1 | Indeterminate | 06/01/11 | 06/01/11 | Indeterminate |
| ENTR | 4SCOTT2 138.00 - 4SEMERE 138.00 138KV CKT 1 | Indeterminate | 06/01/09 | 06/01/09 | Indeterminate |
| ENTR | 5BEE BR - QUITMAN 161KV CKT 1 | Indeterminate | 06/01/09 | 06/01/09 | Indeterminate |
| ENTR | 5CLINTN - CLINTON WEST (AEC) 161KV CKT 1 | Indeterminate | 12/01/12 | 12/01/12 | Indeterminate |
| ENTR | 5ST_JOE 161.00 - EVERTON 161KV CKT 1 | Indeterminate | 12/01/08 | 12/01/08 | Indeterminate |
| ENTR | 8WELLS 500.00 - WEBRE 500KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | 8WELLS 500.00 500/230KV TRANSFORMER CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | ADAMS CREEK - BOGALUSA 230KV CKT 2 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | ARKANSAS NUCLEAR ONE 161 - RUSSELLVILLE NORTH 161KV CKT 1 | Indeterminate | 06/01/09 | 06/01/09 | Indeterminate |
| ENTR | CECELIA - DOC BONIN 138KV CKT 1 | Indeterminate | 12/01/08 | 12/01/08 | Indeterminate |
| ENTR | CECELIA - MORIL 138KV CKT 1 | Indeterminate | 12/01/09 | 12/01/09 | Indeterminate |
| ENTR | DARDANELLE - RUSSELLVILLE SOUTH 161KV CKT 1 ENTR | Indeterminate | 06/01/09 | 06/01/09 | Indeterminate |
| ENTR | DOC BONIN - SCOTT 138KV CKT 1 | Indeterminate | 06/01/09 | 06/01/09 | Indeterminate |
| ENTR | EVERTON - HARRISON-EAST 161KV CKT 1 | Indeterminate | 12/01/08 | 12/01/08 | Indeterminate |
| ENTR | FRONT STREET - SLIDELL 230KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | GIBSON - HUMPHREY 115KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | GIBSON - RAMOS 138KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | GIBSON 138/115KV TRANSFORMER CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | GRIMES - MT. ZION 138KV CKT 1 | Indeterminate | 06/01/11 | 06/01/11 | Indeterminate |
| ENTR | HARRISON-EAST - SUMMIT 161KV CKT 1 | Indeterminate | 06/01/11 | 06/01/11 | Indeterminate |
| ENTR | HARTBURG - INLAND-ORANGE 230KV CKT 1 | Indeterminate | 01/01/10 | 06/01/11 | Indeterminate |
| ENTR | LINE 642 TAP - LIVONIA BULK 138KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | LIVONIA BULK - WILBERT 138KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | LOUISIANA STATION - WILBERT 138KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | MAGAZINE REC - NORTH MAGAZINE 161KV CKT 1 ENTR | Rebuild 7.43 miles of 250 CWC with 795 ACSR | 06/01/10 | 06/01/10 | Indeterminate |
| ENTR | RUSSELLVILLE EAST - RUSSELLVILLE NORTH 161KV CKT 1 | Indeterminate | 06/01/09 | 06/01/09 | Indeterminate |
| ENTR | RUSSELLVILLE EAST - RUSSELLVILLE SOUTH 161KV CKT 1 | Indeterminate | 11/01/08 | 11/01/08 | Indeterminate |
| ENTR | WATERFORD - WILLOW GLEN 500KV CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| ENTR | WATERFORD 500/230KV TRANSFORMER CKT 1 | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |
| LAFA | DOC BONIN 230/138KV TRANSFORMER CKT 1 | Indeterminate | 06/01/09 | 06/01/09 | Indeterminate |
| NPPD | GENTLMREDWIL | Indeterminate | 10/01/08 | 10/01/08 | Indeterminate |