



SPP

*Southwest
Power Pool*

***System Impact Study
SPP-2007-003
For Transmission Service
Requested By:
American Electric Power***

From AEPW to AEPW

***For a Reserved Amount Of
200 MW***

***From 02/13/2007
To 02/14/2007***

SPP Transmission Planning

1. EXECUTIVE SUMMARY	3
2. INTRODUCTION	5
3. STUDY METHODOLOGY.....	6
A. DESCRIPTION	6
B. MODEL UPDATES	6
C. TRANSFER ANALYSIS	6
4. STUDY RESULTS	7
5. CONCLUSION.....	10

1. Executive Summary

American Electric Power has requested a system impact study for daily firm transmission service from AEPW to AEPW. The period of the transaction is from 02/13/2007 to 02/14/2007. The request is for reservation 1228427 for the amount of 200 MW.

The 200 MW transaction from AEPW to AEPW has an impact on the following flowgate with no AFC: PECXFRMUSFTS. To provide the AFC necessary for this transfer, the impact on this flowgate must be relieved.

After studying many scenarios using curtailment of reservations and generation redispatch, there are several feasible scenarios that will relieve the flowgate in question.

2. Introduction

American Electric Power has requested a system impact study for transmission service from AEPW to AEPW.

There is one constrained flowgate that requires relief in order for this reservation to be accepted. The flowgate and the explanation are as follows:

- PECXFRMUSFTS: Pecan 345/161 kV XFR for the loss of Muskogee to Fort Smith 345 kV line

3. Study Methodology

A. Description

Southwest Power Pool used Managing and Utilizing System Transmission (MUST) to obtain possible unit pairings that would relieve the constraint. MUST calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

B. Model Updates

The 2006 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

C. Transfer Analysis

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using Managing and Utilizing System Transmission (MUST), specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by MUST is the amount of redispatch necessary to relieve the impact on the affected flowgate.

4. Study Results

After studying the impacts of request 1228427, one flowgate requires relief. The flowgate the associated amount of relief is as follows:

Table 1

Flowgates	Sensitivity (%)	Duration	Required Relief (MW)
PECXFRMUSFTS	4.8	February 13	10

Table 2 displays a list of generator pairs that are possible relief options for the flowgates in question.

Table 2

Source	Sink	PECXFRMUSFTS Sensitivity (%)
Welsh (AEPW)	NES (AEPW)	2.4
Wilkes (AEPW)	NES (AEPW)	2.7
Wilkes (AEPW)	SWS (AEPW)	2.2
Welsh (AEPW)	SWS (AEPW)	2.0
Wilkes (AEPW)	RSS (AEPW)	2.5
Weleetka (AEPW)	NES (AEPW)	4.4
Weleetka (AEPW)	RSS (AEPW)	4.3
Weleetka (AEPW)	SWS (AEPW)	4.0
Weleetka (AEPW)	TPS (AEPW)	4.0
Dolet Hills (AEPW)	Commanche (AEPW)	3.0
Dolet Hills (AEPW)	RSS (AEPW)	3.0

Table 3 displays the amount of redispatch capacity necessary for each generator pair.

Table 3

Source	Sink	PECXFRMUSFTS Relief (MW)
Welsh (AEPW)	NES (AEPW)	417
Wilkes (AEPW)	NES (AEPW)	370
Wilkes (AEPW)	SWS (AEPW)	454
Welsh (AEPW)	SWS (AEPW)	500
Wilkes (AEPW)	RSS (AEPW)	400
Weleetka (AEPW)	NES (AEPW)	227
Weleetka (AEPW)	RSS (AEPW)	232
Weleetka (AEPW)	SWS (AEPW)	250
Weleetka (AEPW)	TPS (AEPW)	250
Dolet Hills (AEPW)	Commanche (AEPW)	333
Dolet Hills (AEPW)	RSS (AEPW)	333

5. Conclusion

Reservation curtailment and generation redispatch options were studied in order to relieve the necessary constraint. The results of this study shows that the constraints on the flowgate in question could be relieved by executing one or more of the options described in the Study Results section of this document. Before the Transmission Provider accepts the reservations, proof of the necessary relief options must be presented to Southwest Power Pool. Noncompliance with this guideline will result in the refusal of the reservation.