



**Definitive Interconnection
System Impact Study for
Generation Interconnection
Requests**

(DISIS-2010-002-4)

**February, 2013
Generation Interconnection**

Revision History

Date or Version Number	Author	Change Description
01/31/2011	SPP	Report Issued (DISIS-2010-002)
07/26/2011	SPP	Account for Withdrawn Projects, Report Re-Posted (DISIS-2010-002-1)
11/08/2011	SPP	Account for Withdrawn Projects, Report Re-Posted (DISIS-2010-002-2)
03/25/2012	SPP	Account for Withdrawn Projects, Report Re-Posted (DISIS-2010-002-3)
2/8/2013	SPP	Account for Withdrawn Projects, Report Re-Posted (DISIS-2010-002-4)

Executive Summary

Generation Interconnection customers have requested a Definitive Interconnection System Impact Study (DISIS) under the Generation Interconnection Procedures (GIP) in the Southwest Power Pool Open Access Transmission Tariff (OATT). The Interconnection Customers' requests have been clustered together for the following System Impact Cluster Study window which closed September 30, 2010. The customers will be referred to in this study as the DISIS-2010-002 Interconnection Customers. This System Impact Study analyzes the interconnecting of multiple generation interconnection requests associated with new generation totaling approximately 1,212.7 MW of new generation which would be located within the transmission systems of Midwest Energy Inc. (MIDW), Oklahoma Gas and Electric (OKGE), Omaha Public Power District (OPPD), Sunflower Electric Power Corporation/Mid-Kansas Electric Power LLC (SUNC)/(MKEC), Southwestern Public Service (SPS), and Westar Energy (WERE). The various generation interconnection requests have differing proposed in-service dates¹. The generation interconnection requests included in this System Impact Cluster Study are listed in Appendix A by their queue number, amount, requested interconnection service, area, requested interconnection point, proposed interconnection point, and the requested in-service date. This restudy was performed to account for withdrawals within the DISIS-2010-002 study and/or higher queued projects withdrawing.

Power flow analysis has indicated that for the power flow cases studied, 1,212.7 MW of nameplate generation may be interconnected with transmission system reinforcements within the SPP transmission system. Dynamic stability and power factor analysis has determined the need for reactive compensation in accordance with Order No. 661-A for wind farm interconnection requests and those requirements are listed for each interconnection request within the contents of this report. Dynamic stability analysis has determined that the transmission system will remain stable with the assigned Network Upgrades and necessary reactive compensation requirements.

The total estimated minimum cost for interconnecting the DISIS-2010-002 interconnection customers is \$25,762,557. These costs are shown in Appendix E and F. Interconnection Service to DISIS-2010-002 interconnection customers is also contingent upon higher queued customers paying for certain required network upgrades. **The in service date for the DISIS customers will be deferred until the construction of these network upgrades can be completed.**

These costs do not include the Interconnection Customer Interconnection Facilities as defined by the SPP Open Access Transmission Tariff (OATT). This cost does not include additional network constraints in the SPP transmission system identified and shown in Appendix H.

¹ The generation interconnection requests in-service dates will need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customer's that proceed to the Facility Study will be provided a new in-service date based on the Facility Study's time for completion of the Network Upgrades necessary.

Network Constraints listed in Appendix H are in the local area of the new generation when this generation is injected throughout the SPP footprint for the Energy Resource (ERIS) Interconnection Request. Certain Interconnection Requests were also studied for Network Resource Interconnection Service (NRIS). Those constraints are also listed in Appendix H. Additional Network constraints will have to be verified with a Transmission Service Request (TSR) and associated studies. With a defined source and sink in a TSR, this list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

The required interconnection costs listed in Appendix E and F do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT.

Table of Contents

Introduction	1
Model Development	1
Identification of Network Constraints	5
Determination of Cost Allocated Network Upgrades.....	5
Interconnection Facilities	6
Power Flow Analysis	6
Stability Analysis	9
Conclusion	10
Appendix.....	11
A: Generation Interconnection Requests Considered for Impact Study.....	A0
B: Prior Queued Interconnection Requests.....	B0
C: Study Groupings	C0
D: Proposed Point of Interconnection One line Diagrams	D0
E: Cost Allocation per Interconnection Request (Including Prior Queued Upgrades)	E0
F: Cost Allocation per Proposed Study Network Upgrade	F0
G: Power Flow Analysis (Constraints For Mitigation)	G0
H: Power Flow Analysis (Other Constraints Not Requiring Mitigation)	H0
I: Category C Contingency Analysis.....	I0

Introduction

Pursuant to the Southwest Power Pool (SPP) Open Access Transmission Tariff (OATT), SPP has conducted this Definitive Interconnection System Impact Study (DISIS) for certain generation interconnection requests in the SPP Generation Interconnection Queue. These interconnection requests have been clustered together for the following System Impact Study window which closed September 30, 2010. The customers will be referred to in this study as the DISIS-2010-002 Interconnection Customers. This System Impact Study analyzes the interconnecting of multiple generation interconnection requests associated with new generation totaling 1,212.7 MW of new generation which would be located within the transmission systems of Midwest Energy Inc. (MIDW), Oklahoma Gas and Electric (OKGE), Omaha Public Power District (OPPD), Sunflower Electric Power Corporation/Mid-Kansas Electric Power LLC (SUNC)/(MKEC), Southwestern Public Service (SPS), and Westar Energy (WERE). The various generation interconnection requests have differing proposed in-service dates². The generation interconnection requests included in this System Impact Study are listed in Appendix A by their queue number, amount, requested interconnection service, area, requested interconnection point, proposed interconnection point, and the requested in-service date. This restudy was performed to account for withdrawals within the DISIS-2010-002 cluster study and/or higher queued projects withdrawing.

The primary objective of this Definitive Interconnection System Impact Study is to identify the system constraints associated with connecting the generation to the area transmission system. The Impact and other subsequent Interconnection Studies are designed to identify attachment facilities, Network Upgrades and other Direct Assignment Facilities needed to accept power into the grid at each specific interconnection receipt point.

Model Development

Interconnection Requests Included in the Cluster

SPP has included all interconnection requests that submitted a Definitive Interconnection System Impact Study Agreement no later than September 30, 2010 and were subsequently accepted by Southwest Power Pool under the terms of the Generator Interconnection Procedures (GIP) that became effective March 30, 2010. The interconnection requests that are included in this study are listed in Appendix A.

² The generation interconnection requests in-service dates will need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customer's that proceed to the Facility Study will be provided a new in-service date based on the competition of the Facility Study.

Affected System Interconnection Requests

Also included in this Definitive Impact Study are three Affected System Studies, all located on the Lea County Electric Cooperative (LCEC) system, which is located in Lea County, New Mexico, and shares connections to the SPS system. The Affected System Study Requests has been given the designations: ASGI-2010-020 (30 MW, POI is a tap on LCEC-Tatum – LCEC-Crossroads 69kV), ASGI-2010-021 (15 MW, POI is a tap on LCEC-Saunders – LCEC-Anderson 69kV), and ASGI-2011-001 (28.8 MW, POI is at LCEC-Lovington 115kV).

Previously Queued Interconnection Requests

The previous queued requests included in this study are listed in Appendix B. In addition to the Base Case Upgrades, the previous queued requests and associated upgrades were assumed to be in-service and added to the Base Case models. These projects were dispatched as Energy Resources with equal distribution across the SPP footprint.

Development of Base Cases

Power Flow

The 2012 series Transmission Service Request (TSR) Models 2013 spring, 2013 summer and winter peak, and the 2018 summer and winter peak, and 2023 summer peak scenario 0 cases were used for this study. After the cases were developed, each of the control areas' resources were then re-dispatched to account for the new generation requests using current dispatch orders.

Dynamic Stability

The 2012 series SPP Model Development Working Group (MDWG) Models 2014 winter and 2014 summer were used as starting points for this study.

Base Case Upgrades

The following facilities are part of the SPP Transmission Expansion Plan or the Balanced Portfolio or recently approved Priority Projects. These facilities, have an approved Notice to Construct (NTC), or are in construction stages and were assumed to be in-service at the time of dispatch and added to the base case models. The DISIS-2010-002 Customers have not been assigned acceleration costs for the below listed projects. The DISIS-2010-002 Customers Generation Facilities in service dates may need to be delayed until the completion of the following upgrades. If for some reason, construction on these projects is discontinued, additional restudies will be needed to determine the interconnection needs of the DISIS customers.

- Hitchland 230/115kV area projects³:
 - Hitchland – Moore County 230kV, (placed in-service in 2012)
 - Hitchland – Ochiltree 230kV Project, scheduled for 12/31/2012 in-service
- Valliant – Hugo – Sunnyside 345kV, (placed in-service in 2012)⁴

³ SPP Regional Reliability Projects identified in 2007 STEP. As of the writing of this report, SPP Project Tracking TAGIT shows some of these project's in-service dates have been delayed from the original 2010/2011 in-service dates.

⁴ SPP Transmission Service Projects identified in SPP-2006-AG3-AFS-11.

- Rose Hill – Sooner 345kV, (placed in-service in 2012)⁵
- Balanced Portfolio Projects⁶:
 - Woodward – Border – TUCO 345kV project, scheduled for 5/19/2014 in-service
 - Woodward 345/138kV circuit #2 autotransformer
 - TUCO 345/138kV circuit #2 autotransformer
 - Reactors at Woodward and Border
 - Iatan– Nashua 345kV, scheduled for 6/1/2015 in-service
 - Nashua 345/161kV autotransformer
 - Muskogee– Seminole 345kV, scheduled for 12/31/2013 in-service
 - Spearville – Post Rock 345kV, (placed in service in 2012)
 - Post Rock 345/230kV autotransformer, (placed in-service in 2012)
 - Post Rock – Axtell 345kV, , (placed in-service in 2012)
 - Cleveland – Sooner 345kV, scheduled for 12/31/2012 in-service
 - Tap Stillwell – Swissvale 345kV line at West Gardner, scheduled for 12/31/2012 in-service
- Priority Projects⁷:
 - Hitchland – Woodward double circuit 345kV, scheduled for 6/30/2014 in-service
 - Hitchland 345/230kV autotransformer
 - Woodward – Thistle double circuit 345kV, scheduled for 12/31/2014 in-service
 - Spearville – Clark double circuit 345kV, scheduled for 12/31/2014 in-service
 - Clark – Thistle double circuit 345kV, scheduled for 12/31/2014 in-service
 - Thistle – Wichita double circuit 345kV, scheduled for 12/31/2014 in-service
 - Thistle 345/138kV autotransformer, scheduled for 12/31/2014 in-service
 - Thistle – Flat Ridge 138kV, scheduled for 12/31/2014 in-service
- Various MKEC Transmission System Upgrades⁸
 - Harper – Flat Ridge 138kV rebuild, scheduled for 12/31/2013 in-service
 - Flat Ridge – Medicine Lodge 138kV rebuild, scheduled for 12/31/2013 in-service
 - Pratt – Medicine Lodge 115kV rebuild, scheduled for 6/1/2013 in-service
 - Medicine Lodge 138/115kV autotransformer replacement, scheduled for 6/1/2013 in-service

Contingent Upgrades

The following facilities do not yet have approval. These facilities have been assigned to higher queued interconnection customers. These facilities have been included in the models for the DISIS-2010-002 study and are assumed to be in service. This list may not be all inclusive. The DISIS-2010-002 Customers at this time do not have responsibility for these facilities but may later be assigned the cost of these facilities if higher queued customers terminate their GIA or withdraw from the

⁵ SPP Regional Reliability Project. Approved based on an order of the Kansas Corporation Commission issued in Docket no. 07-WSEE-715-MIS.

⁶ Notice to Construct (NTC) issued June 2009.

⁷ Notice to Construct (NTC) issued June 2010.

⁸ SPP Transmission Service Projects identified in SPP-2007-AG3-AFS-9.

interconnection queue. The DISIS-2010-002 Customer Generation Facilities in service dates may need to be delayed until the completion of the following upgrades.

- Upgrades assigned to 1st Cluster (ICS-2008-001) Interconnection Customers:
 - Amarillo - Swisher 230kV CKT 1 Rerate replace line traps
 - Clinton Jct - GEN-2007-032 Tap - Clinton 138kV Rerate
 - Finney-Holcomb 345kV 2nd Circuit
- Upgrades assigned to DISIS-2009-001 Interconnection Customers:
 - Fort Dodge – North Fort Dodge – Spearville 115kV circuit #2
 - Albion – Petersburg – Neligh 115kV rerate (placed in service 2011)
 - Fort Randall – Madison County – Kelly 230kV rerate (320MVA)
 - Spearville 345/115kV autotransformer
- Upgrades assigned to DISIS-2010-001 Interconnection Customers:
 - Post Rock 345/230kV circuit #2 autotransformer
 - South Hays – Hays Plant – Vine Street 115kV rebuild
 - Switch 2749 – Wildorado 69kV rebuild
 - Madison County – Kelly 230kV rerate (478MVA)
 - Washita – Gracemont 138kV circuit #2 (placed in service 2012)

Potential Upgrades Not in the Base Case

Any potential upgrades that do not have a Notification to Construct (NTC) have not been included in the base case. These upgrades include any identified in the SPP Extra-High Voltage (EHV) overlay plan, or any other SPP planning study other than the upgrades listed above in the previous section.

Regional Groupings

The interconnection requests listed in Appendix A were grouped together in fifteen different regional groups based on geographical and electrical impacts. These groupings are shown in Appendix C.

To determine interconnection impacts, fifteen different dispatch variations of the spring base case models were developed to accommodate the regional groupings.

Power Flow

For each interconnection request, the generator was dispatched at 100% of nameplate in each season. In light load seasons (2012 spring), within each group, all other wind generating plants were dispatched at 80% nameplate of maximum generation. In the groups the generator was not a part, the wind generating plants were dispatched at 20% nameplate of maximum generation. This process created multiple scenarios with each interconnection request being studied at 100% nameplate while other request being studied at 80% nameplate rating. These projects were dispatched as Energy Resources with equal distribution across the SPP footprint. Certain projects that requested Network Resource Interconnection Service were dispatched in an additional analysis into the balancing authority of the interconnecting transmission owner. This method allowed for the identification of network constraints that were common to the regional groupings that could then in turn have the mitigating upgrade cost allocated throughout the entire cluster.

Peaking units were not dispatched in the 2013 spring model. To study peaking units' impacts, the 2013 summer and winter, 2018 summer and winter, and 2023 summer peak seasonal models were chosen and peaking units were modeled at 100% of the nameplate rating and wind generating facilities were modeled at 10% of the nameplate rating. Each interconnection request was also modeled separately at 100% nameplate for certain analyses.

Dynamic Stability

For each group, all interconnection requests were studied at 100% nameplate output while the other groups were dispatched at 20% output for wind requests and 100% output for fossil requests.

Identification of Network Constraints

The initial set of network constraints were found by using PTI MUST First Contingency Incremental Transfer Capability (FCITC) analysis on the entire cluster grouping dispatched at the various levels mentioned above. These constraints were then screened to determine if any of the generation interconnection requests had at least a 20% Distribution Factor (DF) upon the constraint. Constraints that measured at least a 20% DF from at least one interconnection request were considered for mitigation. Interconnection Requests that were being studied for Network Resource Interconnection Service (NRIS) were studied in the additional NRIS analysis to determine if any constraint had at least a 3% DF. If so, these constraints were considered for mitigation.

Determination of Cost Allocated Network Upgrades

Cost Allocated Network Upgrades of wind generation interconnection requests were determined using the 2013 spring model. Cost Allocated Network Upgrades of peaking units was determined using the 2018 summer peak model. A MUST sensitivity analysis was performed to determine the Distribution Factors (DF), a distribution factor with no contingency that each generation interconnection request had on each new upgrade. The impact each generation interconnection request had on each upgrade project was weighted by the size of each request. Finally the costs due by each request for a particular project were then determined by allocating the portion of each request's impact over the impact of all affecting requests.

For example, assume that there are three Generation Interconnection requests, X, Y, and Z that are responsible for the costs of Upgrade Project '1'. Given that their respective PTDF for the project have been determined, the cost allocation for Generation Interconnection request 'X' for Upgrade Project 1 is found by the following set of steps and formulas:

- Determine an Impact Factor on a given project for all responsible GI requests:

$$\text{Request X Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(X) * \text{MW}(X) = X1$$

$$\text{Request Y Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Y) * \text{MW}(Y) = Y1$$

$$\text{Request Z Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Z) * \text{MW}(Z) = Z1$$

- Determine each request's Allocation of Cost for that particular project:

$$\text{Request X's Project 1 Cost Allocation (\$)} = \frac{\text{Network Upgrade Project 1 Cost(\$)} * X1}{X1 + Y1 + Z1}$$

- Repeat previous for each responsible GI request for each Project

The cost allocation of each needed Network Upgrade is determined by the size of each request and its impact on the given project. This allows for the most efficient and reasonable mechanism for sharing the costs of upgrades.

Credits for Amounts Advanced for Network Upgrades

Interconnection Customer shall be entitled to credits in accordance with Attachment Z1 of the SPP Tariff for any Network Upgrades including any tax gross-up or any other tax-related payments associated with the Network Upgrades, and not refunded to the Interconnection Customer.

Interconnection Facilities

The requirement to interconnect the 1,212.7 MW of generation into the existing and proposed transmission systems in the affected areas of the SPP transmission footprint consist of the necessary cost allocated shared facilities listed in Appendix F by upgrade. The interconnection requirements for the cluster total \$25,762,557. Interconnection Facilities specific to each generation interconnection request are listed in Appendix E. A preliminary one-line drawing for each generation interconnection request are listed in Appendix D.

A list of constraints with greater than or equal to a 20% DF that were identified and used for mitigation are listed in Appendix G. Other Network Constraints, those between 3% and 20% DF, which were not used are shown in Appendix H. With a defined source and sink in a TSR, this list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

Power Flow Analysis

Power Flow Analysis Methodology

The ACCC function of PSS/E was used to simulate single element and special (i.e., breaker-to-breaker, multi-element, etc) contingencies in portions or all of the modeled control areas of SPP, as well as, other control areas external to SPP and the resulting scenarios analyzed. NERC Category "B" and "C" contingencies were evaluated.

Power Flow Analysis

A power flow analysis was conducted for each Interconnection Customer's facility using modified versions of the 2013 spring peak, 2013 summer and winter peak, and the 2018 summer and winter peak, and 2023 summer peak models. The output of the Interconnection Customer's facility was offset in each model by a reduction in output of existing online SPP generation. This method allows the request to be studied as an Energy Resource (ER) Interconnection Request. Certain requests that requested Network Resource Interconnection Service (NRIS) had an additional analysis conducted for displacing resources in the interconnecting Transmission Owner's balancing authority.

This analysis was conducted assuming that previous queued requests in the immediate area of these interconnect requests were in-service. The analysis of each Customer's project indicates that criteria violations will occur on the NPPD, OKGE, and SPS transmission systems under steady state and contingency conditions in the peak seasons.

Cluster Group 1 (Woodward Area)

In addition to the 3,001.6 MW of previously queued generation in the area, 300.0 MW of new interconnection service was studied. With Base Case and previously allocated network upgrades in service, no new upgrades are necessary for interconnection of the generators in this group. No new constraints for mitigation were found in this area.

Cluster Group 2 (Hitchland Area)

In addition to the 1,966.7 MW of previously queued generation in the area, 300.0 MW of new interconnection service was studied. With the withdrawal of higher queued and DISIS-2010-002 requests, the interconnection constraints are alleviated for the expansion of the Beaver County 345kV to interconnect both Hitchland-Woodward 345kV lines into the Beaver County Substation.

Cluster Group 3 (Spearville Area)

In addition to the 2,695.6 MW of previously queued generation in the area, 197.8 MW of new interconnection service was studied. With Base Case and previously allocated network upgrades in service, no new upgrades are necessary for interconnection of the generators in this group. No new constraints for mitigation were found in this area.

Cluster Group 4 (NW Kansas Group)

In addition to the 1,917.1 MW of previously queued generation in the area, 70.0 MW of new interconnection service was studied. With Base Case and previously allocated network upgrades in service, no new upgrades are necessary for interconnection of the generators in this group. No new constraints for mitigation were found in this area.

Cluster Group 5 (Amarillo Area)

In addition to the 1,572.6 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

Cluster Group 6 (South Texas Panhandle/New Mexico)

In addition to the 1,771.2 MW of previously queued generation in the area, 129.8 MW of new interconnection service was studied. Lowered capacity for the ASGI-2010-020 and ASGI-2010-021 requests has relieved the thermal overloading on the 69kV transmission line from the ASGI-2010-020 Tap – LCEC-Tatum – LCEC-McDonald – LCEC-Reed – LCEC-Lovington that was previously being mitigated.

Cluster Group 7 (Southwestern Oklahoma)

In addition to the 1,669.0 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

Cluster Group 8 (South Central Kansas/North Oklahoma)

In addition to the 1,831.4 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

Cluster Group 9/10 (Nebraska)

In addition to the 1,261 MW of previously queued generation in the area, 210.5 MW of new interconnection service was studied. Through further investigation by the transmission owner, additional work will be required on the GEN-2010-051 Tap – Twin Church – Dixon County 230kV to accommodate the interconnection of GEN-2010-051.

MONTCOMMONNAME	RATEB	TDF	TC%LOADING	CONTNAME
'G10-51T 230.00 - TWIN CHURCH 230KV CKT 1'	192	1	104.5287	'G10-51T 230.00 - HOSKINS 230KV CKT 1'
'G10-51T 230.00 - HOSKINS 230KV CKT 1'	192	1	104.2096	'G10-51T 230.00 - TWIN CHURCH 230KV CKT 1'

Cluster Group 12 (Northwest Arkansas)

In addition to the 0.0 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

Cluster Group 13 (Northwest Missouri)

In addition to the 380 MW of previously queued generation in the area, 4.6 MW of new interconnection service was studied. No new constraints were found in this area.

Cluster Group 14 (South Central Oklahoma)

In addition to the 200.0 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

Stability Analysis

The Stability Analysis was not repeated as no major transmission configuration was necessary as a result of this restudy. Previous Impact Studies for DISIS-2010-002 should be consulted for power factor requirements.

Conclusion

The minimum cost of interconnecting 1,212.7 MW of new interconnection requests included in this Definitive Interconnection System Impact Study is estimated at \$25,762,557 for the Allocated Network Upgrades and Transmission Owner Interconnection Facilities are listed in Appendix E and F. These costs do not include the cost of upgrades of other transmission facilities listed in Appendix H which are Network Constraints.

These interconnection costs do not include any cost of Network Upgrades determined to be required by short circuit analysis. These studies will be performed if the Interconnection Customer executes the appropriate Interconnection Facilities Study Agreement and provides the required data along with demonstration of Site Control and the appropriate deposit. At the time of the Interconnection Facilities Study, a better determination of the interconnection facilities may be available.

The required interconnection costs listed in Appendices E, and F, and other upgrades associated with Network Constraints do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request (TSR) through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP Open Access Transmission Tariff (OATT).

Appendix

A: Generation Interconnection Requests Considered for Impact Study

See next page.

A: Generation Interconnection Requests Considered for Impact Study

Request	Amount	Service	Area	Requested Point of Interconnection	Proposed Point of Interconnection	Requested In-Service Date	In Service Date Delayed Until no earlier than*
ASGI-2010-020	30.0	ER	SPS	Tap LE-Tatum - LE-Crossroads 69kV	Tap LE-Tatum - LE-Crossroads 69kV		
ASGI-2010-021	15.0	ER	SPS	Tap LE-Saunders Tap - LE-Anderson 69kV	Tap LE-Saunders Tap - LE-Anderson 69kV		
ASGI-2011-001	28.8	ER	SPS	LE-Lovington 115kV	Lovington 115kV		
GEN-2010-001	300.0	ER	SPS	Tap Hitchland - Woodward Ckt 1 (Beaver County) 345kV	Tap Hitchland - Woodward Ckt 1 (Beaver County) 345kV	1/1/2012	12/31/2014
GEN-2010-036	4.6	ER	WERE	6th Street 115kV	6th Street 115kV	8/1/2012	TBD
GEN-2010-040	300.0	ER/NR	OKGE	Cimarron 345kV	Cimarron 345kV	11/30/2011	TBD
GEN-2010-041	10.5	ER	OPPD	S 1399 161kV	S 1399 161kV	12/31/2011	TBD
GEN-2010-045	197.8	ER/NR	SUNCMKEC	Tap Holcomb - Spearville (Gray County) 345kV	Buckner 345kV	12/31/2012	12/31/2014
GEN-2010-046	56.0	ER	SPS	Tuco 230kV	TUCO Interchange 230kV	5/1/2013	12/31/2014
GEN-2010-048	70.0	ER/NR	MIDW	Tap Beach Station - Redline 115kV	Tap Beach Station - Redline 115kV	12/31/2011	12/31/2014
GEN-2010-051	200.0	ER	NPPD	Tap Twin Church - Hoskins 230kV	Tap Twin Church - Hoskins 230kV	12/15/2012	TBD
TOTAL						1,212.7	

*request dependent upon Priority Projects or Balanced Portfolio may be delayed until 12/31/2014. Other projects in service date to be determined after Facility Study.

B: Prior Queued Interconnection Requests

See next page.

B: Prior Queued Interconnection Requests

Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
ASGI-2010-006	150	AECI	Tap Fairfax (AECI) - Shilder (AEPW) 138kV	AECI queue Affected Study
ASGI-2010-010	42.2	SPS	Lovington 115kV	Lea County Affected Study
GEN-2001-014	96	WFEC	Ft Supply 138kV	On-Line
GEN-2001-026	74	WFEC	Washita 138kV	On-Line
GEN-2001-033	180	SPS	San Juan Tap 230kV	On-Line
GEN-2001-036	80	SPS	Norton 115kV	On-Line
GEN-2001-037	102	OKGE	FPL Moreland Tap 138kV	On-Line
GEN-2001-039A	105	SUNCMKEC	Tap Greensburg - Ft Dodge (Shooting Star Tap) 115kV	On Schedule for 2012
GEN-2001-039M	99	SUNCMKEC	Central Plains Tap 115kV	On-Line
GEN-2002-004	200	WERE	Latham 345kV	On-Line at 150MW
GEN-2002-005	120	WFEC	Red Hills Tap 138kV	On-Line
GEN-2002-008	240	SPS	Hitchland 345kV	On-Line at 120MW
GEN-2002-009	80	SPS	Hansford 115kV	On-Line
GEN-2002-022	240	SPS	Bushland 230kV	On-Line
GEN-2002-023N	0.8	NPPD	Harmony 115kV	On-Line
GEN-2002-025A	150	SUNCMKEC	Spearville 230kV	On-Line
GEN-2003-004 GEN-2004-023 GEN-2005-003	151.2	WFEC	Washita 138kV	On-Line
GEN-2003-005	100	WFEC	Anadarko - Paradise (Blue Canyon) 138kV	On-Line
GEN-2003-006A	200	SUNCMKEC	Elm Creek 230kV	On-Line
GEN-2003-019	250	MIDW	Smoky Hills Tap 230kV	On-Line
GEN-2003-020	160	SPS	Martin 115kV	On-Line at 80MW
GEN-2003-021N	75	NPPD	Ainsworth Wind Tap 115kV	On-Line
GEN-2003-022	120	AEPW	Washita 138kV	On-Line
GEN-2004-005N	30	NPPD	St Francis 115kV	On Suspension
GEN-2004-014	154.5	SUNCMKEC	Spearville 230kV	On Schedule for 2012
GEN-2004-020	27	AEPW	Washita 34.5kV	On-Line
GEN-2004-023N	75	NPPD	Columbus Co 115kV	On-Line
GEN-2005-005	18	OKGE	FPL Moreland Tap 138kV	IA Pending
GEN-2005-008	120	OKGE	Woodward 138kV	On-Line
GEN-2005-012	250	SUNCMKEC	Spearville 345kV	On Schedule for 2012
GEN-2005-013	201	WERE	Tap Latham - Neosho (Caney River) 345kV	On-Line
GEN-2006-002	101	AEPW	Sweetwater 230kV	On-Line
GEN-2006-006	205.5	SUNCMKEC	Spearville 345kV	IA Pending
GEN-2006-014	300	MIPU	Tap Maryville - Midway (Nodway Co) 161kV	On Suspension
GEN-2006-018	170	SPS	TUCO Interchange 230kV	On-Line
GEN-2006-020N	42	NPPD	Bloomfield 115kV	On-Line
GEN-2006-020S	18.9	SPS	DWS Frisco 115kV	On Schedule for 3/2012
GEN-2006-021	101	SUNCMKEC	Flat Ridge Tap 138kV	On-Line
GEN-2006-022	150	SUNCMKEC	Ninnescah 115kV	On Suspension
GEN-2006-024S	19.8	WFEC	Buffalo Bear Tap 69kV	On-Line
GEN-2006-026	604	SPS	Hobbs 230kV & Hobbs 115kV	On-Line
GEN-2006-031	75	MIDW	Knoll 115kV	On-Line
GEN-2006-032	200	MIDW	South Hays 230kV	On Suspension
GEN-2006-035	225	AEPW	Sweetwater 230kV	On-Line at 132MW

Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2006-037N1	75	NPPD	Broken Bow 115kV	On Suspension
GEN-2006-038N005	80	NPPD	Broken Bow 115kV	On-Line
GEN-2006-038N019	80	NPPD	Petersburg North 115kV	On-Line
GEN-2006-040	108	SUNCMKEC	Mingo 115kV	On Suspension
GEN-2006-043	99	AEPW	Sweetwater 230kV	On-Line
GEN-2006-044	370	SPS	Hitchland 345kV	On Schedule for 2012
GEN-2006-044N	40.5	OPPD	North Petersburg 115kV	On-Line
GEN-2006-045	240	SPS	Tap Potter - Plant X 230kV (South Randle County) 230kV	On Suspension
GEN-2006-046	131	OKGE	Dewey 138kV	On-Line
GEN-2006-047	240	SPS	Tap Bushland - Deaf Smith (Buffalo) 230kV	On Suspension
GEN-2007-011	135	SUNCMKEC	Syracuse 115kV	On Suspension
GEN-2007-011N08	81	NPPD	Bloomfield 115kV	On-Line
GEN-2007-015	135	WERE	Tap Kelly(WERE) - S1399(OPPD) 161kV	On Schedule 2014
GEN-2007-021	201	OKGE	Tatonga 345kV	On Schedule for 2014
GEN-2007-025	300	WERE	Viola 345kV	On Schedule for 2012
GEN-2007-032	150	WFEC	Tap Clinton Junction - Clinton 138kV	On Schedule for 2013
GEN-2007-038	200	SUNCMKEC	Spearville 345kV	On Schedule for 2015
GEN-2007-040	200	SUNCMKEC	Buckner 345kV	On Schedule for 2012
GEN-2007-043	200	OKGE	Minco 345kV	On-Line
GEN-2007-044	300	OKGE	Tatonga 345kV	On Schedule for 2014
GEN-2007-046	199.5	SPS	Hitchland 115kV	On Schedule for 2014
GEN-2007-048	400	SPS	Tap Amarillo S - Swisher 230kV	On Schedule for 2014
GEN-2007-050	170	OKGE	Woodward EHV 138kV	On-Line at 150MW
GEN-2007-052	150	WFEC	Anadarko 138kV	On-Line
GEN-2007-057	34.5	SPS	Moore County East 115kV	On Schedule for 2014
GEN-2007-062	765	OKGE	Woodward EHV 345kV	On Schedule for 2014
GEN-2008-003	101	OKGE	Woodward EHV 138kV	On-Line
GEN-2008-008	60	SPS	Graham 69kV	On Suspension
GEN-2008-009	60	SPS	San Juan Tap 230kV	On Schedule for 2014
GEN-2008-013	300	OKGE	Tap Wichita - Woodring (Hunter) 345kV	On-Line
GEN-2008-017	300	SUNCMKEC	Setab 345kV	On Schedule for 2014
GEN-2008-018	405	SPS	Finney 345kV	On Schedule for 2012
GEN-2008-019	300	OKGE	Tatonga 345kV	On Schedule for 2015
GEN-2008-021	42.0	WERE	Wolf Creek 345kV	On-Line
GEN-2008-022	300	SPS	Tap Eddy Co - Tolk (Chaves County) 345kV	On Schedule for 2015
GEN-2008-023	150	AEPW	Hobart Junction 138kV	On Schedule for 2012
GEN-2008-025	101	SUNCMKEC	Ruleton 115kV	On Schedule for 2015
GEN-2008-029	250	OKGE	Woodward EHV 138kV	On Schedule for 2014
GEN-2008-037	101	WFEC	Tap Washita - Blue Canyon Wind 138kV	On-Line
GEN-2008-044	197.8	OKGE	Tatonga 345kV	On-Line
GEN-2008-046	200	OKGE	Sunnyside 345kV	On Suspension
GEN-2008-047	300	SPS	Tap Hitchland - Woodward Ckt 1 (Beaver County) 345kV	IA Pending
GEN-2008-051	322	SPS	Potter County 345kV	On Schedule for 2012
GEN-2008-071	76.8	OKGE	Newkirk 138kV	On Suspension
GEN-2008-079	98.9	SUNCMKEC	Tap Cudahy - Ft Dodge 115kV	On-Line
GEN-2008-086N02	200	NPPD	Tap Ft Randle - Columbus (Madison County) 230kV	On Schedule for 2014
GEN-2008-088	50.6	SPS	Vega 69kV	IA Pending

Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2008-092	201	MIDW	Knoll 230kV	IA Pending
GEN-2008-098	100.8	WERE	Tap Lacygne - Wolf Creek (Anderson County) 345kV	IA Pending
GEN-2008-1190	60	OPPD	S1399 161kV	On-Line
GEN-2008-123N	89.7	NPPD	Tap Guide Rock - Pauline 115kV	On Suspension
GEN-2008-124	200	SUNCMKEC	Spearville 345kV	On Schedule for 2014
GEN-2008-124T	42	SPS	TC-Keyes Texas County 69kV	IA Pending
GEN-2008-129	80	MIPU	Pleasant Hill 161kV	On-Line
GEN-2009-008	199.5	MIDW	South Hays 230kV	On Suspension
GEN-2009-016	100.8	AEPW	Falcon Road 138kV	On Suspension
GEN-2009-020	48.6	MIDW	Tap Nekoma - Bazine 69kV	On Suspension
GEN-2009-025	60	OKGE	Tap Deer Creek - Sinclair Blackwell 69kV	On Schedule for 2012
GEN-2009-040	73.8	WERE	Marshall 115kV	On Suspension
GEN-2009-067S	20	SPS	Seven Rivers 69kV	On Suspension
GEN-2009-073T	48	SPS	TC-Eva Texas County 69kV	IA Pending
GEN-2010-003	100.8	WERE	Tap Lacygne - Wolf Creek (Anderson County) 345kV	IA Pending
GEN-2010-005	300	WERE	Viola 345kV	On Schedule for 2012
GEN-2010-006	205	SPS	Jones 230kV	On-Line
GEN-2010-009	165.6	SUNCMKEC	Buckner 345kV	On-Line
GEN-2010-011	30	OKGE	Tatonga 345kV	On Line
GEN-2010-014	358.8	SPS	Hitchland 345kV	On Schedule for 2016
GEN-2010-015	200.1	SUNCMKEC	Spearville 345kV	On Schedule for 2015
Gray County Wind (Montezuma)	110	SUNCMKEC	Gray County Tap 115kV	On-Line
Llano Estacado (White Deer)	80	SPS	Llano Wind 115kV	On-Line
NPPD Distributed (Broken Bow)	8.3	NPPD	Broken Bow 115kV	On-Line
NPPD Distributed (Burwell)	3	NPPD	Ord 115kV	On-Line
NPPD Distributed (Columbus Hydro)	45	NPPD	Columbus 115kV	On-Line
NPPD Distributed (North Platte - Lexington)	54	NPPD	Multiple: Jeffrey 115kV, John_1 115kV, John_2 115kV	On-Line
NPPD Distributed (Ord)	10.8	NPPD	Ord 115kV	On-Line
NPPD Distributed (Stuart)	2.1	NPPD	Ainsworth 115kV	On-Line
SPS Distributed (Dumas 19th St)	20	SPS	Dumas 19th Street 115kV	On-Line
SPS Distributed (Etter)	20	SPS	Etter 115kV	On-Line
SPS Distributed (Hopi)	10	SPS	Hopi 115kV	On-Line
SPS Distributed (Jal)	10	SPS	S Jal 115kV	On-Line
SPS Distributed (Lea Road)	10	SPS	Lea Road 115kV	On-Line
SPS Distributed (Monument)	10	SPS	Monument 115kV	On-Line
SPS Distributed (Moore E)	25	SPS	Moore East 115kV	On-Line
SPS Distributed (Ocotillo)	10	SPS	Ocotillo 115kV	On-Line
SPS Distributed (Sherman)	20	SPS	Sherman 115kV	On-Line
SPS Distributed (Spearman)	10	SPS	Spearman 69kV	On-Line
SPS Distributed (TC-Texas County)	20	SPS	Texas County 115kV	On-Line
TOTAL 18,266.2				

C: Study Groupings

See next page

C. Study Groups

GROUP 1: WOODWARD AREA			
Request	Capacity	Area	Proposed Point of Interconnection
GEN-2001-014	96.0	WFEC	Ft Supply 138kV
GEN-2001-037	102.0	OKGE	FPL Moreland Tap 138kV
GEN-2005-005	18.0	OKGE	FPL Moreland Tap 138kV
GEN-2005-008	120.0	OKGE	Woodward 138kV
GEN-2006-024S	19.8	WFEC	Buffalo Bear Tap 69kV
GEN-2006-046	131.0	OKGE	Dewey 138kV
GEN-2007-021	201.0	OKGE	Tatonga 345kV
GEN-2007-043	200.0	OKGE	Minco 345kV
GEN-2007-044	300.0	OKGE	Tatonga 345kV
GEN-2007-050	170.0	OKGE	Woodward EHV 138kV
GEN-2007-062	765.0	OKGE	Woodward EHV 345kV
GEN-2008-003	101.0	OKGE	Woodward EHV 138kV
GEN-2008-019	300.0	OKGE	Tatonga 345kV
GEN-2008-029	250.0	OKGE	Woodward EHV 138kV
GEN-2008-044	197.8	OKGE	Tatonga 345kV
GEN-2010-011	30.0	OKGE	Tatonga 345kV
PRIOR QUEUED SUBTOTAL	3,001.6		
GEN-2010-040	300.0	OKGE	Cimarron 345kV
CURRENT CLUSTER SUBTOTAL	300.0		
AREA TOTAL	3,301.6		

GROUP 2: HITCHLAND AREA			
Request	Capacity	Area	Proposed Point of Interconnection
GEN-2002-008	240.0	SPS	Hitchland 345kV
GEN-2002-009	80.0	SPS	Hansford 115kV
GEN-2003-020	160.0	SPS	Martin 115kV
GEN-2006-020S	18.9	SPS	DWS Frisco 115kV
GEN-2006-044	370.0	SPS	Hitchland 345kV
GEN-2007-046	199.5	SPS	Hitchland 115kV
GEN-2007-057	34.5	SPS	Moore County East 115kV
GEN-2008-047	300.0	SPS	Tap Hitchland - Woodward Ckt 1 (Beaver County) 345kV
GEN-2008-124T	42.0	SPS	TC-Keyes Texas County 69kV
GEN-2009-073T	48.0	SPS	TC-Eva Texas County 69kV
GEN-2010-014	358.8	SPS	Hitchland 345kV
SPS Distributed (Dumas 19th St)	20.0	SPS	Dumas 19th Street 115kV
SPS Distributed (Etter)	20.0	SPS	Etter 115kV
SPS Distributed (Moore E)	25.0	SPS	Moore East 115kV
SPS Distributed (Sherman)	20.0	SPS	Sherman 115kV
SPS Distributed (Spearman)	10.0	SPS	Spearman 69kV
SPS Distributed (TC-Texas County)	20.0	SPS	Texas County 115kV
PRIOR QUEUED SUBTOTAL	1,966.7		
GEN-2010-001	300.0	SPS	Tap Hitchland - Woodward Ckt 1 (Beaver County) 345kV
CURRENT CLUSTER SUBTOTAL	300.0		
AREA TOTAL	2,266.7		

GROUP 3: SPEARVILLE AREA			
Request	Capacity	Area	Proposed Point of Interconnection
GEN-2001-039A	105.0	SUNCMKEC	Tap Greensburg - Ft Dodge (Shooting Star Tap) 115kV
GEN-2002-025A	150.0	SUNCMKEC	Spearville 230kV
GEN-2004-014	154.5	SUNCMKEC	Spearville 230kV
GEN-2005-012	250.0	SUNCMKEC	Spearville 345kV
GEN-2006-006	205.5	SUNCMKEC	Spearville 345kV
GEN-2006-021	101.0	SUNCMKEC	Flat Ridge Tap 138kV
GEN-2006-022	150.0	SUNCMKEC	Ninnescah 115kV
GEN-2007-038	200.0	SUNCMKEC	Spearville 345kV
GEN-2007-040	200.0	SUNCMKEC	Buckner 345kV
GEN-2008-018	405.0	SPS	Finney 345kV
GEN-2008-079	98.9	SUNCMKEC	Tap Cudahy - Ft Dodge 115kV
GEN-2008-124	200.0	SUNCMKEC	Spearville 345kV
GEN-2010-009	165.6	SUNCMKEC	Buckner 345kV
GEN-2010-015	200.1	SUNCMKEC	Spearville 345kV
Gray County Wind (Montezuma)	110.0	SUNCMKEC	Gray County Tap 115kV
PRIOR QUEUED SUBTOTAL	2,695.6		
GEN-2010-045	197.8	SUNCMKEC	Buckner 345kV
CURRENT CLUSTER SUBTOTAL	197.8		
AREA TOTAL	2,893.4		

GROUP 4: NW KANSAS AREA			
Request	Capacity	Area	Proposed Point of Interconnection
GEN-2001-039M	99.0	SUNCMKEC	Central Plains Tap 115kV
GEN-2003-006A	200.0	SUNCMKEC	Elm Creek 230kV
GEN-2003-019	250.0	MIDW	Smoky Hills Tap 230kV
GEN-2006-031	75.0	MIDW	Knoll 115kV
GEN-2006-032	200.0	MIDW	South Hays 230kV
GEN-2006-040	108.0	SUNCMKEC	Mingo 115kV
GEN-2007-011	135.0	SUNCMKEC	Syracuse 115kV
GEN-2008-017	300.0	SUNCMKEC	Setab 345kV
GEN-2008-025	101.0	SUNCMKEC	Ruleton 115kV
GEN-2008-092	201.0	MIDW	Knoll 230kV
GEN-2009-008	199.5	MIDW	South Hays 230kV
GEN-2009-020	48.6	MIDW	Tap Nekoma - Bazine 69kV
PRIOR QUEUED SUBTOTAL	1,917.1		
GEN-2010-048	70.0	MIDW	Tap Beach Station - Redline 115kV
CURRENT CLUSTER SUBTOTAL	70.0		
AREA TOTAL	1,987.1		

GROUP 5: AMARILLO AREA

Request	Capacity	Area	Proposed Point of Interconnection
GEN-2002-022	240.0	SPS	Bushland 230kV
GEN-2006-045	240.0	SPS	Tap Potter - Plant X 230kV (South Randle County) 230kV
GEN-2006-047	240.0	SPS	Tap Bushland - Deaf Smith (Buffalo) 230kV
GEN-2007-048	400.0	SPS	Tap Amarillo S - Swisher 230kV
GEN-2008-051	322.0	SPS	Potter County 345kV
GEN-2008-088	50.6	SPS	Vega 69kV
Llano Estacado (White Deer)	80.0	SPS	Llano Wind 115kV
PRIOR QUEUED SUBTOTAL	1,572.6		
AREA TOTAL	1,572.6		

GROUP 6: S-TX PANHANDLE/NW AREA

Request	Capacity	Area	Proposed Point of Interconnection
ASGI-2010-010	42.2	SPS	Lovington 115kV
GEN-2001-033	180.0	SPS	San Juan Tap 230kV
GEN-2001-036	80.0	SPS	Norton 115kV
GEN-2006-018	170.0	SPS	TUCO Interchange 230kV
GEN-2006-026	604.0	SPS	Hobbs 230kV & Hobbs 115kV
GEN-2008-008	60.0	SPS	Graham 69kV
GEN-2008-009	60.0	SPS	San Juan Tap 230kV
GEN-2008-022	300.0	SPS	Tap Eddy Co - Tolk (Chaves County) 345kV
GEN-2009-067S	20.0	SPS	Seven Rivers 69kV
GEN-2010-006	205.0	SPS	Jones 230kV
SPS Distributed (Hopi)	10.0	SPS	Hopi 115kV
SPS Distributed (Jal)	10.0	SPS	S Jal 115kV
SPS Distributed (Lea Road)	10.0	SPS	Lea Road 115kV
SPS Distributed (Monument)	10.0	SPS	Monument 115kV
SPS Distributed (Ocotillo)	10.0	SPS	Ocotillo 115kV
PRIOR QUEUED SUBTOTAL	1,771.2		
ASGI-2010-020	30.0	SPS	Tap LE-Tatum - LE-Crossroads 69kV
ASGI-2010-021	15.0	SPS	Tap LE-Saunders Tap - LE-Anderson 69kV
ASGI-2011-001	28.8	SPS	Lovington 115kV
GEN-2010-046	56.0	SPS	TUCO Interchange 230kV
CURRENT CLUSTER SUBTOTAL	129.8		
AREA TOTAL	1,901.0		

GROUP 7: SW OKLAHOMA AREA			
Request	Capacity	Area	Proposed Point of Interconnection
GEN-2001-026	74.0	WFEC	Washita 138kV
GEN-2002-005	120.0	WFEC	Red Hills Tap 138kV
GEN-2003-004 GEN-2004-023 GEN-2005-003	151.2	WFEC	Washita 138kV
GEN-2003-005	100.0	WFEC	Anadarko - Paradise (Blue Canyon) 138kV
GEN-2003-022	120.0	AEPW	Washita 138kV
GEN-2004-020	27.0	AEPW	Washita 34.5kV
GEN-2006-002	101.0	AEPW	Sweetwater 230kV
GEN-2006-035	225.0	AEPW	Sweetwater 230kV
GEN-2006-043	99.0	AEPW	Sweetwater 230kV
GEN-2007-032	150.0	WFEC	Tap Clinton Junction - Clinton 138kV
GEN-2007-052	150.0	WFEC	Anadarko 138kV
GEN-2008-023	150.0	AEPW	Hobart Junction 138kV
GEN-2008-037	101.0	WFEC	Tap Washita - Blue Canyon Wind 138kV
GEN-2009-016	100.8	AEPW	Falcon Road 138kV
PRIOR QUEUED SUBTOTAL	1,669.0		
AREA TOTAL	1,669.0		

GROUP 8: N-OK/S-KS AREA			
Request	Capacity	Area	Proposed Point of Interconnection
ASGI-2010-006	150.0	AECI	Tap Fairfax (AECI) - Shilder (AEPW) 138kV
GEN-2002-004	200.0	WERE	Latham 345kV
GEN-2005-013	201.0	WERE	Tap Latham - Neosho (Caney River) 345kV
GEN-2007-025	300.0	WERE	Viola 345kV
GEN-2008-013	300.0	OKGE	Tap Wichita - Woodring (Hunter) 345kV
GEN-2008-021	42.0	WERE	Wolf Creek 345kV
GEN-2008-071	76.8	OKGE	Newkirk 138kV
GEN-2008-098	100.8	WERE	Tap Lacygne - Wolf Creek (Anderson County) 345kV
GEN-2009-025	60.0	OKGE	Tap Deer Creek - Sinclair Blackwell 69kV
GEN-2010-003	100.8	WERE	Tap Lacygne - Wolf Creek (Anderson County) 345kV
GEN-2010-005	300.0	WERE	Viola 345kV
PRIOR QUEUED SUBTOTAL	1,831.4		
AREA TOTAL	1,831.4		

GROUP 9/10: NEBRASKA AREA			
Request	Capacity	Area	Proposed Point of Interconnection
GEN-2002-023N	0.8	NPPD	Harmony 115kV
GEN-2003-021N	75.0	NPPD	Ainsworth Wind Tap 115kV
GEN-2004-005N	30.0	NPPD	St Francis 115kV
GEN-2004-023N	75.0	NPPD	Columbus Co 115kV
GEN-2006-020N	42.0	NPPD	Bloomfield 115kV
GEN-2006-037N1	75.0	NPPD	Broken Bow 115kV
GEN-2006-038N005	80.0	NPPD	Broken Bow 115kV
GEN-2006-038N019	80.0	NPPD	Petersburg North 115kV
GEN-2006-044N	40.5	OPPD	North Petersburg 115kV
GEN-2007-011N08	81.0	NPPD	Bloomfield 115kV
GEN-2007-015	135.0	WERE	Tap Kelly(WERE) - S1399(OPPD) 161kV
GEN-2008-086N02	200.0	NPPD	Tap Ft Randle - Columbus (Madison County) 230kV
GEN-2008-1190	60.0	OPPD	S1399 161kV
GEN-2008-123N	89.7	NPPD	Tap Guide Rock - Pauline 115kV
GEN-2009-040	73.8	WERE	Marshall 115kV
NPPD Distributed (Broken Bow)	8.3	NPPD	Broken Bow 115kV
NPPD Distributed (Burwell)	3.0	NPPD	Ord 115kV
NPPD Distributed (Columbus Hydro)	45.0	NPPD	Columbus 115kV
NPPD Distributed (North Platte - Lexington)	54.0	NPPD	Multiple: Jeffrey 115kV, John_1 115kV, John_2 115kV
NPPD Distributed (Ord)	10.8	NPPD	Ord 115kV
NPPD Distributed (Stuart)	2.1	NPPD	Ainsworth 115kV
PRIOR QUEUED SUBTOTAL	1,261.0		
GEN-2010-041	10.5	OPPD	S 1399 161kV
GEN-2010-051	200.0	NPPD	Tap Twin Church - Hoskins 230kV
CURRENT CLUSTER SUBTOTAL	210.5		
AREA TOTAL	1,471.5		

GROUP 12: NW AR AREA

Request	Capacity	Area	Proposed Point of Interconnection
AREA TOTAL	0.0		

GROUP 13: NW MISSOURI AREA

Request	Capacity	Area	Proposed Point of Interconnection
GEN-2006-014	300.0	MIPU	Tap Maryville - Midway (Nodway Co) 161kV
GEN-2008-129	80.0	MIPU	Pleasant Hill 161kV
PRIOR QUEUED SUBTOTAL	380.0		
GEN-2010-036	4.6	WERE	6th Street 115kV
CURRENT CLUSTER SUBTOTAL	4.6		
AREA TOTAL	380.0		

GROUP 14: S OKLAHOMA AREA

Request	Capacity	Area	Proposed Point of Interconnection
GEN-2008-046	200.0	OKGE	Sunnyside 345kV
PRIOR QUEUED SUBTOTAL	200.0		
AREA TOTAL	200.0		


CLUSTER TOTAL (CURRENT STUDY)	1,212.7	MW
PQ TOTAL (PRIOR QUEUED)	18,266.2	MW
CLUSTER TOTAL (INCLUDING PRIOR QUEUED)	19,478.9	MW

D: Proposed Point of Interconnection One line Diagrams

Refer to most recent Facility study for each request for an updated one-line.


ASGI-2010-020

**New (SPS)
69 kV SWITCHING STATION**




ASGI-2010-021

**New (SPS)
69 kV SWITCHING STATION**



ASGI-2011-001



E: Cost Allocation per Interconnection Request (Including Prior Queued Upgrades)

Important Note:

****WITHDRAWAL OF HIGHER QUEUED PROJECTS WILL CAUSE A RESTUDY
AND MAY RESULT IN HIGHER INTERCONNECTION COSTS****

This section shows each Generation Interconnection Request Customer, their current study impacted Network Upgrades, and the previously allocated upgrades upon which they rely to accommodate their interconnection to the transmission system.

The costs associated with the current study Network Upgrades are allocated to the Customers shown in this report.

In addition should a higher queued request, defined as one this study includes as a prior queued request, withdraw, the Network Upgrades assigned to the withdrawn request may be reallocated to the remaining requests that have an impact on the Network Upgrade under a restudy. Also, should a Interconnection Request choose to go into service prior to the operation date of any necessary Network Upgrades, the costs associated with those upgrades may be reallocated to the impacted Interconnection Request. The actual costs allocated to each Generation Interconnection Request Customer will be determined at the time of a restudy.

The required interconnection costs listed do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT. In addition, costs associated with a short circuit analysis will be allocated should the Interconnection Request Customer choose to execute a Facility Study Agreement.

Appendix E. Cost Allocation Per Request

(Including Previously Allocated Network Upgrades*)

Interconnection Request and Upgrades	Upgrade Type	Allocated Cost	Upgrade Cost
ASGI-2010-020			
ASGI-2010-020 Interconnection Costs See Online Diagram.	Current Study	\$0.00	\$0.00
Beaver County - Woodward 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Border - Tuco Interchange 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Border - Woodward 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Hitchland - Beaver County 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Hitchland - Woodward 345kV CKT 2 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Nichols - Harrington West 230kV CKT 1 Per GEN-2008-051 LOIS: Rebuild approximately 1 mile of 230kV @ 1825 amps	Previously Allocated		\$869,251.00
Thistle - Flat Ridge 138kV CKT 1 Priority Project: Thistle - Flat Ridge 138kV CKT 1 (Total Project E&C Cost Shown.)	Previously Allocated		\$4,004,423.00
Thistle - Wichita 345KV Dbl CKT Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$166,598,000.00
Thistle - Woodward 345KV Dbl CKT Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$212,090,000.00
Thistle 345/138KV Transformer CKT 1 Priority Project: Thistle 345/138kV Transformer CKT 1 (Total Project E&C Cost Shown.)	Previously Allocated		\$8,627,726.00
TUCO Interchange 345/230/13.2KV Autotransformer CKT 2 Balanced Portfolio: TUCO 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)	Previously Allocated		\$14,900,907.00
Woodward XFMR 345/138/13.8kV CKT 2 Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown).	Previously Allocated		\$15,000,000.00
	Current Study Total	\$0.00	

ASGI-2010-021

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Interconnection Request and Upgrades	Upgrade Type	Allocated Cost	Upgrade Cost
ASGI-2010-021 Interconnection Costs See Online Diagram.	Current Study	\$0.00	\$0.00
Beaver County - Woodward 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Border - Tuco Interchange 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Border - Woodward 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Hitchland - Beaver County 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Hitchland - Woodward 345kV CKT 2 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Nichols - Harrington West 230kV CKT 1 Per GEN-2008-051 LOIS: Rebuild approximately 1 mile of 230kV @ 1825 amps	Previously Allocated		\$869,251.00
Thistle - Flat Ridge 138kV CKT 1 Priority Project: Thistle - Flat Ridge 138kV CKT 1 (Total Project E&C Cost Shown.)	Previously Allocated		\$4,004,423.00
Thistle - Wichita 345KV Dbl CKT Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$166,598,000.00
Thistle - Woodward 345KV Dbl CKT Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$212,090,000.00
Thistle 345/138KV Transformer CKT 1 Priority Project: Thistle 345/138kV Transformer CKT 1 (Total Project E&C Cost Shown.)	Previously Allocated		\$8,627,726.00
TUCO Interchange 345/230/13.2KV Autotransformer CKT 2 Balanced Portfolio: TUCO 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)	Previously Allocated		\$14,900,907.00
Woodward XFMR 345/138/13.8kV CKT 2 Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown).	Previously Allocated		\$15,000,000.00
	Current Study Total	\$0.00	

ASGI-2011-001

ASGI-2011-001 Interconnection Costs See Online Diagram.	Current Study	\$0.00	\$0.00
Beaver County - Woodward 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Interconnection Request and Upgrades	Upgrade Type	Allocated Cost	Upgrade Cost
Border - Tuco Interchange 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Border - Woodward 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Hitchland - Beaver County 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Hitchland - Woodward 345kV CKT 2 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Nichols - Harrington West 230kV CKT 1 Per GEN-2008-051 LOIS: Rebuild approximately 1 mile of 230kV @ 1825 amps	Previously Allocated		\$869,251.00
Thistle - Flat Ridge 138kV CKT 1 Priority Project: Thistle - Flat Ridge 138kV CKT 1 (Total Project E&C Cost Shown.)	Previously Allocated		\$4,004,423.00
Thistle - Wichita 345KV Dbl CKT Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$166,598,000.00
Thistle - Woodward 345KV Dbl CKT Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$212,090,000.00
Thistle 345/138KV Transformer CKT 1 Priority Project: Thistle 345/138kV Transformer CKT 1 (Total Project E&C Cost Shown.)	Previously Allocated		\$8,627,726.00
TUCO Interchange 345/230/13.2KV Autotransformer CKT 2 Balanced Portfolio: TUCO 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)	Previously Allocated		\$14,900,907.00
Woodward XFMR 345/138/13.8kV CKT 2 Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown).	Previously Allocated		\$15,000,000.00
	Current Study Total	\$0.00	

GEN-2010-001

GEN-2010-001 Interconnection Costs See Online Diagram.	Current Study	\$3,566,677.00	\$3,566,677.00
Beaver County - Woodward 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Border - Tuco Interchange 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Border - Woodward 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Interconnection Request and Upgrades	Upgrade Type	Allocated Cost	Upgrade Cost
Hitchland - Woodward 345kV CKT 2 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Thistle - Flat Ridge 138kV CKT 1 Priority Project: Thistle - Flat Ridge 138kV CKT 1 (Total Project E&C Cost Shown.)	Previously Allocated		\$4,004,423.00
Thistle - Wichita 345KV Dbl CKT Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$166,598,000.00
Thistle - Woodward 345KV Dbl CKT Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$212,090,000.00
Thistle 345/138KV Transformer CKT 1 Priority Project: Thistle 345/138kV Transformer CKT 1 (Total Project E&C Cost Shown.)	Previously Allocated		\$8,627,726.00
Woodward XFMR 345/138/13.8kV CKT 2 Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown).	Previously Allocated		\$15,000,000.00
	Current Study Total	\$3,566,677.00	

GEN-2010-036

GEN-2010-036 Interconnection Costs See Online Diagram.	Current Study	\$204,600.00	\$204,600.00
Iatan - Nashua 345KV CKT 1 Balanced Portfolio: Iatan - Nashua 345kV CKT 1 (Total Project E&C Cost Shown).	Previously Allocated		\$60,800,000.00
	Current Study Total	\$204,600.00	

GEN-2010-040

GEN-2010-040 Interconnection Costs See Online Diagram.	Current Study	\$8,046,756.00	\$8,046,756.00
Border - Tuco Interchange 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Border - Woodward 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Thistle - Woodward 345KV Dbl CKT Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$212,090,000.00
TUCO Interchange 345/230/13.2KV Autotransformer CKT 2 Balanced Portfolio: TUCO 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)	Previously Allocated		\$14,900,907.00
Woodward XFMR 345/138/13.8kV CKT 2 Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown).	Previously Allocated		\$15,000,000.00

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Interconnection Request and Upgrades	Upgrade Type	Allocated Cost	Upgrade Cost
	Current Study Total	\$8,046,756.00	
<hr/>			
GEN-2010-041			
GEN-2010-041 Interconnection Costs See Online Diagram.	Current Study	\$0.00	\$0.00
	Current Study Total	\$0.00	
<hr/>			
GEN-2010-045			
GEN-2010-045 Interconnection Costs See Online Diagram.	Current Study	\$5,000,000.00	\$5,000,000.00
Beaver County - Woodward 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Border - Tuco Interchange 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Border - Woodward 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$249,932,114.00
Clark - Thistle 345KV Dbl CKT Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$300,194,436.00
Hitchland - Beaver County 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Hitchland - Woodward 345kV CKT 2 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Hitchland 345/230kV Autotransformer CKT 2 Priority Project: Hitchland 345/230kV Autotransformer CKT 2 (Total Project E&C Cost Shown).	Previously Allocated		\$8,883,760.00
Post Rock 345/230/13.8kV Autotransformer CKT 2 DISIS-2010-001 Restudy	Previously Allocated		\$13,749,527.00
Spearville -Clark 345KV Dbl CKT Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$300,194,436.00
Thistle - Wichita 345KV Dbl CKT Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$166,598,000.00
Thistle - Woodward 345KV Dbl CKT Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$212,090,000.00
TUCO Interchange 345/230/13.2KV Autotransformer CKT 2 Balanced Portfolio: TUCO 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)	Previously Allocated		\$14,900,907.00

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Interconnection Request and Upgrades	Upgrade Type	Allocated Cost	Upgrade Cost
Woodward XFMR 345/138/13.8kV CKT 2 Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown).	Previously Allocated		\$15,000,000.00
	Current Study Total	\$5,000,000.00	
GEN-2010-046			
GEN-2010-046 Interconnection Costs See Oonline Diagram.	Current Study	\$0.00	\$0.00
Beaver County - Woodward 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Hitchland - Woodward 345kV CKT 2 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Nichols - Harrington Mid 230kV CKT 1 Per GEN-2008-051 LOIS: Rebuild approximately 1 mile of 230kV @ 1825 amps	Previously Allocated		\$869,251.00
Nichols - Harrington West 230kV CKT 1 Per GEN-2008-051 LOIS: Rebuild approximately 1 mile of 230kV @ 1825 amps	Previously Allocated		\$869,251.00
Thistle - Flat Ridge 138kV CKT 1 Priority Project: Thistle - Flat Ridge 138kV CKT 1 (Total Project E&C Cost Shown.)	Previously Allocated		\$4,004,423.00
Thistle - Wichita 345KV Dbl CKT Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$166,598,000.00
Thistle - Woodward 345KV Dbl CKT Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$212,090,000.00
Thistle 345/138KV Transformer CKT 1 Priority Project: Thistle 345/138kV Transformer CKT 1 (Total Project E&C Cost Shown.)	Previously Allocated		\$8,627,726.00
TUCO Interchange 345/230/13.2KV Autotransformer CKT 2 Balanced Portfolio: TUCO 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)	Previously Allocated		\$14,900,907.00
Woodward XFMR 345/138/13.8kV CKT 2 Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown).	Previously Allocated		\$15,000,000.00
	Current Study Total	\$0.00	

GEN-2010-048

GEN-2010-048 Interconnection Costs See Oonline Diagram.	Current Study	\$2,144,524.00	\$2,144,524.00
Beaver County - Woodward 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Interconnection Request and Upgrades	Upgrade Type	Allocated Cost	Upgrade Cost
Clark - Thistle 345KV Dbl CKT Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$300,194,436.00
Hitchland - Beaver County 345kV CKT 1 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Hitchland - Woodward 345kV CKT 2 Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$226,040,727.00
Hitchland 345/230kV Autotransformer CKT 2 Priority Project: Hitchland 345/230kV Autotransformer CKT 2 (Total Project E&C Cost Shown).	Previously Allocated		\$8,883,760.00
Post Rock 345/230/13.8kV Autotransformer CKT 2 DISIS-2010-001 Restudy	Previously Allocated		\$13,749,527.00
Spearville -Clark 345KV Dbl CKT Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$300,194,436.00
Thistle - Wichita 345KV Dbl CKT Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$166,598,000.00
	Current Study Total	\$2,144,524.00	
GEN-2010-051			
GEN-2010-051 Interconnection Costs See Online Diagram.	Current Study	\$6,700,000.00	\$6,700,000.00
Twin Church - Dixon County 230kV Increase conductor clearances to accommodate 320MVA facility rating	Current Study	\$100,000.00	\$100,000.00
	Current Study Total	\$6,800,000.00	
TOTAL CURRENT STUDY COSTS:		\$25,762,557.00	

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

F: Cost Allocation per Proposed Study Network Upgrade

Important Note:

****WITHDRAWAL OF HIGHER QUEUED PROJECTS WILL CAUSE A RESTUDY
AND MAY RESULT IN HIGHER INTERCONNECTION COSTS****

This section shows each Direct Assigned Facility and Network Upgrade and the Generation Interconnection Request Customer(s) which have an impact in this study assuming all higher queued projects remain in the queue and achieve commercial operation.

The required interconnection costs listed do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT. In addition, costs associated with a short circuit analysis will be allocated should the Interconnection Request Customer choose to execute a Facility Study Agreement.

There may be additional costs allocated to each Customer. See Appendix E for more details.

Appendix F. Cost Allocation by Upgrade

ASGI-2010-020 Interconnection Costs		\$0.00
See Online Diagram.		
	ASGI-2010-020	\$0.00
	Total Allocated Costs	\$0.00
ASGI-2010-021 Interconnection Costs		\$0.00
See Online Diagram.		
	ASGI-2010-021	\$0.00
	Total Allocated Costs	\$0.00
ASGI-2011-001 Interconnection Costs		\$0.00
See Online Diagram.		
	ASGI-2011-001	\$0.00
	Total Allocated Costs	\$0.00
Twin Church - Dixon County 230kV		\$100,000.00
Increase conductor clearances to accommodate 320MVA facility rating		
	GEN-2010-051	\$100,000.00
	Total Allocated Costs	\$100,000.00
GEN-2010-001 Interconnection Costs		\$3,566,677.00
See Online Diagram.		
	GEN-2010-001	\$3,566,677.00
	Total Allocated Costs	\$3,566,677.00
GEN-2010-036 Interconnection Costs		\$204,600.00
See Online Diagram.		
	GEN-2010-036	\$204,600.00
	Total Allocated Costs	\$204,600.00
GEN-2010-040 Interconnection Costs		\$8,046,756.00
See Online Diagram.		
	GEN-2010-040	\$8,046,756.00
	Total Allocated Costs	\$8,046,756.00
GEN-2010-041 Interconnection Costs		\$0.00
See Online Diagram.		
	GEN-2010-041	\$0.00

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

		Total Allocated Costs	\$0.00
GEN-2010-045 Interconnection Costs			\$5,000,000.00
See Oonline Diagram.			
	GEN-2010-045		\$5,000,000.00
		Total Allocated Costs	\$5,000,000.00
GEN-2010-046 Interconnection Costs			\$0.00
See Oonline Diagram.			
	GEN-2010-046		\$0.00
		Total Allocated Costs	\$0.00
GEN-2010-048 Interconnection Costs			\$2,144,524.00
See Oonline Diagram.			
	GEN-2010-048		\$2,144,524.00
		Total Allocated Costs	\$2,144,524.00
GEN-2010-051 Interconnection Costs			\$6,700,000.00
See Oonline Diagram.			
	GEN-2010-051		\$6,700,000.00
		Total Allocated Costs	\$6,700,000.00

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

G: Power Flow Analysis (Constraints For Mitigation)

See next page.

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADII	CONTNAME
	FDNS	00G10_051		0 23SP	G10_051	'FROM->TO'	'G10-51T 230.00 - TWIN CHURCH 230KV C	192		1 104.5287	'G10-51T 230.00 - HOSKINS 230KV CKT 1'
	FDNS	00G10_051		0 23SP	G10_051	'FROM->TO'	'G10-51T 230.00 - HOSKINS 230KV CKT 1'	192		1 104.2096	'G10-51T 230.00 - TWIN CHURCH 230KV CKT 1'

H: Power Flow Analysis (Other Constraints Not Requiring Mitigation)

See Next page

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	00G10_001		0	13SP	G10_001	'TO->FROM' CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.04319	103.5191	'DBL-WICH-THI'
	FDNS	00G10_001		0	13SP	G10_001	'FROM->TO' HARPER - MILAN TAP 138KV CKT 1'	95.6	0.04319	128.0326	'DBL-WICH-THI'
	FDNS	00G10_001		0	13WP	G10_001	'TO->FROM' CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.04425	103.7998	'DBL-WICH-THI'
	FDNS	00G10_001		0	13WP	G10_001	'FROM->TO' HARPER - MILAN TAP 138KV CKT 1'	95.6	0.04425	128.045	'DBL-WICH-THI'
	FDNS	00G10_001		0	18WP	G10_001	'TO->FROM' CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.04336	101.0793	'DBL-WICH-THI'
	FDNS	00G10_001		0	18WP	G10_001	'FROM->TO' HARPER - MILAN TAP 138KV CKT 1'	95.6	0.04336	125.2745	'DBL-WICH-THI'
ISLAND-GE	FDNS	00G10_036		0	13SP	G10_036	'FROM->TO' LAWRENCE HILL - SWISSVALE 230KV CKT 1'	363	0.29689	108.2	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	00G10_036		0	13WP	G10_036	'FROM->TO' LAWRENCE HILL - SWISSVALE 230KV CKT 1'	363	0.297	121.7	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	00G10_036		0	13WP	G10_036	'FROM->TO' LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1'	308	0.2227	103.2	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
	FDNS	00G10_041		0	13SP	G10_041	'FROM->TO' HUMBOLDT (S975 T4) 161/69/13.8KV TRANSFORMER CKT 1'	67.2	0.04671	95.2	'SUB 1263 BROCK (S1263 T1) 161/69/13.8KV TRANSFORMER CKT 1'
	FDNS	00G10_041		0	13SP	G10_041	'FROM->TO' HUMBOLDT (S975 T4) 161/69/13.8KV TRANSFORMER CKT 1'	67.2	0.03714	96.5	'S1263T1 AUTO'
	FDNS	00G10_041		0	18SP	G10_041	'FROM->TO' HUMBOLDT (S975 T4) 161/69/13.8KV TRANSFORMER CKT 1'	67.2	0.04667	95.9	'SUB 1263 BROCK (S1263 T1) 161/69/13.8KV TRANSFORMER CKT 1'
	FDNS	00G10_041		0	18SP	G10_041	'FROM->TO' HUMBOLDT (S975 T4) 161/69/13.8KV TRANSFORMER CKT 1'	67.2	0.03715	97.8	'S1263T1 AUTO'
	FDNS	00G10_041		0	18WP	G10_041	'FROM->TO' HUMBOLDT (S975 T4) 161/69/13.8KV TRANSFORMER CKT 1'	67.2	0.04668	96.5	'SUB 1263 BROCK (S1263 T1) 161/69/13.8KV TRANSFORMER CKT 1'
	FDNS	00G10_041		0	18WP	G10_041	'FROM->TO' HUMBOLDT (S975 T4) 161/69/13.8KV TRANSFORMER CKT 1'	67.2	0.03712	97.8	'S1263T1 AUTO'
	FDNS	00G10_041		0	18WP	G10_041	'FROM->TO' HUMBOLDT (S975 T4) 161/69/13.8KV TRANSFORMER CKT 1'	67.2	0.03712	95.7	'S1263T1 AUTO'
	FDNS	00G10_045		0	13SP	G10_045	'TO->FROM' CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.04771	102.4238	'DBL-WICH-THI'
	FDNS	00G10_045		0	13SP	G10_045	'FROM->TO' HARPER - MILAN TAP 138KV CKT 1'	95.6	0.04771	126.7228	'DBL-WICH-THI'
	FDNS	00G10_045		0	13WP	G10_045	'TO->FROM' CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.04887	102.8361	'DBL-WICH-THI'
	FDNS	00G10_045		0	13WP	G10_045	'FROM->TO' HARPER - MILAN TAP 138KV CKT 1'	95.6	0.04887	126.8276	'DBL-WICH-THI'
NCONV	FNSL-Iterat	00G10_045		0	13WP	G10_045	Non-Converged Contingency	0	0.03943	9999	'TRF-STEGALL'
	FDNS	00G10_045		0	18WP	G10_045	'TO->FROM' CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.04788	99.9	'DBL-WICH-THI'
	FDNS	00G10_045		0	18WP	G10_045	'FROM->TO' HARPER - MILAN TAP 138KV CKT 1'	95.6	0.04788	123.8342	'DBL-WICH-THI'
	FDNS	00G10_046		0	18SP	G10_046	'FROM->TO' Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2'	351	0.0444	96.2	'JONES STATION - LUBBOCK SOUTH INTERCHANGE 230KV CKT 1'
NCONV	FNSL-Iterat	00G10_048		0	13WP	G10_048	Non-Converged Contingency	0	0.04563	9999	'TRF-STEGALL'
NCONV	FNSL-Iterat	00G10_048		0	13WP	G10_048	Non-Converged Contingency	0	0.03042	9999	'NEB01WAPAB3'
NCONV	FNSL-Iterat	00G10_051		0	13SP	G10_051	Non-Converged Contingency	0	0.04123	9999	'ATC_B2_W-8_G'
	FDNS	00G10_051		0	13WP	G10_051	'FROM->TO' G10-51T 230.00 - TWIN CHURCH 230KV CKT 1'	225	1	95	'G10-51T 230.00 - HOSKINS 230KV CKT 1'
	FDNS	00G10_051		0	18SP	G10_051	'FROM->TO' G10-51T 230.00 - TWIN CHURCH 230KV CKT 1'	225	1	95.6	'G10-51T 230.00 - HOSKINS 230KV CKT 1'
	FDNS	00G10_051		0	18SP	G10_051	'FROM->TO' HOSKINS (HOSKINS T1) 230/115/13.8KV TRANSFORMER CKT 1'	187	0.09948	97.4	'HOSKINS (HOSKN T4) 345/115/13.8KV TRANSFORMER CKT 1'
	FDNS	00G10_051		0	18SP	G10_051	'FROM->TO' HOSKINS (HOSKINS T1) 230/115/13.8KV TRANSFORMER CKT 1'	187	0.09948	95.6	'HOSKINS (HOSKN T4) 345/115/13.8KV TRANSFORMER CKT 1'
NCONV	FNSL-Iterat	00G10_051		0	18WP	G10_051	Non-Converged Contingency	0	0.04114	9999	'ATC_B2_W-8_G'
ISLAND-GE	FDNS	00NR		0	18WP	G10_045	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	189.3	'BUCKNER7 345.00 - G10-45 345.00 345KV CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_045	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	100.6	'FLAT RIDGE WIND - FLATRDG3 138KV CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_045	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	100.1	'MRWYP16 - MRWYP26 230KV CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_045	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	125.7	'ELM CREEK - MRWYP16 230KV CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_045	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	288.9	'HOLCOMB 115/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_045	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	100.6	'FLAT RIDGE WIND (FLATRDG3) 138/34.53963/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_045	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	100.2	'MRWYP26 (MERDWYP2) 230/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_045	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	105.7	'MRWYP16 (MERIDWY1) 230/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_045	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	114.9	'MULLERGREN 115/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_045	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	189.3	'G10-45 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_048	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	189.3	'BUCKNER7 345.00 - G10-45 345.00 345KV CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_048	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	100.6	'FLAT RIDGE WIND - FLATRDG3 138KV CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_048	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	100.1	'MRWYP16 - MRWYP26 230KV CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_048	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	125.7	'ELM CREEK - MRWYP16 230KV CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_048	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	288.9	'HOLCOMB 115/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_048	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	100.6	'FLAT RIDGE WIND (FLATRDG3) 138/34.53963/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	00NR		0	18WP	G10_048	'FROM->TO' JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.25589	100.2	'MRWYP26 (MERDWYP2) 230/34.5/13.8KV TRANSFORMER CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
	FDNS		0	0	18SP	G10_046	'FROM->TC'	Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2'	351	0.0444	95.7	'JONES STATION - LUBBOCK SOUTH INTERCHANGE 230KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TC'	LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.0327	115.3004	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TC'	LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.03267	115.3004	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TC'	LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.03272	115.3004	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TC'	LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.0327	123.8497	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TC'	LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.03267	123.8497	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TC'	LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.03272	123.8497	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TC'	MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.05003	100.2159	'HOBBS INTERCHANGE - MILLEN SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TC'	MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.05706	100.2159	'HOBBS INTERCHANGE - MILLEN SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TC'	MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.04253	100.2159	'HOBBS INTERCHANGE - MILLEN SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'TO->FROM'	OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.05003	100.2192	'HOBBS INTERCHANGE - MILLEN SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'TO->FROM'	OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.05706	100.2192	'HOBBS INTERCHANGE - MILLEN SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'TO->FROM'	OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.04253	100.2192	'HOBBS INTERCHANGE - MILLEN SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TC'	MADDOX STATION - MONUMENT SUB 115KV CKT 1'	141	0.03687	98.4	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TC'	MADDOX STATION - MONUMENT SUB 115KV CKT 1'	141	0.04213	98.4	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TC'	MADDOX STATION - MONUMENT SUB 115KV CKT 1'	141	0.03125	98.4	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TC'	MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'	141	0.03687	95.9	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TC'	MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'	141	0.04213	95.9	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TC'	MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'	141	0.03125	95.9	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TC'	MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.04445	104.2497	'MADDOX STATION - MONUMENT SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TC'	MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.05185	104.2497	'MADDOX STATION - MONUMENT SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TC'	MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.03654	104.2497	'MADDOX STATION - MONUMENT SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'TO->FROM'	OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.04445	104.2531	'MADDOX STATION - MONUMENT SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'TO->FROM'	OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.05185	104.2531	'MADDOX STATION - MONUMENT SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'TO->FROM'	OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.03654	104.2531	'MADDOX STATION - MONUMENT SUB 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TC'	MADDOX STATION - MONUMENT SUB 115KV CKT 1'	141	0.03687	98.4	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TC'	MADDOX STATION - MONUMENT SUB 115KV CKT 1'	141	0.04213	98.4	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TC'	MADDOX STATION - MONUMENT SUB 115KV CKT 1'	141	0.03125	98.4	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TC'	MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'	141	0.03687	95.9	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TO'	'MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'	141	0.04213	95.9	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TO'	'MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'	141	0.03125	95.9	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TO'	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.04445	103.1972	'MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TO'	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.05185	103.1972	'MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TO'	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.03654	103.1972	'MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'TO->FROM'	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.04445	103.2009	'MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'TO->FROM'	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.05185	103.2009	'MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'TO->FROM'	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.03654	103.2009	'MONUMENT SUB - WEST HOBBS SWITCHING STATION 115KV CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.03388	102.9986	'LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.03385	102.9986	'LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.03391	102.9986	'LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.03388	109.1998	'LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.03385	109.1998	'LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRA	252	0.03391	109.1998	'LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS		0	0	18SP	ASGI_2010_020	'FROM->TO'	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.04445	103.4795	'SPP-SWPS-T42'
	FDNS		0	0	18SP	ASGI_2010_021	'FROM->TO'	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.05185	103.4795	'SPP-SWPS-T42'
	FDNS		0	0	18SP	ASGI_2011_001	'FROM->TO'	'MADDOX STATION - SANGER SWITCHING STATION 115KV CKT 1'	141	0.03654	103.4795	'SPP-SWPS-T42'
	FDNS		0	0	18SP	ASGI_2010_020	'TO->FROM'	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.04445	103.4828	'SPP-SWPS-T42'
	FDNS		0	0	18SP	ASGI_2010_021	'TO->FROM'	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.05185	103.4828	'SPP-SWPS-T42'
	FDNS		0	0	18SP	ASGI_2011_001	'TO->FROM'	'OXY PERMIAN SUB - SANGER SWITCHING STATION 115KV CKT 1'	141	0.03654	103.4828	'SPP-SWPS-T42'
ISLAND-GE	FDNS		0	0	13WP	G10_036	'FROM->TO'	'LAWRENCE HILL - SWISSVALE 230KV CKT 1'	363	0.297	120.1	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS		0	0	13WP	G10_036	'FROM->TO'	'LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1'	308	0.2227	104.5	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS		0	0	13WP	G10_036	'FROM->TO'	'LAWRENCE HILL - SWISSVALE 230KV CKT 1'	363	0.297	120.1	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS		0	0	13WP	G10_036	'FROM->TO'	'LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1'	308	0.2227	104.5	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS		0	0	13WP	G10_036	'FROM->TO'	'LAWRENCE HILL - SWISSVALE 230KV CKT 1'	363	0.297	121.6	'JEFFREY ENERGY CENTER 230/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS		0	0	13WP	G10_036	'FROM->TO'	'LAWRENCE HILL (LAWHL29X) 230/115/13.8KV TRANSFORMER CKT 1'	308	0.2227	103.6	'JEFFREY ENERGY CENTER 230/26.0KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	117.6619	'BASE CASE'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	117.6619	'BASE CASE'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03016	98.3	'BASE CASE'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05811	98.3	'BASE CASE'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05766	99.9	'LYDIA - VALLIANT 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03061	100	'DELAWARE - NORTHEAST STATION 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05825	100	'DELAWARE - NORTHEAST STATION 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05655	98.4	'CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05655	98.6	'CLINTON AIR FORCE BASE TAP - HOBART JUNCTION 138KV CKT 1'
INVALID	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03115	114.7887	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
INVALID	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04134	114.7887	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04133	114.7887	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04135	114.7887	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06157	114.7887	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03115	99.2366	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04134	99.2366	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04133	99.2366	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04135	99.2366	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06157	99.2366	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03115	105.4155	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04134	105.4155	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04133	105.4155	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04135	105.4155	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06157	105.4155	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05637	98.5	'CLINTON JUNCTION - ELK CITY 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03164	113.2387	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03729	113.2387	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0373	113.2387	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03728	113.2387	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06236	113.2387	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03164	98.5	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03729	98.5	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0373	98.5	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03728	98.5	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06236	98.5	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03164	102.2812	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03729	102.2812	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0373	102.2812	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03728	102.2812	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06236	102.2812	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05481	98.8	'WAUKOMIS - WAUKOMIS TAP 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05481	98.3	'HENESSEY - WAUKOMIS 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05652	98.3	'KNOBHILL - SALINE 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05652	98.7	'HELENA TAP - SALINE 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05652	99.4	'GOLTYTP2 69.000 - IMO 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05481	97.6	'DOVER SW - HENESSEY 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03419	114.8876	'WOODWARD - WOODWARD 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06589	114.8876	'WOODWARD - WOODWARD 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03419	98	'WOODWARD - WOODWARD 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06589	98	'WOODWARD - WOODWARD 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05218	96.7	'WOODWARD - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03631	119.3636	'DEWEY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03006	119.3636	'DEWEY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03006	119.3636	'DEWEY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03006	119.3636	'DEWEY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06978	119.3636	'DEWEY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03631	100.7458	'DEWEY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03006	100.7458	'DEWEY - IODINE 138KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03006	100.7458	'DEWEY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03006	100.7458	'DEWEY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06978	100.7458	'DEWEY - IODINE 138KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	111.1	'DEWEY - TALOGA WIND 138KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	111.1	'DEWEY - TALOGA WIND 138KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03016	96.7	'DEWEY - TALOGA WIND 138KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05811	96.7	'DEWEY - TALOGA WIND 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03075	116.9014	'DEWEY - TALOGA 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05947	116.9014	'DEWEY - TALOGA 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03075	99.9	'DEWEY - TALOGA 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05947	99.9	'DEWEY - TALOGA 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03003	99.8	'ALVA - KNOBHILL 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05783	99.8	'ALVA - KNOBHILL 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03631	120.3962	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03006	120.3962	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03006	120.3962	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03006	120.3962	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06978	120.3962	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03631	101.3122	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03006	101.3122	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03006	101.3122	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03006	101.3122	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06978	101.3122	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03073	100.2364	'CRESWELL - MIDLTNT4 138.00 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05833	100.2364	'CRESWELL - MIDLTNT4 138.00 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03066	106.1469	'CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05902	106.1469	'CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1'	153	0.03059	96.1	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04445	178.3527	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03168	178.3527	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04042	178.3527	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04042	178.3527	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04042	178.3527	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.08548	178.3527	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'GLASS MOUNTAIN - MOORELAND 138KV CKT 1'	124	0.03059	121.8819	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'EL RENO - ROMAN NOSE 138KV CKT 1'	153	0.03693	112.5825	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'ROMAN NOSE - SOUTHWEST 138KV CKT 1'	153	0.03693	117.3526	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04445	135.2322	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_048	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03168	135.2322	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04042	135.2322	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04042	135.2322	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04042	135.2322	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.08548	135.2322	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05652	99.2	'GOLTYTP2 69.000 - HELENA TAP 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0335	112.5973	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0624	112.5973	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0335	97.7	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0624	97.7	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05539	105.4354	'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06571	117.5793	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06571	100.6109	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06571	117.5793	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06571	100.6109	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	95.8	'CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	95.8	'CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	95.8	'G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	95.8	'G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0335	112.8994	'BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0624	112.8994	'BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0335	97.8	'BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0624	97.8	'BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	133.5	'FPL SWITCH - OKLA WIND ENERGY CENTER 138KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	133.5	'FPL SWITCH - OKLA WIND ENERGY CENTER 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03003	100	'ALVA - CHEROKEE SW 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05785	100	'ALVA - CHEROKEE SW 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05782	100.2814	'BRANTLEY - MORWOOD 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03093	99.9	'FARGO JCT - FT SUPPLY 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05963	99.9	'FARGO JCT - FT SUPPLY 69KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	121.7	'FT SUPPLY - SLEEPING BEAR 138KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	121.7	'FT SUPPLY - SLEEPING BEAR 138KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03016	102.7	'FT SUPPLY - SLEEPING BEAR 138KV CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05811	102.7	'FT SUPPLY - SLEEPING BEAR 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03052	116.0939	'FT SUPPLY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05873	116.0939	'FT SUPPLY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03052	100	'FT SUPPLY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05873	100	'FT SUPPLY - IODINE 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03052	114.5085	'IODINE - MOORELAND 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05873	114.5085	'IODINE - MOORELAND 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03052	99.1	'IODINE - MOORELAND 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05873	99.1	'IODINE - MOORELAND 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05782	100.2714	'MOREWOOD SW - MORWOOD 138KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05723	99.7	'OKEENE - WATONGA SW 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03133	104.8582	'CARTER JCT - WOODWARD 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06036	104.8582	'CARTER JCT - WOODWARD 69KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06364	105.8939	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.07324	105.3657	'BEAVER CO 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03164	110.9098	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03729	110.9098	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0373	110.9098	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03728	110.9098	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06236	110.9098	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03164	96.9	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03729	96.9	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0373	96.9	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03728	96.9	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06236	96.9	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03096	110.0699	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03124	110.0699	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03125	110.0699	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03124	110.0699	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06038	110.0699	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03096	96.4	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03124	96.4	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03125	96.4	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03124	96.4	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06038	96.4	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06364	107.544	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03276	105.2301	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05919	105.2301	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03264	104.5413	'MINGO - SETAB 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05942	104.5413	'MINGO - SETAB 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03225	104.6798	'BENTON - WICHITA 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05973	104.6798	'BENTON - WICHITA 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03391	100	'VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05954	100	'VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03439	111.0014	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0622	111.0014	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03439	97	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0622	97	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03439	111.0014	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0622	111.0014	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03439	97	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'	FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0622	97	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03164	113.2313	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03729	113.2313	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0373	113.2313	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'	FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03728	113.2313	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOAD	CONTNAME
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06236	113.2313	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03164	98.5	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03729	98.5	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0373	98.5	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03728	98.5	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06236	98.5	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03025	104.9844	'WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05617	104.9844	'WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03419	127.7183	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06589	127.7183	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
SPP_FG-52	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03419	105.6247	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
SPP_FG-52	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06589	105.6247	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	104.5	'SOONER 138/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	104.5	'SOONER 138/22.0KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05343	112.7423	'WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05343	97.9	'WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05344	111.8042	'WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05344	97.5	'WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	111.2	'TALOGA WIND (TLGAWND1) 138/34.5/9.96KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	111.2	'TALOGA WIND (TLGAWND1) 138/34.5/9.96KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03016	96.7	'TALOGA WIND (TLGAWND1) 138/34.5/9.96KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05811	96.7	'TALOGA WIND (TLGAWND1) 138/34.5/9.96KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	99.1	'CRSRDSW7 345.00 (CRSRDSWB1) 345/34.5/13.8KV TRANSFORMER CKT 2'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	99.1	'CRSRDSW7 345.00 (CRSRDSWB1) 345/34.5/13.8KV TRANSFORMER CKT 2'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	98.8	'CRSRDSW7 345.00 (CRSRDSWB1) 345/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	98.8	'CRSRDSW7 345.00 (CRSRDSWB1) 345/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	133.7	'OKLA WIND ENERGY CENTER (FPLWIND) 138/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	133.7	'OKLA WIND ENERGY CENTER (FPLWIND) 138/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	106.3	'MOORELAND 138/18.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	106.3	'MOORELAND 138/18.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03016	97.1	'MOORELAND 138/18.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05811	97.1	'MOORELAND 138/18.0KV TRANSFORMER CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03318	106.1617	'POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06199	106.1617	'POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	98.2	'TOLK STATION EAST 230/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	98.2	'TOLK STATION EAST 230/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	95.8	'G07-21 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	95.8	'G07-21 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	99.6	'SUB 3458 NEB CTY 345/18.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	99.6	'SUB 3458 NEB CTY 345/18.0KV TRANSFORMER CKT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04846	139.3862	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03088	139.3862	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03694	139.3862	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03694	139.3862	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03693	139.3862	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.07583	139.3862	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'ROMAN NOSE - SOUTHARD 138KV CKT 1'	153	0.03048	95.1	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.17739	105.7258	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_048	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.11163	105.7258	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.17123	105.7258	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.17126	105.7258	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.1712	105.7258	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.27879	105.7258	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04846	113.9928	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_048	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03088	113.9928	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03694	113.9928	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03694	113.9928	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03693	113.9928	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.07583	113.9928	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.0391	127.6137	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.03621	127.6137	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.0391	174.6777	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03621	174.6777	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0391	153.4929	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.03621	153.4929	'DBL-WICH-THI'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04529	158.2566	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04529	158.2566	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04529	158.2566	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.08787	158.2566	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'GLASS MOUNTAIN - MOORELAND 138KV CKT 1'	124	0.03296	115.8656	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'EL RENO - ROMAN NOSE 138KV CKT 1'	153	0.03489	96.5	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'ROMAN NOSE - SOUTHARD 138KV CKT 1'	153	0.03489	101.2876	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.0707	114.0599	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	G10_048	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.03267	114.0599	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.19979	114.0599	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.19981	114.0599	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.19977	114.0599	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	1195	0.31995	114.0599	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04529	124.6581	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04529	124.6581	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04529	124.6581	'DBL-THIS-WWR'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.08787	124.6581	'DBL-THIS-WWR'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05765	99.8	'SPP-AEPW-01'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03115	107.4486	'SPP-AEPW-32'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04134	107.4486	'SPP-AEPW-32'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04133	107.4486	'SPP-AEPW-32'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04135	107.4486	'SPP-AEPW-32'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06157	107.4486	'SPP-AEPW-32'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0544	98.2	'OGE3TERM1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	102.2813	'NC1_GEN-NEBRASKA CITY 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	102.2813	'NC1_GEN-NEBRASKA CITY 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03124	105.8208	'SPP-SWPS-01'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04062	105.8208	'SPP-SWPS-01'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04062	105.8208	'SPP-SWPS-01'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04063	105.8208	'SPP-SWPS-01'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06165	105.8208	'SPP-SWPS-01'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03164	113.2387	'SPP-SWPS-02A'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03729	113.2387	'SPP-SWPS-02A'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0373	113.2387	'SPP-SWPS-02A'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03728	113.2387	'SPP-SWPS-02A'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06236	113.2387	'SPP-SWPS-02A'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03164	96.9	'SPP-SWPS-02A'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03729	96.9	'SPP-SWPS-02A'
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0373	96.9	'SPP-SWPS-02A'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03728	96.9	'SPP-SWPS-02A'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06236	96.9	'SPP-SWPS-02A'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03167	111.8355	'SPP-SWPS-03'
	FDNS	01ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03748	111.8355	'SPP-SWPS-03'
	FDNS	01ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03749	111.8355	'SPP-SWPS-03'
	FDNS	01ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03747	111.8355	'SPP-SWPS-03'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06242	111.8355	'SPP-SWPS-03'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03167	97.4	'SPP-SWPS-03'
	FDNS	01ALL		0	13G	ASGI_2010_020	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03748	97.4	'SPP-SWPS-03'
	FDNS	01ALL		0	13G	ASGI_2010_021	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03749	97.4	'SPP-SWPS-03'
	FDNS	01ALL		0	13G	ASGI_2011_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03747	97.4	'SPP-SWPS-03'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.06242	97.4	'SPP-SWPS-03'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06364	105.9407	'SPP-SWPS-05'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	104.5662	'GEN335831 1-RIVERBEND UNIT#1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	104.5662	'GEN335831 1-RIVERBEND UNIT#1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	105.2664	'GEN336153 1-WATERFORD UNIT#3'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	105.2664	'GEN336153 1-WATERFORD UNIT#3'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	104.6069	'GEN501801 1-DOLET HILLS UNIT1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	104.6069	'GEN501801 1-DOLET HILLS UNIT1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	104.601	'GEN509403 1-PIRKEY GENERATION'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	104.601	'GEN509403 1-PIRKEY GENERATION'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	104.6186	'GEN509416 1-TURK GENERATION'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	104.6186	'GEN509416 1-TURK GENERATION'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	108.0454	'GEN514805 1-SOONER UNIT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	108.0454	'GEN514805 1-SOONER UNIT 1'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03016	95.3	'GEN514805 1-SOONER UNIT 1'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05811	95.3	'GEN514805 1-SOONER UNIT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	105.9866	'GEN514806 1-SOONER UNIT 2'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	105.9866	'GEN514806 1-SOONER UNIT 2'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	104.4814	'GEN515223 1-MUSKOGEE 4G'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	104.4814	'GEN515223 1-MUSKOGEE 4G'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	104.4483	'GEN515225 1-MUSKOGEE 5G'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	104.4483	'GEN515225 1-MUSKOGEE 5G'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	104.8012	'GEN515226 1-MUSKOGEE 6G'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	104.8012	'GEN515226 1-MUSKOGEE 6G'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	112.077	'GEN515389 1-TLAWND1 34.500'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	112.077	'GEN515389 1-TLGAWND1 34.500'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03016	97.3	'GEN515389 1-TLGAWND1 34.500'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05811	97.3	'GEN515389 1-TLGAWND1 34.500'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	99.8	'GEN515449 1-CRSRDW11 34.500'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	99.8	'GEN515449 1-CRSRDW11 34.500'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	99.8	'GEN515450 1-CRSRDW21 34.500'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	99.8	'GEN515450 1-CRSRDW21 34.500'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	130.483	'GEN515787 1-OKLA WIND ENERGY CENTER'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	130.483	'GEN515787 1-OKLA WIND ENERGY CENTER'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	123.0226	'GEN520922 1-SLEEPING BEAR'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	123.0226	'GEN520922 1-SLEEPING BEAR'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03016	103.4569	'GEN520922 1-SLEEPING BEAR'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05811	103.4569	'GEN520922 1-SLEEPING BEAR'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	104.6104	'GEN520947 1-HUGO1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	104.6104	'GEN520947 1-HUGO1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	106.9805	'GEN520997 1-MORLND2'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	106.9805	'GEN520997 1-MORLND2'
	FDNS	01ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03016	97.5	'GEN520997 1-MORLND2'
	FDNS	01ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.05811	97.5	'GEN520997 1-MORLND2'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	105.7	'GEN521120 1-BUFBEAR2'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	105.7	'GEN521120 1-BUFBEAR2'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	98.7	'GEN523971 1-HARRINGTON GEN #1 24 KV'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	98.7	'GEN523971 1-HARRINGTON GEN #1 24 KV'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	98.7	'GEN523972 1-HARRINGTON GEN #2 24 KV'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	98.7	'GEN523972 1-HARRINGTON GEN #2 24 KV'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	98.7	'GEN523973 1-HARRINGTON GEN #3 24 KV'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	98.7	'GEN523973 1-HARRINGTON GEN #3 24 KV'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	100.1527	'GEN525494 1-PLANT X GEN #4 20 KV'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	100.1527	'GEN525494 1-PLANT X GEN #4 20 KV'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	98.5	'GEN525561 1-TOLK GEN #1 24 KV'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	98.5	'GEN525561 1-TOLK GEN #1 24 KV'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	96.2	'GEN525562 1-TOLK GEN #2 24 KV'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	96.2	'GEN525562 1-TOLK GEN #2 24 KV'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	99.5	'GEN526331 1-JONES GEN #1 22 KV'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	99.5	'GEN526331 1-JONES GEN #1 22 KV'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	99.5	'GEN526332 1-JONES GEN #2 21 KV'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	99.5	'GEN526332 1-JONES GEN #2 21 KV'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	100.0523	'GEN527882 1-CUNNINGHAM GEN #2 20 KV'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	100.0523	'GEN527882 1-CUNNINGHAM GEN #2 20 KV'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	100.1923	'GEN527901 1-HOBBS PLANT #1 (CT)'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	100.1923	'GEN527901 1-HOBBS PLANT #1 (CT)'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	100.2067	'GEN527902 1-HOBBS PLANT #2 (CT)'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	100.2067	'GEN527902 1-HOBBS PLANT #2 (CT)'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	99.2	'GEN527903 1-HOBBS PLANT #3 (ST)'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	99.2	'GEN527903 1-HOBBS PLANT #3 (ST)'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	96.9	'GEN531447 1-HOLCOMB GENERATOR'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	96.9	'GEN531447 1-HOLCOMB GENERATOR'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	100	'GEN532651 1-JEFFREY ENERGY CENTER UNIT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	100	'GEN532651 1-JEFFREY ENERGY CENTER UNIT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	100	'GEN532652 1-JEFFREY ENERGY CENTER UNIT 2'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	100	'GEN532652 1-JEFFREY ENERGY CENTER UNIT 2'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	100	'GEN532653 1-JEFFREY ENERGY CENTER UNIT 3'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	100	'GEN532653 1-JEFFREY ENERGY CENTER UNIT 3'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	100.109	'GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05811	100.109	'GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03016	100.259	'GEN542962 2-ITAN UNIT #2'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	100.259	'GEN542962 2-IATAN UNIT #2'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	97.2	'GEN560648 1-G07-21 0.5750'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	97.2	'GEN560648 1-G07-21 0.5750'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	99.7	'GEN640009 1-COOPER NUCLEAR STATION'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	99.7	'GEN640009 1-COOPER NUCLEAR STATION'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	99.3	'GEN640010 1-GERALD GENTLEMAN STATION UNIT 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	99.3	'GEN640010 1-GERALD GENTLEMAN STATION UNIT 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	99.4	'GEN640011 2-GERALD GENTLEMAN STATION UNIT 2'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	99.4	'GEN640011 2-GERALD GENTLEMAN STATION UNIT 2'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	100.0626	'GEN645011 1-NEBRASKA CITY 1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	100.0626	'GEN645011 1-NEBRASKA CITY 1'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	99.9	'GEN645012 2-NEBRASKA CITY 2'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	99.9	'GEN645012 2-NEBRASKA CITY 2'
	FDNS	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	97.7	'GEN659118 1-LARAMIE RIVER UNIT1'
	FDNS	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	97.7	'GEN659118 1-LARAMIE RIVER UNIT1'
	FNSL	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	105.4462	'GEN336821 1-GRAND GULF UNIT'
	FNSL	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	105.4462	'GEN336821 1-GRAND GULF UNIT'
	FNSL	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	104.7316	'GEN337910 1-ARKANSAS NUCLEAR ONE UNIT #1'
	FNSL	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	104.7316	'GEN337910 1-ARKANSAS NUCLEAR ONE UNIT #1'
	FNSL	01ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	105.2064	'GEN337911 1-ARKANSAS NUCLEAR ONE UNIT #2'
	FNSL	01ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05811	105.2064	'GEN337911 1-ARKANSAS NUCLEAR ONE UNIT #2'
NCONV	FNSL-Itera	01ALL		0	13G	G10_045	Non-Converged Contingency		0	0.04233	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	01ALL		0	13G	G10_048	Non-Converged Contingency		0	0.04851	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	01ALL		0	13G	G10_048	Non-Converged Contingency		0	0.03234	9999	'NEB01WAPAB3'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	149.9367	'BASE CASE'
	FDNS	02ALL		0	13G	G10_040	'FROM->TO'LAWEASOKLUNI'		425	0.06441	113.3	'BASE CASE'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'SPSSPTIESB1'		620	0.3904	118.5332	'BASE CASE'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'SPSSPTIESB1'		620	0.39033	118.5332	'BASE CASE'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'SPSSPTIESB1'		620	0.39047	118.5332	'BASE CASE'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'SPSSPTIESB1'		620	0.2113	118.5332	'BASE CASE'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'SPSSPTIESC'		620	0.3904	118.5332	'BASE CASE'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'SPSSPTIESC'		620	0.39033	118.5332	'BASE CASE'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'SPSSPTIESC'		620	0.39047	118.5332	'BASE CASE'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'SPSSPTIESC'		620	0.2113	118.5332	'BASE CASE'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05693	128.0053	'LYDIA - VALLIANT 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05752	128.0534	'DELAWARE - NORTHEAST STATION 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05589	124.1698	'CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05589	124.3958	'CLINTON AIR FORCE BASE TAP - HOBART JUNCTION 138KV CKT 1'
INVALID	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03014	156.6298	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04034	156.6298	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04033	156.6298	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04035	156.6298	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06056	156.6298	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'		287	0.10086	105.5569	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'		287	0.10089	105.5569	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'		287	0.10083	105.5569	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'		287	0.10086	104.4271	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'		287	0.10089	104.4271	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
INVALID	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10083	104.4271	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03014	144.0417	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04034	144.0417	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04033	144.0417	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04035	144.0417	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06056	144.0417	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
SPP_FG-50	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10086	95.6	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
SPP_FG-50	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10089	95.6	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
SPP_FG-50	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10083	95.6	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
SPP_FG-50	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10086	95.1	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
SPP_FG-50	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10089	95.1	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
SPP_FG-50	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10083	95.1	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05573	123.225	'CLINTON JUNCTION - ELK CITY 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05424	124.3745	'ELK CITY - RED HILLS WIND 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05696	128.0586	'WEATHERFORD JCT. - WEATHERFORD SOUTHEAST 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03062	159.8532	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03626	159.8532	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03627	159.8532	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03625	159.8532	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06133	159.8532	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03062	130.3369	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03626	130.3369	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03627	130.3369	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03625	130.3369	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06133	130.3369	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03309	135.7941	'HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05873	135.7941	'HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05584	127.4875	'KNOBHILL - SALINE 69KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05584	127.858	'HELENA TAP - SALINE 69KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04949	110.6159	'CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04783	113.2658	'CLEO CORNER - MEN TAP 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03337	149.987	'WOODWARD - WOODWARD 69KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06507	149.987	'WOODWARD - WOODWARD 69KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	126.5	'CENT 4 138.00 - WOODWARD 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05154	117.0671	'WOODWARD - WOODWARD EHV 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05612	127.5151	'WOODWARD - WOODWARD EHV 138KV CKT 2'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03541	159.1	'DEWEY - IODINE 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06889	159.1	'DEWEY - IODINE 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05425	121.603	'DEWEY - SOUTHARD 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03005	135.7593	'DEWEY - TALOGA 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05878	135.7593	'DEWEY - TALOGA 138KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04949	109.605	'GLASS MOUNTAIN - MOORELAND 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04783	114.1735	'IMO TAP - MEN TAP 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05712	127.799	'ALVA - KNOBHILL 69KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05529	120.8526	'KNOBHILL - MOORELAND 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03541	160.1301	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06889	160.1301	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05425	123.2772	'EL RENO - ROMAN NOSE 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05425	122.6281	'ROMAN NOSE - SOUTHARD 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05831	134.0923	'CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04324	190.8535	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03047	190.8535	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03921	190.8535	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03922	190.8535	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03921	190.8535	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.08427	190.8535	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04324	107.995	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_048	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03047	107.995	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03921	107.995	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03922	107.995	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03921	107.995	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.08427	107.995	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07449	95.1	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07454	95.1	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07444	95.1	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.03117	95.1	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04324	175.3946	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03047	175.3946	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03921	175.3946	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03922	175.3946	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03921	175.3946	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.08427	175.3946	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04324	99.4	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_048	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03047	99.4	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03921	99.4	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03922	99.4	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03921	99.4	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.08427	99.4	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05475	119.9062	'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06495	143.0094	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06495	143.0094	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	122.1	'G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0369	113.7856	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07332	99.9	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07337	99.9	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07326	99.9	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.0523	99.9	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07332	99.1	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07337	99.1	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07326	99.1	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.0523	99.1	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	127.8	'KEENAN4 - WOODWARD EHV 138KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	126.1	'G08-29 138.00 - WOODWARD EHV 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03309	134.2424	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05873	134.2424	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	135.8	'FPL SWITCH - OKLA WIND ENERGY CENTER 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05109	111.6459	'CEDARDALE - MOORELAND 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05109	112.3562	'CEDARDALE - OKEENE 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05279	120.5186	'DOVER SW - OKEENE 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03019	132.5277	'FARGO JCT - FT SUPPLY 69KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05889	132.5277	'FARGO JCT - FT SUPPLY 69KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	134	'FT SUPPLY - SLEEPING BEAR 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05607	124.9846	'MOORELAND - TALOGA 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05066	122.3228	'MOORELAND - NINE MILE 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05424	128.2266	'MOREWOOD SW - RED HILLS WIND 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05066	122.7479	'MOREWOOD SW - NINE MILE 138KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05653	128.2409	'OKEENE - WATONGA SW 69KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03019	133.4725	'FARGO JCT - WOODWARD 69KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05889	133.4725	'FARGO JCT - WOODWARD 69KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03058	132.8436	'CARTER JCT - WOODWARD 69KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05961	132.8436	'CARTER JCT - WOODWARD 69KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06287	143.2743	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	125.1	'G10-14 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0726	124.9684	'BEAVER CO 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03062	157.0212	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03626	157.0212	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03627	157.0212	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03625	157.0212	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06133	157.0212	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03007	148.4422	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03036	148.4422	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03036	148.4422	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03036	148.4422	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0595	148.4422	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
ISLAND-LO	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	127.7454	'Graves Sub - STATELINE INTERCHANGE 115KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06287	145.7294	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07753	95.1	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07758	95.1	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.07748	95.1	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.03171	95.1	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03203	133.7809	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05847	133.7809	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05806	133.5086	'BUCKNER7 345.00 - HOLCOMB 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03192	133.6594	'MINGO - SETAB 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05869	133.6594	'MINGO - SETAB 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03218	132.9692	'MINGO - RED WILLOW 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05885	132.9692	'MINGO - RED WILLOW 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03495	134.5845	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05806	134.5845	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0315	133.513	'BENTON - WICHITA 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05898	133.513	'BENTON - WICHITA 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03362	140.2088	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06144	140.2088	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03362	140.2088	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06144	140.2088	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	124.3	'BEAVER CO 345.00 - G08-47 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	128.3	'G07-62 345.00 - G07-62-1 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	128.3	'G07-62 345.00 - G07-62-2 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	128.2	'G07-62 345.00 - G07-62-3 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	128.2	'G07-62 345.00 - G07-62-4 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	125.1	'G10-14 345.00 345/115KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	123.8	'BEAVER CO 345.00 - G10-01 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	127.5	'G06-44 115.00 - G06-44-3 115.00 115KV CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03062	159.8665	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03626	159.8665	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOAD	CONTNAME
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03627	159.8665	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03625	159.8665	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06133	159.8665	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05546	136.485	'WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03337	162.7397	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06507	162.7397	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05529	121.3524	'KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	132.7	'SOONER 138/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	125.9	'CENT 4 138.00 (CENTENNIAL) 138/34.5/9.96KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05277	122.2741	'WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05279	121.6207	'WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	127.7	'KEENAN4 (KEENAN1) 138/34.5/9.96KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	136.1	'OKLA WIND ENERGY CENTER (FPLWIND) 138/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	138.7	'MOORELAND 138/18.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	126.9	'Hitchland Interchange (PRO G2218-01) 345/115/13.8KV TRANSFORMER CKT 1'
ISLAND-LO	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	127.7423	'STATELINE INTERCHANGE (H TP80154301) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03258	132.8085	'POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06139	132.8085	'POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	122.9	'TOLK STATION EAST 230/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	124.3	'G08-47 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	128.3	'G07-62-1 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	128.3	'G07-62-2 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	128.2	'G07-62-3 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	128.2	'G07-62-4 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	127.6	'G10-14 115.00 115/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	127.6	'G10-14 115.00 115/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	123.8	'G10-01 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	126.1	'G08-29 138.00 138/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	127.5	'G06-44-3 115.00 115/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	127.1	'SUB 3458 NEB CTY 345/18.0KV TRANSFORMER CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONT	COMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
ISLAND-GE	FDNS	02ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	128.2	'RAUN 345/22.0KV TRANSFORMER CKT 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04755	173.4512	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03603	173.4512	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03603	173.4512	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03603	173.4512	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.07492	173.4512	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	G10_045	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04755	98.4	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03603	98.4	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03603	98.4	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.03603	98.4	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.07492	98.4	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'	'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.03868	129.5888	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'	'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.03579	129.5888	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	G10_045	'FROM->TO'	'FLATRDRG3 - HARPER 138KV CKT 1'	95.6	0.03868	176.9227	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'	'FLATRDRG3 - HARPER 138KV CKT 1'	95.6	0.03579	176.9227	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	G10_045	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.03868	155.7723	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.03579	155.7723	'DBL-WICH-THI'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04439	177.138	'DBL-THIS-WWR'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04439	177.138	'DBL-THIS-WWR'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04439	177.138	'DBL-THIS-WWR'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.08697	177.138	'DBL-THIS-WWR'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04439	100.3341	'DBL-THIS-WWR'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04439	100.3341	'DBL-THIS-WWR'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.04439	100.3341	'DBL-THIS-WWR'
	FDNS	02ALL		0	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.08697	100.3341	'DBL-THIS-WWR'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05692	127.9994	'SPP-AEPW-01'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03014	146.6449	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04034	146.6449	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04033	146.6449	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04035	146.6449	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06056	146.6449	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10086	97	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10089	97	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10083	97	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10086	96.4	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10089	96.4	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10083	96.4	'SPP-AEPW-32'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05739	130.3372	'NC1_GEN-NEBRASKA CITY 1'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03025	144.0137	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03963	144.0137	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03962	144.0137	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03964	144.0137	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06066	144.0137	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.103	95.8	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10302	95.8	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10297	95.8	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	ASGI_2010_020	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.103	95.3	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	ASGI_2010_021	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10302	95.3	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	ASGI_2011_001	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.10297	95.3	'SPP-SWPS-01'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03062	159.8532	'SPP-SWPS-02A'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03626	159.8532	'SPP-SWPS-02A'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03627	159.8532	'SPP-SWPS-02A'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03625	159.8532	'SPP-SWPS-02A'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06133	159.8532	'SPP-SWPS-02A'
	FDNS	02ALL		0	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03064	158.0717	'SPP-SWPS-03'
	FDNS	02ALL		0	13G	ASGI_2010_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03645	158.0717	'SPP-SWPS-03'
	FDNS	02ALL		0	13G	ASGI_2010_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03646	158.0717	'SPP-SWPS-03'
	FDNS	02ALL		0	13G	ASGI_2011_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03644	158.0717	'SPP-SWPS-03'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06139	158.0717	'SPP-SWPS-03'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06287	143.3263	'SPP-SWPS-05'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	132.4662	'GEN509403 1-PIRKEY GENERATION'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	132.5563	'GEN509416 1-TURK GENERATION'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	136.0494	'GEN514805 1-SOONER UNIT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	133.8332	'GEN514806 1-SOONER UNIT 2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	132.5847	'GEN515226 1-MUSKOGEE 6G'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	128.1098	'GEN515365 1-CENT 21 34.500'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	128.2353	'GEN515393 1-OGEWND2G'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	135.2694	'GEN515787 1-OKLA WIND ENERGY CENTER'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	134.306	'GEN520922 1-SLEEPING BEAR'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	132.7582	'GEN520947 1-HUGO1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	139.5349	'GEN520997 1-MORLND2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	122.3626	'GEN523103 1-NOBLE WND 3115.00'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	128.1411	'GEN523195 1-Hansford County Switch Station'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	124.8168	'GEN523971 1-HARRINGTON GEN #1 24 KV'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	124.8126	'GEN523972 1-HARRINGTON GEN #2 24 KV'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	124.8213	'GEN523973 1-HARRINGTON GEN #3 24 KV'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.1147	'GEN525494 1-PLANT X GEN #4 20 KV'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	122.8462	'GEN525561 1-TOLK GEN #1 24 KV'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	120.9362	'GEN525562 1-TOLK GEN #2 24 KV'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	125.9529	'GEN526331 1-JONES GEN #1 22 KV'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	125.9513	'GEN526332 1-JONES GEN #2 21 KV'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.5542	'GEN527161 1-MUSTANG GEN #1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.5542	'GEN527162 1-MUSTANG GEN #2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.9447	'GEN527882 1-CUNNINGHAM GEN #2 20 KV'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.7258	'GEN527901 1-HOBBS PLANT #1 (CT)'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.7439	'GEN527902 1-HOBBS PLANT #2 (CT)'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.482	'GEN527903 1-HOBBS PLANT #3 (ST)'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	123.1058	'GEN531447 1-HOLCOMB GENERATOR'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.6588	'GEN532651 1-JEFFREY ENERGY CENTER UNIT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.6595	'GEN532652 1-JEFFREY ENERGY CENTER UNIT 2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.6591	'GEN532653 1-JEFFREY ENERGY CENTER UNIT 3'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.1224	'GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.8175	'GEN542957 1-IATAN UNIT #1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.0468	'GEN542962 2-IATAN UNIT #2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	118.4104	'GEN560121 1-G08-47 0.5750'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	124.3925	'GEN560256 1-G10-14-1 0.6900'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	124.2388	'GEN560257 1-G10-14-2 0.6900'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	124.0407	'GEN560286 1-G10-01-1WTG 0.6900'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	124.0407	'GEN560287 1-G10-01-2WTG 0.6900'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	124.5785	'GEN560371 1-G07-46 0.6900'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.4484	'GEN560429 1-G08-29 0.6400'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	125.9537	'GEN560585 1-G06-44-2 0.6000'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	124.1145	'GEN560586 1-G06-44-3 0.6000'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.2714	'GEN640009 1-COOPER NUCLEAR STATION'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.2147	'GEN640010 1-GERALD GENTLEMAN STATION UNIT 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.3187	'GEN640011 2-GERALD GENTLEMAN STATION UNIT 2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.6165	'GEN645001 1-FORT CALHOUN 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.028	'GEN645011 1-NEBRASKA CITY 1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	126.6887	'GEN645012 2-NEBRASKA CITY 2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.6397	'GEN659103 1-ANTELOPE VALLEY UNIT1'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	127.6397	'GEN659107 2-ANTELOPE VALLEY UNIT2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	128.2994	'GEN659111 2-LELAND OLDS UNIT2'
	FDNS	02ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05739	124.2358	'GEN659118 1-LARAMIE RIVER UNIT1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	137.7612	'BASE CASE'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05574	115.4212	'CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05574	115.6396	'CLINTON AIR FORCE BASE TAP - HOBART JUNCTION 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05556	115.276	'CLINTON JUNCTION - ELK CITY 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05418	111.3278	'ELK CITY - RED HILLS WIND 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03065	119.7532	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	03ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03629	119.7532	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	03ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.0363	119.7532	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	03ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03628	119.7532	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06136	119.7532	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05722	117.346	'CIMARRON - WOODRING 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05569	117.6135	'KNOBHILL - SALINE 69KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04933	104.0241	'CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04766	107.3409	'CLEO CORNER - MEN TAP 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03322	137.7311	'WOODWARD - WOODWARD 69KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06492	137.7311	'WOODWARD - WOODWARD 69KV CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	115.7	'CENT 4 138.00 - WOODWARD 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05141	107.6978	'WOODWARD - WOODWARD EHV 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05599	117.1815	'WOODWARD - WOODWARD EHV 138KV CKT 2'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03526	145.7515	'DEWEY - IODINE 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06873	145.7515	'DEWEY - IODINE 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05412	111.7655	'DEWEY - SOUTHARD 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05863	125.188	'DEWEY - TALOGA 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04933	103.0063	'GLASS MOUNTAIN - MOORELAND 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04766	108.2405	'IMO TAP - MEN TAP 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05698	117.4919	'ALVA - KNOBHILL 69KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05515	111.542	'KNOBHILL - MOORELAND 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03526	146.7778	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06873	146.7778	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05412	113.4451	'EL RENO - ROMAN NOSE 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05412	112.8002	'ROMAN NOSE - SOUTHARD 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05816	123.6462	'CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03265	126.921	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06155	126.921	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06494	117.3306	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06494	117.3306	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	111.3	'G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	117	'KEENAN4 - WOODWARD EHV 138KV CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	115.5	'G08-29 138.00 - WOODWARD EHV 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03265	127.0983	'BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06155	127.0983	'BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	125.9	'FPL SWITCH - OKLA WIND ENERGY CENTER 138KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05094	104.0089	'CEDARDALE - MOORELAND 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05094	104.7274	'CEDARDALE - OKEENE 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05264	112.094	'DOVER SW - OKEENE 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05713	121.7455	'FAIRVIEW - OKEENE 69KV CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	123.8	'FT SUPPLY - SLEEPING BEAR 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05593	115.0898	'MOORELAND - TALOGA 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05068	103.7175	'MOORELAND - NINE MILE 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05418	115.631	'MOREWOOD SW - RED HILLS WIND 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05068	104.1399	'MOREWOOD SW - NINE MILE 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05639	117.7633	'OKEENE - WATONGA SW 69KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03005	122.5074	'FARGO JCT - WOODWARD 69KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05875	122.5074	'FARGO JCT - WOODWARD 69KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03044	121.8933	'CARTER JCT - WOODWARD 69KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05947	121.8933	'CARTER JCT - WOODWARD 69KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03003	131.4755	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	03ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03031	131.4755	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	03ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03032	131.4755	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	03ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03031	131.4755	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05945	131.4755	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
ISLAND-LO	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.4814	'Graves Sub - STATELINE INTERCHANGE 115KV CKT 1' 'FINNEY SWITCHING STATION - G08-18 345.00 345KV CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.1	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03186	126.6575	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0583	126.6575	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'MULLERGREN - SPEARVILLE 230KV CKT 1'	355.3	0.10526	129.8929	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'MULLERGREN - SPEARVILLE 230KV CKT 1'	355.3	0.03814	129.8929	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03076	123.2883	'AXTELL - POST ROCK 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05801	123.2883	'AXTELL - POST ROCK 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'FROM->TO'SMOKYH6 230.00 - SUMMIT 230KV CKT 1'	319	0.06971	96.5	'AXTELL - POST ROCK 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_048	'FROM->TO'SMOKYH6 230.00 - SUMMIT 230KV CKT 1'	319	0.13618	96.5	'AXTELL - POST ROCK 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03127	122.4432	'HOLCOMB - SETAB 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05829	122.4432	'HOLCOMB - SETAB 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03177	124.3849	'MINGO - SETAB 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05854	124.3849	'MINGO - SETAB 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03047	121.8424	'BENTON - ROSE HILL 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05805	121.8424	'BENTON - ROSE HILL 345KV CKT 1'
CONT-LaC	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05727	121.8319	'LACYGNE - NEOSHO 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0329	124.5533	'VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05853	124.5533	'VIOLA 7 345.00 - WICHITA 345KV CKT 1'
NCONV	FNSL-Blow	03ALL		0	13G	G10_045	Non-Converged Contingency	0	0.24948	9999	'DBL-WICH-THI'
NCONV	FNSL-Blow	03ALL		0	13G	G10_048	Non-Converged Contingency	0	0.12336	9999	'DBL-WICH-THI'
NCONV	FNSL-Blow	03ALL		0	13G	ASGI_2010_020	Non-Converged Contingency	0	0.16995	9999	'DBL-WICH-THI'
NCONV	FNSL-Blow	03ALL		0	13G	ASGI_2010_021	Non-Converged Contingency	0	0.16997	9999	'DBL-WICH-THI'
NCONV	FNSL-Blow	03ALL		0	13G	ASGI_2011_001	Non-Converged Contingency	0	0.16993	9999	'DBL-WICH-THI'
NCONV	FNSL-Blow	03ALL		0	13G	G10_001	Non-Converged Contingency	0	0.24141	9999	'DBL-WICH-THI'
NCONV	FNSL-Blow	03ALL		0	13G	G10_041	Non-Converged Contingency	0	0.04702	9999	'DBL-THIS-CLR'
NCONV	FNSL-Blow	03ALL		0	13G	G10_051	Non-Converged Contingency	0	0.07189	9999	'DBL-THIS-CLR'
NCONV	FNSL-Blow	03ALL		0	13G	G10_045	Non-Converged Contingency	0	0.361	9999	'DBL-THIS-CLR'
NCONV	FNSL-Blow	03ALL		0	13G	G10_048	Non-Converged Contingency	0	0.23524	9999	'DBL-THIS-CLR'
NCONV	FNSL-Blow	03ALL		0	13G	G10_041	Non-Converged Contingency	0	0.04702	9999	'DBL-SPRVL-CL'
NCONV	FNSL-Blow	03ALL		0	13G	G10_051	Non-Converged Contingency	0	0.07189	9999	'DBL-SPRVL-CL'
NCONV	FNSL-Blow	03ALL		0	13G	G10_045	Non-Converged Contingency	0	0.361	9999	'DBL-SPRVL-CL'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	COMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
NCONV	FNSL-Blow	03ALL		0	13G	G10_048	Non-Converged Contingency	0	0.23524	9999	'DBL-SPRVL-CL'
NCONV	FNSL-Itera	03ALL		0	13G	G10_040	Non-Converged Contingency	0	0.16619	9999	'SPP-AEPW-01'
NCONV	FNSL-Itera	03ALL		0	13G	G10_045	Non-Converged Contingency	0	0.07041	9999	'SPP-AEPW-01'
NCONV	FNSL-Itera	03ALL		0	13G	G10_048	Non-Converged Contingency	0	0.04834	9999	'SPP-AEPW-01'
NCONV	FNSL-Itera	03ALL		0	13G	ASGI_2010_020	Non-Converged Contingency	0	0.14355	9999	'SPP-AEPW-01'
NCONV	FNSL-Itera	03ALL		0	13G	ASGI_2010_021	Non-Converged Contingency	0	0.14354	9999	'SPP-AEPW-01'
NCONV	FNSL-Itera	03ALL		0	13G	ASGI_2011_001	Non-Converged Contingency	0	0.14357	9999	'SPP-AEPW-01'
NCONV	FNSL-Itera	03ALL		0	13G	G10_001	Non-Converged Contingency	0	0.11167	9999	'SPP-AEPW-01'
NCONV	FNSL-Itera	03ALL		0	13G	G10_040	Non-Converged Contingency	0	0.05077	9999	'GRDA-OPGD-05'
NCONV	FNSL-Itera	03ALL		0	13G	G10_041	Non-Converged Contingency	0	0.15127	9999	'KCPL-OL166-1'
NCONV	FNSL-Itera	03ALL		0	13G	G10_051	Non-Converged Contingency	0	0.20073	9999	'KCPL-OL166-1'
NCONV	FNSL-Itera	03ALL		0	13G	G10_048	Non-Converged Contingency	0	0.04675	9999	'KCPL-OL166-1'
NCONV	FNSL-Itera	03ALL		0	13G	G10_041	Non-Converged Contingency	0	0.03738	9999	'KCPL-OL166-2'
NCONV	FNSL-Itera	03ALL		0	13G	G10_045	Non-Converged Contingency	0	0.04164	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	03ALL		0	13G	G10_048	Non-Converged Contingency	0	0.04783	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	03ALL		0	13G	G10_045	Non-Converged Contingency	0	0.03176	9999	'SPP-SWPS-01'
NCONV	FNSL-Itera	03ALL		0	13G	G10_001	Non-Converged Contingency	0	0.0549	9999	'SPP-SWPS-01'
NCONV	FNSL-Itera	03ALL		0	13G	ASGI_2010_020	Non-Converged Contingency	0	0.13395	9999	'SPP-SWPS-03'
NCONV	FNSL-Itera	03ALL		0	13G	ASGI_2010_021	Non-Converged Contingency	0	0.13404	9999	'SPP-SWPS-03'
NCONV	FNSL-Itera	03ALL		0	13G	ASGI_2011_001	Non-Converged Contingency	0	0.13385	9999	'SPP-SWPS-03'
NCONV	FNSL-Itera	03ALL		0	13G	G10_001	Non-Converged Contingency	0	0.04309	9999	'SPP-SWPS-03'
NCONV	FNSL-Itera	03ALL		0	13G	G10_041	Non-Converged Contingency	0	0.06896	9999	'SPP-SWPS-05'
NCONV	FNSL-Itera	03ALL		0	13G	G10_051	Non-Converged Contingency	0	0.08013	9999	'SPP-SWPS-05'
NCONV	FNSL-Itera	03ALL		0	13G	G10_045	Non-Converged Contingency	0	0.2407	9999	'SPP-SWPS-05'
NCONV	FNSL-Itera	03ALL		0	13G	G10_048	Non-Converged Contingency	0	0.15691	9999	'SPP-SWPS-05'
NCONV	FNSL-Itera	03ALL		0	13G	G10_040	Non-Converged Contingency	0	0.03949	9999	'SPP-WERE-07C'
NCONV	FNSL-Itera	03ALL		0	13G	G10_045	Non-Converged Contingency	0	0.03077	9999	'WRTOD400'
NCONV	FNSL-Itera	03ALL		0	13G	G10_048	Non-Converged Contingency	0	0.04535	9999	'WRTOD400'
NCONV	FNSL-Itera	03ALL		0	13G	G10_048	Non-Converged Contingency	0	0.03189	9999	'NEB01WAPAB3'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.7	'G07-62 345.00 - G07-62-1 345.00 345KV CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.7	'G07-62 345.00 - G07-62-2 345.00 345KV CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.6	'G07-62 345.00 - G07-62-3 345.00 345KV CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.6	'G07-62 345.00 - G07-62-4 345.00 345KV CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	121.8	'40SAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0553	128.2901	'WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03322	150.4415	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06492	150.4415	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05515	112.0424	'KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	122.2	'SOONER 138/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	115.4	'CENT 4 138.00 (CENTENNIAL) 138/34.5/9.96KV TRANSFORMER CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05265	112.8736	'WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05266	112.2373	'WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.9	'KEENAN4 (KEENAN1) 138/34.5/9.96KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	126.1	'OKLA WIND ENERGY CENTER (FPLWIND) 138/34.5/13.8KV TRANSFORMER CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	128.6	'MOORELAND 138/18.0KV TRANSFORMER CKT 1'
ISLAND-LO	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	117.4788	'STATELINE INTERCHANGE (H TP80154301) 230/115/13.2KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	114.6	'TOLK STATION EAST 230/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	113.5	'JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	117.7	'G07-62-1 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	117.7	'G07-62-2 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	117.6	'G07-62-3 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	117.6	'G07-62-4 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_045	'FROM->TO'SPEARVILLE (SPEARVLX) 345/115/13.8KV TRANSFORMER CKT 3'		336	0.03333	100.2	'G10-15 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_045	'FROM->TO'SPEARVILLE (SPEARVLX) 345/115/13.8KV TRANSFORMER CKT 3'		336	0.03333	100.6	'G10-15 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	117.1	'G08-18 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	115.4	'G08-29 138.00 138/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	116.6	'SUB 3458 NEB CTY 345/18.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	121.8	'40SAGEWIND 138.00 138/34.5KV TRANSFORMER CKT 1'
	FDNS	03ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04475	109.1604	'DBL-THIS-WWR'
	FDNS	03ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04475	109.1604	'DBL-THIS-WWR'
	FDNS	03ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04475	109.1604	'DBL-THIS-WWR'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.08733	109.1604	'DBL-THIS-WWR'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03016	127.8979	'SPP-AEPW-32'
	FDNS	03ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04036	127.8979	'SPP-AEPW-32'
	FDNS	03ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04035	127.8979	'SPP-AEPW-32'
	FDNS	03ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04037	127.8979	'SPP-AEPW-32'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06058	127.8979	'SPP-AEPW-32'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	119.7532	'NC1_GEN-NEBRASKA CITY 1'
	FDNS-CHE	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03065	135	'SPP-SWPS-02A'
	FDNS-CHE	03ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03629	135	'SPP-SWPS-02A'
	FDNS-CHE	03ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.0363	135	'SPP-SWPS-02A'
	FDNS-CHE	03ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03628	135	'SPP-SWPS-02A'
	FDNS-CHE	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06136	135	'SPP-SWPS-02A'
	FDNS	03ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03232	121.9234	'SPP-SWPS-04'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06113	121.9234	'SPP-SWPS-04'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	125.7517	'GEN514805 1-SOONER UNIT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	123.5147	'GEN514806 1-SOONER UNIT 2'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	121.902	'GEN515223 1-MUSKOGEE 4G'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	121.8689	'GEN515225 1-MUSKOGEE 5G'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	122.2122	'GEN515226 1-MUSKOGEE 6G'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	117.2749	'GEN515365 1-CENT 21 34.500'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	117.454	'GEN515393 1-OGEWND2G'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	125.3292	'GEN515787 1-OKLA WIND ENERGY CENTER'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	124.0902	'GEN520922 1-SLEEPING BEAR'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	122.2982	'GEN520947 1-HUGO1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	129.3449	'GEN520997 1-MORLND2'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	115.4878	'GEN523971 1-HARRINGTON GEN #1 24 KV'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	115.484	'GEN523972 1-HARRINGTON GEN #2 24 KV'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05726	115.4873	'GEN523973 1-HARRINGTON GEN #3 24 KV'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.2215	'GEN525494 1-PLANT X GEN #4 20 KV'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	114.7779	'GEN525561 1-TOLK GEN #1 24 KV'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	112.3505	'GEN525562 1-TOLK GEN #2 24 KV'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.3422	'GEN526331 1-JONES GEN #1 22 KV'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.341	'GEN526332 1-JONES GEN #2 21 KV'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.5652	'GEN527161 1-MUSTANG GEN #1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.5653	'GEN527162 1-MUSTANG GEN #2'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.0961	'GEN527882 1-CUNNINGHAM GEN #2 20 KV'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.3412	'GEN527901 1-HOBBS PLANT #1 (CT)'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.3578	'GEN527902 1-HOBBS PLANT #2 (CT)'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.1973	'GEN527903 1-HOBBS PLANT #3 (ST)'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	112.5226	'GEN531447 1-HOLCOMB GENERATOR'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.6035	'GEN532651 1-JEFFREY ENERGY CENTER UNIT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.5977	'GEN532652 1-JEFFREY ENERGY CENTER UNIT 2'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.5968	'GEN532653 1-JEFFREY ENERGY CENTER UNIT 3'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.2277	'GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	113.9076	'GEN539670 4-JUDSON LARGE GENERATOR'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.615	'GEN539945 1-FLATRWDWG1 0.6900'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.5209	'GEN560121 1-G08-47 0.5750'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	115.6955	'GEN560209 1-G07-40 0.5750'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.3766	'GEN560238 1-G10-09 0.6900'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	111.0766	'GEN560279 1-G08-18 0.6900'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	115.7006	'GEN560329 1-G10-45 0.6900'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	115.8491	'GEN560429 1-G08-29 0.6400'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	115.819	'GEN560432 1-G08-124 0.6900'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.8161	'GEN560514 1-G04_014 0.6900'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	114.8689	'GEN560522 1-G05-12 0.6900'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	115.7176	'GEN560549 1-G06-06 0.6900'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	117.339	'GEN560558 1-G06-022 0.6900'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	115.8663	'GEN560659 1-G07-38 0.6900'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.0209	'GEN640010 1-GERALD GENTLEMAN STATION UNIT 1'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	116.1235	'GEN640011 2-GERALD GENTLEMAN STATION UNIT 2'
	FDNS	03ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05726	114.0888	'GEN659118 1-LARAMIE RIVER UNIT1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	107.2396	'BASE CASE'
	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	100.4155	'BASE CASE'
	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	100.4155	'BASE CASE'
INVALID	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03061	106.5061	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	04ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04081	106.5061	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	04ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0408	106.5061	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	04ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04082	106.5061	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06103	106.5061	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05386	102.1628	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
INVALID	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10925	102.1628	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03061	96.6	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04081	96.6	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0408	96.6	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04082	96.6	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06103	96.6	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0311	108.8176	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03674	108.8176	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
	FDNS	04ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03675	108.8176	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03673	108.8176	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06181	108.8176	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.0311	100.1	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	04ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03674	100.1	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	04ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03675	100.1	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	04ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03673	100.1	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06181	100.1	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05435	95.9	'WAUKOMIS - WAUKOMIS TAP 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05435	95.4	'HENESSEY - WAUKOMIS 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03331	101.1815	'HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05895	101.1815	'HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05261	99.3	'HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.1082	99.3	'HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03366	107.6736	'WOODWARD - WOODWARD 69KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06536	107.6736	'WOODWARD - WOODWARD 69KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03572	113.542	'DEWEY - IODINE 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.0692	113.542	'DEWEY - IODINE 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03029	97.9	'DEWEY - TALOGA 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05902	97.9	'DEWEY - TALOGA 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03572	114.557	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.0692	114.557	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03018	96.8	'CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05855	96.8	'CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04369	133.4493	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03092	133.4493	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03966	133.4493	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03967	133.4493	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03966	133.4493	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.08472	133.4493	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05602	104.1064	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.11095	104.1064	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04369	116.9318	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03092	116.9318	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03966	116.9318	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03967	116.9318	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03966	116.9318	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.08472	116.9318	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05602	102.4968	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.11095	102.4968	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03302	98.8	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06192	98.8	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOAD	CONTNAME	
	FDNS	04ALL		0	13G	G10_045	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05427	101.5213	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10952	101.5213	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03302	99	'BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06192	99	'BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03331	99.5	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05895	99.5	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	99.3	'FPL SWITCH - OKLA WIND ENERGY CENTER 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05751	95.2	'FAIRVIEW - OKEENE 69KV CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	97.2	'FT SUPPLY - SLEEPING BEAR 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03045	95.3	'FARGO JCT - WOODWARD 69KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05915	95.3	'FARGO JCT - WOODWARD 69KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.06808	107.0364	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11874	107.0364	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0311	106.0054	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_020	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03674	106.0054	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_021	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03675	106.0054	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2011_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03673	106.0054	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06181	106.0054	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03045	103.4039	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_020	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03073	103.4039	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_021	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03074	103.4039	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	04ALL		0	13G	ASGI_2011_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03073	103.4039	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05987	103.4039	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.06808	105.2512	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11874	105.2512	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.03079	113.8506	'KNOLL 230 - POSTROCK6 230.00 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.23552	113.8506	'KNOLL 230 - POSTROCK6 230.00 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05335	99.4	'KNOLL - REDLINE 115KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05941	99.4	'KNOLL - REDLINE 115KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05394	95.3	'POSTROCK6 230.00 - SOUTH HAYS 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.1031	95.3	'POSTROCK6 230.00 - SOUTH HAYS 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05406	112.4585	'MULLERGREN - SOUTH HAYS 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.1316	112.4585	'MULLERGREN - SOUTH HAYS 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_051	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.03367	102.1282	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.14762	102.1282	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03118	95.6	'AXTELL - POST ROCK 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05843	95.6	'AXTELL - POST ROCK 345KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONT	COMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.0709	113.4822	'AXTELL - POST ROCK 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.13736	113.4822	'AXTELL - POST ROCK 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03036	96.5	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05787	96.5	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'KNOLL 230 - POSTROCK6 230.00 230KV CKT 1'	398	0.40324	103.5923	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05335	99.3	'G10-48T 115.00 - REDLINE 115KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05941	99.3	'G10-48T 115.00 - REDLINE 115KV CKT 1'
INVALID	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05492	101.9608	'ST JOHN - ST JOHN 115KV CKT 1'
INVALID	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11076	101.9608	'ST JOHN - ST JOHN 115KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.06686	97.7	'BUCKNER7 345.00 - HOLCOMB 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10916	97.7	'BUCKNER7 345.00 - HOLCOMB 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03245	96	'MINGO - RED WILLOW 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05912	96	'MINGO - RED WILLOW 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03521	95.4	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05832	95.4	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.03372	96.5	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10916	96.5	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05804	102.8819	'CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11218	102.8819	'CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05804	102.8819	'CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 2'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11218	102.8819	'CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 2'
CONT-040	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.04936	105.8971	'JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
CONT-040	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10524	105.8971	'JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05365	98	'EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10859	98	'EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05134	97.2	'RENO COUNTY - WICHITA 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10051	97.2	'RENO COUNTY - WICHITA 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05334	101.688	'IATAN - STRANGER CREEK 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10906	101.688	'IATAN - STRANGER CREEK 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05241	97.7	'SWISSVALE - WEST GARDNER 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10779	97.7	'SWISSVALE - WEST GARDNER 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03176	96.2	'BENTON - WICHITA 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05924	96.2	'BENTON - WICHITA 345KV CKT 1'
CONT-LaC	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05765	95.3	'LACYGNE - NEOSHO 345KV CKT 1'
CONT-LaC	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05336	99.3	'LACYGNE - NEOSHO 345KV CKT 1'
CONT-LaC	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10885	99.3	'LACYGNE - NEOSHO 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03331	96	'VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05895	96	'VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03392	99.8	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06174	99.8	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.0589	104.4816	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11194	104.4816	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03392	99.8	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06174	99.8	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.0589	104.4816	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11194	104.4816	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05359	99.3	'AUBURN ROAD - JEFFREY ENERGY CENTER 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10916	99.3	'AUBURN ROAD - JEFFREY ENERGY CENTER 230KV CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045		'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	102.5	'LAWRENCE ENERGY CENTER UNIT 5 - LAWRENCE HILL 230KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONT	COMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
ISLAND-GE	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	102.5	'LAWRENCE ENERGY CENTER UNIT 5 - LAWRENCE HILL 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.0564	101.5129	'CIRCLE - EAST MCPHERSON 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11187	101.5129	'CIRCLE - EAST MCPHERSON 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.06563	111.4541	'CIRCLE - MULLERGREN 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.12592	111.4541	'CIRCLE - MULLERGREN 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05623	97.6	'EAST MCPHERSON - SUMMIT 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11114	97.6	'EAST MCPHERSON - SUMMIT 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05027	98.8	'SUMMIT - UNIONRG6 230.00 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.1049	98.8	'SUMMIT - UNIONRG6 230.00 230KV CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	102.6	'MRWYP16 - MRWYP26 230KV CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	102.6	'MRWYP16 - MRWYP26 230KV CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	95.7	'ELM CREEK - MRWYP16 230KV CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	105	'ELM CREEK - MRWYP16 230KV CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	105	'ELM CREEK - MRWYP16 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05523	98	'CONCORDIA - ELM CREEK 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11645	98	'CONCORDIA - ELM CREEK 230KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05537	101.8098	'PHILLIPSBURG - SMITH CENTER 115KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.12508	101.8098	'PHILLIPSBURG - SMITH CENTER 115KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05457	101.5781	'SEWARD - ST JOHN 115KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11147	101.5781	'SEWARD - ST JOHN 115KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.06282	105.7454	'CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11532	105.7454	'CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.06282	105.7454	'CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11532	105.7454	'CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05426	102.1495	'COOPER - ST JOE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11032	102.1495	'COOPER - ST JOE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05387	98.9	'EASTOWN7 345.00 - IATAN 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10972	98.9	'EASTOWN7 345.00 - IATAN 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05738	104.8798	'AXTELL - PAULINE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11434	104.8798	'AXTELL - PAULINE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05412	98.9	'AXTELL - SWEETWATER 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11082	98.9	'AXTELL - SWEETWATER 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05478	101.6043	'MCCOOL - MOORE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.1107	101.6043	'MCCOOL - MOORE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05479	102.0795	'GRAND ISLAND - MCCOOL 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11069	102.0795	'GRAND ISLAND - MCCOOL 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05687	104.1056	'MOORE - PAULINE 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->T'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11357	104.1056	'MOORE - PAULINE 345KV CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	95.3	'4OSAGEWIND 138.00 - 4REMINGTON 138.00 138KV CKT 1'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0311	108.8092	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_020		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03674	108.8092	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	ASGI_2010_021		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03675	108.8092	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	ASGI_2011_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03673	108.8092	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06181	108.8092	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05568	102.2543	'WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03366	120.1836	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06536	120.1836	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	95.7	'SOONER 138/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	99.5	'OKLA WIND ENERGY CENTER (FPLWIND) 138/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	104.5	'MOORELAND 138/18.0KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0327	96.7	'POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06151	96.7	'POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	99.2	'TOLK STATION EAST 230/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	99.2	'TOLK STATION EAST 230/24.0KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05242	101.9189	'POST ROCK (POSTROCK T1) 345/230/13.8KV TRANSFORMER CKT 2'
	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11669	101.9189	'POST ROCK (POSTROCK T1) 345/230/13.8KV TRANSFORMER CKT 2'
	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05242	101.9189	'POST ROCK (POSTROCK T1) 345/230/13.8KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11669	101.9189	'POST ROCK (POSTROCK T1) 345/230/13.8KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05337	101.6243	'MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11758	101.6243	'MINGO (MINGO) 345/115/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	102.9	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	102.9	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	102.9	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	102.9	'JEFFREY ENERGY CENTER 345/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	102.6	'JEFFREY ENERGY CENTER 230/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	102.6	'JEFFREY ENERGY CENTER 230/26.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	102.5	'LAWRENCE ENERGY CENTER UNIT 5 230/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	102.5	'LAWRENCE ENERGY CENTER UNIT 5 230/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	99.4	'EVANS ENERGY CENTER NORTH 138/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	99.4	'EVANS ENERGY CENTER NORTH 138/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	102.6	'MRWYP26 (MERDWYP2) 230/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	102.6	'MRWYP26 (MERDWYP2) 230/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	102.6	'MRWYP16 (MERIDWY1) 230/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	102.6	'MRWYP16 (MERIDWY1) 230/34.5/13.8KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05523	98	'CONCORDIA (CONCORD6) 230/115/13.8KV TRANSFORMER CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11645	98	'CONCORDIA (CONCORD6) 230/115/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	98.8	'JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	98.8	'JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	101.5	'SIBLEYPL 161.00 161/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	101.5	'SIBLEYPL 161.00 161/22.0KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05396	101.5243	'COOPER - FAIRPORT 345KV CKT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10983	101.5243	'COOPER - FAIRPORT 345KV CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	97.6	'GERALD GENTLEMAN STATION 345/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	97.6	'GERALD GENTLEMAN STATION 345/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	97.5	'GERALD GENTLEMAN STATION 230/23.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	97.5	'GERALD GENTLEMAN STATION 230/23.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	98.2	'SUB 3458 NEB CTY 345/18.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	98.2	'SUB 3458 NEB CTY 345/18.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	95.3	'4OSAGEWIND 138.00 138/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	98.6	'RAUN 345/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	98.6	'RAUN 345/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	101.8	'LOUISA 345/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	101.8	'LOUISA 345/24.0KV TRANSFORMER CKT 1'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.048	121.7948	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03042	121.7948	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03647	121.7948	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03648	121.7948	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03647	121.7948	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.07537	121.7948	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.07651	119.0783	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.12081	119.0783	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_001	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.04004	119.0783	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.03907	100.7522	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.03619	100.7522	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_045	'FROM->TC'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03907	133.5134	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_001	'FROM->TC'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03619	133.5134	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_045	'FROM->TC'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.03907	122.4611	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_001	'FROM->TC'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.03619	122.4611	'DBL-WICH-THI'
	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05394	101.3519	'SPP-2006-001'
	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10981	101.3519	'SPP-2006-001'
	FDNS	04ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03061	99.1	'SPP-AEPW-32'
	FDNS	04ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04081	99.1	'SPP-AEPW-32'
	FDNS	04ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0408	99.1	'SPP-AEPW-32'
	FDNS	04ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04082	99.1	'SPP-AEPW-32'
	FDNS	04ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06103	99.1	'SPP-AEPW-32'
	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05334	101.7266	'KCPL-OPGD#07'
	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10906	101.7266	'KCPL-OPGD#07'
	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05395	101.3791	'KCPL-OL166-1'
	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10981	101.3791	'KCPL-OL166-1'
	FDNS	04ALL		0	13G	G10_045	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05394	101.3519	'LN-FAIRPORT'
	FDNS	04ALL		0	13G	G10_048	'FROM->TC'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10981	101.3519	'LN-FAIRPORT'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONT	COMMONNAME	RATEB	TDF	TC%LOAD	CONTNAME	
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05394	96.1	'OGE3TERM1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	100.4155	'NC1_GEN-NEBRASKA CITY 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	100.4155	'NC1_GEN-NEBRASKA CITY 1'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03071		'SPP-SWPS-01'
	FDNS	04ALL		0	13G	ASGI_2010_020		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04009		'SPP-SWPS-01'
	FDNS	04ALL		0	13G	ASGI_2010_021		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04008		'SPP-SWPS-01'
	FDNS	04ALL		0	13G	ASGI_2011_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.0401		'SPP-SWPS-01'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06112		'SPP-SWPS-01'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.0311	108.8176	'SPP-SWPS-02A'
	FDNS	04ALL		0	13G	ASGI_2010_020		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03674	108.8176	'SPP-SWPS-02A'
	FDNS	04ALL		0	13G	ASGI_2010_021		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03675	108.8176	'SPP-SWPS-02A'
	FDNS	04ALL		0	13G	ASGI_2011_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03673	108.8176	'SPP-SWPS-02A'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06181	108.8176	'SPP-SWPS-02A'
	FDNS	04ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03112	106.884	'SPP-SWPS-03'
	FDNS	04ALL		0	13G	ASGI_2010_020		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03693	106.884	'SPP-SWPS-03'
	FDNS	04ALL		0	13G	ASGI_2010_021		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03694	106.884	'SPP-SWPS-03'
	FDNS	04ALL		0	13G	ASGI_2011_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03692	106.884	'SPP-SWPS-03'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.06187	106.884	'SPP-SWPS-03'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.06808	107.0721	'SPP-SWPS-05'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.11874	107.0721	'SPP-SWPS-05'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05457	101.5728	'SPP-MKEC-06'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.11147	101.5728	'SPP-MKEC-06'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05254	99.4	'WR-DOUBLE17'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10826	99.4	'WR-DOUBLE17'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05392	102.1546	'NEB01WAPAB3'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10963	102.1546	'NEB01WAPAB3'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.3	'GEN335831 1-RIVERBEND UNIT#1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.9	'GEN336153 1-WATERFORD UNIT#3'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	101.4616	'GEN336153 1-WATERFORD UNIT#3'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	101.4616	'GEN336153 1-WATERFORD UNIT#3'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.6	'GEN501801 1-DOLET HILLS UNIT1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.7	'GEN509403 1-PIRKEY GENERATION'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.3	'GEN509404 1-WELSH #1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.3	'GEN509405 1-WELSH #2'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.3	'GEN509406 1-WELSH #3'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.8	'GEN509416 1-TURK GENERATION'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.3	'GEN512688 2-GRDA1 GSU2 22'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	99.4	'GEN514805 1-SOONER UNIT 1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	97.1	'GEN514806 1-SOONER UNIT 2'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	101.3592	'GEN514806 1-SOONER UNIT 2'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	101.3592	'GEN514806 1-SOONER UNIT 2'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.4	'GEN515223 1-MUSKOGEE 4G'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.4	'GEN515225 1-MUSKOGEE 5G'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.8	'GEN515226 1-MUSKOGEE 6G'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	98.7	'GEN515787 1-OKLA WIND ENERGY CENTER'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	97.5	'GEN520922 1-SLEEPING BEAR'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.9	'GEN520947 1-HUGO1'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	105.3023	'GEN520997 1-MORLND2'
	FDNS	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05764	95.2	'GEN521207 1-RHWIND1WG11 0.6900'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	99.2	'GEN523971 1-HARRINGTON GEN #1 24 KV'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	99.2	'GEN523971 1-HARRINGTON GEN #1 24 KV'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	99.2	'GEN523972 1-HARRINGTON GEN #2 24 KV'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	99.2	'GEN523972 1-HARRINGTON GEN #2 24 KV'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	99.2	'GEN523973 1-HARRINGTON GEN #3 24 KV'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	99.2	'GEN523973 1-HARRINGTON GEN #3 24 KV'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	99.4	'GEN525561 1-TOLK GEN #1 24 KV'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	99.4	'GEN525561 1-TOLK GEN #1 24 KV'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	98.8	'GEN525562 1-TOLK GEN #2 24 KV'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	98.8	'GEN525562 1-TOLK GEN #2 24 KV'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONT	COMMONNAME	RATEB	TDF	TC%LOAD	CONTNAME	
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	98.8	'GEN525562 1-TOLK GEN #2 24 KV'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	95.7	'GEN531447 1-HOLCOMB GENERATOR'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	95.7	'GEN531447 1-HOLCOMB GENERATOR'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	99.1	'GEN531495 1-CNTRLPLWG1 0.6900'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	99.1	'GEN531495 1-CNTRLPLWG1 0.6900'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	107.4943	'GEN532651 1-JEFFREY ENERGY CENTER UNIT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	107.4943	'GEN532651 1-JEFFREY ENERGY CENTER UNIT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	107.7619	'GEN532652 1-JEFFREY ENERGY CENTER UNIT 2'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	107.7619	'GEN532652 1-JEFFREY ENERGY CENTER UNIT 2'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	107.7611	'GEN532653 1-JEFFREY ENERGY CENTER UNIT 3'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	107.7611	'GEN532653 1-JEFFREY ENERGY CENTER UNIT 3'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	102.7021	'GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	102.7021	'GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	101.8657	'GEN532722 1-EVANS ENERGY CENTER UNIT 2'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	101.8657	'GEN532722 1-EVANS ENERGY CENTER UNIT 2'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	105.9923	'GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	105.9923	'GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	98.9	'GEN539670 4-JUDSON LARGE GENERATOR'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	98.9	'GEN539670 4-JUDSON LARGE GENERATOR'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	99.4	'GEN539767 1-GRAY COUNTY WIND FARM'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	99.4	'GEN539767 1-GRAY COUNTY WIND FARM'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	101.7829	'GEN541151 3-SIBLEY GENERATING UNIT #3'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	101.7829	'GEN541151 3-SIBLEY GENERATING UNIT #3'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	102.2047	'GEN542951 5-HAWTHORN UNIT #5'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	102.2047	'GEN542951 5-HAWTHORN UNIT #5'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	102.9266	'GEN542955 1-LACYGNE UNIT #1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	102.9266	'GEN542955 1-LACYGNE UNIT #1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	102.9225	'GEN542956 2-LACYGNE UNIT #2'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	102.9225	'GEN542956 2-LACYGNE UNIT #2'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	102.7196	'GEN542957 1-IATAN UNIT #1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	102.7196	'GEN542957 1-IATAN UNIT #1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	103.4256	'GEN542962 2-IATAN UNIT #2'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	103.4256	'GEN542962 2-IATAN UNIT #2'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	101.5288	'GEN546702 1-NM GEN N1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	101.5288	'GEN546702 1-NM GEN N1'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	96.2	'GEN560173 1-G08-17 0.5750'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	96.2	'GEN560173 1-G08-17 0.5750'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	99.3	'GEN560279 1-G08-18 0.6900'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	99.3	'GEN560279 1-G08-18 0.6900'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	98.8	'GEN560293 1-G08-25 0.7500'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	98.8	'GEN560293 1-G08-25 0.7500'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	98.1	'GEN560339 1-G10-48 0.6900'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	98.1	'GEN560339 1-G10-48 0.6900'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	98.8	'GEN560573 1-G06-40 0.6900'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	98.8	'GEN560573 1-G06-40 0.6900'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	98.5	'GEN560606 1-G07-11 0.5750'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	98.5	'GEN560606 1-G07-11 0.5750'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	99	'GEN640009 1-COOPER NUCLEAR STATION'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	99	'GEN640009 1-COOPER NUCLEAR STATION'
	FDNS	04ALL		0	13G	G10_045	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.05362	95.7	'GEN640010 1-GERALD GENTLEMAN STATION UNIT 1'
	FDNS	04ALL		0	13G	G10_048	'FROM->T'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'		319	0.10928	95.7	'GEN640010 1-GERALD GENTLEMAN STATION UNIT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONT	COMMONNAME	RATEB	TDF	TC%LOAD	CONTNAME
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	95.8	'GEN640011 2-GERALD GENTLEMAN STATION UNIT 2'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	95.8	'GEN640011 2-GERALD GENTLEMAN STATION UNIT 2'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	99	'GEN641089 2-ENERGY CENTER 2'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	99	'GEN641089 2-ENERGY CENTER 2'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	98.7	'GEN645001 1-FORT CALHOUN 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	98.7	'GEN645001 1-FORT CALHOUN 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	98.6	'GEN645011 1-NEBRASKA CITY 1'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	98.6	'GEN645011 1-NEBRASKA CITY 1'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	98.4	'GEN645012 2-NEBRASKA CITY 2'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	98.4	'GEN645012 2-NEBRASKA CITY 2'
	FDNS	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	98.8	'GEN659111 2-LELAND OLDS UNIT2'
	FDNS	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	98.8	'GEN659111 2-LELAND OLDS UNIT2'
	FNSL	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05599	104.8628	'GRAND ISLAND - SWEETWATER 345KV CKT 1'
	FNSL	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.11217	104.8628	'GRAND ISLAND - SWEETWATER 345KV CKT 1'
	FNSL	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05394	101.415	'NUNDRWD - WAYSIDE 230KV CKT 1'
	FNSL	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10965	101.415	'NUNDRWD - WAYSIDE 230KV CKT 1'
	FNSL	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05392	102.149	'STEGALL - STEGALL TY 345KV CKT 1'
	FNSL	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10963	102.149	'STEGALL - STEGALL TY 345KV CKT 1'
	FNSL	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05392	102.1514	'TRF-STEGALL'
	FNSL	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10963	102.1514	'TRF-STEGALL'
	FNSL-CHEC	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	96.1	'GEN336821 1-GRAND GULF UNIT'
	FNSL-CHEC	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	101.6	'GEN336821 1-GRAND GULF UNIT'
	FNSL-CHEC	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	101.6	'GEN336821 1-GRAND GULF UNIT'
	FNSL	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	95.6	'GEN337910 1-ARKANSAS NUCLEAR ONE UNIT #1'
	FNSL	04ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05764	96	'GEN337911 1-ARKANSAS NUCLEAR ONE UNIT #2'
	FNSL	04ALL		0	13G	G10_045		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.05362	101.5103	'GEN337911 1-ARKANSAS NUCLEAR ONE UNIT #2'
	FNSL	04ALL		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.10928	101.5103	'GEN337911 1-ARKANSAS NUCLEAR ONE UNIT #2'
NCONV	FNSL-Blow	04ALL		0	13G	G10_048		Non-Converged Contingency	319	0.07054	37.78442	'ELM CREEK - NORTHWEST MANHATTAN 230KV CKT 1'
NCONV	FNSL-Itera	04ALL		0	13G	G10_041		Non-Converged Contingency	0	0.05189	9999	'DBL-THIS-CLR'
NCONV	FNSL-Itera	04ALL		0	13G	G10_051		Non-Converged Contingency	0	0.07675	9999	'DBL-THIS-CLR'
NCONV	FNSL-Itera	04ALL		0	13G	G10_045		Non-Converged Contingency	0	0.36587	9999	'DBL-THIS-CLR'
NCONV	FNSL-Itera	04ALL		0	13G	G10_048		Non-Converged Contingency	0	0.24011	9999	'DBL-THIS-CLR'
NCONV	FNSL-Itera	04ALL		0	13G	G10_041		Non-Converged Contingency	0	0.05189	9999	'DBL-SPRVL-CL'
NCONV	FNSL-Itera	04ALL		0	13G	G10_051		Non-Converged Contingency	0	0.07675	9999	'DBL-SPRVL-CL'
NCONV	FNSL-Itera	04ALL		0	13G	G10_045		Non-Converged Contingency	0	0.36587	9999	'DBL-SPRVL-CL'
NCONV	FNSL-Itera	04ALL		0	13G	G10_048		Non-Converged Contingency	0	0.24011	9999	'DBL-SPRVL-CL'
ISLAND-GE	FDNS	04NR		0	13G	G10_048		'FROM->TO'JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.09569	98	'G07-11 115.00 - SYRACUSE 115KV CKT 1'
ISLAND-GE	FDNS	04NR		0	13G	G10_048		'FROM->TO'JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.09569	174.1	'G08-17 345.00 - SETAB 345KV CKT 1'
ISLAND-GE	FDNS	04NR		0	13G	G10_048		'FROM->TO'JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.09569	129.3	'ELM CREEK - MRWYP16 230KV CKT 1'
ISLAND-GE	FDNS	04NR		0	13G	G10_048		'FROM->TO'JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.09569	237.1	'HOLCOMB 115/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04NR		0	13G	G10_048		'FROM->TO'JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.09569	173.9	'G08-17 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	04NR		0	13G	G10_048		'FROM->TO'JUDSON LARGE 115/15.0KV TRANSFORMER CKT 1'	187	0.09569	98	'G07-11 115.00 115/34.5KV TRANSFORMER CKT 1'
	FDNS	04NR		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.04962	104.243	'DBL-THIS-CLR'
	FDNS	04NR		0	13G	G10_048		'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.04962	104.097	'DBL-SPRVL-CL'
	FDNS	06ALL		0	13G	G10_045		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0446	106.3839	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ALL		0	13G	ASGI_2011_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04057	106.3839	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ALL		0	13G	ASGI_2010_020		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04058	106.3839	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ALL		0	13G	ASGI_2010_021		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04058	106.3839	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ALL		0	13G	G10_048		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03183	106.3839	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ALL		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.08563	106.3839	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	06ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03429	97.9	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	06ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06599	97.9	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	06ALL		0	13G	G10_045	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03983	102.3257	'DBL-WICH-THI'
	FDNS	06ALL		0	13G	G10_001	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03694	102.3257	'DBL-WICH-THI'
NCONV	FNSL-Itera	06ALL		0	13G	G10_045	Non-Converged Contingency	0	0.04232	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	06ALL		0	13G	G10_048	Non-Converged Contingency	0	0.04851	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	06ALL		0	13G	G10_048	Non-Converged Contingency	0	0.03234	9999	'NEB01WAPAB3'
	FDNS	07ALL		0	13G	G10_045	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03921	113.5726	'DBL-WICH-THI'
	FDNS	07ALL		0	13G	G10_001	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03632	113.5726	'DBL-WICH-THI'
	FDNS	07ALL		0	13G	G10_045	'FROM->TO'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.03921	102.4085	'DBL-WICH-THI'
	FDNS	07ALL		0	13G	G10_001	'FROM->TO'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.03632	102.4085	'DBL-WICH-THI'
NCONV	FNSL-Itera	07ALL		0	13G	G10_045	Non-Converged Contingency	0	0.04219	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	07ALL		0	13G	G10_048	Non-Converged Contingency	0	0.04837	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	07ALL		0	13G	G10_048	Non-Converged Contingency	0	0.03225	9999	'NEB01WAPAB3'
	FDNS	09ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03561	97.5	'DEWEY - IODINE 138KV CKT 1'
	FDNS	09ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06909	97.5	'DEWEY - IODINE 138KV CKT 1'
	FDNS	09ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03561	98.5	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	09ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06909	98.5	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	09ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04356	114.5185	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	09ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0308	114.5185	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	09ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03954	114.5185	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	09ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03954	114.5185	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	09ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03954	114.5185	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	09ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0846	114.5185	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	09ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04356	97.8	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	09ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0308	97.8	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	09ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03954	97.8	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	09ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03954	97.8	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	09ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03954	97.8	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	09ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0846	97.8	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	09ALL		0	13G	G10_051	'FROM->TO'G10-51T 230.00 - HOSKINS 230KV CKT 1'	225	1	95.7	'G10-51T 230.00 - TWIN CHURCH 230KV CKT 1'
	FDNS	09ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03356	105.0296	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	09ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06526	105.0296	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	09ALL		0	13G	G10_041	'FROM->TO'MOORE (MOORE T1) 345/115/13.8KV TRANSFORMER CKT 1'	336	0.06616	96.5	'GERALD GENTLEMAN STATION 230/23.0KV TRANSFORMER CKT 1'
	FDNS	09ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04796	99	'DBL-WICH-THI'
	FDNS	09ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03038	99	'DBL-WICH-THI'
	FDNS	09ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03644	99	'DBL-WICH-THI'
	FDNS	09ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03644	99	'DBL-WICH-THI'
	FDNS	09ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03644	99	'DBL-WICH-THI'
	FDNS	09ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.07533	99	'DBL-WICH-THI'
	FDNS	09ALL		0	13G	G10_045	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03917	102.6573	'DBL-WICH-THI'
	FDNS	09ALL		0	13G	G10_001	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03628	102.6573	'DBL-WICH-THI'
NCONV	FNSL-Itera	09ALL		0	13G	G10_045	Non-Converged Contingency	0	0.042	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	09ALL		0	13G	G10_048	Non-Converged Contingency	0	0.04818	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	09ALL		0	13G	G10_048	Non-Converged Contingency	0	0.03212	9999	'NEB01WAPAB3'
	FDNS	13ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04376	103.7035	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	13ALL		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03099	103.7035	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	13ALL		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03974	103.7035	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	13ALL		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03974	103.7035	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	13ALL		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03973	103.7035	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	13ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.08479	103.7035	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	13ALL		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03371	96.4	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	13ALL		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06541	96.4	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	13ALL		0	13G	G10_045	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03928	96.1	'DBL-WICH-THI'
	FDNS	13ALL		0	13G	G10_001	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03639	96.1	'DBL-WICH-THI'
NCONV	FNSL-Itera	13ALL		0	13G	G10_045	Non-Converged Contingency	0	0.04199	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	13ALL		0	13G	G10_048	Non-Converged Contingency	0	0.04818	9999	'TRF-STEGALL'
NCONV	FNSL-Itera	13ALL		0	13G	G10_048	Non-Converged Contingency	0	0.03212	9999	'NEB01WAPAB3'
	FDNS	00G10_001		0	23SP	G10_001	'FROM->TO'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFO	250	0.03295	107.0083	'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1'
	FDNS	00G10_001		0	23SP	G10_001	'FROM->TO'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFO	250	0.03295	111.3232	'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1'
	FDNS	00G10_001		0	23SP	G10_001	'FROM->TO'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFO	250	0.03295	107.2008	'OCHILTREE (H TP80219401) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS	00G10_001		0	23SP	G10_001	'FROM->TO'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFO	250	0.03295	111.602	'OCHILTREE (H TP80219401) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS	00G10_001		0	23SP	G10_001	'FROM->TO'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFO	250	0.03539	102.1513	'SPP-SWPS-K31'
	FDNS	00G10_046		0	23SP	G10_046	'FROM->TO'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2'	351	0.03782	104.9528	'JONES STATION - LUBBOCK SOUTH INTERCHANGE 230KV CKT 1'
	FDNS	00G10_051		0	23SP	G10_051	'FROM->TO'G10-51T 230.00 - TWIN CHURCH 230KV CKT 1'	192	1	104.5287	'G10-51T 230.00 - HOSKINS 230KV CKT 1'
	FDNS	00G10_051		0	23SP	G10_051	'FROM->TO'G10-51T 230.00 - HOSKINS 230KV CKT 1'	192	1	104.2096	'G10-51T 230.00 - TWIN CHURCH 230KV CKT 1'
	FDNS		0	0	23SP	G10_001	'FROM->TO'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFO	250	0.03283	103.5208	'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1'
	FDNS		0	0	23SP	G10_001	'FROM->TO'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFO	250	0.03283	107.8233	'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1'
	FDNS		0	0	23SP	G10_046	'FROM->TO'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2'	351	0.03782	104.9441	'JONES STATION - LUBBOCK SOUTH INTERCHANGE 230KV CKT 1'
	FDNS		0	0	23SP	G10_001	'FROM->TO'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFO	250	0.03283	103.7336	'OCHILTREE (H TP80219401) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS		0	0	23SP	G10_001	'FROM->TO'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFO	250	0.03283	108.1067	'OCHILTREE (H TP80219401) 230/115/13.2KV TRANSFORMER CKT 1'
GSU	FDNS		0	0	23SP	ASGI_2011_001	'FROM->TO'LEA COUNTY REC-LOVINGTON INTERCHANGE 115/69KV TRANSFORME	100	0.09739	121.5902	'SPP-SWPS-V98'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	136.2721	'BASE CASE'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.057	116.2822	'LYDIA - VALLIANT 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05759	116.1932	'DELAWARE - NORTHEAST STATION 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05595	112.8732	'CLINTON AIR FORCE BASE TAP - ELK CITY 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05595	113.0994	'CLINTON AIR FORCE BASE TAP - HOBART JUNCTION 138KV CKT 1'
INVALID	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0607	140.2276	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0607	129.1929	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05579	112.0534	'CLINTON JUNCTION - ELK CITY 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05433	111.8345	'ELK CITY - RED HILLS WIND 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05703	116.3802	'WEATHERFORD JCT. - WEATHERFORD SOUTHEAST 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06147	144.3979	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06147	118.4585	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05879	123.8152	'HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0559	115.8463	'KNOBHILL - SALINE 69KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0559	116.2181	'HELENA TAP - SALINE 69KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04954	100.2097	'CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04788	103.0337	'CLEO CORNER - MEN TAP 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06516	136.4052	'WOODWARD - WOODWARD 69KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	114.4	'CENT 4 138.00 - WOODWARD 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0516	106.5246	'WOODWARD - WOODWARD EHV 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05619	115.9148	'WOODWARD - WOODWARD EHV 138KV CKT 2'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06898	144.8504	'DEWEY - IODINE 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05432	110.1617	'DEWEY - SOUTHARD 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05885	123.3016	'DEWEY - TALOGA 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.04788	103.9437	'IMO TAP - MEN TAP 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05719	116.0967	'ALVA - KNOBHILL 69KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05536	109.5718	'KNOBHILL - MOORELAND 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06898	145.8373	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05432	111.854	'EL RENO - ROMAN NOSE 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05432	111.2063	'ROMAN NOSE - SOUTHARD 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05838	122.1462	'CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0844	174.9274	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'FROM->TO'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0844	100.3696	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0844	158.6986	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06188	121.1109	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05481	109.834	'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06505	128.8699	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06505	128.8699	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	109.9	'G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03696	103.057	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	115.7	'KEENAN4 - WOODWARD EHV 138KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	114.1	'G08-29 138.00 - WOODWARD EHV 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06188	121.3013	'BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05879	122.2423	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	124.6	'FPL SWITCH - OKLA WIND ENERGY CENTER 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05115	101.1808	'CEDARDALE - MOORELAND 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05115	101.9021	'CEDARDALE - OKEENE 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05285	109.3075	'DOVER SW - OKEENE 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05734	120.4297	'FAIRVIEW - OKEENE 69KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	122.5	'FT SUPPLY - SLEEPING BEAR 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05614	113.1002	'MOORELAND - TALOGA 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05077	109.9649	'MOORELAND - NINE MILE 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05433	116.1091	'MOREWOOD SW - RED HILLS WIND 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05077	110.3268	'MOREWOOD SW - NINE MILE 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0566	116.4464	'OKEENE - WATONGA SW 69KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05897	121.2232	'FARGO JCT - WOODWARD 69KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05969	120.482	'CARTER JCT - WOODWARD 69KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06297	126.4407	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	114.3	'G10-14 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.07266	115.2138	'BEAVER CO 345.00 - Hitchland Interchange 345KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONT	COMMONNAME	RATEB	TDF	TC%LOAD	CONTNAME
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06147	141.4103	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05961	134.3821	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
ISLAND-LO	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	115.9599	'Graves Sub - STATELINE INTERCHANGE 115KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06297	128.4814	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05855	121.3853	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05878	121.0144	'MINGO - SETAB 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05814	121.5219	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05906	121.2353	'BENTON - WICHITA 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06153	127.0745	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06153	127.0745	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	112.4	'BEAVER CO 345.00 - G08-47 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.4	'G07-62 345.00 - G07-62-1 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.4	'G07-62 345.00 - G07-62-2 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.3	'G07-62 345.00 - G07-62-3 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.3	'G07-62 345.00 - G07-62-4 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	114.3	'G10-14 345.00 345/115KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	111.8	'BEAVER CO 345.00 - G10-01 345.00 345KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.3	'G06-44 115.00 - G06-44-3 115.00 115KV CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	120.5	'40SAGEWIND 138.00 - 4REMINGTON 138.00 138KV CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06147	144.3927	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05552	125.0226	'WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06516	149.1703	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05536	110.066	'KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	120.9	'SOONER 138/22.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	114.1	'CENT 4 138.00 (CENTENNIAL) 138/34.5/9.96KV TRANSFORMER CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05284	111.6056	'WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05285	110.9782	'WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	115.6	'KEENAN4 (KEENAN1) 138/34.5/9.96KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	124.9	'OKLA WIND ENERGY CENTER (FPLWIND) 138/34.5/13.8KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	127.6	'MOORELAND 138/18.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	115.7	'Hitchland Interchange (PRO G2218-01) 345/115/13.8KV TRANSFORMER CKT 1'
ISLAND-LO	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	115.9571	'STATELINE INTERCHANGE (H TP80154301) 230/115/13.2KV TRANSFORMER CKT 1'
	FDNS	02G10_001		0	13G	G10_001		'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06143	120.8514	'POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	112	'TOLK STATION EAST 230/24.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	112.4	'G08-47 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.4	'G07-62-1 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.4	'G07-62-2 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.3	'G07-62-3 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.3	'G07-62-4 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.3	'G10-14 115.00 115/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	111.8	'G10-01 345.00 345/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	114.1	'G08-29 138.00 138/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.3	'G06-44-3 115.00 115/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	115.2	'SUB 3458 NEB CTY 345/18.0KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	120.5	'40SAGEWIND 138.00 138/34.5KV TRANSFORMER CKT 1'
ISLAND-GE	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.3	'RAUN 345/22.0KV TRANSFORMER CKT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.07507	157.0262	'DBL-WICH-THI'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.03594	119.9065	'DBL-WICH-THI'
	FDNS	02G10_001		0	13G	G10_001	'FROM->TO'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.03594	160.5873	'DBL-WICH-THI'
	FDNS	02G10_001		0	13G	G10_001	'FROM->TO'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.03594	144.5647	'DBL-WICH-THI'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.08716	159.1515	'DBL-THIS-WWR'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05765	116.7907	'DBL-SPRVL-CL'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.057	116.2757	'SPP-AEPW-01'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0607	131.7355	'SPP-AEPW-32'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	118.4588	'NC1_GEN-NEBRASKA CITY 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06079	128.9789	'SPP-SWPS-01'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06147	144.3979	'SPP-SWPS-02A'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06153	142.5196	'SPP-SWPS-03'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.06297	126.4858	'SPP-SWPS-05'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	120.578	'GEN509403 1-PIRKEY GENERATION'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	120.6639	'GEN509416 1-TURK GENERATION'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	124.2432	'GEN514805 1-SOONER UNIT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	121.9781	'GEN514806 1-SOONER UNIT 2'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	120.6915	'GEN515226 1-MUSKOGEE 6G'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	115.9679	'GEN515365 1-CENT 21 34.500'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	116.1398	'GEN515393 1-OGEWIND2G'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	124.0515	'GEN515787 1-OKLA WIND ENERGY CENTER'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	122.8058	'GEN520922 1-SLEEPING BEAR'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	120.8425	'GEN520947 1-HUGO1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	128.3866	'GEN520997 1-MORLND2'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	112.2059	'GEN523103 1-NOBLE_WND 3115.00'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	113.3245	'GEN523971 1-HARRINGTON GEN #1 24 KV'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	113.3211	'GEN523972 1-HARRINGTON GEN #2 24 KV'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	113.3269	'GEN523973 1-HARRINGTON GEN #3 24 KV'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	115.455	'GEN525494 1-PLANT X GEN #4 20 KV'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	112.0241	'GEN525561 1-TOLK GEN #1 24 KV'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	109.643	'GEN525562 1-TOLK GEN #2 24 KV'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	114.3748	'GEN526331 1-JONES GEN #1 22 KV'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.05747	114.3733	'GEN526332 1-JONES GEN #2 21 KV'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME	
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.8738	'GEN527161 1-MUSTANG GEN #1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.8738	'GEN527162 1-MUSTANG GEN #2'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.3129	'GEN527882 1-CUNNINGHAM GEN #2 20 KV'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.8083	'GEN527901 1-HOBBS PLANT #1 (CT)'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.8267	'GEN527902 1-HOBBS PLANT #2 (CT)'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	114.5396	'GEN527903 1-HOBBS PLANT #3 (ST)'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	111.4949	'GEN531447 1-HOLCOMB GENERATOR'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	114.8008	'GEN532651 1-JEFFREY ENERGY CENTER UNIT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	114.8012	'GEN532652 1-JEFFREY ENERGY CENTER UNIT 2'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	114.8009	'GEN532653 1-JEFFREY ENERGY CENTER UNIT 3'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	114.2774	'GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.9569	'GEN542957 1-IATAN UNIT #1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.1898	'GEN542962 2-IATAN UNIT #2'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	106.8646	'GEN560121 1-G08-47 0.5750'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	113.8125	'GEN560256 1-G10-14-1 0.6900'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	113.6891	'GEN560257 1-G10-14-2 0.6900'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	112.319	'GEN560286 1-G10-01-1WTG 0.6900'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	112.319	'GEN560287 1-G10-01-2WTG 0.6900'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	113.9841	'GEN560371 1-G07-46 0.6900'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	114.5272	'GEN560429 1-G08-29 0.6400'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.062	'GEN560585 1-G06-44-2 0.6000'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	113.6307	'GEN560586 1-G06-44-3 0.6000'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	114.4892	'GEN640009 1-COOPER NUCLEAR STATION'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	114.4275	'GEN640010 1-GERALD GENTLEMAN STATION UNIT 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	114.5258	'GEN640011 2-GERALD GENTLEMAN STATION UNIT 2'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.7736	'GEN645001 1-FORT CALHOUN 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.1881	'GEN645011 1-NEBRASKA CITY 1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	114.8496	'GEN645012 2-NEBRASKA CITY 2'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.8445	'GEN659103 1-ANTELOPE VALLEY UNIT1'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	115.8445	'GEN659107 2-ANTELOPE VALLEY UNIT2'
	FDNS	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	112.5119	'GEN659118 1-LARAMIE RIVER UNIT1'
	FNSL	02G10_001		0	13G	G10_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.05747	120.5743	'GEN337911 1-ARKANSAS NUCLEAR ONE UNIT #2'
INVALID	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03047	120.8464	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03047	110.686	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03096	122.7612	'ELK CITY 230KV - SWEETWATER 230KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03096	105.9784	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03321	114.5319	'HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03354	122.1719	'WOODWARD - WOODWARD 69KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03559	129.1279	'DEWEY - IODINE 138KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03019	110.7346	'DEWEY - TALOGA 138KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03559	130.1538	'IODINE - WOODWARD EHV 138KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03008	109.6563	'CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04352	153.3655	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.04352	136.8876	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03294	112.2127	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03294	112.4054	'BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03321	112.8973	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'		153	0.03034	108.3839	'FARGO JCT - WOODWARD 69KV CKT 1'

EVENTTYPE	SOLUTION	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONTCOMMONNAME	RATEB	TDF	TC%LOADI	CONTNAME
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03096	119.9047	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03032	116.9314	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03218	111.7541	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	355.3	0.10668	105.1709	'POST ROCK - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03107	108.7253	'AXTELL - POST ROCK 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03025	108.0864	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03207	109.5042	'MINGO - SETAB 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03233	109.3016	'MINGO - RED WILLOW 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03165	109.7169	'BENTON - WICHITA 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03321	109.493	'VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03379	116.359	'THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03379	116.359	'THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03032	108.1133	'MULLERGREN - SPEARVILLE 230KV CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03096	122.7502	'ELK CITY 230KV (ELCKTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03354	134.7375	'WOODWARD (WOODWRD2) 138/69/13.2KV TRANSFORMER CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03261	110.0835	'POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03047	113.1695	'SPP-AEPW-32'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03057	110.854	'SPP-SWPS-01'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03096	122.7612	'SPP-SWPS-02A'
	FDNS	03G10_045		0	13G	G10_045	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03098	120.8046	'SPP-SWPS-03'
NCONV	FNSL-Itera	03G10_045		0	13G	G10_045	Non-Converged Contingency	0	0.25261	9999	'DBL-WICH-THI'
NCONV	FNSL-Itera	03G10_045		0	13G	G10_045	Non-Converged Contingency	0	0.36463	9999	'DBL-THIS-CLR'
NCONV	FNSL-Itera	03G10_045		0	13G	G10_045	Non-Converged Contingency	0	0.36463	9999	'DBL-SPRVL-CL'
NCONV	FNSL-Itera	03G10_045		0	13G	G10_045	Non-Converged Contingency	0	0.2418	9999	'SPP-SWPS-05'
	FDNS	04G10_048		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03098	123.5945	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	04G10_048		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03098	106.9495	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04G10_048		0	13G	G10_048	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03049	111.4805	'DBL-WICH-THI'
	FDNS	04G10_048		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.13918	104.2711	'DBL-THIS-CLR'
	FDNS	04G10_048		0	13G	G10_048	'FROM->TO'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.13918	104.1251	'DBL-SPRVL-CL'
	FDNS	06ASGI_10_020		0	13G	ASGI_2010_020	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03959	113.5607	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ASGI_10_021		0	13G	ASGI_2010_021	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03959	113.4823	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ASGI_11_001		0	13G	ASGI_2011_001	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03959	113.5366	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06G10_046		0	13G	G10_046	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03883	115.0274	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06G10_046		0	13G	G10_046	'TO->FROM'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03608	101.0884	'DBL-WICH-THI'

I: Category “C” Contingency Analysis

See Next page

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING	
								(MVA)	TDF	(%MVA)	CONTINGENCY
NCONV	FNSL-Blown up	0	1	18SP	ASGI_201 0_020		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1922	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	23SP	ASGI_201 0_020		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1149	9999	'BASE CASE'
NCONV	FNSL-Blown up	00ASGI_10_0 20	1	18SP	ASGI_201 0_020		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1922	9999	'BASE CASE'
NCONV	FNSL-Blown up	00ASGI_10_0 20	1	23SP	ASGI_201 0_020		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1149	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	18WP	ASGI_201 0_020		'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 &HITCHLAND INTERCHANGE 0 - MOORE COUNTY INTERCHANGE 230KV CKT 1'	0	0.054	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	18SP	ASGI_201 0_021		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1952	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	23SP	ASGI_201 0_021		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1159	9999	'BASE CASE'
NCONV	FNSL-Blown up	00ASGI_10_0 21	1	18SP	ASGI_201 0_021		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1952	9999	'BASE CASE'
NCONV	FNSL-Blown up	00ASGI_10_0 21	1	23SP	ASGI_201 0_021		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1159	9999	'BASE CASE'
NCONV	FNSL-Blown up	00ASGI_10_0 21	1	13WP	ASGI_201 0_021		'HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1 &MOORE COUNTY INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1'	0	0.1379	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	18WP	ASGI_201 0_021		'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 &HITCHLAND INTERCHANGE 0 - MOORE COUNTY INTERCHANGE 230KV CKT 1'	0	0.0541	9999	'BASE CASE'
NCONV	FNSL-Blown up	00ASGI_10_0 21	1	13WP	ASGI_201 0_021		'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 &HITCHLAND INTERCHANGE 0 - MOORE COUNTY INTERCHANGE 230KV CKT 1'	0	0.057	9999	'BASE CASE'
NCONV	FNSL-Blown up	00ASGI_11_0 01	1	18WP	ASGI_201 1_001		'CHAN/TASCOS6230.00 - POTTER COUNTY INTERCHANGE 230KV CKT 1 &POTTER 0 COUNTY INTERCHANGE - S-RANDLCO 230.00 230KV CKT 1'	0	0.1282	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	18SP	ASGI_201 1_001		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1891	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	23SP	ASGI_201 1_001		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1138	9999	'BASE CASE'
NCONV	FNSL-Blown up	00ASGI_11_0 01	1	18SP	ASGI_201 1_001		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1891	9999	'BASE CASE'
NCONV	FNSL-Blown up	00ASGI_11_0 01	1	23SP	ASGI_201 1_001		'CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1 &CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	0	0.1138	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	18WP	ASGI_201 1_001		'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 &HITCHLAND INTERCHANGE 0 - MOORE COUNTY INTERCHANGE 230KV CKT 1'	0	0.054	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	13SP	G10_001		'BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 &BUFFALO 230.00 - BUSHLAND INTERCHANGE 230KV CKT 1'	0	0.0676	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	13SP	G10_001		'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 0 230KV CKT 1'	0	0.0318	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	13WP	G10_001		'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 0 230KV CKT 1'	0	0.0322	9999	'BASE CASE'
NCONV	FNSL-Blown up	00G10_001	1	13SP	G10_001		'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 0 230KV CKT 1'	0	0.0316	9999	'BASE CASE'
NCONV	FNSL-Blown up	00G10_001	1	13WP	G10_001		'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 0 230KV CKT 1'	0	0.032	9999	'BASE CASE'
NCONV	FNSL-Blown up	00G10_001	1	18WP	G10_001		'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 0 230KV CKT 1'	0	0.0321	9999	'BASE CASE'
NCONV	FNSL-Blown up	02G10_001	1	13G	G10_001		'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 0 230KV CKT 1'	0	0.0355	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	13SP	G10_036		'BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 &BUFFALO 230.00 - BUSHLAND INTERCHANGE 230KV CKT 1'	0	0.0374	9999	'BASE CASE'
NCONV	FNSL-Blown up	00G10_036	1	13SP	G10_036		'BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 &BUFFALO 230.00 - BUSHLAND INTERCHANGE 230KV CKT 1'	0	0.0374	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	13SP	G10_041		'BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 &BUFFALO 230.00 - BUSHLAND INTERCHANGE 230KV CKT 1'	0	0.0384	9999	'BASE CASE'
NCONV	FNSL-Blown up	0	1	23SP	G10_041		'KCPL-C3'	0	0.1127	9999	'BASE CASE'
NCONV	FNSL-Blown up	00G10_041	1	18SP	G10_041		'KCPL-C3'	0	0.1197	9999	'BASE CASE'
NCONV	FNSL-Blown up	00G10_041	1	23SP	G10_041		'KCPL-C3'	0	0.1127	9999	'BASE CASE'
NCONV	FNSL-Blown up	03G10_045	1	13G	G10_045		'BUCKNER7 345.00 - G07-40 345.00 345KV CKT 1 &BUCKNER7 345.00 - G10- 0 45 345.00 345KV CKT 1'	0	1	9999	'BASE CASE'
NCONV	FNSL-Blown up	03NR	1	13G	G10_045		'BUCKNER7 345.00 - G07-40 345.00 345KV CKT 1 &BUCKNER7 345.00 - G10- 0 45 345.00 345KV CKT 1'	0	1	9999	'BASE CASE'
NCONV	FNSL-Blown up	00G10_045	1	13WP	G10_045		'BUCKNER7 345.00 - HOLCOMB 345KV CKT 1 &BUCKNER7 345.00 - SPEARVILLE 0 345KV CKT 1'	0	1	9999	'BASE CASE'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
NCONV	FNSL-Blown up	00G10_045		1	18WP	G10_045	'BUCKNER7 345.00 - HOLCOMB 345KV CKT 1 &BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'	0	1	9999	'BASE CASE'	
NCONV	FNSL-Blown up	03NR		1	13G	G10_045	'BUCKNER7 345.00 - HOLCOMB 345KV CKT 1 &BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'	0	1	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	13SP	G10_045	'BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 &BUFFALO 230.00 - BUSHLAND INTERCHANGE 230KV CKT 1'	0	0.0551	9999	'BASE CASE'	
NCONV	FNSL-Blown up	03G10_045		1	13G	G10_045	'CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'	0	0.3646	9999	'BASE CASE'	
NCONV	FNSL-Blown up	03G10_045		1	13G	G10_045	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &G08-92 230.00 - KNOLL 230 230KV CKT 1'	0	0.0534	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_045		1	13SP	G10_045	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1'	0	0.0502	9999	'BASE CASE'	
NCONV	FNSL-Blown up	03G10_045		1	13G	G10_045	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMKYP2 6 230.00 - SMOKYHL6 230.00 230KV CKT 1'	0	0.0534	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	13SP	G10_045	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1006	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	13WP	G10_045	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1033	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_045		1	13SP	G10_045	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1004	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_045		1	13WP	G10_045	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1032	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_045		1	18WP	G10_045	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1009	9999	'BASE CASE'	
NCONV	FNSL-Blown up	03G10_045		1	13G	G10_045	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1067	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	13SP	G10_045	'SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.0503	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_045		1	13SP	G10_045	'SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.0502	9999	'BASE CASE'	
NCONV	FNSL-Singular jacobian or 0.0	0		1	13SP	G10_046	'CARLISLE INTERCHANGE - LUBBOCK POWER & LIGHT-MILWAUKEE 230KV CKT 1 &CARLISLE INTERCHANGE - TUCO INTERCHANGE 230KV CKT 1'	0	0.0382	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	13WP	G10_046	'CARLISLE INTERCHANGE - LUBBOCK POWER & LIGHT-MILWAUKEE 230KV CKT 1 &CARLISLE INTERCHANGE - TUCO INTERCHANGE 230KV CKT 1'	0	0.035	9999	'BASE CASE'	
NCONV	FNSL-Singular jacobian or 0.0	0		1	18SP	G10_046	'CARLISLE INTERCHANGE - LUBBOCK POWER & LIGHT-MILWAUKEE 230KV CKT 1 &CARLISLE INTERCHANGE - TUCO INTERCHANGE 230KV CKT 1'	0	0.0368	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	18WP	G10_046	'CARLISLE INTERCHANGE - LUBBOCK POWER & LIGHT-MILWAUKEE 230KV CKT 1 &CARLISLE INTERCHANGE - TUCO INTERCHANGE 230KV CKT 1'	0	0.0381	9999	'BASE CASE'	
NCONV	FNSL-Singular jacobian or 0.0	0		1	23SP	G10_046	'CARLISLE INTERCHANGE - LUBBOCK POWER & LIGHT-MILWAUKEE 230KV CKT 1 &CARLISLE INTERCHANGE - TUCO INTERCHANGE 230KV CKT 1'	0	0.0337	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_046		1	13SP	G10_046	'CARLISLE INTERCHANGE - LUBBOCK POWER & LIGHT-MILWAUKEE 230KV CKT 1 &CARLISLE INTERCHANGE - TUCO INTERCHANGE 230KV CKT 1'	0	0.0382	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_046		1	13WP	G10_046	'CARLISLE INTERCHANGE - LUBBOCK POWER & LIGHT-MILWAUKEE 230KV CKT 1 &CARLISLE INTERCHANGE - TUCO INTERCHANGE 230KV CKT 1'	0	0.035	9999	'BASE CASE'	
NCONV	FNSL-Singular jacobian or 0.0	00G10_046		1	18SP	G10_046	'CARLISLE INTERCHANGE - LUBBOCK POWER & LIGHT-MILWAUKEE 230KV CKT 1 &CARLISLE INTERCHANGE - TUCO INTERCHANGE 230KV CKT 1'	0	0.0368	9999	'BASE CASE'	
NCONV	FNSL-Singular jacobian or 0.0	00G10_046		1	18WP	G10_046	'CARLISLE INTERCHANGE - LUBBOCK POWER & LIGHT-MILWAUKEE 230KV CKT 1 &CARLISLE INTERCHANGE - TUCO INTERCHANGE 230KV CKT 1'	0	0.0381	9999	'BASE CASE'	
NCONV	FNSL-Singular jacobian or 0.0	00G10_046		1	23SP	G10_046	'CARLISLE INTERCHANGE - LUBBOCK POWER & LIGHT-MILWAUKEE 230KV CKT 1 &CARLISLE INTERCHANGE - TUCO INTERCHANGE 230KV CKT 1'	0	0.0337	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	18WP	G10_046	'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 &HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1'	0	0.0429	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	13SP	G10_048	'BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 &BUFFALO 230.00 - BUSHLAND INTERCHANGE 230KV CKT 1'	0	0.0475	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048		1	13G	G10_048	'HAYS WIND - SOUTH HAYS 230KV CKT 1 &MULLERGREN - SOUTH HAYS 230KV CKT 1'	0	0.1193	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR		1	13G	G10_048	'HAYS WIND - SOUTH HAYS 230KV CKT 1 &MULLERGREN - SOUTH HAYS 230KV CKT 1'	0	0.1216	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	18SP	G10_048	'HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 &JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1'	0	0.0478	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	23SP	G10_048	'HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 &JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1'	0	0.0473	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048		1	13WP	G10_048	'HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 &JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1'	0	0.0414	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048		1	18SP	G10_048	'HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 &JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1'	0	0.0478	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048		1	23SP	G10_048	'HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 &JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1'	0	0.0473	9999	'BASE CASE'	

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
NCONV	FNSL-Blown up	04G10_048		1	13G	G10_048	'KNOLL 230 - POSTROCK6 230.00 230KV CKT 1 &G08-92 230.00 - KNOLL 230 230KV CKT 1'	0	0.3024	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR		1	13G	G10_048	'KNOLL 230 - POSTROCK6 230.00 230KV CKT 1 &G08-92 230.00 - KNOLL 230 230KV CKT 1'	0	0.3484	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048		1	13G	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &G08-92 230.00 - KNOLL 230 230KV CKT 1'	0	0.1094	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR		1	13G	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &G08-92 230.00 - KNOLL 230 230KV CKT 1'	0	0.0587	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048		1	13SP	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1'	0	0.1013	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048		1	13WP	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1'	0	0.1073	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048		1	13G	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1'	0	0.1094	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR		1	13G	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1'	0	0.0587	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048		1	13G	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMKYP2 6 230.00 - SMOKYHL6 230.00 230KV CKT 1'	0	0.1094	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR		1	13G	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMKYP2 6 230.00 - SMOKYHL6 230.00 230KV CKT 1'	0	0.0587	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	13SP	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.2026	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0		1	13WP	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.2147	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048		1	13SP	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.2026	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048		1	13WP	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.2147	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048		1	18WP	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.2031	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00NR		1	13SP	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1081	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00NR		1	13WP	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1174	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00NR		1	18WP	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1082	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048		1	13G	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.2187	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR		1	13G	G10_048	'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1174	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048		1	18SP	G10_048	0 'MIDW-CATC02'	0	1.1417	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048		1	23SP	G10_048	0 'MIDW-CATC02'	0	1.1414	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00NR		1	13SP	G10_048	0 'MIDW-CATC02'	0	1.14	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00NR		1	18SP	G10_048	0 'MIDW-CATC02'	0	1.1428	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00NR		1	18WP	G10_048	0 'MIDW-CATC02'	0	1.14	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00NR		1	23SP	G10_048	0 'MIDW-CATC02'	0	1.1423	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048		1	13G	G10_048	0 'MIDW-CATC02'	0	1.1393	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR		1	13G	G10_048	0 'MIDW-CATC02'	0	1.1359	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048		1	13G	G10_048	'MULLERGREN - SOUTH HAYS 230KV CKT 1 &G09-08 230.00 - SOUTH HAYS 230KV CKT 1'	0	0.1193	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR		1	13G	G10_048	'MULLERGREN - SOUTH HAYS 230KV CKT 1 &G09-08 230.00 - SOUTH HAYS 230KV CKT 1'	0	0.1216	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048		1	13G	G10_048	'POSTROCK6 230.00 - SOUTH HAYS 230KV CKT 1 &G09-08 230.00 - SOUTH HAYS 230KV CKT 1'	0	0.054	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR		1	13G	G10_048	'POSTROCK6 230.00 - SOUTH HAYS 230KV CKT 1 &G09-08 230.00 - SOUTH HAYS 230KV CKT 1'	0	0.0505	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048		1	13G	G10_048	'POSTROCK6 230.00 - SOUTH HAYS 230KV CKT 1 &HAYS WIND - SOUTH HAYS 230KV CKT 1'	0	0.054	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR		1	13G	G10_048	'POSTROCK6 230.00 - SOUTH HAYS 230KV CKT 1 &HAYS WIND - SOUTH HAYS 230KV CKT 1'	0	0.0505	9999	'BASE CASE'	

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
NCONV	FNSL-Blown up	0	1	13SP	G10_048		'SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1013	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048	1	13SP	G10_048		'SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1013	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048	1	13WP	G10_048		'SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1073	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_048	1	18WP	G10_048		'SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1015	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00NR	1	13SP	G10_048		'SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.0541	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048	1	13G	G10_048		'SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1094	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR	1	13G	G10_048		'SMKYP1 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.0587	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04G10_048	1	13G	G10_048		'SMKYP2 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.1094	9999	'BASE CASE'	
NCONV	FNSL-Blown up	04NR	1	13G	G10_048		'SMKYP2 6 230.00 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.0587	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0	1	13SP	G10_051		'BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 &BUFFALO 230.00 - BUSHLAND INTERCHANGE 230KV CKT 1'	0	0.0387	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0	1	23SP	G10_051		'KCPL-C3'	0	0.1696	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_051	1	18SP	G10_051		'KCPL-C3'	0	0.1821	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_051	1	23SP	G10_051		'KCPL-C3'	0	0.1696	9999	'BASE CASE'	
NCONV	FNSL-Blown up	0	1	13WP	G10_051		'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.0341	9999	'BASE CASE'	
NCONV	FNSL-Blown up	00G10_051	1	13WP	G10_051		'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.0341	9999	'BASE CASE'	
NCONV	FNSL-Blown up	09G10_051	1	13G	G10_051		'KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1 &SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	0	0.038	9999	'BASE CASE'	
NCONV	FNSL-Blown up	09G10_051	1	13G	G10_051		'MIDW-CATD02B'	0	0.0447	9999	'BASE CASE'	
	FDNS	00ASGI_10_020	1	18SP	ASGI_201_0_020	'FROM->TO'	'AMOCO WASSON SWITCHING STATION - OXYBRU_TP 6230.00 230KV CKT 1'	351	0.125	103.2246	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_0_020	'FROM->TO'	'AMOCO WASSON SWITCHING STATION - OXYBRU_TP 6230.00 230KV CKT 1'	351	0.125	102.2123	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS	00ASGI_10_020	1	18SP	ASGI_201_0_020	'TO->FROM'	'BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1'	160	0.0351	106.1165	'DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 &BUFFALO 230.00 - DEAF SMITH COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_0_020	'TO->FROM'	'BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1'	160	0.0351	105.5539	'DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 &BUFFALO 230.00 - DEAF SMITH COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_020	1	18SP	ASGI_201_0_020	'FROM->TO'	'CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	351	0.0332	108.9743	'EDDY COUNTY INTERCHANGE - EDDY_NORTH 6230.00 230KV CKT 1 &CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_0_020	'FROM->TO'	'CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	351	0.0332	108.5496	'EDDY COUNTY INTERCHANGE - EDDY_NORTH 6230.00 230KV CKT 1 &CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_020	1	18SP	ASGI_201_0_020	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1471	143.5488	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_0_020	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1471	141.0479	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_020	1	18SP	ASGI_201_0_020	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1471	134.1214	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_0_020	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1471	131.7184	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_020	1	23SP	ASGI_201_0_020	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.133	128.1837	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	23SP	ASGI_201_0_020	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.133	125.9176	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_020	1	23SP	ASGI_201_0_020	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.133	119.1964	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	23SP	ASGI_201_0_020	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.133	116.9388	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_020	1	18SP	ASGI_201_0_020	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1471	135.0857	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_0_020	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1471	132.5929	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_020	1	18SP	ASGI_201_0_020	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1471	125.6321	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	0	1	18SP	ASGI_201 0_020	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1471	123.1879	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	23SP	ASGI_201 0_020	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.133	120.6448	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	23SP	ASGI_201 0_020	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.133	118.3775	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	23SP	ASGI_201 0_020	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.133	111.6003	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	23SP	ASGI_201 0_020	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.133	109.3386	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	06ASGI_10_0 20	1	13G	ASGI_201 0_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0394	115.1974	'NORTHWEST - SPRING CREEK 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'	
	FDNS	06ASGI_10_0 20	1	13G	ASGI_201 0_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0395	113.938	'ARCADIA - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'	
	FDNS	06ASGI_10_0 20	1	13G	ASGI_201 0_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0394	113.7459	'CIMARRON - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'	
	FDNS	06ASGI_10_0 20	1	13G	ASGI_201 0_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0396	110.1989	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'	
	FDNS	06ASGI_10_0 20	1	13G	ASGI_201 0_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0396	109.8394	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'	
	FDNS	06ASGI_10_0 20	1	13G	ASGI_201 0_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0396	108.7022	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'	
	FDNS	06ASGI_10_0 20	1	13G	ASGI_201 0_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0502	107.5069	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'	
	FDNS	06ASGI_10_0 20	1	13G	ASGI_201 0_020	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0502	107.5069	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'	
	FDNS	00ASGI_10_0 20	1	13WP	ASGI_201 0_020	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.031	102.2909	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'	
	FDNS	0	1	13WP	ASGI_201 0_020	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.031	101.3288	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'	
	FDNS	00ASGI_10_0 20	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	133.3273	'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	132.9806	'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0333	127.6322	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 &JONES STATION - Jones Station Bus#2 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0333	127.2856	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 &JONES STATION - Jones Station Bus#2 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0348	123.9907	'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0348	123.7685	'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	123.1026	'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	122.7861	'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0333	117.845	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 &JONES STATION - Jones Station Bus#2 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0333	117.5276	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 &JONES STATION - Jones Station Bus#2 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0348	114.2223	'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0348	114.0047	'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	109.6462	'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	109.3186	'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	103.4839	'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201 0_020	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	103.1707	'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	18SP	ASGI_201 0_020	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1242	112.4137	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201 0_020	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1242	111.405	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS	00ASGI_10_0 20	1	23SP	ASGI_201 0_020	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1169	106.7567	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'	

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	0		1	23SP	ASGI_201 0_020	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1169	105.7998	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'
	FDNS	00ASGI_10_0 20		1	18SP	ASGI_201 0_020	'FROM->TO'	'MUSTANG STATION N. - SEAGRAVES INTERCHANGE 115KV CKT 1'	160	0.0974	106.3486	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	18SP	ASGI_201 0_020	'FROM->TO'	'MUSTANG STATION N. - SEAGRAVES INTERCHANGE 115KV CKT 1'	160	0.0974	104.667	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 20		1	18SP	ASGI_201 0_020	'FROM->TO'	'MUSTANG STATION N. - SEAGRAVES INTERCHANGE 115KV CKT 1'	160	0.0974	100.5302	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 20		1	18SP	ASGI_201 0_020	'TO->FROM'	'ODC TAP - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1471	105.2519	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	18SP	ASGI_201 0_020	'TO->FROM'	'ODC TAP - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1471	102.7844	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 20		1	18SP	ASGI_201 0_020	'FROM->TO'	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.125	100.9111	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'
	FDNS	06ASGI_10_0 20		1	13G	ASGI_201 0_020	'FROM->TO'	'PLANT X STATION (WH ALM20171) 230/115/13.2KV TRANSFORMER CKT 1'	239	0.0363	100.1725	'TOLK STATION TAP - TOLK STATION WEST 230KV CKT 1 &LAMB COUNTY INTERCHANGE - TOLK STATION WEST 230KV CKT 1'
	FDNS	06ASGI_10_0 20		1	13G	ASGI_201 0_020	'FROM->TO'	'PLANT X STATION (WH ALM20171) 230/115/13.2KV TRANSFORMER CKT 1'	239	0.0363	100.1265	'TOLK STATION TAP - TOLK STATION WEST 230KV CKT 1 &LAMB COUNTY INTERCHANGE - TOLK STATION WEST 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	18SP	ASGI_201 0_021	'FROM->TO'	'AMOCO WASSON SWITCHING STATION - OXYBRU_TP 6230.00 230KV CKT 1'	351	0.1138	102.6671	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'
	FDNS	0		1	18SP	ASGI_201 0_021	'FROM->TO'	'AMOCO WASSON SWITCHING STATION - OXYBRU_TP 6230.00 230KV CKT 1'	351	0.1138	102.2123	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	18SP	ASGI_201 0_021	'TO->FROM'	'BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1'	160	0.0351	105.8232	'DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 &BUFFALO 230.00 - DEAF SMITH COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	18SP	ASGI_201 0_021	'TO->FROM'	'BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1'	160	0.0351	105.5539	'DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 &BUFFALO 230.00 - DEAF SMITH COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	18SP	ASGI_201 0_021	'FROM->TO'	'CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	351	0.0318	108.7397	'EDDY COUNTY INTERCHANGE - EDDY_NORTH 6230.00 230KV CKT 1 &CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	18SP	ASGI_201 0_021	'FROM->TO'	'CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	351	0.0318	108.5496	'EDDY COUNTY INTERCHANGE - EDDY_NORTH 6230.00 230KV CKT 1 &CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	18SP	ASGI_201 0_021	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1366	142.1948	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	18SP	ASGI_201 0_021	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1366	141.0479	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	18SP	ASGI_201 0_021	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1366	132.8602	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	18SP	ASGI_201 0_021	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1366	131.7184	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	23SP	ASGI_201 0_021	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.122	126.941	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	23SP	ASGI_201 0_021	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.122	125.9176	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	23SP	ASGI_201 0_021	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.122	117.958	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	23SP	ASGI_201 0_021	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.122	116.9388	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	18SP	ASGI_201 0_021	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1366	133.7359	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	18SP	ASGI_201 0_021	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1366	132.5929	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	18SP	ASGI_201 0_021	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1366	124.3273	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	18SP	ASGI_201 0_021	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1366	123.1879	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	23SP	ASGI_201 0_021	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.122	119.4015	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	23SP	ASGI_201 0_021	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.122	118.3775	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_0 21		1	23SP	ASGI_201 0_021	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.122	110.3597	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1	23SP	ASGI_201 0_021	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.122	109.3386	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	06ASGI_10_0 21		1	13G	ASGI_201 0_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0394	115.1195	'NORTHWEST - SPRING CREEK 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ASGI_10_0 21		1	13G	ASGI_201 0_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0395	113.8598	'ARCADIA - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ASGI_10_0 21		1	13G	ASGI_201 0_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0394	113.6637	'CIMARRON - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	06ASGI_10_021		1 13G	ASGI_201_0_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0396	110.1205		'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ASGI_10_021		1 13G	ASGI_201_0_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0396	109.757		'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ASGI_10_021		1 13G	ASGI_201_0_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0396	108.6239		'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	06ASGI_10_021		1 13G	ASGI_201_0_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0502	107.4037		'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	06ASGI_10_021		1 13G	ASGI_201_0_021	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0502	107.4037		'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	00ASGI_10_021		1 13WP	ASGI_201_0_021	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.031	101.7962		'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	0		1 13WP	ASGI_201_0_021	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.031	101.3288		'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	133.1491		'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	132.9806		'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0333	127.4501		'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 &JONES STATION - Jones Station Bus#2 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0333	127.2856		'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 &JONES STATION - Jones Station Bus#2 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0348	123.8182		'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0348	123.7685		'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	122.9401		'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	122.7861		'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0333	117.6792		'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 &JONES STATION - Jones Station Bus#2 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0333	117.5276		'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 &JONES STATION - Jones Station Bus#2 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0348	114.0638		'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0348	114.0047		'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0339	109.4961		'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0339	109.3186		'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0339	103.3376		'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0339	103.1707		'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1131	111.8584		'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1131	111.405		'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'
	FDNS	00ASGI_10_021		1 23SP	ASGI_201_0_021	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1055	106.2259		'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'
	FDNS	0		1 23SP	ASGI_201_0_021	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1055	105.7998		'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'MUSTANG STATION N. - SEAGRAVES INTERCHANGE 115KV CKT 1'	160	0.0917	105.4504		'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'FROM->TO'	'MUSTANG STATION N. - SEAGRAVES INTERCHANGE 115KV CKT 1'	160	0.0917	104.667		'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'TO->FROM'	'ODC TAP - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1366	103.9156		'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	0		1 18SP	ASGI_201_0_021	'TO->FROM'	'ODC TAP - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1366	102.7844		'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00ASGI_10_021		1 18SP	ASGI_201_0_021	'FROM->TO'	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1138	100.3539		'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'
	FDNS	06ASGI_10_021		1 13G	ASGI_201_0_021	'FROM->TO'	'PLANT X STATION (WH ALM20171) 230/115/13.2KV TRANSFORMER CKT 1'	239	0.0371	100.0879		'TOLK STATION TAP - TOLK STATION WEST 230KV CKT 1 &LAMB COUNTY INTERCHANGE - TOLK STATION WEST 230KV CKT 1'
	FDNS	06ASGI_10_021		1 13G	ASGI_201_0_021	'FROM->TO'	'PLANT X STATION (WH ALM20171) 230/115/13.2KV TRANSFORMER CKT 1'	239	0.0371	100		'TOLK STATION TAP - TOLK STATION WEST 230KV CKT 1 &LAMB COUNTY INTERCHANGE - TOLK STATION WEST 230KV CKT 1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	00ASGI_11_01		1 18SP	ASGI_201_1_001	'FROM->TO'	'AMOCO WASSON SWITCHING STATION - OXYBRU_TP 6230.00 230KV CKT 1'	351	0.1369	103.2921	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS			1 18SP	ASGI_201_1_001	'FROM->TO'	'AMOCO WASSON SWITCHING STATION - OXYBRU_TP 6230.00 230KV CKT 1'	351	0.1369	102.2123	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 18SP	ASGI_201_1_001	'TO->FROM'	'BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1'	160	0.0351	106.0969	'DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 &BUFFALO 230.00 - DEAF SMITH COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS			1 18SP	ASGI_201_1_001	'TO->FROM'	'BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1'	160	0.0351	105.5539	'DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 &BUFFALO 230.00 - DEAF SMITH COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 18SP	ASGI_201_1_001	'FROM->TO'	'CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	351	0.0346	108.9696	'EDDY COUNTY INTERCHANGE - EDDY_NORTH 6230.00 230KV CKT 1 &CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS			1 18SP	ASGI_201_1_001	'FROM->TO'	'CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV CKT 1'	351	0.0346	108.5496	'EDDY COUNTY INTERCHANGE - EDDY_NORTH 6230.00 230KV CKT 1 &CUNNINGHAM STATION - EDDY COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 18SP	ASGI_201_1_001	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1584	143.6777	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS			1 18SP	ASGI_201_1_001	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1584	141.0479	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 18SP	ASGI_201_1_001	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1584	134.2507	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS			1 18SP	ASGI_201_1_001	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1584	131.7184	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 23SP	ASGI_201_1_001	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1448	128.3026	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS			1 23SP	ASGI_201_1_001	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1448	125.9176	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 23SP	ASGI_201_1_001	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1448	119.3174	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS			1 23SP	ASGI_201_1_001	'FROM->TO'	'DENVER CITY INTERCHANGE N. - EL PASO SUB 115KV CKT 1'	160	0.1448	116.9388	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 18SP	ASGI_201_1_001	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1584	135.2146	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS			1 18SP	ASGI_201_1_001	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1584	132.5929	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 18SP	ASGI_201_1_001	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1584	125.7615	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS			1 18SP	ASGI_201_1_001	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1584	123.1879	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 23SP	ASGI_201_1_001	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1448	120.7644	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS			1 23SP	ASGI_201_1_001	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1448	118.3775	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 23SP	ASGI_201_1_001	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1448	111.7216	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS			1 23SP	ASGI_201_1_001	'FROM->TO'	'EL PASO SUB - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1448	109.3386	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 &MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	06ASGI_11_01		1 13G	ASGI_201_1_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0394	115.1736	'NORTHWEST - SPRING CREEK 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'	
	FDNS			1 13G	ASGI_201_1_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0395	113.9139	'ARCADIA - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'	
	FDNS	06ASGI_11_01		1 13G	ASGI_201_1_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0394	113.7219	'CIMARRON - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'	
	FDNS			1 13G	ASGI_201_1_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0396	110.1748	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'	
	FDNS	06ASGI_11_01		1 13G	ASGI_201_1_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0396	109.812	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'	
	FDNS			1 13G	ASGI_201_1_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0396	108.6781	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'	
	FDNS	06ASGI_11_01		1 13G	ASGI_201_1_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0502	107.4742	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'	
	FDNS			1 13G	ASGI_201_1_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0502	107.4742	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'	
	FDNS			1 13WP	ASGI_201_1_001	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.031	101.3288	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'	
	FDNS	00ASGI_11_01		1 18SP	ASGI_201_1_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0341	133.3174	'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS			1 18SP	ASGI_201_1_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0341	132.9806	'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01		1 18SP	ASGI_201_1_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0333	127.6221	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 &JONES STATION - Jones Station Bus#2 230KV CKT 1'	

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	0	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0334	127.2856	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 & JONES STATION - Jones Station Bus#2 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0349	123.9813	'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 & Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0349	123.7685	'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 & Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0341	123.0935	'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 & Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0341	122.7861	'Jones Station Bus#2 - LUBBOCK POWER & LIGHT-HOLLY PLANT 230KV CKT 1 & Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0333	117.8357	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 & JONES STATION - Jones Station Bus#2 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0334	117.5276	'Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1 & JONES STATION - Jones Station Bus#2 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0349	114.2137	'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 & Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.0349	114.0047	'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 & Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	109.6358	'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 & Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	109.3186	'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 & Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	103.474	'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 & Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_001	'FROM->TO'	'LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV TRANSFORMER CKT 1'	252	0.034	103.1707	'LUBBOCK EAST INTERCHANGE - LUBBOCK POWER & LIGHT-WADSWORTH 230KV CKT 1 & Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.136	112.4806	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 & MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_001	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.136	111.405	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 & MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	23SP	ASGI_201_001	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1292	106.8185	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 & MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS	0	1	23SP	ASGI_201_001	'FROM->TO'	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1292	105.7998	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 & MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'FROM->TO'	'MUSTANG STATION N. - SEAGRAVES INTERCHANGE 115KV CKT 1'	160	0.1035	106.409	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 & MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_001	'FROM->TO'	'MUSTANG STATION N. - SEAGRAVES INTERCHANGE 115KV CKT 1'	160	0.1035	104.667	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 & MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'FROM->TO'	'MUSTANG STATION N. - SEAGRAVES INTERCHANGE 115KV CKT 1'	160	0.1035	100.5908	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 & MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'TO->FROM'	'ODC TAP - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1584	105.3806	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 & MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	0	1	18SP	ASGI_201_001	'TO->FROM'	'ODC TAP - SHELL CO2 GAS SUB 115KV CKT 1'	160	0.1584	102.7844	'AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 & MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	
	FDNS	00ASGI_11_01	1	18SP	ASGI_201_001	'FROM->TO'	'OXYBRU_TP 6230.00 - YOAKUM COUNTY INTERCHANGE 230KV CKT 1'	351	0.1369	100.9787	'MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 & MUSTANG STATION - SEMINOLE 230KV CKT 1'	
	FDNS	06ASGI_11_01	1	13G	ASGI_201_001	'FROM->TO'	'PLANT X STATION (WH ALM20171) 230/115/13.2KV TRANSFORMER CKT 1'	239	0.0356	100.1347	'TOLK STATION TAP - TOLK STATION WEST 230KV CKT 1 & LAMB COUNTY INTERCHANGE - TOLK STATION WEST 230KV CKT 1'	
	FDNS	06ASGI_11_01	1	13G	ASGI_201_001	'FROM->TO'	'PLANT X STATION (WH ALM20171) 230/115/13.2KV TRANSFORMER CKT 1'	239	0.0356	100.0888	'TOLK STATION TAP - TOLK STATION WEST 230KV CKT 1 & LAMB COUNTY INTERCHANGE - TOLK STATION WEST 230KV CKT 1'	
	FDNS	02G10_001	1	13G	G10_001	'TO->FROM'	'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.0359	119.9065	'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'	
	FDNS	00G10_001	1	13WP	G10_001	'TO->FROM'	'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.0443	103.7998	'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'	
	FDNS	00G10_001	1	13SP	G10_001	'TO->FROM'	'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.0432	103.5191	'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'	
	FDNS	00G10_001	1	18WP	G10_001	'TO->FROM'	'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.0434	101.0793	'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'	
	FDNS	02G10_001	1	13G	G10_001	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.0974	121.7847	'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2 & BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'	
	FDNS	02G10_001	1	13G	G10_001	'FROM->TO'	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'	287	0.0974	119.1566	'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2 & BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'	
	FDNS	02G10_001	1	13G	G10_001	'FROM->TO'	'FLATRDG3 - HARPER 138KV CKT 1'	95.6	0.0359	160.5873	'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'	
	FDNS	02G10_001	1	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.1001	103.6943	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 & THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'	
	FDNS	02G10_001	1	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.1001	103.6943	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 & THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'	

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	02G10_001		1	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0845	101.2833	'NORTHWEST - SPRING CREEK 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0843	100.5295	'ARCADIA - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'FROM->TO'	'FPL SWITCH - MOORELAND 138KV CKT 1'	287	0.0843	100.4243	'CIMARRON - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.1001	181.3116	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.1001	181.3116	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0845	176.6018	'NORTHWEST - SPRING CREEK 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0843	175.21	'ARCADIA - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0843	175.0298	'CIMARRON - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0844	171.4975	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0844	171.3824	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0844	170.0174	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0927	165.3688	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0872	159.1515	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0844	158.9867	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0844	158.7543	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0844	158.7286	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0844	158.7263	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0751	157.0262	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0819	147.2323	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0844	145.2931	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0615	144.3979	'ELK CITY 230KV - SWEETWATER 230KV CKT 1 &STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0615	143.6187	'ELK CITY 230KV - SWEETWATER 230KV CKT 1 &ROARK6 230.00 - SWEETWATER 230KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0615	143.5969	'ELK CITY 230KV - SWEETWATER 230KV CKT 1 &NEXTERA - SWEETWATER 230KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0615	142.6205	'ELK CITY 230KV - SWEETWATER 230KV CKT 1 &DEMPSEY6 230.00 - SWEETWATER 230KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0615	142.5196	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 &GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0615	141.4103	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1 &GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0652	140.7134	'WDWRD69KVPCB'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0608	140.5544	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1 &GRACEMONT - LAWTON EASTSIDE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0603	139.1117	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1 &LAWTON EASTSIDE - SUNNYSIDE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0579	138.1194	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	136.2718	'BASE CASE'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0679	135.3663	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0679	135.3663	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0679	135.3663	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 &THISTLE7 345.00 - WICHITA 345KV CKT 1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0679	135.3663	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0597	134.723	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 &AMARILLO SOUTH INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0596	134.4629	'HUTCHINSON COUNTY INTERCHANGE - NICHOLS STATION 230KV CKT 1 &GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0596	134.4196	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 &Harrington Station Mid Bus - NICHOLS STATION 230KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0596	134.4065	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 &HARRINGTON STATION - NICHOLS STATION 230KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0704	132.4935	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0704	132.4935	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0607	131.7355	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1 &OKLAUN - OKLAUNION 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0607	131.6768	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1 &OKLAUN - OKLAUNION 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0607	131.672	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1 &OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0651	129.2606	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0651	129.2606	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0651	129.2606	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0651	129.2606	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0626	128.9547	'BENTON - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0626	128.9547	'BENTON - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0632	128.7198	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 &HOLCOMB - SETAB 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.063	128.642	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 &FINNEY SWITCHING STATION - PSCO LAMAR DC TIE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0535	128.5235	'WDRNG102'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	128.3513	'GEN520997 1-MORLND2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0578	128.2192	'SOONER - WOODRING 345KV CKT 1 &HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0634	128.1115	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 &BUCKNER7 345.00 - HOLCOMB 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0628	128.029	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1 &BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.063	127.3742	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 &FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.063	127.3634	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 &FINNEY SWITCHING STATION - G08-18 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0616	127.2458	'EMPORIA ENERGY CENTER - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0616	127.2458	'EMPORIA ENERGY CENTER - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0614	127.0814	'RENO COUNTY - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0614	127.0814	'RENO COUNTY - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0617	126.9913	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0617	126.9913	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0617	126.9913	'THISTLE7 345.00 - WICHITA 345KV CKT 2 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0617	126.9913	'THISTLE7 345.00 - WICHITA 345KV CKT 2 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.063	126.9215	'FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 &FINNEY SWITCHING STATION - G08-18 345.00 345KV CKT 1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0682	126.9205	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 &Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0565	126.7353	'WDRNG383'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0623	126.4927	'VIOLA 7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0623	126.4927	'VIOLA 7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.063	126.4858	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 &FINNEY SWITCHING STATION - PSCO LAMAR DC TIE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0603	125.1037	'HOLCOMB - SETAB 345KV CKT 1 &BUCKNER7 345.00 - HOLCOMB 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0586	124.6261	'NOWST302'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0559	124.5233	'WDRNG313'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0586	124.1012	'NOWST303'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	124.0344	'GEN515787 1-OKLA WIND ENERGY CENTER'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0579	123.8969	'HARRINGTON STATION - NICHOLS STATION 230KV CKT 1 &Harrington Station Mid Bus - NICHOLS STATION 230KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	123.8593	'GEN514805 1-SOONER UNIT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0616	123.482	'BENTON - WICHITA 345KV CKT 1 &VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0588	122.8498	'POST ROCK - SPEARVILLE 345KV CKT 1 &BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	122.7895	'GEN520922 1-SLEEPING BEAR'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0605	122.7201	'CIMARRON - NORTHWEST 345KV CKT 1 &ARCADIA - NORTHWEST 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0588	122.6832	'CHSHLMV7 345.00 - HUNTERS7 345.00 345KV CKT 1 &HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0588	122.6272	'HUNTERS7 345.00 - WOODRING 345KV CKT 1 &HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0584	122.6043	'CMARN383'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0588	122.559	'HUNTERS7 345.00 - WOODRING 345KV CKT 1 &CHSHLMV7 345.00 - HUNTERS7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0584	122.3133	'CIMARRON - NORTHWEST 345KV CKT 1 &CANADIN7 345.00 - CIMARRON 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0584	122.0296	'CIMARRON - MINCO 345KV CKT 1 &CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.058	122.0086	'CANEYRV7 345.00 - NEOSHO 345KV CKT 1 &LACYGNE - NEOSHO 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0588	122.0084	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1 &G07-25 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0588	121.9391	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1 &G10-05 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0598	121.928	'EMPORIA ENERGY CENTER - WICHITA 345KV CKT 1 &BENTON - WICHITA 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0588	121.8096	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1 &VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0582	121.7789	'BENTON - ROSE HILL 345KV CKT 1 &ROSE HILL - WOLF CREEK 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.059	121.6946	'CIMARRON - WOODRING 345KV CKT 1 &HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0574	121.6367	'NORTHEAST STATION - ONETA 345KV CKT 1 &NORTHEAST STATION - TULSA NORTH 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.059	121.6348	'BENTON - WICHITA 345KV CKT 1 &BENTON - WOLF CREEK 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	121.5913	'GEN514806 1-SOONER UNIT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0581	121.5447	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &G05-12 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0582	121.5442	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0582	121.5442	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0581	121.5348	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &G06-06 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0581	121.5296	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &G08-124 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0581	121.529	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &G10-15 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0588	121.5198	'POST ROCK - SPEARVILLE 345KV CKT 1 &AXTELL - POST ROCK 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0591	121.4732	'RENO COUNTY - WICHITA 345KV CKT 1 &BENTON - WICHITA 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.058	121.4601	'CIMARRON - NORTHWEST 345KV CKT 1 &CIMARRON - DRAPER LAKE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0592	121.4486	'NORTHWEST - SPRING CREEK 345KV CKT 1 &CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0581	121.4387	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &BUCKNER7 345.00 - G10-09 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0583	121.4293	'CIMARRON - WOODRING 345KV CKT 1 &CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0585	121.4252	'POST ROCK - SPEARVILLE 345KV CKT 1 &CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0585	121.4252	'POST ROCK - SPEARVILLE 345KV CKT 1 &CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0581	121.3942	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &BUCKNER7 345.00 - G10-45 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0581	121.394	'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &BUCKNER7 345.00 - G07-40 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0586	121.3871	'POST ROCK - SPEARVILLE 345KV CKT 1 &G05-12 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0586	121.3806	'POST ROCK - SPEARVILLE 345KV CKT 1 &G06-06 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0586	121.3766	'POST ROCK - SPEARVILLE 345KV CKT 1 &G08-124 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0586	121.3745	'POST ROCK - SPEARVILLE 345KV CKT 1 &G10-15 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.063	121.3111	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 &G10-14 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0738	121.273	'FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 &BEAVER CO 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0591	121.1201	'BENTON - ROSE HILL 345KV CKT 1 &BENTON - WICHITA 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0619	121.1104	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0589	120.9902	'HOLCOMB - SETAB 345KV CKT 1 &MINGO - SETAB 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	120.9654	'HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 &JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0591	120.9456	'MINGO - SETAB 345KV CKT 1 &MINGO - RED WILLOW 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	120.8997	'DEMPSEY6 230.00 - SWEETWATER 230KV CKT 1 &ROARK6 230.00 - SWEETWATER 230KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0573	120.89	'SONR184'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0581	120.8668	'BUCKNER7 345.00 - HOLCOMB 345KV CKT 1 &BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	120.8184	'NEXTERA - SWEETWATER 230KV CKT 1 &DEMPSEY6 230.00 - SWEETWATER 230KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0588	120.8049	'MINGO - SETAB 345KV CKT 1 &G08-17 345.00 - SETAB 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	120.5035	'GEN520947 1-HUGO1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0588	120.4857	'VIOLA 7 345.00 - WICHITA 345KV CKT 1 &G10-05 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0615	120.0037	'DEMPSEY6 230.00 - SWEETWATER 230KV CKT 1 &STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0615	119.1987	'ROARK6 230.00 - SWEETWATER 230KV CKT 1 &STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0615	119.1123	'NEXTERA - SWEETWATER 230KV CKT 1 &STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0577	116.7907	'CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1 &CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0576	116.3403	'NORTHEAST STATION - TULSA NORTH 345KV CKT 1 &DELAWARE - NORTHEAST STATION 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	116.3348	'GEN542951 5-HAWTHORN UNIT #5'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0574	116.3255	'LYDIA - WELSH 345KV CKT 1 &EASTDC - WELSH 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	116.3214	'DIANA - WELSH 345KV CKT 2 &EASTDC - WELSH 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	116.3177	'GEN532722 1-EVANS ENERGY CENTER UNIT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	116.3172	'DIANA - WELSH 345KV CKT 1 &EASTDC - WELSH 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	116.3157	'GEN542956 2-LACYGNE UNIT #2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	116.3117	'GEN542955 1-LACYGNE UNIT #1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0572	116.3014	'CLEVELAND - SOONER 345KV CKT 1 &SOONER - SPRING CREEK 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.057	116.2763	'LYDIA - WELSH 345KV CKT 1 &LYDIA - VALLIANT 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.057	116.2757	'LYDIA - NORTHWEST TEXARKANA 345KV CKT 1 &LYDIA - VALLIANT 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.057	116.274	'LYDIA - NORTHWEST TEXARKANA 345KV CKT 1 &LYDIA - WELSH 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.057	116.2564	'LYDIA - VALLIANT 345KV CKT 1 &PITTSBURG - VALLIANT 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0572	116.2551	'CLEVELAND - SOONER 345KV CKT 1 &ROSE HILL - SOONER 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.057	116.2508	'LYDIA - VALLIANT 345KV CKT 1 &HUGO - VALLIANT 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.057	116.2296	'COTTONWOOD'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	116.212	'GEN659111 2-LELAND OLDS UNIT2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	116.1156	'GEN515393 1-OGEWND2G'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	116.1053	'WELSH - WILKES 345KV CKT 1 &EASTDC - WELSH 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0576	116.1028	'NORTHEAST STATION - ONETA 345KV CKT 1 &DELAWARE - NORTHEAST STATION 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	116.0402	'CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.9481	'GEN515365 1-CENT 21 34.500'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.7632	'GEN527162 1-MUSTANG GEN #2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.7631	'GEN527161 1-MUSTANG GEN #1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0572	115.7148	'BUS18'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.708	'GEN527902 1-HOBBS PLANT #2 (CT)'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.6887	'GEN527901 1-HOBBS PLANT #1 (CT)'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.5275	'GEN542957 1-IATAN UNIT #1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.487	'GEN659103 1-ANTELOPE VALLEY UNIT1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.487	'GEN659107 2-ANTELOPE VALLEY UNIT2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.4183	'GEN645001 1-FORT CALHOUN 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.3847	'CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		
								(MVA)	TDF	(%MVA)	CONTINGENCY	
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.3196	'GEN525494 1-PLANT X GEN #4 20 KV'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.247	'G08-19 345.00 - TATONGA7 345.00 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0573	115.1777	'SO469KVPCB'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	115.1717	'GEN527882 1-CUNNINGHAM GEN #2 20 KV'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.9764	'GEN560585 1-G06-44-2 0.6000'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0745	114.8813	'Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 &BEAVER CO 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.7522	'GEN645011 1-NEBRASKA CITY 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.6452	'GEN542962 2-IATAN UNIT #2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.4857	'GEN560429 1-G08-29 0.6400'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.3724	'GEN645012 2-NEBRASKA CITY 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.3644	'GEN527903 1-HOBBS PLANT #3 (ST)'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.3108	'G07-62 345.00 - G07-62-1 345.00 345KV CKT 1 &G07-62 345.00 - G07-62-2 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.3008	'GEN532651 1-JEFFREY ENERGY CENTER UNIT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.3005	'GEN532652 1-JEFFREY ENERGY CENTER UNIT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.3001	'GEN532653 1-JEFFREY ENERGY CENTER UNIT 3'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.238	'GEN640011 2-GERALD GENTLEMAN STATION UNIT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.2016	'G07-62 345.00 - G07-62-1 345.00 345KV CKT 1 &G07-62 345.00 - G07-62-3 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.2016	'G07-62 345.00 - G07-62-1 345.00 345KV CKT 1 &G07-62 345.00 - G07-62-4 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.2016	'G07-62 345.00 - G07-62-2 345.00 345KV CKT 1 &G07-62 345.00 - G07-62-3 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.2016	'G07-62 345.00 - G07-62-2 345.00 345KV CKT 1 &G07-62 345.00 - G07-62-4 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.1981	'GEN526331 1-JONES GEN #1 22 KV'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.1967	'GEN526332 1-JONES GEN #2 21 KV'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.1274	'GEN640010 1-GERALD GENTLEMAN STATION UNIT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	114.0947	'G07-62 345.00 - G07-62-3 345.00 345KV CKT 1 &G07-62 345.00 - G07-62-4 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	113.9726	'GEN640009 1-COOPER NUCLEAR STATION'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0573	113.8782	'LACYGNE - WEST GARDNER 345KV CKT 1 &LACYGNE - STILWELL 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	113.8534	'GEN560371 1-G07-46 0.6900'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	113.7033	'GEN560256 1-G10-14-1 0.6900'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	113.5698	'GEN560257 1-G10-14-2 0.6900'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	113.5098	'GEN560586 1-G06-44-3 0.6000'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	113.2772	'GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	113.0752	'GEN523973 1-HARRINGTON GEN #3 24 KV'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	113.0696	'GEN523971 1-HARRINGTON GEN #1 24 KV'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	113.0692	'GEN523972 1-HARRINGTON GEN #2 24 KV'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	112.196	'GEN560286 1-G10-01-1WTG 0.6900'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	112.196	'GEN560287 1-G10-01-2WTG 0.6900'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0619	112.1718	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0727	112.1667	'G10-14 345.00 - Hitchland Interchange 345KV CKT 1 &BEAVER CO 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0542	112.1015	'BUS16'
	FNSL	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	112.0486	'GEN659118 1-LARAMIE RIVER UNIT1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	112.0484	'GEN523103 1-NOBLE_WND 3115.00'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	111.7306	'GEN525561 1-TOLK GEN #1 24 KV'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0415	111.436	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0415	111.436	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 &BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0614	111.3922	'Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 &G10-14 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	111.2273	'GEN531447 1-HOLCOMB GENERATOR'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0592	110.4084	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0585	110.1896	'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2 &Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	109.9373	'G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-62 345.00 - G07-62-1 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	109.9373	'G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-62 345.00 - G07-62-2 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	109.9373	'G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-62 345.00 - G07-62-3 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	109.9373	'G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-62 345.00 - G07-62-4 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0549	109.5413	'BUS10'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	109.2458	'GEN525562 1-TOLK GEN #2 24 KV'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0548	106.7878	'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2 &G10-14 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	106.6215	'GEN560121 1-G08-47 0.5750'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0575	106.2378	'BEAVER CO 345.00 - G08-47 345.00 345KV CKT 1 &BEAVER CO 345.00 - G10-01 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0727	105.9344	'BEAVER CO 345.00 - Hitchland Interchange 345KV CKT 1 &BEAVER CO 345.00 - G08-47 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0727	104.9698	'BEAVER CO 345.00 - Hitchland Interchange 345KV CKT 1 &BEAVER CO 345.00 - G10-01 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0479	103.8792	'IMOTAP84'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0478	103.1624	'IMOTAP83'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0374	102.0759	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0548	101.3252	'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2 &G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.037	100.0893	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BEAVER CO 345.00 - G08-47 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0475	100	'BUS11'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.037	100	'BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BEAVER CO 345.00 - G10-01 345.00 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'TO->FROM'	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'	351	0.0876	105.1574	'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2 &BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	02G10_001		1	13G	G10_001	'FROM->TO'	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'	351	0.0974	102.2715	'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2 &BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	02G10_001		1 13G	G10_001	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0359	144.5647		'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	00G10_001		1 13WP	G10_001	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0443	128.045		'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	00G10_001		1 13SP	G10_001	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0432	128.0326		'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	00G10_001		1 18WP	G10_001	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0434	125.2745		'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS		0	1 13SP	G10_001	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0433	101.4366		'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS		0	1 13WP	G10_001	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0443	101.3288		'THISTLE7 345.00 - WICHITA 345KV CKT 1 & THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	00G10_001		1 18SP	G10_001	'FROM->TO'	'Harrington Station Mid Bus - RANDALL COUNTY INTERCHANGE 230KV CKT 1'	351	0.0312	100.8448		'HARRINGTON STATION - NICHOLS STATION 230KV CKT 1 & Harrington Station Mid Bus - NICHOLS STATION 230KV CKT 2'
	FDNS	00G10_001		1 23SP	G10_001	'FROM->TO'	'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFORMER CKT 1'	250	0.0448	122.9827		'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 & HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1'
	FDNS		0	1 23SP	G10_001	'FROM->TO'	'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFORMER CKT 1'	250	0.0446	118.1865		'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 & HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00G10_001		1 23SP	G10_001	'FROM->TO'	'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFORMER CKT 1'	250	0.0448	117.921		'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 & HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1'
	FDNS		0	1 23SP	G10_001	'FROM->TO'	'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFORMER CKT 1'	250	0.0446	113.1738		'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 & HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00G10_001		1 23SP	G10_001	'FROM->TO'	'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFORMER CKT 1'	250	0.0354	101.7103		'HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1 & MOORE COUNTY INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1'
	FDNS	00G10_001		1 13WP	G10_001	'FROM->TO'	'NORTHWEST (NORTWST2) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0334	121.2094		'NOWST303'
	FDNS	00G10_001		1 13WP	G10_001	'FROM->TO'	'NORTHWEST (NORTWST2) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0334	118.7175		'NOWST303'
	FDNS	02G10_001		1 13G	G10_001	'FROM->TO'	'NORTHWEST (NORTWST2) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0361	117.0018		'NOWST303'
	FDNS	02G10_001		1 13G	G10_001	'FROM->TO'	'NORTHWEST (NORTWST2) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0361	115.3838		'NOWST303'
	FDNS		0	1 13WP	G10_001	'FROM->TO'	'NORTHWEST (NORTWST2) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0344	111.5249		'NOWST303'
	FDNS		0	1 13WP	G10_001	'FROM->TO'	'NORTHWEST (NORTWST2) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0344	109.5201		'NOWST303'
	FDNS	00G10_001		1 13WP	G10_001	'FROM->TO'	'NORTHWEST (NORTWST3) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0325	112.3857		'NOWST302'
	FDNS	00G10_001		1 13WP	G10_001	'FROM->TO'	'NORTHWEST (NORTWST3) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0325	110.1754		'NOWST302'
	FDNS	02G10_001		1 13G	G10_001	'FROM->TO'	'NORTHWEST (NORTWST3) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0352	108.4777		'NOWST302'
	FDNS	02G10_001		1 13G	G10_001	'FROM->TO'	'NORTHWEST (NORTWST3) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0352	107.1475		'NOWST302'
	FDNS		0	1 13WP	G10_001	'FROM->TO'	'NORTHWEST (NORTWST3) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0335	103.3881		'NOWST302'
	FDNS		0	1 13WP	G10_001	'FROM->TO'	'NORTHWEST (NORTWST3) 345/138/13.8KV TRANSFORMER CKT 1'	493	0.0335	101.6729		'NOWST302'
	FDNS		0	1 23SP	G10_036	'TO->FROM'	'EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1'	446	0.0337	121.2232		'JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1 & JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
	FDNS	00G10_036		1 23SP	G10_036	'TO->FROM'	'EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1'	446	0.0337	121.2232		'JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1 & JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
	FDNS		0	1 18SP	G10_036	'TO->FROM'	'EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1'	446	0.0334	118.7897		'JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1 & JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
	FDNS	00G10_036		1 18SP	G10_036	'TO->FROM'	'EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1'	446	0.0334	118.7897		'JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1 & JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
	FDNS		0	1 18WP	G10_036	'TO->FROM'	'EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1'	446	0.0305	106.6227		'JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1 & JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
	FDNS	00G10_036		1 18WP	G10_036	'TO->FROM'	'EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1'	446	0.0305	106.6227		'JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1 & JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
	FDNS		0	1 13SP	G10_036	'TO->FROM'	'EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1'	446	0.0312	100.6177		'JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1 & JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
	FDNS	00G10_036		1 13SP	G10_036	'TO->FROM'	'EAST MANHATTAN - JEFFREY ENERGY CENTER 230KV CKT 1'	446	0.0312	100.6177		'JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1 & JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
	FDNS	01NR		1 13G	G10_040	'FROM->TO'	'CIMARRON - HAYMAKER 138KV CKT 1'	308	0.1241	101.1508		'CIMARRONR'
	FDNS	01G10_040		1 13G	G10_040	'FROM->TO'	'CIMARRON - HAYMAKER 138KV CKT 1'	308	0.1084	101.0755		'CIMARRONR'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		
								(MVA)	TDF	(%MVA)	CONTINGENCY	
	FDNS	00NR		1	23SP	G10_040	'FROM->TO'	'SEMINOLE 138/20.9KV TRANSFORMER CKT 1'	898	0.0505	9999	'MSKGE384-13'
	FDNS	00NR		1	23SP	G10_040	'FROM->TO'	'SEMINOLE 138/20.9KV TRANSFORMER CKT 1'	898	0.0505	9999	'MSKGE385'
	FDNS	00NR		1	23SP	G10_040	'FROM->TO'	'SEMINOLE 138/20.9KV TRANSFORMER CKT 1'	898	0.0505	9999	'SONR181'
	FDNS	00NR		1	23SP	G10_040	'FROM->TO'	'SEMINOLE 138/20.9KV TRANSFORMER CKT 1'	898	0.0505	9999	'SONR38'
	FDNS	00NR		1	23SP	G10_040	'FROM->TO'	'SEMINOLE 138/20.9KV TRANSFORMER CKT 1'	898	0.0505	9999	'SONR392'
	FDNS	00G10_041		1	13WP	G10_041	'FROM->TO'	'AUBURN ROAD - SWISSVALE 230KV CKT 1'	319	0.0388	100	'JEFFREY ENERGY CENTER - MORRIS COUNTY 345KV CKT 1 &JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1'
	FDNS	00G10_041		1	23SP	G10_041	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0488	102.4589	'KCPL-C2'
	FDNS	0		1	23SP	G10_041	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0488	102.0369	'KCPL-C2'
	FDNS	00G10_041		1	23SP	G10_041	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0488	101.7462	'KCPLB-6'
	FDNS	0		1	23SP	G10_041	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0488	101.3191	'KCPLB-6'
	FDNS	00G10_041		1	23SP	G10_041	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0488	100.8448	'KCPL-C2'
	FDNS	00G10_041		1	18SP	G10_041	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0517	100.4717	'KCPL-C2'
	FDNS	0		1	23SP	G10_041	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0488	100.4277	'KCPL-C2'
	FDNS	00G10_041		1	23SP	G10_041	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0488	100.1411	'KCPLB-6'
	FDNS	00G10_045		1	13WP	G10_045	'TO->FROM'	'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.0489	102.8361	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	00G10_045		1	13SP	G10_045	'TO->FROM'	'CLEARWATER - MILAN TAP 138KV CKT 1'	110	0.0477	102.4238	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0438	155.1862	'NORTHWEST - SPRING CREEK 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0434	153.6638	'ARCADIA - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0435	153.5457	'CIMARRON - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0435	150.0437	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0435	149.8831	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0435	148.523	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0493	148.1866	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0411	140.5108	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0411	140.5108	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0435	137.2348	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0435	136.9693	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0435	136.9481	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0435	136.9459	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0418	132.5412	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0418	130.8456	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0335	126.3871	'WDWRD69KVPCB'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0435	124.0273	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	122.7612	'ELK CITY 230KV - SWEETWATER 230KV CKT 1 &STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	122.0806	'ELK CITY 230KV - SWEETWATER 230KV CKT 1 &NEXTERA - SWEETWATER 230KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	122.0658	'ELK CITY 230KV - SWEETWATER 230KV CKT 1 &ROARK6 230.00 - SWEETWATER 230KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	121.1811	'ELK CITY 230KV - SWEETWATER 230KV CKT 1 &DEMPSEY6 230.00 - SWEETWATER 230KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0305	121.0695	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1 &GRACEMONT - LAWTON EASTSIDE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	120.8046	'GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 &GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0333	120.2148	'SOONER - WOODRING 345KV CKT 1 &HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	119.9047	'STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1 &GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0302	119.8843	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1 &LAWTON EASTSIDE - SUNNYSIDE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0353	118.9246	'BENTON - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0353	118.9246	'BENTON - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0366	118.4499	'VIOLA 7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0366	118.4499	'VIOLA 7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.032	118.1989	'WDRNG383'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0304	117.23	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 &AMARILLO SOUTH INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0303	117.0486	'HUTCHINSON COUNTY INTERCHANGE - NICHOLS STATION 230KV CKT 1 &GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0303	116.9923	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 &Harrington Station Mid Bus - NICHOLS STATION 230KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0303	116.9778	'GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 &HARRINGTON STATION - NICHOLS STATION 230KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.034	116.7077	'RENO COUNTY - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.034	116.7077	'RENO COUNTY - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0339	116.5589	'EMPORIA ENERGY CENTER - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0339	116.5589	'EMPORIA ENERGY CENTER - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0373	116.2748	'BENTON - WICHITA 345KV CKT 1 &VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0324	114.44	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0324	114.44	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0324	114.44	'THISTLE7 345.00 - WICHITA 345KV CKT 2 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0324	114.44	'THISTLE7 345.00 - WICHITA 345KV CKT 2 &CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0303	114.0952	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0303	114.0952	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0303	114.0952	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 &THISTLE7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0303	114.0952	'THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03	114.059	'WDRNG313'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0326	113.7687	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1 &BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0332	113.3651	'CHSHLMV7 345.00 - HUNTERS7 345.00 345KV CKT 1 &HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0332	113.3152	'HUNTERS7 345.00 - WOODRING 345KV CKT 1 &HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0305	113.3109	'OKLAUNION - TUCO INTERCHANGE 345KV CKT 1 &OKLAUN - OKLAUNION 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0305	113.292	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1 &OKLAUNION - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0332	113.2338	'HUNTERS7 345.00 - WOODRING 345KV CKT 1 &CHSHLMV7 345.00 - HUNTERS7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0305	113.1694	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1 &OKLAUN - OKLAUNION 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0332	112.6514	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1 &G07-25 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0332	112.5962	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1 &G10-05 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0332	112.4629	'HUNTERS7 345.00 - VIOLA 7 345.00 345KV CKT 1 &VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0329	112.2127	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0302	112.1467	'NOWST302'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0325	112.1198	'POST ROCK - SPEARVILLE 345KV CKT 1 &AXTELL - POST ROCK 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0349	112.1096	'POST ROCK - SPEARVILLE 345KV CKT 1 &BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03	112.0298	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03	112.0298	'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0322	111.9166	'POST ROCK - SPEARVILLE 345KV CKT 1 &G06-06 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0322	111.8848	'POST ROCK - SPEARVILLE 345KV CKT 1 &G08-124 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0322	111.8842	'POST ROCK - SPEARVILLE 345KV CKT 1 &G10-15 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0322	111.8552	'POST ROCK - SPEARVILLE 345KV CKT 1 &G05-12 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0302	111.6196	'NOWST303'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0328	111.5579	'CIMARRON - WOODRING 345KV CKT 1 &HUNTERS7 345.00 - WOODRING 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0319	111.4898	'POST ROCK - SPEARVILLE 345KV CKT 1 &CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0319	111.4898	'POST ROCK - SPEARVILLE 345KV CKT 1 &CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 2'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0332	111.1211	'VIOLA 7 345.00 - WICHITA 345KV CKT 1 &G10-05 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0332	110.9998	'VIOLA 7 345.00 - WICHITA 345KV CKT 1 &G07-25 345.00 - VIOLA 7 345.00 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0322	110.4597	'EMPORIA ENERGY CENTER - WICHITA 345KV CKT 1 &BENTON - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0316	110.1489	'BENTON - WICHITA 345KV CKT 1 &BENTON - WOLF CREEK 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0305	110.1223	'CANEYRV7 345.00 - NEOSHO 345KV CKT 1 &LACYGNE - NEOSHO 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0308	110.1219	'BENTON - ROSE HILL 345KV CKT 1 &ROSE HILL - WOLF CREEK 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0337	109.9892	'EMPORIA ENERGY CENTER - WICHITA 345KV CKT 1 &VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03	109.9108	'CMARN383'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0326	109.8954	'MINGO - SETAB 345KV CKT 1 &MINGO - RED WILLOW 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0316	109.8892	'RENO COUNTY - WICHITA 345KV CKT 1 &BENTON - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0315	109.8635	'CIMARRON - NORTHWEST 345KV CKT 1 &ARCADIA - NORTHWEST 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0301	109.8348	'CIMARRON - NORTHWEST 345KV CKT 1 &CANADIN7 345.00 - CIMARRON 345KV CKT 1'
	FDNS	03G10_045		1	13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0318	109.7172	'BENTON - ROSE HILL 345KV CKT 1 &BENTON - WICHITA 345KV CKT 1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0332	109.6301		'RENO COUNTY - WICHITA 345KV CKT 1 &VIOLA 7 345.00 - WICHITA 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0301	109.5851		'CIMARRON - MINCO 345KV CKT 1 &CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0323	109.4802		'HOLCOMB - SETAB 345KV CKT 1 &MINGO - SETAB 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0321	109.3794		'MINGO - SETAB 345KV CKT 1 &G08-17 345.00 - SETAB 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0312	109.3723		'BKR-AXT-3308'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0312	109.3304		'AXTELL - POST ROCK 345KV CKT 1 &AXTELL - SWEETWATER 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0323	109.3107		'MINGO - RED WILLOW 345KV CKT 1 &GERALD GENTLEMAN STATION - RED WILLOW 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0323	109.3055		'BKR-RW-3302'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0312	109.2248		'AXTELL - POST ROCK 345KV CKT 1 &AXTELL - PAULINE 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0308	109.0606		'CIRCLE - MULLERGREN 230KV CKT 1 &MULLERGREN - SPEARVILLE 230KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0305	109.0015		'MULLERGREN - SOUTH HAYS 230KV CKT 1 &MULLERGREN - SPEARVILLE 230KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0316	108.5893		'HOLCOMB - SETAB 345KV CKT 1 &G08-17 345.00 - SETAB 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0351	108.3344		'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &G05-12 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0351	108.2442		'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &G06-06 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0351	108.2165		'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &G08-124 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0351	108.2138		'BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 &G10-15 345.00 - SPEARVILLE 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0303	108.1645		'MULLERGREN - SPEARVILLE 230KV CKT 1 &G04_014 230.00 - SPEARVILLE 230KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0304	108.1453		'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 &EAST MCPHERSON - SUMMIT 230KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0301	108.1397		'NORTHWEST - SPRING CREEK 345KV CKT 1 &CIMARRON - NORTHWEST 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0303	108.0952		'HEIZER 6 230.00 - MULLERGREN 230KV CKT 1 &MULLERGREN - SPEARVILLE 230KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0303	108.0951		'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 &SUMMIT - UNIONRG6 230.00 230KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	107.3195		'DEMPSEY6 230.00 - SWEETWATER 230KV CKT 1 &STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	106.4736		'NEXTERA - SWEETWATER 230KV CKT 1 &STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	106.4502		'ROARK6 230.00 - SWEETWATER 230KV CKT 1 &STATELINE INTERCHANGE - SWEETWATER 230KV CKT &1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.03	103.9858		'NORTHEAST STATION - ONETA 345KV CKT 1 &DELAWARE - NORTHEAST STATION 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0307	103.8672		'Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 &BEAVER CO 345.00 - Hitchland Interchange 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0307	103.5534		'Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2 &Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1'
	FDNS	03G10_045		1 13G	G10_045	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0329	103.1274		'BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-62 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	00G10_045		1 13WP	G10_045	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0489	126.8276		'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	00G10_045		1 13SP	G10_045	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0477	126.7228		'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	00G10_045		1 18WP	G10_045	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0479	123.8342		'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	0		1 13SP	G10_045	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0478	101.4366		'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	0		1 13WP	G10_045	'FROM->TO'	'HARPER - MILAN TAP 138KV CKT 1'	95.6	0.0489	101.3288		'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
	FDNS	00G10_045		1 23SP	G10_045	'FROM->TO'	'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFORMER CKT 1'	250	0.0338	122.7347		'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 &HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
FDNS		0		1	23SP	G10_045	'FROM->TO'	'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFORMER CKT 1'	250	0.0338	118.1865	'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 &HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1'
FDNS	00G10_045			1	23SP	G10_045	'FROM->TO'	'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFORMER CKT 1'	250	0.0338	117.7576	'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 &HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1'
FDNS		0		1	23SP	G10_045	'FROM->TO'	'HITCHLAND INTERCHANGE (H TP80148301) 230/115/13.2KV TRANSFORMER CKT 1'	250	0.0338	113.1738	'HITCHLAND INTERCHANGE - OCHILTREE 230KV CKT 1 &HITCHLAND INTERCHANGE - MOORE COUNTY INTERCHANGE 230KV CKT 1'
FDNS	03G10_045			1	13G	G10_045	'TO->FROM'	'MULLERGREN - SPEARVILLE 230KV CKT 1'	355.3	0.1177	114.2161	'POST ROCK - SPEARVILLE 345KV CKT 1 &CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1'
FDNS	03G10_045			1	13G	G10_045	'TO->FROM'	'MULLERGREN - SPEARVILLE 230KV CKT 1'	355.3	0.1177	114.2161	'POST ROCK - SPEARVILLE 345KV CKT 1 &CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 2'
FDNS	03G10_045			1	13G	G10_045	'TO->FROM'	'MULLERGREN - SPEARVILLE 230KV CKT 1'	355.3	0.1067	105.5741	'POST ROCK - SPEARVILLE 345KV CKT 1 &G05-12 345.00 - SPEARVILLE 345KV CKT 1'
FDNS	03G10_045			1	13G	G10_045	'TO->FROM'	'MULLERGREN - SPEARVILLE 230KV CKT 1'	355.3	0.1067	105.3445	'POST ROCK - SPEARVILLE 345KV CKT 1 &G06-06 345.00 - SPEARVILLE 345KV CKT 1'
FDNS	03G10_045			1	13G	G10_045	'TO->FROM'	'MULLERGREN - SPEARVILLE 230KV CKT 1'	355.3	0.1067	105.2771	'POST ROCK - SPEARVILLE 345KV CKT 1 &G08-124 345.00 - SPEARVILLE 345KV CKT 1'
FDNS	03G10_045			1	13G	G10_045	'TO->FROM'	'MULLERGREN - SPEARVILLE 230KV CKT 1'	355.3	0.1067	105.2746	'POST ROCK - SPEARVILLE 345KV CKT 1 &G10-15 345.00 - SPEARVILLE 345KV CKT 1'
FDNS	03G10_045			1	13G	G10_045	'TO->FROM'	'MULLERGREN - SPEARVILLE 230KV CKT 1'	355.3	0.0985	100.4288	'POST ROCK - SPEARVILLE 345KV CKT 1 &AXTELL - POST ROCK 345KV CKT 1'
FDNS	06G10_046			1	13G	G10_046	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0386	116.6564	'NORTHWEST - SPRING CREEK 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
FDNS	06G10_046			1	13G	G10_046	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0387	115.4011	'ARCADIA - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
FDNS	06G10_046			1	13G	G10_046	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0386	115.2051	'CIMARRON - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
FDNS	06G10_046			1	13G	G10_046	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0388	111.6629	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
FDNS	06G10_046			1	13G	G10_046	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0388	111.3198	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'
FDNS	06G10_046			1	13G	G10_046	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0388	110.1751	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'
FDNS	06G10_046			1	13G	G10_046	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0493	109.3634	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
FDNS	06G10_046			1	13G	G10_046	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0493	109.3634	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2'
FDNS	06G10_046			1	13G	G10_046	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0361	101.0884	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
FDNS	00G10_046			1	23SP	G10_046	'FROM->TO'	'JONES STATION - LUBBOCK SOUTH INTERCHANGE 230KV CKT 1'	502	0.0388	104.2745	'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
FDNS		0		1	23SP	G10_046	'FROM->TO'	'JONES STATION - LUBBOCK SOUTH INTERCHANGE 230KV CKT 1'	502	0.0388	104.2691	'Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2 &Jones Station Bus#2 - LUBBOCK EAST INTERCHANGE 230KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0313	125.417	'NORTHWEST - SPRING CREEK 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0309	123.9516	'ARCADIA - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0309	123.8168	'CIMARRON - NORTHWEST 345KV CKT 1 &NORTHWEST - TATONGA7 345.00 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	120.2819	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	119.9817	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	118.8104	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0363	115.7508	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0305	111.4805	'THISTLE7 345.00 - WICHITA 345KV CKT 1 &THISTLE7 345.00 - WICHITA 345KV CKT 2'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	107.3012	'NORTHWEST - TATONGA7 345.00 345KV CKT 1 &TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	107.0432	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G08-19 345.00 - TATONGA7 345.00 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	107.018	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &CRSRDSW7 345.00 - TATONGA7 345.00 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.031	107.0153	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &G07-21 345.00 - TATONGA7 345.00 345KV CKT 1'
FDNS	04G10_048			1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0305	103.72	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 &Hitchland Interchange - WOODWARD DISTRICT EHV 345KV CKT 2'

EVENTTYPE	SOLUTIONTYPE	GROUP	SCENARIO	SEASON	SOURCE	DIRECTION	MONITORED ELEMENT	RATEB		TC%LOADING		CONTINGENCY
								(MVA)	TDF	(%MVA)		
	FDNS	04G10_048		1	13G	G10_048	'TO->FROM'	'FPL SWITCH - WOODWARD 138KV CKT 1'	153	0.0305	101.9724	'TATONGA7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 & BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1'
	FDNS	04G10_048		1	13G	G10_048	'FROM->TO'	'HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1'	336	0.0458	101.4513	'HOLCOMB - SETAB 345KV CKT 1 & MINGO - SETAB 345KV CKT 1'
	FDNS	04G10_048		1	13G	G10_048	'FROM->TO'	'HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1'	336	0.0458	100.9448	'HOLCOMB - SETAB 345KV CKT 1 & MINGO - SETAB 345KV CKT 1'
	FDNS	04G10_048		1	13G	G10_048	'FROM->TO'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.1392	104.2711	'CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1 & CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'
	FDNS	04NR		1	13G	G10_048	'FROM->TO'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.0496	104.243	'CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1 & CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2'
	FDNS	04G10_048		1	13G	G10_048	'FROM->TO'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.1392	104.1251	'CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1 & CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 2'
	FDNS	04NR		1	13G	G10_048	'FROM->TO'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.0496	104.097	'CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1 & CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 2'
	FDNS	04G10_048		1	13G	G10_048	'FROM->TO'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.2294	101.1918	'POST ROCK - SPEARVILLE 345KV CKT 1 & AXTELL - POST ROCK 345KV CKT 1'
	FDNS	04NR		1	13G	G10_048	'FROM->TO'	'SMOKYHL6 230.00 - SUMMIT 230KV CKT 1'	319	0.19	101.1462	'POST ROCK - SPEARVILLE 345KV CKT 1 & AXTELL - POST ROCK 345KV CKT 1'
	FDNS	00G10_051		1	23SP	G10_051	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0573	103.7393	'KCPL-C2'
	FDNS	00G10_051		1	23SP	G10_051	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0573	103.0267	'KCPLB-6'
	FDNS	00G10_051		1	23SP	G10_051	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0573	102.0822	'KCPL-C2'
	FDNS	0		1	23SP	G10_051	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0573	102.0369	'KCPL-C2'
	FDNS	00G10_051		1	18SP	G10_051	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.062	101.8483	'KCPL-C2'
	FDNS	00G10_051		1	23SP	G10_051	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0573	101.379	'KCPLB-6'
	FDNS	0		1	23SP	G10_051	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0573	101.3191	'KCPLB-6'
	FDNS	00G10_051		1	18SP	G10_051	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.062	101.1321	'KCPLB-6'
	FDNS	0		1	23SP	G10_051	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.0573	100.4277	'KCPL-C2'
	FDNS	00G10_051		1	18SP	G10_051	'FROM->TO'	'NASHUA (NASH 11) 345/161/13.8KV TRANSFORMER CKT 11'	660	0.062	100.235	'KCPL-C2'