

# Screening Study SPP-DPT-2010-002

For OASIS Request #74299038

MAINTAINED BY  
SPP Engineering, SPP Transmission Service Studies  
Original September 10, 2010  
Rev 1 November 3, 2010  
Rev 2 November 4, 2010

*Copyright © 2010 by Southwest Power Pool, Inc. All rights reserved.*



# Table of Contents

<b>Executive Summary .....</b>	<b>3</b>
<b>Introduction.....</b>	<b>4</b>
<b>Study Methodology .....</b>	<b>5</b>
Description .....	5
Model Updates .....	6
Transmission Request Modeling.....	6
Transfer Analysis.....	7
<b>Study Results.....</b>	<b>8</b>
Study Analysis Results.....	8
<b>Conclusion .....</b>	<b>9</b>
<b>Appendix A.....</b>	<b>10</b>

## Executive Summary

AEPM has requested a screening study to determine the impacts on SPP and first-tier third party facilities due to a Delivery Point Transfer of 14 MW. Third party includes both first-tier neighboring facilities outside SPP and Transmission Owner facilities within SPP that are not under the SPP OATT. The service type requested for this screening study is Delivery Point Transfer (DPT). The period of the service requested is from 2/01/2011 to 2/01/2031.

The principal objective of this study is to identify system problems and potential system modifications necessary to facilitate the DPT request while maintaining system reliability. The DPT request was studied using two system scenarios. The service was modeled by a transfer from the CSWS to OKGE and from SPA to CSWS. The two scenarios were studied to capture system limitations caused or impacted by the requested service. An analysis was conducted on the planning horizon from 2/01/2011 to 2/01/2031.

The service was modeled from the CSWS to OKGE and from SPA to CSWS. The requested service does not significantly impact facilities on the SPP system or first-tier third party systems. Tables 1 and 2 summarize the results of the screening study analysis for the new source location for the scenarios listed in the table. Table 1 lists SPP and first-tier third party thermal transfer limitations identified. Table 2 lists SPP and first-tier third party voltage transfer limitations identified. Table 3 lists the network upgrades required to mitigate the limitations impacted by this request. Table 4 lists the potential redispatch relief pairs to prevent deferral of service, if applicable.

## Introduction

AEPM has requested a screening study to determine the impacts on SPP and first-tier third party facilities for a Delivery Point Transfer of 14 MW. The principal objective of this study is to identify the constraints on the SPP and first-tier third party transmission systems that may limit the requested service and to determine the potential least cost solutions required to alleviate the limiting facilities.

This study includes steady-state contingency analysis (PSS/E function ACCC). The steady-state analysis considers the impact of the request on transmission line and transformer loadings, and bus voltages for outages of single transmission lines, transformers, and generating units, and selected multiple transmission lines and transformers on the SPP and first-tier third party systems.

The DPT request was studied using two system scenarios. The service was modeled by a transfer from CSWS to OKGE and from SPA to CSWS. The two scenarios were studied to capture the system limitations caused or impacted by the requested service. Scenario 0 includes projected usage of transmission service included in the SPP 2010 Series Cases. Scenario 5 includes transmission service not already included in the SPP 2010 Series Cases.

## Study Methodology

### Description

The facility study analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier non-SPP control area systems. The steady-state analysis was performed to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled. SPP conforms to NERC Reliability Standards, which provide strict requirements related to voltage violations and thermal overloads during normal conditions and during a contingency. NERC Standards require all facilities to be within normal operating ratings for normal system conditions and within emergency ratings after a contingency.

Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP Model Development Working Group (MDWG) models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 105% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 103.5% and 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69 kV and above; first tier non-SPP control area branches and ties 115 kV and above; any defined contingencies for these control areas; and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier non-SPP control area branches and ties 115 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier non-SPP control area facilities, a 3 % TDF cutoff was applied to AECL, AMRN (Ameren), and ENTR (Entergy) control areas. A 2 % TDF cutoff was

applied to WAPA. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

### **Model Updates**

SPP used eight seasonal models to study the 14 MW DPT request for the requested service period. The following SPP Transmission Expansion Plan 2010 Build 2 Cases were used to study the impact of the requested service on the transmission system:

- 2010/11 Winter Peak (10WP)
- 2011 Summer Peak (11SP)
- 2011/12 Winter Peak (11WP)
- 2012 Summer Peak (12SP)
- 2012/13 Winter Peak (12WP)
- 2016 Summer Peak (16SP)
- 2016/17 Winter Peak (16WP)
- 2021 Summer Peak (21SP)

The Spring Peak models apply to April and May, the Summer Peak models apply to June through September, the Fall Peak models apply to October and November, and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the current modeling information. From the eight seasonal models, two system scenarios were developed. Scenario 0 includes projected usage of transmission included in the SPP 2010 Series Cases. Scenario 5 includes transmission not already included in the SPP 2010 Series Cases.

### **Transmission Request Modeling**

Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation because the requested Network Integration Transmission Service is a request to serve network load with the new designated network resource, and the impacts on the Transmission System are determined accordingly. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the request source and redispatching the request sink.

## **Transfer Analysis**

Using the selected cases both with and without the requested transfer modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs (SPP and 1<sup>st</sup>-Tier) and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

## Study Results

### Study Analysis Results

Tables 1 and 2 contain the initial steady-state analysis results of the DPT. The tables are attached to the end of this report, if applicable. The tables identify the scenario and season in which the event occurred, the transfer amount studied, the facility control area location, applicable ratings of the thermal transfer limitations and voltage transfer limitations, and the loading percentage and voltage per unit (pu).

Table 1 lists the SPP and first-tier third party thermal transfer limitations caused or impacted by the 14 MW transfer for applicable scenarios. Solutions are identified for the limitations in this table.

Table 2 lists the SPP and first-tier third party voltage transfer limitations caused or impacted by the 14 MW transfer for applicable scenarios. Solutions are identified for the violations in this table.

Table 3 lists the network upgrades required to mitigate the limitations caused or impacted by this request. Engineering and construction costs are provided for assigned upgrades in this table.

Table 4 lists the potential redispatch relief pairs to prevent deferral of service.



## **Conclusion**

The results of the screening study show that limiting constraints do not exist on the SPP system for the 14 MW DPT. No new impacts were identified for the requested term of this DPT. Since no additional limitations were identified, the request will be accepted. Once the request has been confirmed, SPP will issue a revised service agreement.

## Appendix A

### PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

#### BASE CASES:

- Solutions: Fixed slope decoupled Newton-Raphson solution (FDNS)
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads
- VAR limits: Apply immediately
- Solution options:
  - Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

#### ACCC CASES for system intact:

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- Contingency case rating: Rate A
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3 MW
- Excl'd cases w/ no overloads form report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads
- VAR limits: Apply automatically
- Solution options:
  - Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

#### ACCC CASES for branch and transformer contingencies:

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary

- Min flow change in overload report: 3mw
- Excluded cases w/ no overloads form report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads
- VAR limits: Apply automatically
- Solution options:
  - X Phase shift adjustment
  - \_ Flat start
  - \_ Lock DC taps
  - \_ Lock switched shunts

**ACCC CASES for generator contingencies (largest machine at a bus):**

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3mw
- Excluded cases w/ no overloads form report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Disabled
- Var limits: Apply automatically
- Solution options:
  - X Phase shift adjustment
  - \_ Flat start
  - \_ Lock DC taps
  - \_ Lock switched shunts

Table 1- SPP Facility Thermal Transfer Limitations Caused by the 14 MW Transfer

Scenario	Season	From Area	To Area	Monitored Branch Over 100% Rate B	Base Case Loading (%)	Transfer Case Loading (%)	TDF (%)	Outaged Branch Causing Overload	Upgrade Name	Solution
				None						

Table 2- SPP Facility Voltage Transfer Limitations Caused by the 14 MW Transfer

Scenario	Season	Area	Monitored Bus with Violation	Post-transfer Voltage (PU)	Outaged Branch Causing Overload	Upgrade Name	Solution
			None				

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	NTC
	None				

Limitations were not identified; therefore, redispatch was not calculated.