



# Feasibility Cluster Study for Generation Interconnection Requests (FCS-2011-002-1)

August 2011

Tariff Studies – Generation Interconnection

---

## Revision History

---

Date or Version Number	Author	Change Description	Comments
06/28/2011	Southwest Power Pool	N/A	Report Issued
8/19/2011	Southwest Power Pool	Report reposted for Incorrect Generator Size for GEN-2011-031	Report Posted

---

## Executive Summary

---

Generation Interconnection customers have requested a Feasibility Study under the Generation Interconnection Procedures (GIP) in the Southwest Power Pool Open Access Transmission Tariff (OATT). The Interconnection Customers' requests have been clustered together for the following Feasibility Cluster Study. This Feasibility Cluster Study analyzes the interconnecting of multiple generation interconnection requests associated with new generation totaling approximately 2,227 MW of new generation which would be located within the transmission systems of Midwest Energy Inc. (MIDW), Missouri Public Service (MIPU), Southwestern Public Service (SPS), and Sunflower Electric Power Corporation (SUNC). The various generation interconnection requests have differing proposed in-service dates<sup>1</sup>. The generation interconnection requests included in this Feasibility Cluster Study are listed in Appendix A by their queue number, amount, requested interconnection service, area, requested interconnection point, proposed interconnection point, and the requested in-service date.

Power flow analysis has indicated that for the power flow cases studied, 2,227 MW of nameplate generation may be interconnected with transmission system reinforcements within the SPP transmission system. The need for reactive compensation in accordance with Order No. 661-A for wind farm interconnection requests will be evaluated in the Interconnection System Impact Study based on the wind turbine manufacturer and type requested by the Customer. Dynamic stability studies performed as part of the System Impact Cluster Study will provide additional guidance as to whether the required reactive compensation can be static or a portion must be dynamic (such as a SVC).

The total estimated minimum cost for interconnecting the studied generation interconnection request is \$187,700,000. These costs are shown in Appendix E. These costs do not include the Interconnection Customer Interconnection Facilities as defined by the SPP Open Access Transmission Tariff (OATT). This cost does not include the possible need for reactive compensation or additional interconnection facilities or network upgrades that may be identified through additional analyses performed in the Preliminary Interconnection System Impact Study (PISIS).

Network Constraints listed in Appendix F are in the local area of the new generation when this generation is injected throughout the SPP footprint for the Energy Resource (ER) Interconnection Request. Certain interconnection requests have been studied for Network Resource (NR) Interconnection Service. Additional Network constraints will have to be verified with a Transmission Service Request (TSR) and associated studies. With a defined source and sink in a TSR, this list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

The required interconnection costs listed in Appendix E does not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT.

---

<sup>1</sup> The generation interconnection requests in-service dates will need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customer's that proceed to the Facility Study will be provided a new in-service date based on the competition of the Facility Study.

---

## Table of Contents

---

<b>Revision History</b> .....	<b>1</b>
<b>Executive Summary</b> .....	<b>2</b>
<b>Table of Contents</b> .....	<b>3</b>
<b>Introduction</b> .....	<b>4</b>
<b>Model Development</b> .....	<b>4</b>
Interconnection Requests Included in the Cluster .....	4
Electrically Isolated Interconnection Requests.....	4
Previous Queued Projects.....	4
Development of Base Cases.....	4
Base Case Upgrades.....	5
Contingent Upgrades .....	6
Regional Groupings.....	7
<b>Identification of Network Constraints</b> .....	<b>7</b>
<b>Determination of Cost Allocated Network Upgrades</b> .....	<b>8</b>
Credits for Amounts Advanced for Network Upgrades .....	8
<b>Interconnection Facilities</b> .....	<b>9</b>
<b>Powerflow Analysis Methodology</b> .....	<b>9</b>
<b>Powerflow Analysis</b> .....	<b>10</b>
<b>Conclusion</b> .....	<b>12</b>
<b>Appendix</b> .....	<b>13</b>
A: Generation Interconnection Requests Considered for Feasibility Study .....	14
B: Prior Queued Interconnection Requests .....	15
C: Study Groupings .....	20
D: Proposed Point of Interconnection One line Diagrams.....	27
E: Cost Allocation per Interconnection Request.....	31
F: FCITC Analysis (No Upgrades) .....	32

---

## Introduction

---

Generation Interconnection customers have requested a Feasibility Study under the Generation Interconnection Procedures (GIP) in the Southwest Power Pool Open Access Transmission Tariff (OATT). The Interconnection Customers' requests have been clustered together for the following Feasibility Cluster Study. This Feasibility Cluster Study analyzes the interconnecting of multiple generation interconnection requests associated with new generation totaling approximately 2,227 MW of new generation which would be located within the transmission systems of Midwest Energy Inc. (MIDW), Missouri Public Service (MIPU), Southwestern Public Service (SPS), and Sunflower Electric Power Corporation (SUNC). The various generation interconnection requests have differing proposed in-service dates<sup>2</sup>. The generation interconnection requests included in this Feasibility Cluster Study are listed in Appendix A by their queue number, amount, area, requested interconnection service, requested interconnection point, proposed interconnection point, and the requested in-service date.

The primary objective of this Feasibility Cluster Study is to identify the system constraints associated with connecting the generation to the area transmission system. The Feasibility and other subsequent Interconnection Studies are designed to identify attachment facilities, Network Upgrades and other Direct Assignment Facilities needed to accept power into the grid at each specific interconnection receipt point.

---

## Model Development

---

**Interconnection Requests Included in the Cluster** – SPP has included the interconnection requests listed in Appendix A to be analyzed in this cluster study. These interconnection requests represent requests with an executed Feasibility Study Agreement signed by 03/30/2011.

**Electrically Isolated Interconnection Requests** – Electrically isolated requests are discussed in the “Regional Groupings” section.

**Previous Queued Projects** - The previous queued projects included in this study are listed in Appendix B. In addition to the Base Case Upgrades, the previous queued projects were assumed to be in-service and added to the Base Case models. These projects were dispatched as Energy Resources with equal distribution across the SPP footprint.

**Development of Base Cases** - The 2010 series Transmission Service Request (TSR) Models 2011 spring, 2011 summer and winter, and 2016 summer and winter scenario 0 peak cases were used for this study. After the cases were developed, each of the control areas' resources were then redispatched using current dispatch orders.

---

<sup>2</sup> The generation interconnection requests in-service dates will need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customer's that proceed to the Facility Study will be provided a new in-service date based on the competition of the Facility Study.

**Base Case Upgrades** - The following facilities are part of the SPP Transmission Expansion Plan, Balanced Portfolio, or Priority Projects. These facilities have been approved or are in the construction stages and were assumed to be in-service at the time of dispatch and added to the base case models. The FCS-2011-002 Customers do not have cost for the below listed projects. **However, the FCS-2011-002 Customer Generation Facilities in service dated may need to be delayed until the completion of the following upgrades (See Appendix A for more detail).** If for some reason, construction on these projects is discontinued, additional restudies will be needed to determine the interconnection needs of the FCS-2011-002 customers.

- Hitchland 345/230/115kV upgrades to be built by SPS for 2010/2011 in-service<sup>3</sup>.
  - Hitchland – Moore County 230kV line
  - Hitchland – Perryton 230kV line
  - Hitchland – Texas County 115kV line
  - Hitchland – Hansford County 115kV line
  - Hitchland – Sherman County Tap 115kV line
- Valliant – Hugo – Sunnyside 345kV – assigned to Aggregate Study AG3-2006 Customers.
- Wichita – Reno County – Summit 345kV to be built by WERE<sup>4</sup>.
- Rose Hill – Sooner 345kV to be built by WERE/OKGE.
- Knob Hill – Steele City 115kV to be built by NPPD/WERE.
- Balanced Portfolio Projects<sup>5</sup>:
  - Gracemont 345/138/13.2kV Autotransformer
  - Woodward– Tuco 345kV line
  - Iatan– Nashua 345kV line
  - Muskogee– Seminole 345kV line
  - Post Rock – Axtell 345kV line
  - Spearville– Post Rock 345kV line
  - Tap Stillwell – Swissvale 345kV line at West Gardner
- Priority Projects<sup>6</sup>:
  - Hitchland - Woodward double circuit 345kV
  - Woodward – Medicine Lodge double circuit 345kV
  - Spearville – Comanche (Clark) double circuit 345kV
  - Comanche (Clark) – Medicine Lodge double circuit 345kV
  - Medicine Lodge – Wichita double circuit 345kV
  - Medicine Lodge 345/138kV autotransformer

---

<sup>3</sup> Approved 230kV upgrades are based on SPP 2007 STEP. Upgrades may need to be re-evaluated in the system impact study.

<sup>4</sup> Approved based on an order of the Kansas Corporation Commission issued in Docket no. 07-WSEE-715-MIS

<sup>5</sup> Notice to Construct (NTC) issued June, 2009

<sup>6</sup> Notice to Construct (NTC) issued June, 2010. NTC for double circuit lines indicated that NTC may be revised at a later time to be built at a higher voltage.

**Contingent Upgrades** - The following facilities do not yet have approval. These facilities have been assigned to higher queued interconnection customers. These facilities have been included in the models for the FCS-2011-002 study and are assumed to be in service. The FCS-2011-002 Customers at this time do not have responsibility for these facilities but may later be assigned the cost of these facilities if higher queued customers terminate their GIA, withdraw from the interconnection queue, or withdraw from NRIS interconnection queue. The FCS-2011-002 Customer Generation Facilities in service dates may need to be delayed until the completion of the following upgrades.

- Finney – Holcomb 345kV ckt #2 line assigned to GEN-2006-044 interconnection customer. This customer is currently in suspension<sup>7</sup>.
- Central Plains – Setab 115kV transmission line assigned to GEN-2007-013 interconnection customer.
- Grassland 230/115kV autotransformer #2 assigned to 1<sup>st</sup> Cluster Interconnection Customers (100% to GEN-2008-016)
- Judson Large – North Judson Large – Spearville Ckt #2 assigned to DISIS-2009-001-1 Interconnection Customers (100% to GEN-2008-079)
- Hitchland – Wheeler (Border) double circuit 345kV assigned to DISIS-2010-001 Interconnection Customers
- Madison County - Hoskins 230kV Ckt #1 assigned to DISIS-2010-001 Interconnection Customers
- Washita – Gracemont 138kV Ckt #2 assigned to DISIS-2010-001 Interconnection Customers
- Post Rock 345/230kV autotransformer #2 assigned to DISIS-2010-001 Interconnection Customers
- Washita – Weatherford 138kV Ckt #1 assigned to DISIS-2010-001 Interconnection Customers
- Spearville 345/115kV autotransformer #1 assigned to DISIS-2010-001 Interconnection Customers
- Beaver County – Gray County 345kV Ckt #1 assigned to DISIS-2010-002 Interconnection Customers
- Circle – Reno double circuit 345kV assigned to DISIS-2010-002 Interconnection Customers
- Medicine Lodge 345/115kV autotransformer #1 assigned to DISIS-2010-002 Interconnection Customers
- Mullergren – Circle double circuit 345kV assigned to DISIS-2010-002 Interconnection Customers
- Spearville – Mullergren double circuit 345kV assigned to DISIS-2010-002 Interconnection Customers
- St. John – St. John 115kV Ckt #1 assigned to DISIS-2010-002 Interconnection Customers
- Northwest 345/138/13.8kV autotransformer Ckt #1 assigned to DISIS-2010-002 NRIS Interconnection Customer Gen-2010-040

**Potential Upgrades Not in the Base Case** - Any potential upgrades that do not have a Notification to Construct (NTC) to construct have not been included in the base case. These upgrades include any identified in the SPP Extra-High Voltage (EHV) overlay plan, or any other SPP planning study other than the upgrades listed above in the previous section.

---

<sup>7</sup> Based on Facility Study Posting November 2008

**Regional Groupings** - The interconnection requests listed in Appendix A were grouped together in four different regional groups based on geographical and electrical impacts. These groupings are shown in Appendix C.

To determine interconnection impacts, four different dispatch variations of the spring base case models were developed to accommodate the regional groupings.

For each group, the various wind generating plants were modeled at 80% nameplate of maximum generation. The wind generating plants in the other areas were modeled at 20% nameplate of maximum generation. This process created four different scenarios with each group being studied at 80% nameplate rating. These projects were dispatched as Energy Resources with equal distribution across the SPP footprint. Certain projects that requested Network Resource Interconnection Service were dispatched in an additional analysis into the balancing authority of the interconnecting transmission owner. This method allowed for the identification of network constraints that were common to the regional groupings that could then in turn have the mitigating upgrade cost allocated throughout the entire cluster. Each interconnection request was also modeled separately at 100% nameplate for certain analyses.

Peaking units were not dispatched in the 2010 spring model. To study peaking units' impacts, the 2016 summer peak model was chosen and peaking units were modeled at 100% of the nameplate rating and wind generating facilities were modeled at 10% of the nameplate rating. Each interconnection request was also modeled separately at 100% nameplate for certain analyses.

---

## Identification of Network Constraints

---

The initial set of network constraints were found by using PTI MUST First Contingency Incremental Transfer Capability (FCITC) analysis on the entire cluster grouping dispatched at the various levels mentioned above. These constraints were then screened to determine if any of the generation interconnection requests had at least a 20% Distribution Factor (DF) upon the constraint. Constraints that measured at least a 20% DF from at least one interconnection request were considered for mitigation. Interconnection Requests that were being studied for Network Resource Interconnection Service were studied in the additional NRIS analysis to determine if any constraint had at least a 3% DF. If so, these constraints were considered for mitigation.

**Identification of Electrically Isolated Groups and Requests** – From the FCITC analysis, it was determined that some of the regional groups had no common impacts with the other groups. However, this determination may change as the Interconnection Customers depending upon the time at which the interconnection customers enter either the Preliminary Interconnection System Impact Study (PISIS) or the Definitive Interconnection System Impact Study (DISIS).

## Determination of Cost Allocated Network Upgrades

Cost Allocated Network Upgrades of wind generation interconnection requests were determined using the 2011 spring model. Cost Allocated Network Upgrades of peaking units was determined using the 2016 summer peak model. Once a determination of the required Network Upgrades was made, a powerflow model of the 2011 spring case was developed with all cost allocated Network Upgrades in-service. A MUST FCITC analysis was performed to determine the Power Transfer Distribution Factors (PTDF), a distribution factor with no contingency that each generation interconnection request had on each new upgrade. The impact each generation interconnection request had on each upgrade project was weighted by the size of each request. Finally the costs due by each request for a particular project were then determined by allocating the portion of each request’s impact over the impact of all affecting requests.

For example, assume that there are three Generation Interconnection requests, X, Y, and Z that are responsible for the costs of Upgrade Project ‘1’. Given that their respective PTDF for the project have been determined, the cost allocation for Generation Interconnection request ‘X’ for Upgrade Project 1 is found by the following set of steps and formulas:

- Determine an Impact Factor on a given project for all responsible GI requests:

$$\text{Request X Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(X) * \text{MW}(X) = X1$$

$$\text{Request Y Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Y) * \text{MW}(Y) = Y1$$

$$\text{Request Z Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Z) * \text{MW}(Z) = Z1$$

- Determine each request's Allocation of Cost for that particular project:

$$\text{Request X's Project 1 Cost Allocation} (\$) = \frac{\text{Network Upgrade Project 1 Cost}(\$) * X1}{X1 + Y1 + Z1}$$

- Repeat previous for each responsible GI request for each Project

The cost allocation of each needed Network Upgrade is determined by the size of each request and its impact on the given project. This allows for the most efficient and reasonable mechanism for sharing the costs of upgrades.

**Credits for Amounts Advanced for Network Upgrades** - Interconnection Customer shall be entitled to credits in accordance with Attachment Z1 of the SPP Tariff for any Network Upgrades including any tax gross-up or any other tax-related payments associated with the Network Upgrades, and not refunded to the Interconnection Customer.

---

## Interconnection Facilities

---

The requirement to interconnect the 2,227 MW of generation into the existing and proposed transmission systems in the affected areas of the SPP transmission footprint consist of the necessary cost allocated shared facilities listed in Appendix E with an approximate cost of \$187,700,000. Appendix E also includes Interconnection Facilities specific to each generation interconnection request.

A list of constraints with greater than or equal to a 20% OTDF that were identified and used for mitigation are listed in Appendix F. Other Network Constraints in the AEPW, MIDW, OKGE, SPS, MIPU, NPPD, SUNC, MKEC, WERE, and WFEC transmission systems that were identified that may be needed to deliver to load are listed in Appendix F. With a defined source and sink in a TSR, a list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

A preliminary one-line drawing for each generation interconnection request are listed in Appendix D.

---

## Power flow Analysis Methodology

---

The Southwest Power Pool (SPP) Criteria states that:

“The transmission system of the SPP region shall be planned and constructed so that the contingencies as set forth in the Criteria will meet the applicable *NERC Reliability Standards* for transmission planning. All MDWG power flow models shall be tested to verify compliance with the System Performance Standards from NERC Table 1 – Category A.”

The FCITC function of MUST was used to simulate single contingencies in portions or all of the modeled control areas of AEPW, EMDE, Grand River Dam Authority (GRDA), Kansas City Power & Light (KCPL), LES, MIDW, MIPU, NPPD, OPPD, OKGE, SPS, SUNC, WERE, WFEC and other control areas were applied and the resulting scenarios analyzed. This satisfies the “more probable” contingency testing criteria mandated by NERC and the SPP criteria.

---

## Powerflow Analysis

---

A powerflow analysis was conducted for each Interconnection Customer's facility using modified versions of the 2011 (spring, summer, and winter) peak models and the 2016 (summer and winter) peak models. The output of the Interconnection Customer's facility was offset in each model by a reduction in output of existing online SPP generation. This method allows the request to be studied as an Energy Resource (ER) Interconnection Request. The available seasonal models used were through the 2016 Winter Peak. Certain requests that requested Network Resource Interconnection Service (NRIS) had an additional analysis conducted for sinking the energy in the interconnecting Transmission Owner's balancing authority.

This analysis was conducted assuming that previous queued requests in the immediate area of these interconnect requests were in-service. The analysis of each Customer's project indicates that additional criteria violations will occur on the AEPW, MIDW, MIPU, NPPD, OKGE, SPS, SUNC, SWPA, MKEC, WERE, and WFEC transmission systems under steady state and contingency conditions in the peak seasons.

The need for reactive compensation will be determined during the Interconnection System Impact Study. The need for reactive compensation will be based on the Interconnection Customer's choice of wind turbine make and manufacturer. Dynamic Stability studies performed as part of the System Impact Cluster Study will provide additional guidance as to whether the reactive compensation can be static or a portion must be dynamic (such as a SVC or STATCOM). It is possible that an SVC or STATCOM device will be required at the Customer facility because of FERC Order 661A Low Voltage Ride-Through Provisions (LVRT) which went into effect January 1, 2006. FERC Order 661A orders that wind farms stay on-line for 3-phase faults at the point of interconnection even if that requires the installation of a SVC or STATCOM device.

**Hitchland Area** – The Hitchland group had 300.8 MW of interconnection requests in addition to the 4,436.3 MW of previously queued generation in the area. No additional constraints were observed in this area. This determination is depended on higher queued customers paying for certain upgrades. Withdrawal of higher queued customers may change this result.

**Spearville Area** – The Spearville group had 1,030 MW of interconnection requests in addition to the 5,626.7 MW of previously queued generation in the area. No additional constraints were observed in this area. This determination is depended on higher queued customers paying for certain upgrades. Withdrawal of higher queued customers may change this result.

**South Panhandle/New Mexico Area** – There are approximately 195.6 MW of interconnection requests in the southern panhandle area in addition to the 2,566.3 MW of previously queued generation in the area. Certain higher queued interconnection requests withdrew since the posting of the original study. As a result, the Group 6 interconnection request was seen to cause constraints for the loss of the Midland-Hobbs 230kV transmission line. The mitigation is to construct a new 230kV line (insulated at 345kV) to the SPS Borden substation.

**Southwest Oklahoma Area** - The Southwest Oklahoma group had 200 MW of interconnection requests in addition to the 2,895.8 MW of previously queued generation in the area. The major constraint in the Southwest Oklahoma area was noticed on the Rush Springs Tap – OMPA Marlow – OMPA Duncan – Duncan Eastside – AEPW Duncan transmission line. To mitigate this constraint, the entire section will need to be rebuilt. Other constraints were seen on the Duncan – Tosco – Comanche 69kV line and the entire section will also need to be rebuilt and a second

138/69kV transformer installed at Duncan. In addition, the switches on the Cornville – Rush Springs Natural Gas Tap 138kV transmission line switches will need to be replaced due to overloads on the line.

**North Oklahoma Area** - The North Oklahoma area had 350.4MW of interconnection requests in addition to the 3,356 MW of previously queued generation in the area. The major constraint noticed in this area was caused by GEN-2011-006 overloading the Shidler – West Pawhuska 138kV transmission line. To mitigate the constraint, a new 138kV transmission line from Hominy – Shidler will need to be built as well as rebuilding the line section to Sand Springs

**Nebraska Area** - The Nebraska area had 150.4MW of interconnection requests in addition to the 1,259.8 MW of previously queued generation in the area. No additional constraints were observed in this area.

---

## Conclusion

---

The minimum cost of interconnecting all of the interconnection requests included in the Feasibility Cluster Study is estimated at \$187,700,000 for the Allocated Network Upgrades and Transmission Owner Interconnection Facilities are listed in Appendix E. These costs do not include the cost of upgrades of other transmission facilities listed in Appendix F which are Network Constraints.

These interconnection costs do not include any cost of Network Upgrades determined to be required by AC power flow, short circuit or transient stability analysis. These studies will be performed if the Interconnection Customer executes the appropriate Interconnection System Impact Study Agreement and provides the required data along with demonstration of Site Control and the appropriate deposit. At the time of the System Impact Cluster Study, a better determination of the interconnection facilities may be available.

The required interconnection costs listed in Appendix E, and other upgrades associated with Network Constraints do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request (TSR) through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP Open Access Transmission Tariff (OATT).

---

# Appendix

---

**A: Generation Interconnection Requests Considered for Feasibility Study**

Request	MW	Service	Area	Requested Point of Interconnection	Proposed Point of Interconnection	Requested In-Service Date	EARLIEST IN SERVICE DATE AVAILABLE**
GEN-2011-003	10	ER	MKEC	Tap Judson Large – Cudahy 115kV	GEN-2008-079 115kV	05/29/2012	Determined in Facility Study
GEN-2011-004	150.4	ER	WERE	Creswell 138kV	Creswell 138kV	12/31/2013	Determined in Facility Study
GEN-2011-005	150.4	ER/NR	NPPD	Rising City 115kV	Rising City 115kV	12/15/2013	Determined in Facility Study
GEN-2011-006	200	ER/NR	AEPW	Shidler 138kV	Shidler 138kV	06/01/2013	Determined in Facility Study
GEN-2011-028	300.8	ER/NR	OKGE	Tap Guymon – Woodward 345kV	Tap Guymon – Woodward 345kV	11/01/2014	12/31/2014
GEN-2011-029	200	ER/NR	WFEC	Tap Rush Springs (Nat. Gas) – Rush Springs (Marlow) 115kV	Tap Rush Springs (Nat. Gas) – Rush Springs (Marlow) 138kV	12/31/2013	Determined in Facility Study
GEN-2011-030	1020	ER	SUNC	Holcomb 345kV	Holcomb 345kV	06/01/2017	6/1/2017
GEN-2011-031	195.6	ER	SPS	Midland 230kV	Midland 230kV	12/31/2014	Determined in Facility Study
<b>TOTAL</b>	<b>2,227.2</b>						

\* Planned Facility

^ Proposed Facility

\*\* Interconnection Customer may be delayed until the completion of certain Base Case Upgrades. Interconnection Customer may explore the possibility of an earlier in service date with a Limited Operation Study available under GIA 5.9.

**B: Prior Queued Interconnection Requests**

Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2001-014	96	WFEC	Fort Supply 138kV	On-Line
GEN-2001-026	74	WFEC	Washita 138kV	On-Line
GEN-2001-033	180	SPS	San Juan Mesa Tap 230kV	On-Line
GEN-2001-036	80	SPS	Caprock Tap 115kV	On-Line
GEN-2001-037	100	OKGE	Windfarm Switching 138kV	On-Line
GEN-2001-039A	105	MKEC	Greensburg - Judson-Large 115kV	On Schedule for 2011
GEN-2001-039M	100	SUNC	Central Plains Tap 115kV	On-Line
GEN-2002-004	200	WERE	Latham 345kV	On-Line at 150MW
GEN-2002-005	120	WFEC	Red Hills Tap 138kV	On-Line
GEN-2002-008	240	SPS	*Hitchland 345kV	On-Line at 120MW
GEN-2002-009	80	SPS	Hansford County 115kV	On-Line
GEN-2002-022	240	SPS	Bushland 230kV	On-Line at 160MW
GEN-2002-025A	150	MKEC	Spearville 230kV	On-Line at 100.5MW
GEN-2003-005	100	WFEC	Anadarko - Paradise 138kV	On Line
GEN-2003-006A-E	100	MKEC	Elm Creek 230kV	On-Line
GEN-2003-006A-W	100	MKEC	Elm Creek 230kV	On-Line
GEN-2003-013**	198	SPS	*Hitchland - Finney 345kV	On Schedule for 2012
GEN-2003-019	250	MIDW	Smoky Hills Tap 230kV	On-Line
GEN-2003-020	160	SPS	Martin 115kV	On-Line at 80MW
GEN-2003-022	120	AEPW	Washita 138kV	On-Line
GEN-2004-014	154.5	MKEC	Spearville 230kV	On Schedule for 2012
GEN-2004-020	27	AEPW	Washita 138kV	On-Line
GEN-2005-005	18	OKGE	Windfarm Tap 138kV	IA Pending
GEN-2005-008	120	OKGE	Woodward 138kV	On-Line
GEN-2005-012	250	SUNC	Spearville 345kV	On Schedule for 2012
GEN-2005-013	201	WERE	Tap Latham - Neosho	On Schedule for 2012
GEN-2005-017	340	SPS	Tap *Hitchland - Potter County 345kV	On Suspension
GEN-2006-002	101	AEPW	Grapevine - Elk City 230kV	On-Line
GEN-2006-006	206	MKEC	Spearville 230kV	IA Pending
GEN-2006-014	300	MIPU	Tap Maryville – Clarinda and tie Midway (WFARMS) 161kV	On Suspension
GEN-2006-017	300	MIPU	Tap Maryville – Clarinda and tie Midway (WFARMS) 161kV	On Suspension
GEN-2006-018	170	SPS	Tuco 230kV	On Schedule for 2011
GEN-2006-020S	20	SPS	DWS Frisco Tap	On Schedule for 2011
GEN-2006-020N	42	NPPD	Bloomfield 115kV	1/1/2009
GEN-2006-021	101	MKEC	Flat Ridge Tap 138kV	On-Line
GEN-2006-022	150	MKEC	Ninnescah Tap 115kV	On Suspension
GEN-2006-024S	20	WFEC	South Buffalo Tap 69kV	On-Line
GEN-2006-026	502	SPS	Hobbs 230kV	On-Line
GEN-2006-031	75	MIDW	Knoll 115kV	On-Line
GEN-2006-032	200	MIDW	South Hays 230kV	On Suspension
GEN-2006-034	81	SUNC	Tap Kanarado - Sharon Springs 115kV	On Suspension
GEN-2006-035	225	AEPW	Tap Grapevine - Elk City 230kV	On Schedule for 2011
GEN-2006-037N1	75	NPPD	Broken Bow 115kV	On Suspension
GEN-2006-038N005	80	NPPD	Broken Bow 115kV	On Schedule for 2012
GEN-2006-038N019	80	NPPD	Petersburg 115kV	On-Line
GEN-2006-038	750	WFEC	Hugo 345kV	On Suspension

Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2006-039	400	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV	On Suspension
GEN-2006-040	108	SUNC	Mingo 115kV	On Schedule for 2010
GEN-2006-043	99	AEPW	Grapevine - Elk City 230kV	On Line
GEN-2006-044	370	SPS	*Hitchland 345kV	On Schedule for 2014
GEN-2006-044N	40.5	NPPD	Tap Neligh – Petersburg 115kV	On Schedule for 12/2011
GEN-2006-044N02	100.5	NPPD	GEN-2008-086N02 230kV	Under Study (DISIS-2010-001)
GEN-2006-045	240	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV	On Suspension
GEN-2006-046	131	OKGE	Dewey 138kV	On-Line
GEN-2006-047	240	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV	On Suspension
GEN-2006-049	400	SPS	*Hitchland - Finney 345kV	On Schedule for 2014
GEN-2007-002	160	SPS	Grapevine 115kV	On Suspension
GEN-2007-006	160	OKGE	Roman Nose 138kV	On Suspension
GEN-2007-011	135	SUNC	Syracuse 115kV	On Schedule
GEN-2007-011N08	81	NPPD	Bloomfield 115kV	On-Line
GEN-2007-013	99	SUNC	Selkirk 115kV	On Suspension
GEN-2007-015	135	WERE	Tap Humboldt – Kelly 161kV	On Suspension
GEN-2007-017	101	MIPU	Tap Maryville – Clarinda and tie Midway (WFARMS) 161kV	On Suspension
GEN-2007-021	201	OKGE	*Tatonga 345kV	On Schedule for 2014
GEN-2007-025	300	WERE	Tap Woodring – Wichita 345kV	On Schedule for 2012
GEN-2007-032	150	WFEC	Tap Clinton Junction – Clinton 138kV	On Schedule for 2012
GEN-2007-038	200	SUNC	Spearville 345kV	On Schedule for 2014
GEN-2007-040	200	SUNC	Tap Holcomb – Spearville 345kV	On Schedule for 2012
GEN-2007-043	200	OKGE	Tap Lawton Eastside – Cimarron 345kV	On-Line (100MW)
GEN-2007-044	300	OKGE	*Tatonga 345kV	On Schedule for 2014
GEN-2007-046	200	SPS	Tap & Tie Texas County – Hitchland & DWS Frisco Tap – Hitchland 115kV	On Schedule for 2014
GEN-2007-048	400	SPS	Tap Amarillo South – Swisher 230kV	On Schedule for 2014
GEN-2007-050	170	OKGE	*Woodward 138kV	On-Line at 150MW
GEN-2007-051	200	WFEC	Mooreland 138kV	On Schedule for 2014
GEN-2007-052	150	WFEC	Anadarko 138kV	On-Line
GEN-2007-053	110	MIPU	Tap Maryville – Clarinda and tie Midway (WFARMS) 161kV	On Schedule for 2013
GEN-2007-057	35	SPS	Moore County East 115kV	On Schedule for 2014
GEN-2007-062	765	OKGE	*Woodward 345kV	On Schedule for 2014
GEN-2008-003	101	OKGE	*Woodward EHV 138kV	On-Line
GEN-2008-008	60	SPS	Graham 115kV	On Schedule for 2014
GEN-2008-009	60	SPS	San Juan Mesa Tap 230kV	On Schedule for 2014
GEN-2008-013	300	OKGE	Tap Woodring – Wichita 345kV	On Schedule for 2013
GEN-2008-014	150	SPS	Tap Tuco – Oklaunion 345kV	On Schedule for 2014
GEN-2008-016	248	SPS	Grassland 230kV	IA Pending
GEN-2008-017	300	SUNC	Setab 345kV	On Schedule for 2014
GEN-2008-018	405	SUNC	Finney 345kV	IA Pending
GEN-2008-019**	300	OKGE	*Tatonga 345kV	On Schedule for 2015
GEN-2008-021	42	WERE	Wolf Creek 345kV	IA Pending
GEN-2008-022	300	SPS	Tap Eddy – GEN-2007-034 345kV	IA Pending
GEN-2008-023	150	AEPW	Hobart Junction 138kV	On Schedule for 2012
GEN-2008-025	101.2	SUNC	Ruleton 115kV	IA Pending
GEN-2008-029	250.5	OKGE	Woodward EHV 138kV	On Schedule for 2014
GEN-2008-037	100.8	WFEC	Tap Washita – Blue Canyon 138kV	IA Pending
GEN-2008-044	197.8	OKGE	Tatonga 345kV	On Schedule for 2011
GEN-2008-046	200	OKGE	Sunnyside 345kV	IA Pending

Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2008-047	300	SPS	Tap Hitchland - Woodward 345kV	IA Pending
GEN-2008-051	322	SPS	Potter 345kV	On Schedule for 2014
GEN-2008-071	76.8	OKGE	Newkirk 138kV	IA Pending
GEN-2008-079	100.5	MKEC	Tap Fort Dodge – Cudahy 115kV	IA Pending
GEN-2008-086N02	200	NPPD	Tap Ft. Randall – Columbus 230kV	On Schedule for 2014
GEN-2008-088	50.6	SPS	Vega 69kV	IA Pending
GEN-2008-092	201	MIDW	Knoll 115kV	IA Pending
GEN-2008-098	100.8	WERE	Tap Wolf Creek – LaCygne 345kV	IA Pending
GEN-2008-110	299.2	SPS	Hitchland 345kV	IA Pending
GEN-2008-1190	60	OPPD	Tap Humboldt – Kelly (North of GEN-2007-015) 161kV	On-Line
GEN-2008-123N	89.7	NPPD	Tap Guide - Pauline 115kV	IA Pending
GEN-2008-124	200.1	MKEC	Spearville 230kV	IA Pending
GEN-2008-127	200.1	WERE	Tap Sooner – Rose Hill 345kV	On Schedule for 2012
GEN-2008-129	80	MIPU	Pleasant Hill 161kV	On-Line
GEN-2009-008	200	SUNC	South Hays 230kV	IA Pending
GEN-2009-011	50	MKEC	Tap Plainville – Phillipsburg 115kV	IA Pending
GEN-2009-016	140	AEPW	Falcon Road 138kV	IA Pending
GEN-2009-017**	60	SPS	Tap Pembroke – Stiles 138kV	Under Study (DISIS-2009-001)
GEN-2009-020	48.6	MIDW	Tap Bazine – Nekoma 69kV	IA Pending
GEN-2009-025	60	OKGE	Tap Deer Creek – Sinclair 69kV	On Suspension
GEN-2009-030	100.8	WFEC	Weatherford 138kV	IA Pending
GEN-2009-040	73.8	WERE	Tap Smittyville - Knob Hill 115kV	IA Pending
GEN-2009-060	84	WFEC	Gotebo 69kV	IA Pending
GEN-2009-062	115	SUNC	Hugoton 115kV	IA Pending
GEN-2009-067S	20	SPS	7 Rivers 69kV	IA Pending
GEN-2010-001	300	WFEC	Tap Woodward – Hitchland 230kV	Under Study (DISIS-2010-002)
GEN-2010-003	100.8	WERE	GEN-2008-098 345kV	IA Pending
GEN-2010-005	300	WERE	GEN-2007-025 345kV	IA Pending
GEN-2010-006	205	SPS	Jones 230kV	IA Pending
GEN-2010-007	73.8	SPS	Tap Pringle - Riverview 115kV	IA Pending
GEN-2010-008	64.4	WFEC	Fargo 69kV	IA Pending
GEN-2010-009	165.6	SUNC	Gray County 345kV	IA Pending
GEN-2010-010	100.5	NPPD	Emerick 69kV	IA Pending
GEN-2010-011	29.7	OKGE	GEN-2008-044 345kV	IA Pending
GEN-2010-014	358.8	SPS	Hitchland 345kV	IA Pending
GEN-2010-015	200.1	SUNC	Spearville 345kV	IA Pending
GEN-2010-016	199.8	SUNC	Tap Spearville - Knoll 345kV	IA Pending
GEN-2010-020	20	SPS	Roswell 69kV	Under Study (DISIS-2011-001)
GEN-2010-029	450	SUNC	Spearville 345kV	Under Study (DISIS-2011-001)
GEN-2010-036	4.6	WERE	6 <sup>th</sup> Street 115kV	Under Study (DISIS-2010-002)
GEN-2010-040	300	OKGE	Cimarron 345kV	Under Study (DISIS-2010-002)
GEN-2010-041	10.5	OPPD	S 1399 161kV	Under Study (DISIS-2010-002)
GEN-2010-043	320	WFEC	Mooreland 138kV	Under Study (DISIS-2010-002)
GEN-2010-045	197.8	SUNC	Tap Holcomb – Spearville 345kV	Under Study (DISIS-2010-002)
GEN-2010-046	56	SPS	Tuco 230kV	Under Study (DISIS-2010-002)
GEN-2010-047	72	NPPD	Tap Beatrice – Harbine 115kV	Under Study (DISIS-2010-002)
GEN-2010-048	70	MIDW	Tap Beach Station – Redline 115kV	Under Study (DISIS-2010-002)

Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
GEN-2010-049	49.6	MKEC	Pratt 115kV	Under Study (DISIS-2010-002)
GEN-2010-051	200	NPPD	Tap Twin Church – Hoskins 230kV	Under Study (DISIS-2010-002)
GEN-2010-052	301.3	SPS	Finney 345kV	Under Study (DISIS-2010-002)
GEN-2010-053	199.8	SUNC	Comanche 345kV	Under Study (DISIS-2010-002)
GEN-2010-055	4.5	AEPW	Wekiwa 138kV	Under Study (DISIS-2011-001)
GEN-2010-056	151.2	MIPU	Tap Saint Joseph - Cooper 345kV	Under Study (DISIS-2011-001)
GEN-2010-057	201	MIDW	Rice County 230kV	Under Study (DISIS-2011-001)
GEN-2010-058	20	SPS	Chaves County 69kV	Under Study (DISIS-2011-001)
GEN-2011-007	250	OKGE	Tap Cimarron - Woodring 345kV	Under Study (DISIS-2011-001)
GEN-2011-008	600	SUNC	Clark County 345kV	Under Study (DISIS-2011-001)
GEN-2011-009	150.4	AEPW	Hobart 138kV	Under Study (DISIS-2011-001)
GEN-2011-010	100.8	OKGE	Minco 345kV	Under Study (DISIS-2011-001)
GEN-2011-011	50	KCPL	Iatan 345kV	Under Study (DISIS-2011-001)
GEN-2011-012	104.5	SPS	Tap Moore County - Hitchland 230kV	Under Study (DISIS-2011-001)
GEN-2011-013	101.7	OKGE	Sunnyside 345kV	Under Study (DISIS-2011-001)
GEN-2011-014	201	OKGE	Tap Hitchland - Woodward 345kV	Under Study (DISIS-2011-001)
GEN-2011-015	300.6	OKGE	Tap Tatonga - Northwest 345kV	Under Study (DISIS-2011-001)
GEN-2011-016	200.1	SUNC	Spearville 345kV	Under Study (DISIS-2011-001)
GEN-2011-017	299	SUNC	Tap Spearville - Knoll 345kV	Under Study (DISIS-2011-001)
GEN-2011-018	73.6	NPPD	Steele City 115kV	Under Study (DISIS-2011-001)
GEN-2011-019	299	OKGE	Woodward 345kV	Under Study (DISIS-2011-001)
GEN-2011-020	299	OKGE	Woodward 345kV	Under Study (DISIS-2011-001)
GEN-2011-021	299	SPS	Tap Hitchland - Woodward 345kV	Under Study (DISIS-2011-001)
GEN-2011-022	299	SPS	Hitchland 345kV	Under Study (DISIS-2011-001)
GEN-2011-023	299	SUNC	Tap Clark - Spearville 345kV	Under Study (DISIS-2011-001)
GEN-2011-024	299	OKGE	Tatonga 345kV	Under Study (DISIS-2011-001)
GEN-2011-025	82.3	SPS	Tap Floyd County - Crosby County 115kV	Under Study (DISIS-2011-001)
GEN-2011-027	120	NPPD	Tap Twin Church - Hoskins 230kV	Under Study (DISIS-2011-001)
Broken Bow	8.3	NPPD	Genoa 115kV	On-Line
Ord	13.9	NPPD	Bloomfield 115kV	On-Line
Stuart	2.1	NPPD	Petersburg 115kV	On-Line
Ainsworth	75	NPPD	Ainsworth Wind Tap 115kV	On-Line
Rosebud Wind Project	30	NPPD	St. Francis 115kV	On-Line
Wolf Creek	1170	WERE	Wolf Creek 345kV	On-Line
Genoa	4	NPPD	Genoa 115kV	On-Line
ASGI-2010-001	400	AECI	Tap Cooper – Fairport 345kV	AECI queue Affected Study
ASGI-2010-004	50	AECI	Tap Queen City - Lancaster 69kV	AECI queue Affected Study
ASGI-2010-005	99	AECI	Lathrop 161kV	AECI queue Affected Study

Request	Amount	Area	Requested/Proposed Point of Interconnection	Status or In-Service Date
ASGI-2010-006	150	AECI	Tap Fairfax – Fairfax Tap138kV	AECI queue Affected Study
ASGI-2010-007	150	AECI	Tap Fairfax – Fairfax Tap138kV	AECI queue Affected Study
ASGI-2010-008	100	AECI	Maryville 161kV	AECI queue Affected Study
ASGI-2010-009	201	AECI	Osborn 161kV	AECI queue Affected Study
ASGI-2010-010	42	SPS	Lovington 115kV	AECI queue Affected Study
ASGI-2010-011	48	SPS	Texas County 69kV	Affected Study
ASGI-2010-020	50	SPS	Tap (LE) Tatum – (LE) Crossroads 69kV	Affected Study
ASGI-2010-021	36.6	SPS	Tap (LE) Saunders Tap – (LE) Anderson 69kV	Affected Study
ASGI-2011-001	28.8	SPS	Lovington 115kV	Affected Study
ASGI-2011-002	10	SPS	Herring 115kV	Under Study (DISIS-2011-001)
ASGI-2011-003	10	SPS	Hendricks 115kV	Under Study (DISIS-2011-001)
Llanoest	80	SPS	Llano Wind Farm Tap 115kV	On-Line
SPSDISTR	90	SPS	DUMAS_19ST 115kV	On-Line
			Etter 115kV	On-Line
			Sherman 115kV	On-Line
			Spearman 115kV	On-Line
			Texas County 115kV	On-Line
BLUCAN2	153	WFEC	Washita 138kV (GEN-2003-004)	On-Line
			Washita 138kV (GEN-2004-023)	On-Line
			Washita 138kV (GEN-2005-003)	On-Line
Monte	110	MKEC	Haggard 115kV	On-Line
<b>GROUPED TOTAL</b>	<b>32,728.3</b>			

\*\* Interconnection on Caprock Electric tested for impacts on SPP

\* Planned Facility

^ Proposed Facility

**C: Study Groupings**

Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	GEN-2001-014	96	WFEC	Fort Supply 138kV
	GEN-2001-037	100	OKGE	Windfarm Switching 138kV
	GEN-2005-005	18	OKGE	Windfarm Tap 138kV
	GEN-2005-008	120	OKGE	Woodward 138kV
	GEN-2006-024S	20	WFEC	South Buffalo Tap 69kV
	GEN-2006-046	131	OKGE	Dewey 138kV
	GEN-2007-006	160	OKGE	Roman Nose 138kV
	GEN-2007-021	201	OKGE	*Tatonga 345kV
	GEN-2007-044	300	OKGE	*Tatonga 345kV
	GEN-2007-050	170	OKGE	*Woodward 138kV
	GEN-2007-051	200	WFEC	Mooreland 138kV
	GEN-2007-062	765	OKGE	*Woodward 345kV
	GEN-2008-003	101	OKGE	*Woodward EHV 138kV
	GEN-2008-019	300	OKGE	*Tatonga 345kV
	GEN-2008-029	250.5	OKGE	Woodward EHV 138kV
	GEN-2008-044	197.8	OKGE	Tatonga 345kV
	GEN-2010-008	64.4	WFEC	Fargo 69kV
	GEN-2010-011	29.7	OKGE	GEN-2008-044 345kV
	GEN-2010-043	320	WFEC	Mooreland 138kV
	GEN-2011-015	300.6	OKGE	Tap Tatonga – Woodward 345kV
GEN-2011-019	299	OKGE	Woodward 345kV	
GEN-2011-020	299	OKGE	Woodward 345kV	
GEN-2011-024	299	OKGE	Tatonga 345kV	
<b>PRIOR QUEUED SUBTOTAL</b>		<b>4,742</b>		
<b>WOODWARD SUBTOTAL</b>		<b>4,742</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	SPS Distribution	90	SPS	Various
	ASGI-2010-011	48	SPS	Texas County 69kV
	ASGI-2011-002	10	SPS	Herring 115kV
	ASGI-2011-003	10	SPS	Hendricks 115kV
	GEN-2002-008	240	SPS	*Hitchland 345kV
	GEN-2002-009	80	SPS	Hansford County 115kV
	GEN-2003-013	198	SPS	*Tap Hitchland - Finney 345kV
	GEN-2003-020	160	SPS	Martin 115kV
	GEN-2005-017	340	SPS	*Tap Hitchland - Potter County 345kV
	GEN-2006-020	20	SPS	DWS Frisco Tap
	GEN-2006-044	370	SPS	*Hitchland 345kV
	GEN-2006-049	400	SPS	*Tap Hitchland - Finney 345kV
	GEN-2007-046	200	SPS	Tap & Tie Texas County – Hitchland & DWS Frisco Tap – Hitchland 115kV
	GEN-2007-057	35	SPS	Moore County East 115kV
	GEN-2008-047	300	SPS	Tap Hitchland – Woodward 345kV
	GEN-2008-110	299.2	SPS	Hitchland 345kV
	GEN-2010-001	300	WFEC	Tap Woodward – Hitchland 230kV
	GEN-2010-007	73.8	SPS	Tap Pringle – Riverview 115kV
	GEN-2010-014	358.8	SPS	Hitchland 345kV
	GEN-2011-012	104.5	SPS	Tap Moore County - Hitchland 230kV
	GEN-2011-014	201	SPS	Tap Hitchland - Woodward 345kV
	GEN-2011-021	299	SPS	Tap Hitchland - Woodward 345kV
GEN-2011-022	299	SPS	Hitchland 345kV	
<b>PRIOR QUEUED SUBTOTAL</b>		<b>4,436.3</b>		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Hitchland</b>	GEN-2011-028	300.8	OKGE	Tap Guymon – Woodward 345kV
<b>HITCHLAND SUBTOTAL</b>		<b>300.8</b>		
<b>AREA SUBTOTAL</b>		<b>4,737.1</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	Montezuma	110	MKEC	Haggard 115kV
	GEN-2001-039A	105	MKEC	Tap Greensburg - Judson-Large 115kV
	GEN-2002-025A	150	MKEC	Spearville 230kV
	GEN-2004-014	154.5	MKEC	Spearville 230kV
	GEN-2005-012	250	SUNC	Spearville 345kV
	GEN-2006-006	206	MKEC	Spearville 230kV
	GEN-2006-021	101	MKEC	Flat Ridge Tap 138kV
	GEN-2006-022	150	MKEC	Ninnescah Tap 115kV
	GEN-2007-038	200	SUNC	Spearville 345kV
	GEN-2007-040	200	SUNC	Tap Holcomb – Spearville 345kV
	GEN-2008-018	405	SPS	Finney 345kV
	GEN-2008-079	100.5	MKEC	Tap Fort Dodge – Cudahy 115kV
	GEN-2008-124	200.1	MKEC	Spearville 230kV
	GEN-2009-062	115	SUNC	Hugoton 115kV
	GEN-2010-009	165.6	SUNC	Gray County 345kV
	GEN-2010-015	200.1	SUNC	Spearville 345kV
	GEN-2010-016	199.8	SUNC	Tap Spearville – Knoll 345kV
	GEN-2010-029	450	SUNC	Spearville 345kV
	GEN-2010-045	197.8	SUNC	Tap Holcomb – Spearville 345kV
	GEN-2010-049	49.6	MKEC	Pratt 115kV
	GEN-2010-052	301.3	SPS	Finney 345kV
	GEN-2010-053	199.8	SUNC	Comanche 345kV
	GEN-2011-008	600	SUNC	Clark County 345kV
	GEN-2011-016	200.1	SUNC	Spearville 345kV
GEN-2011-017	299	SUNC	Tap Spearville - Knoll 345kV	
GEN-2011-023	299	SUNC	Tap Clark - Spearville 345kV	
<b>PRIOR QUEUED SUBTOTAL</b>		<b>5,609.2</b>		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Spearville</b>	GEN-2011-003	10	MKEC	GEN-2008-079 115kV
	GEN-2011-030	1,020	SUNC	Holcomb 345kV
<b>SPEARVILLE SUBTOTAL</b>		<b>1,030</b>		
<b>AREA SUBTOTAL</b>		<b>6,656.7</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	GEN-2001-039M	100	SUNC	Central Plains Tap 115kV
	GEN-2006-034	81	SUNC	Tap Kanarado - Sharon Springs 115kV
	GEN-2006-040	108	SUNC	Mingo 115kV
	GEN-2007-011	135	SUNC	Syracuse 115kV
	GEN-2007-013	99	SUNC	Selkirk 115kV
	GEN-2008-017	300	SUNC	Setab 345kV
	GEN-2008-025	101.2	SUNC	Ruleton 115kV
<b>PRIOR QUEUED SUBTOTAL</b>		<b>924.2</b>		
<b>MINGO/NW KANSAS SUBTOTAL</b>		<b>924.2</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	Llano Estacado	80	SPS	Llano Estacado Tap 115kV
	GEN-2002-022	240	SPS	Bushland 230kV
	GEN-2006-039	400	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV
	GEN-2006-045	240	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV
	GEN-2006-047	240	SPS	Tap and Tie both Potter County - Plant X 230kV and Bushland - Deaf Smith 230kV
	GEN-2007-002	160	SPS	Grapevine 115kV
	GEN-2007-048	400	SPS	Tap Amarillo South – Swisher 230kV
	GEN-2008-051	322	SPS	Potter 345kV
	GEN-2008-088	50.6	SPS	Vega 69kV
<b>PRIOR QUEUED SUBTOTAL</b>		<b>2,132.6</b>		
<b>AMARILLO SUBTOTAL</b>		<b>2,132.6</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	ASGI-2010-010	42	SPS	Lovington 115kV
	ASGI-2010-020	50	SPS	Tap (LE) Tatum – (LE) Crossroads 69kV
	ASGI-2010-021	36.6	SPS	Tap (LE) Saunders Tap – (LE) Anderson 69kV
	ASGI-2011-001	28.8	SPS	Lovington 115kV
	GEN-2001-033	180	SPS	San Juan Mesa Tap 230kV
	GEN-2001-036	80	SPS	Caprock Tap 115kV
	GEN-2006-018	170	SPS	Tuco 230kV
	GEN-2006-026	502	SPS	Hobbs 230kV
	GEN-2008-008	60	SPS	Graham 115kV
	GEN-2008-009	60	SPS	San Juan Mesa Tap 230kV
	GEN-2008-014	150	SPS	Tap Tuco – Oklaunion 345kV
	GEN-2008-016	248	SPS	Grassland 230kV
	GEN-2008-022	300	SPS	Tap Eddy – GEN-2007-034 345kV
	GEN-2009-017	60	SPS	Tap Pembroke – Stiles 138kV
	GEN-2009-067S	20	SPS	7 Rivers 69kV
	GEN-2010-006	205	SPS	Jones 345kV
	GEN-2010-020	20	SPS	Roswell 69kV
	GEN-2010-046	56	SPS	Tuco 230kV
GEN-2010-058	20	SPS	Chaves County 69kV	
GEN-2011-025	82.3	SPS	Tap Floyd County - Crosby County 115kV	
<b>PRIOR QUEUED SUBTOTAL</b>		<b>2,370.7</b>		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>South Panhandle</b>	GEN-2011-031	195.6	SPS	Midland 230kV
<b>SOUTH PANHANDLE/NM SUBTOTAL</b>		<b>195.6</b>		
<b>AREA SUBTOTAL</b>		<b>2,566.3</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	GEN-2001-026	74	WFEC	Washita 138kV
	GEN-2002-005	120	WFEC	Tap Morewood - Elk City 138kV
	GEN-2003-004	101	WFEC	Washita 138kV
	GEN-2003-005	100	WFEC	Anadarko - Paradise 138kV
	GEN-2003-022	120	AEPW	Washita 138kV
	GEN-2004-020	27	AEPW	Washita 138kV
	GEN-2004-023	21	WFEC	Washita 138kV
	GEN-2005-003	31	WFEC	Washita 138kV
	GEN-2006-002	101	AEPW	Grapevine - Elk City 230kV
	GEN-2006-035	225	AEPW	Grapevine - Elk City 230kV
	GEN-2006-043	99	AEPW	Grapevine - Elk City 230kV
	GEN-2007-032	150	WFEC	Tap Clinton Junction – Clinton 138kV
	GEN-2007-043	200	OKGE	Tap Lawton Eastside – Cimarron 345kV
	GEN-2007-052	150	WFEC	Anadarko 138kV
	GEN-2008-023	150	AEPW	Hobart Junction 138kV
	GEN-2008-037	100.8	WFEC	Tap Washita – Blue Canyon 138kV
	GEN-2009-016	140	AEPW	Falcon Road 138kV
	GEN-2009-030	100.8	WFEC	Weatherford 138kV
	GEN-2009-060	84	WFEC	Gotebo 69kV
	GEN-2010-040	300	OKGE	Cimarron 345kV
GEN-2011-007	250	OKGE	Tap Cimarron - Woodring 345kV	
GEN-2011-009	150.4	AEPW	Hobart 138kV	
GEN-2011-010	100.8	OKGE	Minco 345kV	
<b>PRIOR QUEUED SUBTOTAL</b>		<b>2,895.8</b>		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>SW Oklahoma</b>	GEN-2011-029	200	WFEC	Tap Rush Springs (Nat. Gas) – Rush Springs (Marlow) 69kV
<b>SW OKLAHOMA SUBTOTAL</b>		<b>200</b>		
<b>AREA SUBTOTAL</b>		<b>3,095.8</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	Wolf Creek	1170	WERE	Wolf Creek 345kV
	ASGI-2010-006	150	AECI	Tap Fairfax – Fairfax Tap 138kV
	ASGI-2010-007	150	AECI	Tap Fairfax – Fairfax Tap 138kV
	GEN-2002-004	200	WERE	Latham 345kV
	GEN-2005-013	201	WERE	Tap Latham - Neosho
	GEN-2007-025	300	WERE	Tap Woodring – Wichita 345kV
	GEN-2008-013	300	OKGE	Tap Woodring – Wichita 345kV
	GEN-2008-021	42	WERE	Wolf Creek 25kV
	GEN-2008-071	76.8	OKGE	Newkirk 138kV
	GEN-2008-098	100.8	WERE	Tap Wolf Creek – LaCygne 345kV
	GEN-2008-127	200.1	WERE	Tap Sooner – Rose Hill 345kV
	GEN-2009-025	60	OKGE	Tap Deer Creek – Sinclair 69kV
	GEN-2010-003	100.8	WERE	GEN-2008-098 345kV
	GEN-2010-005	300	WERE	GEN-2007-025 345kV
	GEN-2010-055	4.5	AEPW	Wekiwa 138kV
<b>PRIOR QUEUED SUBTOTAL</b>		<b>3,356</b>		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>North Oklahoma</b>	GEN-2011-004	150.4	WERE	Creswell 138kV
	GEN-2011-006	200	AEPW	Shidler 138kV
<b>NORTH OKLAHOMA SUBTOTAL</b>		<b>350.4</b>		
<b>AREA SUBTOTAL</b>		<b>3,706.4</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
Prior Queued	Broken Bow	8.3	NPPD	Genoa 115kV
	Genoa	4	NPPD	Genoa 115kV
	Ord	13.9	NPPD	Bloomfield 115kV
	Stuart	2.1	NPPD	Petersburg 115kV
	Ainsworth	75	NPPD	Ainsworth Wind Tap 115kV
	Rosebud Wind Project	30	NPPD	St. Francis 115kV
	GEN-2006-020N	42	NPPD	Bloomfield 115kV
	GEN-2006-037N1	75	NPPD	Broken Bow 115kV
	GEN-2006-038N005	80	NPPD	Broken Bow 115kV
	GEN-2006-038N019	80	NPPD	Petersburg 115kV
	GEN-2006-044N	40.5	NPPD	Tap Neligh – Petersburg 115kV
	GEN-2006-044N02	100.5	NPPD	GEN-2008-086N02 230kV
	GEN-2007-011N08	81	NPPD	Bloomfield 115kV
	GEN-2008-086N02	200	NPPD	Tap Ft. Randall – Columbus 230kV
	GEN-2010-010	100.5	NPPD	Emerick 69kV
GEN-2010-051	200	NPPD	Tap Twin Church – Hoskins 230kV	
GEN-2011-027	120	NPPD	Tap Twin Church - Hoskins 230kV	
<b>PRIOR QUEUED SUBTOTAL</b>		<b>1,252.8</b>		
Cluster	Request	Amount	Area	Proposed Point of Interconnection
Nebraska	GEN-2011-005	150.4	NPPD	Rising City 115kV
<b>NEBRASKA SUBTOTAL</b>		<b>150.4</b>		
<b>AREA SUBTOTAL</b>		<b>1,410.2</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
Prior Queued	GEN-2003-006A-E	100	MKEC	Elm Creek 230kV
	GEN-2003-006A-W	100	MKEC	Elm Creek 230kV
	GEN-2003-019	250	MIDW	Smoky Hills Tap 230kV
	GEN-2006-031	75	MIDW	Knoll 115kV
	GEN-2006-032	200	MIDW	South Hays 230kV
	GEN-2008-092	201	MIDW	Knoll 115kV
	GEN-2009-008	200	SUNC	South Hays 230kV
	GEN-2009-011	50	MKEC	Tap Plainville – Phillipsburg 115kV
	GEN-2009-020	48.6	MIDW	Tap Bazine – Nekoma 69kV
	GEN-2010-048	70	MIDW	Tap Beach Station – Redline 115kV
	GEN-2010-057	201	MIDW	Rice County 230kV
<b>PRIOR QUEUED SUBTOTAL</b>		<b>1,495.6</b>		
<b>NORTH KANSAS SUBTOTAL</b>		<b>1,495.6</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	ASGI-2010-001	400	AECI	Tap Cooper – Fairport 345kV
	ASGI-2010-004	50	AECI	Tap Queen City – Lancaster 69kV
	ASGI-2010-005	99	AECI	Lathrop 161kV
	ASGI-2010-008	100	AECI	Maryville 161kV
	ASGI-2010-009	201	AECI	Osborn 161kV
	GEN-2006-014	300	MIPU	Tap Maryville – Clarinda 161kV & Tie to Midway 161kV
	GEN-2006-017	300	MIPU	Tap Maryville – Clarinda 161kV & Tie to Midway 161kV
	GEN-2007-015	135	WERE	Tap Humboldt – Kelly 161kV
	GEN-2007-017	101	MIPU	Tap Maryville – Clarinda 161kV & Tie to Midway 161kV
	GEN-2007-053	110	MIPU	Tap Maryville – Clarinda 161kV & Tie to Midway 161kV
	GEN-2008-1190	60	OPPD	Tap Humboldt – Kelly 161kV
	GEN-2008-129	80	MIPU	Pleasant Hill 161kV
	GEN-2009-040	73.8	WERE	Tap Smittyville – Knob Hill 115kV
	GEN-2010-036	4.6	WERE	6 <sup>th</sup> Street 115kV
	GEN-2010-041	10.5	OPPD	S 1399 161kV
	GEN-2010-047	72	NPPD	Tap Beatrice – Harbine 115kV
	GEN-2010-056	151.2	MIPU	Tap St. Joe – Cooper 345kV
GEN-2011-011	50	KCPL	Iatan 345kV	
GEN-2011-018	73.6	NPPD	Steele City 115kV	
<b>PRIOR QUEUED SUBTOTAL</b>		<b>2,371.7</b>		
<b>NORTH MISSOURI SUBTOTAL</b>				


Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	GEN-2006-038	750	WFEC	Hugo 345kV
	GEN-2008-046	200	OKGE	Sunnyside 345kV
	GEN-2011-013	101.7	OKGE	Sunnyside 345kV
<b>PRIOR QUEUED SUBTOTAL</b>		<b>1,051.7</b>		
<b>SOUTH CENTRAL OKLAHOMA SUBTOTAL</b>		<b>1,051.7</b>		

Cluster	Request	Amount	Area	Proposed Point of Interconnection
<b>Prior Queued</b>	GEN-2008-123N	89.7	NPPD	Tap Guide – Pauline 115kV
<b>SOUTHWEST NEBRASKA</b>		<b>89.7</b>		
<b>***CLUSTERED TOTAL (w/o PRIOR QUEUED)</b>		<b>2,227.2</b>		
<b>***CLUSTERED TOTAL (w/PRIOR QUEUED)</b>		<b>34,955.5</b>		


- \* Planned Facility
- ^ Proposed Facility
- \*\* Alternate requests - counted as one request for study purpose
- \*\*\* Electrically Remote Interconnection Requests

### D: Proposed Point of Interconnection One line Diagrams


GEN-2011-003




GEN-2011-004




GEN-2011-005




GEN-2011-006




GEN-2011-028



GEN-2011-029




GEN-2011-030



GEN-2011-031

0



## **E: Cost Allocation per Interconnection Request**

# E. Cost Allocation Per Request

(Including Previously Allocated Network Upgrades\*)

Interconnection Request and Upgrades	Upgrade Type	Allocated Cost	Upgrade Cost
<b>GEN 2011-003</b>			
GEN-2011-003 Interconnection Costs See Online Diagram.	Current Study	\$0.00	\$0.00
Axtell - PostRock 345KV CKT 1 Balanced Portfolio: Spearville - PostRock - Axtell 345KV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$112,700,000.00
Beaver County - Gray County 345kV Build approximately 90 miles of 345kV from Beaver County - Gray County	Previously Allocated		\$90,000,000.00
Border - Tuco Interchange 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV (Total Project E&C Cost Shown)	Previously Allocated		\$148,727,500.00
Fort Dodge - North Fort Dodge 115kV CKT 2 Construct approximately 1 mile of new 115kV for 2nd circuit	Previously Allocated		\$6,113,000.00
Matthewson - Cimarron 345kV CKT 2 Build second 345kV circuit from Matthewson - Cimarron	Previously Allocated		\$15,000,000.00
Medicine Lodge - Wichita 345KV Dbl CKT Priority Project: Spearville - Comanche - Med Lodge - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$356,300,000.00
Medicine Lodge 345/115kV transformer Install new 345/115kV transformer at Medicine Lodge	Previously Allocated		\$10,000,000.00
Mullegreen - Circle 345kV Dbl CKT Build new 345kV line from Mullergreen - Circle	Previously Allocated		\$132,000,000.00
North Fort Dodge - Spearville 115kV DIS-2009-001-1 upgrade.	Previously Allocated		\$9,660,000.00
PostRock - GEN-2010-016 Tap 345KV CKT 1 Balanced Portfolio: Spearville - PostRock - Axtell 345KV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$112,700,000.00
Spearville - GEN-2010-016 Tap 345KV CKT 1 Balanced Portfolio: Spearville - PostRock - Axtell 345KV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$112,700,000.00
Spearville - Mullergreen 345kV Dbl CKT Build new 345kV line from Spearville - Mullergreen	Previously Allocated		\$124,000,000.00
Spearville 345/115/13.8kV Transformer CKT 1 New 345/115kV Spearville Transformer (Partial Cost allocation)	Previously Allocated		\$3,745,000.00
Tatonga - Matthewson 345kV CKT 2 Build second 345kV circuit from Tatonga - Matthewson	Previously Allocated		\$60,000,000.00

<b>Interconnection Request and Upgrades</b>	<b>Upgrade Type</b>	<b>Allocated Cost</b>	<b>Upgrade Cost</b>
Tuco Interchange 345/230/13.2KV Autotransformer CKT 2 Balanced Portfolio: Tuco 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)	Previously Allocated		\$11,250,000.00
	<b>Current Study Total</b>	\$0.00	
<b>GEN 2011-004</b>			
GEN-2011-004 Interconnection Costs See Oonline Diagram.	Current Study	\$2,000,000.00	\$2,000,000.00
Cleveland - Sooner 345KV CKT 1 Balanced Portfolio: Cleveland - Sooner 345kV CKT (Total Project E&C Cost Shown).	Previously Allocated		\$17,000,000.00
	<b>Current Study Total</b>	\$2,000,000.00	
<b>GEN 2011-005</b>			
GEN-2011-005 Interconnection Costs See Oonline Diagram.	Current Study	\$2,000,000.00	\$2,000,000.00
Rising City - Seward 115kV Rebuild approximately 31.7 miles of 115kV line	Current Study	\$23,800,000.00	\$23,800,000.00
Madison County - Hoskins 230kV Build approximately 30 miles of 230kV between Madison County and Hoskins	Previously Allocated		\$30,000,000.00
	<b>Current Study Total</b>	\$25,800,000.00	
<b>GEN 2011-006</b>			
GEN-2011-006 Interconnection Costs See Oonline Diagram.	Current Study	\$2,000,000.00	\$2,000,000.00
Highway 20 Tap - Highway 20 138kV Rebuild approximately 6 miles of 138kV line	Current Study	\$5,000,000.00	\$5,000,000.00
Sand Springs - Highway 20 tap 138kV Rebuild approximately 19 miles of 138kV line	Current Study	\$18,000,000.00	\$18,000,000.00
Shidler - Hominy 138kV Build new 138kV line from Shidler - Hominy	Current Study	\$31,000,000.00	\$31,000,000.00
Shilder - West Pawhuska 138kV Replace switches at Shidler 138kV substation	Current Study	\$200,000.00	\$200,000.00
	<b>Current Study Total</b>	\$56,200,000.00	
<b>GEN 2011-028</b>			
GEN-2011-028 Interconnection Costs See Oonline Diagram.	Current Study	\$4,000,000.00	\$4,000,000.00

<b>Interconnection Request and Upgrades</b>	<b>Upgrade Type</b>	<b>Allocated Cost</b>	<b>Upgrade Cost</b>
Beaver County - Gray County 345kV Build approximately 90 miles of 345kV from Beaver County - Gray County	Previously Allocated		\$90,000,000.00
Border - Tuco Interchange 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV (Total Project E&C Cost Shown)	Previously Allocated		\$148,727,500.00
Finney Switching Station - Holcomb 345KV CKT 2 Per GEN-2006-044 Facility Study	Previously Allocated		\$6,299,839.00
Hitchland - Border 345 kV Dbl CKT Build approximately 105 miles of 345kV and SVC at Hitchland.	Previously Allocated		\$224,831,940.00
Matthewson - Cimarron 345kV CKT 2 Build second 345kV circuit from Matthewson - Cimarron	Previously Allocated		\$15,000,000.00
Medicine Lodge - Wichita 345KV Dbl CKT Priority Project: Spearville - Comanche - Med Lodge - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$356,300,000.00
Medicine Lodge - Woodward 345KV Dbl CKT Priority Project: Med Lodge - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$194,972,759.00
Medicine Lodge 345/138KV Transformer CKT 1 Priority Project: Spearville - Comanche - Med Lodge - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$356,300,000.00
Tatonga - Matthewson 345kV CKT 2 Build second 345kV circuit from Tatonga - Matthewson	Previously Allocated		\$60,000,000.00
Tuco Interchange 345/230/13.2KV Autotransformer CKT 2 Balanced Portfolio: Tuco 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)	Previously Allocated		\$11,250,000.00
	<b>Current Study Total</b>		<b>\$4,000,000.00</b>

## GEN 2011-029

AEPW Duncan - Duncan Eastside 138kV Rebuild approximately 5.1 miles of 138kV line	Current Study	\$3,800,000.00	\$3,800,000.00
Commanche tap - Commanche 69kV Rebuild approximately 2.6 miles of 69kV line	Current Study	\$3,000,000.00	\$3,000,000.00
Cornville - Rush Springs Natural Gas 138kV Replace switches on Cornville - Rush Springs Natural Gas 138kV line	Current Study	\$3,000,000.00	\$3,000,000.00
Duncan - Tosco 69kV Rebuild approximately 3.9 miles of 69kV line	Current Study	\$3,000,000.00	\$3,000,000.00
Duncan 138/69kV transformer #2 Install 2nd 138/69/13.8kV transformer at Duncan	Current Study	\$2,000,000.00	\$2,000,000.00

<b>Interconnection Request and Upgrades</b>	<b>Upgrade Type</b>	<b>Allocated Cost</b>	<b>Upgrade Cost</b>
GEN-2011-029 Interconnection Costs See Online Diagram.	Current Study	\$4,000,000.00	\$4,000,000.00
Marlow - OMPA Duncan 138kV Rebuild approximately 3.2 miles of 138kV line	Current Study	\$2,000,000.00	\$2,000,000.00
OMPA Duncan - Duncan Eastside 138kV Rebuild approximately 1.2 miles of 138kV line	Current Study	\$900,000.00	\$900,000.00
Rush Springs - Marlow 138kV Rebuild approximately 8.6 miles of 138kV line	Current Study	\$6,000,000.00	\$6,000,000.00
Tosco - Commanche Tap 69kV Rebuild approximately 3.2 miles of 69kV line	Current Study	\$2,000,000.00	\$2,000,000.00
Gracemont Transformer 345/138/13.8KV CKT 1 Priority Project: Gracemont Transformer 345/138/13.8KV CKT 1 (Total Project E&C Cost Shown)	Previously Allocated		\$8,000,000.00
Washita - Gracemont 138kV CKT 2 Build approximately 11 miles of 138kV.	Previously Allocated		\$5,621,986.00
	<b>Current Study Total</b>	<b>\$29,700,000.00</b>	

### **GEN 2011-030**

GEN-2011-030 Interconnection Costs See Online Diagram.	Current Study	\$5,000,000.00	\$5,000,000.00
Axtell - PostRock 345KV CKT 1 Balanced Portfolio: Spearville - PostRock - Axtell 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$112,700,000.00
Beaver County - Gray County 345kV Build approximately 90 miles of 345kV from Beaver County - Gray County	Previously Allocated		\$90,000,000.00
Border - Tuco Interchange 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV (Total Project E&C Cost Shown)	Previously Allocated		\$148,727,500.00
Border - Woodward 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV (Total Project E&C Cost Shown)	Previously Allocated		\$148,727,500.00
Matthewson - Cimarron 345kV CKT 2 Build second 345kV circuit from Matthewson - Cimarron	Previously Allocated		\$15,000,000.00
Medicine Lodge - Wichita 345KV Dbl CKT Priority Project: Spearville - Comanche - Med Lodge - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$356,300,000.00
Medicine Lodge 345/138KV Transformer CKT 1 Priority Project: Spearville - Comanche - Med Lodge - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$356,300,000.00

<b>Interconnection Request and Upgrades</b>	<b>Upgrade Type</b>	<b>Allocated Cost</b>	<b>Upgrade Cost</b>
Mullegreen - Circle 345kV Dbl CKT Build new 345kV line from Mullegreen - Circle	Previously Allocated		\$132,000,000.00
PostRock - GEN-2010-016 Tap 345KV CKT 1 Balanced Portfolio: Spearville - PostRock - Axtell 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$112,700,000.00
Spearville - GEN-2010-016 Tap 345KV CKT 1 Balanced Portfolio: Spearville - PostRock - Axtell 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$112,700,000.00
Spearville - Mullegreen 345kV Dbl CKT Build new 345kV line from Spearville - Mullegreen	Previously Allocated		\$124,000,000.00
Tatonga - Matthewson 345kV CKT 2 Build second 345kV circuit from Tatonga - Matthewson	Previously Allocated		\$60,000,000.00
Tuco Interchange 345/230/13.2KV Autotransformer CKT 2 Balanced Portfolio: Tuco 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)	Previously Allocated		\$11,250,000.00
	<b>Current Study Total</b>	<b>\$5,000,000.00</b>	
<b>GEN 2011-031</b>			
GEN-2011-031 Interconnection Costs See Online Diagram.	Current Study	\$5,000,000.00	\$5,000,000.00
Midland - Borden 230kV Build new 230kV line from Midland - Borden	Current Study	\$60,000,000.00	\$60,000,000.00
Border - Tuco Interchange 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV (Total Project E&C Cost Shown)	Previously Allocated		\$148,727,500.00
Border - Woodward 345KV CKT 1 Balanced Portfolio: Tuco - Woodward 345kV (Total Project E&C Cost Shown)	Previously Allocated		\$148,727,500.00
Hitchland - Beaver 345kV Dbl CKT Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$247,005,793.00
Hitchland - Border 345 kV Dbl CKT Build approximately 105 miles of 345kV and SVC at Hitchland.	Previously Allocated		\$224,831,940.00
Medicine Lodge - Wichita 345KV Dbl CKT Priority Project: Spearville - Comanche - Med Lodge - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)	Previously Allocated		\$356,300,000.00
Medicine Lodge - Woodward 345KV Dbl CKT Priority Project: Med Lodge - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)	Previously Allocated		\$194,972,759.00
	<b>Current Study Total</b>	<b>\$65,000,000.00</b>	
<b>TOTAL CURRENT STUDY COSTS:</b>		<b>\$187,700,000.00</b>	

## **F: FCITC Analysis (No Upgrades)**

Season	Scenario	Source	MontCommonName	Direction	TDF	Rating	Contingency Loading %	Contname
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.2538	1188.5	124.9558	'DBL-MEDLO-WIC'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.26806	1188.5	116.9965	'DBL-WOOD-MED'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21098	1188.5	110.5275	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21098	1188.5	105.8494	'G08-14T 345.00 - OKLAUNION 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21098	1188.5	105.4035	'G08-14T 345.00 - TUCO INTERCHANGE 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21402	1188.5	103.2547	'MED-LDG5 345.00 - WICHITA 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21402	1188.5	103.2547	'MED-LDG5 345.00 - WICHITA 345KV CKT 2'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.22072	1188.5	102.3448	'MED-LDG5 345.00 - WWRDEHV7 345.00 345KV CKT 2'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.22072	1188.5	102.3448	'MED-LDG5 345.00 - WWRDEHV7 345.00 345KV CKT 1'
11G	0	G11_028	'G11-015T 345.00 - TATONGA7 345.00 345KV CKT 1'	FROM->TO	0.2538	1194.9	102.4771	'DBL-MEDLO-WIC'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21071	1188.5	101.8311	'GRAY CO 345.00 - SPEARVILLE 345KV CKT 1'
11G	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.34989	142.7	105.4231	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.25659	1190.6	116.7296	'DBL-MEDLO-WIC'
11G	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.35	142.7	103.7004	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.9	117.4557	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.9	112.1133	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.9	110.0065	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	110.8558	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	107.0018	'G11-029 138.00 - RUSH SPRINGS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	104.3407	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.9	104.6641	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	104.0939	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_005	'RISING CITY - SEWARD 115KV CKT 1'	FROM->TO	1	120	103.5	'COLUMNSOUTHEAST - RISING CITY 115KV CKT 1'
11G	0	G11_005	'RISING CITY - SEWARD 115KV CKT 1'	FROM->TO	1	120	111.5833	'COLUMNSOUTHEAST - RISING CITY 115KV CKT 1'
11WP	0	G11_005	'RISING CITY - SEWARD 115KV CKT 1'	FROM->TO	1	120	105.0833	'COLUMNSOUTHEAST - RISING CITY 115KV CKT 1'
16WP	0	G11_005	'RISING CITY - SEWARD 115KV CKT 1'	FROM->TO	1	120	103.5	'COLUMNSOUTHEAST - RISING CITY 115KV CKT 1'
11G	0	G11_005	'RISING CITY - SEWARD 115KV CKT 1'	FROM->TO	1	120	111.5833	'COLUMNSOUTHEAST - RISING CITY 115KV CKT 1'
11SP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.35788	143	126.0671	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11SP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.4076	143	127.7063	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11SP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.4076	143	127.7063	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.52299	169.9	127.9565	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11SP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.4076	143	123.7203	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.52299	179.9	120.8438	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.50211	169.9	118.3178	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.50211	169.9	117.847	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.50211	169.9	114.08	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11SP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.52299	179.8	112.9021	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.50211	169.9	112.6674	'DOMES - MOUND ROAD 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50211	179.9	111.741	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50211	179.9	111.2963	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50211	179.9	107.7387	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11SP	0	G11_006	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'	TO->FROM	0.4076	170	106.3647	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11SP	0	G11_006	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'	TO->FROM	0.4076	170	106.3647	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11SP	0	G11_006	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'	TO->FROM	0.35788	170	104.9859	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50211	179.9	106.4047	'DOMES - MOUND ROAD 138KV CKT 1'
11SP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.2608	143	102.9874	'NORTHEAST STATION 138/22.0KV TRANSFORMER CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.37251	169.9	103.4738	'SOONER 138/22.0KV TRANSFORMER CKT 1'
11SP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.50211	179.8	103.7942	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11SP	0	G11_006	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'	TO->FROM	0.4076	170	103.0118	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11SP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.50211	179.8	103.2937	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11SP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.37251	135.9	100.9581	'BASE CASE'
11WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.3569	142.9	130.077	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.40708	142.9	127.9328	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.40708	142.9	127.9328	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.40708	142.9	123.944	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.52411	180	119.0122	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'

Season	Scenario	Source	MontCommonName	Direction	TDF	Rating	Contingency Loading %	Contname
11WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.52411	192	111.574	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11WP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.52411	179.9	111.0739	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50276	180	108.5844	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50276	180	108.14	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50276	180	106.0289	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50276	180	104.9178	'DOMES - MOUND ROAD 138KV CKT 1'
11WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.50276	192	101.7979	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.50276	192	101.3813	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11WP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.50276	179.9	100.5848	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11WP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.50276	179.9	100.1957	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.2737	142.9	100.098	'FAIRFAX 138/69KV TRANSFORMER CKT 1'
16WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.35824	142.9	128.0952	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.40778	142.9	127.1211	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
16WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.40778	142.9	127.1211	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
16WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.40778	142.9	123.1323	'OSAGE - WEBB CITY TAP 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.52269	180	119.5767	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.52269	192	112.1031	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16WP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.52269	179.9	111.6387	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50196	180	109.2733	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50196	180	108.94	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50196	180	106.7178	'DOMES - PAWHUSKA TAP 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.50196	180	105.4956	'DOMES - MOUND ROAD 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.50196	192	102.4438	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.50196	192	102.1312	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.26123	142.9	101.4094	'NORTHEAST STATION 138/22.0KV TRANSFORMER CKT 1'
16WP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.50196	179.9	101.3296	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.50196	179.9	100.9405	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.50196	192	100.0479	'DOMES - PAWHUSKA TAP 138KV CKT 1'
16WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.35036	142.9	126.9923	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.40416	142.9	126.6144	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
16WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.40416	142.9	126.6144	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
16WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.40416	142.9	122.6256	'OSAGE - WEBB CITY TAP 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.53198	180	120.6089	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.53198	192	113.0708	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16WP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.53198	179.9	112.6715	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.5081	180	109.9556	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.5081	180	109.6222	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.5081	180	107.4	'DOMES - PAWHUSKA TAP 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - SHIDLER 138KV CKT 1'	TO->FROM	0.5081	180	106.1778	'DOMES - MOUND ROAD 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.5081	192	103.0833	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.5081	192	102.7708	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.5081	179.9	102.0122	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'OSAGE - WEBB CITY TAP 138KV CKT 1'	TO->FROM	0.5081	179.9	101.6231	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16WP	0	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.25373	142.9	100.7362	'NORTHEAST STATION 138/22.0KV TRANSFORMER CKT 1'
16WP	0	G11_006	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'	FROM->TO	0.5081	192	100.6875	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.2538	1188.5	126.6129	'DBL-MEDLO-WIC'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.26806	1188.5	118.7199	'DBL-WOOD-MED'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21098	1188.5	112.0492	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21098	1188.5	107.3711	'G08-14T 345.00 - OKLAUNION 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21098	1188.5	106.9251	'G08-14T 345.00 - TUCO INTERCHANGE 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21402	1188.5	104.6462	'MED-LDG5 345.00 - WICHITA 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21402	1188.5	104.6462	'MED-LDG5 345.00 - WICHITA 345KV CKT 2'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.22072	1188.5	103.7726	'MED-LDG5 345.00 - WWRDEHV7 345.00 345KV CKT 2'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.22072	1188.5	103.7726	'MED-LDG5 345.00 - WWRDEHV7 345.00 345KV CKT 1'
11G	0	G11_028	'G11-015T 345.00 - TATONGA7 345.00 345KV CKT 1'	FROM->TO	0.2538	1194.9	104.1254	'DBL-MEDLO-WIC'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.21071	1188.5	103.2077	'GRAY CO 345.00 - SPEARVILLE 345KV CKT 1'

Season	Scenario	Source	MontCommonName	Direction	TDF	Rating	Contingency Loading %	Contname
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.20877	1188.5	101.3159	'DEWEY - SOUTHARD 138KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.20278	1188.5	101.1979	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.20278	1188.5	101.1979	'ELK CITY 230KV - SWEETWT6 230.00 230KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.20774	1188.5	101.0795	'MINGO - RED WILLOW 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.20581	1188.5	101.039	'FINNEY SWITCHING STATION - STEVENSCO 345.00 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.20877	1188.5	101.0298	'EL RENO - ROMAN NOSE 138KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.20646	1188.5	101.0134	'G10-16T 345.00 - POSTROCK7 345.00 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.20703	1188.5	100.9942	'MINGO - SETAB 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.20877	1188.5	100.8363	'ROMAN NOSE - SOUTHARD 138KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.20284	1188.5	100.8039	'SPP-SWPS-03'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.33212	1188.5	128.5964	'DBL-MEDLO-WIC'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.33912	1188.5	120.5196	'DBL-WOOD-MED'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.297	1188.5	114.2278	'LAWTON EASTSIDE - OKLAUNION 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.297	1188.5	109.5496	'G08-14T 345.00 - OKLAUNION 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.297	1188.5	109.1037	'G08-14T 345.00 - TUCCO INTERCHANGE 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.28716	1188.5	106.4986	'MED-LDG5 345.00 - WICHITA 345KV CKT 2'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.28716	1188.5	106.4986	'MED-LDG5 345.00 - WICHITA 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.29209	1188.5	105.5801	'MED-LDG5 345.00 - WWRDEHV7 345.00 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.29209	1188.5	105.5801	'MED-LDG5 345.00 - WWRDEHV7 345.00 345KV CKT 2'
11G	0	G11_028	'G11-015T 345.00 - TATONGA7 345.00 345KV CKT 1'	FROM->TO	0.33212	1194.9	106.0983	'DBL-MEDLO-WIC'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.28338	1188.5	105.0482	'GRAY CO 345.00 - SPEARVILLE 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.28291	1188.5	103.1936	'DEWEY - SOUTHARD 138KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.27744	1188.5	103.0887	'ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.27744	1188.5	103.0887	'ELK CITY 230KV - SWEETWT6 230.00 230KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.27872	1188.5	102.8771	'MINGO - RED WILLOW 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.27741	1188.5	102.8524	'FINNEY SWITCHING STATION - STEVENSCO 345.00 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.28291	1188.5	102.9075	'EL RENO - ROMAN NOSE 138KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.27737	1188.5	102.8093	'G10-16T 345.00 - POSTROCK7 345.00 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.27816	1188.5	102.7956	'MINGO - SETAB 345KV CKT 1'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.27761	1188.5	102.6976	'SPP-SWPS-03'
11G	0	G11_028	'NORTHWEST - TATONGA7 345.00 345KV CKT 1'	TO->FROM	0.28291	1188.5	102.714	'ROMAN NOSE - SOUTHARD 138KV CKT 1'
11G	0	G11_028	'G11-015T 345.00 - WWRDEHV7 345.00 345KV CKT 1'	TO->FROM	0.33212	1194.7	101.4119	'DBL-MEDLO-WIC'
11SP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	116.6	166.8954	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	116.6	158.319	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	116.7	154.7558	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	116.7	146.1868	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.4	133.427	'G11-029 138.00 - RUSH SPRINGS TAP 138KV CKT 1'
11SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.4	129.6348	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'
11SP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	132.7619	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	116.9	125.1497	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.4	119.8034	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'
11SP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	123.2381	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	116.9	116.5954	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20282	48	103.8833	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20282	48	100.9667	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.7	148.0784	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	104.9	156.4347	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.7	143.1047	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.7	141.4469	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	104.9	150.2383	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	135.6241	'G11-029 138.00 - RUSH SPRINGS TAP 138KV CKT 1'
11WP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.7	136.4733	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	133.1697	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'
11WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	126.9986	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'
11WP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	132.9	126.9376	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20214	47.7	113.4759	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'

Season	Scenario	Source	MontCommonName	Direction	TDF	Rating	Contingency Loading %	Contname
11WP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	132.9	122.0466	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20214	52.8	110.6591	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20214	47.7	110.5409	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20214	52.8	108.197	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	113.7447	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'
11WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	110.5189	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'
11WP	0	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20214	54.8	104.7956	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	0	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20214	54.8	102.2409	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	116.3	167.4978	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	116.3	158.6414	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	116.6	154.3739	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	116.6	145.5403	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.1	133.4975	'G11-029 138.00 - RUSH SPRINGS TAP 138KV CKT 1'
16SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.1	129.8381	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'
16SP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	129.2381	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.1	119.4229	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'
16SP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	117	122.0513	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	119.4286	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	117	113.2479	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.6	148.3409	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.6	143.2127	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	104.8	154.6756	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.6	141.3273	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	135.554	'G11-029 138.00 - RUSH SPRINGS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	104.8	148.2824	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.6	136.1991	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	133.1697	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'
16WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	126.648	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'
16WP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	132.8	125.6024	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20815	47.8	112.6151	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	132.8	120.5572	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20815	52.8	110.4735	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20815	47.8	109.477	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20815	52.8	107.6326	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	112.2721	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'
16WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	108.9762	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'
16WP	0	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20815	54.8	104.6168	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20815	54.8	101.8796	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN (DUNCAN) 138/69/13.8KV TRANSFORMER CKT 1'	FROM->TO	0.20815	71.8	100.5989	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN (DUNCAN) 138/69/13.8KV TRANSFORMER CKT 1'	FROM->TO	0.20815	72	100.3194	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.9	147.5546	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.9	142.2122	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.9	140.1053	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	148.9524	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	135.014	'G11-029 138.00 - RUSH SPRINGS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	132.3529	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.9	134.763	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	142.1905	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	125.4202	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'
11G	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	133	121.3534	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	133	116.015	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20347	47.9	105.4154	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	108.0532	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'
11G	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20347	53	104.3283	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	104.5518	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'
11G	0	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20347	47.9	102.2839	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'

Season	Scenario	Source	MontCommonName	Direction	TDF	Rating	Contingency Loading %	Contname
11G	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20347	53	101.4981	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	116.6	166.8954	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	116.6	158.319	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	116.7	154.7558	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	116.7	146.1868	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.4	133.427	'G11-029 138.00 - RUSH SPRINGS TAP 138KV CKT 1'
11SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.4	129.6348	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'
11SP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	132.7619	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	116.9	125.1497	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.4	119.8034	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'
11SP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	123.2381	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	116.9	116.5954	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20233	48	103.6792	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20233	48	100.7625	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	116.3	167.4978	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	116.3	158.6414	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	116.6	154.3739	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	116.6	145.5403	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.1	133.4975	'G11-029 138.00 - RUSH SPRINGS TAP 138KV CKT 1'
16SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.1	129.8381	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'
16SP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	129.2381	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.1	119.4229	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'
16SP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	117	122.0513	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	119.4286	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16SP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	117	113.2479	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.6	148.3409	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.6	143.2127	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	104.8	154.6756	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.6	141.3273	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	135.554	'G11-029 138.00 - RUSH SPRINGS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	104.8	148.2824	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.6	136.1991	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	133.1697	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'
16WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	126.648	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'
16WP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	132.8	125.6024	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20788	47.8	112.5021	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	132.8	120.5572	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20788	52.8	110.3712	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20788	47.8	109.364	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20788	52.8	107.5303	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	112.2721	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'
16WP	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.6	108.9762	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'
16WP	0	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20788	54.8	104.5182	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20788	54.8	101.781	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN (DUNCAN) 138/69/13.8KV TRANSFORMER CKT 1'	FROM->TO	0.20788	71.8	100.5237	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	0	G11_029	'DUNCAN (DUNCAN) 138/69/13.8KV TRANSFORMER CKT 1'	FROM->TO	0.20788	72	100.2445	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.9	147.5546	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'	TO->FROM	1	132.9	142.2122	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.9	140.1053	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	148.9524	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	135.014	'G11-029 138.00 - RUSH SPRINGS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	132.3529	'OMPA-MARLOW - RUSH SPRINGS TAP 138KV CKT 1'
11G	0	G11_029	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'	TO->FROM	1	132.9	134.763	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'	TO->FROM	1	105	142.1905	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	125.4202	'OMPA-DUNCAN 821 - OMPA-MARLOW 138KV CKT 1'
11G	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	133	121.3534	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'

Season	Scenario	Source	MontCommonName	Direction	TDF	Rating	Contingency Loading %	Contname
11G	0	G11_029	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'	TO->FROM	1	133	116.015	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20284	47.9	105.1524	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	108.0532	'DUNCAN EASTSIDE - OMPA-DUNCAN 821 138KV CKT 1'
11G	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20284	53	104.0906	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'	TO->FROM	1	142.8	104.5518	'DUNCAN - DUNCAN EASTSIDE 138KV CKT 1'
11G	0	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20284	47.9	102.0209	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	0	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20284	53	101.2604	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	0	G11_031	'HOBBS INTERCHANGE 230/115KV TRANSFORMER CKT 1'	FROM->TO	0.65744	149.1	219.3561	'HOBBS INTERCHANGE - LEA COUNTY INTERCHANGE 230KV CKT 1'
11SP	0	G11_031	'BORDEN COUNTY INTERCHANGE 230/138KV TRANSFORMER CKT 1'	TO->FROM	1	167.7	148.718	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11SP	0	G11_031	'CAPROCK REC-TATE - CAPROCK REC-TRIANGLE 138KV CKT 1'	FROM->TO	1	175.3	142.5556	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11SP	0	G11_031	'CAPROCK REC-GRADY - CAPROCK REC-TRIANGLE 138KV CKT 1'	TO->FROM	1	175.5	142.2222	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11SP	0	G11_031	'CAPROCK REC-KOCH - CAPROCK REC-REED 138KV CKT 1'	TO->FROM	1	175.6	142.0843	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11SP	0	G11_031	'CAPROCK REC-KOCH - CAPROCK REC-VEALMOOR 138KV CKT 1'	FROM->TO	1	175.7	141.9465	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11SP	0	G11_031	'MIDLAND COUNTY INTERCHANGE 230/138KV TRANSFORMER CKT 1'	FROM->TO	1	192.4	129.8857	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11WP	0	G11_031	'HOBBS INTERCHANGE 230/115KV TRANSFORMER CKT 1'	FROM->TO	0.65536	149.6	221.6176	'HOBBS INTERCHANGE - LEA COUNTY INTERCHANGE 230KV CKT 1'
11WP	0	G11_031	'BORDEN COUNTY INTERCHANGE 230/138KV TRANSFORMER CKT 1'	TO->FROM	1	167.9	148.6599	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11WP	0	G11_031	'CAPROCK REC-TATE - CAPROCK REC-TRIANGLE 138KV CKT 1'	FROM->TO	1	175.5	142.3932	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11WP	0	G11_031	'CAPROCK REC-GRADY - CAPROCK REC-TRIANGLE 138KV CKT 1'	TO->FROM	1	175.7	142.1742	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11WP	0	G11_031	'CAPROCK REC-KOCH - CAPROCK REC-REED 138KV CKT 1'	TO->FROM	1	175.8	142.0364	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11WP	0	G11_031	'CAPROCK REC-KOCH - CAPROCK REC-VEALMOOR 138KV CKT 1'	FROM->TO	1	175.9	141.8988	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11WP	0	G11_031	'MIDLAND COUNTY INTERCHANGE 230/138KV TRANSFORMER CKT 1'	FROM->TO	1	209.6	119.2271	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
16SP	0	G11_031	'HOBBS INTERCHANGE 230/115KV TRANSFORMER CKT 1'	FROM->TO	0.65559	148.9	195.8345	'HOBBS INTERCHANGE - LEA COUNTY INTERCHANGE 230KV CKT 1'
16SP	0	G11_031	'CAPROCK REC-TATE - CAPROCK REC-TRIANGLE 138KV CKT 1'	FROM->TO	1	175.9	141.8988	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
16SP	0	G11_031	'CAPROCK REC-GRADY - CAPROCK REC-TRIANGLE 138KV CKT 1'	TO->FROM	1	175.9	141.444	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
16SP	0	G11_031	'CAPROCK REC-KOCH - CAPROCK REC-REED 138KV CKT 1'	TO->FROM	1	175.9	141.1598	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
16SP	0	G11_031	'CAPROCK REC-KOCH - CAPROCK REC-VEALMOOR 138KV CKT 1'	FROM->TO	1	175.9	140.9892	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
16WP	0	G11_031	'HOBBS INTERCHANGE 230/115KV TRANSFORMER CKT 1'	FROM->TO	0.65313	148.3	221.7684	'HOBBS INTERCHANGE - LEA COUNTY INTERCHANGE 230KV CKT 1'
16WP	0	G11_031	'CAPROCK REC-KOCH - CAPROCK REC-VEALMOOR 138KV CKT 1'	FROM->TO	1	175	142.5143	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
16WP	0	G11_031	'CAPROCK REC-KOCH - CAPROCK REC-REED 138KV CKT 1'	TO->FROM	1	175.1	142.49	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
16WP	0	G11_031	'CAPROCK REC-GRADY - CAPROCK REC-TRIANGLE 138KV CKT 1'	TO->FROM	1	175.3	142.3845	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
16WP	0	G11_031	'CAPROCK REC-TATE - CAPROCK REC-TRIANGLE 138KV CKT 1'	FROM->TO	1	175.5	142.2792	'HOBBS INTERCHANGE - MIDLAND COUNTY INTERCHANGE 230KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23183	92.9	126.8683	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22737	92.9	123.8636	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22737	92.9	123.5407	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22737	92.9	121.3878	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22737	92.9	120.5267	'DOMES - MOUND ROAD 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23183	108.5	111.5767	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22737	108.5	109.0961	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22737	108.5	108.8196	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25906	92.9	110.3007	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25906	92.9	110.3007	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22737	108.5	106.9763	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22737	108.5	106.239	'DOMES - MOUND ROAD 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25906	92.9	106.4255	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19403	92.9	102.5473	'BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1'
11G	2	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.26695	142.9	100.9288	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19204	92.9	100.5557	'CLEVELAND - CLEVELANDTAP138.00 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2365	82.7	121.5236	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.26071	82.7	118.7932	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.26071	82.7	118.7932	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23339	82.7	116.6602	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23339	82.7	116.1765	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.26071	82.7	114.4401	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23339	82.7	112.549	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23339	82.7	111.2189	'DOMES - MOUND ROAD 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.2365	95.8	107.9332	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'

Season	Scenario	Source	MontCommonName	Direction	TDF	Rating	Contingency Loading %	Contname
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.26071	95.8	105.5762	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.26071	95.8	105.5762	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23339	95.8	103.7349	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23339	95.8	103.3173	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.26071	95.8	101.8184	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23339	95.8	100.1858	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23515	93.5	121.1016	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23182	93.5	115.8973	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23182	93.5	115.4695	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23182	93.5	113.6513	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2597	93.5	114.8021	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2597	93.5	114.8021	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23182	93.5	112.6888	'DOMES - MOUND ROAD 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2597	93.5	110.8449	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23515	108.8	106.4614	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23182	108.8	101.989	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23182	108.8	101.7132	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.2597	108.8	101.0478	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.2597	108.8	101.0478	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23331	82.2	132.4355	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23331	82.2	131.9489	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2365	82.2	132.3601	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23331	82.2	128.1776	'DOMES - PAWHUSKA TAP 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23331	82.2	126.5961	'DOMES - MOUND ROAD 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23331	95.3	117.5887	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2607	82.2	122.6764	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2607	82.2	122.6764	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.2365	95.3	117.5236	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23331	95.3	117.1689	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2607	82.2	118.1752	'OSAGE - WEBB CITY TAP 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23331	95.3	113.9161	'DOMES - PAWHUSKA TAP 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23331	95.3	112.5519	'DOMES - MOUND ROAD 138KV CKT 1'
16SP	2	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.27276	143	106.6098	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.2607	95.3	109.0661	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.2607	95.3	109.0661	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19108	82.2	107.4404	'FAIRFAX 138/69KV TRANSFORMER CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19066	82.2	106.2433	'CLEVELANDTAP138.00 - STILLWATER 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19916	82.2	106.4866	'BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19113	82.2	105.1411	'ASGI-10-06 138.00 - FAIRFAX 138KV CKT 1'
16SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.2607	95.3	105.2886	'OSAGE - WEBB CITY TAP 138KV CKT 1'
16SP	2	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.2605	143	101.7483	'OMPA-HOMINY - SHIDLER 138KV CKT 1'
16SP	2	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.30193	143	100.6196	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
16SP	2	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.30193	143	100.6196	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
16SP	2	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.2605	143	100.2797	'HIGHWAY 20 - OMPA-HOMINY 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23584	94.3	115.4486	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23288	94.3	110.2609	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23288	94.3	109.9427	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.26001	94.3	110.5005	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.26001	94.3	110.5005	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23288	94.3	108.0339	'DOMES - PAWHUSKA TAP 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23288	94.3	106.9735	'DOMES - MOUND ROAD 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.26001	94.3	106.5769	'OSAGE - WEBB CITY TAP 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23584	109.4	101.6161	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23611	92.9	133.1776	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23315	92.9	129.9569	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23315	92.9	129.634	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'

Season	Scenario	Source	MontCommonName	Direction	TDF	Rating	Contingency Loading %	Contname
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23315	92.9	127.4812	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23315	92.9	126.62	'DOMES - MOUND ROAD 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23611	108.5	116.9788	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2603	92.9	121.0549	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2603	92.9	121.0549	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23315	108.5	114.3134	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23315	108.5	114.0369	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2603	92.9	117.1798	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23315	108.5	112.1936	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23315	108.5	111.4562	'DOMES - MOUND ROAD 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.1907	92.9	107.6857	'FAIRFAX 138/69KV TRANSFORMER CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19884	92.9	107.7158	'BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19022	92.9	107.1518	'CLEVELANDTAP138.00 - STILLWATER 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19073	92.9	106.831	'ASGI-10-06 138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.27345	142.9	105.8712	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19209	92.9	105.8321	'SOONER (SOONER5) 345/138/13.8KV TRANSFORMER CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.2603	108.5	106.6912	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.2603	108.5	106.6912	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19659	92.9	105.6168	'CLEAVELAND - CLEVELANDTAP138.00 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.2603	108.5	103.2811	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11G	2	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.26119	142.9	101.0063	'OMPA-HOMINY - SHIDLER 138KV CKT 1'
11G	2	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.26119	142.9	100.0266	'HIGHWAY 20 - OMPA-HOMINY 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23162	82.7	120.3434	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25885	82.7	118.3434	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25885	82.7	118.3434	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22721	82.7	115.1657	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22721	82.7	114.682	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25885	82.7	113.9903	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22721	82.7	111.0544	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22721	82.7	109.7243	'DOMES - MOUND ROAD 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23162	95.8	106.9144	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.25885	95.8	105.1879	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.25885	95.8	105.1879	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22721	95.8	102.4447	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22721	95.8	102.0271	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11SP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.25885	95.8	101.4301	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23146	93.5	120.3123	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22698	93.5	114.862	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22698	93.5	114.4342	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25882	93.5	114.6139	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25882	93.5	114.6139	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22698	93.5	112.6161	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22698	93.5	111.6535	'DOMES - MOUND ROAD 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25882	93.5	110.6567	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23146	108.8	105.7831	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22698	108.8	101.0993	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.25882	108.8	100.886	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.25882	108.8	100.886	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22698	108.8	100.8235	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23179	94.3	114.5896	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2273	94.3	109.0774	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25883	94.3	110.2503	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25883	94.3	110.2503	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2273	94.3	108.7593	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2273	94.3	106.8505	'DOMES - PAWHUSKA TAP 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.2273	94.3	105.79	'DOMES - MOUND ROAD 138KV CKT 1'

Season	Scenario	Source	MontCommonName	Direction	TDF	Rating	Contingency Loading %	Contname
16WP	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25883	94.3	106.3266	'OSAGE - WEBB CITY TAP 138KV CKT 1'
16WP	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23179	109.4	100.8757	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.23183	92.9	132.2562	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22737	92.9	128.7126	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22737	92.9	128.3897	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22737	92.9	126.2368	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.22737	92.9	125.3757	'DOMES - MOUND ROAD 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.23183	108.5	116.1899	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25906	92.9	120.7879	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25906	92.9	120.7879	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22737	108.5	113.2479	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22737	108.5	112.9714	'PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.25906	92.9	116.9128	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22737	108.5	111.1281	'DOMES - PAWHUSKA TAP 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.22737	108.5	110.3908	'DOMES - MOUND ROAD 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19403	92.9	106.6803	'BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.25906	108.5	106.4627	'FAIRFAX TAP - SHIDLER 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.25906	108.5	106.4627	'FAIRFAX TAP - WEBB CITY TAP 138KV CKT 1'
11G	2	G11_006	'SHIDLER - WEST PAWHUSKA 138KV CKT 1'	FROM->TO	0.26695	142.9	104.9615	'CLEVELANDTAP138.00 - FAIRFAX 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 TAP - SAND SPRINGS 138KV CKT 1'	FROM->TO	0.19204	92.9	104.6372	'CLEVELAND - CLEVELANDTAP138.00 138KV CKT 1'
11G	2	G11_006	'HIGHWAY 20 - HIGHWAY 20 TAP 138KV CKT 1'	FROM->TO	0.25906	108.5	103.0525	'OSAGE - WEBB CITY TAP 138KV CKT 1'
11SP	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20281	48	103.8792	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	2	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20281	48	100.9625	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20214	47.7	113.4759	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20214	52.8	110.6591	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20214	47.7	110.5409	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20214	52.8	108.197	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20214	54.8	104.7956	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20214	54.8	102.2409	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20814	47.8	112.6109	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20814	52.9	110.2609	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20814	47.8	109.4728	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20814	52.9	107.4253	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20814	54.8	104.6131	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20814	54.8	101.8759	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'DUNCAN (DUNCAN) 138/69/13.8KV TRANSFORMER CKT 1'	FROM->TO	0.20814	71.8	100.5961	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'DUNCAN (DUNCAN) 138/69/13.8KV TRANSFORMER CKT 1'	FROM->TO	0.20814	72	100.3167	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20347	47.9	105.6242	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20347	53	104.3283	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20347	47.9	102.4927	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20347	53	101.4981	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20233	48	103.6792	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11SP	2	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20233	48	100.7625	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20192	47.7	113.3837	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20192	52.8	110.5758	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20192	47.7	110.4486	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20192	52.8	108.1136	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20192	54.8	104.7153	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11WP	2	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20192	54.8	102.1606	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20788	47.8	112.5021	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20788	52.9	110.1626	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20788	47.8	109.364	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20788	52.9	107.327	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20788	54.8	104.5182	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'COMANCHE TAP - TOSCO 69KV CKT 1'	TO->FROM	0.20788	54.8	101.781	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
16WP	2	G11_029	'DUNCAN (DUNCAN) 138/69/13.8KV TRANSFORMER CKT 1'	FROM->TO	0.20788	71.8	100.5237	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'

Season	Scenario	Source	MontCommonName	Direction	TDF	Rating	Contingency Loading %	Contname
16WP	2	G11_029	'DUNCAN (DUNCAN) 138/69/13.8KV TRANSFORMER CKT 1'	FROM->TO	0.20788	72	100.2445	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20284	47.9	105.3612	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20284	53	104.0906	'G11-029 138.00 - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	2	G11_029	'COMANCHE - COMANCHE TAP 69KV CKT 1'	TO->FROM	0.20284	47.9	102.2296	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'
11G	2	G11_029	'DUNCAN - TOSCO 69KV CKT 1'	FROM->TO	0.20284	53	101.2604	'CORNVILLE - RUSH SPRINGS NATURAL GAS TAP 138KV CKT 1'