

# Screening Study SPP-LTSR- 2011- 006

For OASIS Request #75627520, 75627527, #75627530, 75627533,  
75627554, 75627557, 75627566, 75627572

MAINTAINED BY  
SPP Engineering, SPP Transmission Service Studies  
August 5, 2011

*Copyright © 2011 by Southwest Power Pool, Inc. All rights reserved.*



## Table of Contents

<b>Executive Summary .....</b>	<b>2</b>
<b>Introduction.....</b>	<b>3</b>
<b>Study Methodology .....</b>	<b>4</b>
Description .....	4
Model Updates .....	4
Transmission Request Modeling.....	5
Transfer Analysis.....	5
<b>Study Results.....</b>	<b>6</b>
Study Analysis Results.....	6
<b>Conclusion .....</b>	<b>7</b>
<b>Appendix A.....</b>	<b>8</b>

## Executive Summary

Southwestern Public Service Company has requested a screening study to determine the impacts on SPP facilities due to the Long Term Service Requests for 190 MW. The service type requested for this screening study is Long Term Service Request (LTSR). OASIS# 75627527, 75627527, 75627530, 75627533, 75627554, 75627557, 75627566, and 75627572 were studied as one request from 1/1/2012 to 1/1/2022.

The principal objective of this study is to identify system problems and potential system modifications necessary to facilitate the LTSR request while maintaining system reliability. The LTSR request was studied using two system scenarios. The service was modeled by the transfers from SPS to SPS. The two scenarios were studied to capture system limitations caused or impacted by the requested service. An analysis was conducted on the planning horizon from 1/1/2012 to 1/1/2022.

The service was modeled from SPS to SPS. Facilities on the SPP system were identified for the requested service due to the SPP Study Methodology criteria. Tables 1 and 2 summarize the results of the screening study analysis for the transfers for the scenarios listed in the table. Table 1 lists SPP thermal transfer limitations identified. Table 2 lists SPP voltage transfer limitations identified. Table 3 lists the network upgrades required to mitigate the limitations impacted by this request.

## Introduction

Southwestern Public Service Company has requested a screening study to determine the impacts on SPP facilities for the Long Term Service Requests for 190 MW.

The purpose of the LTSR Option Screening Study is to provide the Eligible Customer with an approximation of the transmission remediation costs of each potential LTSR and a reasonable cost differential between alternatives for the purpose of an Eligible Customer's ranking of its potential LTSRs. The results of the Screening Study are not binding and the Eligible Customer retains the rights to enter the Aggregate Transmission Service Study. The Screening Study results will not assess the third party impacts and upgrades required. Service will not be granted based on the Screening Study for potential LTSRs on the Transmission System. To obtain a Service Agreement, Eligible Customers must apply for service and follow the application process set forth in Parts II and III of the Tariff.

This study includes steady-state contingency analysis (PSS/E function ACCC). The steady-state analysis considers the impact of the request on transmission line and transformer loadings for outages of single transmission lines, transformers, and generating units, and selected multiple transmission lines and transformers on the SPP and first-tier third party systems.

The LTSR request was studied using two system scenarios. The service was modeled by a transfer from SPS to SPS. The two scenarios were studied to capture the system limitations caused or impacted by the requested service. Scenario 0 includes projected usage of transmission service included in the SPP 2010 Series Cases. Scenario 5 includes transmission service not already included in the SPP 2010 Series Cases.

## Study Methodology

### Description

The facility study analysis was conducted to determine the steady-state impact of the requested service on the SPP system. The steady-state analysis was performed to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled. SPP conforms to NERC Reliability Standards, which provide strict requirements related to voltage violations and thermal overloads during normal conditions and during a contingency. NERC Standards require all facilities to be within normal operating ratings for normal system conditions and within emergency ratings after a contingency.

Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP Model Development Working Group (MDWG) models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 105% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 103.5% and 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69 kV and above; first tier non-SPP control area branches and ties 115 kV and above; any defined contingencies for these control areas; and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV. and above,. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

### Model Updates

SPP used six seasonal models to study the SPS to SPS 190 MW request for the requested service period. The following SPP Transmission Expansion Plan 2010 Build 2

Cases were used to study the impact of the requested service on the transmission system:

- 2011/12 Winter Peak (11WP)
- 2012 Summer Peak (12SP)
- 2012/13 Winter Peak (12WP)
- 2016 Summer Peak (16SP)
- 2016/17 Winter Peak (16WP)
- 2021 Summer Peak (21SP)

The Spring Peak models apply to April and May, the Summer Peak models apply to June through September, the Fall Peak models apply to October and November, and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the current modeling information. From the six seasonal models, two system scenarios were developed. Scenario 0 includes projected usage of transmission included in the SPP 2010 Series Cases. Scenario 5 includes transmission not already included in the SPP 2010 Series Cases.

### **Transmission Request Modeling**

Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation because the requested Network Integration Transmission Service is a request to serve network load with the new designated network resource, and the impacts on the Transmission System are determined accordingly. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the request source and redispatching the request sink.

### **Transfer Analysis**

Using the selected cases both with and without the requested transfer modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

## Study Results

### Study Analysis Results

Tables 1 and 2 contain the initial steady-state analysis results of the LTSR. The tables are attached to the end of this report, if applicable. The tables identify the scenario and season in which the event occurred, the transfer amount studied, the facility control area location, applicable ratings of the thermal transfer limitations and voltage transfer limitations, and the loading percentage and voltage per unit (pu).

Table 1 lists the SPP thermal transfer limitations caused or impacted by the 190 MW requested transfers for applicable scenarios. Solutions are identified for the limitations in this table.

Table 2 lists the SPP voltage transfer limitations caused or impacted by the 190 MW requested transfers for applicable scenarios. Solutions are identified for the violations in this table.

Table 3 lists the network upgrades required to mitigate the limitations caused or impacted by this request. Engineering and construction costs are provided for assigned upgrades in this table.

## Conclusion

The results of the screening study show that limiting constraints exist within the SPP regional transmission system for the requested transfer of 190 MW. The next steps are to WITHDRAW the request on OASIS and, if desired, enter a new OASIS request into the aggregate study queue.

The results contained in this study are for informational purposes only. Service will not be granted based on the Screening Study results. To obtain a Service Agreement, Eligible Customers must apply for service and follow the application processes set forth in Parts II and III of the Tariff and enter the Aggregate Study process. The results of the Aggregate Study may vary from the results of this screening study.

As a final step in this process, it is requested that the customer WITHDRAW the LTSR screening study request on OASIS.



## Appendix A

### PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

**BASE CASES:**

- Solutions: Fixed slope decoupled Newton-Raphson solution (FDNS)
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads
- VAR limits: Apply immediately
- Solution options:
  - Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

**ACCC CASES for system intact:**

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- Contingency case rating: Rate A
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3 MW
- Excl'd cases w/ no overloads form report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads
- VAR limits: Apply automatically
- Solution options:
  - Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

**ACCC CASES for branch and transformer contingencies:**

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary

- Min flow change in overload report: 3mw
- Excl'd cases w/ no overloads from report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads
- VAR limits: Apply automatically
- Solution options:
  - X Phase shift adjustment
  - \_ Flat start
  - \_ Lock DC taps
  - \_ Lock switched shunts

**ACCC CASES for generator contingencies (largest machine at a bus):**

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3mw
- Excl'd cases w/ no overloads from report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Disabled
- Var limits: Apply automatically
- Solution options:
  - X Phase shift adjustment
  - \_ Flat start
  - \_ Lock DC taps
  - \_ Lock switched shunts

Scenario	Season	From Area	To Area	Monitored Branch Over 100% Rate B	Transfer Case % Loading	TDF (%)	Outaged Branch Causing Overload	Upgrade Name	Solution
5	12WP	SPS	SPS	BUSHLAND INTERCHANGE - DEAF SMITH COUNTY INTERCHANGE 230KV CKT 1	110.0	27.4%	GEN525562 1-TOLK GEN #2 24 KV	Priority Project	
5	12WP	SPS	SPS	BUSHLAND INTERCHANGE - DEAF SMITH COUNTY INTERCHANGE 230KV CKT 1	106.3	27.4%	GEN525561 1-TOLK GEN #1 24 KV	Priority Project	
5	12SP	SPS	SPS	CANYON EAST SUB - OSAGE SWITCHING STATION 115KV CKT 1	102.5	13.4%	BUSHLAND INTERCHANGE - DEAF SMITH COUNTY INT	526_SPS_Osage_Termination_Mods Accelerate	Construct approximately 2 miles of new 115 kV line from Randall Co. with 795 ACSR. Tie new line into V70 around (not to) Osage Substation. Add new 115 kV terminal at Randall Co. Interchange. (Re-build Randall 115 kV bus to breaker and one-half design.) Re-Conductor V70 with 795 ACSR. Remove line termination at Osage Substation. Upgrade terminal equipment and reset relays at South Georgia Interchange. Remove V04 termination from Osage and remove circuit back to Manhattan Tap (remove 3-terminal condition). Remove circuits V67 & V05 terminations from Osage and tie together around Osage Substation. Leave only V43 & T75 terminated at the Osage Substation.
5	12WP	SPS	SPS	CANYON EAST SUB - OSAGE SWITCHING STATION 115KV CKT 1	107.9	12.5%	BUSHLAND INTERCHANGE - DEAF SMITH COUNTY INT	526_SPS_Osage_Termination_Mods Accelerate	Construct approximately 2 miles of new 115 kV line from Randall Co. with 795 ACSR. Tie new line into V70 around (not to) Osage Substation. Add new 115 kV terminal at Randall Co. Interchange. (Re-build Randall 115 kV bus to breaker and one-half design.) Re-Conductor V70 with 795 ACSR. Remove line termination at Osage Substation. Upgrade terminal equipment and reset relays at South Georgia Interchange. Remove V04 termination from Osage and remove circuit back to Manhattan Tap (remove 3-terminal condition). Remove circuits V67 & V05 terminations from Osage and tie together around Osage Substation. Leave only V43 & T75 terminated at the Osage Substation.
5	11WP	SPS	SPS	HAPPY INTERCHANGE - PALO DURO SUB 115KV CKT 1	115.6	11.2%	AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	Reconductor Randall - Kress 115 kV with 795 ACSR
5	12WP	SPS	SPS	HAPPY INTERCHANGE - PALO DURO SUB 115KV CKT 1	123.1	10.8%	AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	Reconductor Randall - Kress 115 kV with 795 ACSR
5	11WP	SPS	SPS	HAPPY INTERCHANGE - TULIA TAP 115KV CKT 1	105.4	11.2%	AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	Reconductor Randall - Kress 115 kV with 795 ACSR
5	12WP	SPS	SPS	HAPPY INTERCHANGE - TULIA TAP 115KV CKT 1	112.7	10.8%	AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	Reconductor Randall - Kress 115 kV with 795 ACSR
5	16SP	SPS	SPS	Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2	105.3	15.5%	JONES STATION - LUBBOCK SOUTH INTERCHANGE 230	Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2	Upgrade Line trap at both Jones Bus # 2and Lubbock South interchange
5	11WP	SPS	SPS	KRESS INTERCHANGE - TULIA TAP 115KV CKT 1	102.3	11.2%	AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	Reconductor Randall - Kress 115 kV with 795 ACSR
5	12WP	SPS	SPS	KRESS INTERCHANGE - TULIA TAP 115KV CKT 1	109.6	10.8%	AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	Reconductor Randall - Kress 115 kV with 795 ACSR
5	11WP	SPS	SPS	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	116.9	11.2%	AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	Reconductor Randall - Kress 115 kV with 795 ACSR
5	12WP	SPS	SPS	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	124.5	10.8%	AMARILLO SOUTH INTERCHANGE - SWISHER COUNTY	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	Reconductor Randall - Kress 115 kV with 795 ACSR
5	16WP	SPS	SPS	SUNDOWN INTERCHANGE 230/115KV TRANSFORMER CKT 1	101.1	9.6%	AMOCO SWITCHING STATION - SUNDOWN INTERCHAN	SUNDOWN INTERCHANGE 230/115KV TRANSFORMER CKT 1	Upgrade the Sundown 230/115 kV TF.
5	16SP	SPS	SPS	SWISHER COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	103.8	3.9%	PALO DURO SUB - RANDALL COUNTY INTERCHANGE	SWISHER COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	Upgrade the Swisher County 230/115 kV TF.
5	16SP	SPS	SPS	SWISHER COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	103.3	3.9%	SPP-SWPS-T66	SWISHER COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	Upgrade the Swisher County 230/115 kV TF.
5	12WP			SPSNORTH_STH	112.7	79.9%	BASECASE	Priority Project	TUCO - WOODWARD 345 KV CKT 1

Scenario	Season	Area	Monitored Bus with Violation	Post-transfer Voltage (PU)	Outaged Branch Causing Overload	Upgrade Name	Solution
			None				

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost	RTO Determined Need Date
SPS	Line - Osage Station and Line Re-termination Accelerate	Construct approximately 2 miles of new 115 kV line from Randall Co. with 795 ACSR. Tie new line into V70 around (not to) Osage Substation. Add new 115 kV terminal at Randall Co. Interchange. (Re-build Randall 115 kV bus to breaker and one-half design.) Re-Conductor V70 with 795 ACSR. Remove line termination at Osage Substation. Upgrade terminal equipment and reset relays at South Georgia Interchange. Remove V04 termination from Osage and remove circuit back to Manhattan Tap (remove 3-terminal condition). Remove circuits V67 & V05 terminations from Osage and tie together around Osage Substation. Leave only V43 & T75 terminated at the Osage Substation.	6/1/2012	6/1/2012	\$672,000	6/1/2016
SPS	SUNDOWN INTERCHANGE 230/115KV TRANSFORMER CKT 1	Upgrade the Sundown 230/115 kV TF.	10/1/2013	10/1/2013	\$5,953,500	

**Construction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.**

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
SPS	Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2	Upgrade Line trap at both Jones Bus # 2and Lubbock South Interchange	6/1/2013	6/1/2013	\$500,000

**Expansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.**

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
SPS	PALO DURO SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	Reconductor Randall - Kress 115 kV with 795 ACSR	6/1/2013	6/1/2016
OKGE	TUCO - WOODWARD 345 KV CKT 1 OKGE	Build new 345 kV line from Woodward EHV to Tuco	10/1/2012	6/1/2014

**Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.**

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
SPS	SWISHER COUNTY INTERCHANGE 230/115KV TRANSFORMER CKT 1	Upgrade the Swisher County 230/115 kV TF.	6/1/2016	6/1/2016

**Priority Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.**

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
MKEC	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	Build a new 55 mile double circuit 345 kV line	7/31/2011	1/1/2015
MKEC	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	Build a new 35 mile double circuit 345 kV line with at least 3000 A capacity from the new Medicine Lodge 345 kV substation to the WR interception from the Wichita substation.	7/31/2011	1/1/2015
MKEC	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	Build a new 28.6 mile dbl ckt 345 kV line with at least 3000 A capacity from the Medicine Lodge sub to the KS/OK state border towards the Woodward District EHV sub. Install the necessary breakers and terminal equipment at the Medicine Lodge sub.	7/31/2011	1/1/2015
MKEC	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	Build a new 27.5 mile double circuit 345 kV line	7/31/2011	1/1/2015
MKEC	XFR - Medicine Lodge 345/138 kV	Install a 400 MVA 345/138 kV transformer at the new 345 kV Medicine Lodge substation.	7/31/2011	1/1/2015
OKGE	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	Build a new 60.5 mile double circuit 345 kV line	7/31/2011	7/1/2014
OKGE	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	Build a new 79 mile dbl ckt 345 kV line with at least 3000 A capacity from the Woodward District EHV sub to the KS/OK state border towards the Medicine Lodge sub. Upgrade the Woodward District EHV sub with the necessary breakers and terminal equipment.	7/31/2011	1/1/2015
SPS	Line - Hitchland - Woodward 345 kV dbl ckt SPS	Build a new 60.5 mile double circuit 345 kV line	7/31/2011	7/1/2014
SUNC	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	Build a new 27.5 mile double circuit 345 kV line with at least 3000 A capacity from the Spearville substation to the MKEC interception point from the new Comanche County substation.	7/31/2011	1/1/2015
WERE	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	Build a new 35 mile double circuit 345 kV line	7/31/2011	1/1/2015

\* The previously identified Network Upgrade may be accelerated. The accelerated cost would be based on the change in date from the respective "RTO Determined Need Date" to the Estimated Date of Upgrade Completion (EOC) in accordance with Financial Analysis of the Aggregate Transmission Service Study (See Financial Analysis section). An expected cost may be estimated by assuming 5-10% of the Estimated Engineering & Construction Cost per year.