



Aggregate Facility Study

SPP-2012-AG1-AFS-1

3/30/2012

SPP Engineering, SPP Transmission Service Studies



Table of Contents

Table of Contents	1
Executive Summary	2
Introduction.....	3
Financial Analysis	5
Third-Party Facilities	6
Study Methodology	6
Description	6
Model Development.....	7
Transmission Request Modeling.....	8
Transfer Analysis.....	8
Curtailment and Redispatch Evaluation.....	8
Study Results	9
Study Analysis Results	9
Example A:.....	10
Example B:.....	10
Example C:.....	11
Study Definitions	11
Conclusion	12
Appendix A	13
BASE CASE SETTINGS:	13
ACCC CASE SETTINGS:.....	13

Executive Summary

Pursuant to Attachment Z1 of the Southwest Power Pool, Inc. (SPP) Open Access Transmission Tariff (OATT), 3019 MW of long-term transmission service requests have been studied in this Aggregate Facility Study (AFS). The principal objective of the AFS is to identify system problems and potential modifications necessary to facilitate these transfers while maintaining or improving system reliability, as well as summarizing the operating limits and determination of the financial characteristics associated with facility upgrades. A highly tangible benefit of studying transmission requests aggregately under the SPP OATT Attachment Z1 is the sharing of costs among Transmission Customers using the same facility. Facility upgrade costs are allocated on a prorated basis to all requests positively impacting any individual overloaded facility.

Attachment Z2 further provides for facility upgrade cost recovery by stating: “Transmission Customers paying Directly Assigned Upgrade Costs for Service Upgrades or that are in excess of the Safe Harbor Cost Limit for Network Upgrades associated with new or changed Designated Resources and Project Sponsors paying Directly Assigned Upgrade Costs for Sponsored Upgrades shall receive revenue credits in accordance with Attachment Z2. Generation Interconnection Customers paying for Network Upgrades shall receive credits for new transmission service using the facility as specified in Attachment Z1.”

- The AFS determined that the total assigned facility upgrade Engineering and Construction (E&C) cost is \$98 Million. Additionally an indeterminate amount of assigned E&C cost for third party facility upgrades are assignable to the customer.
- Total upgrade levelized revenue requirements for all transmission requests after consideration of potential base plan funding is \$27 Million.

To accommodate the requested SPP Transmission Service, third-party facilities must be upgraded when the third-party transmission provider determines that they are constrained. Third-party facilities include both first-tier neighboring facilities outside SPP and Transmission Owner facilities within SPP that are not under the SPP OATT. In this AFS, third-party facilities were identified. Total E&C cost estimates for required third-party facility upgrades are applicable.

SPP will tender a Letter of Intent on March 30, 2012. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), SPP must receive from the Customer by April 14, 2012, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to withdraw the request or leave the request in study mode.

At the conclusion of the ATSS, Service Agreements for each request for service will be tendered identifying the terms and conditions of the confirmed service.

If Customers withdraw from the ATSS after posting of this AFS, the AFS will be re-performed to determine final cost allocation and Available Transmission Capability (ATC) in consideration of the remaining ATSS participants. All allocated revenue requirements for facility upgrades are assigned

to the Customer in the AFS data tables. Potential base plan funding allowable is contingent upon validation of designated resources meeting Attachment J, Section III B criteria.

Introduction

Important milestones and dates in SPP's Aggregate Transmission Study process:

- In 2005, the Federal Energy Regulatory Commission (FERC) accepted SPP's proposed Aggregate Transmission Study procedures in Docket ER05-109.
- In 2008, in Docket ER08-1379-000 SPP filed with FERC to pair open seasons closing during January 2010 with an effective date of August 9, 2008.
- In January 2010, in Docket ER10-659-000 SPP filed with FERC to extend its current practice of pairing open seasons through January 31, 2011, with an effective date of January 28, 2010.
- In March 2010, in Docket ER10-659-000 FERC issued a letter order accepting SPP's proposal to continue to pair open seasons through January 31, 2011, effective January 28, 2010.
- All requests for long-term transmission service with a signed study agreement received before January 31, 2012 for 2012-AG1 have been included in this first Aggregate Transmission Service Study (ATSS) of 2012.

Approximately 3019 MW of long-term Transmission Service was studied in this Aggregate Facility Study (AFS), and over \$98 Million in transmission upgrades is proposed. The results of the AFS are detailed in Tables 1 through 6. Detailed results depict individual upgrade costs by study and potential base plan allowances determined by Attachments J and Z1. The [OATT](#) may be accessed at SPP's website by going to [SPP.org>Org Groups>Governing Documents](#).

To understand the extent to which Base Plan Upgrades may be applied to both Point-to-Point (PTP) and Network Transmission Services, it is necessary to highlight the definition of Designated Resource. Per Section 1.9a of the SPP OATT, a Designated Resource is:

“[a]ny designated generation resource owned, purchased or leased by a Transmission Customer to serve load in the SPP Region. Designated Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Transmission Customer's load on a non-interruptible basis.”

Network and PTP service has potential for base plan funding if the conditions for classifying upgrades associated with designated resources as Base Plan Upgrades as defined in Section III.B of Attachment J are met.

Pursuant to Attachment J, Section III B of the SPP OATT, the Transmission Customer must provide SPP information necessary to verify that the new or changed Designated Resource meets the following conditions:

1. Transmission Customer's commitment to the requested new or changed Designated Resource must have a duration of at least five years.
2. During the first year the Designated Resource is planned to be used by the Transmission Customer, the accredited capacity of the Transmission Customer's existing Designated Resources plus the lesser of:
 - a. The planned maximum net dependable capacity applicable to the Transmission Customer or
 - b. The requested capacity; shall not exceed 125% of the Transmission Customer's projected system peak responsibility determined pursuant to SPP Criteria 2.

According to Attachment Z1 Section VI.A, PTP customers pay the higher of the monthly transmission access charge (base rate) or the monthly revenue requirement associated with the assigned facility upgrades, including any prepayments for redispatch required during construction.

Network Integration Service Customers pay the total monthly transmission access charges and the monthly revenue requirement associated with the facility upgrades, including any prepayments for redispatch during construction.

Transmission Customers paying for a directly assigned Network Upgrade shall receive credits for new transmission service using the facility as specified in Attachment Z2.

Facilities identified as limiting the requested Transmission Service have been reviewed to determine the required in-service date of each Network Upgrade. The year that each Network Upgrade is required to accommodate a request is determined by interpolating between the applicable model years given the respective loading data. Both previously assigned facilities and the facilities assigned to this request for Transmission Service were evaluated.

In some instances, due to lead times for engineering and construction, Network Upgrades may not be available when required to accommodate a request for Transmission Service. When this occurs, the ATC with available Network Upgrades will be less than the capacity requested during either a portion of or all of the requested reservation period. As a result, the lowest seasonal allocated ATC within the requested reservation period will be offered to the Transmission Customer on an applicable annual basis as listed in Table 1. The ATC may be limited by transmission owner planned projects, expansion plan projects, or Customer assigned upgrades.

Some constraints identified in the AFS were not assigned to the Customer because SPP, the Transmission Provider, determined that upgrades are not required due to various reasons or the Transmission Owner has construction plans pending for these upgrades. These facilities are listed by reservation in Table 3. This table also includes constrained facilities in the current planning horizon that limit the rollover rights of the Transmission Customer. Table 6 lists possible redispatch pairs to allow start of service prior to completion of assigned Network Upgrades. Table 7 (if applicable) lists

deferral of expansion plan projects with different upgrades with the new required in service date as a result of this AFS.

Financial Analysis

The AFS utilizes the allocated Customer's E&C cost in a present worth analysis to determine the monthly leveled revenue requirement of each facility upgrade over the term of the reservation. In some cases, Network Upgrades cannot be completed within the requested reservation period, thus deferred reservation periods will be utilized in the present worth analysis. If the Customer chose Option 2, Redispatch, in the Letter of Intent sent coincident with the initial AFS, the present worth analysis of revenue requirements will be based on the deferred term with redispatch in the subsequent AFS. The upgrade leveled revenue requirement includes interest, depreciation, and carrying costs.

Each request for Transmission Service is evaluated independently as the cost associated with each Network Upgrade is assigned to a request. When facilities are upgraded throughout the reservation period, the Transmission Customer shall 1) pay the total E&C costs and other annual operating costs associated with the new facilities, and 2) receive credits associated with the depreciated book value of removed usable facilities; salvage value of removed non-usable facilities; and the carrying charges, excluding depreciation, associated with all removed usable facilities based on their respective book values.

In the event that the engineering and construction of a previously assigned Network Upgrade may be accelerated, with no additional upgrades, to accommodate a new request for Transmission Service, the leveled present worth of only the incremental expenses though the reservation period of the new request, excluding depreciation, shall be assigned to the new request. These incremental expenses, excluding depreciation, include:

1. The leveled difference in present worth of the engineering and construction expenses given the change in date to complete construction to account for additional interest expense and reduced engineering and construction expense due to inflation,
2. The leveled present worth of all expediting fees, and
3. The leveled present worth of the incremental annual carrying charges, excluding depreciation and interest, during the new reservation period taking into account both:
 - a. The reservation in which the project was originally assigned, and
 - b. A reservation, if any, in which the project was previously accelerated.

In the case of a Base Plan Upgrade being displaced or deferred by an earlier in service date for a requested upgrade, achievable base plan avoided revenue requirements shall be determined per Attachment J, Section VII.B methodology. A deferred Base Plan Upgrade is defined as a different requested Network Upgrade needed at an earlier date that negates the need for the initial Base Plan

Upgrade within the planning horizon. A displaced Base Plan Upgrade is defined as the same Network Upgrade being displaced by a requested upgrade needed at an earlier date.

A 40-year service life assumption is utilized for Base Plan funded projects, unless another assumption is provided by the Transmission Owner. A present worth analysis of revenue requirements on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan revenue requirements due to the displacement or deferral of the Base Plan Upgrade by the Requested Upgrade. The difference in present worth between the Base Plan and Requested Upgrades is assigned to the transmission requests impacting this upgrade based on the displacement or deferral.

Third-Party Facilities

For third-party facilities listed in Table 3 and Table 5, the Transmission Customer is responsible for funding the necessary upgrades of these facilities per Section 21.1 of the Transmission Provider's OATT. In this AFS, third-party facilities were identified. Total E&C cost estimates for required third-party facility upgrades are applicable. The Transmission Provider will undertake reasonable efforts to assist the Transmission Customer in making arrangements for necessary engineering, permitting, and construction of the third-party facilities. Third-party facility upgrade E&C cost estimates are not utilized to determine the present worth value of leveled revenue requirements for SPP system Network Upgrades.

All modeled facilities within the Transmission Provider system were monitored during the development of this study, as well as certain facilities in first-tier neighboring systems. Third-party facilities must be upgraded when it is determined that they are overloaded while accommodating the requested Transmission Service. An agreement between the Customer and third party owner detailing the mitigation of the third party impact must be provided to the Transmission Provider prior to tendering of a Transmission Service Agreement. These facilities also include those owned by members of the Transmission Provider who have not placed their facilities under the Transmission Provider's OATT. Upgrades on the Southwest Power Administration network requires prepayment of the upgrade cost prior to construction of the upgrade.

Third-party facilities are evaluated for only those requests whose load sinks within the SPP footprint. The Customer must arrange for study of third party facilities for load that sinks outside the SPP footprint with the applicable Transmission Providers.

Study Methodology

Description

The facility study analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier non-SPP control area systems. The steady-state analysis was performed to ensure current SPP Criteria and NERC Reliability Standards requirements are fulfilled.

SPP conforms to NERC Reliability Standards, which provide strict requirements related to voltage violations and thermal overloads during normal conditions and during a contingency. NERC Standards require all facilities to be within normal operating ratings for normal system conditions and within emergency ratings after a contingency.

Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP Model Development Working Group (MDWG) models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 105% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 103.5% and 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69 kV and above; first tier non-SPP control area branches and ties 115 kV and above; any defined contingencies for these control areas; and generation unit outages for the control areas with SPP reserve share program redispatch. The monitor elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier non-SPP control area branches and ties 115 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3 % transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier non-SPP control area facilities, a 3 % TDF cutoff was applied to AECI, AMRN (Ameren), and ENTR (Entergy) control areas. A 2 % TDF cutoff was applied to WAPA. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

Model Development

SPP used six seasonal models to study the aggregate transfers of 3019 MW over a variety of requested service periods. The following SPP Transmission Expansion Plan 2011 Build 2 Cases were used to study the impact of the requested service on the transmission system:

- 2012/13 Winter Peak (12WP)
- 2013 Summer Peak (13SP)
- 2013/14 Winter Peak (13WP)
- 2017 Summer Peak (17SP)
- 2017/18 Winter Peak (17WP)
- 2022 Summer Peak (22SP)

The Summer Peak models apply to June through September and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the current modeling information. One group of requests was developed from the aggregate of 3019 MW to model the requested service. From the six seasonal models, two system scenarios were developed. Scenario 0 includes projected usage of transmission included in the SPP 2011 Series Cases. Scenario 5 includes transmission service not already included in the SPP 2011 Series Cases.

Transmission Request Modeling

Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation transfers. Network Integration Transmission Service requests are modeled as Generation to Load transfers in addition to Generation to Generation because the requested Network Integration Transmission Service is a request to serve network load with the new designated network resource, and the impacts on Transmission System are determined accordingly. Point-To-Point Transmission Service requests are modeled as Generation to Generation transfers. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the request source and redispatching the request sink.

Transfer Analysis

Using the selected cases both with and without the requested transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. Transfer distribution factor cutoffs (SPP and 1st-Tier) and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

Curtailment and Redispatch Evaluation

During any period in which SPP determines that a transmission constraint exists on and may impair Transmission System reliability, SPP will take whatever actions are reasonably necessary to maintain reliability. If SPP determines Transmission System reliability can be maintained by redispatching resources, it will evaluate the interim curtailment of existing confirmed service or interim redispatch of units to provide service prior to completion of any assigned Network Upgrades. Any redispatch may not unduly discriminate between the Transmission Owners' use of the Transmission System on behalf of their Native Load Customers and any Transmission Customer's use of the Transmission System to serve its designated load. Redispatch was evaluated to provide only interim service during the time frame prior to completion of any assigned Network Upgrades. Curtailment of existing confirmed service is evaluated to provide only interim service. Curtailment of existing confirmed service is only evaluated at the request of the transmission Customer.

SPP determined potential relief pairs to relieve the incremental MW impact on limiting facilities as identified in Table 6. Using the selected cases where the limiting facilities were identified, potential incremental and decremental units were identified by determining the generation amount available for increasing and decreasing from the units generation amount, maximum generation amount, and minimum generation amount. If the incremental or decremental amount was greater than 1 MW, the unit was considered as a potential incremental or decremental unit.

Generation shift factors were calculated for the potential incremental and decremental units using Managing and Utilizing System Transmission (MUST). Relief pairs from the generation shift factors for the incremental and decremental units with a greater than 3% TDF on the limiting constraint were determined from the incremental units with the lowest generation shift factors and decremental units with highest generation shift factors. If the aggregate redispatch amount for the potential relief pair was determined to be three times greater than the lower of the increment or decrement, then the pair was determined not to be feasible and is not included. Transmission Customers can request SPP

to provide additional relief pairs beyond those determined. The potential relief pairs were not evaluated to determine impacts on limiting facilities in the SPP and first tier systems. The SPP Reliability Coordinator would call upon the redispatch requirements before implementing NERC TLR Level 5a.

Study Results

Study Analysis Results

Tables 1 through 6 contain the AFS steady-state analysis results. Table 1 identifies the participating long-term Transmission Service requests included in the AFS. This table lists deferred start and stop dates both with and without redispatch (based on Customer selection of redispatch if available) and the minimum annual allocated ATC without upgrades and season of first impact.

Table 2 identifies total E&C cost allocated to each Transmission Customer, letter of credit requirements, third party E&C cost assignments, potential base plan E&C funding (lower of allocated E&C or Attachment J Section III B criteria), total revenue requirements for assigned upgrades without consideration of potential base plan funding, point-to-point base rate charge, total revenue requirements for assigned upgrades with consideration of potential base plan funding, and final total cost allocation to the Transmission Customer. In addition, Table 2 identifies SWPA upgrade costs which require prepayment in addition to other allocated costs.

Table 3 provides additional details for each request including all assigned facility upgrades required, allocated E&C costs, allocated revenue requirements for upgrades, upgrades not assigned to the Customer but required for service to be confirmed, credits to be paid for previously assigned AFS or Generation Interconnection Network Upgrades, and any required third party upgrades.

Table 4 lists all upgrade requirements with associated solutions needed to provide Transmission Service for the AFS, minimum ATC per upgrade with season of impact, earliest date upgrade is required (DUN), estimated date the upgrade will be completed, in service (EOC), and estimated E&C cost.

Table 5 lists identified third-party constrained facilities.

Table 6 identifies potential redispatch pairs available to relieve the aggregate impacts on identified constraints to prevent deferral of start of service.

Table 7 (if applicable) identifies deferred expansion plan projects that were replaced with requested upgrades at earlier dates.

The potential base plan funding allowable is contingent on meeting each of the conditions for classifying upgrades associated with designated resources as Base Plan Upgrades as defined in Section III.B of Attachment J. If the additional capacity of the new or changed Designated Resource exceeds the 125% resource to load forecast for the year of start of service, the requested resource is not eligible for base plan funding of required Network Upgrades and the full cost of the upgrades is assignable to the Customer.

If the request is for wind generation, the total requested capacity of wind generation plus existing wind generation capacity shall not exceed 20% of the customer's projected system peak responsibility in the first year the Designated Resource is planned to be used by the customer. If the five-year term and 125% resource to load criteria are met, (as well as the 20% wind resource to load criteria for wind generation requests) the requested capacity is multiplied by \$180,000 to determine the potential base plan funding allowable. The maximum potential base plan funding allowable may be less than the potential base plan funding allowable, due to the E&C cost allocated to the customer being lower than the potential amount allowable to the Customer. The Customer is responsible for any assigned upgrade costs in excess of potential base plan E&C funding allowable. Network Upgrades required for wind generation requests located in a zone other than the Customer POD shall be allocated as 67% base plan region-wide charge and 33% directly assigned to the Customer.

Regarding application of base plan funding for PTP requests, if PTP base rate exceeds upgrade revenue requirements without taking into effect the reduction of revenue requirements by potential base plan funding, then the base rate revenue pays back the Transmission Owner for upgrades and no base plan funding is applicable as the access charge must be paid as it is the higher of "OR" pricing.

However, if initially the upgrade revenue requirements exceed the PTP base rate, then potential base plan funding would be applicable. The test of the higher of "OR" pricing would then be made against the remaining assignable revenue requirements versus PTP base rate. Examples are as follows:

Example A:

E&C allocated for upgrades is \$74 million with revenue requirements of \$140 million and PTP base rate of \$101 million. Potential base plan funding is \$47 million, with the difference of \$27 million E&C assignable to the Customer. If the revenue requirements for the assignable portion is \$54 million and the PTP base rate is \$101 million, the Customer will pay the higher amount (so-called "or pricing") of \$101 million base rate of which \$54 million revenue requirements will be paid back to the Transmission Owners for the upgrades, and the remaining revenue requirements of \$86 million (\$140 million less \$54 million) will be paid by base plan funding.

Example B:

E&C allocated for upgrades is \$74 million with revenue requirements of \$140 million and PTP base rate of \$101 million. Potential base plan funding is \$10 million with the difference of \$64 million E&C assignable to the Customer. If the revenue requirements for this assignable portion is \$128 million and the PTP base rate is \$101 million, the Customer will pay the higher amount of \$128 million revenue requirements to be paid back to the Transmission Owners, and the remaining revenue requirements of \$12 million (\$140 million less \$128 million) will be paid by base plan funding.

Example C:

E&C allocated for upgrades is \$25 million with revenue requirements of \$50 million and PTP base rate of \$101 million. Potential base plan funding is \$10 million. Base plan funding is not applicable as the higher amount of PTP base rate of \$101 million must be paid and the \$50 million revenue requirements will be paid from this.

The 125% resource to load determination is performed on a per request basis and is not based on a total of Designated Resource requests per Customer. A footnote will provide the maximum resource designation allowable for base plan funding consideration per Customer basis per year.

Base plan funding verification requires that each Transmission Customer with potential for base plan funding provide SPP attestation statements verifying that the firm capacity of the requested Designated Resource is committed for a minimum five year duration.

Study Definitions

- The date upgrade needed date (DUN) is the earliest date the upgrade is required to alleviate a constraint considering all requests.
- End of construction (EOC) is the estimated date the upgrade will be completed and in service.
- Total engineering and construction cost (E&C) is the upgrade solution cost as determined by the Transmission Owner.
- The Transmission Customer's allocation of the E&C cost is based on the request (1) having an impact of at least 3% on the limiting element, and (2) having a positive impact on the upgraded facility.
- Minimum ATC is the portion of the requested capacity that can be accommodated without upgrading facilities.
- Annual ATC allocated to the Transmission Customer is determined by the least amount of allocated seasonal ATC within each year of a reservation period.

Conclusion

The results of the AFS show that limiting constraints exist in many areas of the regional Transmission System. Due to these constraints, Transmission Service cannot be granted unless noted in Table 3.

The Transmission Provider will tender a Letter of Intent on March 30, 2012. This will open a 15-day window for Customer response. To remain in the Aggregate Transmission Service Study (ATSS), the Transmission Provider must receive from the Transmission Customer by April 14, 2012, an executed Letter of Intent. The Letter of Intent will list options the Customer must choose to clarify their commitment to remain in the ATSS. The only action required on OASIS is to WITHDRAW the request or leave the request in STUDY mode.

The Transmission Provider must receive an unconditional and irrevocable letter of credit in the amount of the total allocated E&C costs assigned to the Customer. This letter of credit is not required for those facilities that are fully base plan funded. The amount of the letter of credit will be adjusted down on an annual basis to reflect cost recovery based on revenue allocation. The Transmission Provider will issue notifications to construct Network Upgrades to the constructing Transmission Owner after filing of necessary service agreements at FERC.

Appendix A

PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

BASE CASE SETTINGS:

- Solutions: Fixed slope decoupled Newton-Raphson solution (FDNS)
- Tap adjustment: Stepping
- Area Interchange Control: Tie lines and loads
- Var limits: Apply immediately
- Solution Options:
 - Phase shift adjustment
 - Flat start
 - Lock DC taps
 - Lock switched shunts

ACCC CASE SETTINGS:

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- System intact rating: Rate A
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3mw
- Excl cases w/ no overloads from report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. Case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads (Disabled for generator outages)
- Var limits: Apply immediately
- Solution options:
 - Phase shift adjustment
 - Flat start
 - Lock DC taps
 - Lock switched shunts

Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study

Customer	Study Number	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date without interim redispatch	Deferred Stop Date without interim redispatch	Start Date with interim redispatch	Stop Date with interim redispatch	Minimum Allocated ATC (MW) within reservation period	Season of Minimum Allocated ATC within reservation period
AECC	2012-AG1-038	76585985	WR	CSWS	51	10/1/2012	10/1/2017	6/1/2018	6/1/2023	6/1/2018	6/1/2023	0	13SP
AECC	2012-AG1-039	76586000	OKGE	CSWS	48	11/1/2012	11/1/2017	6/1/2018	6/1/2023	6/1/2018	6/1/2023	0	13SP
AECC	2012-AG1-040	76586012	WR	OKGE	51	7/1/2015	7/1/2020	6/1/2019	6/1/2024	6/1/2018	6/1/2023	0	22SP
AECC	2012-AG1-041	76586023	OKGE	OKGE	48	7/1/2015	7/1/2020	6/1/2018	6/1/2023	6/1/2018	6/1/2023	0	22SP
AEPM	2012-AG1-033	76584399	CSWS	CSWS	250	1/1/2016	1/1/2021	6/1/2018	6/1/2023	6/1/2016	6/1/2021	0	22SP
AEPM	2012-AG1-034	76584402	CSWS	CSWS	250	1/1/2016	1/1/2021	6/1/2018	6/1/2023	6/1/2016	6/1/2021	0	22SP
AEPM	2012-AG1-036	76584451	WR	CSWS	78	10/1/2012	1/1/2032	6/1/2019	9/1/2038	6/1/2018	9/1/2037	0	13SP
AEPM	2012-AG1-037	76584464	SPS	CSWS	80	10/1/2012	1/1/2032	6/1/2019	9/1/2038	6/1/2019	9/1/2038	0	13SP
AEPM	2012-AG1-042	76586559	OKGE	CSWS	101	10/1/2012	12/31/2032	6/1/2018	8/1/2038	6/1/2018	8/1/2038	0	13SP
AEPM	2012-AG1-044	76586582	OKGE	CSWS	53	10/1/2012	12/31/2032	6/1/2018	8/1/2038	6/1/2018	8/1/2038	0	13SP
AEPM	2012-AG1-046	76586592	OKGE	CSWS	48	10/1/2012	12/31/2032	6/1/2018	8/1/2038	6/1/2018	8/1/2038	0	13SP
CHAN	2012-AG1-028	76583997	KACY	WR	3	1/1/2014	1/1/2019	6/1/2016	6/1/2021	6/1/2016	6/1/2021	0	17SP
CHAN	2012-AG1-029	76583999	KCPL	WR	45	1/1/2014	1/1/2019	6/1/2018	6/1/2023	6/1/2016	6/1/2021	0	17SP
CHAN	2012-AG1-031	76584004	SPA	WR	1	1/1/2014	1/1/2019	6/1/2018	6/1/2023	6/1/2018	6/1/2023	0	17SP
CHAN	2012-AG1-032	76584010	WR	WR	121	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	17SP
CHAN	2012-AG1-050	76586685	NPPD	WR	2	1/1/2014	1/1/2019	6/1/2019	6/1/2024	6/1/2019	6/1/2024	0	17SP
CHAN	2012-AG1-052	76583977	WR	WR	115	1/1/2014	1/1/2019	1/1/2014	1/1/2019	1/1/2014	1/1/2019	0	17SP
CHAN	2012-AG1-053	76583984	GRDA	WR	2	1/1/2014	1/1/2019	6/1/2018	6/1/2023	6/1/2018	6/1/2023	0	17SP
CRGL	2012-AG1-001	76300099	CSWS	ERCOTN	207	1/1/2014	1/1/2024	6/1/2016	6/1/2026	6/1/2016	6/1/2026	0	17SP
CRGL	2012-AG1-002	76348872	ERCOTN	ERCOTN	207	2/1/2013	2/1/2018	2/1/2013	2/1/2018	2/1/2013	2/1/2018	0	13SP
CRGL	2012-AG1-025	76583812	WPEK	EES	200	1/1/2014	1/1/2024	6/1/2019	6/1/2029	6/1/2019	6/1/2029	0	17SP
CRGL	2012-AG1-026	76583814	WPEK	EES	200	1/1/2014	1/1/2024	6/1/2019	6/1/2029	6/1/2019	6/1/2029	0	17SP
CRGL	2012-AG1-027	76583815	WPEK	EES	100	1/1/2014	1/1/2024	6/1/2019	6/1/2029	6/1/2019	6/1/2029	0	17SP
ETEC	2012-AG1-043	76586568	CSWS	CSWS	8	1/1/2013	1/1/2015	6/1/2016	6/1/2018	6/1/2016	6/1/2018	0	13SP
KMEA	2012-AG1-007	76553455	NPPD	WR	3	2/1/2013	4/1/2025	6/1/2019	8/1/2031	6/1/2019	8/1/2031	0	13SP
KMEA	2012-AG1-012	76580367	NPPD	WR	1	5/1/2013	4/30/2025	6/1/2019	5/1/2031	6/1/2019	5/1/2031	0	13SP
KMEA	2012-AG1-013	76580375	GRDA	WR	3	5/1/2013	5/1/2026	6/1/2018	6/1/2031	6/1/2018	6/1/2031	0	13SP
KMEA	2012-AG1-014	76580381	KACY	WR	4	10/1/2013	6/1/2022	6/1/2016	2/1/2025	6/1/2016	2/1/2025	0	17SP
KMEA	2012-AG1-015	76580392	SPA	WR	1	5/1/2013	1/1/2019	6/1/2018	2/1/2024	6/1/2018	2/1/2024	0	13SP
KMEA	2012-AG1-016	76580395	WR	WR	5	5/1/2013	1/1/2019	6/1/2018	2/1/2024	6/1/2018	2/1/2024	0	13SP
KMEA	2012-AG1-017	76580515	SPA	WR	1	1/1/2014	1/1/2019	6/1/2018	6/1/2023	6/1/2018	6/1/2023	0	17SP
KMEA	2012-AG1-018	76580552	NPPD	WR	1	1/1/2014	5/1/2025	6/1/2019	10/1/2030	6/1/2019	10/1/2030	0	17SP
KMEA	2012-AG1-019	76582326	WR	WR	41	5/1/2013	5/1/2026	6/1/2018	6/1/2031	6/1/2018	6/1/2031	0	13SP
KMEA	2012-AG1-022	76583607	WR	WR	21	1/1/2014	5/1/2026	1/1/2014	5/1/2026	1/1/2014	5/1/2026	0	17SP
KMEA	2012-AG1-023	76583617	GRDA	WR	5	1/1/2014	5/1/2026	6/1/2018	10/1/2030	6/1/2018	10/1/2030	0	17SP
KMEA	2012-AG1-024	76583629	WR	WR	4	1/1/2014	1/1/2019	6/1/2018	6/1/2023	6/1/2018	6/1/2023	0	17SP
KMEA	2012-AG1-048	76586675	KCPL	WR	15	6/1/2013	6/1/2023	6/1/2019	6/1/2029	6/1/2019	6/1/2029	0	13SP
KMEA	2012-AG1-049	76586679	WR	WR	15	6/1/2013	6/1/2013	6/1/2013	6/1/2013	6/1/2013	6/1/2013	0	13SP
KMEA	2012-AG1-051	76586961	NPPD	WR	1	6/1/2013	5/1/2013	6/1/2013	5/1/2013	6/1/2013	5/1/2013	0	13SP
NTEC	2012-AG1-045	76586584	CSWS	CSWS	8	1/1/2013	1/1/2015	6/1/2016	6/1/2018	6/1/2016	6/1/2018	0	13SP
OGE	2012-AG1-008	76571379	OKGE	OKGE	60	12/19/2012	12/19/2032	6/1/2019	6/1/2039	6/1/2015	6/1/2035	0	13SP
OPPM	2012-AG1-011	76575755	OPPD	OPPD	53	12/31/2012	12/31/2037	6/1/2016	6/1/2041	12/31/2012	12/31/2037	0	13SP
PSCM	2012-AG1-021	76582673	SPS	LAM345	208	3/1/2013	3/1/2018	6/1/2018	6/1/2023	6/1/2018	6/1/2023	0	13SP

Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study

Customer	Study Number	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date without interim redispatch	Deferred Stop Date without interim redispatch	Start Date with interim redispatch	Stop Date with interim redispatch	Minimum Allocated ATC (MW) within reservation period	Season of Minimum Allocated ATC within reservation period
TEXL	2012-AG1-047	76586594	CSWS	CSWS	20	1/1/2013	1/1/2015	6/1/2016	6/1/2018	6/1/2016	6/1/2018	0	13SP
WFEC	2012-AG1-004	76548687	CSWS	WFEC	160	6/1/2014	12/31/2035	6/1/2018	12/1/2039	6/1/2016	12/1/2037	0	17SP
WFEC	2012-AG1-005	76548692	CSWS	WFEC	90	6/1/2017	12/31/2035	6/1/2018	12/1/2036	6/1/2017	12/1/2035	0	22SP
WFEC	2012-AG1-006	76548702	CSWS	WFEC	30	6/1/2019	12/31/2035	6/1/2019	12/1/2035	6/1/2019	12/1/2035	0	22SP
Note 1: Start and Stop Dates with interim redispatch are determined based on customers choosing option to pursue redispatch to start service at Requested Start and Stop Dates or earliest date possible.													
Note 2: Start dates with and without redispatch are based on the assumed completion dates of previous Aggregate Transmission Service Studies currently being conducted. Actual start dates may differ from the potential start dates upon completion of the previous studies.													
Note 3: Request is unable to be deferred due to fixed stop dates.													
Note 4: Transmission customer did not select "remain in the study using interim redispatch" option.													

Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

Customer	Study Number	Reservation	Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements	¹ Letter of Credit Amount Required	² Potential Base Plan Engineering and Construction Funding Allowable	Notes	⁴ Additional Engineering and Construction Cost for 3rd Party Upgrades	³ ⁵ Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITH Potential Base Plan Funding Allocation	Point-to-Point Base Rate Over Reservation Period	⁴ Total Cost of Reservation Assignable to Customer Contingent Upon Base Plan Funding
AECC	2012-AG1-038	76585985	\$ 4,391,414	\$ -	\$ 4,391,414		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
AECC	2012-AG1-039	76586000	\$ 4,180,404	\$ -	\$ 4,180,404		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
AECC	2012-AG1-040	76586012	\$ 3,362,710	\$ -	\$ 3,362,710		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
AECC	2012-AG1-041	76586023	\$ 3,651,374	\$ -	\$ 3,651,374		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
AEPM	2012-AG1-033	76584399	\$ 21,892,328	\$ -	\$ 21,892,328		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
AEPM	2012-AG1-034	76584402	\$ 22,228,902	\$ -	\$ 22,228,902		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
AEPM	2012-AG1-036	76584451	\$ 6,048,842	\$ 123,924	\$ 5,924,918		Indeterminate	\$ 575,955	\$ -	\$ 575,955
AEPM	2012-AG1-037	76584464	\$ 5,745,068	\$ -	\$ 5,745,068		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
AEPM	2012-AG1-042	76586559	\$ 7,768,702	\$ -	\$ 7,768,702		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
AEPM	2012-AG1-044	76586582	\$ 4,076,637	\$ -	\$ 4,076,637		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
AEPM	2012-AG1-046	76586592	\$ 3,692,062	\$ -	\$ 3,692,062		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-028	76583997	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-029	76583999	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-031	76584004	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-032	76584010	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-050	76586685	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-052	76583977	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
CHAN	2012-AG1-053	76583984	\$ 2,525	\$ 2,525	\$ -		Indeterminate	\$ 8,316	\$ -	\$ 8,316
CRGL	2012-AG1-001	76300099	\$ 3,963	\$ 3,963	\$ -	6	Indeterminate	\$ 14,401	\$ 39,308,058	\$ 39,308,060
CRGL	2012-AG1-002	76348872	\$ -	\$ -	\$ -	7	\$ -	\$ -	\$ 19,654,029	\$ 19,654,030
CRGL	2012-AG1-025	76583812	\$ 2,475,703	\$ 2,475,703	\$ -		Indeterminate	\$ 10,088,150	\$ 28,320,000	\$ 28,320,000
CRGL	2012-AG1-026	76583814	\$ 2,475,703	\$ 2,475,703	\$ -		Indeterminate	\$ 10,088,150	\$ 28,320,000	\$ 28,320,000
CRGL	2012-AG1-027	76583815	\$ 1,237,851	\$ 1,237,851	\$ -		Indeterminate	\$ 5,044,070	\$ 14,160,000	\$ 14,160,000
ETEC	2012-AG1-043	76586568	\$ -	\$ -	\$ -		\$ 3,504,887	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-007	76553455	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-012	76580367	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-013	76580375	\$ 18,508	\$ -	\$ 18,508		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-014	76580381	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-015	76580392	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-016	76580395	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-017	76580515	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-018	76580552	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-019	76582326	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-022	76583607	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-023	76583617	\$ 7,118	\$ -	\$ 7,118		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-024	76583629	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-048	76586675	\$ -	\$ -	\$ -		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-049	76586679	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
KMEA	2012-AG1-051	76586961	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
NTEC	2012-AG1-045	76586584	\$ -	\$ -	\$ -		\$ 7,009,775	\$ -	\$ -	Schedule 9 & 11 Charges
OGE	2012-AG1-008	76571379	\$ 2,160,281	\$ -	\$ 2,160,281		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
OPPM	2012-AG1-011	76575755	\$ -	\$ -	\$ -		\$ -	\$ -	\$ -	Schedule 9 & 11 Charges
PSCM	2012-AG1-021	76582673	\$ 424,681	\$ 424,681	\$ -		Indeterminate	\$ 852,690	\$ 23,599,680	\$ 23,599,680
TEXL	2012-AG1-047	76586594	\$ -	\$ -	\$ -		\$ 8,762,218	\$ -	\$ -	Schedule 9 & 11 Charges

Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

Customer	Study Number	Reservation	Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements	¹ Letter of Credit Amount Required	² Potential Base Plan Engineering and Construction Funding Allowable	Notes	⁴ Additional Engineering and Construction Cost for 3rd Party Upgrades	³ ⁵ Total Revenue Requirements for Assigned Upgrades Over Term of Reservation WITH Potential Base Plan Funding Allocation	Point-to-Point Base Rate Over Reservation Period	⁴ Total Cost of Reservation Assignable to Customer Contingent Upon Base Plan Funding
WFEC	2012-AG1-004	76548687	\$ 1,279,533	\$ -	\$ 1,279,533		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
WFEC	2012-AG1-005	76548692	\$ 719,737	\$ -	\$ 719,737		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
WFEC	2012-AG1-006	76548702	\$ 244,812	\$ -	\$ 244,812		Indeterminate	\$ -	\$ -	Schedule 9 & 11 Charges
Grand Total			\$ 98,088,858		\$ 91,344,508			\$ 26,671,732		
Note 1: Letter of Credit required for financial security for transmission owner for network upgrades is determined by allocated engineering and construction costs less engineering and construction costs for upgrades when network customer is the transmission owner less the E & C allocation of expedited projects. Letter of Credit is required for upgrades assigned to PTP requests. The amount of the letter of credit will be adjusted down on an annual basis to reflect cost recovery based on revenue allocation. This letter of credit is not required for those facilities that are fully base plan funded. The Letter Of Credit Amount listed is based on meeting OATT Attachment J requirements for base plan funding.										
Note 2: If potential base plan funding is applicable, this value is the lesser of the Engineering and Construction costs of assignable upgrades or the value of base plan funding calculated pursuant to Attachment J, Section III B criteria. Allocation of base plan funding is contingent upon verification of customer agreements meeting Attachment J, Section II B criteria. Not applicable if Point-to-Point base rate exceeds revenue requirements.										
Note 3: Revenue Requirements (RR) are based upon deferred end dates if applicable. Deferred dates are based upon customer's choice to pursue redispatch. Achievable Base Plan Avoided RR in the case of a Base Plan upgrade being displaced or deferred by an earlier in service date for a Requested Upgrade shall be determined per Attachment J, Section VII.C methodology. Assumption of a 40 year service life is utilized for Base Plan funded projects. A present worth analysis of RR on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan RR due to the displacement or deferral of the Base Plan upgrade by the Requested Upgrade. The incremental increase in present worth of a Requested Upgrade on a common year basis as a Base Plan upgrade is assigned to the transmission requests impacting the upgrade based on the displacement or deferral. If the displacement analysis results in lower RR due to the shorter amortization period of the requested upgrade when compared to a base plan amortization period, then no direct assignment of the upgrade cost is made due to the displacement to an earlier start date.										
Note 4: For Point-to-Point requests, total cost is based on the higher of the base rate or assigned upgrade revenue requirements. For Network requests, the total cost is based on the assigned upgrade revenue requirement. Allocation of base plan funding will be determined after verification of designated resource meeting Attachment J, Section II B Criteria. Additionally E & C of 3rd Party upgrades is assignable to Customer. This includes prepayments required for any SWPA upgrades. Revenue requirements for 3rd Party facilities are not calculated. Total cost to customer is based on assumption of Revenue Requirements with confirmation of base plan funding. Customer is responsible for negotiating redispatch costs if applicable. Customer is also responsible to pay credits for previously assigned upgrades that are impacted by their request. Credits can be paid from base plan funding if applicable.										
Note 5: RR with base plan funding may increase or decrease even if no base plan funding is applicable to a particular request if another request that shares the upgrade is now full base plan funded resulting in a different amortization period for the upgrade and thus different RR.										
Note 6: Mutually exclusive with 76348872. System impacts were identified by only modeling mutually exclusive request 76300099.										
Note 7: Mutually exclusive with 76300099. System impacts were identified by only modeling mutually exclusive request 76300099.										

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer AECC
Study Number 2012-AG1-038

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AECC	76585985	WR	CSWS	51	10/1/2012	10/1/2017	6/1/2018	6/1/2023	\$ 4,391,414	\$ -	\$ 4,391,414	\$ 13,447,692
									\$ 4,391,414	\$ -	\$ 4,391,414	\$ 13,447,692

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76585985	BETHEL - BROKEN BOW 138KV CKT 1	10/1/2014	6/1/2016			\$ 240,213	\$ -	\$ 240,213	\$ 9,190,000	\$ 935,989
	BETHEL - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 586,286	\$ -	\$ 586,286	\$ 22,430,000	\$ 2,284,461
	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1 Accelerate	6/1/2014	6/1/2016		No	\$ 992,448	\$ -	\$ 992,448	\$ 1,927,873	\$ 2,475,951
	CLAYTON - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 302,422	\$ -	\$ 302,422	\$ 11,570,000	\$ 1,178,286
	CLAYTON - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 38,162	\$ -	\$ 38,162	\$ 1,460,000	\$ 148,685
	ENOWILT - LONE OAK 138KV CKT 1	10/1/2014	6/1/2016			\$ 16,337	\$ -	\$ 16,337	\$ 625,000	\$ 55,974
	ENOWILT - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 360,711	\$ -	\$ 360,711	\$ 13,800,000	\$ 1,405,269
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017		No	\$ 218,188	\$ -	\$ 218,188	\$ 14,500,000	\$ 667,615
	HIGHWAY 59 - VBI 161KV CKT 1	6/1/2013	6/1/2018		No	\$ 1,686	\$ -	\$ 1,686	\$ 80,000	\$ 4,058
	KINZE - MCELROY 138KV CKT 1	6/1/2018	6/1/2018			\$ 211,384	\$ -	\$ 211,384	\$ 1,800,000	\$ 575,509
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016			\$ 34,200	\$ -	\$ 34,200	\$ 330,000	\$ 122,067
	Multi - Bonanza - North Huntington 69KV Accelerate	6/1/2014	6/1/2016		No	\$ 1,374,795	\$ -	\$ 1,374,795	\$ 3,510,229	\$ 3,549,541
	NORTHWEST TEXARKANA - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2018	6/1/2018			\$ 14,582	\$ -	\$ 14,582	\$ 605,000	\$ 44,285
						Total		\$ 4,391,414	\$ 81,828,102	\$ 13,447,692

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76585985	IATAN - NASHUA 345KV CKT 1	6/1/2013	6/1/2015		No
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015		
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014		
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015		
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015		
	NORTHWEST TEXARKANA - VALIANT 345KV CKT 1	10/1/2012	10/1/2014		No
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014		
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014		
	XFR - Medicine Lodge 345/138 KV	10/1/2012	1/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76585985	5 TRIBES - HANCOCK 161KV CKT 1 #1	6/1/2013	6/1/2014		No

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76585985	5 TRIBES - HANCOCK 161KV CKT 1 #2	6/1/2013	6/1/2015		No
	5 TRIBES - PECAN CREEK 161KV CKT 1 Accelerate	6/1/2013	6/1/2015		No
BENTON - WICHITA 345KV CKT 1		6/1/2018	6/1/2018	6/1/2015	
CHISHOLM - MAIZE 138KV CKT 1 #1		6/1/2014	6/1/2016		No
CHISHOLM - MAIZE 138KV CKT 1 #2		6/1/2014	6/1/2016		No
CIMARRON - DRAPER LAKE 345KV CKT 1		6/1/2014	6/1/2015		No
Cimarron - Mathewson 345 KV Ckt 1		6/1/2014	6/1/2017		
Circle - Reno 345KV Dbl CKT		10/1/2012	6/1/2019		
ELM SPRINGS REC - TONTITOWN 161KV CKT 1		6/1/2018	6/1/2018		
EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1		6/1/2014	6/1/2016		No
EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2		6/1/2014	6/1/2016		No
FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW		6/1/2014	6/1/2015		Yes
FT SMITH - MUSKOGEE 345KV CKT 1		6/1/2014	6/1/2015		Yes
GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate		6/1/2014	6/1/2015		Yes
HOYT - JEFFREY ENERGY CENTER 345KV CKT 1		6/1/2013	6/1/2017		No
Iatan - Jeffrey Energy Center 345 KV KACP		6/1/2013	6/1/2018		No
Iatan - Jeffrey Energy Center 345 KV WERE		6/1/2013	6/1/2018		No
Iatan - Swissvale 345KV KACP		6/1/2013	6/1/2018		No
Iatan - Swissvale 345KV WERE		6/1/2014	6/1/2018		No
Lacygne - Morgan 345KV KACP		10/1/2012	6/1/2018		No
Lacygne - Wolf Creek 345KV CKT 2 KACP		10/1/2012	6/1/2018		No
Lacygne - Wolf Creek 345KV CKT 2 WERE		10/1/2012	6/1/2018		No
Mathewson - Tatonga 345 KV Ckt 1		6/1/2014	6/1/2017		
Mathewson 345 KV		6/1/2014	6/1/2017		
Mullergruen - Circle 345kV Dbl CKT MKEC		10/1/2012	6/1/2019		
Mullergruen - Circle 345kV Dbl CKT WERE		10/1/2012	6/1/2019		
Muskogee - VBI 345 kV with 345/161 kV bus tie at VBI		6/1/2013	6/1/2018		No
NEOSHO - SUB 452 - RIVERTON 161KV CKT 1 EMDE		6/1/2014	6/1/2016		No
NEOSHO - SUB 452 - RIVERTON 161KV CKT 1 WERE		6/1/2014	6/1/2016		No
Spearville - Mullergruen 345KV Dbl CKT		10/1/2012	6/1/2019		
SUB 124 - AURORA H.T. 69KV		6/1/2018	6/1/2018		
Swissvale - Wolf Creek 345KV		10/1/2012	6/1/2018		No
Turk - McNeil 345 KV AEPW		6/1/2013	6/1/2018		No
VBI - Arkansas Nuclear One 345kV OKGE		6/1/2013	6/1/2018		No
Viola - Rose Hill 345kv CKT 1		6/1/2014	6/1/2018		No
Waldron 69 KV Capacitor		6/1/2018	6/1/2018		
Wolf Creek - Wichita 345KV		10/1/2012	6/1/2018		No

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76585985	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
HUGO POWER PLANT - VALLIANT 345 KV AEPW		7/1/2012	7/1/2012		
HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC		7/1/2012	7/1/2012		
Mathewson 345 KV		6/1/2012	6/1/2019		
MCNAB REC - TURK 115KV CKT 1		7/1/2012	7/1/2012		
NORTHWEST - TATONGA 345KV CKT 1		1/1/2010	1/1/2010		
OKAY - TURK 138KV CKT 1		7/1/2012	7/1/2012		
SUGAR HILL - TURK 138KV CKT 1		7/1/2012	7/1/2012		
TATONGA - WOODWARD 345KV CKT 1		1/1/2010	1/1/2010		
Viola - Rose Hill 345KV CKT 1		6/1/2014	6/1/2018		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76585985	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 229,217	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 593,777	\$ 18,000,000	
	TOVERTON 345.00 () 345/161/13.8KV TRANSFORMER CKT 1	10/1/2012	6/1/2016	No	\$ 891,997	\$ 16,100,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014			0.44%	100.00%
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018	No	\$ 76,348	\$ 12,000,000	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 1,352,779	\$ 20,000,000	
	Brookline - Compton Ridge 345 kV	6/1/2013	6/1/2018	No		6.26%	100.00%
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No		2.09%	100.00%
	GORE - MUSKOGEE TAP 161KV CKT 1	6/1/2013	6/1/2016	No	\$ 601,331	\$ 8,000,000	
	GORE - SALLISAW 161KV CKT 1	6/1/2013	6/1/2016	No	\$ 171,714	\$ 9,000,000	
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018	No		7.05%	100.00%
	LIBERTY TAP - SALLISAW 161KV CKT 1 SWPA	6/1/2013	6/1/2016	No	\$ 300,545	\$ 6,500,000	
	SHEELDSHEHSE	10/1/2012	10/1/2012			1.25%	100.00%
	VBI - Arkansas Nuclear One 345KV EES	6/1/2013	6/1/2018	No		0.63%	100.00%
				Total	\$ 4,217,708	\$ 97,600,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345KV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer AECC
Study Number 2012-AG1-039

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AECC	76586000	OKGE	CWSW	48	11/1/2012	11/1/2017	6/1/2018	6/1/2023	\$ 4,180,404	\$ -	\$ 4,180,404	\$ 12,931,066
									\$ 4,180,404	\$ -	\$ 4,180,404	\$ 12,931,066

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
76586000	BETHEL - BROKEN BOW 138KV CKT 1	10/1/2014	6/1/2016			\$ 241,529	\$ -	\$ 241,529	\$ 9,190,000	\$ 941,117	
	BETHEL - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 589,498	\$ -	\$ 589,498	\$ 22,430,000	\$ 2,296,976	
	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1 Accelerate	6/1/2014	6/1/2016		No	\$ 935,425	\$ -	\$ 935,425	\$ 1,927,873	\$ 2,333,691	
	CLAYTON - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 304,079	\$ -	\$ 304,079	\$ 11,570,000	\$ 1,184,742	
	CLAYTON - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 38,371	\$ -	\$ 38,371	\$ 1,460,000	\$ 149,500	
	ENOWILT - LONE OAK 138KV CKT 1	10/1/2014	6/1/2016			\$ 16,426	\$ -	\$ 16,426	\$ 625,000	\$ 56,279	
	ENOWILT - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 362,687	\$ -	\$ 362,687	\$ 13,800,000	\$ 1,412,968	
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017		No	\$ 290,328	\$ -	\$ 290,328	\$ 14,500,000	\$ 888,351	
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 22,842	\$ -	\$ 22,842	\$ 2,500,000	\$ 65,209	
	HIGHWAY 59 - VE 161KV CKT 1	6/1/2013	6/1/2018		No	\$ 1,349	\$ -	\$ 1,349	\$ 80,000	\$ 3,247	
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016			\$ 35,141	\$ -	\$ 35,141	\$ 330,000	\$ 125,426	
	Multi - Bonanza - North Huntington 69KV Accelerate	6/1/2014	6/1/2016		No	\$ 1,327,763	\$ -	\$ 1,327,763	\$ 3,510,229	\$ 3,428,111	
	NORTHWEST TEXARKANA - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2018	6/1/2018			\$ 14,966	\$ -	\$ 14,966	\$ 605,000	\$ 45,451	
						Total		\$ 4,180,404	\$ 4,180,404	\$ 82,528,102	\$ 12,931,066

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586000	IATAN - NASHUA 345KV CKT 1	6/1/2013	6/1/2015		No
	NORTHWEST TEXARKANA - VALIANT 345KV CKT 1	10/1/2012	10/1/2014		No

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586000	5 TRIBES - HANCOCK 161KV CKT 1 #1	6/1/2013	6/1/2014		No

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586000	5 TRIBES - HANCOCK 161KV CKT 1 #2	6/1/2013	6/1/2015		No
	5 TRIBES - PECAN CREEK 161KV CKT 1 Accelerate	6/1/2013	6/1/2015		No
	BEAVER - EUREKA SPRINGS 161KV CKT 1 AEPW Accelerate	6/1/2013	6/1/2015		No
	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015		No
	ELM SPRINGS REC - TONTITOWN 161KV CKT 1	6/1/2018	6/1/2018		
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015		Yes
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015		Yes
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015		Yes
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		No
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		No
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		No
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		No
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		No
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		No
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		No
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		No
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018		No
	NEOSHO - SUB 452 - RIVERTON 161KV CKT 1 EMDE	6/1/2014	6/1/2016		No
	NEOSHO - SUB 452 - RIVERTON 161KV CKT 1 WERE	6/1/2014	6/1/2016		No
	SUB 124 - AURORA H.T. 69KV	6/1/2018			
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		No
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		No
	VBI - Arkansas Nuclear One 345KV OKGE	6/1/2013	6/1/2018		No
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018		No
	Waldron 69 KV Capacitor	6/1/2018	6/1/2018		
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		No

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586000	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	MCNAB REC - TURK 115KV CKT 1	7/1/2012	7/1/2012		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	OKAY - TURK 138KV CKT 1	7/1/2012	7/1/2012		
	SUGAR HILL - TURK 138KV CKT 1	7/1/2012	7/1/2012		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345kV CKT 1	6/1/2014	6/1/2018		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586000	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 210,775	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 497,009	\$ 18,000,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014		0.97%	100.00%	
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018	No	\$ 130,869	\$ 12,000,000	
	BEAVER - EUREKA SPRINGS 161KV CKT 1 SWPA	6/1/2013	6/1/2015	No	\$ -	\$ -	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 840,079	\$ 20,000,000	
	Brookline - Compton Ridge 345 KV	6/1/2013	6/1/2018	No	4.52%	100.00%	
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No	1.02%	100.00%	
	GORE - MUSKOGEE TAP 161KV CKT 1	6/1/2013	6/1/2016	No	\$ 663,059	\$ 8,000,000	
	GORE - SALLISAW 161KV CKT 1	6/1/2013	6/1/2016		\$ 108,632	\$ 9,000,000	
	Lacygne - Morgan 345KV AEI	10/1/2012	6/1/2018	No	3.74%	100.00%	
	LIBERTY TAP - SALLISAW 161KV CKT 1 SWPA	6/1/2013	6/1/2016	No	\$ 313,656	\$ 6,500,000	
	SHEELDSHEHSE	10/1/2012	10/1/2012		0.93%	100.00%	
	VBI - Arkansas Nuclear One 345kV EES	6/1/2013	6/1/2018	No	1.09%	100.00%	
				Total	\$ 2,764,079	\$ 81,500,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGK, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer AECC
Study Number 2012-AG1-040

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AECC	76586012	WR	OKGE	51	7/1/2015	7/1/2020	6/1/2019	6/1/2024	\$ 3,362,710	\$ -	\$ 3,362,710	\$ 7,829,420
									\$ 3,362,710	\$ -	\$ 3,362,710	\$ 7,829,420

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
76586012	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017		Yes	\$ 146,916	\$ -	\$ 146,916	\$ 14,500,000	\$ 449,536	
	HIGHWAY 59 - VBI 161KV CKT 1	6/1/2013	6/1/2018		No	\$ 1,141	\$ -	\$ 1,141	\$ 80,000	\$ 2,746	
	KINZE - MCELROV 138KV CKT 1	6/1/2018	6/1/2018			\$ 53,208	\$ -	\$ 53,208	\$ 1,800,000	\$ 144,863	
	Multi - Bonanza - North Huntington 69kV Accelerate	6/1/2014	6/1/2016			\$ 417,753	\$ -	\$ 417,753	\$ 3,510,229	\$ 1,078,584	
	MUSKOGEE - ROSS LAKE 161KV CKT 1	6/1/2018	6/1/2018			\$ 157,744	\$ -	\$ 157,744	\$ 350,000	\$ 348,466	
	PECAN CREEK (PECANCK1) 345/161/13.8KV TRANSFORMER CKT 1	6/1/2018	6/1/2018			\$ 2,585,948	\$ -	\$ 2,585,948	\$ 5,500,000	\$ 5,805,224	
						Total	\$ 3,362,710	\$ -	\$ 3,362,710	\$ 25,740,229	\$ 7,829,420

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586012	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015		
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014		
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015		
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015		
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014		
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014		
	XFR - Medicine Lodge 345/138 KV	10/1/2012	1/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586012	5 TRIBES - HANCOCK 161KV CKT 1 #1	6/1/2013	6/1/2014		
	AGENCY - PECAN CREEK 161KV CKT 1	6/1/2018	6/1/2018		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586012	5 TRIBES - HANCOCK 161KV CKT 1 #2	6/1/2013	6/1/2015		
	5 TRIBES - PECAN CREEK 161KV CKT 1 Accelerate	6/1/2013	6/1/2015		
BENTON - WICHITA 345KV CKT 1		6/1/2018	6/1/2018	6/1/2015	
CHISHOLM - MAIZE 138KV CKT 1 #1		6/1/2014	6/1/2016		
CHISHOLM - MAIZE 138KV CKT 1 #2		6/1/2014	6/1/2016		
CIMARRON - DRAPER LAKE 345KV CKT 1		6/1/2015			
Cimarron - Mathewson 345 kV Ckt 1		6/1/2014	6/1/2017		
Circle - Reno 245kV Dbl Ckt		10/1/2012	6/1/2019		
EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1		6/1/2014	6/1/2016		
EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2		6/1/2014	6/1/2016		
FT SMITH - MUSKOGEE 345KV CKT 1		6/1/2014	6/1/2015		
GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate		6/1/2014	6/1/2015		
HOYT - JEFFREY ENERGY CENTER 345 KV KACP		6/1/2013	6/1/2017	No	
Iatan - Jeffrey Energy Center 345 KV KACP		6/1/2013	6/1/2018	No	
Iatan - Jeffrey Energy Center 345 KV WERE		6/1/2013	6/1/2018	No	
Iatan - Swissvale 345KV KACP		6/1/2013	6/1/2018	No	
Iatan - Swissvale 345KV WERE		6/1/2014	6/1/2018	No	
Lacygne - Morgan 345KV KACP		10/1/2012	6/1/2018	No	
Lacygne - Wolf Creek 345KV CKT 2 KACP		10/1/2012	6/1/2018	No	
Lacygne - Wolf Creek 345KV CKT 2 WERE		10/1/2012	6/1/2018	No	
Mathewson - Tatonga 345 KV Ckt 1		6/1/2014	6/1/2017		
Mathewson 345 KV		6/1/2014	6/1/2017		
Mullergruen - Circle 345kV Dbl CKT MKEC		10/1/2012	6/1/2019		
Mullergruen - Circle 345kV Dbl CKT WERE		10/1/2012	6/1/2019		
Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI		6/1/2013	6/1/2018	No	
Spearville - Mullergruen 345kV Dbl CKT		10/1/2012	6/1/2019		
SUB 124 - AURORA H.T. 69KV		6/1/2018	6/1/2018		
Swissvale - Wolf Creek 345KV		10/1/2012	6/1/2018	No	
Turk - McNeil 345 KV AEPW		6/1/2013	6/1/2018	No	
VBI - Arkansas Nuclear One 345kV OGKE		6/1/2013	6/1/2018	No	
Viola - Rose Hill 345kV CKT 1		6/1/2014	6/1/2018	No	
Waldron 69 KV Capacitor		6/1/2018	6/1/2018		
Wolf Creek - Wichita 345KV		10/1/2012	6/1/2018	No	

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586012	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
HUGO POWER PLANT - VALLIANT 345 KV AEPW		7/1/2012	7/1/2012		
HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC		7/1/2012	7/1/2012		
Mathewson - Tatonga 345 KV Ckt 1		6/1/2012	6/1/2019		
Mathewson 345 KV		6/1/2012	6/1/2019		
NORTHWEST - TATONGA 345KV CKT 1		1/1/2010	1/1/2010		
TATONGA - WOODWARD 345KV CKT 1		1/1/2010	1/1/2010		
Viola - Rose Hill 345kV CKT 1		6/1/2014	6/1/2018		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586012	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 45,067	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 117,266	\$ 18,000,000	
	TOVERTON 345.00 () 345/161/13.8KV TRANSFORMER CKT 1	10/1/2012	6/1/2016	No	\$ 206,733	\$ 16,100,000	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 258,628	\$ 20,000,000	
	Brookline - Compton Ridge 345 KV	6/1/2013	6/1/2018	No	1.18%	100.00%	
	Compton Ridge - Cox Creek 345 KV	6/1/2013	6/1/2018	No	0.30%	100.00%	
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No	1.34%	100.00%	
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018	No	1.49%	100.00%	
	GORE - MUSKOGEE TAP 161KV CKT 1	6/1/2013	6/1/2016	No	\$ 571,507	\$ 8,000,000	
	GORE - SALLISAW 161KV CKT 1	6/1/2013	6/1/2016	No	\$ 250,078	\$ 9,000,000	
	Lacygne - Morgan 345KV AEI	10/1/2012	6/1/2018	No	1.40%	100.00%	
	LIBERTY TAP - SALLISAW 161KV CKT 1 SWPA	6/1/2013	6/1/2016	No	\$ 307,144	\$ 6,500,000	
	McNeil 500/345KV	6/1/2013	6/1/2018	No	\$ 125,876	\$ 12,000,000	
				Total	\$ 1,882,299	\$ 97,600,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGKE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 KV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer AECC
Study Number 2012-AG1-041

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AECC	76586023	OKGE	OKGE	48	7/1/2015	7/1/2020	6/1/2018	6/1/2023	\$ 3,651,374	\$ -	\$ 3,651,374	\$ 8,447,288
									\$ 3,651,374	\$ -	\$ 3,651,374	\$ 8,447,288

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586023	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017		Yes	\$ 154,155	\$ -	\$ 154,155	\$ 14,500,000	\$ 471,686
	HIGHWAY 59 - VBI 161KV CKT 1	6/1/2013	6/1/2018		No	\$ 992	\$ -	\$ 992	\$ 80,000	\$ 2,388
	MULTI - Bonanza - North Huntington 69kV Accelerate	6/1/2014	6/1/2016			\$ 389,919	\$ -	\$ 389,919	\$ 3,510,229	\$ 1,006,720
	MUSKOGEE - ROSS LAKE 161KV CKT 1	6/1/2018	6/1/2018			\$ 192,256	\$ -	\$ 192,256	\$ 350,000	\$ 424,705
	PECAN CREEK (PECANCK1) 345/161/13.8KV TRANSFORMER CKT 1	6/1/2018	6/1/2018			\$ 2,914,052	\$ -	\$ 2,914,052	\$ 5,500,000	\$ 6,541,789
					Total	\$ 3,651,374	\$ -	\$ 3,651,374	\$ 23,940,229	\$ 8,447,288

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586023	5 TRIBES - HANCOCK 161KV CKT 1 #1	6/1/2013	6/1/2014		
	AGENCY - PECAN CREEK 161KV CKT 1	6/1/2018	6/1/2018		
	HAMMETT TAP - HORSESHOE LAKE 138KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586023	5 TRIBES - HANCOCK 161KV CKT 1 #2	6/1/2013	6/1/2015		
	5 TRIBES - PECAN CREEK 161KV CKT 1 Accelerate	6/1/2013	6/1/2015		
	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015		
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015		
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015		
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015		
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		No
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		No
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		No
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		No
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		No
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		No
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		No
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		No
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018		No
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		No
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		No
	VBI - Arkansas Nuclear One 345KV OKGE	6/1/2013	6/1/2018		No
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018		No
	Waldron 69 KV Capacitor	6/1/2018	6/1/2018		
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		No

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586023	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586023	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 40,174	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 93,338	\$ 18,000,000	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 137,818	\$ 20,000,000	
	Brookline - Compton Ridge 345 KV	6/1/2013	6/1/2018	No	0.68%	100.00%	
	Compton Ridge - Cox Creek 345 KV	6/1/2013	6/1/2018	No	0.27%	100.00%	
	Compton Ridge - Osage Creek 345 KV	6/1/2013	6/1/2018	No	0.02%	100.00%	
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No	1.01%	100.00%	
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018	No	1.33%	100.00%	
	GORE - MUSKOGEE TAP 161KV CKT 1	6/1/2013	6/1/2016	No	\$ 546,137	\$ 8,000,000	
	GORE - SALLISAW 161KV CKT 1	6/1/2013	6/1/2016		\$ 217,096	\$ 9,000,000	
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018	No	0.61%	100.00%	
	LIBERTY TAP - SALLISAW 161KV CKT 1 SWPA	6/1/2013	6/1/2016	No	\$ 288,607	\$ 6,500,000	
	McNeil 500/345KV	6/1/2013	6/1/2018	No	\$ 178,631	\$ 12,000,000	
				Total	\$ 1,501,801	\$ 81,500,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
AEPM 2012-AG1-033

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76584399	CSWS	CSWS	250	1/1/2016	1/1/2021	6/1/2018	6/1/2023	\$ 21,892,328	\$ -	\$ 21,892,328	\$ 69,336,966
									\$ 21,892,328	\$ -	\$ 21,892,328	\$ 69,336,966

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584399	BETHEL - BROKEN BOW 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 2,652,829	\$ 9,190,000	\$ 8,766,761	
	BETHEL - NASHOBIA 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 6,474,750	\$ 22,430,000	\$ 21,397,001	
	CLAYTON - NASHOBIA 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 3,339,851	\$ 11,570,000	\$ 11,036,211	
	CLAYTON - SARDIS 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 421,451	\$ 1,460,000	\$ 1,392,644	
	ENOWILT - LONE OAK 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 180,415	\$ 625,000	\$ 524,257	
	ENOWILT - SARDIS 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 3,983,573	\$ 13,800,000	\$ 13,162,206	
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017	Yes	\$ 2,519,753	\$ 14,500,000	\$ 6,420,296	
	Ft. SMITH 500 kV CAPACITOR	6/1/2018	6/1/2018		\$ 486,966	\$ 2,500,000	\$ 1,160,130	
	HIGHWAY 59 - VBI 161KV CKT 1	6/1/2013	6/1/2018		\$ 20,008	\$ 80,000	\$ 40,187	
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016		\$ 42,675	\$ 330,000	\$ 129,182	
	NORTHWEST TEXARKANA - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2018	6/1/2018		\$ 164,770	\$ 605,000	\$ 426,308	
	WILKES (WILKES) 345/138/13.2KV TRANSFORMER CKT 1	6/1/2018	6/1/2018	6/1/2016	\$ 1,605,287	\$ 5,500,000	\$ 4,881,782	
				Total	\$ 21,892,328	\$ 82,590,000	\$ 69,336,966	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584399	DIANA - PERDUE 138KV CKT 1 #1	6/1/2013	6/1/2013		
	DIANA - PERDUE 138KV CKT 1 #2	6/1/2013	6/1/2016		Yes

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584399	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015		
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015		
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015		
	GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015		
	Iatan - Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 kV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345kV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Muskogee - VBI 345 kV with 345/161 kV bus tie at VBI	6/1/2013	6/1/2018		
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 kV AEPW	6/1/2013	6/1/2018		
	VBI - Arkansas Nuclear One 345KV OKGE	6/1/2013	6/1/2018		
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584399	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76584399	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 1,198,930	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 2,402,072	\$ 18,000,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014			17.68%	100.00%
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018	Yes	\$ 2,346,914	\$ 12,000,000	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016		\$ 1,390,984	\$ 20,000,000	
	Brookline - Compton Ridge 345 kV	6/1/2013	6/1/2018	Yes		7.68%	100.00%
	Compton Ridge - Cox Creek 345 kV	6/1/2013	6/1/2018	Yes		15.56%	100.00%
	Compton Ridge - Osage Creek 345 kV	6/1/2013	6/1/2018	Yes		20.75%	100.00%
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	Yes		15.24%	100.00%
	Compton Ridge 345/161 kV Transformer	6/1/2013	6/1/2018	Yes		20.96%	100.00%
	GORE - SALLISAW 161KV CKT 1	6/1/2013	6/1/2016	Yes	\$ 1,854,619	\$ 9,000,000	
	HARTBURG - INLAND-ORANGE 230KV CKT 1	10/1/2013	10/1/2013			29.92%	100.00%
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018			0.30%	100.00%
	LIBERTY TAP - SALLISAW 161KV CKT 1 SWPA	6/1/2013	6/1/2016		\$ 1,089,354	\$ 6,500,000	
	SHEELDSHESE	10/1/2012	10/1/2012			22.89%	100.00%
	VBI - Arkansas Nuclear One 345kV EES	6/1/2013	6/1/2018	Yes		19.47%	100.00%
				Total	\$ 10,282,873	\$ 73,500,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGK, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
AEPM 2012-AG1-034

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76584402	CSWS	CSWS	250	1/1/2016	1/1/2021	6/1/2018	6/1/2023	\$ 22,228,902	\$ -	\$ 22,228,902	\$ 70,442,127
									\$ 22,228,902	\$ -	\$ 22,228,902	\$ 70,442,127

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584402	BETHEL - BROKEN BOW 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 2,703,268	\$ 9,190,000	\$ 8,933,446	
	BETHEL - NASHOBIA 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 6,597,855	\$ 22,430,000	\$ 21,803,824	
	CLAYTON - NASHOBIA 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 3,403,352	\$ 11,570,000	\$ 11,246,044	
	CLAYTON - SARDIS 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 429,464	\$ 1,460,000	\$ 1,419,122	
	ENOWILT - LONE OAK 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 183,846	\$ 625,000	\$ 534,227	
	ENOWILT - SARDIS 138KV CKT 1	10/1/2014	6/1/2016	Yes	\$ 4,059,314	\$ 13,800,000	\$ 13,412,464	
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017	Yes	\$ 2,518,782	\$ 14,500,000	\$ 6,417,822	
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018		\$ 490,363	\$ 2,500,000	\$ 1,168,223	
	HIGHWAY 59 - VBI 161KV CKT 1	6/1/2013	6/1/2018		\$ 20,180	\$ 80,000	\$ 40,533	
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016		\$ 53,936	\$ 330,000	\$ 163,270	
	NORTHWEST TEXARKANA - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2018	6/1/2018		\$ 165,498	\$ 605,000	\$ 428,191	
	WILKES (WILKES) 345/13.8KV TRANSFORMER CKT 1	6/1/2018	6/1/2018	6/1/2016	\$ 1,603,044	\$ 5,500,000	\$ 4,874,961	
					Total	\$ 22,228,902	\$ 82,590,000	\$ 70,442,127

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584402	77TH & MEMORIAL WEST - EAST 61ST STREET 138KV CKT 1	6/1/2018	6/1/2018		
	DIANA - PERDUE 138KV CKT 1 #1	6/1/2013	6/1/2013		
	DIANA - PERDUE 138KV CKT 1 #2	6/1/2013	6/1/2016	Yes	

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584402	5 TRIBES - HANCOCK 161KV CKT 1 #2	6/1/2013	6/1/2015		
	5 TRIBES - PECAN CREEK 161KV CKT 1 Accelerate	6/1/2013	6/1/2015		
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015		
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015		
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015		
	GRDAL - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018	Yes	
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018	Yes	
	VBI - Arkansas Nuclear One 345kV OKGE	6/1/2013	6/1/2018	Yes	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584402	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76584402	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 1,138,128	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 2,298,821	\$ 18,000,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014		17.84%	100.00%	
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018	Yes	\$ 2,355,094	\$ 12,000,000	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016		\$ 1,125,230	\$ 20,000,000	
	Brookline - Compton Ridge 345 kV	6/1/2013	6/1/2018	Yes	8.05%	100.00%	
	Compton Ridge - Cox Creek 345 kV	6/1/2013	6/1/2018	Yes	14.76%	100.00%	
	Compton Ridge - Osage Creek 345 kV	6/1/2013	6/1/2018	Yes	18.88%	100.00%	
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	Yes	14.63%	100.00%	
	Compton Ridge 345/161 kV Transformer	6/1/2013	6/1/2018	Yes	19.50%	100.00%	
	GORE - SALLISAW 161KV CKT 1	6/1/2013	6/1/2016	Yes	\$ 1,882,841	\$ 9,000,000	
	HARTBURG - INLAND-ORANGE 230KV CKT 1	10/1/2013	10/1/2013		29.64%	100.00%	
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018		1.23%	100.00%	
	LIBERTY TAP - SALLISAW 161KV CKT 1 SWPA	6/1/2013	6/1/2016		\$ 1,203,149	\$ 6,500,000	
	SHEELDSHESE	10/1/2012	10/1/2012		22.68%	100.00%	
	VBI - Arkansas Nuclear One 345kV EES	6/1/2013	6/1/2018	Yes	19.54%	100.00%	
				Total	\$ 10,003,263	\$ 73,500,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGK, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer AEPM
Study Number 2012-AG1-036

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76584451	WR	CSWS	78	10/1/2012	1/1/2032	6/1/2019	9/1/2038	\$ 5,924,918	\$ -	\$ 6,048,842	\$ 36,641,506
									\$ 5,924,918	\$ -	\$ 6,048,842	\$ 36,641,506

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
76584451	BETHEL - BROKEN BOW 138KV CKT 1	10/1/2014	6/1/2016			\$ 716,213	\$ -	\$ 716,213	\$ 9,190,000	\$ 4,529,449	
	BETHEL - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 1,748,059	\$ -	\$ 1,748,059	\$ 22,430,000	\$ 11,055,014	
	CLAYTON - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 901,696	\$ -	\$ 901,696	\$ 11,570,000	\$ 5,701,989	
	CLAYTON - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 113,784	\$ -	\$ 113,784	\$ 1,460,000	\$ 719,527	
	ENOWILT - LONE OAK 138KV CKT 1	10/1/2014	6/1/2016			\$ 48,709	\$ -	\$ 48,709	\$ 625,000	\$ 270,866	
	ENOWILT - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 1,075,489	\$ -	\$ 1,075,489	\$ 13,800,000	\$ 6,800,411	
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017			\$ 417,761	\$ -	\$ 417,761	\$ 14,500,000	\$ 2,166,335	
	Ft. SMITH 500 kV CAPACITOR	6/1/2018	6/1/2018			\$ 99,478	\$ -	\$ 99,478	\$ 2,500,000	\$ 484,789	
	KINZE - MCELROY 138KV CKT 1	6/1/2018	6/1/2018			\$ 251,603	\$ 123,924	\$ 375,527	\$ 1,800,000	\$ 1,745,317	
	NORTHWEST TEXARKANA - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2018	6/1/2018			\$ 51,408	\$ -	\$ 51,408	\$ 605,000	\$ 253,791	
	WILKES (WILKES) 345/138/13.2KV TRANSFORMER CKT 1	6/1/2018	6/1/2018	6/1/2016		\$ 500,718	\$ -	\$ 500,718	\$ 5,500,000	\$ 2,914,018	
						Total	\$ 5,924,918	\$ 123,924	\$ 6,048,842	\$ 83,980,000	\$ 36,641,506

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584451	IATAN - NASHUA 345KV CKT 1	6/1/2013	6/1/2015	No	
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015	No	
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014	No	
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015	No	
	NORTHWEST TEXARKANA - VALIANT 345KV CKT 1	10/1/2012	10/1/2014	No	
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014	No	
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014	No	
	XFR - Medicine Lodge 345/138 kV	10/1/2012	1/1/2015	No	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584451	DIANA - PERDUE 138KV CKT 1 #1	6/1/2013	6/1/2013		
	DIANA - PERDUE 138KV CKT 1 #2	6/1/2013	6/1/2016		Yes

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584451	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016	No	
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016	No	
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015	No	
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2014	6/1/2017		
	Circle - Reno 345KV Dbl CKT	10/1/2012	6/1/2019		
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016	No	
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016	No	
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015		
	GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015	Yes	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017	No	
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018	No	
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018	No	
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2014	6/1/2017		
	Mathewson 345 KV	6/1/2014	6/1/2017		
	Mullergruen - Circle 345kV Dbl CKT MKEC	10/1/2012	6/1/2019		
	Mullergruen - Circle 345kV Dbl CKT WERF	10/1/2012	6/1/2019		
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018		
	Spearerville - Mullergruen 345KV Dbl CKT	10/1/2012	6/1/2019		
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018	No	
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		
	VBI - Arkansas Nuclear One 345KV OKGE	6/1/2013	6/1/2018		
	Viola - Rose Hill 345KV CKT 1	6/1/2014	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018	No	

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584451	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76584451	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 274,279	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 699,255	\$ 18,000,000	
	TOVERTON 345.00 () 345/161/13.8KV TRANSFORMER CKT 1	10/1/2012	6/1/2016	No	\$ 1,222,568	\$ 16,100,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014			3.16%	100.00%
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018		\$ 466,069	\$ 12,000,000	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 1,430,766	\$ 20,000,000	
	Brookline - Compton Ridge 345 kV	6/1/2013	6/1/2018			6.81%	100.00%
	Compton Ridge - Cox Creek 345 kV	6/1/2013	6/1/2018			3.67%	100.00%
	Compton Ridge - Osage Creek 345 kV	6/1/2013	6/1/2018			0.08%	100.00%
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018			6.09%	100.00%
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018			5.15%	100.00%
	HARTBURG - INLAND-ORANGE 230KV CKT 1	10/1/2013	10/1/2013			9.34%	100.00%
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018	No		8.23%	100.00%
	SHEELDSHESE	10/1/2012	10/1/2012			6.55%	100.00%
	VBI - Arkansas Nuclear One 345kV EES	6/1/2013	6/1/2018			3.87%	100.00%
				Total	\$ 4,092,937	\$ 74,100,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGKE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345KV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer AEPM
Study Number 2012-AG1-037

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76584464	SPS	CSWS	80	10/1/2012	1/1/2032	6/1/2019	9/1/2038	\$ 5,745,068	\$ -	\$ 5,745,068	\$ 38,286,514
									\$ 5,745,068	\$ -	\$ 5,745,068	\$ 38,286,514

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584464	BETHEL - BROKEN BOW 138KV CKT 1	10/1/2014	6/1/2016			\$ 716,132	\$ -	\$ 716,132	\$ 9,190,000	\$ 4,912,380
	BETHEL - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 1,747,860	\$ -	\$ 1,747,860	\$ 22,430,000	\$ 11,989,622
	CLAYTON - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 901,593	\$ -	\$ 901,593	\$ 11,570,000	\$ 6,184,041
	CLAYTON - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 113,771	\$ -	\$ 113,771	\$ 1,460,000	\$ 780,357
	ENOWILT - LONE OAK 138KV CKT 1	10/1/2014	6/1/2016			\$ 48,703	\$ -	\$ 48,703	\$ 625,000	\$ 293,763
	ENOWILT - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 1,075,366	\$ -	\$ 1,075,366	\$ 13,800,000	\$ 7,375,325
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017			\$ 470,525	\$ -	\$ 470,525	\$ 14,500,000	\$ 2,673,744
	Ft. SMITH 500 kV CAPACITOR	6/1/2018	6/1/2018			\$ 107,201	\$ -	\$ 107,201	\$ 2,500,000	\$ 569,576
	NORTHWEST TEXARKANA - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2018	6/1/2018			\$ 54,464	\$ -	\$ 54,464	\$ 605,000	\$ 291,833
	WILKES (WILKES) 345/138/13.2KV TRANSFORMER CKT 1	6/1/2018	6/1/2018	6/1/2016		\$ 509,453	\$ -	\$ 509,453	\$ 5,500,000	\$ 3,215,872
						Total		\$ 5,745,068	\$ 82,180,000	\$ 38,286,514

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584464	Cherry Co - Gentleman 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co - Holt Co 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co 345 kV Terminal Upgrades	10/1/2012	1/1/2018	No	
	Elk City 345/230 kV	6/1/2014	6/1/2018	No	
	Elk City to Gracemont 345kV AEPW	6/1/2014	6/1/2018	No	
	Elk City to Gracemont 345kV OKGE	6/1/2014	6/1/2018	No	
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015	No	
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014	No	
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015	No	
	Line - NPPD - Axtell - Kansas Border 345 kV	10/1/2012	6/1/2013	No	
	Line - Post Rock - Axtell 345 kV	10/1/2012	6/1/2013	No	
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015	No	
	Line - Spearville - Post Rock 345 kV	10/1/2012	10/1/2012	6/1/2012	
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	10/1/2012	6/1/2015	No	
	NORTHWEST TEXARKANA - VALIANT 345KV CKT 1	10/1/2012	10/1/2014	No	
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014	No	
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014	No	
	XFR - Post Rock 345/230 kV	10/1/2012	10/1/2012	6/1/2012	
	XFR - Medicine Lodge 345/138 kV	10/1/2012	1/1/2015	No	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584464	DIANA - PERDUE 138KV CKT 1 #1	6/1/2013	6/1/2013		
	DIANA - PERDUE 138KV CKT 1 #2	6/1/2013	6/1/2016	Yes	
	Line - Osage Station and Line Re-termination	6/1/2013	6/1/2015	No	

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584464	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CANYON EAST SUB - CANYON WEST SUB 115KV CKT 1	6/1/2015	6/1/2016	No	
	CANYON EAST SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	6/1/2015	6/1/2016	No	
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016	Yes	
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016	Yes	
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015	No	
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2014	6/1/2017	No	
	Circle - Reno 345KV Dbl Ckt	10/1/2012	6/1/2019	No	
	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC	10/1/2012	6/1/2015	No	
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE	10/1/2012	6/1/2015	No	
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016	Yes	
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016	Yes	
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015	Yes	
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018	No	
	GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015	Yes	
	HARPER - MILAN TAP 138KV CKT 1 #1	10/1/2013	6/1/2014	No	
	HARPER - MILAN TAP 138KV CKT 1 #2	10/1/2012	6/1/2015	No	
	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	10/1/2012	6/1/2015	No	
	HAYS PLANT - VINE STREET 115KV CKT 1	10/1/2012	6/1/2016	No	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017	No	
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018	No	
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018	No	
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2014	6/1/2017	No	
	Mathewson 345 KV	6/1/2014	6/1/2017	No	
	Mullergruen - Circle 345kv Dbl CKT MKEC	10/1/2012	6/1/2019	No	
	Mullergruen - Circle 345kv Dbl CKT WERE	10/1/2012	6/1/2019	No	
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018	Yes	
	Spearville - Mullergruen 345KV Dbl Ckt	10/1/2012	6/1/2019	No	
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018	No	
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018	No	
	VBI - Arkansas Nuclear One 345KV OKGE	6/1/2013	6/1/2018	Yes	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018	No	

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584464	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	CHERRY6 - 230.00 - Harrington Station East Bus 230KV CKT 1	6/1/2015	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
	Circle - Reno 345KV Dbl Ckt	10/1/2012	6/1/2019		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	Mullergruen - Circle 345kv Dbl CKT MKEC	10/1/2012	6/1/2019		
	Mullergruen - Circle 345kv Dbl CKT WERE	10/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	Spearville - Mullergruen 345KV Dbl Ckt	10/1/2012	6/1/2019		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76584464	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 215,419	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 544,949	\$ 18,000,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014		3.50%	100.00%	
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018	Yes	\$ 504,757	\$ 12,000,000	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016		\$ 932,693	\$ 20,000,000	
	Brookline - Compton Ridge 345 kV	6/1/2013	6/1/2018	No	5.09%	100.00%	
	Compton Ridge - Cox Creek 345 kV	6/1/2013	6/1/2018	No	3.35%	100.00%	
	Compton Ridge - Osage Creek 345 kV	6/1/2013	6/1/2018	No	1.21%	100.00%	
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No	5.09%	100.00%	
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018	No	4.85%	100.00%	
	HARTBURG - INLAND-ORANGE 230KV CKT 1	10/1/2013	10/1/2013		9.01%	100.00%	
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018	No	5.59%	100.00%	
	SHEELDSHEHSE	10/1/2012	10/1/2012		6.32%	100.00%	
	VBI - Arkansas Nuclear One 345KV EES	6/1/2013	6/1/2018	Yes	4.19%	100.00%	
				Total	\$ 2,197,818	\$ 58,000,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer AEPM
Study Number 2012-AG1-042

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76586559	OKGE	CSWS	101	10/1/2012	12/31/2032	6/1/2018	8/1/2038	\$ 7,768,702	\$ -	\$ 7,768,702	\$ 48,771,028
									\$ 7,768,702	\$ -	\$ 7,768,702	\$ 48,771,028

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
76586559	BETHEL - BROKEN BOW 138KV CKT 1	10/1/2014	6/1/2016			\$ 959,909	\$ -	\$ 959,909	\$ 9,190,000	\$ 6,211,800	
	BETHEL - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 2,342,845	\$ -	\$ 2,342,845	\$ 22,430,000	\$ 15,161,109	
	CLAYTON - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 1,208,503	\$ -	\$ 1,208,503	\$ 11,570,000	\$ 7,819,845	
	CLAYTON - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 152,499	\$ -	\$ 152,499	\$ 1,460,000	\$ 986,773	
	ENOWILT - LONE OAK 138KV CKT 1	10/1/2014	6/1/2016			\$ 65,282	\$ -	\$ 65,282	\$ 625,000	\$ 371,469	
	ENOWILT - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 1,441,430	\$ -	\$ 1,441,430	\$ 13,800,000	\$ 9,326,249	
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017	Yes		\$ 719,746	\$ -	\$ 719,746	\$ 14,500,000	\$ 3,867,533	
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 153,813	\$ -	\$ 153,813	\$ 2,500,000	\$ 772,431	
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016	No		\$ 14,270	\$ -	\$ 14,270	\$ 330,000	\$ 84,588	
	NORTHWEST TEXARKANA - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2018	6/1/2018			\$ 69,656	\$ -	\$ 69,656	\$ 605,000	\$ 353,557	
	WILKES (WILKES) 345/138/13.2KV TRANSFORMER CKT 1	6/1/2018	6/1/2018	6/1/2016		\$ 640,749	\$ -	\$ 640,749	\$ 5,500,000	\$ 3,815,673	
						Total	\$ 7,768,702	\$ -	\$ 7,768,702	\$ 82,510,000	\$ 48,771,028

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586559	NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1	10/1/2012	10/1/2014		No

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586559	DIANA - PERDUE 138KV CKT 1 #1	6/1/2013	6/1/2013		
	DIANA - PERDUE 138KV CKT 1 #2	6/1/2013	6/1/2016	Yes	
	HAMMETT TAP - HORSESHOE LAKE 138KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586559	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015		No
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015	Yes	
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015	Yes	
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015	Yes	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		No
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		No
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		No
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		No
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		No
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		No
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		No
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018		Yes
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		No
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		No
	VBI - Arkansas Nuclear One 345kv OKGE	6/1/2013	6/1/2018		Yes
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018		No
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		No

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586559	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2012	6/1/2019		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 kV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 kV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345kV CKT 1	6/1/2014	6/1/2018		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586559	7JASPER - 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 344,779	\$ 8,000,000	
	7JASPER - 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 775,463	\$ 18,000,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014		5.27%	100.00%	
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018	Yes	\$ 727,669	\$ 12,000,000	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016		\$ 941,439	\$ 20,000,000	
	Brookline - Compton Ridge 345 kV	6/1/2013	6/1/2018	No	5.09%	100.00%	
	Compton Ridge - Cox Creek 345 kV	6/1/2013	6/1/2018	No	4.67%	100.00%	
	Compton Ridge - Osage Creek 345 kV	6/1/2013	6/1/2018	No	3.51%	100.00%	
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No	5.88%	100.00%	
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018	No	6.27%	100.00%	
	HARTBURG - INLAND-ORANGE 230KV CKT 1	10/1/2013	10/1/2013		11.05%	100.00%	
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018	No	4.56%	100.00%	
	SHEELDSHEHSE	10/1/2012	10/1/2012		7.96%	100.00%	
	VBI - Arkansas Nuclear One 345KV EES	6/1/2013	6/1/2018	Yes	6.04%	100.00%	
				Total	\$ 2,789,350	\$ 58,000,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345KV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345KV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and TP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
AEPM 2012-AG1-044

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76586582	OKGE	CSWS	53	10/1/2012	12/31/2032	6/1/2018	8/1/2038	\$ 4,076,637	\$ -	\$ 4,076,637	\$ 25,592,662
									\$ 4,076,637	\$ -	\$ 4,076,637	\$ 25,592,662

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586582	BETHEL - BROKEN BOW 138KV CKT 1	10/1/2014	6/1/2016			\$ 503,713	\$ -	\$ 503,713	\$ 9,190,000	\$ 3,259,647
	BETHEL - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 1,229,411	\$ -	\$ 1,229,411	\$ 22,430,000	\$ 7,955,812
	CLAYTON - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 634,163	\$ -	\$ 634,163	\$ 11,570,000	\$ 4,103,471
	CLAYTON - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 80,024	\$ -	\$ 80,024	\$ 1,460,000	\$ 517,810
	ENOWILT - LONE OAK 138KV CKT 1	10/1/2014	6/1/2016			\$ 34,257	\$ -	\$ 34,257	\$ 625,000	\$ 194,930
	ENOWILT - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 756,392	\$ -	\$ 756,392	\$ 13,800,000	\$ 4,893,959
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017	Yes		\$ 377,688	\$ -	\$ 377,688	\$ 14,500,000	\$ 2,029,495
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 80,714	\$ -	\$ 80,714	\$ 2,500,000	\$ 405,336
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016	No		\$ 7,488	\$ -	\$ 7,488	\$ 330,000	\$ 44,387
	NORTHWEST TEXARKANA - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2018	6/1/2018			\$ 36,552	\$ -	\$ 36,552	\$ 605,000	\$ 185,529
	WILKES (WILKES) 345/138/13.2KV TRANSFORMER CKT 1	6/1/2018	6/1/2018	6/1/2016		\$ 336,235	\$ -	\$ 336,235	\$ 5,500,000	\$ 2,002,286
					Total	\$ 4,076,637	\$ -	\$ 4,076,637	\$ 82,510,000	\$ 25,592,662

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586582	NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1	10/1/2012	10/1/2014		No

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586582	DIANA - PERDUE 138KV CKT 1 #1	6/1/2013	6/1/2013		
	DIANA - PERDUE 138KV CKT 1 #2	6/1/2013	6/1/2016	Yes	
	HAMMETT TAP - HORSESHOE LAKE 138KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586582	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015	No	
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015	Yes	
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015		
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015	Yes	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018	No	
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018	No	
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018	Yes	
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018	No	
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018	No	
	VBI - Arkansas Nuclear One 345kv OKGE	6/1/2013	6/1/2018	Yes	
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018	No	

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586582	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2012	6/1/2019		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 kV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 kV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345kV CKT 1	6/1/2014	6/1/2018		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586582	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 180,923	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 406,927	\$ 18,000,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014		2.77%	100.00%	
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018		\$ 381,846	\$ 12,000,000	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016		\$ 494,022	\$ 20,000,000	
	Brookline - Compton Ridge 345 kV	6/1/2013	6/1/2018	No	2.67%	100.00%	
	Compton Ridge - Cox Creek 345 kV	6/1/2013	6/1/2018	No	2.45%	100.00%	
	Compton Ridge - Osage Creek 345 kV	6/1/2013	6/1/2018	No	1.84%	100.00%	
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No	3.09%	100.00%	
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018	No	3.29%	100.00%	
	HARTBURG - INLAND-ORANGE 230KV CKT 1	10/1/2013	10/1/2013		5.80%	100.00%	
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018	No	2.39%	100.00%	
	SHEELDSHEHSE	10/1/2012	10/1/2012		4.18%	100.00%	
	VBI - Arkansas Nuclear One 345KV EES	6/1/2013	6/1/2018	Yes	3.17%	100.00%	
				Total	\$ 1,463,718	\$ 58,000,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345KV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345KV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer AEPM
Study Number 2012-AG1-046

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	76586592	OKGE	CSWS	48	10/1/2012	12/31/2032	6/1/2018	8/1/2038	\$ 3,692,062	\$ -	\$ 3,692,062	\$ 23,178,347
									\$ 3,692,062	\$ -	\$ 3,692,062	\$ 23,178,347

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
76586592	BETHEL - BROKEN BOW 138KV CKT 1	10/1/2014	6/1/2016			\$ 456,195	\$ -	\$ 456,195	\$ 9,190,000	\$ 2,952,147	
	BETHEL - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 1,113,434	\$ -	\$ 1,113,434	\$ 22,430,000	\$ 7,205,297	
	CLAYTON - NASHOBA 138KV CKT 1	10/1/2014	6/1/2016			\$ 574,339	\$ -	\$ 574,339	\$ 11,570,000	\$ 3,716,368	
	CLAYTON - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 72,475	\$ -	\$ 72,475	\$ 1,460,000	\$ 468,963	
	ENOWILT - LONE OAK 138KV CKT 1	10/1/2014	6/1/2016			\$ 31,025	\$ -	\$ 31,025	\$ 625,000	\$ 176,539	
	ENOWILT - SARDIS 138KV CKT 1	10/1/2014	6/1/2016			\$ 685,038	\$ -	\$ 685,038	\$ 13,800,000	\$ 4,432,289	
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017	Yes		\$ 342,057	\$ -	\$ 342,057	\$ 14,500,000	\$ 1,838,033	
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 73,099	\$ -	\$ 73,099	\$ 2,500,000	\$ 367,095	
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016	No		\$ 6,782	\$ -	\$ 6,782	\$ 330,000	\$ 40,202	
	NORTHWEST TEXARKANA - NW TEXARKANA-BANN T 138KV CKT 1	6/1/2018	6/1/2018			\$ 33,104	\$ -	\$ 33,104	\$ 605,000	\$ 168,028	
	WILKES (WILKES) 345/138/13.2KV TRANSFORMER CKT 1	6/1/2018	6/1/2018	6/1/2016		\$ 304,514	\$ -	\$ 304,514	\$ 5,500,000	\$ 1,813,387	
						Total		\$ 3,692,062	\$ 3,692,062	\$ 82,510,000	\$ 23,178,347

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586592	NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1	10/1/2012	10/1/2014		No

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586592	DIANA - PERDUE 138KV CKT 1 #1	6/1/2013	6/1/2013		
	DIANA - PERDUE 138KV CKT 1 #2	6/1/2013	6/1/2016	Yes	
	HAMMETT TAP - HORSESHOE LAKE 138KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586592	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015	No	
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015	Yes	
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015		
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015	Yes	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018	No	
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018	No	
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018	Yes	
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018	No	
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018	No	
	VBI - Arkansas Nuclear One 345kv OKGE	6/1/2013	6/1/2018	Yes	
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018	No	

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586592	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2012	6/1/2019		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 kV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 kV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345kV CKT 1	6/1/2014	6/1/2018		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586592	7JASPER - 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 163,856	\$ 8,000,000	
	7JASPER - 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 368,536	\$ 18,000,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014		2.51%	100.00%	
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018		\$ 345,823	\$ 12,000,000	
	BLACKBERRY - NEOSHO 345KV CKT 1	6/1/2014	6/1/2016		\$ 447,416	\$ 20,000,000	
	Brookline - Compton Ridge 345 kV	6/1/2013	6/1/2018	No	2.42%	100.00%	
	Compton Ridge - Cox Creek 345 kV	6/1/2013	6/1/2018	No	2.22%	100.00%	
	Compton Ridge - Osage Creek 345 kV	6/1/2013	6/1/2018	No	1.67%	100.00%	
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No	2.79%	100.00%	
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018	No	2.98%	100.00%	
	HARTBURG - INLAND-ORANGE 230KV CKT 1	10/1/2013	10/1/2013		5.25%	100.00%	
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018	No	2.17%	100.00%	
	SHEELDSHEHSE	10/1/2012	10/1/2012		3.78%	100.00%	
	VBI - Arkansas Nuclear One 345KV EES	6/1/2013	6/1/2018	Yes	2.87%	100.00%	
				Total	\$ 1,325,631	\$ 58,000,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345KV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345KV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
CHAN 2012-AG1-028

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76583997	KACY	WR	3	1/1/2014	1/1/2019	6/1/2016	6/1/2021	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583997	None					\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	
						Total	\$ - \$ - \$ - \$ -	

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583997	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	BIRMINGHAM - HAWTHORN 161KV CKT 1	6/1/2014	6/1/2015		
	BIRMINGHAM - LIBERTY SOUTH 161KV CKT 1 KACP	6/1/2014	6/1/2015		
	BIRMINGHAM - LIBERTY SOUTH 161KV CKT 1 MIPU	6/1/2014	6/1/2015		
	BUTLER - MIDIAN 138KV CKT 1	6/1/2018	6/1/2018		
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 kV AEPW	6/1/2013	6/1/2018		
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583997	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	DEARING 138KV Capacitor	6/1/2012	6/1/2012		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76583997	SOVERTON 161.00 - 50VERTON 2 161.00 161KV CKT 1	6/1/2014	6/1/2014			0.43%	100.00%
	TOVERTON 345.00 () 345/161/13.8KV TRANSFORMER CKT 1	10/1/2012	6/1/2016	No	\$ 66,231	\$ 16,100,000	
	Brookline - Compton Ridge 345 kV	6/1/2013	6/1/2018			0.04%	100.00%
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018			0.17%	100.00%
	Lacygne - Morgan 345KV AECL	10/1/2012	6/1/2018			0.24%	100.00%
					Total	\$ 66,231	\$ 16,100,000

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OGKE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
CHAN 2012-AG1-029

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76583999	KCPL	WR	45	1/1/2014	1/1/2019	6/1/2018	6/1/2023	\$ - \$	- \$	- \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583999	None					\$ - \$	- \$	-
						Total	\$ - \$	- \$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583999	LATAN - NASHUA 345KV CKT 1	6/1/2013	6/1/2015		Yes

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583999	BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #1	6/1/2014	6/1/2014		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583999	SBUTLER - ADRIAN 161KV CKT 1	6/1/2018	6/1/2018		
	ADRIAN - ARCHIE 161KV CKT 1	6/1/2018	6/1/2018		
	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	BIRMINGHAM - HAWTHORN 161KV CKT 1	6/1/2014	6/1/2015		Yes
	BIRMINGHAM - LIBERTY SOUTH 161KV CKT 1 KACP	6/1/2014	6/1/2015		Yes
	BIRMINGHAM - LIBERTY SOUTH 161KV CKT 1 MIPU	6/1/2014	6/1/2015		Yes
	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #2	6/1/2014	6/1/2016		Yes
	BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #2	6/1/2014	6/1/2016		Yes
	BLUE SPRINGS EAST - BLUE SPRINGS WEST 161KV CKT 1	6/1/2014	6/1/2016		Yes
	BLUE SPRINGS EAST - GRAIN VALLEY 161KV CKT 1	6/1/2014	6/1/2016		Yes
	BUTLER - MIDIAN 138KV CKT 1	6/1/2018	6/1/2018		
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		Yes
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		Yes
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		Yes
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		Yes
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		Yes
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		Yes
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		Yes
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		Yes
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		Yes
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		Yes
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		Yes
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		Yes
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		Yes
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583999	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	DEARING 138KV Capacitor	6/1/2012	6/1/2012		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76583999	SOVERTON 161.00 - SOVERTON 2 161.00 161KV CKT 1	6/1/2014	6/1/2014			7.14%	100.00%
	70VERTON 345.00 (I) 345/161/13.8KV TRANSFORMER CKT 1	10/1/2012	6/1/2016	No		\$ 1,102,576	\$ 16,100,000
	Brookline - Compton Ridge 345 kV	6/1/2013	6/1/2018	Yes		1.18%	100.00%
	CLINTON 161/69KV TRANSFORMER CKT 1	6/1/2018	6/1/2018			100.00%	100.00%
	CLINTON 161/69KV TRANSFORMER CKT 3	6/1/2018	6/1/2018			100.00%	100.00%
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018	Yes		2.47%	100.00%
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018	Yes		3.40%	100.00%
	NORTH WARSAW - TRUMAN 161KV CKT 1 SWPA	6/1/2014	6/1/2014			\$ -	\$ -
				Total		\$ 1,102,576	\$ 16,100,000

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
CHAN 2012-AG1-031

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76584004	SPA	WR	1	1/1/2014	1/1/2019	6/1/2018	6/1/2023	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584004	None					\$ - \$ - \$ - \$ -		
					Total	\$ - \$ - \$ - \$ -		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584004	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	BUTLER - MIDIAN 138KV CKT 1	6/1/2018	6/1/2018		
	Iatan - Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 kV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345kV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345kV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345kV CKT 2 WERE	10/1/2012	6/1/2018		
	Swissvale - Wolf Creek 345kV	10/1/2012	6/1/2018		
	Turk - McNeil 345 kV AEPW	6/1/2013	6/1/2018		
	Viola - Rose Hill 345kV CKT 1	6/1/2014	6/1/2018	No	
	Wolf Creek - Wichita 345kV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76584004	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	DEARING 138KV Capacitor	6/1/2012	6/1/2012		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76584004	BUFORO 5 161.00 - NORFORK 161KV CKT 1	6/1/2013	6/1/2016	No	\$ - \$ - \$ -		
	NORFORK - SOUTHLAND AECC 161KV CKT 1 SWPA	6/1/2014	6/1/2014		\$ - \$ - \$ -		
	NORTH WARSAW - TRUMAN 161KV CKT 1 SWPA	6/1/2014	6/1/2014		\$ - \$ - \$ -		
	SHEELDSHEHSE	10/1/2012	10/1/2012		0.02%	100.00%	
				Total	\$ - \$ - \$ -		

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and TP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
CHAN 2012-AG1-032

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispach	Deferred Stop Date Without Redispach	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76584010	WR	WR	121	1/1/2014	1/1/2019			\$ - \$	- \$	\$ - \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispach Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76584010	None				\$	- \$	- \$	-
				Total	\$	- \$	- \$	-

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
CHAN 2012-AG1-050

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76586685	NPPD	WR	2	1/1/2014	1/1/2019	6/1/2019	6/1/2024	\$ - \$	- \$	- \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586685	None					\$ - \$	- \$	-
				Total		\$ - \$	- \$	-

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586685	Cherry Co - Gentleman 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co - Holt Co 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co 345 kV Terminal Upgrades	10/1/2012	1/1/2018	No	
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015	No	
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014	No	
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015	No	
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	10/1/2012	6/1/2015	No	
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014	No	
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014	No	
	XFR - Medicine Lodge 345/138 kV	10/1/2012	1/1/2015	No	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586685	SHELTON - SW7TH & PLEASANT HILL 115KV CKT 2 LES	12/31/2012	6/1/2013		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586685	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	BROKEN BOW - LOUP CITY 115KV CKT 1	10/1/2014	6/1/2016	No	
	BUTLER - MIDIAN 138KV CKT 1	6/1/2018	6/1/2018		
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2014	6/1/2017	No	
	Circle - Reno 345kV Dbl Ckt	10/1/2012	6/1/2019	No	
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018	No	
	Iatan - Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 kV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345kV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Mathewson - Tatonga 345 kV Ckt 1	6/1/2014	6/1/2017	No	
	Mathewson 345 kV	6/1/2014	6/1/2017	No	
	Mullergruen - Circle 345kV Dbl Ckt MKEC	10/1/2012	6/1/2019	No	
	Mullergruen - Circle 345kV Dbl Ckt WERE	10/1/2012	6/1/2019	No	
	Spearville - Mullergruen 345kV Dbl Ckt	10/1/2012	6/1/2019	No	
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 kV AEPW	6/1/2013	6/1/2018		
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586685	ALBION - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	DEARING 138KV Capacitor	6/1/2012	6/1/2012		
	LACYNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	NELIGH - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586685	Compton Ridge 345/161 kV Transformer	6/1/2013	6/1/2018			0.13%	100.00%
	Lacyne - Morgan 345kV AECI	10/1/2012	6/1/2018			0.05%	100.00%
				Total	\$ -	\$ -	-

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OGK, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
CHAN 2012-AG1-052

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispach	Deferred Stop Date Without Redispach	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76583977	WR	WR	115	1/1/2014	1/1/2019			\$ - \$	- \$	\$ - \$	-
									\$ - \$	- \$	- \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispach Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583977	None				\$	- \$	- \$	-
					Total	\$ - \$	- \$	-

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
CHAN 2012-AG1-053

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CHAN	76583984	GRDA	WR	2	1/1/2014	1/1/2019	6/1/2018	6/1/2023	\$ - \$	- \$	2,525 \$	8,316

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583984	None					\$ - \$	- \$	-
				Total		\$ - \$	- \$	-

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583984	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	BUTLER - MIDIAN 138KV CKT 1	6/1/2018	6/1/2018		
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015		
	GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Muskogee - VBI 345 kV with 345/161 kV bus tie at VBI	6/1/2013	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		
	VBI - Arkansas Nuclear One 345KV OKGE	6/1/2013	6/1/2018		
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 KV AEPW, and McNeil 500/345kv Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer CRGL
Study Number 2012-AG1-001

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76300099	CSWS	ERCOTN	207	1/1/2014	1/1/2024	6/1/2016	6/1/2026	\$ - \$ 39,308,058	\$ 3,963	\$ 39,308,058	\$ 14,401

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76300099	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016	No	\$ 3,963	\$ 330,000	\$ 14,401	
				Total	\$ 3,963	\$ 330,000	\$ 14,401	

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76300099	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015	No	
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014	No	
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015	No	
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014	No	
	TUCO - WOODWARD 345 KV CKT 1 SPA	10/1/2012	6/1/2014	No	
	XFR - Medicine Lodge 345/138 kV	10/1/2012	1/1/2015	No	

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76300099	Muskogee - VBI 345 kV with 345/161 kV bus tie at VBI	6/1/2013	6/1/2018		
	Turk - McNeil 345 kV AEPW	6/1/2013	6/1/2018		
	VBI - Arkansas Nuclear One 345kV OKGE	6/1/2013	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76300099	BANN - RED SPRINGS REC 138KV CKT 1	7/1/2012	7/1/2012		
	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	GRACMNT4_138.00 - WASHITA 138KV CKT 2 OKGE	1/1/2012	1/1/2012		
	GRACMNT4_138.00 - WASHITA 138KV CKT 2 WFEC	1/1/2012	1/1/2012		
	HUGO POWER PLANT - VALLIANT 345 kV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 kV Ckt 1	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76300099	Compton Ridge - Osage Creek 345 kV	6/1/2013	6/1/2018			1.86%	100.00%
	McNeil 500/345kV	6/1/2013	6/1/2018			\$ 3,233,519	\$ 12,000,000
				Total		\$ 3,233,519	\$ 12,000,000

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer CRGL
Study Number 2012-AG1-002

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76348872	ERCOTN	ERCOTN	207	2/1/2013	2/1/2018			\$ - \$ 19,654,029	\$ - \$	\$ - \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76348872	None				\$	- \$	- \$	-
				Total	\$	- \$	- \$	-

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer CRGL
Study Number 2012-AG1-025

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76583812	WPEK	EES	200	1/1/2014	1/1/2024	6/1/2019	6/1/2029	\$ - \$ 28,320,000	\$ 2,475,703	\$ 10,088,145	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583812	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017		Yes	\$ 2,086,925	\$ 14,500,000	\$ 8,571,078
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 333,848	\$ 2,500,000	\$ 1,282,015
	HIGHWAY 59 - VBI 161KV CKT 1	6/1/2013	6/1/2018		No	\$ 13,857	\$ 80,000	\$ 44,863
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016			\$ 41,073	\$ 330,000	\$ 190,189
				Total		\$ 2,475,703	\$ 17,410,000	\$ 10,088,145

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583812	Cherry Co - Gentleman 345 kV Ckt1	10/1/2012	1/1/2018		No
	Cherry Co - Holt Co 345 kV Ckt1	10/1/2012	1/1/2018		No
	Cherry Co 345 kV Terminal Upgrades	10/1/2012	1/1/2018		No
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015		No
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014		No
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014		No
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015		No
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		No
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015		No
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014		
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014		
	XFR - Medicine Lodge 345/138 kV	10/1/2012	1/1/2015		No

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583812	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016	Yes	
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016	Yes	
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015	No	
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2014	6/1/2017	No	
	Circle - Reno 345KV Dbl CKT	10/1/2012	6/1/2019	No	
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016	Yes	
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016	Yes	
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015	Yes	
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015	Yes	
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018	No	
	GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015	Yes	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017	No	
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018	No	
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018	No	
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2014	6/1/2017	No	
	Mathewson 345 KV	6/1/2014	6/1/2017	No	
	Mullergruen - Circle 345kV Dbl CKT MKEC	10/1/2012	6/1/2019	No	
	Mullergruen - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019	No	
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018	No	
	Spearerville - Mullergruen 345kv Dbl CKT	10/1/2012	6/1/2019	No	
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018	No	
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018	No	
	VBI - Arkansas Nuclear One 345kv OKGE	6/1/2013	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018	No	

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583812	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
	Circle - Reno 345KV Dbl CKT	10/1/2012	6/1/2019		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	Mullergruen - Circle 345kV Dbl CKT MKEC	10/1/2012	6/1/2019		
	Mullergruen - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	Spearerville - Mullergruen 345kv Dbl CKT	10/1/2012	6/1/2019		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76583812	SOVERTON 161.00 - SOVERTON 2 161.00 161KV CKT 1	6/1/2014	6/1/2014			36.32%	100.00%
7JASPER	345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 1,557,942	\$ 8,000,000	
7JASPER	345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 3,655,999	\$ 18,000,000	
7OVERTON	345.00 () 345/161/13.8KV TRANSFORMER CKT 1	10/1/2012	6/1/2016	No	\$ 4,923,601	\$ 16,100,000	
ARKANSAS NUCLEAR ONE	- PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014		15.64%	100.00%	
Arkansas Nuclear One	500/345 Transformer	6/1/2018		No	\$ 1,574,620	\$ 12,000,000	
BLACKBERRY	- NEOSHO 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 4,259,259	\$ 20,000,000	
BOGALUSA	- FRANKLIN 500KV CKT 1	10/1/2014	10/1/2014		40.00%	100.00%	
Brookline - Compton Ridge	345 KV	6/1/2013	6/1/2018	No	19.14%	100.00%	
Compton Ridge - Cox Creek	345 KV	6/1/2013	6/1/2018	No	17.90%	100.00%	
Compton Ridge - Osage Creek	345 KV	6/1/2013	6/1/2018	No	10.63%	100.00%	
COMPTON RIDGE	- SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No	15.22%	100.00%	
Compton Ridge	345/161 KV Transformer	6/1/2013	6/1/2018	No	7.85%	100.00%	
GORE	- MUSKOGEE TAP 161KV CKT 1	6/1/2013	6/1/2016	No	\$ 2,247,187	\$ 8,000,000	
GORE	- SALLISAW 161KV CKT 1	6/1/2013	6/1/2016	Yes	\$ 892,726	\$ 9,000,000	
HUBEN	345/161KV TRANSFORMER CKT 1	6/1/2014	6/1/2014		38.39%	100.00%	
Lacygne	- Morgan 345KV AECI	10/1/2012	6/1/2018	No	22.95%	100.00%	
LIBERTY TAP	- SALLISAW 161KV CKT 1 SWPA	6/1/2013	6/1/2016	No	\$ 1,199,018	\$ 6,500,000	
McNeil	500/345KV	6/1/2013	6/1/2018	No	\$ 3,377,299	\$ 12,000,000	
MONTGOMERY CITY	- WILLIAMSBURG 161KV CKT 1	6/1/2014	6/1/2014		40.00%	100.00%	
SHEELDSHEHS		10/1/2012	10/1/2012		7.30%	100.00%	
VBI	- Arkansas Nuclear One 345kV EES	6/1/2013	6/1/2018	No	13.07%	100.00%	
				Total	\$ 23,687,651	\$ 109,600,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OGKE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer CRGL
Study Number 2012-AG1-026

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76583814	WPEK	EES	200	1/1/2014	1/1/2024	6/1/2019	6/1/2029	\$ - \$ 28,320,000	\$ 2,475,703	\$ 10,088,145	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583814	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017		Yes	\$ 2,086,925	\$ 14,500,000	\$ 8,571,078
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 333,848	\$ 2,500,000	\$ 1,282,015
	HIGHWAY 59 - VBI 161KV CKT 1	6/1/2013	6/1/2018		No	\$ 13,857	\$ 80,000	\$ 44,863
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016			\$ 41,073	\$ 330,000	\$ 190,189
				Total		\$ 2,475,703	\$ 17,410,000	\$ 10,088,145

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583814	Cherry Co - Gentleman 345 kV Ckt1	10/1/2012	1/1/2018		No
	Cherry Co - Holt Co 345 kV Ckt1	10/1/2012	1/1/2018		No
	Cherry Co 345 kV Terminal Upgrades	10/1/2012	1/1/2018		No
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015		No
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014		No
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014		No
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015		No
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		No
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015		No
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014		
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014		
	XFR - Medicine Lodge 345/138 KV	10/1/2012	1/1/2015		No

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583814	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016	Yes	
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016	Yes	
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015	No	
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2014	6/1/2017	No	
	Circle - Reno 345KV Dbl CKT	10/1/2012	6/1/2019	No	
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016	Yes	
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016	Yes	
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015	Yes	
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015	Yes	
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018	No	
	GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015	Yes	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017	No	
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018	No	
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018	No	
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2014	6/1/2017	No	
	Mathewson 345 KV	6/1/2014	6/1/2017	No	
	Mullergruen - Circle 345kV Dbl CKT MKEC	10/1/2012	6/1/2019	No	
	Mullergruen - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019	No	
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018	No	
	Spearerville - Mullergruen 345kv Dbl CKT	10/1/2012	6/1/2019	No	
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018	No	
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018	No	
	VBI - Arkansas Nuclear One 345kv OKGE	6/1/2013	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018	No	

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583814	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
	Circle - Reno 345KV Dbl CKT	10/1/2012	6/1/2019		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	Mullergruen - Circle 345kV Dbl CKT MKEC	10/1/2012	6/1/2019		
	Mullergruen - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	Spearerville - Mullergruen 345kv Dbl CKT	10/1/2012	6/1/2019		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76583814	SOVERTON 161.00 - SOVERTON 2 161.00 161KV CKT 1	6/1/2014	6/1/2014			36.32%	100.00%
7JASPER	345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 1,557,942	\$ 8,000,000	
7JASPER	345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 3,655,999	\$ 18,000,000	
7OVERTON	345.00 () 345/161/13.8KV TRANSFORMER CKT 1	10/1/2012	6/1/2016	No	\$ 4,923,601	\$ 16,100,000	
ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1		6/1/2014	6/1/2014		15.64%	100.00%	
Arkansas Nuclear One 500/345 Transformer		6/1/2018	No	\$ 1,574,620	\$ 12,000,000		
BLACKBERRY - NEOSHO 345KV CKT 1		6/1/2014	6/1/2016	No	\$ 4,259,259	\$ 20,000,000	
BOGALUSA - FRANKLIN 500KV CKT 1		10/1/2014	10/1/2014		40.00%	100.00%	
Brookline - Compton Ridge 345 KV		6/1/2013	6/1/2018	No	19.14%	100.00%	
Compton Ridge - Cox Creek 345 KV		6/1/2013	6/1/2018	No	17.90%	100.00%	
Compton Ridge - Osage Creek 345 KV		6/1/2013	6/1/2018	No	10.63%	100.00%	
COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1		6/1/2013	6/1/2018	No	15.22%	100.00%	
Compton Ridge 345/161 KV Transformer		6/1/2013	6/1/2018	No	7.85%	100.00%	
GORE - MUSKOGEE TAP 161KV CKT 1		6/1/2013	6/1/2016	No	\$ 2,247,187	\$ 8,000,000	
GORE - SALLISAW 161KV CKT 1		6/1/2013	6/1/2016	Yes	\$ 892,726	\$ 9,000,000	
HUBEN 345/161KV TRANSFORMER CKT 1		6/1/2014	6/1/2014		38.39%	100.00%	
Lacygne - Morgan 345KV AECI		10/1/2012	6/1/2018	No	22.95%	100.00%	
LIBERTY TAP - SALLISAW 161KV CKT 1 SWPA		6/1/2013	6/1/2016	No	\$ 1,199,018	\$ 6,500,000	
McNeil 500/345KV		6/1/2013	6/1/2018	No	\$ 3,377,299	\$ 12,000,000	
MONTGOMERY CITY - WILLIAMSBURG 161KV CKT 1		6/1/2014	6/1/2014		40.00%	100.00%	
SHEELDSHEHS		10/1/2012	10/1/2012		7.30%	100.00%	
VBI - Arkansas Nuclear One 345kV EES		6/1/2013	6/1/2018	No	13.07%	100.00%	
				Total	\$ 23,687,651	\$ 109,600,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OGKE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer CRGL
Study Number 2012-AG1-027

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
CRGL	76583815	WPEK	EES	100	1/1/2014	1/1/2024	6/1/2019	6/1/2029	\$ - \$ 14,160,000	\$ 1,237,851	\$ 5,044,070	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583815	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017		Yes	\$ 1,043,462	\$ 14,500,000	\$ 4,285,537
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 166,924	\$ 2,500,000	\$ 641,008
	HIGHWAY 59 - VBI 161KV CKT 1	6/1/2013	6/1/2018		No	\$ 6,929	\$ 80,000	\$ 22,433
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016			\$ 20,536	\$ 330,000	\$ 95,092
				Total		\$ 1,237,851	\$ 17,410,000	\$ 5,044,070

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583815	Cherry Co - Gentleman 345 kV Ckt1	10/1/2012	1/1/2018		No
	Cherry Co - Holt Co 345 kV Ckt1	10/1/2012	1/1/2018		No
	Cherry Co 345 kV Terminal Upgrades	10/1/2012	1/1/2018		No
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015		No
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014		No
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014		No
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015		No
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		No
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015		No
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014		
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014		
	XFR - Medicine Lodge 345/138 KV	10/1/2012	1/1/2015		No

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583815	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016	Yes	
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016	Yes	
	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015	No	
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2014	6/1/2017	No	
	Circle - Reno 345KV Dbl CKT	10/1/2012	6/1/2019	No	
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016	Yes	
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016	Yes	
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015	Yes	
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015	Yes	
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018	No	
	GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015	Yes	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017	No	
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018	No	
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018	No	
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2014	6/1/2017	No	
	Mathewson 345 KV	6/1/2014	6/1/2017	No	
	Mullergruen - Circle 345kV Dbl CKT MKEC	10/1/2012	6/1/2019	No	
	Mullergruen - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019	No	
	Muskogee - VBI 345 KV with 345/161 KV bus tie at VBI	6/1/2013	6/1/2018	No	
	Spearerville - Mullergruen 345kv Dbl CKT	10/1/2012	6/1/2019	No	
	SUB 124 - AURORA H.T. 69KV	6/1/2018	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018	No	
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018	No	
	VBI - Arkansas Nuclear One 345kv OKGE	6/1/2013	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018	No	

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583815	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
	Circle - Reno 345KV Dbl CKT	10/1/2012	6/1/2019		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	Mullergruen - Circle 345kV Dbl CKT MKEC	10/1/2012	6/1/2019		
	Mullergruen - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	Spearerville - Mullergruen 345kv Dbl CKT	10/1/2012	6/1/2019		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76583815	SOVERTON 161.00 - SOVERTON 2 161.00 161KV CKT 1	6/1/2014	6/1/2014			18.16%	100.00%
7JASPER	345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 778,973	\$ 8,000,000	
7JASPER	345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 1,827,999	\$ 18,000,000	
7OVERTON	345.00 () 345/161/13.8KV TRANSFORMER CKT 1	10/1/2012	6/1/2016	No	\$ 2,461,800	\$ 16,100,000	
ARKANSAS NUCLEAR ONE	- PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014		7.82%	100.00%	
Arkansas Nuclear One	500/345 Transformer	6/1/2018		No	\$ 787,310	\$ 12,000,000	
BLACKBERRY	- NEOSHO 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 2,129,629	\$ 20,000,000	
BOGALUSA	- FRANKLIN 500KV CKT 1	10/1/2014	10/1/2014		20.00%	100.00%	
Brookline - Compton Ridge	345 KV	6/1/2013	6/1/2018	No	9.57%	100.00%	
Compton Ridge - Cox Creek	345 KV	6/1/2013	6/1/2018	No	8.95%	100.00%	
Compton Ridge - Osage Creek	345 KV	6/1/2013	6/1/2018	No	5.32%	100.00%	
COMPTON RIDGE - SUB 412	- BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No	7.61%	100.00%	
Compton Ridge	345/161 KV Transformer	6/1/2013	6/1/2018	No	3.93%	100.00%	
GORE - MUSKOGEE TAP	161KV CKT 1	6/1/2013	6/1/2016	No	\$ 1,123,593	\$ 8,000,000	
GORE - SALLISAW 161KV CKT 1		6/1/2013	6/1/2016	Yes	\$ 446,363	\$ 9,000,000	
HUBEN 345/161KV TRANSFORMER	CKT 1	6/1/2014	6/1/2014		19.19%	100.00%	
Lacygne - Morgan	345KV AECI	10/1/2012	6/1/2018	No	11.48%	100.00%	
LIBERTY TAP - SALLISAW	161KV CKT 1 SWPA	6/1/2013	6/1/2016	No	\$ 599,509	\$ 6,500,000	
McNeil 500/345KV		6/1/2013	6/1/2018	No	\$ 1,688,649	\$ 12,000,000	
MONTGOMERY CITY - WILLIAMSBURG	161KV CKT 1	6/1/2014	6/1/2014		20.00%	100.00%	
SHEELDSHEHS		10/1/2012	10/1/2012		3.65%	100.00%	
VBI - Arkansas Nuclear One	345kV EES	6/1/2013	6/1/2018	No	6.53%	100.00%	
				Total	\$ 11,843,823	\$ 109,600,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGKE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
ETEC 2012-AG1-043

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
ETEC	76586568	CSWS	CSWS	8	1/1/2013	1/1/2015	6/1/2016	6/1/2018	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586568	None					\$ - \$ - \$ - \$ -		
						Total	\$ - \$ - \$ - \$ -	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586568	DIANA - PERDUE 138KV CKT 1 #1	6/1/2013	6/1/2013		
	DIANA - PERDUE 138KV CKT 1 #2	6/1/2013	6/1/2016		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586568	GRIMES - MT. ZION 138KV CKT 1	10/1/2013	6/1/2016		No	\$ 2,721,254	\$ 14,966,895
	HUNTSVILLE - LINE 558 TAP 138KV CKT 1	10/1/2013	6/1/2016		No	\$ 783,634	\$ 4,309,985
					Total	\$ 3,504,887	\$ 19,276,880

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-007

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76553455	NPPD	WR	3	2/1/2013	4/1/2025	6/1/2019	8/1/2031	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76553455	None					\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	
						Total	\$ - \$ - \$ - \$ -	

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76553455	CENTENNIAL - COWSKIN 138KV CKT 1	6/1/2014	6/1/2016		No
	Cherry Co - Gentleman 345 KV Ckt1	10/1/2012	1/1/2018		No
	Cherry Co - Holt Co 345 KV Ckt1	10/1/2012	1/1/2018		No
	Cherry Co 345 KV Terminal Upgrades	10/1/2012	1/1/2018		No
	Line - Comanche County - Medicine Lodge 345 KV dbl ckt	10/1/2012	1/1/2015		No
	Line - Hitchland - Woodward 345 KV dbl ckt OKGE	10/1/2012	7/1/2014		No
	Line - Hitchland - Woodward 345 KV dbl ckt SPS	10/1/2012	7/1/2014		No
	Line - Medicine Lodge - Wichita 345 KV dbl ckt MKEC	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Wichita 345 KV dbl ckt WERE	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Woodward 345 KV dbl Ckt MKEC	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Woodward 345 KV dbl Ckt OKGE	10/1/2012	1/1/2015		No
	Line - Spearville - Comanche County 345 KV dbl ckt MKEC	10/1/2012	1/1/2015		No
	Line - Spearville - Comanche County 345 KV dbl ckt SUNC	10/1/2012	1/1/2015		No
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	10/1/2012	6/1/2015		No
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014		No
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014		No
	XFR - Medicine Lodge 345/138 KV	10/1/2012	1/1/2015		No

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76553455	SHELDON - SW7TH & PLEASANT HILL 115KV CKT 2 LES	12/31/2012	6/1/2013		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76553455	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	BROKEN BOW - LOUP CITY 115KV CKT 1	10/1/2014	6/1/2016		No
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2014	6/1/2017		No
	Circle - Reno 345KV Dbl Ckt	10/1/2012	6/1/2019		No
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018		No
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		No
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		No
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		No
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		No
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		No
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		No
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		No
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2014	6/1/2017		No
	Mathewson 345 KV	6/1/2014	6/1/2017		No
	Mullergren - Circle 345KV Dbl Ckt MKEC	10/1/2012	6/1/2019		No
	Mullergren - Circle 345KV Dbl Ckt WERE	10/1/2012	6/1/2019		No
	Spearville - Mullergren 345KV Dbl Ckt	10/1/2012	6/1/2019		No
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		No
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		No
	Viola - Rose Hill 345KV CKT 1	6/1/2014	6/1/2018		No
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		No

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76553455	ALBION - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Circle - Reno 345kV Dbl CKT	10/1/2012	6/1/2019		
	Mullergruen - Circle 345kV Dbl CKT MKEC	10/1/2012	6/1/2019		
	Mullergruen - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019		
	NELIGH - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76553455	Compton Ridge 345/161 kV Transformer	6/1/2013	6/1/2018		No	0.02%	100.00%

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-012

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580367	NPPD	WR	1	5/1/2013	4/30/2025	6/1/2019	5/1/2031	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580367	None					\$ - \$ - \$ - \$ -		
						Total	\$ - \$ - \$ - \$ -	

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580367	Cherry Co - Gentleman 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co - Holt Co 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co 345 kV Terminal Upgrades	10/1/2012	1/1/2018	No	
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015	No	
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014	No	
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015	No	
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014	No	
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014	No	
	XFR - Medicine Lodge 345/138 kV	10/1/2012	1/1/2015	No	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580367	SHELDON - SW7TH & PLEASANT HILL 115KV CKT 2 LES	12/31/2012	6/1/2013		
	UNIONRG3 115.00 - CHAPMAN 115KV CKT 1	6/1/2018		6/1/2018	

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580367	BROKEN BOW - LOUP CITY 115KV CKT 1	10/1/2014	6/1/2016	No	
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2014	6/1/2017	No	
	Circle - Reno 345kV Dbl CKT	10/1/2012	6/1/2019	No	
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018	No	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 kV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345kV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345kV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345kV CKT 2 WERE	10/1/2012	6/1/2018		
	Mathewson - Tatonga 345 kV Ckt 1	6/1/2014	6/1/2017	No	
	Mathewson 345 kV	6/1/2014	6/1/2017	No	
	Mullergren - Circle 345kV Dbl Ckt MKEC	10/1/2012	6/1/2019	No	
	Mullergren - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019	No	
	Spearville - Mullergren 345kV Dbl Ckt	10/1/2012	6/1/2019	No	
	Swissvale - Wolf Creek 345kV	10/1/2012	6/1/2018		
	Turk - McNeil 345 kV AEPW	6/1/2013	6/1/2018		
	Wolf Creek - Wichita 345kV	10/1/2012	6/1/2018		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580367	ALBION - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	CIRCLE - RICE CO 230KV CKT 1	10/1/2012	11/15/2012		
	LYONS - RICE CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	Mullergren - Circle 345kv Dbl CKT MKEC	10/1/2012	6/1/2019		
	Mullergren - Circle 345kv Dbl CKT WERE	10/1/2012	6/1/2019		
	NELIGH - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	RICE CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76580367	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018			0.11%	100.00%

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGKE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kv AEPW, and McNeil 500/345kv Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-013

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580375	GRDA	WR	3	5/1/2013	5/1/2026	6/1/2018	6/1/2031	\$ 18,508	\$ -	\$ 18,508	\$ 81,052

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580375	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 8,006	\$ 2,500,000	\$ 31,368
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016			\$ 10,502	\$ 330,000	\$ 49,685
				Total		\$ 18,508	\$ 2,830,000	\$ 81,052

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580375	UNIONRG3 115.00 - CHAPMAN 115KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580375	BEAVER - EUREKA SPRINGS 161KV CKT 1 AEPW Accelerate	6/1/2013	6/1/2015		No
	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015		Yes
	GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015		Yes
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Muskogee - VBI 345 kV with 345/161 kV bus tie at VBI	6/1/2013	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		
	VBI - Arkansas Nuclear One 345KV OKGE	6/1/2013	6/1/2018		
	Viola - Rose Hill 345kV CKT 1	6/1/2014	6/1/2018		No
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580375	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
	CIRCLE - RICE, CO 230KV CKT 1	10/1/2012	11/15/2012		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE, CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	RICE, CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		
	SUB 110 - ORONOGO ICT. - SUB 167 - RIVERTON 161KV CKT 1	6/1/2011	6/1/2011		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76580375	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 45,933	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 45,204	\$ 18,000,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014		0.35%	100.00%	
	BEAVER - EUREKA SPRINGS 161KV CKT 1 SWPA	6/1/2013	6/1/2015	No	\$ -	\$ -	
	Compton Ridge - Cox Creek 345 KV	6/1/2013	6/1/2018		0.52%	100.00%	
	Compton Ridge - Osage Creek 345 KV	6/1/2013	6/1/2018		1.95%	100.00%	
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018		0.91%	100.00%	
	HUBEN 345/161KV TRANSFORMER CKT 1	6/1/2014	6/1/2014		2.91%	100.00%	
	McNeil 500/345KV	6/1/2013	6/1/2018		\$ 12,606	\$ 12,000,000	
	VBI - Arkansas Nuclear One 345kV EES	6/1/2013	6/1/2018		0.28%	100.00%	
				Total	\$ 103,743	\$ 38,000,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGK, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 KV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-014

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580381	KACY	WR	4	10/1/2013	6/1/2022	6/1/2016	2/1/2025	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580381	None					\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -
						Total	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580381	UNIONNRG3 115.00 - CHAPMAN 115KV CKT 1		6/1/2018	6/1/2018	

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580381	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580381	CIRCLE - RICE CO 230KV CKT 1	10/1/2012	11/15/2012		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE_CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	RICE_CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76580381	TOVERTON 345.00 () 345/161/13.8KV TRANSFORMER CKT 1	10/1/2012	6/1/2016	No	\$ 58,073	\$ 16,100,000	
	Brookline – Compton Ridge 345 KV	6/1/2013	6/1/2018		0.05%	100.00%	
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018		0.11%	100.00%	
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018		0.18%	100.00%	
				Total	\$ 58,073	\$ 16,100,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGK, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 KV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-015

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580392	SPA	WR	1	5/1/2013	1/1/2019	6/1/2018	2/1/2024	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580392	None					\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	
						Total	\$ - \$ - \$ - \$ -	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580392	UNIONRG3 115.00 - CHAPMAN 115KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580392	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580392	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2012	6/1/2019		
	CIRCLE - RICE_ CO 230KV CKT 1	10/1/2012	11/15/2012		
	LACYNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE_ CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	RICE_ CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76580392	BUFORO_ 5 161.00 - NORFORK 161KV CKT 1	6/1/2013	6/1/2016	No	\$ - \$ - \$ -	100.00%	100.00%
	BULL SHOALS - MIDWAY (YVEPA) 161KV CKT 1	6/1/2013	6/1/2013			0.02%	100.00%
	Compton Ridge - Cox Creek 345 KV	6/1/2013	6/1/2018			0.00%	100.00%
	Compton Ridge - Osage Creek 345 kV	6/1/2013	6/1/2018			0.03%	100.00%
	NORFORK - SOUTHLAND AECC 161KV CKT 1 SWPA	6/1/2014	6/1/2014				
	SHEELDSHEHSE	10/1/2012	10/1/2012				
				Total	\$ - \$ - \$ -		

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-016

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580395	WR	WR	5	5/1/2013	1/1/2019	6/1/2018	2/1/2024	\$ - \$	- \$	- \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580395	None					\$ - \$	- \$	-
				Total		\$ - \$	- \$	-

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580395	Cherry Co - Gentleman 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co - Holt Co 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co 345 kV Terminal Upgrades	10/1/2012	1/1/2018	No	
	IATAN - NASHUA 345KV CKT 1	6/1/2013	6/1/2015	No	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580395	UNIONRG3 115.00 - CHAPMAN 115KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580395	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018	No	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017	No	
	Iatan - Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018	No	
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018	No	
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018	No	
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018	No	
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018	No	

Planned Projects

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580395	BELL - PECK 69KV CKT 1	6/1/2014	6/1/2014	12/1/2012	
	BELL - SUMNER COUNTY NO. 3 MILLER 69KV CKT 1	6/1/2014	6/1/2014		
	CITY OF WELLINGTON - SUMNER COUNTY NO. 3 MILLER 69KV CKT 1	6/1/2014	6/1/2014		
	CITY OF WELLINGTON - SUMMER COUNTY NO. 4 ROME 69KV CKT 1	6/1/2014	6/1/2014		
	CRESWELL - SUMMER COUNTY NO. 4 ROME 69KV CKT 1	6/1/2014	6/1/2014		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580395	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	CIRCLE - RICE CO 230KV CKT 1	10/1/2012	11/15/2012		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	LACYNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	RICE_CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76580395	Brookline – Compton Ridge 345 kV	6/1/2013	6/1/2018	No	0.14%	100.00%	
	Compton Ridge – Cox Creek 345 kV	6/1/2013	6/1/2018	No	0.02%	100.00%	
	Compton Ridge – Osage Creek 345 kV	6/1/2013	6/1/2018	No	0.30%	100.00%	
	Compton Ridge 345/161 kV Transformer	6/1/2013	6/1/2018	No	0.87%	100.00%	
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018	No	0.79%	100.00%	
				Total	\$	- \$	-

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Tranformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-017

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580515	SPA	WR	1	1/1/2014	1/1/2019	6/1/2018	6/1/2023	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580515	None					\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	
						Total	\$ - \$ - \$ - \$ -	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580515	UNIONRG3 115.00 - CHAPMAN 115KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580515	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 kV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345kV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 kV AEPW	6/1/2013	6/1/2018		
	Viola - Rose Hill 345kV CKT 1	6/1/2014	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580515	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2012	6/1/2019		
	CIRCLE - RICE CO 230KV CKT 1	10/1/2012	11/15/2012		
	LACYNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	Mathewson 345 kV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	RICE CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76580515	BUFORO - 5 161.00 - NORFORK 161KV CKT 1	6/1/2013	6/1/2016	No	\$ - \$ - \$ -	0.01% 100.00%	
	Compton Ridge - Cox Creek 345 KV	6/1/2013	6/1/2018			0.00% 100.00%	
	Compton Ridge - Osage Creek 345 KV	6/1/2013	6/1/2018				
	NORFORK - SOUTHLAND AECC 161KV CKT 1 SWPA	6/1/2014	6/1/2014		\$ - \$ - \$ -		
	SHEELDSHEHSE	10/1/2012	10/1/2012			0.02% 100.00%	
				Total	\$ - \$ - \$ -		

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OGKE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-018

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76580552	NPPD	WR	1	1/1/2014	5/1/2025	6/1/2019	10/1/2030	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76580552	None					\$ - \$ - \$ - \$ -		
						Total	\$ - \$ - \$ - \$ -	

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580552	Cherry Co - Gentleman 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co - Holt Co 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co 345 kV Terminal Upgrades	10/1/2012	1/1/2018	No	
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015	No	
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014	No	
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015	No	
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014	No	
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014	No	
	XFR - Medicine Lodge 345/138 kV	10/1/2012	1/1/2015	No	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580552	SHELDON - SW7TH & PLEASANT HILL 115KV CKT 2 LES	12/31/2012	6/1/2013		
	UNIONRG3 115.00 - CHAPMAN 115KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580552	BROKEN BOW - LOUP CITY 115KV CKT 1	10/1/2014	6/1/2016	No	
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2014	6/1/2017	No	
	Circle - Reno 345kV Dbl CKT	10/1/2012	6/1/2019	No	
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018	No	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 kV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345kV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345kV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345kV CKT 2 WERE	10/1/2012	6/1/2018		
	Mathewson - Tatonga 345 kV Ckt 1	6/1/2014	6/1/2017	No	
	Mathewson 345 kV	6/1/2014	6/1/2017	No	
	Mullergrn - Circle 345kV Dbl Ckt MKEC	10/1/2012	6/1/2019	No	
	Mullergrn - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019	No	
	Spearville - Mullergrn 345kV Dbl Ckt	10/1/2012	6/1/2019	No	
	Swissvale - Wolf Creek 345kV	10/1/2012	6/1/2018		
	Turk - McNeil 345 kV AEPW	6/1/2013	6/1/2018		
	Wolf Creek - Wichita 345kV	10/1/2012	6/1/2018		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76580552	ALBION - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	CIRCLE - RICE CO 230KV CKT 1	10/1/2012	11/15/2012		
	LYONS - RICE CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	Mullergren - Circle 345kv Dbl CKT MKEC	10/1/2012	6/1/2019		
	Mullergren - Circle 345kv Dbl CKT WERE	10/1/2012	6/1/2019		
	NELIGH - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	RICE CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76580552	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018			0.04%	100.00%

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGKE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kv AEPW, and McNeil 500/345kv Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-019

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispach	Deferred Stop Date Without Redispach	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76582326	WR	WR	41	5/1/2013	5/1/2026	6/1/2018	6/1/2031	\$ - \$	- \$	\$ - \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispach Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76582326	None					\$ - \$	- \$	-
						Total	\$ - \$	- \$ -

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispach Available
76582326	UNIONNRG3 115.00 - CHAPMAN 115KV CKT 1			6/1/2018	6/1/2018
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		No
	Iatan - Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018		No
	Iatan - Jeffrey Energy Center 345 kV WERE	6/1/2013	6/1/2018		No

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OGKE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-022

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispach	Deferred Stop Date Without Redispach	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76583607	WR	WR	21	1/1/2014	5/1/2026			\$ - \$	- \$	\$ - \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispach Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583607	None				\$	- \$	- \$	-
				Total	\$	- \$	- \$	-

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-023

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76583617	GRDA	WR	5	1/1/2014	5/1/2026	6/1/2018	10/1/2030	\$ 7,118	\$ -	\$ 7,118	\$ 30,419
									\$ 7,118	\$ -	\$ 7,118	\$ 30,419

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583617	FT. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 3,079	\$ 2,500,000	\$ 11,768
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016			\$ 4,039	\$ 330,000	\$ 18,651
				Total		\$ 7,118	\$ 2,830,000	\$ 30,419

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583617	UNIONNRG3 115.00 - CHAPMAN 115KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583617	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1 AEPW	6/1/2014	6/1/2015		
	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015		
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Muskogee - VBI 345 kV with 345/161 kV bus tie at VBI	6/1/2013	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		
	VBI - Arkansas Nuclear One 345kV OKGE	6/1/2013	6/1/2018		
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018	No	
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583617	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 kv Ckt 1	6/1/2012	6/1/2019		
	CIRCLE - RICE CO 230KV CKT 1	10/1/2012	11/15/2012		
	LACYNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	Mathewson - Tatonga 345 KV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	RICE CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		
	SUB 110 - ORONOOGO JCT. - SUB 167 - RIVERTON 161KV CKT 1	6/1/2011	6/1/2011		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76583617	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	6/1/2013	6/1/2016	No	\$ 17,667	\$ 8,000,000	
	7JASPER 345.00 - MORGAN 345KV CKT 1	6/1/2014	6/1/2016	No	\$ 17,386	\$ 18,000,000	
	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014		0.13%	100.00%	
	Compton Ridge - Cox Creek 345 kV	6/1/2013	6/1/2018		0.20%	100.00%	
	Compton Ridge - Osage Creek 345 kV	6/1/2013	6/1/2018		0.75%	100.00%	
	Compton Ridge 345/161 kV Transformer	6/1/2013	6/1/2018		0.35%	100.00%	
	HUBEN 345/161KV TRANSFORMER CKT 1	6/1/2014	6/1/2014		1.12%	100.00%	
	McNeil 500/345kV	6/1/2013	6/1/2018		\$ 4,848	\$ 12,000,000	
	VBI - Arkansas Nuclear One 345kV EES	6/1/2013	6/1/2018	Total	\$ 39,901	\$ 38,000,000	

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and TP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-024

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76583629	WR	WR	4	1/1/2014	1/1/2019	6/1/2018	6/1/2023	\$ - \$	- \$	- \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76583629	None					\$ - \$	- \$	-
						Total	\$ - \$	- \$ -

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583629	Cherry Co - Gentleman 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co - Holt Co 345 kV Ckt1	10/1/2012	1/1/2018	No	
	Cherry Co 345 kV Terminal Upgrades	10/1/2012	1/1/2018	No	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583629	UNIONNRG3 115.00 - CHAPMAN 115KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583629	BENTON - WICHITA 345KV CKT 1	6/1/2018	6/1/2018	6/1/2015	
	CHISHOLM - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		
	CHISHOLM - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	6/1/2014	6/1/2016		
	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	6/1/2014	6/1/2016		
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018	No	
	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	6/1/2013	6/1/2017		
	Iatan - Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345kV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 KV AEPW	6/1/2013	6/1/2018		
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Planned Projects

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583629	BELL - PECK 69KV CKT 1	6/1/2014	6/1/2014	12/1/2012	
	BELL - SUMNER COUNTY NO. 3 MILLER 69KV CKT 1	6/1/2014	6/1/2014		
	CITY OF WELLINGTON - SUMNER COUNTY NO. 3 MILLER 69KV CKT 1	6/1/2014	6/1/2014		
	CITY OF WELLINGTON - SUMNER COUNTY NO. 4 ROME 69KV CKT 1	6/1/2014	6/1/2014		
	CRESWELL - SUMNER COUNTY NO. 4 ROME 69KV CKT 1	6/1/2014	6/1/2014		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76583629	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	CIRCLE - RICE, CO 230KV CKT 1	10/1/2012	11/15/2012		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	LYONS - RICE, CO 115KV CKT 1	10/1/2012	4/1/2013		
	LYONS - WHEATLAND 115KV CKT 1 #1	10/1/2012	7/15/2013		
	LYONS - WHEATLAND 115KV CKT 1 #2	10/1/2012	7/15/2013		
	RICE_CO 230/115KV TRANSFORMER CKT 1	10/1/2012	11/15/2012		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76583629	Brookline – Compton Ridge 345 kV	6/1/2013	6/1/2018			0.03%	100.00%
	Compton Ridge – Cox Creek 345 kV	6/1/2013	6/1/2018			0.00%	100.00%
	Compton Ridge – Osage Creek 345 kV	6/1/2013	6/1/2018			0.06%	100.00%
	Compton Ridge 345/161 kV Transformer	6/1/2013	6/1/2018			0.18%	100.00%
	Lacygne - Morgan 345KV AECI	10/1/2012	6/1/2018			0.17%	100.00%
				Total	\$	-	-

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Tranformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-048

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76586675	KCPL	WR	15	6/1/2013	6/1/2023	6/1/2019	6/1/2029	\$ - \$ - \$	- \$ - \$	- \$ - \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586675	None					\$ - \$ - \$	- \$ - \$	-
						Total	\$ - \$ - \$	-

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586675	CENTENNIAL - COWSKIN 138KV CKT 1	6/1/2014	6/1/2016		No
	JATAN - NASHUA 345KV CKT 1	6/1/2013	6/1/2015		No
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015		No
	Line - Hitchcland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014		No
	Line - Hitchcland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014		No
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015		No
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015		No
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		No
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015		No
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	10/1/2012	6/1/2015		No
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014		No
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014		No
	XFR - Medicine Lodge 345/138 KV	10/1/2012	1/1/2015		No

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586675	BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #1	6/1/2014	6/1/2014		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586675	SBUTLER - ADRIAN 161KV CKT 1		6/1/2018	6/1/2018	
	ADRIAN - ARCHIE 161KV CKT 1		6/1/2018	6/1/2018	
BENTON - WICHITA 345KV CKT 1		6/1/2018	6/1/2018	6/1/2015	
BIRMINGHAM - HAWTHORN 161KV CKT 1		6/1/2014	6/1/2015	6/1/2015	
BIRMINGHAM - LIBERTY SOUTH 161KV CKT 1 KACP		6/1/2014	6/1/2015	6/1/2015	
BIRMINGHAM - LIBERTY SOUTH 161KV CKT 1 MIPU		6/1/2014	6/1/2015	6/1/2015	
BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #2		6/1/2014	6/1/2016	No	
BLUE SPRING SOUTH - PRAIRIE LEE 161KV CKT 1 #2		6/1/2014	6/1/2016	No	
BLUE SPRINGS EAST - BLUE SPRINGS WEST 161KV CKT 1		6/1/2014	6/1/2016	No	
BLUE SPRINGS EAST - GRAIN VALLEY 161KV CKT 1		6/1/2014	6/1/2016	No	
CHISHOLM - MAIZE 138KV CKT 1 #1		6/1/2014	6/1/2016		
CHISHOLM - MAIZE 138KV CKT 1 #2		6/1/2014	6/1/2016		
Cimarron - Mathewson 345 KV Ckt 1		6/1/2014	6/1/2017	No	
Circle - Reno 345KV Dbl Ckt		10/1/2012	6/1/2019	No	
CLEARWATER - MILAN TAP 138KV CKT 1 MKEC		10/1/2012	6/1/2015	No	
CLEARWATER - MILAN TAP 138KV CKT 1 WERE		10/1/2012	6/1/2015	No	
EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1		6/1/2014	6/1/2016		
EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2		6/1/2014	6/1/2016		
HARPER - MILAN TAP 138KV CKT 1 #1		10/1/2013	6/1/2014		
HARPER - MILAN TAP 138KV CKT 1 #2		10/1/2012	6/1/2015	No	
HOYT - JEFFREY ENERGY CENTER 345KV CKT 1		6/1/2013	6/1/2017	No	
Iatan - Jeffrey Energy Center 345 KV KACP		6/1/2013	6/1/2018	No	
Iatan - Jeffrey Energy Center 345 KV WERE		6/1/2013	6/1/2018	No	
Iatan - Swissvale 345KV KACP		6/1/2013	6/1/2018	No	
Iatan - Swissvale 345KV WERE		6/1/2014	6/1/2018	No	
Lacygne - Morgan 345KV KACP		10/1/2012	6/1/2018	No	
Lacygne - Wolf Creek 345KV CKT 2 KACP		10/1/2012	6/1/2018	No	
Lacygne - Wolf Creek 345KV CKT 2 WERE		10/1/2012	6/1/2018	No	
Mathewson Tatonga 345 KV Ckt 1		6/1/2014	6/1/2017	No	
Mathewson 345 KV		6/1/2014	6/1/2017	No	
Mullergeren - Circle 345kV Dbl CKT MKEC		10/1/2012	6/1/2019	No	
Mullergeren - Circle 345kV Dbl CKT WERE		10/1/2012	6/1/2019	No	
Spearville - Mullergeren 345kV Dbl CKT		10/1/2012	6/1/2019	No	
Swissvale - Wolf Creek 345KV		10/1/2012	6/1/2018	No	
Turk - McNeil 345 KV AEPW		6/1/2013	6/1/2018	No	
Viola - Rose Hill 345kV CKT 1		6/1/2014	6/1/2018	No	
Wolf Creek - Wichita 345KV		10/1/2012	6/1/2018	No	

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586675	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	FLATRDG3 138.00 - HARPER 138KV CKT 1	12/1/2009	6/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586675	SOVERTON 161.00 - SOVERTON 2 161.00 161KV CKT 1	6/1/2014	6/1/2014			1.64%	100.00%
	70VERTON 345.00 (I) 345/161/13.8KV TRANSFORMER CKT 1	10/1/2012	6/1/2016			\$ 242,820	\$ 16,100,000
	Brookline – Compton Ridge 345 kV	6/1/2013	6/1/2018	No		0.27%	100.00%
	Compton Ridge – Cox Creek 345 kV	6/1/2013	6/1/2018	No		0.05%	100.00%
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	No		0.17%	100.00%
	Lacygne - Morgan 345kV AECI	10/1/2012	6/1/2018	No		0.52%	100.00%
	NORTH WARSAW - TRUMAN 161KV CKT 1 SWPA	6/1/2014	6/1/2014			\$ -	\$ -
				Total		\$ 242,820	\$ 16,100,000

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-049

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispach	Deferred Stop Date Without Redispach	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76586679	WR	WR	15	6/1/2013	6/1/2013			\$ - \$	- \$	\$ - \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispach Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586679	None				\$	- \$	- \$	-

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
KMEA 2012-AG1-051

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	76586961	NPPD	WR	1	6/1/2013	5/1/2013			\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -		

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586961	None					\$ - \$ - \$ - \$ -		
						Total	\$ - \$ - \$ - \$ -	

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586961	Cherry Co - Gentleman 345 kV Ckt1	10/1/2012	1/1/2018		
	Cherry Co - Holt Co 345 kV Ckt1	10/1/2012	1/1/2018		
	Cherry Co 345 kV Terminal Upgrades	10/1/2012	1/1/2018		
	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015		
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014		
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015		
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015		
	MOUNDRIDGE 138/115KV TRANSFORMER CKT 2	10/1/2012	6/1/2015		
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014		
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014		
	XFR - Medicine Lodge 345/138 kV	10/1/2012	1/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586961	SHELTON - SW7TH & PLEASANT HILL 115KV CKT 2 LES	12/31/2012	6/1/2013		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586961	Circle - Reno 345kV Dbl CKT	10/1/2012	6/1/2019		
	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC	10/1/2012	6/1/2015		
	CLEARWATER - MILAN TAP 138KV CKT 1 WERE	10/1/2012	6/1/2015		
	GRAND ISLAND - SWEETWATER 345KV CKT 2	10/1/2012	6/1/2018		
	HARPER - MILAN TAP 138KV CKT 1 #2	10/1/2012	6/1/2015		
	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	10/1/2012	6/1/2015		
	HAYS PLANT - VINE STREET 115KV CKT 1	10/1/2012	6/1/2016		
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Mullergrn - Circle 345kV Dbl CKT MKEC	10/1/2012	6/1/2019		
	Mullergrn - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019		
	Spearerville - Mullergrn 345kV Dbl CKT	10/1/2012	6/1/2019		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586961	ALBION - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006		
	NELIGH - PETERSBURG 115KV CKT 1	1/1/2013	1/1/2013		

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
NTEC 2012-AG1-045

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
NTEC	76586584	CSWS	CSWS	8	1/1/2013	1/1/2015	6/1/2016	6/1/2018	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586584	None					\$ - \$ - \$ - \$ -		
						Total	\$ - \$ - \$ - \$ -	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586584	DIANA - PERDUE 138KV CKT 1 #1	6/1/2013	6/1/2013		
	DIANA - PERDUE 138KV CKT 1 #2	6/1/2013	6/1/2016		Yes

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586584	GRIMES - MT. ZION 138KV CKT 1	10/1/2013	6/1/2016		No	\$ 5,442,507	\$ 14,966,895
	HUNTSVILLE - LINE 558 TAP 138KV CKT 1	10/1/2013	6/1/2016		No	\$ 1,567,267	\$ 4,309,985
					Total	\$ 7,009,775	\$ 19,276,880

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
OGE 2012-AG1-008

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
OGE	76571379	OKGE	OKGE	60	12/19/2012	12/19/2032	6/1/2019	6/1/2039	\$ 2,160,281	\$ -	\$ 2,160,281	\$ 7,904,402

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76571379	HEFNER - TULSA 138KV CKT 1	6/1/2018	6/1/2018			\$ 1,000,400	\$ -	\$ 1,000,400	\$ 1,000,400	\$ 3,717,071
	KINZE - MCELROY 138KV CKT 1	6/1/2018	6/1/2018			\$ 1,159,881	\$ -	\$ 1,159,881	\$ 1,800,000	\$ 4,187,331
						Total	\$ 2,160,281	\$ -	\$ 2,160,281	\$ 2,800,400

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76571379	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015		
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014		
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014		
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015		
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015		
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015		
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015		
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014		
	TUCO - WOODWARD 345 KV CKT 1 SPS	10/1/2012	6/1/2014		
	XFR - Medicine Lodge 345/138 kV	10/1/2012	1/1/2015		

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76571379	BLUEBELL - PRATTVILLE 138KV CKT 1 AEPW	6/1/2018	6/1/2018		
	DIVISION AVE - LAKESIDE 138KV CKT 1	6/1/2018	6/1/2018		
	EL RENO - SERVICE PL EL RENO 69KV CKT 1	6/1/2014	6/1/2015	No	

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76571379	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015		No
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2014	6/1/2017		
	Circle - Reno 345kV Dbl Ckt	10/1/2012	6/1/2019		
	Mathewson - Tatonga 345 kV Ckt 1	6/1/2014	6/1/2017		
	Mathewson 345 kV	6/1/2014	6/1/2017		
	Mullergren - Circle 345kV Dbl Ckt MKEC	10/1/2012	6/1/2019		
	Mullergren - Circle 345kV dbl Ckt WERE	10/1/2012	6/1/2019		
	NORTHWEST 345/138/13.8KV TRANSFORMER CKT 3 Accelerated	12/19/2012	6/1/2015	No	
	Spearville - Mullergren 345kV Dbl Ckt	10/1/2012	6/1/2019		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76571379	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2012	6/1/2019		
	Mathewson - Tatonga 345 kV Ckt 1	6/1/2012	6/1/2019		
	Mathewson 345 kV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76571379	SHEELDSHEHSE	10/1/2012	10/1/2012			0.49%	100.00%

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
OPPM 2012-AG1-011

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
OPPM	76575755	OPPD	OPPD	53	12/31/2012	12/31/2037	6/1/2016	6/1/2041	\$ - \$	- \$	- \$	-

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76575755	None					\$ - \$	- \$	-
						Total	\$ - \$	- \$ -

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76575755	SHELDON - SW7TH & PLEASANT HILL 115KV CKT 2 LES	12/31/2012	6/1/2013		Yes
	SUB 906 NORTH - SUB 928 69KV CKT 1	6/1/2021	6/1/2021		
	SUB 921 - SUB 942 69KV CKT 1	6/1/2018	6/1/2018		

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76575755	HYDROCARBON TAP - SUB 974 69KV CKT 1	10/1/2014	6/1/2016		
	NEB CITY U SYR SUB - SUB 970 69KV CKT 1	10/1/2013	6/1/2016		Yes
	SUB 906 SOUTH - SUB 924 69KV CKT 1	6/1/2018	6/1/2018	6/1/2016	
	SUB 912 - SUB 924 69KV CKT 1	6/1/2018	6/1/2018	6/1/2016	
	SUB 967 - SUB 968 69KV CKT 1	12/31/2012	6/1/2016		Yes
	SUB 968 - SUB 969 69KV CKT 1	12/31/2012	6/1/2016		Yes
	SUB 969 - SUB 974 69KV CKT 1	12/31/2012	6/1/2016		Yes

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76575755	HYDROCARBON TAP - SUB 974 69KV CKT 1	10/1/2014	6/1/2016		
	NEB CITY U SYR SUB - SUB 970 69KV CKT 1	10/1/2013	6/1/2016		
	SUB 906 SOUTH - SUB 924 69KV CKT 1	6/1/2018	6/1/2016		
	SUB 912 - SUB 924 69KV CKT 1	6/1/2018	6/1/2016		
	SUB 967 - SUB 968 69KV CKT 1	10/1/2012	6/1/2016		
	SUB 968 - SUB 969 69KV CKT 1	10/1/2012	6/1/2016		
	SUB 969 - SUB 974 69KV CKT 1	10/1/2012	6/1/2016		

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
PSCM 2012-AG1-021

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
PSCM	76582673	SPS	LAM345	208	3/1/2013	3/1/2018	6/1/2018	6/1/2023	\$ - \$ 23,599,680	\$ 424,681	\$ 852,690	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76582673	LUBBOCK SOUTH INTERCHANGE 230/115/13.2KV TRANSFORMER CKT 2 Accelerate	6/1/2014	6/1/2016	No	\$ 424,681	\$ 424,681	\$ 852,690	
				Total	\$ 424,681	\$ 424,681	\$ 852,690	

Expansion Plan - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76582673	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	10/1/2012	1/1/2015	No	
	Line - Hitchland - Woodward 345 kV dbl ckt OKGE	10/1/2012	7/1/2014	No	
	Line - Hitchland - Woodward 345 kV dbl ckt SPS	10/1/2012	7/1/2014	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Wichita 345 kV dbl ckt WERE	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Medicine Lodge - Woodward 345 kV dbl Ckt OKGE	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt MKEC	10/1/2012	1/1/2015	No	
	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	10/1/2012	1/1/2015	No	
	TUCO - WOODWARD 345 KV CKT 1 OKGE	10/1/2012	6/1/2014	No	
	TUCO - WOODWARD 345 KV CKT 1 SPA	10/1/2012	6/1/2014	No	
	XFR - Medicine Lodge 345/138 kV	10/1/2012	1/1/2015	No	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76582673	HOBBS INTERCHANGE 230/115KV TRANSFORMER CKT 2	6/1/2018	6/1/2018		
	PLANT X STATION (WH ALM20171) 230/115/13.2KV TRANSFORMER CKT 1	6/1/2014	6/1/2015	No	

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76582673	Iatan - Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018	No	
	Iatan - Jeffrey Energy Center 345 kV WERE	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345kV KACP	6/1/2013	6/1/2018	No	
	Iatan - Swissvale 345kV WERE	6/1/2014	6/1/2018	No	
	Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2	6/1/2018	6/1/2018		
	Lacygne - Morgan 345kV KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345kV CKT 2 KACP	10/1/2012	6/1/2018	No	
	Lacygne - Wolf Creek 345kV CKT 2 WERE	10/1/2012	6/1/2018	No	
	Swissvale - Wolf Creek 345kV	10/1/2012	6/1/2018	No	
	Turk - McNeil 345 kV AEPW	6/1/2013	6/1/2018	No	
	Viola - Rose Hill 345kv CKT 1	6/1/2014	6/1/2018	No	
	Wolf Creek - Wichita 345kV	10/1/2012	6/1/2018	No	

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76582673	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Circle - Reno 345kV Dbl CKT	10/1/2012	6/1/2019		
	Mullergren - Circle 345kV Dbl CKT MKEC	10/1/2012	6/1/2019		
	Mullergren - Circle 345kV Dbl CKT WERE	10/1/2012	6/1/2019		
	Spearville - Mullergren 345kV Dbl CKT	10/1/2012	6/1/2019		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76582673	Compton Ridge – Cox Creek 345 kV	6/1/2013	6/1/2018	No		1.11%	100.00%
	Compton Ridge – Osage Creek 345 kV	6/1/2013	6/1/2018	No		5.55%	100.00%
				Total	\$ -	\$ -	-

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer **Study Number**
TEXL 2012-AG1-047

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
TEXL	76586594	CSWS	CSWS	20	1/1/2013	1/1/2015	6/1/2016	6/1/2018	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	\$ - \$ - \$ - \$ -	

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76586594	None					\$ - \$ - \$ - \$ -		
						Total	\$ - \$ - \$ - \$ -	

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76586594	DIANA - PERDUE 138KV CKT 1 #1	6/1/2013	6/1/2013		
	DIANA - PERDUE 138KV CKT 1 #2	6/1/2013	6/1/2016		Yes

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76586594	GRIMES - MT. ZION 138KV CKT 1	10/1/2013	6/1/2016		No	\$ 6,803,134	\$ 14,966,895
	HUNTSVILLE - LINE 558 TAP 138KV CKT 1	10/1/2013	6/1/2016		No	\$ 1,959,084	\$ 4,309,985
					Total	\$ 8,762,218	\$ 19,276,880

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer WFEC
Study Number 2012-AG1-004

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WFEC	76548687	CSWS	WFEC	160	6/1/2014	12/31/2035	6/1/2018	12/1/2039	\$ 1,279,533	\$ -	\$ 1,279,533	\$ 4,929,606
									\$ 1,279,533	\$ -	\$ 1,279,533	\$ 4,929,606

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76548687	ENOS 138KV Capacitor	6/1/2014	6/1/2016	No	\$ 555,351	\$ 972,000	\$ 1,585,664	
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017	Yes	\$ 628,857	\$ 14,500,000	\$ 2,934,007	
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018		\$ 79,339	\$ 2,500,000	\$ 346,104	
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016	No	\$ 8,175	\$ 330,000	\$ 43,030	
	WESTMOORE 138KV Accelerate	6/1/2014	6/1/2016	No	\$ 7,811	\$ 13,677	\$ 20,801	
				Total	\$ 1,279,533	\$ 18,315,677	\$ 4,929,606	

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548687	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015		Yes
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015		Yes
	GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015		Yes
latan	Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018		
latan	Jeffrey Energy Center 345 kV WERE	6/1/2013	6/1/2018		
latan	Swissvale 345kV KACP	6/1/2013	6/1/2018		
latan	Swissvale 345kV WERE	6/1/2014	6/1/2018		
Lacygne	Morgan 345KV KACP	10/1/2012	6/1/2018		
Lacygne	Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
Lacygne	Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
Muskogee	VBI 345 kV with 345/161 kV bus tie at VBI	6/1/2013	6/1/2018		Yes
Swissvale	Wolf Creek 345KV	10/1/2012	6/1/2018		
Turk	McNeil 345 KV AEPW	6/1/2013	6/1/2018		Yes
VBI	Arkansas Nuclear One 345KV OKGE	6/1/2013	6/1/2018		Yes
Wolf Creek	Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548687	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2012	6/1/2019		
	G03-05T 138.00 - PARADISE 138KV CKT 1	6/1/2010	6/1/2013		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1	7/1/2012	7/1/2012		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345KV CKT 1	6/1/2014	6/1/2018		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 2	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76548687	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014			3.57%	100.00%
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018	Yes		\$ 416,035	\$ 12,000,000
	Compton Ridge - Cox Creek 345 KV	6/1/2013	6/1/2018	Yes		3.44%	100.00%
	Compton Ridge - Osage Creek 345 KV	6/1/2013	6/1/2018	Yes		8.40%	100.00%
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	Yes		2.01%	100.00%
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018	Yes		5.13%	100.00%
	GORE - SALLISAW 161KV CKT 1	6/1/2013	6/1/2016	Yes		\$ 1,304,505	\$ 9,000,000
	SHEELEDSEHESE	10/1/2012	10/1/2012			2.98%	100.00%
	VBI - Arkansas Nuclear One 345kV EES	6/1/2013	6/1/2018	Yes		3.45%	100.00%
				Total		\$ 1,720,540	\$ 21,000,000

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and TP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer WFEC
Study Number 2012-AG1-005

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WFEC	76548692	CSWS	WFEC	90	6/1/2017	12/31/2035	6/1/2018	12/1/2036	\$ 719,737	\$ -	\$ 719,737	\$ 2,744,659

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76548692	ENOS 138KV Capacitor	6/1/2014	6/1/2016			\$ 312,385	\$ 972,000	\$ 874,268
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017			\$ 353,732	\$ 14,500,000	\$ 1,641,162
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 44,628	\$ 2,500,000	\$ 193,885
	LINDSAY WATER 69KV Capacitor Bank	6/1/2014	6/1/2016			\$ 4,598	\$ 330,000	\$ 23,875
	WESTMOORE 138KV Accelerate	6/1/2014	6/1/2016			\$ 4,394	\$ 13,677	\$ 11,470
				Total		\$ 719,737	\$ 18,315,677	\$ 2,744,659

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548692	CIMARRON - DRAPER LAKE 345KV CKT 1	6/1/2014	6/1/2015		
	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015		
	GRDAI - SILOAM SPRINGS TAP 345KV CKT 1 Accelerate	6/1/2014	6/1/2015		
latan	Jeffrey Energy Center 345 kV KACP	6/1/2013	6/1/2018		
latan	Jeffrey Energy Center 345 kV WERE	6/1/2013	6/1/2018		
latan	Swissvale 345kV KACP	6/1/2013	6/1/2018		
latan	Swissvale 345kV WERE	6/1/2014	6/1/2018		
Lacygne	Morgan 345KV KACP	10/1/2012	6/1/2018		
Lacygne	Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
Lacygne	Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
Muskogee	VBI 345 kV with 345/161 kV bus tie at VBI	6/1/2013	6/1/2018	Yes	
Swissvale	Wolf Creek 345KV	10/1/2012	6/1/2018		
Turk	McNeil 345 KV AEPW	6/1/2013	6/1/2018	Yes	
VBI	Arkansas Nuclear One 345KV OKGE	6/1/2013	6/1/2018	Yes	
Wolf Creek	Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548692	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 kV Ckt 1	6/1/2012	6/1/2019		
	G03-05T 138.00 - PARADISE 138KV CKT 1	6/1/2010	6/1/2013		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1	7/1/2012	7/1/2012		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	NORTHWEST - TATONGA 345KV CKT 1	1/1/2010	1/1/2010		
	TATONGA - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010		
	Viola - Rose Hill 345KV CKT 1	6/1/2014	6/1/2018		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD - WOODWARD EHV 138KV CKT 2	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76548692	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014			2.01%	100.00%
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018	Yes		\$ 234,019	\$ 12,000,000
	Compton Ridge - Cox Creek 345 KV	6/1/2013	6/1/2018	Yes		1.93%	100.00%
	Compton Ridge - Osage Creek 345 KV	6/1/2013	6/1/2018	Yes		4.73%	100.00%
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018	Yes		1.13%	100.00%
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018	Yes		2.89%	100.00%
	GORE - SALLISAW 161KV CKT 1	6/1/2013	6/1/2016			\$ 733,784	\$ 9,000,000
	SHEELEDSEHESE	10/1/2012	10/1/2012			1.68%	100.00%
	VBI - Arkansas Nuclear One 345kV EES	6/1/2013	6/1/2018	Yes		1.94%	100.00%
				Total		\$ 967,803	\$ 21,000,000

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kV OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and TP10 projects conditioned on completion of the NTC business practices.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Customer WFEC
Study Number 2012-AG1-006

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WFEC	76548702	CSWS	WFEC	30	6/1/2019	12/31/2035	6/1/2019	12/1/2035	\$ 244,812	\$ -	\$ 244,812	\$ 1,030,514
									\$ 244,812	\$ -	\$ 244,812	\$ 1,030,514

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
76548702	ENOS 138KV Capacitor	6/1/2014	6/1/2016			\$ 104,264	\$ 972,000	\$ 309,876
	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	6/1/2013	6/1/2017			\$ 124,200	\$ 14,500,000	\$ 644,392
	Ft. SMITH 500 KV CAPACITOR	6/1/2018	6/1/2018			\$ 14,876	\$ 2,500,000	\$ 72,166
	WESTMOORE 138KV Accelerate	6/1/2014	6/1/2016			\$ 1,472	\$ 13,677	\$ 4,080
				Total		\$ 244,812	\$ 17,985,677	\$ 1,030,514

Construction Pending - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548702	FT SMITH - MUSKOGEE 345KV CKT 1	6/1/2014	6/1/2015		
	Iatan - Jeffrey Energy Center 345 KV KACP	6/1/2013	6/1/2018		
	Iatan - Jeffrey Energy Center 345 KV WERE	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV KACP	6/1/2013	6/1/2018		
	Iatan - Swissvale 345KV WERE	6/1/2014	6/1/2018		
	Lacygne - Morgan 345KV KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 KACP	10/1/2012	6/1/2018		
	Lacygne - Wolf Creek 345KV CKT 2 WERE	10/1/2012	6/1/2018		
	Muskogee - VBI 345 kV with 345/161 kV bus tie at VBI	6/1/2013	6/1/2018		
	Swissvale - Wolf Creek 345KV	10/1/2012	6/1/2018		
	Turk - McNeil 345 kV AEPW	6/1/2013	6/1/2018		
	VBI - Arkansas Nuclear One 345KV OKGE	6/1/2013	6/1/2018		
	Wolf Creek - Wichita 345KV	10/1/2012	6/1/2018		

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available
76548702	BENTON - WICHITA 345KV CKT 1	6/1/2014	6/1/2015		
	Cimarron - Mathewson 345 KV Ckt 1	6/1/2012	6/1/2019		
	G03-05T 138.00 - PARADISE 138KV CKT 1	6/1/2010	6/1/2013		
	HUGO POWER PLANT - VALLIANT 345 KV AEPW	7/1/2012	7/1/2012		
	HUGO POWER PLANT - VALLIANT 345KV CKT 1 WFEC	7/1/2012	7/1/2012		
	HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1	7/1/2012	7/1/2012		
	Mathewson 345 KV	6/1/2012	6/1/2019		
	Viola - Rose Hill 345KV CKT 1	6/1/2014	6/1/2018		
	WOODWARD - WOODWARD EHV 138KV CKT 1	1/1/2010	1/1/2010		
	WOODWARD 345/138KV TRANSFORMER CKT 1	1/1/2010	1/1/2010		

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
76548702	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	6/1/2014	6/1/2014			0.68%	100.00%
	Arkansas Nuclear One 500/345 Transformer	6/1/2013	6/1/2018			\$ 78,006	\$ 12,000,000
	Compton Ridge - Cox Creek 345 KV	6/1/2013	6/1/2018			0.64%	100.00%
	Compton Ridge - Osage Creek 345 KV	6/1/2013	6/1/2018			1.58%	100.00%
	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	6/1/2013	6/1/2018			0.38%	100.00%
	Compton Ridge 345/161 KV Transformer	6/1/2013	6/1/2018			0.96%	100.00%
	GORE - SALLISAW 161KV CKT 1	6/1/2013	6/1/2016			\$ 244,917	\$ 9,000,000
	VBI - Arkansas Nuclear One 345KV EES	6/1/2013	6/1/2018			0.65%	100.00%
				Total		\$ 322,923	\$ 21,000,000

*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

*Credits may be required for applicable generation interconnection network upgrades.

*VBI - Arkansas Nuclear One 345kv OKGE, Arkansas Nuclear One 500/345 Transformer, Turk - McNeil 345 kV AEPW, and McNeil 500/345kV Network Upgrades proposed to mitigate violation of Contract Path Limit of 5180 MW from SPP to Entergy and other SPP thermal overloads and voltage violations.

*Includes ITPNT and ITP10 projects conditioned on completion of the NTC business practices.

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
AEPW	BETHEL - BROKEN BOW 138KV CKT 1	Rebuild 9.19 miles of 3/0 Copperweld with 795 ACSR	10/1/2014	6/1/2016	\$ 9,190,000
AEPW	BETHEL - NASHOBIA 138KV CKT 1	Rebuild 22.43 miles of 3/0 Copperweld with 795 ACSR	10/1/2014	6/1/2016	\$ 22,430,000
AEPW	CHAMBER SPRINGS - FARMINGTON AECC 161KV CKT 1 Accelerate	Rebuild 10.24 miles with 2156 ACSR, replace Chamber Springs wavetrap, replace Farmington AECC bus, and reset relays.	6/1/2014	6/1/2016	\$ 1,927,873
AEPW	CLAYTON - NASHOBIA 138KV CKT 1	Rebuild 11.57 miles of 3/0 CWC with 795 ACSR	10/1/2014	6/1/2016	\$ 11,570,000
AEPW	CLAYTON - SANDIS 138KV CKT 1	Rebuild 1.46 miles of 3/0 CWC with 795 ACSR	10/1/2014	6/1/2016	\$ 1,460,000
AEPW	ENDWELL - LONE OAK 138KV CKT 1	Rebuild 0.22 miles of 3/0 CWC with 795 ACSR. Replace jumpers @ Lone Oak	10/1/2014	6/1/2016	\$ 525,000
AEPW	ENDWELL - SANDIS 138KV CKT 1	Rebuild 1.18 miles of 3/0 CWC with 795 ACSR	10/1/2014	6/1/2016	\$ 13,800,000
AEPW	LINDSAY WATER 69KV Capacitor Bank	Install 6 MVAR capacitor bank at Lindsay Water Flood.	6/1/2014	6/1/2016	\$ 330,000
AEPW	Multi - Bananza - North Huntington 69KV Accelerate	Rebuild and reconductor 4.0 miles of 4/0 ACSR 69 KV to 1590 ACSR 161 KV from converting North Huntington to Midland REC to 161 KV. Add 161 KV terminal at North Huntington., Rebuild and reconductor Midland REC-Midland from 69 KV 4/0 ACSR to 161 KV 1590 AC	6/1/2014	6/1/2016	\$ 3,510,229
AEPW	NORTHWEST TEXARKANA - NW TEXARKANA-BANN T 138KV CKT 1	Rebuild 0.3 and Replace switch @ NORTHWEST TEXARKANA	6/1/2018	6/1/2018	\$ 605,000
AEPW	WILKES (WILKES) 345/138/13.2KV TRANSFORMER CKT 1	Replace auto	6/1/2018	6/1/2018	\$ 5,500,000
OKGE	FT SMITH (FTSMITH1) 500/345/13.8KV TRANSFORMER CKT 1	Install 2nd 500/345 KV bus tie at Ft. Smith Sub	6/1/2013	6/1/2017	\$ 14,500,000
OKGE	FL SMITH 500 KV CAPACITOR	Install 60 MVAR of 500 KV capacitors at Ft. Smith Sub plus make breaker & 1/2	6/1/2018	6/1/2018	\$ 2,500,000
OKGE	HEFFNER - TULSA 138KV CKT 1	Reconductor 1.22 miles of 138kV from HEFFNER to TULSA AVE	6/1/2018	6/1/2018	\$ 1,000,400
OKGE	HIGHWAY 59 - VBI 161KV CKT 1	Replace 600 amp switch with 1200 amp	6/1/2013	6/1/2018	\$ 80,000
OKGE	KINZIE - MCLEROY 138KV CKT 1	Reconductor 1.97 Mile Kinzie - McRoy line to 1590A552	6/1/2018	6/1/2018	\$ 1,800,000
OKGE	MUSKOGEE - ROSS LAKE 161KV CKT 1	Replace 800A wave trap at Muskogee and increase relay CTR to 1200-5.	6/1/2018	6/1/2018	\$ 350,000
OKGE	PECAN CREEK (PECANK1) 345/161/13.8KV TRANSFORMER CKT 1	Replace Transformer	6/1/2018	6/1/2018	\$ 5,500,000
SPS	LUBBOCK SOUTH INTERCHANGE 230/115/13.2KV TRANSFORMER CKT 2 Accelerate	Install a second 230/115/13.2 KV transformer at Lubbock South.	6/1/2014	6/1/2016	\$ 424,681
WFEC	ENOS 138KV Capacitor	Install 24 Mvar capacitor at ENOS 138KV	6/1/2014	6/1/2016	\$ 972,000
WFEC	WESTMOORE 138KV Accelerate	Install 32 Mvar capacitor at WESTMOORE 138KV	6/1/2014	6/1/2016	\$ 13,677

Construction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
AEPW	BEAVER - EUREKA SPRINGS 161KV CKT 1 AEPW Accelerate	Rebuild 1.25 miles of 795 ACSR with 1590 ACSR. Replace wavetrap & jumpers @ Eureka Springs	6/1/2013	6/1/2015
AEPW	ELM SPRINGS REC - TONTITOWN 161KV CKT 1	Replace Tonitown wavetrap & jumpers	6/1/2018	6/1/2018
AEPW	FLINT CREEK-SILOAM SPRINGS TAP 345KV CKT 1 AEPW	Replace Terminal Equipment	6/1/2014	6/1/2015
AEPW	JONES STATION 161KV AEPW	Build 1.46 miles of 345 KV line	6/1/2013	6/1/2018
AEPW	Waldron 69 KV Capacitor	Add 12 MVAR to Waldron 69 KV	6/1/2018	6/1/2018
EMD&	NEOSHO - SUB 452 - RIVERTON 161KV CKT 1 EMDE	Rebuild 91.4% ownership of 28.41 miles	6/1/2014	6/1/2016
EMDE	SUB 124 - AURORA H.T. 69KV	Install 3 - Stages of 22 MVAR each for total of 66 MVAR capacitor bank at Aurora Sub #124 bush 547537	6/1/2018	6/1/2018
GRDA	GRDA1 - SILOAM SPRINGS TAP 145KV CKT 1 Accelerate	Replace Terminal Equipment	6/1/2014	6/1/2015
KACP	BIRMINGHAM - HAWTHORN 161KV CKT 1	Reconductor line with 1192 ACS & upgrade terminal equipment for 1200 amps	6/1/2014	6/1/2015
KACP	BIRMINGHAM - LIBERTY SOUTH 161KV CKT 1 KACP	Reconductor 3.41 miles of 4.03 mile line with 1192 ACSS & upgrade terminal equipment for 1200 amps	6/1/2014	6/1/2015
KACP	Iatan - Jeffrey Energy Center 345 KV KACP	Build 14.2 miles of new 345 KV	6/1/2013	6/1/2018
KACP	Iatan - Swissvale 345KV ALCAP	Build approximately 32 of 64 miles of 345KV Iatan - Swissvale	6/1/2013	6/1/2018
KACP	Lacygne - Morgan 345KV KACP	Build approximately 146 miles of 345KV Lacygne - Morgan	10/1/2012	6/1/2018
KACP	Lacygne - Wolf Creek 345KV CKT 2 KACP	Build approximately 36.5 miles of 73 miles of 345KV ckt 2 Lacygne - Wolf Creek	10/1/2012	6/1/2018
MIDW	HAYS PLANT - SOUTH HAYS 115KV CKT 1 #2	Rebuild 3.25 miles	10/1/2012	6/1/2015
MIDW	HAYS PLANT - VINE STREET 115KV CKT 1	Rebuild 0.23 miles	10/1/2012	6/1/2016
MIPU	SBUTLER - ADRIAN 161KV CKT 1	Reconduct line to 1192 ACSR	6/1/2018	6/1/2018
MIPU	ADRIAN - ARCHIE 161KV CKT 1	Reconduct line to 1192 ACSR	6/1/2018	6/1/2018
MIPU	BIRMINGHAM - LIBERTY SOUTH 161KV CKT 1 MIPU	Reconductor 0.62 miles of 4.03 mile line with 1192 ACSS & upgrade terminal equipment for 1200 amps	6/1/2014	6/1/2015
MIPU	BLUE SPRING SOUTH - BLUE SPRINGS EAST 161KV CKT 1 #2	Reconductor 2.5 miles from Blue Springs South - Blue Springs East 161 KV to 795 ACSS and add 1.2 miles of 2000 Amps.	6/1/2014	6/1/2016
MIPU	BLUE SPRING SOUTH - PRAIRIE FEE 161KV CKT 1 #2	Upgrade substation equipment to 2000 Amps.	6/1/2014	6/1/2016
MIPU	BLUE SPRINGS EAST - BLUE SPRINGS WEST 161KV CKT 1	Replace 800 amp wavetrap with 1200 amp unit	6/1/2014	6/1/2016
MIPU	BLUE SPRINGS EAST - GRAIN VALLEY 161KV CKT 1	Replace Grain Valley800 amp wavetrap with 1200 amp unit	6/1/2014	6/1/2016
MKEC	CLEARWATER - MILAN TAP 138KV CKT 1 MKEC	Rebuild MKEC portion of the Clearwater-Milan tap 115 KV	10/1/2012	6/1/2015
MKEC	HARPER - MILAN TAP 138KV CKT 1 #1	Replace Wave Trap at Harper Substation	10/1/2013	6/1/2014
MKEC	HARPER - MILAN TAP 138KV CKT 1 #2	Rebuild 22.1 miles	10/1/2012	6/1/2015
MKEC	Mullergreen - Circle 345KV DBI CKT MKEC	Build ownership of approximately 79 miles of double 345KV Mullergreen - Circle	10/1/2012	6/1/2019
MKEC	Mullergreen - Circle 345KV DBI CKT WERE	Build ownership of approximately 79 miles of double 345KV Mullergreen - Circle	10/1/2012	6/1/2019
MKEC	Spearville - Mullergreen 345KV DBI CKT	Bull approximately 74 miles of double 345KV Spearville - Mullergreen	10/1/2012	6/1/2019
NPPD	BROKEN BOW - LOUP CITY 115KV CKT 1	Terminal upgrades at both ends and a rebuild of the 266 ACSR segment (11 miles of 39 mile line)	10/1/2014	6/1/2016
NPPD	GRAND ISLAND - SWETTAWATER 345KV CKT 2	Build 63.4 mile second circuit	10/1/2012	6/1/2018
OKGE	5 TRIBES - HANCOCK 161KV CKT 1 #2	Reconduct 2.75 miles of transmission line to 1590A552	6/1/2013	6/1/2015
OKGE	5 TRIBES - PECAN CREEK 161KV CKT Accelerate	Reconductor 4.07 miles of line to 1590A552 and replace 2-wave traps, 1-161KV breaker, 3-switches w/Five Tribes & 5-switches, relaying @ Pecan Creek.	6/1/2013	6/1/2015
OKGE	CIMARRON - DRAPER 161KV 345KV CKT 1	Replace Terminal Equipment	6/1/2014	6/1/2015
OKGE	LOWELL - SUB 452 161KV CKT 1	Build 1.85 miles 345 KV line from Mathewson to Cimarron.	6/1/2014	6/1/2017
OKGE	FT SMITH - MUSKOGEE 161KV CKT 1	Replace 1600 amp 345 KV CT in both Muskogee & Ft. Smith Subs	6/1/2014	6/1/2015
OKGE	Mathewson - Tatonga 345 KV CKT 1	Build new 61 mile Tatonga - Mathewson 345 KV line.	6/1/2014	6/1/2017
OKGE	Mathewson 345 KV	Bull new Mathewson 345 KV Substation at the intersection of the Woodring-Cimarron and the existing Northwest - Tatonga 345 KV lines.	6/1/2014	6/1/2017
OKGE	VBI 345/161 KV with 345/161 KV bus tie at VBI	Build 70.95 mile 345 KV line plus new 345/161 KV bus tie at VBI sub	6/1/2013	6/1/2018
OKGE	NORTHWEST 345/138 13.8KV TRANSFORMER CKT 3 Accelerated	Install third 345/138 KV Bus Tie in Northwest Sub	12/19/2012	6/1/2015
OKGE	VBI - Arkansas Nuclear One 345KV OKGE	Build 73 miles of 345KV line	6/1/2013	6/1/2018
OPPD	HYDROCARBON TAP - SUB 874 69KV CKT 1	Replace terminal equipment	10/1/2012	6/1/2016
OPPD	NEB CITY 1 SYR SUB - SUB 970 69KV CKT 1	Replace terminal equipment	10/1/2013	6/1/2016
OPPD	SUB 913 - SUB 924 69KV CKT 1	Replace 6.97 miles 69KV line	6/1/2018	6/1/2018
OPPD	SUB 967 - SUB 968 69KV CKT 1	Replace terminal equipment	12/31/2012	6/1/2016
OPPD	SUB 968 - SUB 969 69KV CKT 1	Replace terminal equipment at Sub 969	12/31/2012	6/1/2016
OPPD	SUB 969 - SUB 972 69KV CKT 1	Replace terminal equipment at Sub 969	12/31/2012	6/1/2016
SPS	CANYON EAST SUB - CANYON WEST SUB 115KV CKT 1	Rebuild 3.73 miles	6/1/2015	6/1/2016
SPS	CANYON EAST SUB - RANDALL COUNTY INTERCHANGE 115KV CKT 1	Rebuild 18 miles	6/1/2015	6/1/2016
SPS	Jones Station Bus#2 - LUBBOCK SOUTH INTERCHANGE 230KV CKT 2	Upgrade Line trap at both Jones Bus # 2 and Lubbock South Interchange	6/1/2018	6/1/2018
WERE	BENTON - WICHITA 345KV CKT 1	Replace terminal equipment at Benton and Wichita	6/1/2018	6/1/2018
WERE	BUTLER - MARY 161KV CKT 1	Replace Terminal Equipment	6/1/2018	6/1/2018
WERE	CHISHOLM - MAIZE 138KV CKT 1 #1	Upgrade disconnect switches, wavetrap, breaker, jumpers	6/1/2014	6/1/2016
WERE	CHISHOLM - MAIZE 138KV CKT 1 #2	Build 7.25 miles	6/1/2014	6/1/2016
WERE	Circle - Reno 345KV DBI CKT	Bull approximately 6 miles of double 345KV Circle - Reno	10/1/2012	6/1/2015
WERE	CLEARWATER - MILAN TAP 138KV CKT 1 WERE	Rebuild WRE portion of the Clearwater-Milan tap 115 KV	10/1/2012	6/1/2015
WERE	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #1	Upgrade disconnect switches, wavetrap, breaker, jumpers	6/1/2014	6/1/2016
WERE	EVANS ENERGY CENTER NORTH - MAIZE 138KV CKT 1 #2	Rebuild 4.8 miles	6/1/2014	6/1/2016
WERE	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	Rebuild 23.4 miles	6/1/2013	6/1/2017
WERE	Iatan - Jeffrey Energy Center 345 KV WERE	Bull 56.8 miles of new 345 KV	6/1/2013	6/1/2018
WERE	Iatan - Swissvale 345KV WERE	Bull approximately 32 of 64 miles of 73 miles of 345KV ckt 2 Lacygne - Wolf Creek	6/1/2014	6/1/2018
WERE	Lacygne - Wolf Creek 345KV CKT 2 WERE	Bull ownership of approximately 79 miles of double 345KV Mullergreen - Circle	10/1/2012	6/1/2019
WERE	Mullergreen - Circle 345KV DBI CKT WERE	Tear down and rebuild Neosho-Columbus SE 161 KV line (WERE = 2.4 miles) and replace WERE wave trap.	6/1/2014	6/1/2016
WERE	NEOSHO - SUB 452 - RIVERTON 161KV CKT 1 WERE	Bull approximately 50 miles of 345KV Swissvale - Wolf Creek	10/1/2012	6/1/2018
WERE	Viola - Rose Hill 345KV CKT 1	Build approximately 45 miles of 345KV from Viola - Rose Hill	6/1/2014	6/1/2018
WERE	Wolf Creek - Wichita 345KV	Build approximately 117 miles of double 345KV Wolf Creek - Wichita	10/1/2012	6/1/2018

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Planned Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
WERE	BELL - PECK 69KV CKT 1	Tear down / Rebuild 8.23 mile Bell-Peck 69 KV line with 1192 ACSR and replace CT	6/1/2014	6/1/2014
WERE	BELL - SUMNER COUNTY NO. 3 MILLER 69KV CKT 1	Tear down / Rebuild 7.3-miles with 954 ACSR	6/1/2014	6/1/2014
WERE	CITY OF WELLINGTON - SUMNER COUNTY NO. 3 MILLER 69KV CKT 1	Tear down / Rebuild 2.1-miles with 954 ACSR	6/1/2014	6/1/2014
WERE	CITY OF WELLINGTON - SUMNER COUNTY NO. 4 ROME 69KV CKT 1	Tear down / Rebuild 9.1-miles with 954 ACSR	6/1/2014	6/1/2014
WERE	CRESWELL - SUMMER COUNTY NO. 4 ROME 69KV CKT 1	Tear down / Rebuild 9.4-miles with 954 ACSR	6/1/2014	6/1/2014

Expansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
AEPW	Elk City 345/230 kV	Expand Elk City substation (or build new station). Install a 345/230 KV 675 MVA transformer at Elk City.	6/1/2014	6/1/2018
AEPW	Elk City to Gracemont 345kV AEPW	Build new 46.5-mile 345 KV line from Elk City to Gracemont (AEP portion).	6/1/2014	6/1/2018
AEPW	NORTHWEST TEXARKANA - VALLIANT 345KV CKT 1	Build a new 76 mile 345 KV line from Valliant to NW Texarkana with at least 3000 A capacity. Upgrade the Valliant and NW Texarkana substations with the necessary breakers and terminal equipment.	10/1/2012	10/1/2014
ITCGP	Line - Post Rock - Axtell 345 kV	Build new 345 KV line from Knoll to interception point of Axtell to Wolf line (Kansas Border). Includes line reactor.	10/1/2012	6/1/2013
ITCGP	Line - Spearville - Post Rock 345 kV	Build new 345 KV line from Knoll to interception point of Spearville to Knoll line. Updated for approved route mileage; reflect addition of reactor at Post Rock (40Mvar).	10/1/2012	10/1/2012
ITCGP	XFR - Post Rock 345/230 kV	Build Post Rock substation to include a 600 MVA 345/230 KV auto transformer.	10/1/2012	10/1/2012
KACP	HATAN - NASHUA 345KV CKT 1	Replace Nshua 345KV in Hattan - St. Joseph 345 KV line. Build new 345 KV line from Ittan to Nshua. Add Nshua 345/151 KV	6/1/2013	6/1/2015
MKEC	Line - Comanche County - Medicine Lodge 345 kV dbl ckt	Build a new 55 mile double circuit 345 KV line	10/1/2012	1/1/2015
MKEC	Line - Medicine Lodge - Wichita 345 kV dbl ckt MKEC	Build a new 35 mile double circuit 345 KV line with at least 3000 A capacity from the new Medicine Lodge 345 KV substation to the WR interception from the Wichita substation.	10/1/2012	1/1/2015
MKEC	Line - Medicine Lodge - Woodward 345 kV dbl Ckt MKEC	Build a new 28.6 mile dbl ckt 345 KV line with at least 3000 A capacity from the Medicine Lodge sub to the KS/OK state borders towards the Woodward District EHV sub. Install the necessary breakers and terminal equipment at the Medicine Lodge sub.	10/1/2012	1/1/2015
MKEC	Line - Spearville - Comanche County 345 KV dbl ckt MKEC	Build a new 27.5 mile double circuit 345 KV line	10/1/2012	1/1/2015
MKEC	Line - Holt - Holt 345 KV	Install a 400 MVA 345/138 KV transformer at the new 345 KV Medicine Lodge substation.	10/1/2012	1/1/2015
MKEC	XFR - Medicine Lodge 345/118 kV	Build new 345 KV Transmission Line from GGS 345 KV Substation to a new Cherry County 345 KV Substation (76 miles).	10/1/2012	1/1/2015
NPPD	Cherry Co - Gentleman 345 KV Ckt1		10/1/2012	1/1/2018
NPPD	Cherry Co - Holt Co 345 KV Ckt1	Build new 345 KV Transmission Line from new Cherry County 345 KV Substation to new 345 KV Holt County Substation. (Estimated 146 miles).	10/1/2012	1/1/2018
NPPD	Cherry Co 345 kV Terminal Upgrades	Build new Cherry County 345 KV Substation.	10/1/2012	1/1/2018
NPPD	Line - NPPD - Axtell - Kansas Border 345 kV	Build new 345 KV line from Axtell to interception point of Axtell to Wolf line (Kansas Border). Includes substation expansion at Axtell and line reactor.	10/1/2012	6/1/2013
OKGE	Elk City to Gracemont 345KV OKGE	Bull new 46.5 mile 345 KV line from Elk City to Gracemont (OGE portion).	6/1/2014	6/1/2018
OKGE	Line - Hitchland - Woodward 345 KV dbl ckt OKGE	Bull a new 60.5 mile double circuit 345 KV line	10/1/2012	7/1/2014
OKGE	Line - Medicine Lodge - Woodward 345 KV dbl Ckt OKGE	Bull a new 79 mile dbl ckt 345 KV line with at least 3000 A capacity from the Woodward District EHV sub to the KS/OK state borders towards the Medicine Lodge sub. Upgrade the Woodward District EHV sub with the necessary breakers and terminal equipment.	10/1/2012	1/1/2015
SPS	Line - Hitchland - Woodward 345 KV dbl ckt SPS	Bull a new 60.5 mile double circuit 345 KV line	10/1/2012	7/1/2014
SPS	TUCO - WOODWARD 345 KV CKT 1 OKGE	Bull new 345 KV line from Woodward EHV to Toco	10/1/2012	6/1/2014
SPS	TUCO - WOODWARD 345 KV CKT 1 SPS	Bull new 345 KV line from Woodward EHV to Toco	10/1/2012	6/1/2014
SUNC	Line - Spearville - Comanche County 345 kV dbl ckt SUNC	Build a new 27.5 mile double circuit 345 KV line with at least 3000 A capacity from the Spearville substation to the MKEC interception point from the new Comanche County substation.	10/1/2012	1/1/2015
WERE	CENTENNIAL - COWSKIN 138KV CKT 1	Rebuild 3.4 miles Cowskin to Centennial 138 KV line.	6/1/2014	6/1/2016
WERE	Line - Medicine Lodge - Wichita 345 KV dbl ckt WERE	Build a new 35 mile double circuit 345 KV line	10/1/2012	1/1/2015
WERE	MOUNDRIIDGE 138/115KV TRANSFORMER CKT 2	Install second 138/115 KV Transformer at Moundridge. Operate both 138/115 KV transformers normally closed.	10/1/2012	6/1/2015

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
AEPW	77TH & MEMORIAL WEST - EAST 61ST STREET 138KV CKT 1	Replace Terminal Equipment	6/1/2018	6/1/2018
AEPW	BLUEBELL - PRATTVILLE 138KV CKT 1 AEPW	Rebuild 9.0 mile Prattville-Bluebell 138 KV line from 795 ACSR to 1590 ACSR. New summer ratings 287/287 limited by breaker, switches, CTs, wave trap.	6/1/2018	6/1/2018
AEPW	DIANA - PERDUE 138KV CKT 1 #1	Replace Breakers 9310 & 1080 & five switches @ Perdue. Replace switch 12798 @ Diana	6/1/2013	6/1/2013
AEPW	DIANA - PERDUE 138KV CKT 1 #2	Rebuild 21.85 mile Diana-Perdue 138 KV line. Replace switches, wave traps and jumpers, and upgrade CT ratios at Diana and Perdue. Upgrade relay settings at Diana.	6/1/2013	6/1/2016
LES	SHEDDON - SWITH & PLEASANT HILL 115KV CKT 2 LES	Rebuild 12 miles of 115 KV between Sheldon and Folsom/Pleasant Hill	12/31/2012	6/1/2013
MIRU	BLUE SPRING SOUTH - PRAIRIE 156/163KV CKT 1 #1	Replace Prairie Lee 800 amp wavewrap with 1200 amp unit	6/1/2014	6/1/2014
OKGE	S TRIBES - HANCOCK 161KV CKT 1 #1	Replace 800A Wave Trap, increase Relay CTR to 1200-5A	6/1/2013	6/1/2014
OKGE	AGENCY - FECAN CREEK 161KV CKT 1	Reconduct 2 miles and Replace Terminal Equipment	6/1/2018	6/1/2018
OKGE	DIVISION AVE - LAKESIDE 138KV CKT 1	Reconduct 3.37 miles of 138KV from DIVISION AVE to HAYMAKER	6/1/2018	6/1/2018
OKGE	EL RENO - SERVICE PL EL RENO 69KV CKT 1	Replace 400 amp CT in El Reno sub with 800 amp	6/1/2014	6/1/2015
OKGE	HAMMETT TAP - HORSESHOE LAKE 138KV CKT 1	Reconduct 4.84 miles of 138KV from HAMMETT TAP to HORSESHOE LAKE	6/1/2018	6/1/2018
OPPD	SUB 906 NORTH - SUB 928 69KV CKT 1	Rebuild 2.00 miles of line, change CT tap settings, and replace line jumpers. Rebuilding & rebuild and other modifications will be 110 MVA.	6/1/2021	6/1/2021
OPPD	SUB 921 - SUB 942 69KV CKT 1	Increase line clearances to allow the use of a higher conductor rating and change CT tap settings.	6/1/2018	6/1/2018
SPS	HOBBS INTERCHANGE 230/115KV TRANSFORMER CKT 2	Addt Second Transformer	6/1/2018	6/1/2018
SPS	Line - Osage Station and Line Re-termination	Construct approximately 2 miles of new 115 KV line from Randall Co. with 795 ACSR. Tie new line into V70 around (not to) Osage Substation. Add new 115 KV terminal at Randall Co. Interchange. (Re-build Randall 115 KV bus to breaker and one-half design.)	6/1/2013	6/1/2015
SPS	PLANT X STATION (WHL ALM20171) 230/115/13.2KV TRANSFORMER CKT 1	Replace Terminal Equipment	6/1/2014	6/1/2015
WERE	UNIONNRG3 115.00 - CHAPMAN 115KV CKT 1	Build 24 mile 115 KV line	6/1/2018	6/1/2018

Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study

Network Upgrades requiring credits per Attachment 22 of the SPP OATT.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
AEPW	BANN - RED SPRINGS REC 138KV CKT 1	Replace 138 kV breakers 3300 & 3310	7/1/2012	7/1/2012
AEPW	HUGO POWER PLANT - VALIANT 345 KV AEPW	Valiant 345 KV line terminal	7/1/2012	7/1/2012
AEPW	MCNAB REC - TURK 115KV CKT 1	Build a new two mile, 138 KV, 1590 ACSR line section (operated at 115 KV) from Turk Substation to the existing Okay-Hope 115 KV line to form a Turk-Hope 115 KV line.	7/1/2012	7/1/2012
AEPW	OKAY - TURK 138KV CKT 1	Build 115' two miles, 138 KV, 1590 ACSR line section from Turk Sub to existing Okay-Hope 115 KV line and rebuild twelve miles of 115 KV line to Okay Sub to 138 KV, 1590 ACSR, to form a Turk-Okay 138 KV line	7/1/2012	7/1/2012
AEPW	SUGAR HILL - TURK 138KV CKT 1	Build new Turk-Sugar Hill 138 KV line and add Sugar Hill 138 KV terminal.	7/1/2012	7/1/2012
EMDE	SUB 110 - ORONGOGO JCT. - SUB 167 - RIVERTON 161KV CKT 1	Reconducto Orongogo 59467 to Riverton 59469 with Bundled 556 ACSR	6/1/2011	6/1/2011
KACP	LACYGNE - WEST GARDNER 345KV CKT 1	KCPL Sponsored Project to Reconducto Line to be In-Service by 6/1/2006	6/1/2006	6/1/2006
MIDW	CIRCLE - RICE CO 230KV CKT 1	Convert from 115KV to 230KV operation	10/1/2012	11/15/2012
MIDW	LYONS - RICE CO 115KV CKT 1	Rebuild 11.7 mile line	10/1/2012	4/1/2013
MIDW	RICE CO 230/115KV TRANSFORMER CKT 1	Add 230/115KV Transformer	10/1/2012	11/15/2012
MKEC	FLATROG3 138.00 - HARPER 138KV CKT 1	Replace 24.15 mile line	12/1/2009	6/1/2013
MKEC	Mullergren - Circle 345KV Dbi CKT MKEC	Build ownership of approximately 79 miles of double 345KV Mullergren - Circle	10/1/2012	6/1/2019
MKEC	Mullergren - Circle 345KV Dbi CKT WERE	Build ownership of approximately 79 miles of double 345KV Mullergren - Circle	10/1/2012	6/1/2019
MKEC	Spearville - Mullergren 345kv Dbi CKT	Build approximately 74 miles of double 345KV Spearville - Mullergren	10/1/2012	6/1/2019
NPPD	ALBION - PETERSBURG 115KV CKT 1	Replace Breaker Switch 1106-D and jumpers at Albion. Replace main bus at Petersburg. Upgrade and replace transmission structures on 115 KV line to facilitate 100 degrees Centigrade line operation.	1/1/2013	1/1/2013
NPPD	NELIGH - PETERSBURG 115KV CKT 1	Replace Breaker 1106, jumpers, and 115 KV Switch 1106-D at Neligh. Replace main bus at Petersburg. Upgrade and replace transmission structures on 115 KV line to facilitate 100 degrees Centigrade line operation.	1/1/2013	1/1/2013
OKGE	Cimarron - Mathewson 345 KV Ckt 1	Build new 16 mile 345 KV line from Mathewson to Cimarron.	6/1/2012	6/1/2019
OKGE	GRACMNTA 138.00 - WASHITA 138KV CKT 2 OKGE	Build 138KV Terminal.	1/1/2012	1/1/2012
OKGE	Mathewson - Tatonga 345 KV Ch 1	Build new 61 mile Tatonga - Mathewson 345 KV line.	6/1/2012	6/1/2019
OKGE	Mathewson 345 KV	Build new Mathewson 345 KV substation at the intersection of the Woodring-Cimarron and the existing Northwest - Tatonga 345 KV lines.	6/1/2013	6/1/2019
OKGE	NORTHWEST - TATONGA 345KV CKT 1	Build 345 KV line	1/1/2010	1/1/2010
OKGE	TATONGA - WOODWARD 345KV CKT 1	Build 345 KV line	1/1/2010	1/1/2010
OKGE	WOODWARD - WOODWARD EHV 138KV CKT 1	Build 5 miles of 138 KV and install terminal equipment	1/1/2010	1/1/2010
OKGE	WOODWARD - WOODWARD EHV 138KV CKT 2	Build 5 miles of 138 KV and install terminal equipment	1/1/2010	1/1/2010
OKGE	WOODWARD 345/138KV TRANSFORMER CKT 1	Install 345/138 KV XF	1/1/2010	1/1/2010
OPPD	HYDROCARBON TAP - SUB 974 69KV CKT 1	Replace terminal equipment	10/1/2014	6/1/2016
OPPD	NEB CITY U SYR SUB - SUB 970 69KV CKT 1	Replace terminal equipment	10/1/2013	6/1/2016
OPPD	SUB 906 SOUTH - SUB 924 69KV CKT 1	Rebuilt 1.34miles 69KV line	6/1/2018	6/1/2016
OPPD	SUB 912 - SUB 924 69KV CKT 1	Rebuilt 1.87miles 69KV line	6/1/2018	6/1/2016
OPPD	SUB 967 - SUB 968 69KV CKT 1	Replace terminal equipment	10/1/2012	6/1/2016
OPPD	SUB 968 - SUB 969 69KV CKT 1	Replace terminal equipment at Sub 969	10/1/2012	6/1/2016
OPPD	SUB 969 - SUB 970 69KV CKT 1	Replace terminal equipment at Sub 970	10/1/2012	6/1/2016
SPS	CHEERRY 230.00 - Harrington Station East Bus 230KV CKT 1	Replace equipment at Harrington East	6/1/2015	6/1/2015
WERE	BENTON - WICHITA 345KV CKT 1	Replace terminal equipment at Benton and Wichita	6/1/2014	6/1/2015
WERE	Circle - Reno 345KV Dbi CKT	Built approximately 6 miles of double 345KV Circle - Reno	10/1/2012	6/1/2019
WERE	DEARING 138KV Capacitor	Dearing 138 KV 20 MVAR Capacitor Addition	6/1/2012	6/1/2012
WERE	LYONS - WHEATLAND 115KV CKT 1 #1	Replace CTs	10/1/2012	7/15/2013
WERE	LYONS - WHEATLAND 115KV CKT 1 #2	Rerate circuit to 1000 amps	10/1/2012	7/15/2013
WERE	Mullergren - Circle 345KV Dbi CKT WERE	Build ownership of approximately 79 miles of double 345KV Mullergren - Circle	10/1/2012	6/1/2019
WERE	Viola - Rose Hill 345KV CKT 1	Build approximately 45 miles of 345KV from Viola - Rose Hill	6/1/2014	6/1/2018
WFEC	G03-051 138.00 - PARADISE 138KV CKT 1	Upgrade Paradise to G03-051 to 1113	6/1/2010	6/1/2013
WFEC	GRACMNTA 138.00 - WASHITA 138KV CKT 2 WFEC	Build approximately 6 miles of 138KV.	1/1/2012	1/1/2012
WFEC	HUGO POWER PLANT - VALIANT 345KV CKT 2 WFEC	New 19 miles 345 KV	7/1/2012	7/1/2012
WFEC	HUGO POWER PLANT 345/138KV TRANSFORMER CKT 1	New 345/138 KV Auto	7/1/2012	7/1/2012

Table 5 - Third Party Facility Constraints

Transmission Owner	UpgradeName	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
AECI	7JASPER 345.00 - BLACKBERRY 345KV CKT 1	Reconductor with 1192.5 54/19 ACSR, 100C. 16 Miles.	6/1/2013	6/1/2016	\$ 8,000,000
AECI	7JASPER 345.00 - MORGAN 345KV CKT 1	Reconductor with 1192.5 54/19 ACSR, 100C. 36 Miles.	6/1/2014	6/1/2016	\$ 18,000,000
AECI	BLACKBERRY - NEOSHO 345KV CKT 1	Reconductor with 1192.5 54/19 ACSR, 100C. 40 miles	6/1/2014	6/1/2016	\$ 20,000,000
AECI	CLINTON 161/69KV TRANSFORMER CKT 1	Indeterminate	6/1/2018	6/1/2018	Indeterminate
AECI	CLINTON 161/69KV TRANSFORMER CKT 3	Indeterminate	6/1/2018	6/1/2018	Indeterminate
AECI	HUBEN 345/161KV TRANSFORMER CKT 1	Indeterminate	6/1/2014	6/1/2014	Indeterminate
AECI	Lacygne - Morgan 345KV AECI	Indeterminate	10/1/2012	6/1/2018	Indeterminate
AECI	MONTGOMERY CITY - WILLIAMSBURG 161KV CKT 1	Indeterminate	6/1/2014	6/1/2014	Indeterminate
AMMO	SOVERTON 161.00 - SOVERTON 2 161.00 161KV CKT 1	Indeterminate	6/1/2014	6/1/2014	Indeterminate
AMMO	TOVERTON 345.00 () 345/161/13.8KV TRANSFORMER CKT 1	Add 1 new 345 bay(s) at Existing station. Add 1 new 161 bay(s) at Existing station. Add 1 new 345/161 autotransformer.	10/1/2012	6/1/2016	\$ 16,100,000
EES	ARKANSAS NUCLEAR ONE - PLEASANT HILL 500KV CKT 1	Indeterminate	6/1/2014	6/1/2014	Indeterminate
EES	Arkansas Nuclear One 500/345 Transformer	Build 500/345 KV Transformer/ at ANO	6/1/2013	6/1/2018	\$ 12,000,000
EES	BOGALUSA - FRANKLIN 500KV CKT 1	Indeterminate	10/1/2014	10/1/2014	Indeterminate
EES	BULL SHOALS - MIDWAY (YVEPA) 161KV CKT 1	Indeterminate	6/1/2013	6/1/2013	Indeterminate
EES	GRIMES - MT. ZION 138KV CKT 1	Upgrade Transmission Line 19.19 miles	10/1/2013	6/1/2016	\$ 14,966,895
EES	HARTBURG - INLAND-ORANGE 230KV CKT 1	Indeterminate	10/1/2013	10/1/2013	Indeterminate
EES	HUNTSVILLE - LINE 558 TAP 138KV CKT 1	Upgrade Transmission Line 2.3 miles	10/1/2013	6/1/2016	\$ 4,309,985
EES	McNeil 500/345KV	Add 500/345KV Transformer	6/1/2013	6/1/2018	\$ 12,000,000
EES	SHELDONSHIESE	Indeterminate	10/1/2012	10/1/2012	Indeterminate
EES	VBI - Arkansas Nuclear One 345KV EES	Indeterminate	6/1/2013	6/1/2018	Indeterminate
SWPA	BEAVER - EUREKA SPRINGS 161KV CKT 1 SWPA	Reconductor 6 miles of 795 ACSR with 1590 ACSR. Replace Switch & Jumpers @ Eureka Springs.	6/1/2013	6/1/2015	Indeterminate
SWPA	BUFORO 5 161.00 - NORFORK 161KV CKT 1	Rebuild line with 1192 ACSR, Grackle	6/1/2013	6/1/2016	Indeterminate
SWPA	GORE - MUSKOGEE TAP 161KV CKT 1	Rebuild line with 1192 ACSR. Upgrade terminal equipment.	6/1/2013	6/1/2016	\$ 8,000,000
SWPA	GORE - SALLISAW 161KV CKT 1	Rebuild w/ 1192 ACSR. Replace wave trap.	6/1/2013	6/1/2016	\$ 9,000,000
SWPA	LIBERTY TAP - SALLISAW 161KV CKT 1 SWPA	Rebuild w/ 1192 ACSR.	6/1/2013	6/1/2016	\$ 6,500,000
SWPA	NORFORK - SOUTHLAND AECC 161KV CKT 3 SWPA	Replace bus and reset metering CT ratio and replace Wavetrap	6/1/2014	6/1/2014	Indeterminate
SWPA	NORTH WARSAW - TRUMAN 161KV CKT 1 SWPA	Replace wave trap and CTs at Truman.	6/1/2014	6/1/2014	Indeterminate

Exploratory Interconnection Project between AECI Cox Creek 345kV (Thayer, Mo), AEPW Osage Creek 345 kV, EMDE Reeds Spring-Branson 161 kV, and SPRM Brookline 345kV

MULTIPLE	Brookline – Compton Ridge 345 kV	Build approx. 30 mile 345 kV line	6/1/2013	6/1/2018	Indeterminate
MULTIPLE	Compton Ridge – Cox Creek 345 kV	Build approx. 120 mile 345 kV line and Operate Gobbler Knob-Cox Creek at 345 kV	6/1/2013	6/1/2018	Indeterminate
MULTIPLE	Compton Ridge – Osage Creek 345 kV	Build approx. 50 mile 345 kV line	6/1/2013	6/1/2018	Indeterminate
MULTIPLE	COMPTON RIDGE - SUB 412 - BRANSON NORTHWEST 161KV CKT 1	Indeterminate	6/1/2013	6/1/2018	Indeterminate
MULTIPLE	Compton Ridge 345/161 kV Transformer	Install 500 MVA, 345/161 kV transformer and Cut EDE Reeds Spring-Branson line at 50% and route in & out of Compton Ridge	6/1/2013	6/1/2018	Indeterminate