



**Definitive Interconnection  
System Impact Study for  
Generation Interconnection  
Requests  
(DISIS-2012-001-2)**

**January 2014**

**Generation Interconnection**



---

## Revision History

---

| Date       | Author | Change Description  |
|------------|--------|---|
| 07/26/2012 | SPP    | Report Issued (DISIS-2012-001)                                      |
| 02/08/2013 | SPP    | Account for Withdrawn Projects, Report Re-Posted (DISIS-2012-001-1) |
| 01/21/2014 | SPP    | Account for Withdrawn Projects, Report Re-Posted (DISIS-2012-001-2) |

---

## Executive Summary

---

Generation Interconnection customers have requested a Definitive Interconnection System Impact Study (DISIS) under the Generation Interconnection Procedures (GIP) in the Southwest Power Pool Open Access Transmission Tariff (OATT). The Interconnection Customers' requests have been clustered together for the following System Impact Cluster Study window which closed March 31, 2012. The customers will be referred to in this study as the DISIS-2012-001 Interconnection Customers. This System Impact Study analyzes the interconnecting of multiple generation interconnection requests associated with new generation totaling approximately 475.1MW of new generation which would be located within the transmission systems of Oklahoma Gas and Electric (OKGE), Sunflower Electric Power Corporation/Mid-Kansas Electric Power LLC (SUNC)/(MKEC), and Southwestern Public Service (SPS). The various generation interconnection requests have differing proposed in-service dates<sup>1</sup>. The generation interconnection requests included in this System Impact Cluster Study are listed in Appendix A by their queue number, amount, requested interconnection service, area, requested interconnection point, proposed interconnection point, and the requested in-service date.

Power flow analysis has indicated that for the power flow cases studied, 475.1MW of nameplate generation may be interconnected with transmission system reinforcements within the SPP transmission system. Previously performed dynamic stability analysis and additional power flow analysis for power factor requirements has determined the need for reactive. Previously performed dynamic stability analysis has determined that the transmission system will remain stable with the assigned Network Upgrades and Interconnection Facilities to the DISIS.

The total estimated minimum cost for interconnecting the DISIS-2012-001 interconnection customers is \$30,111,834.27. These costs are shown in Appendix E and F. Interconnection Service to DISIS-2012-001 interconnection customers is also contingent upon higher queued customers paying for certain required network upgrades. **The in service date for the DISIS customers will be deferred until the construction of these network upgrades can be completed.**

These costs do not include the Interconnection Customer Interconnection Facilities as defined by the SPP Open Access Transmission Tariff (OATT). This cost does not include additional network constraints in the SPP transmission system identified and shown in Appendix H.

Network Constraints listed in Appendix H are in the local area of the new generation when this generation is injected throughout the SPP footprint for the Energy Resource (ERIS) Interconnection Request. Certain Interconnection Requests were also studied for Network Resource Interconnection Service (NRIS). Those constraints are also listed in Appendix H. Additional Network

---

<sup>1</sup> The generation interconnection requests in-service dates will need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customer's that proceed to the Facility Study will be provided a new in-service date based on the Facility Study's time for completion of the Network Upgrades necessary.

constraints will have to be verified with a Transmission Service Request (TSR) and associated studies. With a defined source and sink in a TSR, this list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

The required interconnection costs listed in Appendix E and F do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT.

---

# Table of Contents

---

|  |           |
|--|-----------|
| <b>Introduction</b> .....  | <b>1</b>  |
| <b>Model Development</b> .....   | <b>2</b>  |
| <b>Identification of Network Constraints</b> .....                                     | <b>5</b>  |
| <b>Determination of Cost Allocated Network Upgrades</b> .....                          | <b>5</b>  |
| <b>Required Interconnection Facilities</b> .....                                       | <b>7</b>  |
| <b>Power Flow Analysis</b> .....   | <b>7</b>  |
| <b>Stability Analysis</b> .....  | <b>10</b> |
| <b>Conclusion</b> .....  | <b>11</b> |
| <b>Appendix</b> .....  | <b>12</b> |
| A: Generation Interconnection Requests Considered for Impact Study.....                | A1        |
| B: Prior Queued Interconnection Requests.....  | B1        |
| C: Study Groupings .....   | C1        |
| D: Proposed Point of Interconnection One line Diagrams .....                           | D1        |
| E: Cost Allocation per Interconnection Request (Including Prior Queued Upgrades) ..... | E1        |
| F: Cost Allocation per Proposed Study Network Upgrade .....                            | F1        |
| G: Power Flow Analysis (Constraints For Mitigation) .....                              | G1        |
| H: Power Flow Analysis (Other Constraints Not Requiring Mitigation) .....              | H1        |
| I: Power Flow Analysis (Category C Contingencies) .....                                | I1        |

---

## Introduction

---

Pursuant to the Southwest Power Pool (SPP) Open Access Transmission Tariff (OATT), SPP has conducted this Definitive Interconnection System Impact Study (DISIS) for certain generation interconnection requests in the SPP Generation Interconnection Queue. These interconnection requests have been clustered together for the following System Impact Study window which closed March 31, 2012. The customers will be referred to in this study as the DISIS-2012-001 Interconnection Customers. This System Impact Study analyzes the interconnecting of multiple generation interconnection requests associated with new generation totaling 475.1 MW of new generation which would be located within the transmission systems of Oklahoma Gas and Electric (OKGE), Sunflower Electric Power Corporation/Mid-Kansas Electric Power LLC (SUNC/MKEC), and Southwestern Public Service (SPS). The various generation interconnection requests have differing proposed in-service dates<sup>2</sup>. The generation interconnection requests included in this System Impact Study are listed in Appendix A by their queue number, amount, requested interconnection service, area, requested interconnection point, proposed interconnection point, and the requested in-service date.

The primary objective of this Definitive Interconnection System Impact Study is to identify the system constraints associated with connecting the generation to the area transmission system. The Impact and other subsequent Interconnection Studies are designed to identify attachment facilities, Network Upgrades and other Direct Assignment Facilities needed to accept power into the grid at each specific interconnection receipt point.

---

<sup>2</sup> The generation interconnection requests in-service dates will need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customer's that proceed to the Facility Study will be provided a new in-service date based on the competition of the Facility Study.

---

## Model Development

---

### Interconnection Requests Included in the Cluster

SPP has included all interconnection requests that submitted a Definitive Interconnection System Impact Study Agreement no later than March 31, 2012 and were subsequently accepted by Southwest Power Pool under the terms of the Generator Interconnection Procedures (GIP). The interconnection requests that are included in this study are listed in Appendix A.

### Affected System Interconnection Request

Also included in this Definitive Impact Study is a single Affected System Study, located on the Pioneer Electric Cooperative, Inc. system, which shares connections to the Sunflower Electric Power Corporation (SUNC) system. The Affected System Study Requests has been given the designation: ASGI-2012-006. ASGI-2012-006 capacity nameplate is 22.5 MW (and associated 17MW internal load) with Point of Interconnection (POI) at a tap on Hugoton – Rolla 69kV line.

### Previously Queued Interconnection Requests

The previous queued requests included in this study are listed in Appendix B. In addition to the Base Case Upgrades, the previous queued requests and associated upgrades were assumed to be in-service and added to the Base Case models. These projects were dispatched as Energy Resources with equal distribution across the SPP footprint. Prior queued projects that requested Network Resource Interconnection Service (NRIS) were dispatched in an additional analysis into the balancing authority of the interconnecting transmission owner.

## Development of Base Cases

### Power Flow

The 2013 series Transmission Service Request (TSR) Models 2014 spring, 2014 summer and winter peak, 2019 summer and winter peak, and the 2024 summer peak scenario 0 cases were used for this study. After the cases were developed, each of the control areas' resources were then re-dispatched to account for the new generation requests using current dispatch orders.

### Dynamic Stability

The stability analysis was not re-performed for this restudy.

## Base Case Upgrades

The following facilities are part of the SPP Transmission Expansion Plan or the Balanced Portfolio or recently approved Priority Projects. These facilities, have an approved Notice to Construct (NTC), or are in construction stages and were assumed to be in-service at the time of dispatch and added to the base case models. The DISIS-2012-001 Customers have not been assigned acceleration costs for the below listed projects. The DISIS-2012-001 Customers Generation Facilities in service dates may need to be delayed until the completion of the following upgrades. If for some reason, construction on these projects is discontinued, additional restudies will be needed to determine the interconnection needs of the DISIS customers.

- Hitchland 230/115kV area projects<sup>3</sup>:
  - Hitchland – Ochiltree 230kV Project (placed In-Service in 2013)
- Balanced Portfolio Projects<sup>4</sup>:
  - Woodward – Border – TUCO 345kV project, scheduled for 5/19/2014 in-service
    - Woodward 345/138kV circuit #2 autotransformer
    - TUCO 345/138kV circuit #2 autotransformer
    - Reactors at Woodward and Border
  - Iatan– Nashua 345kV, scheduled for 6/1/2015 in-service
    - Nashua 345/161kV autotransformer
  - Muskogee– Seminole 345kV, scheduled for 12/31/2013 in-service
  - Cleveland – Sooner 345kV (placed In-Service in 2012)
  - Tap Stillwell – Swissvale 345kV line at West Gardner (placed In-Service in 2013)
- Priority Projects<sup>5</sup>:
  - Hitchland – Woodward double circuit 345kV, scheduled for 6/30/2014 in-service
    - Hitchland 345/230kV circuit #2 autotransformer
  - Woodward – Thistle double circuit 345kV, scheduled for 12/31/2014 in-service
  - Spearville – Clark double circuit 345kV, scheduled for 12/31/2014 in-service
  - Clark – Thistle double circuit 345kV, scheduled for 12/31/2014 in-service
  - Thistle – Wichita double circuit 345kV, scheduled for 12/31/2014 in-service
  - Thistle 345/138kV autotransformer, scheduled for 12/31/2014 in-service
  - Thistle – Flat Ridge 138kV, scheduled for 12/31/2014 in-service
- Various MKEC Transmission System Upgrades<sup>6</sup>
  - Harper – Flat Ridge 138kV rebuild (placed In-Service in 2013)
  - Flat Ridge – Medicine Lodge 138kV rebuild, scheduled for 12/31/2013 in-service
  - Pratt – Medicine Lodge 115kV rebuild, scheduled for 6/15/2014 in-service
  - Medicine Lodge 138/115kV autotransformer replacement, (placed In-Service in 2013)

---

<sup>3</sup> SPP Regional Reliability Projects identified in 2007 STEP. As of the writing of this report, SPP Project Tracking TAGIT shows some of these project's in-service dates have been delayed from the original 2010/2011 in-service dates.

<sup>4</sup> Notice to Construct (NTC) issued June 2009.

<sup>5</sup> Notice to Construct (NTC) issued June 2010.

<sup>6</sup> SPP Transmission Service Projects identified in SPP-2007-AG3-AFS-9.



- Northwest 345/138/13.8kV circuit #3 autotransformer, scheduled for 6/1/2017 in-service<sup>7</sup>
- Woodward (OKGE) – Woodward (WFEC) 69kV rebuild, scheduled for 6/1/2015 in-service<sup>8</sup>
- Sheldon – SW7th and Pleasant Hill 115kV circuit #2 rebuild (placed In-Service in 2013)<sup>9</sup>

## Contingent Upgrades

The following facilities do not yet have approval. These facilities have been assigned to higher queued interconnection customers. These facilities have been included in the models for the DISIS-2012-001 study and are assumed to be in service. This list may not be all inclusive. The DISIS-2012-001 Customers at this time do not have responsibility for these facilities but may later be assigned the cost of these facilities if higher queued customers terminate their GIA or withdraw from the interconnection queue. The DISIS-2012-001 Customer Generation Facilities in service dates may need to be delayed until the completion of the following upgrades.

- Upgrades assigned to ICS-2008-001 Interconnection Customers
  - Line Traps at Amarillo South – Swisher 230kV
- Upgrades assigned to DISIS-2009-001 Interconnection Customers:
  - Fort Dodge – North Fort Dodge – Spearville 115kV circuit #2
  - Albion – Petersburg – Neligh 115kV circuit #1 rerate (placed In-Service in 2011)
  - Fort Randall – Madison County – Kelly 230kV circuit #1 rerate (320MVA)
  - Spearville 345/115kV autotransformer circuit #1
- Upgrades assigned to DISIS-2010-001 Interconnection Customers:
  - Beaver County 345kV Expansion (Tap & Tie Hitchland – Woodward circuit #2 into Beaver County 345kV)
  - Switch 2749 – Wildorado 69kV circuit # 1 rebuild
  - Washita – Gracemont 138kV circuit #2 (placed In-Service in 2012)
- Upgrades assigned to DISIS-2010-002 Interconnection Customers:
  - Twin Church – Dixon County 230kV circuit #1 rerate (320MVA)
- Upgrades assigned to DISIS-2011-001 Interconnection Customers:
  - Beaver County – Buckner 345kV circuit #1 buildTatonga – Matthewson - Cimarron 345kV circuit #2 build
    - Tatonga terminal equipment upgrade (1792 MVA)
  - Rice County – Circle 230kV conversion (placed In-Service in 2012)
  - Rice County – Lyons 115kV rebuild (placed In-Service in 2013)
  - Rice County 230/115kV autotransformer (placed In-Service in 2012)
  - Lyons – Wheatland 115kV rerate (placed In-Service in 2012)
  - Hoskins – Dixon County – Twin Church 230kV circuit #1 rerate
  - (NRIS only) Spearville – Mullergren 230kV circuit #1 rebuild
  - (NRIS only) FPL Switch – Woodward - Mooreland 138kV circuit #1 rebuild
  - (NRIS only) Hitchland 230/115kV transformer circuit #2, build

<sup>7</sup> SPP Transmission Service Project identified in SPP-2009-AG2-AFS6. Per SPP-NTC-20137.

<sup>8</sup> SPP Regional Reliability Project. Per SPP-NTC-20003.

<sup>9</sup> SPP Regional Reliability 2012 ITPNT Project. Per SPP-NTC-200171.

- Upgrades assigned to DISIS-2011-002 interconnection Customers:
  - Power System Stabilizers - Install Power System Stabilizers @ Tolk(Units: 1,2) and Jones (Units: 1,2,3,4)
  - GEN-2011-017 Tap – Mullergren 345kV circuit #1 build
    - Build Mullergren 345/230kV Substation
    - Build Mullergren 345/230/13kV Transformer
  - SUB 967 - SUB 968 69kV circuit #1 replace terminal equipment
  - (NRIS only) Hydro Carbon Tap - Sub974 69kV circuit #1 rewire CT
  - (NRIS only) Lubbock South 230/115kV Autotransformer build circuit #2
  - (NRIS only) Mullergren – Reno 345kV circuit #1 build
  - (NRIS only) Nebraska City U Syracuse – SUB 970 circuit #1 replace terminal equipment
  - (NRIS only ) Yoakum 230/115kV transformer circuit #1 and circuit #2 replacement

### Potential Upgrades Not in the Base Case

Any potential upgrades that do not have a Notification to Construct (NTC) and not explicitly listed within this report have not been included in the base case. These upgrades include any identified in the SPP Extra-High Voltage (EHV) overlay plan, or any other SPP planning study other than the upgrades listed above in the previous section.

### Regional Groupings

The interconnection requests listed in Appendix A were grouped together in fifteen different regional groups based on geographical and electrical impacts. These groupings are shown in Appendix C.

To determine interconnection impacts, fifteen different generation dispatch scenarios of the spring base case models were developed to accommodate the regional groupings.

### Power Flow

For each group, the various wind generating plants were modeled at 100% nameplate of maximum generation. The other wind generating plants in each area were modeled at 80% nameplate while the wind generating plants in the other areas were modeled at 20% nameplate of maximum generation. These projects were dispatched as Energy Resources with equal distribution across the SPP footprint. Certain projects that requested Network Resource Interconnection Service were dispatched in an additional analysis into the balancing authority of the interconnecting transmission owner. This method allowed for the identification of network constraints that were common to the regional groupings that could then in turn have the mitigating upgrade cost allocated throughout the entire cluster. Other sensitivity analyses are also performed with all interconnection requests in each group being dispatched at 100% nameplate.

Peaking units were not dispatched in the 2014 spring model. To study peaking units' impacts, the 2014 summer and winter and 2019 summer and winter, and 2024 summer seasonal models were chosen and peaking units were modeled at 100% of the nameplate rating and wind generating facilities were modeled at 10% of the nameplate rating. Each interconnection request was also modeled separately at 100% nameplate for certain analyses.

**Dynamic Stability**

The stability analysis was not re-performed for this restudy.

---

## Identification of Network Constraints

---

The initial set of network constraints were found by using PTI MUST First Contingency Incremental Transfer Capability (FCITC) analysis on the entire cluster grouping dispatched at the various levels mentioned above. These constraints were then screened to determine if any of the generation interconnection requests had at least a 20% Distribution Factor (DF) upon the constraint. Constraints that measured at least a 20% DF from at least one interconnection request were considered for mitigation. Interconnection Requests that have requested Network Resource Interconnection Service (NRIS) were also studied in the NRIS analysis to determine if any constraint had at least a 3% DF. If so, these constraints were considered for mitigation.

---

## Determination of Cost Allocated Network Upgrades

---

Cost Allocated Network Upgrades of wind generation interconnection requests were determined using the 2014 spring model. Cost Allocated Network Upgrades of peaking units was determined using the 2019 summer peak model. A MUST sensitivity analysis was performed to determine the Distribution Factors (DF), a distribution factor with no contingency that each generation interconnection request had on each new upgrade. The impact each generation interconnection request had on each upgrade project was weighted by the size of each request. Finally the costs due by each request for a particular project were then determined by allocating the portion of each request's impact over the impact of all affecting requests.

For example, assume that there are three Generation Interconnection requests, X, Y, and Z that are responsible for the costs of Upgrade Project '1'. Given that their respective PTDF for the project have been determined, the cost allocation for Generation Interconnection request 'X' for Upgrade Project 1 is found by the following set of steps and formulas:

- Determine an Impact Factor on a given project for all responsible GI requests:

$$\text{Request X Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(X) * \text{MW}(X) = X1$$

$$\text{Request Y Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Y) * \text{MW}(Y) = Y1$$

$$\text{Request Z Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Z) * \text{MW}(Z) = Z1$$

- Determine each request's Allocation of Cost for that particular project:

$$\text{Request X's Project 1 Cost Allocation (\$)} = \frac{\text{Network Upgrade Project 1 Cost(\$)} * X1}{X1 + Y1 + Z1}$$

- Repeat previous for each responsible GI request for each Project

The cost allocation of each needed Network Upgrade is determined by the size of each request and its impact on the given project. This allows for the most efficient and reasonable mechanism for sharing the costs of upgrades.

### **Credits for Amounts Advanced for Network Upgrades**

Interconnection Customer shall be entitled to credits in accordance with Attachment Z2 of the SPP Tariff for any Network Upgrades including any tax gross-up or any other tax-related payments associated with the Network Upgrades, and not refunded to the Interconnection Customer.

---

## Required Interconnection Facilities

---

The requirement to interconnect the 475.1 MW of generation into the existing and proposed transmission systems in the affected areas of the SPP transmission footprint consist of the necessary cost allocated shared facilities listed in Appendix F by upgrade. The interconnection requirements for the cluster total \$30,111,834.27. Interconnection Facilities specific to each generation interconnection request are listed in Appendix E. A preliminary one-line drawing for each generation interconnection request are listed in Appendix D.

A list of constraints that were identified and used for mitigation are listed in Appendix G. Listed within Appendix G are the ERIS constraints with greater than or equal to a 20% DF, as well as, the NRIS constraints that have a DF of 3% or greater. Other Network Constraints which are not requiring mitigation are shown in Appendix H. With a defined source and sink in a TSR, this list of Network Constraints will be refined and expanded to account for all Network Upgrade requirements.

---

## Power Flow Analysis

---

### Power Flow Analysis Methodology

The ACCC function of PSS/E was used to simulate single element and special (i.e., breaker-to-breaker, multi-element, etc) contingencies in portions or all of the modeled control areas of SPP, as well as, other control areas external to SPP and the resulting scenarios analyzed. NERC Category “B” and “C” contingencies were evaluated.

### Power Flow Analysis

A power flow analysis was conducted for each Interconnection Customer’s facility using modified versions of the 2014 spring peak, 2014 summer and winter peak, the 2019 summer and winter peak models, and the 2024 summer peak models. The output of the Interconnection Customer’s facility was offset in each model by a reduction in output of existing online SPP generation. This method allows the request to be studied as an Energy Resource (ER) Interconnection Request. Certain requests that requested Network Resource Interconnection Service (NRIS) had an additional analysis conducted for displacing resources in the interconnecting Transmission Owner’s balancing authority.

This analysis was conducted assuming that previous queued requests in the immediate area of these interconnect requests were in-service. The analysis of each Customer’s project indicates that criteria violations will occur on the SPS and SUNC transmission systems under system intact and contingency conditions in the peak seasons.

### Cluster Group 1 (Woodward Area)

In addition to the 4,635.1 MW of previously queued generation in the area, 0 MW of new interconnection service was studied. No new constraints were found in this area.

**Cluster Group 2 (Hitchland Area)**

In addition to the 2,961.2 MW of previously queued generation in the area, 0 MW of new interconnection service was studied. No new constraints were found in this area.

**Cluster Group 3 (Spearville Area)**

In addition to the 3,867.9 MW of previously queued generation in the area, 342.5 MW of new interconnection service was studied. ERIS upgrade second Holcomb 345/230/13kV autotransformer circuit #2 that was previously identified is no longer needed since Holcomb 345/230/13kV circuit #1 does not have overload violations. However without the second Holcomb autotransformer, Garden City – Kansas Ave Water Treatment Plant 115kV and Dobson – Gano 115kV circuits do overload during contingency and will require terminal equipment upgrades. NRIS overloads were also mitigated by the ERIS upgrade placing terminal equipment on Dobson – Gano 115kV.

| Group 3: ERIS Constraints                                     |              |                    |  |
|---|--------------|--------------------|--|
| MONITORED ELEMENT   | RATE B (MVA) | TC%LOADING (% MVA) | CONTINGENCY  |
| GARDEN CITY - KANSAS AVENUE WATER TREATMENT PLANT 115KV CKT 1 | 119.5        | 121.9964           | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1 |
| DOBSON - GANO 3 115.00 115KV CKT 1                            | 148.2        | 101.3103           | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1 |

| Group 3: NRIS Constraints          |              |                    |  |
|------------------------------------|--------------|--------------------|--|
| MONITORED ELEMENT                  | RATE B (MVA) | TC%LOADING (% MVA) | CONTINGENCY  |
| DOBSON - GANO 3 115.00 115KV CKT 1 | 119.5        | 118.0312           | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1 |

**Cluster Group 4/11 (Mingo/NW Kansas Group)**

In addition to the 1,888.10 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. The withdrawal of the GEN-2012-002 request alleviated any thermal violations on the Holcomb 345/115kV autotransformer circuit #1 for this study. The previously identified Holcomb 345/115/13kV autotransformer circuit #2 is no longer required.

**Cluster Group 5 (Amarillo Area)**

In addition to the 1,332.6 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

**Cluster Group 6 (South Texas Panhandle/New Mexico)**

In addition to the 2,380.3 MW of previously queued generation in the area, 91.2 MW of new interconnection service was studied. Outlet constraints of the Mustang 115kV bus were previously identified for generators at Mustang in the last restudy, but due to higher or equally queued request withdrawal, the overloads are alleviated. Previously assigned DISIS-2011-002 upgrade for Mustang – Yoakum 230kV terminal equipment is now assigned to this study. From previous performed stability analysis, potential stability issues were identified for GEN-2012-001 for loss of the Grassland 230kV line from the wind farm.

| Group 6: ERIS Constraints                               |              |                    |  |
|---|--------------|--------------------|--|
| MONITORED ELEMENT                                       | RATE B (MVA) | TC%LOADING (% MVA) | CONTINGENCY  |
| MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1 | 351          | 103.0690           | AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 |

**Cluster Group 7 (Southwestern Oklahoma)**

In addition to the 1,825.2 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

**Cluster Group 8 (South Central Kansas/North Oklahoma)**

In addition to the 1,909.5 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

**Cluster Group 9/10 (Nebraska)**

In addition to the 1,587.9 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

**Cluster Group 11 (North Central Kansas)**

Group 11 has been merged with Group 4.

**Cluster Group 12 (Northwest Arkansas)**

In addition to the 0 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No new constraints were found in this area.

**Cluster Group 13 (Northwest Missouri)**

In addition to the 285.8 MW of previously queued generation in the area, 0 MW of new interconnection service was studied. No new constraints were found in this area.

**Cluster Group 14 (South Central Oklahoma)**

In addition to the 220.8 MW of previously queued generation in the area, 41.4 MW of new interconnection service was studied. No new ERIS constraints were found in this area.

**Cluster Group 15 (reserved)**

This group has been retired and all prior Group 15 requests have been re-designated as Group 9/10 requests.



---

## **Stability Analysis**

---

The stability analysis was not re-performed for this restudy.

---

## Conclusion

---

The minimum cost of interconnecting 475.1 MW of new interconnection requests included in this Definitive Interconnection System Impact Study is estimated at \$30,111,834.27 for the Allocated Network Upgrades and Transmission Owner Interconnection Facilities are listed in Appendix E and F. These costs do not include the cost of upgrades of other transmission facilities listed in Appendix H which are Network Constraints.

These interconnection costs do not include any cost of Network Upgrades determined to be required by short circuit analysis. These studies will be performed if the Interconnection Customer executes the appropriate Interconnection Facilities Study Agreement and provides the required data along with demonstration of Site Control and the appropriate deposit. At the time of the Interconnection Facilities Study, a better determination of the interconnection facilities may be available.

The required interconnection costs listed in Appendices E, and F, and other upgrades associated with Network Constraints do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request (TSR) through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP Open Access Transmission Tariff (OATT).

---

# Appendix

---

**A: Generation Interconnection Requests Considered for Impact Study**

See next page.

## **A: Generation Interconnection Requests Considered for Impact Study**

| Request       | Amount | Service | Area     | Requested Point of Interconnection                  | Proposed Point of Interconnection                            | Requested In-Service Date | In Service Date Delayed Until no earlier than* |
|---------------|--------|---------|----------|---|--|---------------------------|--|
| ASGI-2012-006 | 22.50  | ER      | SUNCMKEC | Tap Hugoton - Rolla 69kV                            | Tap Hugoton - Rolla 69kV                                     |                           |  |
| GEN-2012-001  | 61.20  | ER      | SPS      | Tap Grassland - Borden County 230kV                 | Tap Grassland - Borden County 230kV                          | 11/30/2012                |  |
| GEN-2012-004  | 41.40  | ER/NR   | OKGE     | Pooleville 138kV                                    | Tap Ratliff - Pooleville (Carter County) 138kV               | 12/31/2013                |  |
| GEN-2012-007  | 120.00 | ER/NR   | SUNCMKEC | Rubart 115kV  | Rubart 115kV   | 4/1/2014                  | TBD  |
| GEN-2012-009  | 15.00  | ER      | SPS      | Mustang 230kV                                       | Mustang 230kV  | 4/1/2015                  |  |
| GEN-2012-010  | 15.00  | ER      | SPS      | Mustang 230kV                                       | Mustang 230kV  | 4/1/2015                  |  |
| GEN-2012-011  | 200.00 | ER      | SUNCMKEC | Tap Spearville - Post Rock 345kV (GEN-2011-017 Tap) | Tap Spearville - Post Rock 345kV (North of GEN-2011-017 Tap) | 11/1/2013                 | TBD  |
| <b>Total:</b> |        |         |          |   |  | <b>475.10</b>             |  |

\*Requests that dependent upon Priority Projects or Balanced Portfolio may be delayed until 12/31/2014. Other requests in-service date to be determined after Facility Study.

## **B: Prior Queued Interconnection Requests**

See next page.

## **B: Prior Queued Interconnection Requests**

| Request       | Amount | Area     | Requested/Proposed Point of Interconnection         | Status or In-Service Date    |
|---------------|--------|----------|---|------------------------------|
| ASGI-2010-006 | 150.00 | AECI     | Tap Fairfax (AECI) - Shilder (AEPW) 138kV           | AECI queue Affected Study    |
| ASGI-2010-010 | 42.20  | SPS      | Lovington 115kV                                     | Lea County Affected Study    |
| ASGI-2010-020 | 30.00  | SPS      | Tap LE-Tatum - LE-Crossroads 69kV                   | Lea County Affected Study    |
| ASGI-2010-021 | 15.00  | SPS      | Tap LE-Saunders Tap - LE-Anderson 69kV              | Lea County Affected Study    |
| ASGI-2011-001 | 28.80  | SPS      | Lovington 115kV                                     | On-Line                      |
| ASGI-2011-002 | 20.00  | SPS      | Herring 115kV                                       | On-Line                      |
| ASGI-2011-003 | 10.00  | SPS      | Hendricks 115kV                                     | On-Line                      |
| ASGI-2011-004 | 20.00  | SPS      | Pleasant Hill 69kV                                  | Under Study (DISIS-2011-002) |
| GEN-2001-014  | 96.00  | WFEC     | Ft Supply 138kV                                     | On-Line                      |
| GEN-2001-026  | 74.00  | WFEC     | Washita 138kV                                       | On-Line                      |
| GEN-2001-033  | 180.00 | SPS      | San Juan Tap 230kV                                  | On-Line at 120MW             |
| GEN-2001-036  | 80.00  | SPS      | Norton 115kV  | On-Line                      |
| GEN-2001-037  | 100.00 | OKGE     | FPL Moreland Tap 138kV                              | On-Line                      |
| GEN-2001-039A | 105.00 | SUNCMKEC | Tap Greensburg - Ft Dodge (Shooting Star Tap) 115kV | On-Line                      |
| GEN-2001-039M | 100.00 | SUNCMKEC | Central Plains Tap 115kV                            | On-Line                      |
| GEN-2002-004  | 200.00 | WERE     | Latham 345kV  | On-Line at 150MW             |
| GEN-2002-005  | 120.00 | WFEC     | Red Hills Tap 138kV                                 | On-Line                      |
| GEN-2002-008  | 240.00 | SPS      | Hitchland 345kV                                     | On-Line at 120MW             |
| GEN-2002-009  | 80.00  | SPS      | Hansford 115kV                                      | On-Line                      |
| GEN-2002-022  | 240.00 | SPS      | Bushland 230kV                                      | On-Line                      |
| GEN-2002-023N | 0.80   | NPPD     | Harmony 115kV                                       | On-Line                      |
| GEN-2002-025A | 150.00 | SUNCMKEC | Spearville 230kV                                    | On-Line                      |
| GEN-2003-004  | 100.00 | WFEC     | Washita 138kV                                       | On-Line                      |
| GEN-2003-005  | 100.00 | WFEC     | Anadarko - Paradise (Blue Canyon) 138kV             | On-Line                      |
| GEN-2003-006A | 200.00 | SUNCMKEC | Elm Creek 230kV                                     | On-Line                      |
| GEN-2003-019  | 250.00 | MIDW     | Smoky Hills Tap 230kV                               | On-Line                      |
| GEN-2003-020  | 160.00 | SPS      | Martin 115kV  | On-Line                      |
| GEN-2003-021N | 75.00  | NPPD     | Ainsworth Wind Tap 115kV                            | On-Line                      |
| GEN-2003-022  | 120.00 | AEPW     | Washita 138kV                                       | On-Line                      |
| GEN-2004-005N | 30.00  | NPPD     | St Francis 115kV                                    | On Suspension                |
| GEN-2004-014  | 154.50 | SUNCMKEC | Spearville 230kV                                    | On-Line at 100MW             |
| GEN-2004-020  | 27.00  | AEPW     | Washita 34.5kV                                      | On-Line                      |
| GEN-2004-023  | 20.60  | WFEC     | Washita 138kV                                       | On-Line                      |
| GEN-2004-023N | 75.00  | NPPD     | Columbus Co 115kV                                   | On-Line                      |
| GEN-2005-003  | 30.60  | WFEC     | Washita 138kV                                       | On-Line                      |
| GEN-2005-008  | 120.00 | OKGE     | Woodward 138kV                                      | On-Line                      |
| GEN-2005-012  | 250.00 | SUNCMKEC | Ironwood 345kV                                      | On-Line at 160MW             |
| GEN-2005-013  | 201.00 | WERE     | Tap Latham - Neosho (Caney River) 345kV             | On-Line                      |
| GEN-2006-002  | 101.00 | AEPW     | Sweetwater 230kV                                    | On-Line                      |
| GEN-2006-006  | 205.50 | SUNCMKEC | Spearville 345kV                                    | On Schedule for 2015         |
| GEN-2006-018  | 170.00 | SPS      | TUCO Interchange 230kV                              | On-Line                      |
| GEN-2006-020N | 42.00  | NPPD     | Bloomfield 115kV                                    | On-Line                      |
| GEN-2006-020S | 18.90  | SPS      | DWS Frisco 115kV                                    | On-Line                      |
| GEN-2006-021  | 101.00 | SUNCMKEC | Flat Ridge Tap 138kV                                | On-Line                      |
| GEN-2006-024S | 19.80  | WFEC     | Buffalo Bear Tap 69kV                               | On-Line                      |
| GEN-2006-026  | 604.00 | SPS      | Hobbs 230kV & Hobbs 115kV                           | On-Line                      |
| GEN-2006-031  | 75.00  | MIDW     | Knoll 115kV   | On-Line                      |

| Request          | Amount | Area     | Requested/Proposed Point of Interconnection            | Status or In-Service Date |
|------------------|--------|----------|--|---------------------------|
| GEN-2006-035     | 225.00 | AEPW     | Sweetwater 230kV                                       | On-Line at 132MW          |
| GEN-2006-037N1   | 75.00  | NPPD     | Broken Bow 115kV                                       | On Schedule for 2014      |
| GEN-2006-038N005 | 80.00  | NPPD     | Broken Bow 115kV                                       | On-Line                   |
| GEN-2006-038N019 | 80.00  | NPPD     | Petersburg North 115kV                                 | On-Line                   |
| GEN-2006-040     | 108.00 | SUNCMKEC | Mingo 115kV  | On Suspension             |
| GEN-2006-043     | 99.00  | AEPW     | Sweetwater 230kV                                       | On-Line                   |
| GEN-2006-044     | 370.00 | SPS      | Hitchland 345kV  | On-Line at 80MW           |
| GEN-2006-044N    | 40.50  | NPPD     | North Petersburg 115kV                                 | On-Line                   |
| GEN-2006-046     | 131.00 | OKGE     | Dewey 138kV  | On-Line                   |
| GEN-2006-047     | 240.00 | SPS      | Tap Bushland - Deaf Smith (Buffalo) 230kV              | On Suspension             |
| GEN-2007-011     | 135.00 | SUNCMKEC | Syracuse 115kV   | On Suspension             |
| GEN-2007-011N08  | 81.00  | NPPD     | Bloomfield 115kV                                       | On-Line                   |
| GEN-2007-021     | 201.00 | OKGE     | Tatonga 345kV  | On Schedule for 2014      |
| GEN-2007-025     | 300.00 | WERE     | Viola 345kV  | On-Line                   |
| GEN-2007-032     | 150.00 | WFEC     | Tap Clinton Junction - Clinton 138kV                   | On Suspension             |
| GEN-2007-038     | 200.00 | SUNCMKEC | Spearville 345kV                                       | On Schedule for 2015      |
| GEN-2007-040     | 200.00 | SUNCMKEC | Buckner 345kV  | On-Line at 132MW          |
| GEN-2007-043     | 200.00 | OKGE     | Minco 345kV  | On-Line                   |
| GEN-2007-044     | 300.00 | OKGE     | Tatonga 345kV  | On Schedule for 2014      |
| GEN-2007-046     | 199.50 | SPS      | Hitchland 115kV  | On Schedule for 2014      |
| GEN-2007-048     | 400.00 | SPS      | Tap Amarillo S - Swisher 230kV                         | On Schedule for 2014      |
| GEN-2007-050     | 170.00 | OKGE     | Woodward EHV 138kV                                     | On-Line at 150MW          |
| GEN-2007-052     | 150.00 | WFEC     | Anadarko 138kV   | On-Line                   |
| GEN-2007-062     | 765.00 | OKGE     | Woodward EHV 345kV                                     | On Schedule for 2014      |
| GEN-2008-003     | 101.00 | OKGE     | Woodward EHV 138kV                                     | On-Line                   |
| GEN-2008-008     | 60.00  | SPS      | Graham 69kV  | On Suspension             |
| GEN-2008-013     | 300.00 | OKGE     | Tap Wichita - Woodring (Hunter) 345kV                  | On-Line at 235MW          |
| GEN-2008-017     | 300.00 | SUNCMKEC | Setab 345kV  | On Schedule for 2015      |
| GEN-2008-018     | 250.00 | SPS      | Finney 345kV   | On Schedule for 2014      |
| GEN-2008-019     | 300.00 | OKGE     | Tatonga 345kV  | On Schedule for 2015      |
| GEN-2008-021     | 42.00  | WERE     | Wolf Creek 345kV                                       | On-Line                   |
| GEN-2008-022     | 300.00 | SPS      | Tap Eddy Co - Tolk (Chaves County) 345kV               | On Schedule for 2015      |
| GEN-2008-023     | 150.00 | AEPW     | Hobart Junction 138kV                                  | On-Line                   |
| GEN-2008-029     | 250.50 | OKGE     | Woodward EHV 138kV                                     | On Schedule for 2014      |
| GEN-2008-037     | 101.00 | WFEC     | Tap Washita - Blue Canyon Wind 138kV                   | On-Line                   |
| GEN-2008-044     | 197.80 | OKGE     | Tatonga 345kV  | On-Line                   |
| GEN-2008-047     | 300.00 | OKGE     | Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV | IA Pending                |
| GEN-2008-051     | 322.00 | SPS      | Potter County 345kV                                    | On-Line at 161MW          |
| GEN-2008-079     | 99.20  | SUNCMKEC | Tap Cudahy - Ft Dodge 115kV                            | On-Line                   |
| GEN-2008-086N02  | 200.00 | NPPD     | Tap Ft Randle - Columbus (Madison County) 230kV        | On Schedule for 2014      |
| GEN-2008-088     | 50.60  | SPS      | Vega 69kV  | On Schedule for 2014      |
| GEN-2008-092     | 201.00 | MIDW     | Post Rock 230kV  | IA Pending                |
| GEN-2008-098     | 100.80 | WERE     | Tap Lacygne - Wolf Creek (Anderson County) 345kV       | On Schedule for 2015      |
| GEN-2008-1190    | 60.00  | OPPD     | S1399 161kV  | On-Line                   |
| GEN-2008-123N    | 89.70  | NPPD     | Tap Guide Rock - Pauline (Rosemont) 115kV              | On Schedule for 2014      |
| GEN-2008-124     | 200.10 | SUNCMKEC | Ironwood 345kV   | On Schedule for 2016      |
| GEN-2008-129     | 80.00  | MIPU     | Pleasant Hill 161kV                                    | On-Line                   |
| GEN-2009-008     | 199.50 | MIDW     | South Hays 230kV                                       | On Schedule for 2015      |
| GEN-2009-020     | 48.60  | MIDW     | Tap Nekoma - Bazine (Walnut Creek) 69kV                | On Schedule for 2015      |



| Request      | Amount | Area     | Requested/Proposed Point of Interconnection            | Status or In-Service Date                      |
|--------------|--------|----------|--|--|
| GEN-2009-025 | 60.00  | OKGE     | Nardins 69kV   | On-Line  |
| GEN-2009-040 | 108.00 | WERE     | Marshall 115kV   | On Schedule for 2015                           |
| GEN-2010-001 | 300.00 | OKGE     | Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV | On Schedule for 2014 (204 MW) and 2015 (96 MW) |
| GEN-2010-003 | 100.80 | WERE     | Tap Lacygne - Wolf Creek (Anderson County) 345kV       | On Schedule for 2015                           |
| GEN-2010-005 | 300.00 | WERE     | Viola 345kV  | On-Line at 170MW                               |
| GEN-2010-006 | 205.00 | SPS      | Jones 230kV  | On-Line  |
| GEN-2010-009 | 165.60 | SUNCMKEC | Buckner 345kV  | On-Line  |
| GEN-2010-011 | 29.70  | OKGE     | Tatonga 345kV  | On Line  |
| GEN-2010-014 | 358.80 | SPS      | Hitchland 345kV  | On Schedule for 2016                           |
| GEN-2010-015 | 200.10 | SUNCMKEC | Spearville 345kV                                       | On Schedule for 2015                           |
| GEN-2010-020 | 20.00  | SPS      | Roswell 69kV   | On Suspension                                  |
| GEN-2010-036 | 4.60   | WERE     | 6th Street 115kV                                       | On-Line  |
| GEN-2010-040 | 300.00 | OKGE     | Cimarron 345kV   | On-Line  |
| GEN-2010-041 | 10.50  | OPPD     | S 1399 161kV   | IA Pending                                     |
| GEN-2010-045 | 197.80 | SUNCMKEC | Buckner 345kV  | IA Pending                                     |
| GEN-2010-046 | 56.00  | SPS      | TUCO Interchange 230kV                                 | On Schedule for 2016                           |
| GEN-2010-048 | 70.00  | MIDW     | Tap Beach Station - Redline 115kV                      | IA Pending                                     |
| GEN-2010-051 | 200.00 | NPPD     | Tap Twin Church - Hoskins 230kV                        | On Schedule for 2014                           |
| GEN-2010-055 | 4.50   | AEPW     | Wekiwa 138kV   | On-Line  |
| GEN-2010-056 | 151.20 | MIPU     | Tap Saint Joseph - Cooper 345kV                        | On Suspension                                  |
| GEN-2010-057 | 201.00 | MIDW     | Rice County 230kV                                      | On-Line  |
| GEN-2010-058 | 20.00  | SPS      | Chaves County 115kV                                    | On Suspension                                  |
| GEN-2010-061 | 180.00 | SUNCMKEC | Tap Post Rock - Spearville (GEN-2011-017T) 345kV       | Facility Study                                 |
| GEN-2011-007 | 250.10 | OKGE     | Tap Cimarron - Woodring (Mathewson) 345kV              | On Schedule for 2014                           |
| GEN-2011-008 | 600.00 | SUNCMKEC | Clark County 345kV                                     | IA Pending                                     |
| GEN-2011-010 | 100.80 | OKGE     | Minco 345kV  | On-Line  |
| GEN-2011-011 | 50.00  | KACP     | Iatan 345kV  | On-Line  |
| GEN-2011-014 | 201.00 | OKGE     | Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV | IA Pending                                     |
| GEN-2011-016 | 200.10 | SUNCMKEC | Spearville 345kV                                       | IA Pending                                     |
| GEN-2011-017 | 299.00 | SUNCMKEC | Tap Spearville - PostRock (GEN-2011-017T) 345kV        | IA Pending                                     |
| GEN-2011-018 | 73.60  | NPPD     | Steele City 115kV                                      | On Schedule for 2013                           |
| GEN-2011-019 | 299.00 | OKGE     | Woodward 345kV   | IA Pending                                     |
| GEN-2011-020 | 299.00 | OKGE     | Woodward 345kV   | IA Pending                                     |
| GEN-2011-021 | 299.00 | OKGE     | Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV | IA Pending                                     |
| GEN-2011-022 | 299.00 | SPS      | Hitchland 345kV  | IA Pending                                     |
| GEN-2011-025 | 82.30  | SPS      | Tap Floyd County - Crosby County 115kV                 | On Suspension                                  |
| GEN-2011-027 | 120.00 | NPPD     | Tap Twin Church - Hoskins 230kV (GEN-2010-51 Tap)      | IA Pending                                     |
| GEN-2011-037 | 7.00   | WFEC     | Blue Canyon 5 138kV                                    | On-Line  |
| GEN-2011-040 | 111.00 | OKGE     | Tap Ratliff - Pooleville 138kV                         | On Schedule for 2014                           |
| GEN-2011-045 | 205.00 | SPS      | Jones 230kV  | On-Line  |
| GEN-2011-046 | 27.00  | SPS      | Lopez 115kV  | On Schedule for 2013                           |
| GEN-2011-048 | 175.00 | SPS      | Mustang 230kV  | On Schedule for 2014                           |
| GEN-2011-049 | 250.00 | OKGE     | Border 345kV   | IA Pending                                     |
| GEN-2011-050 | 109.80 | AEPW     | Rush Springs Natural Gas Tap 138kV                     | On Suspension                                  |
| GEN-2011-051 | 104.40 | OKGE     | Tap Woodward - Tatonga 345kV                           | IA Pending                                     |
| GEN-2011-054 | 300.00 | OKGE     | Cimarron 345kV   | On Schedule for 2013 (200 MW) and 2014 (99 MW) |
| GEN-2011-055 | 52.80  | OPPD     | South Sterling 69kV                                    | Facility Study                                 |

| Request                             | Amount | Area            | Requested/Proposed Point of Interconnection | Status or In-Service Date |
|-------------------------------------|--------|-----------------|---|---------------------------|
| GEN-2011-056                        | 3.60   | NPPD            | Jeffrey 115kV                               | On-Line                   |
| GEN-2011-056A                       | 3.60   | NPPD            | John 1 115kV                                | On-Line                   |
| GEN-2011-056B                       | 4.50   | NPPD            | John 2 115kV                                | On-Line                   |
| GEN-2011-057                        | 150.40 | WERE            | Creswell 138kV                              | On Schedule for 2014      |
| Gray County Wind (Montezuma)        | 110.00 | SUNCMKEC        | Gray County Tap 115kV                       | On-Line                   |
| Llano Estacado (White Deer)         | 80.00  | SPS             | Llano Wind 115kV                            | On-Line                   |
| NPPD Distributed (Broken Bow)       | 8.30   | NPPD            | Broken Bow 115kV                            | On-Line                   |
| NPPD Distributed (Burt County Wind) | 12.00  | NPPD            | Tekamah & Oakland 115kV                     | On-Line                   |
| NPPD Distributed (Burwell)          | 3.00   | NPPD            | Ord 115kV                                   | On-Line                   |
| NPPD Distributed (Columbus Hydro)   | 45.00  | NPPD            | Columbus 115kV                              | On-Line                   |
| NPPD Distributed (Ord)              | 11.90  | NPPD            | Ord 115kV                                   | On-Line                   |
| NPPD Distributed (Stuart)           | 2.10   | NPPD            | Ainsworth 115kV                             | On-Line                   |
| SPS Distributed (Dumas 19th St)     | 20.00  | SPS             | Dumas 19th Street 115kV                     | On-Line                   |
| SPS Distributed (Etter)             | 20.00  | SPS             | Etter 115kV                                 | On-Line                   |
| SPS Distributed (Hopi)              | 10.00  | SPS             | Hopi 115kV                                  | On-Line                   |
| SPS Distributed (Jal)               | 10.00  | SPS             | S Jal 115kV                                 | On-Line                   |
| SPS Distributed (Lea Road)          | 10.00  | SPS             | Lea Road 115kV                              | On-Line                   |
| SPS Distributed (Monument)          | 10.00  | SPS             | Monument 115kV                              | On-Line                   |
| SPS Distributed (Moore E)           | 25.00  | SPS             | Moore East 115kV                            | On-Line                   |
| SPS Distributed (Ocotillo)          | 10.00  | SPS             | S_Jal 115kV                                 | On-Line                   |
| SPS Distributed (Sherman)           | 20.00  | SPS             | Sherman 115kV                               | On-Line                   |
| SPS Distributed (Spearman)          | 10.00  | SPS             | Spearman 69kV                               | On-Line                   |
| SPS Distributed (TC-Texas County)   | 20.00  | SPS             | Texas County 115kV                          | On-Line                   |
| <b>Total:</b>                       |        | <b>22,894.4</b> |   |                           |

## **C: Study Groupings**

See next page

## C. Study Groups

| <b>GROUP 1: WOODWARD AREA</b> |                 |             |   |
|-------------------------------|-----------------|-------------|---|
| <b>Request</b>                | <b>Capacity</b> | <b>Area</b> | <b>Proposed Point of Interconnection</b>  |
| GEN-2001-014                  | 96.00           | WFEC        | Ft Supply 138kV                           |
| GEN-2001-037                  | 100.00          | OKGE        | FPL Moreland Tap 138kV                    |
| GEN-2005-008                  | 120.00          | OKGE        | Woodward 138kV                            |
| GEN-2006-024S                 | 19.80           | WFEC        | Buffalo Bear Tap 69kV                     |
| GEN-2006-046                  | 131.00          | OKGE        | Dewey 138kV                               |
| GEN-2007-021                  | 201.00          | OKGE        | Tatonga 345kV                             |
| GEN-2007-043                  | 200.00          | OKGE        | Minco 345kV                               |
| GEN-2007-044                  | 300.00          | OKGE        | Tatonga 345kV                             |
| GEN-2007-050                  | 170.00          | OKGE        | Woodward EHV 138kV                        |
| GEN-2007-062                  | 765.00          | OKGE        | Woodward EHV 345kV                        |
| GEN-2008-003                  | 101.00          | OKGE        | Woodward EHV 138kV                        |
| GEN-2008-019                  | 300.00          | OKGE        | Tatonga 345kV                             |
| GEN-2008-029                  | 250.50          | OKGE        | Woodward EHV 138kV                        |
| GEN-2008-044                  | 197.80          | OKGE        | Tatonga 345kV                             |
| GEN-2010-011                  | 29.70           | OKGE        | Tatonga 345kV                             |
| GEN-2010-040                  | 300.00          | OKGE        | Cimarron 345kV                            |
| GEN-2011-007                  | 250.10          | OKGE        | Tap Cimarron - Woodring (Mathewson) 345kV |
| GEN-2011-010                  | 100.80          | OKGE        | Minco 345kV                               |
| GEN-2011-019                  | 299.00          | OKGE        | Woodward 345kV                            |
| GEN-2011-020                  | 299.00          | OKGE        | Woodward 345kV                            |
| GEN-2011-051                  | 104.40          | OKGE        | Tap Woodward - Tatonga 345kV              |
| GEN-2011-054                  | 300.00          | OKGE        | Cimarron 345kV                            |
| <b>PRIOR QUEUED SUBTOTAL</b>  | <b>4,635.10</b> |             |   |
| <b>AREA TOTAL</b>             | <b>4,635.10</b> |             |   |

**GROUP 2: HITCHLAND AREA**

| Request                           | Capacity        | Area | Proposed Point of Interconnection                      |
|-----------------------------------|-----------------|------|--|
| ASGI-2011-002                     | 20.00           | SPS  | Herring 115kV  |
| GEN-2002-008                      | 240.00          | SPS  | Hitchland 345kV  |
| GEN-2002-009                      | 80.00           | SPS  | Hansford 115kV   |
| GEN-2003-020                      | 160.00          | SPS  | Martin 115kV   |
| GEN-2006-020S                     | 18.90           | SPS  | DWS Frisco 115kV                                       |
| GEN-2006-044                      | 370.00          | SPS  | Hitchland 345kV  |
| GEN-2007-046                      | 199.50          | SPS  | Hitchland 115kV  |
| GEN-2008-047                      | 300.00          | OKGE | Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV |
| GEN-2010-001                      | 300.00          | OKGE | Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV |
| GEN-2010-014                      | 358.80          | SPS  | Hitchland 345kV  |
| GEN-2011-014                      | 201.00          | OKGE | Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV |
| GEN-2011-021                      | 299.00          | OKGE | Tap Hitchland - Woodward Dbl Ckt (Beaver County) 345kV |
| GEN-2011-022                      | 299.00          | SPS  | Hitchland 345kV  |
| SPS Distributed (Dumas 19th St)   | 20.00           | SPS  | Dumas 19th Street 115kV                                |
| SPS Distributed (Etter)           | 20.00           | SPS  | Etter 115kV  |
| SPS Distributed (Moore E)         | 25.00           | SPS  | Moore East 115kV                                       |
| SPS Distributed (Sherman)         | 20.00           | SPS  | Sherman 115kV  |
| SPS Distributed (Spearman)        | 10.00           | SPS  | Spearman 69kV  |
| SPS Distributed (TC-Texas County) | 20.00           | SPS  | Texas County 115kV                                     |
| <b>PRIOR QUEUED SUBTOTAL</b>      | <b>2,961.20</b> |      |  |
| <b>AREA TOTAL</b>                 | <b>2,961.20</b> |      |  |

**GROUP 3: SPEARVILLE AREA**

| Request                         | Capacity        | Area     | Proposed Point of Interconnection                            |
|---------------------------------|-----------------|----------|--|
| GEN-2001-039A                   | 105.00          | SUNCMKEC | Tap Greensburg - Ft Dodge (Shooting Star Tap) 115kV          |
| GEN-2002-025A                   | 150.00          | SUNCMKEC | Spearville 230kV   |
| GEN-2004-014                    | 154.50          | SUNCMKEC | Spearville 230kV   |
| GEN-2005-012                    | 250.00          | SUNCMKEC | Ironwood 345kV   |
| GEN-2006-006                    | 205.50          | SUNCMKEC | Spearville 345kV   |
| GEN-2006-021                    | 101.00          | SUNCMKEC | Flat Ridge Tap 138kV   |
| GEN-2007-038                    | 200.00          | SUNCMKEC | Spearville 345kV   |
| GEN-2007-040                    | 200.00          | SUNCMKEC | Buckner 345kV  |
| GEN-2008-018                    | 250.00          | SPS      | Finney 345kV   |
| GEN-2008-079                    | 99.20           | SUNCMKEC | Tap Cudahy - Ft Dodge 115kV                                  |
| GEN-2008-124                    | 200.10          | SUNCMKEC | Ironwood 345kV   |
| GEN-2010-009                    | 165.60          | SUNCMKEC | Buckner 345kV  |
| GEN-2010-015                    | 200.10          | SUNCMKEC | Spearville 345kV   |
| GEN-2010-045                    | 197.80          | SUNCMKEC | Buckner 345kV  |
| GEN-2010-061                    | 180.00          | SUNCMKEC | Tap Post Rock - Spearville (GEN-2011-017T) 345kV             |
| GEN-2011-008                    | 600.00          | SUNCMKEC | Clark County 345kV   |
| GEN-2011-016                    | 200.10          | SUNCMKEC | Spearville 345kV   |
| GEN-2011-017                    | 299.00          | SUNCMKEC | Tap Spearville - PostRock (GEN-2011-017T) 345kV              |
| Gray County Wind (Montezuma)    | 110.00          | SUNCMKEC | Gray County Tap 115kV  |
| <b>PRIOR QUEUED SUBTOTAL</b>    | <b>3,867.90</b> |          |  |
| ASGI-2012-006                   | 22.50           | SUNCMKEC | Tap Hugoton - Rolla 69kV                                     |
| GEN-2012-007                    | 120.00          | SUNCMKEC | Rubart 115kV   |
| GEN-2012-011                    | 200.00          | SUNCMKEC | Tap Spearville - Post Rock 345kV (North of GEN-2011-017 Tap) |
| <b>CURRENT CLUSTER SUBTOTAL</b> | <b>342.50</b>   |          |  |
| <b>AREA TOTAL</b>               | <b>4,210.40</b> |          |  |

**GROUP 4/11: NW KANSAS AREA**

| Request                      | Capacity        | Area     | Proposed Point of Interconnection       |
|------------------------------|-----------------|----------|---|
| GEN-2001-039M                | 100.00          | SUNCMKEC | Central Plains Tap 115kV                |
| GEN-2003-006A                | 200.00          | SUNCMKEC | Elm Creek 230kV                         |
| GEN-2003-019                 | 250.00          | MIDW     | Smoky Hills Tap 230kV                   |
| GEN-2006-031                 | 75.00           | MIDW     | Knoll 115kV                             |
| GEN-2006-040                 | 108.00          | SUNCMKEC | Mingo 115kV                             |
| GEN-2007-011                 | 135.00          | SUNCMKEC | Syracuse 115kV                          |
| GEN-2008-017                 | 300.00          | SUNCMKEC | Setab 345kV                             |
| GEN-2008-092                 | 201.00          | MIDW     | Post Rock 230kV                         |
| GEN-2009-008                 | 199.50          | MIDW     | South Hays 230kV                        |
| GEN-2009-020                 | 48.60           | MIDW     | Tap Nekoma - Bazine (Walnut Creek) 69kV |
| GEN-2010-048                 | 70.00           | MIDW     | Tap Beach Station - Redline 115kV       |
| GEN-2010-057                 | 201.00          | MIDW     | Rice County 230kV                       |
| <b>PRIOR QUEUED SUBTOTAL</b> | <b>1,888.10</b> |          |   |
| <b>AREA TOTAL</b>            | <b>1,888.10</b> |          |   |

**GROUP 5: AMARILLO AREA**

| Request                      | Capacity        | Area | Proposed Point of Interconnection         |
|------------------------------|-----------------|------|---|
| GEN-2002-022                 | 240.00          | SPS  | Bushland 230kV                            |
| GEN-2006-047                 | 240.00          | SPS  | Tap Bushland - Deaf Smith (Buffalo) 230kV |
| GEN-2007-048                 | 400.00          | SPS  | Tap Amarillo S - Swisher 230kV            |
| GEN-2008-051                 | 322.00          | SPS  | Potter County 345kV                       |
| GEN-2008-088                 | 50.60           | SPS  | Vega 69kV                                 |
| Llano Estacado (White Deer)  | 80.00           | SPS  | Llano Wind 115kV                          |
| <b>PRIOR QUEUED SUBTOTAL</b> | <b>1,332.60</b> |      |   |
| <b>AREA TOTAL</b>            | <b>1,332.60</b> |      |   |

**GROUP 6: S-TX PANHANDLE/W-TX AREA**

| Request                         | Capacity        | Area | Proposed Point of Interconnection        |
|---------------------------------|-----------------|------|--|
| ASGI-2010-010                   | 42.20           | SPS  | Lovington 115kV                          |
| ASGI-2010-020                   | 30.00           | SPS  | Tap LE-Tatum - LE-Crossroads 69kV        |
| ASGI-2010-021                   | 15.00           | SPS  | Tap LE-Saunders Tap - LE-Anderson 69kV   |
| ASGI-2011-001                   | 28.80           | SPS  | Lovington 115kV                          |
| ASGI-2011-003                   | 10.00           | SPS  | Hendricks 115kV                          |
| ASGI-2011-004                   | 20.00           | SPS  | Pleasant Hill 69kV                       |
| GEN-2001-033                    | 180.00          | SPS  | San Juan Tap 230kV                       |
| GEN-2001-036                    | 80.00           | SPS  | Norton 115kV                             |
| GEN-2006-018                    | 170.00          | SPS  | TUCO Interchange 230kV                   |
| GEN-2006-026                    | 604.00          | SPS  | Hobbs 230kV & Hobbs 115kV                |
| GEN-2008-008                    | 60.00           | SPS  | Graham 69kV                              |
| GEN-2008-022                    | 300.00          | SPS  | Tap Eddy Co - Tolk (Chaves County) 345kV |
| GEN-2010-006                    | 205.00          | SPS  | Jones 230kV                              |
| GEN-2010-020                    | 20.00           | SPS  | Roswell 69kV                             |
| GEN-2010-046                    | 56.00           | SPS  | TUCO Interchange 230kV                   |
| GEN-2010-058                    | 20.00           | SPS  | Chaves County 115kV                      |
| GEN-2011-025                    | 82.30           | SPS  | Tap Floyd County - Crosby County 115kV   |
| GEN-2011-045                    | 205.00          | SPS  | Jones 230kV                              |
| GEN-2011-046                    | 27.00           | SPS  | Lopez 115kV                              |
| GEN-2011-048                    | 175.00          | SPS  | Mustang 230kV                            |
| SPS Distributed (Hopi)          | 10.00           | SPS  | Hopi 115kV                               |
| SPS Distributed (Jal)           | 10.00           | SPS  | S_Jal 115kV                              |
| SPS Distributed (Lea Road)      | 10.00           | SPS  | Lea Road 115kV                           |
| SPS Distributed (Monument)      | 10.00           | SPS  | Monument 115kV                           |
| SPS Distributed (Ocotillo)      | 10.00           | SPS  | S_Jal 115kV                              |
| <b>PRIOR QUEUED SUBTOTAL</b>    | <b>2,380.30</b> |      |  |
| GEN-2012-001                    | 61.20           | SPS  | Tap Grassland - Borden County 230kV      |
| GEN-2012-009                    | 15.00           | SPS  | Mustang 230kV                            |
| GEN-2012-010                    | 15.00           | SPS  | Mustang 230kV                            |
| <b>CURRENT CLUSTER SUBTOTAL</b> | <b>91.20</b>    |      |  |
| <b>AREA TOTAL</b>               | <b>2,471.50</b> |      |  |

**GROUP 7: SW-OKLAHOMA AREA**

| Request                      | Capacity        | Area | Proposed Point of Interconnection       |
|------------------------------|-----------------|------|---|
| GEN-2001-026                 | 74.00           | WFEC | Washita 138kV                           |
| GEN-2002-005                 | 120.00          | WFEC | Red Hills Tap 138kV                     |
| GEN-2003-004                 | 100.00          | WFEC | Washita 138kV                           |
| GEN-2003-005                 | 100.00          | WFEC | Anadarko - Paradise (Blue Canyon) 138kV |
| GEN-2003-022                 | 120.00          | AEPW | Washita 138kV                           |
| GEN-2004-020                 | 27.00           | AEPW | Washita 34.5kV                          |
| GEN-2004-023                 | 20.60           | WFEC | Washita 138kV                           |
| GEN-2005-003                 | 30.60           | WFEC | Washita 138kV                           |
| GEN-2006-002                 | 101.00          | AEPW | Sweetwater 230kV                        |
| GEN-2006-035                 | 225.00          | AEPW | Sweetwater 230kV                        |
| GEN-2006-043                 | 99.00           | AEPW | Sweetwater 230kV                        |
| GEN-2007-032                 | 150.00          | WFEC | Tap Clinton Junction - Clinton 138kV    |
| GEN-2007-052                 | 150.00          | WFEC | Anadarko 138kV                          |
| GEN-2008-023                 | 150.00          | AEPW | Hobart Junction 138kV                   |
| GEN-2008-037                 | 101.00          | WFEC | Tap Washita - Blue Canyon Wind 138kV    |
| GEN-2011-037                 | 7.00            | WFEC | Blue Canyon 5 138kV                     |
| GEN-2011-049                 | 250.00          | OKGE | Border 345kV                            |
| <b>PRIOR QUEUED SUBTOTAL</b> | <b>1,825.20</b> |      |   |
| <b>AREA TOTAL</b>            | <b>1,825.20</b> |      |   |

**GROUP 8: N-OK/S-KS AREA**

| Request                      | Capacity        | Area | Proposed Point of Interconnection                |
|------------------------------|-----------------|------|--|
| ASGI-2010-006                | 150.00          | AECI | Tap Fairfax (AECI) - Shilder (AEPW) 138kV        |
| GEN-2002-004                 | 200.00          | WERE | Latham 345kV                                     |
| GEN-2005-013                 | 201.00          | WERE | Tap Latham - Neosho (Caney River) 345kV          |
| GEN-2007-025                 | 300.00          | WERE | Viola 345kV                                      |
| GEN-2008-013                 | 300.00          | OKGE | Tap Wichita - Woodring (Hunter) 345kV            |
| GEN-2008-021                 | 42.00           | WERE | Wolf Creek 345kV                                 |
| GEN-2008-098                 | 100.80          | WERE | Tap Lacygne - Wolf Creek (Anderson County) 345kV |
| GEN-2009-025                 | 60.00           | OKGE | Nardins 69kV                                     |
| GEN-2010-003                 | 100.80          | WERE | Tap Lacygne - Wolf Creek (Anderson County) 345kV |
| GEN-2010-005                 | 300.00          | WERE | Viola 345kV                                      |
| GEN-2010-055                 | 4.50            | AEPW | Wekiwa 138kV                                     |
| GEN-2011-057                 | 150.40          | WERE | Creswell 138kV                                   |
| <b>PRIOR QUEUED SUBTOTAL</b> | <b>1,909.50</b> |      |  |
| <b>AREA TOTAL</b>            | <b>1,909.50</b> |      |  |



| <b>GROUP 9/10: NEBRASKA AREA</b>    |                 |             |   |
|-------------------------------------|-----------------|-------------|---|
| <b>Request</b>                      | <b>Capacity</b> | <b>Area</b> | <b>Proposed Point of Interconnection</b>          |
| GEN-2002-023N                       | 0.80            | NPPD        | Harmony 115kV                                     |
| GEN-2003-021N                       | 75.00           | NPPD        | Ainsworth Wind Tap 115kV                          |
| GEN-2004-005N                       | 30.00           | NPPD        | St Francis 115kV                                  |
| GEN-2004-023N                       | 75.00           | NPPD        | Columbus Co 115kV                                 |
| GEN-2006-020N                       | 42.00           | NPPD        | Bloomfield 115kV                                  |
| GEN-2006-037N1                      | 75.00           | NPPD        | Broken Bow 115kV                                  |
| GEN-2006-038N005                    | 80.00           | NPPD        | Broken Bow 115kV                                  |
| GEN-2006-038N019                    | 80.00           | NPPD        | Petersburg North 115kV                            |
| GEN-2006-044N                       | 40.50           | NPPD        | North Petersburg 115kV                            |
| GEN-2007-011N08                     | 81.00           | NPPD        | Bloomfield 115kV                                  |
| GEN-2008-086N02                     | 200.00          | NPPD        | Tap Ft Randle - Columbus (Madison County) 230kV   |
| GEN-2008-1190                       | 60.00           | OPPD        | S1399 161kV                                       |
| GEN-2008-123N                       | 89.70           | NPPD        | Tap Guide Rock - Pauline (Rosemont) 115kV         |
| GEN-2009-040                        | 108.00          | WERE        | Marshall 115kV                                    |
| GEN-2010-041                        | 10.50           | OPPD        | S 1399 161kV                                      |
| GEN-2010-051                        | 200.00          | NPPD        | Tap Twin Church - Hoskins 230kV                   |
| GEN-2011-018                        | 73.60           | NPPD        | Steele City 115kV                                 |
| GEN-2011-027                        | 120.00          | NPPD        | Tap Twin Church - Hoskins 230kV (GEN-2010-51 Tap) |
| GEN-2011-055                        | 52.80           | OPPD        | South Sterling 69kV                               |
| GEN-2011-056                        | 3.60            | NPPD        | Jeffrey 115kV                                     |
| GEN-2011-056A                       | 3.60            | NPPD        | John 1 115kV                                      |
| GEN-2011-056B                       | 4.50            | NPPD        | John 2 115kV                                      |
| NPPD Distributed (Broken Bow)       | 8.30            | NPPD        | Broken Bow 115kV                                  |
| NPPD Distributed (Burt County Wind) | 12.00           | NPPD        | Tekamah & Oakland 115kV                           |
| NPPD Distributed (Burwell)          | 3.00            | NPPD        | Ord 115kV   |
| NPPD Distributed (Columbus Hydro)   | 45.00           | NPPD        | Columbus 115kV                                    |
| NPPD Distributed (Ord)              | 11.90           | NPPD        | Ord 115kV   |
| NPPD Distributed (Stuart)           | 2.10            | NPPD        | Ainsworth 115kV                                   |
| <b>PRIOR QUEUED SUBTOTAL</b>        | <b>1,587.90</b> |             |   |
| <b>AREA TOTAL</b>                   | <b>1,587.90</b> |             |   |

**GROUP 12: NW-AR AREA**

| Request           | Capacity    | Area | Proposed Point of Interconnection |
|-------------------|-------------|------|-----------------------------------|
| <b>AREA TOTAL</b> | <b>0.00</b> |      |                                   |

**GROUP 13: NW MISSOURI AREA**

| Request                      | Capacity      | Area | Proposed Point of Interconnection |
|------------------------------|---------------|------|-----------------------------------|
| GEN-2008-129                 | 80.00         | MIPU | Pleasant Hill 161kV               |
| GEN-2010-036                 | 4.60          | WERE | 6th Street 115kV                  |
| GEN-2010-056                 | 151.20        | MIPU | Tap Saint Joseph - Cooper 345kV   |
| GEN-2011-011                 | 50.00         | KACP | Iatan 345kV                       |
| <b>PRIOR QUEUED SUBTOTAL</b> | <b>285.80</b> |      |                                   |
| <b>AREA TOTAL</b>            | <b>285.80</b> |      |                                   |

**GROUP 14: S-OKLAHOMA AREA**

| Request                         | Capacity      | Area | Proposed Point of Interconnection              |
|---------------------------------|---------------|------|--|
| GEN-2011-040                    | 111.00        | OKGE | Tap Ratliff - Pooleville 138kV                 |
| GEN-2011-050                    | 109.80        | AEPW | Rush Springs Natural Gas Tap 138kV             |
| <b>PRIOR QUEUED SUBTOTAL</b>    | <b>220.80</b> |      |  |
| GEN-2012-004                    | 41.40         | OKGE | Tap Ratliff - Pooleville (Carter County) 138kV |
| <b>CURRENT CLUSTER SUBTOTAL</b> | <b>41.40</b>  |      |  |
| <b>AREA TOTAL</b>               | <b>262.20</b> |      |  |

|   |                 |           |
|---|-----------------|-----------|
| <b>CLUSTER TOTAL (CURRENT STUDY)</b>          | <b>475.1</b>    | <b>MW</b> |
| <b>PQ TOTAL (PRIOR QUEUED)</b>                | <b>22,894.4</b> | <b>MW</b> |
| <b>CLUSTER TOTAL (INCLUDING PRIOR QUEUED)</b> | <b>23,369.5</b> | <b>MW</b> |

### D: Proposed Point of Interconnection One line Diagrams

**ASGI-2012-006**

\*\*\*Facility Study one-line by Interconnecting Transmission Owner\*\*


**GEN-2012-001**

\*\*\*Please refer to the Facility Study for an updated one-line\*\*\*


**GEN-2012-004**

\*\*\*Please refer to the Facility Study for an updated one-line\*\*\*


**GEN-2012-007**




**GEN-2012-009**



**GEN-2012-010**



**GEN-2012-011**



## **E: Cost Allocation per Interconnection Request (Including Prior Queued Upgrades)**

Important Note:

**\*\*WITHDRAWAL OF HIGHER QUEUED PROJECTS WILL CAUSE A RESTUDY  
AND MAY RESULT IN HIGHER INTERCONNECTION COSTS\*\***

This section shows each Generation Interconnection Request Customer, their current study impacted Network Upgrades, and the previously allocated upgrades upon which they rely to accommodate their interconnection to the transmission system.

The costs associated with the current study Network Upgrades are allocated to the Customers shown in this report.

In addition should a higher queued request, defined as one this study includes as a prior queued request, withdraw, the Network Upgrades assigned to the withdrawn request may be reallocated to the remaining requests that have an impact on the Network Upgrade under a restudy. Also, should a Interconnection Request choose to go into service prior to the operation date of any necessary Network Upgrades, the costs associated with those upgrades may be reallocated to the impacted Interconnection Request. The actual costs allocated to each Generation Interconnection Request Customer will be determined at the time of a restudy.

The required interconnection costs listed do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT. In addition, costs associated with a short circuit analysis will be allocated should the Interconnection Request Customer choose to execute a Facility Study Agreement.

# Appendix E. Cost Allocation Per Request

(Including Previously Allocated Network Upgrades\*)

| Interconnection Request and Upgrades   | Upgrade Type         | Allocated Cost | Upgrade Cost     |
|--|----------------------|----------------|------------------|
| <b>ASGI-2012-006</b>   |                      |                |                  |
| ASGI 2012-006 Interconnection Costs<br>See Online Diagram  | Current Study        | \$100,000.00   | \$100,000.00     |
| Dobson - Gano 115kV CKT 1<br>Replace terminal equipment  | Current Study        | \$3,658.57     | \$82,481.09      |
| Garden City - Kansas Ave Water Treatment Plant 115kV CKT1<br>Replace terminal equipment  | Current Study        | \$4,972.34     | \$112,722.18     |
| Beaver County - Buckner 345kV<br>Build approximately 90 miles of 345kV from Beaver County - Gray County @ 3000 amps  | Previously Allocated |                | \$170,209,050.00 |
| Beaver County - Woodward 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)  | Previously Allocated |                | \$226,040,727.00 |
| Beaver County 345kV Expansion<br>Beaver County Expansion: Tap & Tie in Hitchland - Woodward 345kV CKT 2  | Previously Allocated |                | \$3,500,000.00   |
| Clark - Thistle 345kV Dbl CKT<br>Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)  | Previously Allocated |                | \$426,504,292.00 |
| Fort Dodge - North Fort Dodge 115kV CKT 2<br>Construct approximately 1 mile of new 115kV for 2nd circuit   | Previously Allocated |                | \$6,113,000.00   |
| GEN-2011-017 Tap - Mullergren 345kV CKT 1<br>Build approximately 55 miles of new 345kV and add new terminal at GEN-2011-017 Tap 345kV  | Previously Allocated |                | \$67,000,000.00  |
| Hitchland - Beaver County 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)   | Previously Allocated |                | \$226,040,727.00 |
| Hitchland 345/230kV Autotransformer CKT 2<br>Priority Project: Hitchland 345/230kV Autotransformer CKT 2 (Total Project E&C Cost Shown).   | Previously Allocated |                | \$8,883,760.00   |
| Matthewson - Cimarron 345kV CKT 2<br>Build second 345kV circuit from Matthewson - Cimarron @ 3000 amps   | Previously Allocated |                | \$42,903,753.00  |
| Mullergren 345/230/13kV Transformer CKT 1<br>Build new 345/230/13kV transformer at Mullergren  | Previously Allocated |                | \$8,000,000.00   |
| Mullergren 345/230kV Substation<br>Build new 345/230kV substation for terminating GEN-2011-017 Tap - Mullergren 345kV line, Mullergren 345/230/13kV transformer, and Mullergren - Great Bend 230kV | Previously Allocated |                | \$25,000,000.00  |

\* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades   | Upgrade Type               | Allocated Cost      | Upgrade Cost     |
|--|----------------------------|---------------------|------------------|
| Spearville - Clark 345KV Dbl CKT<br>Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)                 | Previously Allocated       |                     | \$426,504,292.00 |
| Tatonga - Matthewson 345kV CKT 2<br>Build second 345kV circuit from Tatonga - Matthewson @ 3000 amps   | Previously Allocated       |                     | \$104,260,473.00 |
| Thistle - Wichita 345KV Dbl CKT<br>Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)                             | Previously Allocated       |                     | \$426,504,292.00 |
| Woodward XFMR 345/138/13.8kV CKT 2<br>Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown). | Previously Allocated       |                     | \$249,247,072.00 |
|  | <b>Current Study Total</b> | <b>\$108,630.91</b> |                  |

### GEN-2012-001

|  |                      |                |                  |
|--|----------------------|----------------|------------------|
| GEN-2012-001 Interconnection Costs<br>See Online Diagram.  | Current Study        | \$7,316,677.00 | \$7,316,677.00   |
| Beaver County - Woodward 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)  | Previously Allocated |                | \$226,040,727.00 |
| Beaver County 345kV Expansion<br>Beaver County Expansion: Tap & Tie in Hitchland - Woodward 345kV CKT 2                        | Previously Allocated |                | \$3,500,000.00   |
| Border - Tuco Interchange 345KV CKT 1<br>Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)        | Previously Allocated |                | \$249,247,072.00 |
| Border - Woodward 345KV CKT 1<br>Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)                | Previously Allocated |                | \$249,247,072.00 |
| Hitchland - Beaver County 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown) | Previously Allocated |                | \$226,040,727.00 |
| Power System Stabilizers (PSS)<br>Install Power System Stabilizers @ Tolk(Units: 1,2) and Jones (Units: 1,2,3,4)               | Previously Allocated |                | \$300,000.00     |
| Thistle - Flat Ridge 138kV CKT 1<br>Priority Project: Thistle - Flat Ridge 138kV CKT 1 (Total Project E&C Cost Shown.)         | Previously Allocated |                | \$5,776,280.00   |
| Thistle - Wichita 345KV Dbl CKT<br>Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)           | Previously Allocated |                | \$426,504,292.00 |
| Thistle - Woodward 345KV Dbl CKT<br>Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)          | Previously Allocated |                | \$207,782,000.00 |
| Thistle 345/138KV Transformer CKT 1<br>Priority Project: Thistle 345/138kV Transformer CKT 1 (Total Project E&C Cost Shown.)   | Previously Allocated |                | \$6,585,986.00   |

\* Withdrawal of higher queued projects will cause a restudy and may result in higher costs



| <b>Interconnection Request and Upgrades</b>  | <b>Upgrade Type</b>        | <b>Allocated Cost</b> | <b>Upgrade Cost</b> |
|--|----------------------------|-----------------------|---------------------|
| TUCO Interchange 345/230/13.2KV Autotransformer CKT 2<br>Balanced Portfolio: TUCO 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)    | Previously Allocated       |                       | \$14,900,907.00     |
| Woodward XFMR 345/138/13.8kV CKT 2<br>Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown). | Previously Allocated       |                       | \$249,247,072.00    |
|  | <b>Current Study Total</b> | <b>\$7,316,677.00</b> |                     |
| <b>GEN-2012-004</b>  |                            |                       |                     |
| GEN-2012-004 Interconnection Costs<br>See Online Diagram.  | Current Study              | \$0.00                | \$0.00              |
|  | <b>Current Study Total</b> | <b>\$0.00</b>         |                     |
| <b>GEN-2012-007</b>  |                            |                       |                     |
| Dobson - Gano 115kV CKT 1<br>Replace terminal equipment  | Current Study              | \$78,822.52           | \$82,481.09         |
| Garden City - Kansas Ave Water Treatment Plant 115kV CKT1<br>Replace terminal equipment  | Current Study              | \$107,749.84          | \$112,722.18        |
| GEN-2012-007 Interconnection Costs<br>See Online Diagram.  | Current Study              | \$12,299,954.00       | \$12,299,954.00     |
| Beaver County - Buckner 345kV<br>Build approximately 90 miles of 345kV from Beaver County - Gray County @ 3000 amps                              | Previously Allocated       |                       | \$170,209,050.00    |
| Beaver County - Woodward 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)                    | Previously Allocated       |                       | \$226,040,727.00    |
| Beaver County 345kV Expansion<br>Beaver County Expansion: Tap & Tie in Hitchland - Woodward 345kV CKT 2  | Previously Allocated       |                       | \$3,500,000.00      |
| Clark - Thistle 345KV Dbl CKT<br>Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)                    | Previously Allocated       |                       | \$426,504,292.00    |
| Cleveland - Sooner 345KV CKT 1<br>Balanced Portfolio: Cleveland - Sooner 345kV CKT 1 (Total Project E&C Cost Shown).                             | Previously Allocated       |                       | \$58,692,000.00     |
| Fort Dodge - North Fort Dodge 115kV CKT 2<br>Construct approximately 1 mile of new 115kV for 2nd circuit   | Previously Allocated       |                       | \$6,113,000.00      |
| GEN-2011-017 Tap - Mullergren 345kV CKT 1<br>Build approximately 55 miles of new 345kV and add new terminal at GEN-2011-017 Tap 345kV            | Previously Allocated       |                       | \$67,000,000.00     |
| Hitchland - Beaver County 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)                   | Previously Allocated       |                       | \$226,040,727.00    |

\* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| <b>Interconnection Request and Upgrades</b>  | <b>Upgrade Type</b>        | <b>Allocated Cost</b>  | <b>Upgrade Cost</b> |
|--|----------------------------|------------------------|---------------------|
| Hitchland - Woodward 345kV CKT 2<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)  | Previously Allocated       |                        | \$215,877,433.00    |
| Hitchland 345/230kV Autotransformer CKT 2<br>Priority Project: Hitchland 345/230kV Autotransformer CKT 2 (Total Project E&C Cost Shown).   | Previously Allocated       |                        | \$8,883,760.00      |
| Matthewson - Cimarron 345kV CKT 2<br>Build second 345kV circuit from Matthewson - Cimarron @ 3000 amps   | Previously Allocated       |                        | \$42,903,753.00     |
| Mullergren 345/230/13kV Transformer CKT 1<br>Build new 345/230/13kV transformer at Mullergren  | Previously Allocated       |                        | \$8,000,000.00      |
| Mullergren 345/230kV Substation<br>Build new 345/230kV substation for terminating GEN-2011-017 Tap - Mullergren 345kV line, Mullergren 345/230/13kV transformer, and Mullergren - Great Bend 230kV | Previously Allocated       |                        | \$25,000,000.00     |
| North Fort Dodge - Spearville 115kV<br>DIS-2009-001-1 upgrade.   | Previously Allocated       |                        | \$9,660,000.00      |
| Spearville - Clark 345KV Dbl CKT<br>Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)   | Previously Allocated       |                        | \$426,504,292.00    |
| Tatonga - Matthewson 345kV CKT 2<br>Build second 345kV circuit from Tatonga - Matthewson @ 3000 amps   | Previously Allocated       |                        | \$104,260,473.00    |
| Thistle - Wichita 345KV Dbl CKT<br>Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)   | Previously Allocated       |                        | \$426,504,292.00    |
| Woodward XFMR 345/138/13.8kV CKT 2<br>Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown).   | Previously Allocated       |                        | \$249,247,072.00    |
|  | <b>Current Study Total</b> | <b>\$12,486,526.36</b> |                     |

### **GEN-2012-009**

|   |                      |              |                  |
|---|----------------------|--------------|------------------|
| GEN-2012-009 Interconnection Costs<br>See Online Diagram.   | Current Study        | \$0.00       | \$0.00           |
| Mustang - Yoakum 230kV CKT 1<br>Replace line traps at both terminals  | Current Study        | \$100,000.00 | \$200,000.00     |
| Beaver County - Woodward 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown) | Previously Allocated |              | \$226,040,727.00 |
| Beaver County 345kV Expansion<br>Beaver County Expansion: Tap & Tie in Hitchland - Woodward 345kV CKT 2                       | Previously Allocated |              | \$3,500,000.00   |
| Border - Tuco Interchange 345KV CKT 1<br>Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)       | Previously Allocated |              | \$249,247,072.00 |

\* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| <b>Interconnection Request and Upgrades</b>  | <b>Upgrade Type</b>        | <b>Allocated Cost</b> | <b>Upgrade Cost</b> |
|--|----------------------------|-----------------------|---------------------|
| Border - Woodward 345KV CKT 1<br>Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)                                  | Previously Allocated       |                       | \$249,247,072.00    |
| Hitchland - Beaver County 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)                   | Previously Allocated       |                       | \$226,040,727.00    |
| Nichols - Harrington Mid 230kV CKT 1<br>Per GEN-2008-051 LOIS: Rebuild approximately 1 mile of 230kV @ 1825 amps                                 | Previously Allocated       |                       | \$869,251.00        |
| Nichols - Harrington West 230kV CKT 1<br>Per GEN-2008-051 LOIS: Rebuild approximately 1 mile of 230kV @ 1825 amps                                | Previously Allocated       |                       | \$869,251.00        |
| Power System Stabilizers (PSS)<br>Install Power System Stabilizers @ Tolk(Units: 1,2) and Jones (Units: 1,2,3,4)                                 | Previously Allocated       |                       | \$300,000.00        |
| Thistle - Flat Ridge 138kV CKT 1<br>Priority Project: Thistle - Flat Ridge 138kV CKT 1 (Total Project E&C Cost Shown.)                           | Previously Allocated       |                       | \$5,776,280.00      |
| Thistle - Wichita 345KV Dbl CKT<br>Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)                             | Previously Allocated       |                       | \$426,504,292.00    |
| Thistle - Woodward 345KV Dbl CKT<br>Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)                            | Previously Allocated       |                       | \$207,782,000.00    |
| Thistle 345/138KV Transformer CKT 1<br>Priority Project: Thistle 345/138kV Transformer CKT 1 (Total Project E&C Cost Shown.)                     | Previously Allocated       |                       | \$6,585,986.00      |
| TUCO Interchange 345/230/13.2KV Autotransformer CKT 2<br>Balanced Portfolio: TUCO 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)    | Previously Allocated       |                       | \$14,900,907.00     |
| Woodward XFMR 345/138/13.8kV CKT 2<br>Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown). | Previously Allocated       |                       | \$249,247,072.00    |
|  | <b>Current Study Total</b> | \$100,000.00          |                     |

### GEN-2012-010

|   |                      |              |                  |
|---|----------------------|--------------|------------------|
| GEN-2012-010 Interconnection Costs<br>See Online Diagram.   | Current Study        | \$0.00       | \$0.00           |
| Mustang - Yoakum 230kV CKT 1<br>Replace line traps at both terminals  | Current Study        | \$100,000.00 | \$200,000.00     |
| Beaver County - Woodward 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown) | Previously Allocated |              | \$226,040,727.00 |
| Beaver County 345kV Expansion<br>Beaver County Expansion: Tap & Tie in Hitchland - Woodward 345kV CKT 2                       | Previously Allocated |              | \$3,500,000.00   |

\* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| <b>Interconnection Request and Upgrades</b>  | <b>Upgrade Type</b>        | <b>Allocated Cost</b> | <b>Upgrade Cost</b> |
|--|----------------------------|-----------------------|---------------------|
| Border - Tuco Interchange 345KV CKT 1<br>Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)                          | Previously Allocated       |                       | \$249,247,072.00    |
| Border - Woodward 345KV CKT 1<br>Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)                                  | Previously Allocated       |                       | \$249,247,072.00    |
| Hitchland - Beaver County 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)                   | Previously Allocated       |                       | \$226,040,727.00    |
| Nichols - Harrington Mid 230kV CKT 1<br>Per GEN-2008-051 LOIS: Rebuild approximately 1 mile of 230kV @ 1825 amps                                 | Previously Allocated       |                       | \$869,251.00        |
| Nichols - Harrington West 230kV CKT 1<br>Per GEN-2008-051 LOIS: Rebuild approximately 1 mile of 230kV @ 1825 amps                                | Previously Allocated       |                       | \$869,251.00        |
| Power System Stabilizers (PSS)<br>Install Power System Stabilizers @ Tolk(Units: 1,2) and Jones (Units: 1,2,3,4)                                 | Previously Allocated       |                       | \$300,000.00        |
| Thistle - Flat Ridge 138kV CKT 1<br>Priority Project: Thistle - Flat Ridge 138kV CKT 1 (Total Project E&C Cost Shown.)                           | Previously Allocated       |                       | \$5,776,280.00      |
| Thistle - Wichita 345KV Dbl CKT<br>Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)                             | Previously Allocated       |                       | \$426,504,292.00    |
| Thistle - Woodward 345KV Dbl CKT<br>Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)                            | Previously Allocated       |                       | \$207,782,000.00    |
| Thistle 345/138KV Transformer CKT 1<br>Priority Project: Thistle 345/138kV Transformer CKT 1 (Total Project E&C Cost Shown.)                     | Previously Allocated       |                       | \$6,585,986.00      |
| TUCO Interchange 345/230/13.2KV Autotransformer CKT 2<br>Balanced Portfolio: TUCO 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)    | Previously Allocated       |                       | \$14,900,907.00     |
| Woodward XFMR 345/138/13.8kV CKT 2<br>Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown). | Previously Allocated       |                       | \$249,247,072.00    |
|  | <b>Current Study Total</b> | <b>\$100,000.00</b>   |                     |

### GEN-2012-011

|   |                      |                 |                  |
|---|----------------------|-----------------|------------------|
| GEN-2012-011 Interconnection Costs<br>See Online Diagram.   | Current Study        | \$10,000,000.00 | \$10,000,000.00  |
| Beaver County - Buckner 345kV<br>Build approximately 90 miles of 345kV from Beaver County - Gray County @ 3000 amps           | Previously Allocated |                 | \$170,209,050.00 |
| Beaver County - Woodward 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown) | Previously Allocated |                 | \$226,040,727.00 |

\* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| <b>Interconnection Request and Upgrades</b>  | <b>Upgrade Type</b>        | <b>Allocated Cost</b> | <b>Upgrade Cost</b>    |
|--|----------------------------|-----------------------|------------------------|
| Beaver County 345kV Expansion<br>Beaver County Expansion: Tap & Tie in Hitchland - Woodward 345kV CKT 2  | Previously Allocated       |                       | \$3,500,000.00         |
| Border - Tuco Interchange 345KV CKT 1<br>Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)  | Previously Allocated       |                       | \$249,247,072.00       |
| Border - Woodward 345KV CKT 1<br>Balanced Portfolio: Tuco - Woodward 345kV CKT 1 (Total Project E&C Cost Shown)  | Previously Allocated       |                       | \$249,247,072.00       |
| Clark - Thistle 345KV Dbl CKT<br>Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)  | Previously Allocated       |                       | \$426,504,292.00       |
| GEN-2011-017 Tap - Mullergren 345kV CKT 1<br>Build approximately 55 miles of new 345kV and add new terminal at GEN-2011-017 Tap 345kV  | Previously Allocated       |                       | \$67,000,000.00        |
| Hitchland - Beaver County 345kV Dbl CKT<br>Priority Project: Hitchland - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)   | Previously Allocated       |                       | \$226,040,727.00       |
| Hitchland 345/230kV Autotransformer CKT 2<br>Priority Project: Hitchland 345/230kV Autotransformer CKT 2 (Total Project E&C Cost Shown).   | Previously Allocated       |                       | \$8,883,760.00         |
| Matthewson - Cimarron 345kV CKT 2<br>Build second 345kV circuit from Matthewson - Cimarron @ 3000 amps   | Previously Allocated       |                       | \$42,903,753.00        |
| Mullergren 345/230/13kV Transformer CKT 1<br>Build new 345/230/13kV transformer at Mullergren  | Previously Allocated       |                       | \$8,000,000.00         |
| Mullergren 345/230kV Substation<br>Build new 345/230kV substation for terminating GEN-2011-017 Tap - Mullergren 345kV line, Mullergren 345/230/13kV transformer, and Mullergren - Great Bend 230kV | Previously Allocated       |                       | \$25,000,000.00        |
| Spearville - Clark 345KV Dbl CKT<br>Priority Project: Spearville - Clark - Thistle Dbl 345kV CKT (Total Project E&C Cost Shown.)   | Previously Allocated       |                       | \$426,504,292.00       |
| Tatonga - Matthewson 345kV CKT 2<br>Build second 345kV circuit from Tatonga - Matthewson @ 3000 amps   | Previously Allocated       |                       | \$104,260,473.00       |
| Thistle - Wichita 345KV Dbl CKT<br>Priority Project: Thistle - Wichita Dbl 345kV CKT (Total Project E&C Cost Shown.)   | Previously Allocated       |                       | \$426,504,292.00       |
| Thistle - Woodward 345KV Dbl CKT<br>Priority Project: Thistle - Woodward Dbl 345kV CKT (Total Project E&C Cost Shown)  | Previously Allocated       |                       | \$207,782,000.00       |
| TUCO Interchange 345/230/13.2KV Autotransformer CKT 2<br>Balanced Portfolio: TUCO 345/230 kV Transformer CKT 2 (Total Project E&C Cost Shown)  | Previously Allocated       |                       | \$14,900,907.00        |
| Woodward XFMR 345/138/13.8kV CKT 2<br>Balanced Portfolio: Woodward 345/138kV Transformer CKT 2 & 50 MVAR Reactor (Total Project E&C Cost Shown).   | Previously Allocated       |                       | \$249,247,072.00       |
|  | <b>Current Study Total</b> |                       | <b>\$10,000,000.00</b> |

\* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| <b>Interconnection Request and Upgrades</b> | <b>Upgrade Type</b> | <b>Allocated Cost</b>  | <b>Upgrade Cost</b> |
|---|---------------------|------------------------|---------------------|
| <b>TOTAL CURRENT STUDY COSTS:</b>           |                     | <b>\$30,111,834.27</b> |                     |

\* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Tuesday, January 21, 2014



Page 8 of 8

## **F: Cost Allocation per Proposed Study Network Upgrade**

Important Note:

**\*\*WITHDRAWAL OF HIGHER QUEUED PROJECTS WILL CAUSE A RESTUDY  
AND MAY RESULT IN HIGHER INTERCONNECTION COSTS\*\***

This section shows each Direct Assigned Facility and Network Upgrade and the Generation Interconnection Request Customer(s) which have an impact in this study assuming all higher queued projects remain in the queue and achieve commercial operation.

The required interconnection costs listed do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT. In addition, costs associated with a short circuit analysis will be allocated should the Interconnection Request Customer choose to execute a Facility Study Agreement.

There may be additional costs allocated to each Customer. See Appendix E for more details.

# Appendix F. Cost Allocation by Upgrade

|  |                              |                        |
|--|------------------------------|------------------------|
| <b>ASGI 2012-006 Interconnection Costs</b>                       |                              | <b>\$100,000.00</b>    |
| See Online Diagram   |                              |                        |
|  | ASGI-2012-006                | \$100,000.00           |
|  | <b>Total Allocated Costs</b> | <b>\$100,000.00</b>    |
| <b>Dobson - Gano 115kV CKT 1</b>                                 |                              | <b>\$82,481.09</b>     |
| Replace terminal equipment                                       |                              |                        |
|  | ASGI-2012-006                | \$3,658.57             |
|  | GEN-2012-007                 | \$78,822.52            |
|  | <b>Total Allocated Costs</b> | <b>\$82,481.09</b>     |
| <b>Garden City - Kansas Ave Water Treatment Plant 115kV CKT1</b> |                              | <b>\$112,722.18</b>    |
| Replace terminal equipment                                       |                              |                        |
|  | ASGI-2012-006                | \$4,972.34             |
|  | GEN-2012-007                 | \$107,749.84           |
|  | <b>Total Allocated Costs</b> | <b>\$112,722.18</b>    |
| <b>GEN-2012-001 Interconnection Costs</b>                        |                              | <b>\$7,316,677.00</b>  |
| See Online Diagram.  |                              |                        |
|  | GEN-2012-001                 | \$7,316,677.00         |
|  | <b>Total Allocated Costs</b> | <b>\$7,316,677.00</b>  |
| <b>GEN-2012-004 Interconnection Costs</b>                        |                              | <b>\$0.00</b>          |
| See Online Diagram.  |                              |                        |
|  | GEN-2012-004                 | \$0.00                 |
|  | <b>Total Allocated Costs</b> | <b>\$0.00</b>          |
| <b>GEN-2012-007 Interconnection Costs</b>                        |                              | <b>\$12,299,954.00</b> |
| See Online Diagram.  |                              |                        |
|  | GEN-2012-007                 | \$12,299,954.00        |
|  | <b>Total Allocated Costs</b> | <b>\$12,299,954.00</b> |
| <b>GEN-2012-009 Interconnection Costs</b>                        |                              | <b>\$0.00</b>          |
| See Online Diagram.  |                              |                        |
|  | GEN-2012-009                 | \$0.00                 |
|  | <b>Total Allocated Costs</b> | <b>\$0.00</b>          |

\* Withdrawal of higher queued projects will cause a restudy and may result in higher costs



**GEN-2012-010 Interconnection Costs****\$0.00**

See Oonline Diagram.

GEN-2012-010 \$0.00

---

**Total Allocated Costs \$0.00**

---

**GEN-2012-011 Interconnection Costs****\$10,000,000.00**

See Oonline Diagram.

GEN-2012-011 \$10,000,000.00

---

**Total Allocated Costs \$10,000,000.00**

---

**Mustang - Yoakum 230kV CKT 1****\$200,000.00**

Replace line traps at both terminals

GEN-2012-009 \$100,000.00

GEN-2012-010 \$100,000.00

---

**Total Allocated Costs \$200,000.00**

---

\* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

## **G: Power Flow Analysis (Constraints For Mitigation)**

See next page.

| SOLUTION | GROUP     | SCENARIO | SEASON | SOURCE      | DIRECTION | MONITORED ELEMENT   | RATEB |         | TC%LOADING |  | CONTINGENCY |
|----------|-----------|----------|--------|-------------|-----------|---|-------|---------|------------|--|-------------|
|          |           |          |        |             |           |   | (MVA) | TDF     | (% MVA)    |  |             |
| FDNS     | 0         | 0        | 19SP   | ASGI_12_006 | FROM->TO  | DOBSON - GANO 3 115.00 115KV CKT 1                            | 148.2 | 0.36915 | 101.3103   | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1           |             |
| FDNS     | 0         | 0        | 19SP   | G12_007     | FROM->TO  | DOBSON - GANO 3 115.00 115KV CKT 1                            | 148.2 | 0.42032 | 101.3103   | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1           |             |
| FDNS     | 0         | 0        | 24SP   | G12_007     | FROM->TO  | GARDEN CITY - KANSAS AVENUE WATER TREATMENT PLANT 115KV CKT 1 | 119.5 | 0.21662 | 116.6179   | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1           |             |
| FDNS     | 0         | 0        | 19SP   | G12_007     | FROM->TO  | GARDEN CITY - KANSAS AVENUE WATER TREATMENT PLANT 115KV CKT 1 | 119.5 | 0.21636 | 121.9964   | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1           |             |
| FDNS     | 03NR      | 0        | 14G    | G12_007     | FROM->TO  | DOBSON - GANO 3 115.00 115KV CKT 1                            | 148.2 | 0.11589 | 118.0312   | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1           |             |
| FDNS     | 00NR      | 0        | 19SP   | G12_007     | FROM->TO  | DOBSON - GANO 3 115.00 115KV CKT 1                            | 148.2 | 0.05552 | 101.7045   | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1           |             |
| FDNS     | 03NR      | 0        | 14G    | G12_007     | FROM->TO  | GARDEN CITY - KANSAS AVENUE WATER TREATMENT PLANT 115KV CKT 1 | 119.5 | 0.03234 | 107.5977   | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1           |             |
| FDNS     | 00G12_009 | 0        | 14SP   | G12_009     | FROM->TO  | MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1       | 351   | 0.67723 | 99.8       | AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 |             |
| FDNS     | 00G12_009 | 0        | 19SP   | G12_009     | FROM->TO  | MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1       | 351   | 0.67641 | 103.0699   | AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 |             |
| FDNS     | 00G12_010 | 0        | 14SP   | G12_010     | FROM->TO  | MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1       | 351   | 0.67723 | 99.8       | AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 |             |
| FDNS     | 00G12_010 | 0        | 19SP   | G12_010     | FROM->TO  | MUSTANG STATION - YOAKUM COUNTY INTERCHANGE 230KV CKT 1       | 351   | 0.67641 | 103.0699   | AMOCO WASSON SWITCHING STATION - MUSTANG STATION 230KV CKT 1 |             |

## **H: Power Flow Analysis (Other Constraints Not Requiring Mitigation)**

See next page.

| SOLUTION      | GROUP     | SCENARIO | SEASON | SOURCE      | DIRECTION | MONITORED ELEMENT   | RATEB<br>(MVA) | TDF     | TC%LOADING<br>(% MVA) | CONTINGENCY   |
|---------------|-----------|----------|--------|-------------|-----------|---|----------------|---------|-----------------------|---|
| FDNS          | 0         |          | 0 19SP | ASGI_12_006 | FROM->TO  | GARDEN CITY - KANSAS AVENUE WATER TREATMENT PLANT 115KV CKT 1       | 119.5          | 0.18987 | 121.9964              | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1          |
| FDNS          | 0         |          | 0 24SP | ASGI_12_006 | FROM->TO  | GARDEN CITY - KANSAS AVENUE WATER TREATMENT PLANT 115KV CKT 1       | 119.5          | 0.19013 | 116.6179              | HOLCOMB (HOLCOMB) 345/115/13.8KV TRANSFORMER CKT 1          |
| FNSL-Blown up | 03ALL     |          | 0 14G  | G12_001     |           | Non-converged Contingency   | 0              | 0.14657 | -                     | DBL-WICH-THI  |
| FNSL-Blown up | 03ALL     |          | 0 14G  | G12_001     |           | Non-converged Contingency   | 0              | 0.13121 | -                     | DBL-TGA-MATT  |
| FNSL-Blown up | 03ALL     |          | 0 14G  | G12_001     |           | Non-converged Contingency   | 0              | 0.09644 | -                     | DBL-BVR-WWRD  |
| FNSL-Blown up | 06ALL     |          | 0 14G  | G12_001     |           | Non-converged Contingency   | 0              | 0.1326  | -                     | DBL-TGA-MATT  |
| FDNS          | 00G12_001 |          | 0 24SP | G12_001     | TO->FROM  | ALLEN SUB - LUBBOCK SOUTH INTERCHANGE 115KV CKT 1                   | 160            | 0.14975 | 100.1786              | LUBBOCK SOUTH INTERCHANGE - WOLFFORTH INTERCHANGE 230KV     |
| FDNS          | 00G12_001 |          | 0 14SP | G12_001     | TO->FROM  | BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1   | 160            | 0.04388 | 105.1945              | DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 |
| FDNS          | 0         |          | 0 14SP | G12_001     | TO->FROM  | BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1   | 160            | 0.04389 | 103.4154              | DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 |
| FDNS          | 3         |          | 0 14G  | G12_001     | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                                     | 318.7          | 0.03643 | 139.8191              | DBL-WICH-THI  |
| FDNS          | 3         |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.04298 | 165.2322              | DBL-TGA-MATT  |
| FDNS          | 3         |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.04298 | 146.8398              | G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1               |
| FDNS          | 3         |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.04298 | 145.1847              | G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1         |
| FDNS          | 3         |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.03553 | 140.6024              | DBL-WICH-THI  |
| FDNS          | 03ALL     |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.03007 | 118.8703              | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1         |
| FDNS          | 03ALL     |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.04089 | 115.0528              | SPP-AEPW-32   |
| FDNS          | 03ALL     |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.03467 | 113.6509              | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1            |
| FDNS          | 03ALL     |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.03467 | 113.6405              | SPP-SWPS-02   |
| FDNS          | 03ALL     |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.03467 | 113.6347              | STLN-DEMARC6 - SWEETWATER 230KV CKT 1                       |
| FDNS          | 03ALL     |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.04022 | 113.1517              | SPP-SWPS-01   |
| FDNS          | 03ALL     |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.04089 | 112.9543              | OKLAUNION - TUCO INTERCHANGE 345KV CKT 1                    |
| FDNS          | 06G12_001 |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.04307 | 102.117               | DBL-TGA-MATT  |
| FDNS          | 6         |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.04308 | 101.687               | DBL-TGA-MATT  |
| FDNS          | 3         |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.04114 | 100.1731              | LAWTON EASTSIDE - OKLAUNION 345KV CKT 1                     |
| FDNS          | 3         |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.03492 | 100                   | ELK CITY 230KV - SWEETWATER 230KV CKT 1                     |
| FDNS          | 3         |          | 0 14G  | G12_001     | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                                   | 153            | 0.03492 | 99.9                  | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1  |
| FDNS          | 00G12_001 |          | 0 14SP | G12_001     | FROM->TO  | GRASSLAND INTERCHANGE (PENN 0105951) 230/115/13.2KV TRANSFORMER CKT | 100            | 0.10894 | 104.6185              | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV     |
| FDNS          | 00G12_001 |          | 0 14SP | G12_001     | FROM->TO  | GRASSLAND INTERCHANGE (PENN 0105951) 230/115/13.2KV TRANSFORMER CKT | 100            | 0.10894 | 101.8737              | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV     |
| FDNS          | 00G12_001 |          | 0 14SP | G12_001     | FROM->TO  | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV             | 252            | 0.07301 | 113.3658              | JONES STATION - LUBBOCK EAST INTERCHANGE 230KV CKT 1        |
| FDNS          | 0         |          | 0 14SP | G12_001     | FROM->TO  | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV             | 252            | 0.07302 | 111.8404              | JONES STATION - LUBBOCK EAST INTERCHANGE 230KV CKT 1        |
| FDNS          | 00G12_001 |          | 0 14SP | G12_001     | FROM->TO  | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV             | 252            | 0.07301 | 107.8371              | JONES STATION - LUBBOCK EAST INTERCHANGE 230KV CKT 1        |
| FDNS          | 0         |          | 0 14SP | G12_001     | FROM->TO  | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV             | 252            | 0.07302 | 106.3827              | JONES STATION - LUBBOCK EAST INTERCHANGE 230KV CKT 1        |
| FDNS          | 00G12_001 |          | 0 14SP | G12_001     | FROM->TO  | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV             | 252            | 0.07796 | 103.3027              | LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV      |
| FDNS          | 0         |          | 0 14SP | G12_001     | FROM->TO  | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV             | 252            | 0.07797 | 101.6543              | LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV      |
| FDNS          | 03ALL     |          | 0 14G  | G12_001     | FROM->TO  | MULGREN7 345.00 (MULLERGREN1) 345/230/13.8KV TRANSFORMER CKT 1      | 600            | 0.03642 | 100.9988              | G12-011T 345.00 - POST ROCK 345KV CKT 1                     |
| FDNS          | 03ALL     |          | 0 14G  | G12_001     | FROM->TO  | MULGREN7 345.00 (MULLERGREN1) 345/230/13.8KV TRANSFORMER CKT 1      | 600            | 0.03642 | 100.7008              | G12-011T 345.00 - POST ROCK 345KV CKT 1                     |
| FDNS          | 03ALL     |          | 0 14G  | G12_001     | TO->FROM  | MULLERGREN - SPEARVILLE 230KV CKT 1                                 | 318.7          | 0.03457 | 113.3455              | G11-17T 345.00 - SPEARVILLE 345KV CKT 1                     |
| FDNS          | 06ALL     |          | 0 14G  | G12_004     | FROM->TO  | LAWEASOKLUNI  | 425            | 0.08365 | 106.4                 | BASE CASE   |
| FDNS          | 03NR      |          | 0 14G  | G12_007     | TO->FROM  | 5 HICKOCK - RUBART 3 115.00 115KV CKT 1                             | 119.5          | 1       | 98.6                  | RUBART 3 115.00 - SANT T 3 115KV CKT 1                      |
| FDNS          | 03NR      |          | 0 14G  | G12_007     | FROM->TO  | RUBART 3 115.00 - SANT T 3 115KV CKT 1                              | 119.5          | 1       | 98.7                  | 5 HICKOCK - RUBART 3 115.00 115KV CKT 1                     |
| FDNS          | 0         |          | 0 14SP | G12_009     | TO->FROM  | BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1   | 160            | 0.05715 | 103.4154              | DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 |
| FDNS          | 00G12_009 |          | 0 14SP | G12_009     | TO->FROM  | BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1   | 160            | 0.05718 | 103.3283              | DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 |
| FDNS          | 0         |          | 0 14SP | G12_009     | FROM->TO  | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV             | 252            | 0.03084 | 101.6543              | LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV      |
| FDNS          | 00G12_009 |          | 0 14SP | G12_009     | FROM->TO  | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV             | 252            | 0.03088 | 101.35                | LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV      |
| FDNS          | 00G12_009 |          | 0 24SP | G12_009     | TO->FROM  | PCA INTERCHANGE - REDDY 3115.00 115KV CKT 1                         | 160            | 0.03921 | 101.2464              | CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV      |
| FDNS          | 0         |          | 0 24SP | G12_009     | TO->FROM  | PCA INTERCHANGE - REDDY 3115.00 115KV CKT 1                         | 160            | 0.03922 | 100.2039              | CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV      |
| FDNS          | 0         |          | 0 24SP | G12_009     | FROM->TO  | YOAKUM COUNTY INTERCHANGE (PENN C010585) 230/115/13.2KV             | 150            | 0.0593  | 102.8553              | YOAKUM COUNTY INTERCHANGE (GE M100899) 230/115/13.2KV       |
| FDNS          | 00G12_009 |          | 0 24SP | G12_009     | FROM->TO  | YOAKUM COUNTY INTERCHANGE (PENN C010585) 230/115/13.2KV             | 150            | 0.0593  | 102.4358              | YOAKUM COUNTY INTERCHANGE (GE M100899) 230/115/13.2KV       |
| FDNS          | 0         |          | 0 24SP | G12_009     | FROM->TO  | YOAKUM COUNTY INTERCHANGE (PENN C010585) 230/115/13.2KV             | 150            | 0.0593  | 100                   | YOAKUM COUNTY INTERCHANGE (GE M100899) 230/115/13.2KV       |
| FDNS          | 00G12_009 |          | 0 24SP | G12_009     | FROM->TO  | YOAKUM COUNTY INTERCHANGE (PENN C010585) 230/115/13.2KV             | 150            | 0.0593  | 99.6                  | YOAKUM COUNTY INTERCHANGE (GE M100899) 230/115/13.2KV       |
| FDNS          | 0         |          | 0 14SP | G12_010     | TO->FROM  | BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1   | 160            | 0.05715 | 103.4154              | DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 |
| FDNS          | 00G12_010 |          | 0 14SP | G12_010     | TO->FROM  | BAILEY COUNTY REC-EARTH INTERCHANGE - PLANT X STATION 115KV CKT 1   | 160            | 0.05718 | 103.3283              | DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 |
| FDNS          | 0         |          | 0 14SP | G12_010     | FROM->TO  | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV             | 252            | 0.03084 | 101.6543              | LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV      |
| FDNS          | 00G12_010 |          | 0 14SP | G12_010     | FROM->TO  | LUBBOCK SOUTH INTERCHANGE (ABB LLM60043) 230/115/13.2KV             | 252            | 0.03088 | 101.35                | LUBBOCK EAST INTERCHANGE (ENRCO 136162) 230/115/13.2KV      |
| FDNS          | 00G12_010 |          | 0 24SP | G12_010     | TO->FROM  | PCA INTERCHANGE - REDDY 3115.00 115KV CKT 1                         | 160            | 0.03921 | 101.2464              | CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV      |
| FDNS          | 0         |          | 0 24SP | G12_010     | TO->FROM  | PCA INTERCHANGE - REDDY 3115.00 115KV CKT 1                         | 160            | 0.03922 | 100.2039              | CUNNINGHAM STATION - POTASH JUNCTION INTERCHANGE 230KV      |
| FDNS          | 0         |          | 0 24SP | G12_010     | FROM->TO  | YOAKUM COUNTY INTERCHANGE (PENN C010585) 230/115/13.2KV             | 150            | 0.0593  | 102.8553              | YOAKUM COUNTY INTERCHANGE (GE M100899) 230/115/13.2KV       |
| FDNS          | 00G12_010 |          | 0 24SP | G12_010     | FROM->TO  | YOAKUM COUNTY INTERCHANGE (PENN C010585) 230/115/13.2KV             | 150            | 0.0593  | 102.4358              | YOAKUM COUNTY INTERCHANGE (GE M100899) 230/115/13.2KV       |
| FDNS          | 0         |          | 0 24SP | G12_010     | FROM->TO  | YOAKUM COUNTY INTERCHANGE (PENN C010585) 230/115/13.2KV             | 150            | 0.0593  | 100                   | YOAKUM COUNTY INTERCHANGE (GE M100899) 230/115/13.2KV       |
| FDNS          | 00G12_010 |          | 0 24SP | G12_010     | FROM->TO  | YOAKUM COUNTY INTERCHANGE (PENN C010585) 230/115/13.2KV             | 150            | 0.0593  | 99.6                  | YOAKUM COUNTY INTERCHANGE (GE M100899) 230/115/13.2KV       |
| FNSL-Blown up | 03ALL     |          | 0 14G  | G12_011     |           | Non-converged Contingency   | 0              | 0.27141 | -                     | DBL-IRON-CLR  |
| FNSL-Blown up | 03ALL     |          | 0 14G  | G12_011     |           | Non-converged Contingency   | 0              | 0.27141 | -                     | DBL-THIS-CLR  |
| FNSL-Blown up | 03ALL     |          | 0 14G  | G12_011     |           | Non-converged Contingency   | 0              | 0.16112 | -                     | DBL-WICH-THI  |
| FNSL-Blown up | 03ALL     |          | 0 14G  | G12_011     |           | Non-converged Contingency   | 0              | 0.11251 | -                     | DBL-TGA-MATT  |

| SOLUTION      | GROUP     | SCENARIO | SEASON | SOURCE  | DIRECTION | MONITORED ELEMENT                        | RATEB<br>(MVA) | TDF     | TC%LOADING<br>(% MVA) | CONTINGENCY  |
|---------------|-----------|----------|--------|---------|-----------|--|----------------|---------|-----------------------|--|
| FNSL-Blown up | 03ALL     |          | 0 14G  | G12_011 |           | Non-converged Contingency                | 0              | 0.07881 | -                     | DBL-BVR-WWRD   |
| FNSL-Blown up | 03G12_011 |          | 0 14G  | G12_011 |           | Non-converged Contingency                | 0              | 0.11357 | -                     | DBL-TGA-MATT   |
| FNSL-Blown up | 06ALL     |          | 0 14G  | G12_011 |           | Non-converged Contingency                | 0              | 0.1139  | -                     | DBL-TGA-MATT   |
| FDNS          | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 | 611.9          | 0.34059 | 137.0911              | DBL-THIS-CLR   |
| FDNS          | 3         |          | 0 14G  | G12_011 | TO->FROM  | BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1 | 611.9          | 0.3404  | 124.1216              | DBL-THIS-CLR   |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CHISHOLM - MAIZEE 4 138.00 138KV CKT 1   | 287            | 0.04061 | 104.168               | BENTON - WICHITA 345KV CKT 1                                 |
| FDNS          | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.12173 | 164.3538              | DBL-THIS-CLR   |
| FDNS          | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.12184 | 155.2916              | DBL-THIS-CLR   |
| FDNS          | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.10243 | 146.0007              | DBL-WICH-THI   |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.10661 | 145.9406              | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                         |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.12093 | 143.4115              | DBL-SPRVL-CL   |
| FDNS          | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.10254 | 139.8191              | DBL-WICH-THI   |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.09142 | 139.4051              | CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1             |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.09142 | 139.4051              | CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2             |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.10546 | 138.3315              | AXTELL - POST ROCK 345KV CKT 1                               |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.10661 | 138.2114              | KNOLL 230 - SMOKYHL6 230.00 230KV CKT 1                      |
| FDNS          | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.12173 | 138.1379              | DBL-IRON-CLR   |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08737 | 134.8328              | THISTLE7 345.00 - WICHITA 345KV CKT 1                        |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08737 | 134.8328              | THISTLE7 345.00 - WICHITA 345KV CKT 2                        |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08877 | 132.2772              | BEAVER CO 345.00 - BUCKNER7 345.00 345KV CKT 1               |
| FDNS          | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.12184 | 131.5455              | DBL-IRON-CLR   |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.10027 | 131.0346              | G12-011T 345.00 - POST ROCK 345KV CKT 1                      |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08642 | 130.5163              | ST JOHN - ST JOHN 115KV CKT 1                                |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.09617 | 130.4795              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1                     |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08864 | 129.693               | SPP-MKEC-06  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08863 | 129.6557              | SEWARD - ST JOHN 115KV CKT 1                                 |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.06099 | 128.2415              | G11-17T 345.00 - G12-011T 345.00 345KV CKT 1                 |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08339 | 127.8449              | MINGO - RED WILLOW 345KV CKT 1                               |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08642 | 127.7232              | HUNTSVILLE - ST JOHN 115KV CKT 1                             |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08277 | 127.6079              | GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1             |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08642 | 127.4932              | MIDW-CATB05  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08642 | 127.2078              | HUNTSVILLE - HUTCHINSON ENERGY CENTER 115KV CKT 1            |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08277 | 127.0157              | GEN532652 1-JEFFREY ENERGY CENTER UNIT 2                     |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08277 | 127.0151              | GEN532653 1-JEFFREY ENERGY CENTER UNIT 3                     |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08536 | 126.9995              | SPP-SWPS-05  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08536 | 126.8712              | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.09687 | 126.8092              | BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1                     |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08277 | 126.7493              | GEN532651 1-JEFFREY ENERGY CENTER UNIT 1                     |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08699 | 126.6966              | CLARKCOUNTY7345.00 - IRONWOOD7 345.00 345KV CKT 1            |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.0846  | 126.5685              | GRAND ISLAND - SWEETWATER 345KV CKT 1                        |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08628 | 126.5537              | AXTELL - PAULINE 345KV CKT 1                                 |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08699 | 126.5217              | CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1                  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08561 | 126.4339              | GREAT BEND TAP - SEWARD 115KV CKT 1                          |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08561 | 126.4222              | GREAT BEND TAP - MULLERGREN 115KV CKT 1                      |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08568 | 125.7538              | MOORE - PAULINE 345KV CKT 1                                  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08383 | 125.6056              | SPP-MKEC-02  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08328 | 125.4618              | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1        |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08383 | 125.4303              | ELLSWTP3 115.00 - MULLERGREN 115KV CKT 1                     |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08375 | 125.3035              | BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1         |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08375 | 125.3035              | BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2         |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08268 | 125.1305              | MINGO - SETAB 345KV CKT 1                                    |
| FNSL          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08433 | 125.1211              | SPP-MKEC-08  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.06874 | 124.7488              | MULLERGREN - SOUTH HAYS 230KV CKT 1                          |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08383 | 124.7049              | ELLSWTP3 115.00 - RUSSELL 115KV CKT 1                        |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08327 | 124.4794              | SPP-MKEC-09B   |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08327 | 124.346               | GREENSBURG - SSTARTP3 115.00 115KV CKT 1                     |
| FNSL          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08465 | 124.3348              | ELM CREEK - NORTHWEST MANHATTAN 230KV CKT 1                  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08277 | 124.3192              | GEN542962 2-IATAN UNIT #2                                    |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08277 | 124.2702              | GEN530690 1-PRWINDG1 0.6900                                  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08327 | 124.1364              | GREENSBURG - SUN CITY 115KV CKT 1                            |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08277 | 124.109               | GEN542955 1-LACYGNE UNIT #1                                  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08277 | 124.1052              | GEN542956 2-LACYGNE UNIT #2                                  |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08341 | 124.06                | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1                |
| FDNS          | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1          | 318.7          | 0.08341 | 124.06                | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 2                |

| SOLUTION | GROUP     | SCENARIO | SEASON | SOURCE  | DIRECTION | MONITORED ELEMENT               | RATEB |         | TC%LOADING |   | CONTINGENCY |
|----------|-----------|----------|--------|---------|-----------|---------------------------------|-------|---------|------------|---|-------------|
|          |           |          |        |         |           |                                 | (MVA) | TDF     | (% MVA)    |   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08327 | 124.0306   | MEDICINE LODGE - SUN CITY 115KV CKT 1                         |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08298 | 124.0272   | STEGALL TY 345/230KV TRANSFORMER CKT 1                        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08475 | 124.0247   | BUCKNER7 345.00 - HOLCOMB 345KV CKT 1                         |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08298 | 124.0234   | STEGALL - STEGALL TY 345KV CKT 1                              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08298 | 124.0206   | STEGALL - STEGALL TRANSFORMER 230KV CKT 1                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08298 | 124.0176   | TRF-STEGALL   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08339 | 123.9839   | HARPER - MILAN TAP 138KV CKT 1                                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08377 | 123.9767   | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV       |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 123.9239   | GEN542957 1-IATAN UNIT #1                                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08366 | 123.8962   | GRAND ISLAND - MCCOOL 345KV CKT 1                             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08339 | 123.8872   | SPP-MKEC-03A  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08339 | 123.8844   | SPP-MKEC-05   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08383 | 123.8687   | RUSSELL - WALDO 115KV CKT 1                                   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08339 | 123.8132   | SPP-MKEC-03B  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08339 | 123.8112   | CLEARWATER - MILAN TAP 138KV CKT 1                            |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08327 | 123.7937   | BARBER 3 115.00 - MEDICINE LODGE 115KV CKT 1                  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 123.702    | GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 123.6623   | GEN532722 1-EVANS ENERGY CENTER UNIT 2                        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08377 | 123.6432   | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08339 | 123.6148   | CLEARWATER - GILL ENERGY CENTER WEST 138KV CKT 1              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08536 | 123.591    | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.07391 | 123.575    | POSTROCK6 230.00 - SOUTH HAYS 230KV CKT 1                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08383 | 123.5561   | COVERT 3 115.00 - WALDO 115KV CKT 1                           |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08377 | 123.5397   | SPP-SWPS-04   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08383 | 123.5386   | COVERT 3 115.00 - SMITH CENTER 115KV CKT 1                    |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 123.5329   | GEN542951 5-HAWTHORN UNIT #5                                  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08378 | 123.5295   | MULLERGREN (MULGREN6) 230/115/13.8KV TRANSFORMER CKT 1        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08377 | 123.5132   | HEIZER 6 230.00 - MULLERGREN 230KV CKT 1                      |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08301 | 123.5093   | GERALD GENTLEMAN STATION - RED WILLOW 345KV CKT 1             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08377 | 123.4877   | HEIZER 6 230.00 (HEIZER T1) 230/115/12.5KV TRANSFORMER CKT 1  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08365 | 123.4802   | MCCOOL - MOORE 345KV CKT 1                                    |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08299 | 123.2906   | NUNDRWD - WAYSIDE 230KV CKT 1                                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08344 | 123.2904   | G10-056T 345.00 - ST JOE 345KV CKT 1                          |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.10726 | 122.7136   | SMOKYH16 230.00 - SUMMIT 230KV CKT 1                          |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 122.119    | BASE CASE   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 121.2119   | GEN645012 2-NEBRASKA CITY 2                                   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08328 | 121.1356   | MANNING TAP - SCOTT CITY 115KV CKT 1                          |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 121.0048   | GEN560235 1-G08-92 0.6900                                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08187 | 120.9582   | WR-DOUBLE17   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08339 | 120.9473   | CIRCLE - HUTCHINSON ENERGY CENTER 115KV CKT 1                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.9131   | GEN526331 1-JONES GEN #1 22 KV                                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08098 | 120.9124   | VIOLA 7 345.00 - WICHITA 345KV CKT 1                          |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.8816   | GEN527902 1-HOBBS PLANT #2 (CT)                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.8773   | GEN527161 1-MUSTANG GEN #1                                    |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.8773   | GEN527162 1-MUSTANG GEN #2                                    |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.8719   | GEN527901 1-HOBBS PLANT #1 (CT)                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08095 | 120.8403   | CIRCLE - RENO COUNTY 115KV CKT 2                              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.07913 | 120.82     | EAST MCPHERSON - SUMMIT 230KV CKT 1                           |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.7992   | GEN526334 1-JONES 4 116.500                                   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.07768 | 120.7954   | POST ROCK (POSTROCK T1) 345/230/13.8KV TRANSFORMER CKT 1      |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08237 | 120.7948   | LYONS - RICE_CO 115KV CKT 1                                   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.07161 | 120.774    | RENO COUNTY - WICHITA 345KV CKT 1                             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.7713   | GEN526332 1-JONES GEN #2 21 KV                                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.7667   | GEN560140 1-G09-08 0.7000                                     |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.12173 | 120.7349   | DBL-SPRVL-CL  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08237 | 120.7321   | CIRCLE - RICE 6 230.00 230KV CKT 1                            |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.7298   | GEN659111 2-LELAND OLDS UNIT2                                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08151 | 120.7099   | HUNTERS7 345.00 - WOODRING 345KV CKT 1                        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.6876   | GEN527163 1-MUSTANG GEN #3 22 KV                              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08177 | 120.655    | BENTON - WICHITA 345KV CKT 1                                  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.6409   | GEN659103 1-ANTELOPE VALLEY UNIT1                             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.6409   | GEN659107 2-ANTELOPE VALLEY UNIT2                             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08037 | 120.6263   | MORRIS COUNTY - UNIONRG6 230.00 230KV CKT 1                   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08154 | 120.5456   | MOUNDRIAGE (MOUND10X) 138/115/13.8KV TRANSFORMER CKT 1        |             |

| SOLUTION | GROUP     | SCENARIO | SEASON | SOURCE  | DIRECTION | MONITORED ELEMENT               | RATEB |         | TC%LOADING |   | CONTINGENCY |
|----------|-----------|----------|--------|---------|-----------|---------------------------------|-------|---------|------------|---|-------------|
|          |           |          |        |         |           |                                 | (MVA) | TDF     | (% MVA)    |   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08154 | 120.5379   | WR-B3-9   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08263 | 120.5215   | SPP-WR-335A   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.3885   | EASTDC - WELSH 345KV CKT 1                                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.2835   | GEN527903 1-HOBBS PLANT #3 (ST)                           |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 120.2589   | GEN531459 2-S2 GENERATOR                                  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08037 | 120.1688   | SUMMIT - UNIONRG6 230.00 230KV CKT 1                      |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08241 | 120.1274   | EAST MCPHERSON (EMCPHR1X) 230/115/13.8KV TRANSFORMER CKT  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.9741   | GEN539762 1-SSWIND 1 34.500                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.967    | GEN560522 1-G05-12-2 0.6900                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08237 | 119.9582   | RICE 6 230.00 (RICE T1) 230/115/12.47KV TRANSFORMER CKT 1 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08098 | 119.9192   | RENFROW7 345.00 - VIOLA 7 345.00 345KV CKT 1              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08187 | 119.8617   | SWISSVALE - WEST GARDNER 345KV CKT 1                      |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.8284   | GEN539785 1-ENSGW 1 0.5750                                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.8266   | GEN560696 1-G11-008-4 0.6900                              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.7249   | GEN523971 1-HARRINGTON GEN #1 24 KV                       |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.7247   | GEN523972 1-HARRINGTON GEN #2 24 KV                       |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.7179   | GEN523973 1-HARRINGTON GEN #3 24 KV                       |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08097 | 119.531    | WR-B3-8   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08237 | 119.5191   | MIDW-CATB06   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08097 | 119.4969   | MOUNDRIDGE - RENO COUNTY 115KV CKT 1                      |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.4942   | GEN560267 1-G10-15-1 0.6900                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.4342   | GEN560268 1-G10-15-2 0.6900                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.3259   | GEN539767 1-GRAY COUNTY WIND FARM                         |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.188    | GEN560695 1-G11-008-3 0.6900                              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 119.022    | GEN560694 1-G11-008-2 0.6900                              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 118.8609   | GEN525561 1-TOLK GEN #1 24 KV                             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 118.7728   | GEN525562 1-TOLK GEN #2 24 KV                             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 118.6948   | GEN640011 2-GERALD GENTLEMAN STATION UNIT 2               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 118.6429   | GEN560238 1-G10-09 0.6900                                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 118.6187   | GEN640010 1-GERALD GENTLEMAN STATION UNIT 1               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 118.6063   | GEN539670 4-JUDSON LARGE GENERATOR                        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 117.9639   | GEN560693 1-G11-008-1 0.6900                              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 117.9287   | GEN560329 1-G10-45 0.6900                                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 117.9143   | GEN531503 1-CIMRRN 1 34.500                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 117.6545   | GEN539807 1-G05-12 0.6900                                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 117.5814   | GEN539677 3-A. M. MULLERGREN GENERATOR                    |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 117.5745   | GEN542902 1-GPW_G1 0.6900                                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08196 | 117.4637   | HOYT - STRANGER CREEK 345KV CKT 1                         |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 117.388    | GEN560514 1-G04_014 0.6900                                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 117.3419   | GEN523117 1-BUFF_DUNES210.6900                            |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.10735 | 116.9225   | SMOKYH16 230.00 - SUMMIT 230KV CKT 1                      |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 116.89     | GEN560659 1-G07-38 0.6900                                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 116.8682   | GEN560432 1-G08-124 0.6900                                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 116.8461   | GEN562035 1-G11_016_3 0.6900                              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 116.6946   | GEN560549 1-G06-06 0.6900                                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 116.4526   | GEN562123 1-G12_011_3 0.6900                              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 116.3808   | GEN560714 1-G10_061_3 0.6900                              |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 116.0735   | GEN659118 1-LARAMIE RIVER UNIT1                           |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.10611 | 115.6553   | AXTELL - POST ROCK 345KV CKT 1                            |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.09203 | 115.5377   | CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1          |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.09203 | 115.5377   | CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2          |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 115.2153   | GEN531447 1-HOLCOMB GENERATOR                             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08196 | 115.104    | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1                  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.10726 | 115.1026   | KNOLL 230 - SMOKYH16 230.00 230KV CKT 1                   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08189 | 114.6974   | WRTOD400  |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.12184 | 113.699    | DBL-SPRVL-CL  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08758 | 113.3162   | DBL-BVR-WWRD  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08277 | 112.6185   | GEN562032 1-G11_017_3 0.6900                              |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08799 | 112.5762   | THISTLE7 345.00 - WICHITA 345KV CKT 1                     |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08799 | 112.5762   | THISTLE7 345.00 - WICHITA 345KV CKT 2                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08562 | 112.4119   | MULLERGREN - SPEARVILLE 230KV CKT 1                       |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.07687 | 111.1084   | CIRCLE - EAST MCPHERSON 230KV CKT 1                       |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08718 | 110.18     | G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1             |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.09211 | 110.0535   | CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1          |             |



| SOLUTION | GROUP     | SCENARIO | SEASON | SOURCE  | DIRECTION | MONITORED ELEMENT               | RATEB | TC%LOADING |          | CONTINGENCY  |
|----------|-----------|----------|--------|---------|-----------|---------------------------------|-------|------------|----------|--|
|          |           |          |        |         |           |                                 | (MVA) | TDF        | (% MVA)  |  |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.09211    | 110.0535 | CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08718    | 109.9666 | G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1          |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.10619    | 109.8971 | AXTELL - POST ROCK 345KV CKT 1                               |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.09677    | 109.3226 | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.10087    | 109.3134 | G12-011T 345.00 - POST ROCK 345KV CKT 1                      |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08936    | 109.2898 | BEAVER CO 345.00 - BUCKNER7 345.00 345KV CKT 1               |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08702    | 109.2846 | ST JOHN - ST JOHN 115KV CKT 1                                |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.10735    | 109.2777 | KNOLL 230 - SMOKYH6 230.00 230KV CKT 1                       |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08922    | 108.7202 | SPP-MKEC-06  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08921    | 108.6926 | SEWARD - ST JOHN 115KV CKT 1                                 |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08767    | 107.9972 | DBL-BVR-WWRD   |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 107.696  | GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08726    | 107.4144 | DBL-TGA-MATT   |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 107.4136 | GEN532652 1-JEFFREY ENERGY CENTER UNIT 2                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 107.413  | GEN532653 1-JEFFREY ENERGY CENTER UNIT 3                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08808    | 107.3042 | THISTLE7 345.00 - WICHITA 345KV CKT 1                        |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08808    | 107.3042 | THISTLE7 345.00 - WICHITA 345KV CKT 2                        |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 107.1352 | GEN532651 1-JEFFREY ENERGY CENTER UNIT 1                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.06159    | 106.8856 | G11-17T 345.00 - G12-011T 345.00 345KV CKT 1                 |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08702    | 106.5776 | HUNTSVILLE - ST JOHN 115KV CKT 1                             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.14494    | 106.4379 | G11-17T 345.00 - SPEARVILLE 345KV CKT 1                      |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08702    | 106.3501 | MIDW-CAT805  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08758    | 106.0919 | CLARKCOUNTY7345.00 - IRONWOOD7 345.00 345KV CKT 1            |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08702    | 106.0778 | HUNTSVILLE - HUTCHINSON ENERGY CENTER 115KV CKT 1            |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08517    | 106.0192 | GRAND ISLAND - SWEETWATER 345KV CKT 1                        |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08618    | 105.9927 | GREAT BEND TAP - SEWARD 115KV CKT 1                          |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08686    | 105.9779 | AXTELL - PAULINE 345KV CKT 1                                 |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08618    | 105.9699 | GREAT BEND TAP - MULLERGREN 115KV CKT 1                      |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08758    | 105.9541 | CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1                  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08402    | 105.9039 | MINGO - RED WILLOW 345KV CKT 1                               |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08596    | 105.6198 | SPP-SWPS-05  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08596    | 105.5365 | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.09731    | 105.4649 | BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08625    | 105.2661 | MOORE - PAULINE 345KV CKT 1                                  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08441    | 105.2371 | SPP-MKEC-02  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08339    | 105.1286 | LAWTON EASTSIDE - OKLAUNION 345KV CKT 1                      |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08441    | 105.0597 | ELLSWTP3 115.00 - MULLERGREN 115KV CKT 1                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08726    | 105.0029 | G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1                |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08726    | 104.792  | G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1          |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08433    | 104.7733 | BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08433    | 104.7733 | BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08388    | 104.6617 | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1        |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08491    | 104.542  | SPP-MKEC-08  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 104.5362 | GEN530690 1-PRWINDG1 0.6900                                  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 104.5194 | GEN542962 2-IATAN UNIT #2                                    |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08441    | 104.3596 | ELLSWTP3 115.00 - RUSSELL 115KV CKT 1                        |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 104.306  | GEN542955 1-LACYGNE UNIT #1                                  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 104.277  | GEN542956 2-LACYGNE UNIT #2                                  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08327    | 104.2335 | MINGO - SETAB 345KV CKT 1                                    |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.0852     | 104.1925 | ELM CREEK - NORTHWEST MANHATTAN 230KV CKT 1                  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08385    | 104.1878 | SPP-MKEC-09B   |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.0871     | 104.158  | ST JOHN - ST JOHN 115KV CKT 1                                |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08395    | 104.1203 | FLATRDG3 - HARPER 138KV CKT 1                                |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 104.1059 | GEN542957 1-IATAN UNIT #1                                    |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.09684    | 104.0576 | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.06934    | 104.0318 | MULLERGREN - SOUTH HAYS 230KV CKT 1                          |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08385    | 104.0254 | GREENSBURG - SSTARTP3 115.00 115KV CKT 1                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.10095    | 103.9772 | G12-011T 345.00 - POST ROCK 345KV CKT 1                      |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08397    | 103.9338 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1                |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08397    | 103.9338 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 2                |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08944    | 103.9227 | BEAVER CO 345.00 - BUCKNER7 345.00 345KV CKT 1               |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.0794     | 103.9127 | JEFFREY ENERGY CENTER - SUMMIT 345KV CKT 1                   |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 103.8945 | GEN532722 1-EVANS ENERGY CENTER UNIT 2                       |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7 | 0.08333    | 103.8487 | GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5                    |

| SOLUTION | GROUP     | SCENARIO | SEASON | SOURCE  | DIRECTION | MONITORED ELEMENT               | RATEB<br>(MVA) | TDF     | TC%LOADING<br>(% MVA) | CONTINGENCY   |
|----------|-----------|----------|--------|---------|-----------|---------------------------------|----------------|---------|-----------------------|---|
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08385 | 103.8363              | GREENSBURG - SUN CITY 115KV CKT 1                             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08395 | 103.8291              | HARPER - MILAN TAP 138KV CKT 1                                |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08395 | 103.7402              | SPP-MKEC-03A  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08395 | 103.7366              | SPP-MKEC-05   |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08385 | 103.728               | MEDICINE LODGE - SUN CITY 115KV CKT 1                         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08422 | 103.7048              | GRAND ISLAND - MCCOOL 345KV CKT 1                             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 103.7018              | GEN542951 5-HAWTHORN UNIT #5                                  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08433 | 103.6932              | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV       |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08525 | 103.6838              | BUCKNER7 345.00 - HOLCOMB 345KV CKT 1                         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08395 | 103.6576              | SPP-MKEC-03B  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08395 | 103.6544              | CLEARWATER - MILAN TAP 138KV CKT 1                            |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08441 | 103.5708              | RUSSELL - WALDO 115KV CKT 1                                   |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.0893  | 103.5417              | SPP-MKEC-06   |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08385 | 103.5138              | BARBER 3 115.00 - MEDICINE LODGE 115KV CKT 1                  |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08929 | 103.5123              | SEWARD - ST JOHN 115KV CKT 1                                  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08395 | 103.5011              | CLEARWATER - GILL ENERGY CENTER WEST 138KV CKT 1              |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08433 | 103.4168              | MULLERGREN (MULGRENG) 230/115/13.8KV TRANSFORMER CKT 1        |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08432 | 103.411               | HEIZER 6 230.00 - MULLERGREN 230KV CKT 1                      |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08432 | 103.388               | HEIZER 6 230.00 (HEIZER T1) 230/115/12.5KV TRANSFORMER CKT 1  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.084   | 103.3646              | G10-056T 345.00 - ST JOE 345KV CKT 1                          |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 103.3638              | GEN541151 3-SIBLEY GENERATING UNIT #3                         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08433 | 103.3587              | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08422 | 103.3107              | MCCOOL - MOORE 345KV CKT 1                                    |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.07449 | 103.2368              | POSTROCK6 230.00 - SOUTH HAYS 230KV CKT 1                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08341 | 102.7836              | GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1              |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08341 | 102.5489              | GEN532652 1-JEFFREY ENERGY CENTER UNIT 2                      |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08341 | 102.5483              | GEN532653 1-JEFFREY ENERGY CENTER UNIT 3                      |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08341 | 102.2694              | GEN532651 1-JEFFREY ENERGY CENTER UNIT 1                      |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 102.2346              | BASE CASE   |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 102.2346              | NC1_GEN-NEBRASKA CITY 1                                       |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.06167 | 102.0286              | G11-17T 345.00 - G12-011T 345.00 345KV CKT 1                  |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.0871  | 101.4743              | HUNTSVILLE - ST JOHN 115KV CKT 1                              |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08154 | 101.309               | VIOLA 7 345.00 - WICHITA 345KV CKT 1                          |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 101.2697              | GEN645012 2-NEBRASKA CITY 2                                   |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.0871  | 101.2468              | MIDW-CATB05   |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08241 | 101.2311              | WR-DOUBLE17   |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08091 | 101.2096              | MORRIS COUNTY - UNIONRG6 230.00 230KV CKT 1                   |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08316 | 101.1837              | EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.0815  | 101.1699              | CIRCLE - RENO COUNTY 115KV CKT 2                              |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08363 | 101.1675              | EASTOWN7 345.00 - IATAN 345KV CKT 1                           |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 101.1522              | GEN560173 1-G08-17 0.5750                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 101.1487              | GEN560235 1-G08-92 0.6900                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 101.0922              | GEN527882 1-CUNNINGHAM GEN #2 20 KV                           |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 101.0692              | GEN539653 1-CIMARRON RIVER PLANT GENERATOR                    |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08292 | 101.0657              | CIRCLE - RICE 6 230.00 230KV CKT 1                            |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.07824 | 101.0465              | POST ROCK (POSTROCK T1) 345/230/13.8KV TRANSFORMER CKT 1      |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 101.043               | GEN527902 1-HOBBS PLANT #2 (CT)                               |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 101.0385              | GEN527161 1-MUSTANG GEN #1                                    |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 101.0385              | GEN527162 1-MUSTANG GEN #2                                    |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 101.0346              | GEN527901 1-HOBBS PLANT #1 (CT)                               |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 101.0322              | GEN526331 1-JONES GEN #1 22 KV                                |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08525 | 101.0315              | GRAND ISLAND - SWEETWATER 345KV CKT 1                         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08207 | 101.0195              | HUNTERS7 345.00 - WOODRING 345KV CKT 1                        |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08232 | 101.012               | BENTON - WICHITA 345KV CKT 1                                  |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.0871  | 100.974               | HUNTSVILLE - HUTCHINSON ENERGY CENTER 115KV CKT 1             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 100.9628              | GEN526334 1-JONES 4 116.500                                   |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08626 | 100.9597              | GREAT BEND TAP - SEWARD 115KV CKT 1                           |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08292 | 100.95                | LYONS - RICE_CO 115KV CKT 1                                   |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08766 | 100.9485              | CLARKCOUNTY7345.00 - IRONWOOD7 345.00 345KV CKT 1             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08626 | 100.9415              | GREAT BEND TAP - MULLERGREN 115KV CKT 1                       |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 100.9227              | GEN560140 1-G09-08 0.7000                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08694 | 100.9184              | AXTELL - PAULINE 345KV CKT 1                                  |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.08333 | 100.8904              | GEN526332 1-JONES GEN #2 21 KV                                |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1 | 318.7          | 0.06513 | 100.876               | CIRCLE (CIRCLE1X) 230/115/13.8KV TRANSFORMER CKT 1            |

| SOLUTION | GROUP     | SCENARIO | SEASON | SOURCE  | DIRECTION | MONITORED ELEMENT                                | RATEB |         | TC%LOADING |  | CONTINGENCY |
|----------|-----------|----------|--------|---------|-----------|--|-------|---------|------------|--|-------------|
|          |           |          |        |         |           |  | (MVA) | TDF     | (% MVA)    |  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.8606   | GEN659111 2-LELAND OLDS UNIT2                                |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.8463   | GEN527163 1-MUSTANG GEN #3 22 KV                             |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08766 | 100.8119   | CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1                  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.0821  | 100.8048   | MOUNDRIDGE (MOUND10X) 138/115/13.8KV TRANSFORMER CKT 1       |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.0821  | 100.7818   | WR-B3-9  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.7729   | GEN659103 1-ANTELOPE VALLEY UNIT1                            |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.7729   | GEN659107 2-ANTELOPE VALLEY UNIT2                            |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08411 | 100.7687   | MINGO - RED WILLOW 345KV CKT 1                               |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08091 | 100.7225   | SUMMIT - UNIONRG6 230.00 230KV CKT 1                         |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.07222 | 100.7041   | RENO COUNTY - WICHITA 345KV CKT 1                            |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08319 | 100.6992   | SPP-WR-335A  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.608    | GEN539762 1-SSWIND 1 34.500                                  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.6028   | GEN560522 1-G05-12-2 0.6900                                  |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08604 | 100.5148   | SPP-SWPS-05  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.5128   | EASTDC - WELSH 345KV CKT 1                                   |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.4812   | GEN560696 1-G11-008-4 0.6900                                 |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.474    | GEN539785 1-ENSNGW 1 0.5750                                  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.4663   | GEN527903 1-HOBBS PLANT #3 (ST)                              |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.4626   | GEN531459 2-S2 GENERATOR                                     |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08604 | 100.4248   | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08297 | 100.3585   | EAST MCPHERSON (EMCPHR1X) 230/115/13.8KV TRANSFORMER CKT     |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08154 | 100.3244   | RENFROW7 345.00 - VIOLA 7 345.00 345KV CKT 1                 |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08449 | 100.3067   | SPP-MKEC-02  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08292 | 100.2937   | RICE 6 230.00 (RICE T1) 230/115/12.47KV TRANSFORMER CKT 1    |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08633 | 100.2492   | MOORE - PAULINE 345KV CKT 1                                  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.2278   | GEN560267 1-G10-15-1 0.6900                                  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.2028   | GEN560268 1-G10-15-2 0.6900                                  |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08347 | 100.1686   | LAWTON EASTSIDE - OKLAUNION 345KV CKT 1                      |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100.123    | GEN539767 1-GRAY COUNTY WIND FARM                            |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08242 | 100.1067   | SWISSVALE - WEST GARDNER 345KV CKT 1                         |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 100        | GEN560695 1-G11-008-3 0.6900                                 |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 99.9       | GEN523971 1-HARRINGTON GEN #1 24 KV                          |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 99.9       | GEN523972 1-HARRINGTON GEN #2 24 KV                          |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 99.9       | GEN560694 1-G11-008-2 0.6900                                 |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08152 | 99.9       | MOUNDRIDGE - RENO COUNTY 115KV CKT 1                         |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08152 | 99.9       | WR-B3-8  |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.09737 | 99.8       | BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1                     |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08441 | 99.8       | BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1         |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08441 | 99.8       | BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2         |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08395 | 99.8       | SPEARVILLE (SPEARVL) 345/230/13.8KV TRANSFORMER CKT 1        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.07022 | 99.8       | G11-17T 345.00 - MULGREN7 345.00 345KV CKT 1                 |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 99.8       | GEN523973 1-HARRINGTON GEN #3 24 KV                          |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.07022 | 99.7       | MULGREN7 345.00 (MULLERGREN1) 345/230/13.8KV                 |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08292 | 99.7       | MIDW-CATB06  |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08341 | 99.6       | GEN530690 1-PRWINDG1 0.6900                                  |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08341 | 99.6       | GEN542962 2-IATAN UNIT #2                                    |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08333 | 99.6       | GEN560238 1-G10-09 0.6900                                    |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CIRCLE - MULLERGREN 230KV CKT 1                  | 318.7 | 0.08499 | 99.5       | SPP-MKEC-08  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | CLEARWATER - GILL ENERGY CENTER WEST 138KV CKT 1 | 191   | 0.03269 | 116.6579   | DBL-WICH-THI   |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | CLEARWATER - GILL ENERGY CENTER WEST 138KV CKT 1 | 191   | 0.03274 | 112.8814   | DBL-WICH-THI   |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | CLEARWATER - MILAN TAP 138KV CKT 1               | 110   | 0.03269 | 214.7735   | DBL-WICH-THI   |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | CLEARWATER - MILAN TAP 138KV CKT 1               | 110   | 0.03274 | 208.1722   | DBL-WICH-THI   |             |
| FDNS     | 06ALL     |          | 0 14G  | G12_011 | TO->FROM  | CLEARWATER - MILAN TAP 138KV CKT 1               | 110   | 0.03304 | 119.7729   | DBL-WICH-THI   |             |
| FDNS     | 6         |          | 0 14G  | G12_011 | TO->FROM  | CLEARWATER - MILAN TAP 138KV CKT 1               | 110   | 0.03314 | 113.3721   | DBL-WICH-THI   |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | FLATRDG3 - MEDICINE LODGE 138KV CKT 1            | 136.7 | 0.04411 | 116.5217   | DBL-THIS-CLR   |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | FLATRDG3 - MEDICINE LODGE 138KV CKT 1            | 136.7 | 0.04416 | 107.9487   | DBL-THIS-CLR   |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                | 153   | 0.04175 | 165.2322   | DBL-TGA-MATT   |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                | 153   | 0.04169 | 151.8831   | G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1                |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                | 153   | 0.04169 | 150.2287   | G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1          |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                | 153   | 0.04175 | 146.8398   | G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1                |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                | 153   | 0.03778 | 146.2155   | DBL-WICH-THI   |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                | 153   | 0.04175 | 145.1847   | G11_051T 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1          |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                | 153   | 0.03783 | 140.6024   | DBL-WICH-THI   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1                | 153   | 0.03069 | 134.4856   | IODINE - WOODWARD EHV 138KV CKT 1                            |             |

| SOLUTION | GROUP     | SCENARIO | SEASON | SOURCE  | DIRECTION | MONITORED ELEMENT                        | RATEB<br>(MVA) | TDF     | TC%LOADING<br>(% MVA) | CONTINGENCY                                      |
|----------|-----------|----------|--------|---------|-----------|--|----------------|---------|-----------------------|--|
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1        | 153            | 0.03069 | 132.7703              | DEWEY - IODINE 138KV CKT 1                       |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1        | 153            | 0.03107 | 119.3729              | RENFLOW7 345.00 - VIOLA 7 345.00 345KV CKT 1     |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1        | 153            | 0.03235 | 115.7981              | G12-011T 345.00 - POST ROCK 345KV CKT 1          |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1        | 153            | 0.03107 | 115.1276              | VIOLA 7 345.00 - WICHITA 345KV CKT 1             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1        | 153            | 0.03089 | 114.1281              | IODINE - WOODWARD EHV 138KV CKT 1                |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1        | 153            | 0.03089 | 112.4162              | DEWEY - IODINE 138KV CKT 1                       |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1        | 153            | 0.03093 | 110.5149              | IODINE - WOODWARD EHV 138KV CKT 1                |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1        | 153            | 0.03093 | 108.8498              | DEWEY - IODINE 138KV CKT 1                       |
| FDNS     | 6         |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1        | 153            | 0.04186 | 101.687               | DBL-TGA-MATT                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | FPL SWITCH - WOODWARD 138KV CKT 1        | 153            | 0.03124 | 100.6461              | RENFLOW7 345.00 - VIOLA 7 345.00 345KV CKT 1     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | GREAT BEND TAP - MULLERGREEN 115KV CKT 1 | 79.7           | 0.03053 | 165.8295              | DBL-THIS-CLR                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | GREAT BEND TAP - MULLERGREEN 115KV CKT 1 | 79.7           | 0.03055 | 157.6305              | DBL-THIS-CLR                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | GREAT BEND TAP - MULLERGREEN 115KV CKT 1 | 79.7           | 0.03053 | 136.2894              | DBL-IRON-CLR                                     |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | GREAT BEND TAP - MULLERGREEN 115KV CKT 1 | 79.7           | 0.0304  | 129.694               | DBL-SPRVL-CL                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | GREAT BEND TAP - MULLERGREEN 115KV CKT 1 | 79.7           | 0.03055 | 128.9195              | DBL-IRON-CLR                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | GREAT BEND TAP - MULLERGREEN 115KV CKT 1 | 79.7           | 0.03053 | 115.8349              | DBL-SPRVL-CL                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | GREAT BEND TAP - MULLERGREEN 115KV CKT 1 | 79.7           | 0.03055 | 109.1276              | DBL-SPRVL-CL                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | GREAT BEND TAP - SEWARD 115KV CKT 1      | 80.3           | 0.03053 | 164.5754              | DBL-THIS-CLR                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | GREAT BEND TAP - SEWARD 115KV CKT 1      | 80.3           | 0.03055 | 156.4303              | DBL-THIS-CLR                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | GREAT BEND TAP - SEWARD 115KV CKT 1      | 80.3           | 0.03053 | 135.2317              | DBL-IRON-CLR                                     |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | GREAT BEND TAP - SEWARD 115KV CKT 1      | 80.3           | 0.0304  | 128.6924              | DBL-SPRVL-CL                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | GREAT BEND TAP - SEWARD 115KV CKT 1      | 80.3           | 0.03055 | 127.8955              | DBL-IRON-CLR                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | GREAT BEND TAP - SEWARD 115KV CKT 1      | 80.3           | 0.03053 | 114.9144              | DBL-SPRVL-CL                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | GREAT BEND TAP - SEWARD 115KV CKT 1      | 80.3           | 0.03055 | 108.2461              | DBL-SPRVL-CL                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | HARPER - MILAN TAP 138KV CKT 1           | 110            | 0.03269 | 225.2153              | DBL-WICH-THI                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | HARPER - MILAN TAP 138KV CKT 1           | 110            | 0.03274 | 218.684               | DBL-WICH-THI                                     |
| FDNS     | 06ALL     |          | 0 14G  | G12_011 | FROM->TO  | HARPER - MILAN TAP 138KV CKT 1           | 110            | 0.03304 | 130.3028              | DBL-WICH-THI                                     |
| FDNS     | 6         |          | 0 14G  | G12_011 | FROM->TO  | HARPER - MILAN TAP 138KV CKT 1           | 110            | 0.03314 | 123.9095              | DBL-WICH-THI                                     |
| FDNS     | 14ALL     |          | 0 14G  | G12_011 | FROM->TO  | HARPER - MILAN TAP 138KV CKT 1           | 110            | 0.03332 | 109.1508              | DBL-WICH-THI                                     |
| FDNS     | 14        |          | 0 14G  | G12_011 | FROM->TO  | HARPER - MILAN TAP 138KV CKT 1           | 110            | 0.03333 | 108.4529              | DBL-WICH-THI                                     |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | HAYS PLANT - SOUTH HAYS 115KV CKT 1      | 99             | 0.06607 | 158.7036              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | HAYS PLANT - SOUTH HAYS 115KV CKT 1      | 99             | 0.06626 | 140.8065              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | HAYS PLANT - SOUTH HAYS 115KV CKT 1      | 99             | 0.06626 | 135.9975              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 00G12_011 |          | 0 14SP | G12_011 | TO->FROM  | HAYS PLANT - SOUTH HAYS 115KV CKT 1      | 99             | 0.06644 | 101.894               | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | HAYS PLANT - VINE STREET 115KV CKT 1     | 88             | 0.06607 | 155.4805              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | HAYS PLANT - VINE STREET 115KV CKT 1     | 88             | 0.06626 | 135.3013              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | HAYS PLANT - VINE STREET 115KV CKT 1     | 88             | 0.06626 | 129.8858              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | KNOLL - N HAYS3 115.00 115KV CKT 1       | 88             | 0.06607 | 141.9581              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | KNOLL - N HAYS3 115.00 115KV CKT 1       | 88             | 0.06626 | 121.6283              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | KNOLL - N HAYS3 115.00 115KV CKT 1       | 88             | 0.06626 | 116.2287              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1 | 398            | 0.19214 | 101.268               | AXTELL - POST ROCK 345KV CKT 1                   |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | MULLERGREEN - SOUTH HAYS 230KV CKT 1     | 297            | 0.10797 | 117.3779              | G12-011T 345.00 - POST ROCK 345KV CKT 1          |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | TO->FROM  | N HAYS3 115.00 - VINE STREET 115KV CKT 1 | 99             | 0.06607 | 130.9184              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | TO->FROM  | N HAYS3 115.00 - VINE STREET 115KV CKT 1 | 99             | 0.06626 | 112.9                 | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 3         |          | 0 14G  | G12_011 | TO->FROM  | N HAYS3 115.00 - VINE STREET 115KV CKT 1 | 99             | 0.06626 | 108.0917              | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1         |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | SEWARD - ST JOHN 115KV CKT 1             | 87.6           | 0.03778 | 177.1283              | DBL-THIS-CLR                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | SEWARD - ST JOHN 115KV CKT 1             | 87.6           | 0.03782 | 167.3411              | DBL-THIS-CLR                                     |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SEWARD - ST JOHN 115KV CKT 1             | 87.6           | 0.03209 | 152.2573              | CIRCLE - MULLERGREEN 230KV CKT 1                 |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | SEWARD - ST JOHN 115KV CKT 1             | 87.6           | 0.03778 | 142.2152              | DBL-IRON-CLR                                     |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SEWARD - ST JOHN 115KV CKT 1             | 87.6           | 0.03761 | 134.8313              | DBL-SPRVL-CL                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | SEWARD - ST JOHN 115KV CKT 1             | 87.6           | 0.03782 | 134.0634              | DBL-IRON-CLR                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | SEWARD - ST JOHN 115KV CKT 1             | 87.6           | 0.03224 | 131.5707              | CIRCLE - MULLERGREEN 230KV CKT 1                 |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | SEWARD - ST JOHN 115KV CKT 1             | 87.6           | 0.03227 | 125.2979              | CIRCLE - MULLERGREEN 230KV CKT 1                 |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | SEWARD - ST JOHN 115KV CKT 1             | 87.6           | 0.03778 | 118.5854              | DBL-SPRVL-CL                                     |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | SEWARD - ST JOHN 115KV CKT 1             | 87.6           | 0.03782 | 111.0867              | DBL-SPRVL-CL                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1     | 330            | 0.1317  | 128.5642              | DBL-THIS-CLR                                     |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1     | 330            | 0.14301 | 126.5695              | AXTELL - POST ROCK 345KV CKT 1                   |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1     | 330            | 0.12059 | 121.9674              | CIRCLE - MULLERGREEN 230KV CKT 1                 |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1     | 330            | 0.13177 | 121.2359              | DBL-THIS-CLR                                     |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1     | 330            | 0.11861 | 116.1379              | DBL-WICH-THI                                     |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1     | 330            | 0.13114 | 114.7746              | DBL-SPRVL-CL                                     |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1     | 330            | 0.11127 | 112.1753              | CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 1 |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1     | 330            | 0.11127 | 112.1753              | CLARKCOUNTY7345.00 - THISTLE7 345.00 345KV CKT 2 |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1     | 330            | 0.1317  | 111.0269              | DBL-IRON-CLR                                     |

| SOLUTION | GROUP     | SCENARIO | SEASON | SOURCE  | DIRECTION | MONITORED ELEMENT                    | RATEB |         | TC%LOADING |  | CONTINGENCY |
|----------|-----------|----------|--------|---------|-----------|--------------------------------------|-------|---------|------------|--|-------------|
|          |           |          |        |         |           |                                      | (MVA) | TDF     | (% MVA)    |  |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.11868 | 110.9301   | DBL-WICH-THI   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10852 | 108.9427   | THISTLE7 345.00 - WICHITA 345KV CKT 1                        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10852 | 108.9427   | THISTLE7 345.00 - WICHITA 345KV CKT 2                        |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.14356 | 108.8517   | AXTELL - POST ROCK 345KV CKT 1                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10957 | 107.4035   | BEAVER CO 345.00 - BUCKNER7 345.00 345KV CKT 1               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.11042 | 106.3622   | AXTELL - PAULINE 345KV CKT 1                                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10545 | 106.062    | GEN532652 1-JEFFREY ENERGY CENTER UNIT 2                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10545 | 106.0613   | GEN532653 1-JEFFREY ENERGY CENTER UNIT 3                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10545 | 105.8076   | GEN532651 1-JEFFREY ENERGY CENTER UNIT 1                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10771 | 105.553    | GRAND ISLAND - SWEETWATER 345KV CKT 1                        |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.13177 | 105.1165   | DBL-IRON-CLR   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10944 | 105.0777   | MOORE - PAULINE 345KV CKT 1                                  |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.12109 | 105.0227   | CIRCLE - MULLERGEN 230KV CKT 1                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10545 | 104.9588   | GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1081  | 104.5401   | CIRCLE - EAST MCPHERSON 230KV CKT 1                          |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10743 | 103.8692   | SPP-SWPS-05  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10743 | 103.7873   | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.14363 | 103.4675   | AXTELL - POST ROCK 345KV CKT 1                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1083  | 103.2437   | CLARKCOUNTY7345.00 - IRONWOOD7 345.00 345KV CKT 1            |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1083  | 103.1247   | CLARKCOUNTY7345.00 - SPEARVILLE 345KV CKT 1                  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.11367 | 103.0451   | BUCKNER7 345.00 - SPEARVILLE 345KV CKT 1                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10663 | 102.6785   | ST JOHN - ST JOHN 115KV CKT 1                                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10545 | 102.498    | GEN542962 2-IATAN UNIT #2                                    |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10615 | 102.4464   | BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1         |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10615 | 102.4464   | BEAVER CO 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2         |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10729 | 102.4382   | SPP-MKEC-06  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10729 | 102.4217   | SEWARD - ST JOHN 115KV CKT 1                                 |             |
| FNSL     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10736 | 102.4022   | ELM CREEK - NORTHWEST MANHATTAN 230KV CKT 1                  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1056  | 102.2973   | MINGO - RED WILLOW 345KV CKT 1                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10653 | 102.2598   | GRAND ISLAND - MCCOOL 345KV CKT 1                            |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10786 | 102.2013   | PHILLIPSBURG - SMITH CENTER 115KV CKT 1                      |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10734 | 102.1823   | KNOLL - SALINE RIVER 115KV CKT 1                             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10545 | 102.1554   | GEN542955 1-LACYGNE UNIT #1                                  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10545 | 102.1507   | GEN542956 2-LACYGNE UNIT #2                                  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10567 | 102.1011   | STEGALL TY 345/230KV TRANSFORMER CKT 1                       |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10567 | 102.0985   | STEGALL - STEGALL TY 345KV CKT 1                             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10567 | 102.0944   | STEGALL - STEGALL TRANSFORMER 230KV CKT 1                    |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10567 | 102.0919   | TRF-STEGALL  |             |
| FNSL     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1063  | 102.0716   | SPP-MKEC-08  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10545 | 102.0515   | GEN542957 1-IATAN UNIT #1                                    |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10545 | 101.9989   | GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5                    |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10734 | 101.9693   | PLAINVILLE - SALINE RIVER 115KV CKT 1                        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10663 | 101.7581   | HUNTSVILLE - ST JOHN 115KV CKT 1                             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1058  | 101.7517   | SPP-MKEC-09B   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10653 | 101.7398   | MCCOOL - MOORE 345KV CKT 1                                   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10663 | 101.724    | MIDW-CAT805  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1058  | 101.6664   | GREENSBURG - SSTARTP3 115.00 115KV CKT 1                     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10545 | 101.6092   | GEN542951 5-HAWTHORN UNIT #5                                 |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10663 | 101.5852   | HUNTSVILLE - HUTCHINSON ENERGY CENTER 115KV CKT 1            |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10629 | 101.5813   | G10-056T 345.00 - ST JOE 345KV CKT 1                         |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1059  | 101.52     | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1059  | 101.52     | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 2                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10633 | 101.5186   | GREAT BEND TAP - SEWARD 115KV CKT 1                          |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1058  | 101.5162   | GREENSBURG - SUN CITY 115KV CKT 1                            |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10734 | 101.5144   | PHILLIPSBURG - PLAINVILLE 115KV CKT 1                        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10633 | 101.5094   | GREAT BEND TAP - MULLERGEN 115KV CKT 1                       |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10617 | 101.4753   | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV      |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.1058  | 101.427    | MEDICINE LODGE - SUN CITY 115KV CKT 1                        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10585 | 101.3844   | HARPER - MILAN TAP 138KV CKT 1                               |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10601 | 101.3734   | EMPORIA ENERGY CENTER - WICHITA 345KV CKT 1                  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10629 | 101.3707   | COOPER - G10-056T 345.00 345KV CKT 1                         |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10585 | 101.3521   | SPP-MKEC-03A   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10585 | 101.324    | SPP-MKEC-05  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1 | 330   | 0.10568 | 101.3194   | NUNDRWD - WAYSIDE 230KV CKT 1                                |             |

| SOLUTION | GROUP     | SCENARIO | SEASON | SOURCE  | DIRECTION | MONITORED ELEMENT  | RATEB |         | TC%LOADING |  | CONTINGENCY |
|----------|-----------|----------|--------|---------|-----------|--|-------|---------|------------|--|-------------|
|          |           |          |        |         |           |  | (MVA) | TDF     | (% MVA)    |  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                     | 330   | 0.10545 | 101.2669   | GEN541151 3-SIBLEY GENERATING UNIT #3                  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                     | 330   | 0.1058  | 101.2549   | BARBER 3 115.00 - MEDICINE LODGE 115KV CKT 1           |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                     | 330   | 0.10731 | 101.202    | BEACH STATION - G10-48T 115.00 115KV CKT 1             |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                     | 330   | 0.10746 | 101.0019   | KNOLL 230 (KNOLL T1) 230/115/11.49KV TRANSFORMER CKT 1 |             |
| FDNS     | 3         |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                     | 330   | 0.12116 | 100.2088   | CIRCLE - MULLERGREN 230KV CKT 1                        |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                     | 330   | 0.10545 | 100.0976   | BASE CASE  |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                     | 330   | 0.10545 | 100.0976   | NC1 GEN-NEBRASKA CITY 1                                |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                     | 330   | 0.09336 | 99.9       | SUMMIT (SUMMIT1X) 345/230/14.4KV TRANSFORMER CKT 1     |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                     | 330   | 0.10551 | 99.5       | MINGO - SETAB 345KV CKT 1                              |             |
| FDNS     | 03G12_011 |          | 0 14G  | G12_011 | FROM->TO  | SMOKYHL6 230.00 - SUMMIT 230KV CKT 1                     | 330   | 0.1317  | 99.5       | DBL-SPRVL-CL   |             |
| FDNS     | 03ALL     |          | 0 14G  | G12_011 | FROM->TO  | SOUTH HAYS (S HAYS T1) 230/115/12.47KV TRANSFORMER CKT 1 | 166.7 | 0.06607 | 100.7895   | KNOLL 230 - POSTROCK6 230.00 230KV CKT 1               |             |

## **I: Power Flow Analysis (Category C Contingencies)**

See next page.