

GEN-2013-027

Impact Restudy for Generator Modification (Turbine Change)

August 2017
Generator Interconnection

Revision History

| Date | Author | Change Description |
|-----------|--------|--|
| 8/23/2017 | SPP | GEN-2013-027 Impact Restudy for Generator Modification Report Issued |
| | | |
| | | |

Executive Summary

The GEN-2013-027 Interconnection Customer has requested a modification to its Generator Interconnection Request to change wind turbine generators for its project. Previously, it consisted of sixty-one (61) Siemens 108m 2.3MW and four (4) Siemens 108m with Powerboost 2.415MW wind turbines for a total of 149.96 MW. The requested change is for forty-three (43) Vestas V126 GulfStream (GS) 3.45MW wind for a total of 148.35 MW. The Point of Interconnection (POI) is the new Southwestern Public Service Company (SPS) Needmore 230 kV Substation.

The study models used were the 2016 winter, 2017 summer, and 2025 summer models that included Interconnection Requests through the facility study queue at DISIS-2015-002. Additionally, DISIS-2015-001 models were also created from the DISIS-2015-002 models in order to provide a baseline verification for the turbine change. The baseline verification was used to identify Network Upgrade(s) triggered by the addition of the lower queued DISIS-2015-002 generation.

The restudy showed that the stability analysis has determined with all previously assigned Network Upgrades in service, generators in the monitored areas remained stable and within the pre-contingency, voltage recovery, and post fault voltage recovery criterion of 0.7pu to 1.2pu for the entire modeled disturbances. Additionally, the project wind farm was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

Power factor analysis for the study generation project was performed on the 2016 winter peak, 2017 summer peak, and 2025 summer peak cases with identified system upgrades up to the DISIS-2015-001 queue position. As reactive power is required for GEN-2013-027, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.

An analysis was conducted to determine the capacitive effects on the transmission system caused by the generator lead and collector system during periods of reduced generation. To offset these effects, the generating facility is required to provide reactive compensation of approximately 4 Mvar of inductive reactance during periods of reduced generation. Such compensation can be provided either by discrete reactive devices or by the generator itself if it possesses that capability.

Short Circuit analysis was conducted using the current study upgrade 2017 summer peak and 2025 summer peak cases.

With the assumptions outlined in this report and with all the required network upgrades from the DISIS 2015-002 in place, GEN-2013-027 with the Vestas V126 GS 3.45MW wind turbine generators should be able to interconnect reliably to the SPP transmission grid. At this time, the change in wind turbine generator is not a Material Modification.

It should be noted that this study analyzed the requested modification to change generator technology, manufacturer, and layout. Power flow analysis was not performed. This study analyzed many of the most probable contingencies, but it is not an all-inclusive list and cannot account for every operational situation. It is likely that the customer may be required to reduce its generation output to 0 MW, also known as

curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of delivery or transmission service. If the customer wishes to sell power from the facility, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the Customer.

Table of Contents

| | |
|--|------------|
| Revision History | 1 |
| Executive Summary..... | i |
| Table of Contents | iii |
| 1. Introduction..... | 1 |
| 2. Facilities..... | 4 |
| 3. Stability Analysis..... | 5 |
| Model Preparation | 5 |
| Disturbances..... | 5 |
| Results | 10 |
| FERC LVRT Compliance..... | 12 |
| 4. Power Factor Analysis..... | 13 |
| Model Preparation | 13 |
| Disturbances..... | 13 |
| Results | 13 |
| 5. Reduced Wind Generation Analysis | 14 |
| 6. Short Circuit Analysis | 17 |
| Results | 17 |
| 7. Conclusion | 18 |
| Appendix A – 2016 Winter Peak Stability Plots | 20 |
| Appendix B – 2017 Summer Peak Stability Plots | 21 |
| Appendix C – 2025 Summer Peak Stability Plots | 22 |
| Appendix D – Power Factor Analysis Results | 23 |
| Appendix E – Reduced Wind Generation Analysis Results | 24 |
| Appendix F – Short Circuit Analysis Results | 25 |

1. Introduction

The GEN-2013-027 Interconnection Customer has requested a modification to its Generator Interconnection Request to change its generators from Siemens 2.3 MW and 2.415 MW wind turbines to Vestas V126 GS 3.45MW wind turbines. Previously, sixty-one (61) Siemens 108m 2.3MW and four (4) Siemens 108m with Powerboost 2.415MW wind turbines. The requested change is shown in **Table 1-1**.

Table 1-1: Interconnection Request

| Request | Capacity (MW) | Generator Model | Point of Interconnection |
|--------------|---------------|---------------------------------|--|
| GEN-2013-027 | 148.35 | 43 x Vestas V126 GS G114 3.45MW | Tap Tolk (525531) – Yoakum (526935) 230kV, Needmore 230 kV |

Other queued generation projects in the model are listed in **Table 1-2**.

Table 1-2: Other Queued Interconnection Requests in the Model

| Request | Capacity (MW) | Generator Model | Point of Interconnection |
|---------------|--------------------------|--|--|
| GEN-2001-033 | 180 | Mitsubishi 1000 (524890, 524896) | San Juan Mesa 230kV (524885) |
| GEN-2001-036 | 80 | Mitsubishi 1000 (583316) | Norton 115kV (524502) |
| GEN-2006-018 | 170 | GENSAL (525841 A1, 525842 B1, 525843 C1) | Tuco 230kV (525830) |
| GEN-2006-026 | 502 | GENROU (527901, 527902, 527903) | Hobbs 115kV(527891) Hobbs 230kV (527894) |
| GEN-2008-022 | 300 | Vestas (577100, 577110, 577120) | Tap on Eddy County – Tolk 345kV line (G08-022-POI, 560007) |
| GEN-2010-006 | 180 Summer 205 Winter | GENROU (526333) | Jones_bus2 230kV(526337) |
| ASGI-2010-010 | 42 | GENSAL (528331) | Lovington 115kV (528334) |
| ASGI-2010-020 | 30 | GE 2.3MW (580088) | Tap LE-Tatum to LE-Crsroads 69kV (AS10-020-POI, 560360) |
| ASGI-2010-021 | 15 | Mitsubishi MPS-1000A 1.0MW (580083) | Tap LE-Saundrtp to LE-Anderson 69kV (ASGI-021-POI, 560364) |
| GEN-2010-046 | 56 | GENSAL (580043) | Tuco 230kV (525830) |
| ASGI-2011-001 | 27.3 | Suzlon S97 2.1MW (579423) | Lovington 115kV (528334) |
| ASGI-2011-003 | 10 | Sany 2.0MW (579433) | Hendricks 69kV (525943) |
| ASGI-2011-004 | 19.8 | Sany 1.8MW (583193, 583196) | Crosby 69kV (525915) |
| GEN-2011-025 | 80 | GE 1.79MW (581140) | Tap on Floyd County - Crosby County 115kV line (G11-025-POI, 562004) |
| GEN-2011-045 | 180 Summer 205 Winter | GENROU (526334) | Jones_bus2 230kV (526337) |
| GEN-2011-046 | 23 Summer 27 Winter | GENROU (524471) | Quay County 115kV (524472) |
| GEN-2011-048 | 165 Summer 175 Winter | GENROU | Mustang 230kV (527151) |

Table 1-2: Other Queued Interconnection Requests in the Model

| Request | Capacity (MW) | Generator Model | Point of Interconnection |
|---|--|--|--|
| GEN-2012-001 | 61.2 | CCWE 3.6MW (WT4) (599126) | Tap Grassland to Borden 230kV (526679) |
| ASGI-2012-002 | 18 | Vestas 1.65MW V82 (583283) | Clovis 115kV (524808) |
| GEN-2012-020 | 478 | GE 1.68MW (583343, 583346) | Tuco 230kV (525830) |
| GEN-2012-034 | 7 MW increase (Pgen=157MW) | GENROU (unit 4; 527164) | Mustang 230kV (527151) |
| GEN-2012-035 | 7 MW increase (Pgen=157MW) | GENROU (unit 5; 527165) | Mustang 230kV (527151) |
| GEN-2012-036 | 7 MW increase (Pgen=172MW Summer/185MW Winter) | GENROU (unit 6; 527166) | Mustang 230kV (527151) |
| GEN-2012-037 | 196 Summer 203 Winter | GENROU (525844) | Tuco 345kV (525832) |
| GEN-2013-016 | 191 Summer 203 Winter | GENROU (525845) | Tuco 345kV (525832) |
| ASGI-2013-002 | 18.4 | Siemens 2.3MW VS (583613) | Tucumcari 115kV (524509) |
| ASGI-2013-003 | 18.4 | Siemens 2.3MW VS (583623) | Clovis 115kV (524808) |
| ASGI-2013-005 (ASGI-2012-002) | 19.8 | Vestas V82 1.65MW (583283) | FE-Clovis 115kV (524808) |
| ASGI-2013-006 | 2.0 | Gamesa G114 2MW (583813) | Erskine 115kV (526109) |
| GEN-2013-022 | 25.0 | Solaron 500kW (583313) | Caprock 115kV (524486) |
| GEN-2013-027 | 150.0 | Vestas V126 3.45MW (583843) | Tap on Yoakum to Tolk 230kV (562480) |
| GEN-2014-012 (Only in 2020SP, 2020WP, & 2025SP) | 186 Summer 225 Winter | GENROU (528501) | Tap Hobbs (527894) to Andrews (528604) 230kV (Tap bus is 528611) |
| ASGI-2014-001 | 2.5 | GE 107m 2.5MW (583816) | Erskine 69kV (526109) |
| GEN-2014-033 | 70 | GE LV5 4.0MW Inverters and Schneider XC 680 0.68MVA Inverters (583953, 583956) | Chaves County 115kV |
| GEN-2014-034 | 70 | GE LV5 4.0MW Inverters (583963) | Chaves County 115kV |
| GEN-2014-035 | 30 | GE LV5 4.0MW Inverters (583973) | Chaves County 115kV |
| GEN-2014-047 | 40 | AE 500NX 0.5 MW PV inverters (584263) | Tap Tolk - Eddy County (Crossroads) 345kV |

A stability analysis was performed for the change in wind turbines. The analysis was performed on three (3) seasonal models including 2016 winter peak (16WP), the 2017 summer peak (17SP), and the 2025 summer peak (25SP) cases. These cases are modified versions of the 2015 model series of Model Development Working Group (MDWG) dynamic study models that included upgrades and Interconnection Requests through DISIS-2015-002.

The stability analysis determines the impacts of the new interconnecting project on the stability and voltage recovery of the nearby systems and the ability of the interconnecting project to meet FERC Order 661A. If problems with stability or voltage recovery are identified, the need for reactive compensation or system upgrades is investigated. The contingencies listed in **Table 3-1** were used in the stability analysis.

The power factor analysis determines the power factor at the point of interconnection (POI) for the wind interconnection projects for pre-contingency and post-contingency conditions. The contingencies used in the power factor analysis are a subset of the stability analysis contingencies shown in **Table 3-1**.

A reduced (low wind/no wind) generation analysis was performed to determine reactor inductive amounts to compensate for the capacitive effects on the transmission system caused by the interconnecting project's generator lead transmission line and collector systems during low or reduced wind conditions.


Short Circuit analysis was conducted using the current study upgrade 2017 summer peak and 2025 summer peak cases. The results from the Short circuit analysis are shown in **Appendix F**.

Nothing in this System Impact Study constitutes a request for transmission service or grants the Interconnection Customer any rights to transmission service. If the customer wishes to sell power from the facility, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the Customer.

2. Facilities

A one-line PSS/E slider drawing from the 16WP case is shown in **Figure 2-1** for GEN-2013-027. The POI is the new SPS Needmore 230 kV substation.

Figure 2-1: GEN-2013-027 One-line Diagram



3. Stability Analysis

Transient stability analysis is used to determine if the transmission system can maintain angular stability and ensure bus voltages stay within planning criteria bandwidth during and after a disturbance while considering the addition of a generator interconnection request.

Model Preparation

Transient stability analysis was performed using modified versions of the 2015 series of Model Development Working Group (MDWG) dynamic study models including the 2016 winter peak, 2017 summer peak, and the 2025 summer peak seasonal models. The cases are then loaded with prior queued interconnection requests and network upgrades assigned to those interconnection requests. Finally the prior queued and study generation are dispatched into the SPP footprint. Initial simulations are then carried out for a no-disturbance run of twenty (20) seconds to verify the numerical stability of the model.

Disturbances

Thirty-one (31) contingencies were identified for use in this study and are listed in **Table 3-1**. These contingencies are faults at locations defined by SPP Generation Interconnection Staff. These contingencies include three-phase and single-phase N-1. Single-phase line faults were simulated by applying fault impedance to the positive sequence network at the fault location to represent the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the specified fault location of approximately 60% of pre-fault voltage. This method is in agreement with SPP current practice.

Except for transformer faults, the typical sequence of events for a three-phase and single-phase fault is as follows:

1. apply fault at particular location
2. continue fault for five (5) cycles, clear the fault by tripping the faulted facility
3. after an additional twenty (20) cycles, re-close the previous facility back into the fault
4. continue fault for five (5) additional cycles
5. trip the faulted facility and remove the fault

Transformer faults are typically modeled as three-phase faults, unless otherwise noted. The sequence of events for a transformer fault is as follows:

1. apply fault for five (5) cycles
2. clear the fault by tripping the affected transformer facility (unless otherwise noted there will be no re-closing into a transformer fault)

The SPP areas monitored during the stability analysis were:

- 520: American Electric Power (AEPW)
- 524: Oklahoma Gas and Electric Company (OKGE)
- 525: Western Farmers Electric Cooperative (WFEC)
- 526: Southwestern Public Service Company (SPS)

Table 3-1: Contingencies Evaluated

| Cont. No. | Contingency Name | Description |
|-----------|--|--|
| 0 | FLT_000_NOFAULT | No Fault Conditions |
| 1 | FLT_01_CROSSROADS7_EDDYCNTY7_345kV_3PH | 3 phase fault on Crossroads 345kV (527656) to Eddy County 345kV (527802) CKT 1, near Crossroads. a. Apply fault at the Crossroads 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 2 | FLT_02_CROSSROADS7_TOLK7_345kV_3PH | 3 phase fault on Crossroads 345kV (527656) to Tolk 345kV (525549) CKT 1, Crossroads. a. Apply fault at the Crossroads 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 3 | FLT_03_TOLKTAP6_TOLK7_230_345kV_3PH | 3 phase fault on the Tolk Tap 230kV (525543) to Tolk 345kV (525549) to Tolk 13.2kV (525537) XFMR CKT 1, near Tolk Tap 230kV. a. Apply fault at the Tolk Tap 230kV bus. b. Clear fault after 5 cycles and trip the faulted transformer. |
| 4 | FLT_04_G13027TAP_TOLKWEST6_230kV_3PH | 3 phase fault on the GEN-2013-027 (562480) to Tolk West (525531) 230 kV line, near GEN-2013-027. a. Apply fault at the GEN-2013-027 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 5 | FLT_05_G13027TAP_YOAKUM6_230kV_3PH | 3 phase fault on the GEN-2013-027 (562480) to Yoakum (526935) 230 kV line, near GEN-2013-027. a. Apply fault at the GEN-2013-027 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 6 | FLT_06_YOAKUM6_AMOCOS6_230kV_3PH | 3 phase fault on the Yoakum (526935) to Amoco-SS (526460) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

Table 3-1: Contingencies Evaluated

| Cont. No. | Contingency Name | Description |
|-----------|---------------------------------------|---|
| 7 | FLT_07_YOAKUM6_OXYBRUTP6_230kV_3PH | 3 phase fault on the Yoakum (526935) to OxyBru Tap (527010) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 8 | FLT_08_YOAKUM6_MUSTANG6_230kV_3PH | 3 phase fault on the Yoakum (526935) to Mustang (527149) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 9 | FLT_09_YOAKUM6_G1579G1580T_230kV_3PH | 3 phase fault on the Yoakum (526935) to G1579&G1580T (560059) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 10 | FLT_10_YOAKUM6_YOAKUM3_230_115kV_3PH | 3 phase fault on the Yoakum 230kV (526935) to Yoakum 115 kV (526934)/13.2 kV (526931) transformer circuit #1, near Yoakum. a. Apply fault at the Yoakum 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer and remove fault. |
| 11 | FLT_11_TOLKWEST6_ROSEVELTN6_230kV_3PH | 3 phase fault on Tolk West 230kV (525531) to Roosevelt 230kV (524909) CKT 2, near Tolk West. a. Apply fault at the Tolk West 230kV bus. b. Clear fault after 5 cycles and trip the faulted line. |
| 12 | FLT_12_TOLKWEST6_PLANTX6_230kV_3PH | 3 phase fault on the Tolk West (525531) to Plant X (525481) 230 kV circuit #1 line, near Tolk West. a. Apply fault at the Tolk West 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 13 | FLT_13_TOLK7_TOLKTAP6_345_230kV_3PH | 3 phase fault on the Tolk 345 kV (525549) to Tolk Tap 230 kV (525543)/ 13.2 kV (525537) transformer, near Tolk 345 kV. a. Apply fault at the Tolk 345kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 14 | FLT_14_TOLKWEST6_LAMBCNTY6_230kV_3PH | 3 phase fault on the Tolk West (525531) to Lamb Co (525637) 230 kV line, near Tolk West. a. Apply fault at the Tolk West 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |

Table 3-1: Contingencies Evaluated

| Cont. No. | Contingency Name | Description |
|-----------|---|---|
| 15 | FLT_15_TUCOINT7_BORDER7_345kV_3PH | 3 phase fault on the Tuco (525832) to Border (515458) 345kV line circuit 1, near Tuco. a. Apply fault at the Tuco 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 16 | FLT_16_BORDER7_WWRDEHV7_345kV_3PH | 3 phase fault on the Border (515458) to Woodward (515375) 345kV line circuit 1, near Border. a. Apply fault at the Border 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 17 | FLT_17_TUCOINT7_OKU7_345kV_3PH | 3 phase fault on the Tuco (525832) to OKU (511456) 345kV line circuit 1, near Tuco. a. Apply fault at the Tuco 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 18 | FLT_18_TOLKWEST6_G13027TAPSB_230kV_1PH | Single phase fault with stuck breaker on the Tolk West (525531) to GEN-2013-027 (562480) 230 kV line, near Tolk West. a. Apply fault at the Tolk West 230kV bus. b. Run 5 cycles, and then open GEN-2013-027 end of the faulted line. c. Run 10 cycles, and then clear the fault, disconnect Tolk West (525531) 230 kV bus, drop the Tolk 2 machine and disconnect the bus at 525562. |
| 19 | FLT_19_YOAKUM6_G13027TAPSB_230kV_1PH | Single phase fault with stuck breaker on the Yoakum (526935) to GEN-2013-027 (562480) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230kV bus. b. At 5 cycles, open GEN-2013-027 end of the faulted line. c. At 15 cycles, clear the fault and open Yoakum end of the line in (b) and trip Yoakum (526935) to Yoakum 115 (526934)/13.2 kV (526931) transformer circuit #1. |
| 20 | FLT_20_YOAKUM6_YOAKUM3PO_230_115kV_3PH_16WP | (Prior Outage) Yoakum (526935) – Amoco-SS (526460) 230 kV out of service then 3 phase fault on the Yoakum 230 kV (526935) to Yoakum 115 kV (526934)/13.2 kV (526931) transformer circuit #1, near Yoakum. Switch Yoakum (526935) – Amoco-SS (526460) out of service then solve. a. Apply fault at the Yoakum 230kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer and remove fault. |

Table 3-1: Contingencies Evaluated

| Cont. No. | Contingency Name | Description |
|-----------|---|---|
| 21 | FLT_21_YOAKUM6_AMOCOS6SB_230kV_1PH | Single phase fault with stuck breaker on the Yoakum (526935) to Amoco-SS (526460) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230kV bus. b. At 5 cycles, open Amoco-SS end of the faulted line. c. At 15 cycles, clear the fault and trip Yoakum 230 kV (526935) bus. |
| 22 | FLT_22_TOLKWEST6_ROSEVELTN6SB_230kV_1PH | Single phase fault with stuck breaker on the Tolk West (525531) to Roosevelt N (524909) 230 kV line, near Tolk West. a. Apply fault at the Tolk West 230kV bus. b. Run 5 cycles, and then open Roosevelt N end of the faulted line. c. Run 10 cycles, and then clear the fault, disconnect Tolk West (525531) 230 kV bus, drop the Tolk 2 machine and disconnect the bus at 525562. |
| 23 | FLT_23_TOLKWEST6_PLANTX6SB_230kV_1PH | Single phase fault with stuck breaker on the Tolk West (525531) to Plant X (525481) 230 kV circuit #1 line, near Tolk West. a. Apply fault at the Tolk West 230kV bus. b. Run 5 cycles, and then open Plant X end of the faulted line. c. Run 10 cycles, and then clear the fault, disconnect Tolk West (525531) 230 kV bus, drop the Tolk 2 machine and disconnect the bus at 525562. |
| 24 | FLT_24_TOLKWEST6_LAMBCNTY6SB_230kV_1PH | Single phase fault with stuck breaker on the Tolk West (525531) to Lamb Co (525637) 230 kV line, near Tolk West. a. Apply fault at the Tolk West 230kV bus. b. Run 5 cycles, and then open Lamb Co end of the faulted line. c. Run 10 cycles, and then clear the fault, disconnect Tolk West (525531) 230 kV bus, drop the Tolk 2 machine and disconnect the bus at 525562. |
| 25 | FLT_25_TOLKEAST6_PLANTX6PO_230kV_3PH_16WP | (Prior Outage) Tolk West (525531) – Plant X (525481) 230 kV circuit #1 out of service then 3 phase fault on the Tolk East 230 kV (525524) to Plant X (525481) 230 kV circuit #2, near Tolk East. Switch Tolk West (525531) – Plant X (525481) 230 kV circuit #1 out of service then solve. a. Apply fault at the Tolk East 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 26 | FLT_26_TOLKEAST6_PLANTX6SB_230kV_1PH | Single phase fault with stuck breaker on the Tolk East (525524) to Plant X (525481) 230 kV line circuit #2, near Tolk East. a. Apply fault at the Tolk East 230kV bus. b. Run 5 cycles, and then open Plant X end of the faulted line. c. Run 10 cycles, and then clear the fault, disconnect Tolk East (525524) 230 kV bus, drop the Tolk 1 machine and disconnect the bus at 525561. |

Table 3-1: Contingencies Evaluated

| Cont. No. | Contingency Name | Description |
|-----------|---|---|
| 27 | FLT_27_HOBBSINT6_ANDREWS6SB_230kV_1PH_16WP17SP (16WP-17SP Only) | Single phase fault with stuck breaker (4K125) on the Hobbs (527894) to Andrews (528604) 230 kV circuit #1 line, near Hobbs. a. Apply fault at the Hobbs 230kV bus. b. At 5 cycles, open Andrews end of the faulted line. c. At 15 cycles, clear the fault and open Hobbs end of the line in (b) and trip Hobbs Plt (527903). |
| 28 | FLT_28_HOBBSINT6_GAINESGENTP6SB_230kV_1PH_20SP 25SP (25SP Only) | Single phase fault with stuck breaker (4K125) on the Hobbs (527894) to Gaines Generation Tap (528611) 230 kV circuit #1 line, near Hobbs. a. Apply fault at the Hobbs 230kV bus. b. At 5 cycles, open Gaines Generation Tap end of the faulted line. c. At 15 cycles, clear the fault and open Hobbs end of the line in (b) and trip Hobbs Plt (527903). |
| 29 | FLT_29_HOBBSINT6_ANDREWS6SB_230kV_1PH_16WP17SP (16WP-17SP Only) | Single phase fault with stuck breaker (4K120) on the Hobbs (527894) to Andrews (528604) 230 kV circuit #1 line, near Hobbs. a. Apply fault at the Hobbs 230kV bus. b. At 5 cycles, open Andrews end of the faulted line. c. At 15 cycles, clear the fault and open Hobbs end of the line in (b) and trip Hobbs (527894) to Cunningham (527865) and Hobbs to G1579&G1580T (560059). |
| 30 | FLT_30_HOBBSINT6_GAINESGENTP6SB_230kV_1PH_20SP 25SP (25SP Only) | Single phase fault with stuck breaker (4K120) on the Hobbs (527894) to Gaines Generation Tap (528611) 230 kV circuit #1 line, near Hobbs. a. Apply fault at the Hobbs 230kV bus. b. At 5 cycles, open Andrews end of the faulted line. c. At 15 cycles, clear the fault and open Hobbs end of the line in (b) and trip Hobbs (527894) to Cunningham (527865) and Hobbs to G14-070-TAP (560018). |
| 31 | FLT_31_HOBBSINT6_G1579G1580T_230kV_3PH | 3 phase fault on the Hobbs (527894) G1579&G1580T (560059) 230 kV line, near Hobbs. a. Apply fault at the Hobbs 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

Results

The stability analysis was performed and the results are summarized in **Table 3-2**. The stability analysis has shown that for the contingencies simulated the generators in the monitored areas remained stable and the system voltages recovered to acceptable levels.

The stability plots will be available upon customer request.

Table 3-2: Results

| Contingency Number and Name | | 2016WP | 2017SP | 2025SP |
|-----------------------------|--|--------|--------|--------|
| 0 | FLT_000_NOFAULT | STABLE | STABLE | STABLE |
| 1 | FLT_01_CROSSROADS7_EDDYCNTY7_345kV_3PH | STABLE | STABLE | STABLE |
| 2 | FLT_02_CROSSROADS7_TOLK7_345kV_3PH | STABLE | STABLE | STABLE |
| 3 | FLT_03_TOLKTAP6_TOLK7_230_345kV_3PH | STABLE | STABLE | STABLE |
| 4 | FLT_04_G13027TAP_TOLKWEST6_230kV_3PH | STABLE | STABLE | STABLE |
| 5 | FLT_05_G13027TAP_YOAKUM6_230kV_3PH | STABLE | STABLE | STABLE |
| 6 | FLT_06_YOAKUM6_AMOCOSS6_230kV_3PH | STABLE | STABLE | STABLE |
| 7 | FLT_07_YOAKUM6_OXYBRUTP6_230kV_3PH | STABLE | STABLE | STABLE |
| 8 | FLT_08_YOAKUM6_MUSTANG6_230kV_3PH | STABLE | STABLE | STABLE |
| 9 | FLT_09_YOAKUM6_G1579G1580T_230kV_3PH | STABLE | STABLE | STABLE |
| 10 | FLT_10_YOAKUM6_YOAKUM3_230_115kV_3PH | STABLE | STABLE | STABLE |
| 11 | FLT_11_TOLKWEST6_ROSEVELTN6_230kV_3PH | STABLE | STABLE | STABLE |
| 12 | FLT_12_TOLKWEST6_PLANTX6_230kV_3PH | STABLE | STABLE | STABLE |
| 13 | FLT_13_TOLK7_TOLKTAP6_345_230kV_3PH | STABLE | STABLE | STABLE |
| 14 | FLT_14_TOLKWEST6_LAMBCNTY6_230kV_3PH | STABLE | STABLE | STABLE |
| 15 | FLT_15_TUCOINT7_BORDER7_345kV_3PH | STABLE | STABLE | STABLE |
| 16 | FLT_16_BORDER7_WWRDEHV7_345kV_3PH | STABLE | STABLE | STABLE |
| 17 | FLT_17_TUCOINT7_OKU7_345kV_3PH | STABLE | STABLE | STABLE |
| 18 | FLT_18_TOLKWEST6_G13027TAPSB_230kV_1PH | STABLE | STABLE | STABLE |
| 19 | FLT_19_YOAKUM6_G13027TAPSB_230kV_1PH | STABLE | STABLE | STABLE |
| 20 | FLT_20_YOAKUM6_YOAKUM3PO_230_115kV_3PH_16WP | STABLE | STABLE | STABLE |
| 21 | FLT_21_YOAKUM6_AMOCOSS6SB_230kV_1PH | STABLE | STABLE | STABLE |
| 22 | FLT_22_TOLKWEST6_ROSEVELTN6SB_230kV_1PH | STABLE | STABLE | STABLE |
| 23 | FLT_23_TOLKWEST6_PLANTX6SB_230kV_1PH | STABLE | STABLE | STABLE |
| 24 | FLT_24_TOLKWEST6_LAMBCNTY6SB_230kV_1PH | STABLE | STABLE | STABLE |
| 25 | FLT_25_TOLKEAST6_PLANTX6PO_230kV_3PH_16WP | STABLE | STABLE | STABLE |
| 26 | FLT_26_TOLKEAST6_PLANTX6SB_230kV_1PH | STABLE | STABLE | STABLE |
| 27 | FLT_27_HOBBSINT6_ANDREWS6SB_230kV_1PH_16WP17SP (16WP-17SP Only) | STABLE | STABLE | |
| 28 | FLT_28_HOBBSINT6_GAINESGENTP6SB_230kV_1PH_20SP2 5SP (25SP Only) | | | STABLE |
| 29 | FLT_29_HOBBSINT6_ANDREWS6SB_230kV_1PH_16WP17SP (16WP-17SP Only) | STABLE | STABLE | |
| 30 | FLT_30_HOBBSINT6_GAINESGENTP6SB_230kV_1PH_20SP2 5SP (25SP Only) | | | STABLE |
| 31 | FLT_31_HOBBSINT6_G1579G1580T_230kV_3PH | STABLE | STABLE | STABLE |

FERC LVRT Compliance

FERC Order 661A places specific requirements on wind farms through its Low Voltage Ride Through (LVRT) provisions. For Interconnection Agreements signed after December 31, 2006, wind farms shall stay on line for faults at the POI that draw the voltage down at the POI to 0.0 pu. The faults listed below in **Table 3-3** were tested to meet Order 661A LVRT provisions. GEN-2013-027 was found to be in compliance with FERC Order 661A.

Table 3-3: LVRT Contingencies

| Contingency Number and Name | Description |
|--------------------------------------|--|
| FLT_04_G13027TAP_TOLKWEST6_230kV_3PH | <p>3 phase fault on the GEN-2013-027 (562480) to Tolk West (525531) 230 kV line, near GEN-2013-027.</p> <ul style="list-style-type: none"> a. Apply fault at the GEN-2013-027 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| FLT_05_G13027TAP_YOAKUM6_230kV_3PH | <p>3 phase fault on the GEN-2013-027 (562480) to Yoakum (526935) 230 kV line, near GEN-2013-027.</p> <ul style="list-style-type: none"> a. Apply fault at the GEN-2013-027 230kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

4. Power Factor Analysis

The power factor analysis was performed for each project included in this study and is designed to demonstrate the reactive power requirements at the point of interconnection (POI) using the current study upgrade cases. For all projects that require reactive power, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the POI.

Model Preparation

For each project included in this study, as well as previous queued projects modeled at the same POI, the projects were turned off for the power factor analysis. The projects were replaced by an equivalent generator located at the POI producing the total MW of the project at that POI and 0.0 Mvar capability.

An Mvar generator without limits was modeled at the interconnection project POI to hold a voltage schedule at the POI consistent with the greater of the voltage schedule in the base case or unity (1.0 pu) voltage.

Disturbances

Each N-1 three phase contingency evaluated in the Stability Analysis found in **Table 3-1** was also included in the determination of the power factor requirements.

Results

The power factor ranges are summarized in **Table 4-1** and the resultant ranges are shown **Table D-1**. The analysis showed that reactive power is required for the study project, the final requirement in the Generation Interconnection Agreement (GIA) for each project will be the pro-forma 95% lagging to 95% leading at the POI.

For analyzing power factor results a positive Q (Mvar) output indicates that the equivalent generator is supplying reactive power to the system, implying a lagging power factor. A negative Q (Mvar) output indicates that the equivalent generator is absorbing reactive power from the system, implying a leading power factor.

Table 4-1: Summary of Power Factor Analysis at the POI

| Request | Capacity (MW) | Point of Interconnection (POI) | Fuel | Generator | Lagging (providing Mvars) | Leading (absorbing Mvars) |
|--------------|---------------|---|------|----------------------------|---------------------------|---------------------------|
| GEN-2013-027 | 148.35 | Tap Tolk - Yoakum 230kV, Needmore 138kV | Wind | 43 x Vestas V126 GS 3.45MW | 0.95 | 0.95 |


NOTE: As reactive power is required for the project, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.

5. Reduced Wind Generation Analysis

A low wind analysis was performed for GEN-2013-027. SPP performed this low wind analysis to determine the capacitive charging current injected at the POI.


The project generators and capacitors (if any) were turned off in the base case. **Figure 5-1** shows the resulting reactive power injection (approximately 4 Mvar) at the POI that is due to the capacitance of the project's transmission lines and collector cables. Also, the figure shows how the capacitance is distributed throughout the project. In this impact restudy GEN-2013-027 is responsible for a 4 Mvar reactor needed to offset the capacitive effects of the collector system (3.8Mvar) and of the transmission lead (0.2Mvar) that connects into the transmission system under no/reduced wind generating conditions. The 4Mvar reactor will be required and would normally be installed on the low side of the 230/34.5kV transformer. The Interconnection Customer may use wind turbine manufacturing options for providing reactive power under no/reduced generation conditions.

Figure 5-2 shows a shunt reactor added at the GEN-2013-027 project substation 34.5 kV bus to bring the Mvar flow into the POI down to approximately zero.

Figure 5-1: GEN-2013-027 with generators turned off**Notes:**

1. Amber box shows distribution of charging capacitance in the facility. The charging capacitance on the transmission line from the generation facility to the POI is negligible.
2. Red box shows the net effect of all the charging capacitances at the POI

Figure 5-2: GEN-2013-027 with generators turned off and shunt reactor added to the 34.5kV side of the customer substation



6. Short Circuit Analysis

The short circuit analysis was performed on the 2017 & 2025 Summer Peak power flow cases using the PSS/E ASCC program. Since the power flow model does not contain negative and zero sequence data, only three-phase symmetrical fault current levels were calculated at the point of interconnection up to and including five levels away.

Short Circuit Analysis was conducting using flat conditions with the following PSS/E ASCCC program settings:

- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

Results

The results of the short circuit analysis are shown in **Appendix F, Table F-1 GEN-2013-027 Short Circuit Analysis Results (2017SP)** and **Table F-2 GEN-2013-027 Short Circuit Analysis Results (2025SP)**.

7. Conclusion

The GEN-2013-027 Interconnection Customer has requested a modification to its Generator Interconnection Request to change wind turbine generators for its project. Previously, it consisted of sixty-one (61) Siemens 108m 2.3MW and four (4) Siemens 108m with Powerboost 2.415MW wind turbines for a total of 149.96 MW. The requested change is for forty-three (43) Vestas V126 GulfStream (GS) 3.45MW wind for a total of 148.35 MW. The Point of Interconnection (POI) is the new Southwestern Public Service Company (SPS) Needmore 230 kV Substation.

The study models used were the 2016 winter, 2017 summer, and 2025 summer models that included Interconnection. Requests through the facility study queue at DISIS-2015-002. Additionally, DISIS-2015-001 models were also created from the DISIS-2015-002 models in order to provide a baseline verification for the turbine change. The baseline verification was used to identify Network Upgrade(s) triggered by the addition of the lower queued DISIS-2015-002 generation.

The restudy showed that the stability analysis has determined with all previously assigned Network Upgrades in service, generators in the monitored areas remained stable and within the pre-contingency, voltage recovery, and post fault voltage recovery criterion of 0.7pu to 1.2pu for the entire modeled disturbances. Additionally, the project wind farm was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

Power factor analysis for the study generation project was performed on the 2016 winter peak, 2017 summer peak, and 2025 summer peak cases with identified system upgrades up to the DISIS-2015-001 queue position. As reactive power is required for GEN-2013-027, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.

An analysis was conducted to determine the capacitive effects on the transmission system caused by the generator lead and collector system during periods of reduced generation. To offset these effects, the generating facility is required to provide reactive compensation of approximately 4 MVAR of inductive reactance during periods of reduced generation. Such compensation can be provided either by discrete reactive devices or by the generator itself if it possesses that capability.

Short Circuit analysis was conducted using the current study upgrade 2017 summer peak and 2025 summer peak cases.

It should be noted that this study analyzed the requested modification to change generator technology, manufacturer, and layout. Power flow analysis was not performed. This study analyzed many of the most probable contingencies, but it is not an all-inclusive list and cannot account for every operational situation. It is likely that the customer may be required to reduce its generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of delivery or transmission service. If the customer wishes to sell power from the facility, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the Customer.

Appendix A – 2016 Winter Peak Stability Plots

(Available on request)

Appendix B – 2017 Summer Peak Stability Plots

(Available on request)

Appendix C – 2025 Summer Peak Stability Plots

(Available on request)

Appendix D – Power Factor Analysis Results

Table D-1: GEN-2013-027 Power Factor Analysis Results

| Leading power factor is absorbing vars; Lagging power factor is providing vars | | | | | | | | | | | |
|--|-------------------------------------|-----------------|--------------|--|-----------------|--------------|--|-----------------|--------------|--|--|
| GEN-2013-027 POI: Leonard 138 kV (561000) Power at POI (MW): 148.35 | | | | 2016 Winter Peak POI Voltage = 1.014 pu | | | 2017 Summer Peak POI Voltage = 1.015 pu | | | 2025 Summer Peak POI Voltage = 1.013 pu | |
| Contingency Name | | Mvars at POI | Power Factor | | Mvars at POI | Power Factor | | Mvars at POI | Power Factor | | |
| 0 | FLT_00_NoFault | -19.1175 | 0.991799 | LEAD | 4.254371 | 0.999589 | LAG | 2.273539 | 0.999883 | LAG | |
| 1 | FLT_01_CROSSROADS7_EDDYCNTY7_345kV | 16.50787 | 0.993866 | LAG | 37.23049 | 0.969922 | LAG | 29.92099 | 0.98026 | LAG | |
| 2 | FLT_02_CROSSROADS7_TOLK7_345kV | -20.3464 | 0.990725 | LEAD | 2.559471 | 0.999851 | LAG | 1.880084 | 0.99992 | LAG | |
| 3 | FLT_03_TOLKTAP6_TOLK7_230_345kV | -20.3527 | 0.99072 | LEAD | 2.554942 | 0.999852 | LAG | 1.877785 | 0.99992 | LAG | |
| 4 | FLT_04_G13027TAP_TOLKWEST6_230kV | 4.311256 | 0.999578 | LAG | 16.09273 | 0.994168 | LAG | 2.116214 | 0.999898 | LAG | |
| 5 | FLT_05_G13027TAP_YOAKUM6_230kV | -62.3837 | 0.921812 | LEAD | -44.7708 | 0.957353 | LEAD | -38.3462 | 0.968179 | LEAD | |
| 6 | FLT_06_YOAKUM6_AMOCOSS6_230kV | -13.4913 | 0.99589 | LEAD | 6.1329 | 0.999147 | LAG | 0.221952 | 0.999999 | LAG | |
| 7 | FLT_07_YOAKUM6_OXYBRUTP6_230kV | -19.1331 | 0.991785 | LEAD | 4.459285 | 0.999549 | LAG | 1.676351 | 0.999936 | LAG | |
| 8 | FLT_08_YOAKUM6_MUSTANG6_230kV | -18.6211 | 0.992214 | LEAD | 5.009104 | 0.99943 | LAG | 2.117167 | 0.999898 | LAG | |
| 9 | FLT_09_YOAKUM6_G1579&G1580T_230kV | -11.7104 | 0.996899 | LEAD | 24.54577 | 0.986587 | LAG | 11.68639 | 0.996912 | LAG | |
| 10 | FLT_10_YOAKUM6_YOAKUM3_230_115kV | -20.4295 | 0.990651 | LEAD | 3.41293 | 0.999735 | LAG | 1.85363 | 0.999922 | LAG | |
| 11 | FLT_11_TOLKWEST6_ROSEVELTN6_230kV | -18.7528 | 0.992105 | LEAD | 4.994177 | 0.999434 | LAG | 3.220461 | 0.999764 | LAG | |
| 12 | FLT_12_TOLKWEST6_PLANTX6_230kV | -17.3514 | 0.993229 | LEAD | 5.986191 | 0.999187 | LAG | 4.236259 | 0.999593 | LAG | |
| 13 | FLT_13_TOLK7_TOLKTAP6_345_230kV | -20.3527 | 0.99072 | LEAD | 2.554942 | 0.999852 | LAG | 1.877785 | 0.99992 | LAG | |
| 14 | FLT_14_TOLKWEST6_LAMBCNTY6_230kV | -16.012 | 0.994226 | LEAD | 10.8327 | 0.997345 | LAG | 6.91151 | 0.998916 | LAG | |
| 15 | FLT_15_TUCOINT7_BORDER7_345kV | -20.7488 | 0.99036 | LEAD | 3.221926 | 0.999764 | LAG | 1.425043 | 0.999954 | LAG | |
| 16 | FLT_16_BORDER7_WWRDEHV7_345kV | -21.1302 | 0.990008 | LEAD | 2.882341 | 0.999811 | LAG | 0.722355 | 0.999988 | LAG | |
| 17 | FLT_17_TUCOINT7_OKU7_345kV | -21.9178 | 0.989261 | LEAD | 2.458675 | 0.999863 | LAG | 1.044649 | 0.999975 | LAG | |
| 18 | FLT_29_HOBBSINT6_G1579&G1580T_230kV | -13.1535 | 0.996092 | LEAD | 23.04538 | 0.988148 | LAG | 10.02157 | 0.997726 | LAG | |

Appendix E – Reduced Wind Generation Analysis Results

(One-line diagram moved to main body of report)

Appendix F – Short Circuit Analysis Results

Table F-1: GEN-2013-027 Short Circuit Analysis Results (2017SP)

PSS®E ASCC SHORT CIRCUIT CURRENTS THU, AUG 17 2017 8:43
 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO
 MDWG 17S WITH MMWG 15S, MRO 16W TOPO/16S PROF, SERC 16S

OPTIONS USED:

- FLAT CONDITIONS
 - BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
 - GENERATOR P=0, Q=0
 - TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
 - LINE CHARGING=0.0 IN +/-0 SEQUENCE
 - LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
 - LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCE
 - DC LINES AND FACTS DEVICES BLOCKED
 - TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

| X----- BUS -----X | | THREE PHASE FAULT | |
|-------------------|--------------------------|-------------------|--------|
| | | /I+/ | AN(I+) |
| 562480 | [G13-027-TAP 230.00] AMP | 8842.8 | -83.13 |
| 525531 | [TOLK_WEST 6230.00] AMP | 25294.5 | -86.15 |
| 526935 | [YOAKUM 6230.00] AMP | 11670.9 | -83.68 |
| 583840 | [GEN-2013-027230.00] AMP | 8401.7 | -83.23 |
| 524909 | [ROSEVELT_N 6230.00] AMP | 8577.2 | -82.08 |
| 525481 | [PLANT_X 6230.00] AMP | 21882.5 | -85.22 |
| 525543 | [TOLK_TAP 6230.00] AMP | 25294.5 | -86.15 |
| 525637 | [LAMB_CNTY 6230.00] AMP | 5315.1 | -81.86 |
| 526460 | [AMOCO_SS 6230.00] AMP | 9102.1 | -82.55 |
| 526934 | [YOAKUM 3115.00] AMP | 14679.4 | -82.04 |
| 527010 | [OXYBRU_TP 6230.00] AMP | 9858.0 | -83.56 |
| 527149 | [MUSTANG 6230.00] AMP | 10292.0 | -84.21 |
| 560059 | [G1579&G1580T230.00] AMP | 8250.8 | -83.57 |
| 524623 | [DEAFSMITH 6230.00] AMP | 7681.3 | -80.79 |
| 524770 | [PLSNT_HILL 6230.00] AMP | 5969.0 | -81.80 |
| 524908 | [ROOSEVELT 3115.00] AMP | 10053.3 | -81.83 |
| 524915 | [SW_4K33 6230.00] AMP | 8577.2 | -82.08 |
| 525461 | [NEWHART 6230.00] AMP | 10656.8 | -81.87 |
| 525480 | [PLANT_X 3115.00] AMP | 20791.2 | -84.02 |
| 525524 | [TOLK_EAST 6230.00] AMP | 25294.5 | -86.15 |
| 525549 | [TOLK 7345.00] AMP | 6849.6 | -87.53 |
| 525636 | [LAMB_CNTY 3115.00] AMP | 8474.2 | -80.19 |
| 526435 | [SUNDOWN 6230.00] AMP | 10449.2 | -82.64 |
| 526784 | [AMOCOWASSON6230.00] AMP | 9635.2 | -83.83 |
| 526792 | [PRENTICE 3115.00] AMP | 5769.2 | -75.67 |
| 526928 | [PLAINS_INT 3115.00] AMP | 9218.3 | -78.07 |
| 527041 | [ARCO_TP 3115.00] AMP | 11998.5 | -78.94 |
| 527146 | [MUSTANG 3115.00] AMP | 19877.1 | -83.79 |
| 527151 | [GS-MUSTANG 6230.00] AMP | 10292.0 | -84.21 |
| 527194 | [LG-PLSHILL 3115.00] AMP | 7200.0 | -76.35 |
| 527276 | [SEMINOLE 6230.00] AMP | 6103.1 | -82.34 |
| 527894 | [HOBBS_INT 6230.00] AMP | 14489.3 | -86.70 |
| 523959 | [POTTER_CO 6230.00] AMP | 20123.4 | -84.70 |
| 524267 | [BUSHLAND 6230.00] AMP | 9606.8 | -82.93 |
| 524622 | [DEAFSMITH 3115.00] AMP | 11922.6 | -79.72 |
| 524768 | [PLSNT_HILL 3115.00] AMP | 9576.8 | -80.71 |
| 524822 | [CURRY 3115.00] AMP | 10230.1 | -79.53 |
| 524875 | [OASIS 6230.00] AMP | 7157.1 | -81.92 |
| 524911 | [ROSEVELT_S 6230.00] AMP | 8577.2 | -82.08 |

| | | | | | |
|--------|--------------|----------|-----|---------|--------|
| 524924 | [PORTALES | 3115.00] | AMP | 7114.7 | -78.83 |
| 525019 | [EMU&VLY_TP | 3115.00] | AMP | 5083.7 | -76.00 |
| 525056 | [BC-EARTH | 3115.00] | AMP | 8736.1 | -76.58 |
| 525213 | [SWISHER | 6230.00] | AMP | 9977.4 | -82.27 |
| 525446 | [SPGLAKE_TP3 | 115.00] | AMP | 10505.2 | -77.67 |
| 525454 | [HALE_CNTY | 3115.00] | AMP | 10060.2 | -73.67 |
| 525460 | [NEWHART | 3115.00] | AMP | 14949.2 | -81.55 |
| 525635 | [LAMB_CNTY | 269.000] | AMP | 5909.9 | -85.13 |
| 525830 | [TUCO_INT | 6230.00] | AMP | 19165.6 | -84.58 |
| 526020 | [HOCKLEY | 3115.00] | AMP | 5464.0 | -76.21 |
| 526434 | [SUNDOWN | 3115.00] | AMP | 11198.3 | -80.92 |
| 526525 | [WOLFFORTH | 6230.00] | AMP | 12729.9 | -83.31 |
| 526736 | [TERRY_CNTY | 3115.00] | AMP | 10509.2 | -77.12 |
| 526944 | [LG-PLAINS | 3115.00] | AMP | 7550.9 | -77.18 |
| 527018 | [BENNETT | 3115.00] | AMP | 12082.1 | -78.97 |
| 527047 | [OXY_WILRD1 | 3115.00] | AMP | 9800.2 | -77.87 |
| 527062 | [SHELL_CO2 | 3115.00] | AMP | 14455.7 | -80.20 |
| 527130 | [DENVER_N | 3115.00] | AMP | 18662.7 | -82.33 |
| 527136 | [DENVER_S | 3115.00] | AMP | 18662.7 | -82.33 |
| 527202 | [SEAGRAVES | 3115.00] | AMP | 8140.9 | -76.70 |
| 527275 | [SEMINOLE | 3115.00] | AMP | 10367.3 | -80.38 |
| 527656 | [CROSSROADS | 7345.00] | AMP | 5222.7 | -86.02 |
| 527865 | [CUNNINHAM | 6230.00] | AMP | 14213.2 | -86.69 |
| 527891 | [HOBBS_INT | 3115.00] | AMP | 28205.8 | -85.96 |
| 528604 | [ANDREWS | 6230.00] | AMP | 5704.4 | -83.99 |
| 528626 | [LE-PLNSINT | 269.000] | AMP | 4300.1 | -82.89 |
| 523309 | [MOORE_CNTY | 6230.00] | AMP | 6685.6 | -82.73 |
| 523869 | [CHAN/TASCOS | 6230.00] | AMP | 3839.6 | -82.07 |
| 523961 | [POTTER_CO | 7345.00] | AMP | 7410.1 | -86.52 |
| 523979 | [HARRNG_EST | 6230.00] | AMP | 25818.6 | -86.32 |
| 524010 | [ROLLHILLS | 6230.00] | AMP | 19166.6 | -84.79 |
| 524266 | [BUSHLAND | 3115.00] | AMP | 9314.7 | -83.80 |
| 524290 | [WILDOR2_JUS | 6230.00] | AMP | 6590.0 | -83.45 |
| 524502 | [NORTON | 3115.00] | AMP | 2715.0 | -80.50 |
| 524567 | [NE-HEREFORD | 3115.00] | AMP | 9537.9 | -78.34 |
| 524597 | [PANDAHFD | 3115.00] | AMP | 8335.8 | -74.65 |
| 524606 | [HEREFORD | 3115.00] | AMP | 10687.3 | -78.73 |
| 524669 | [DS-#20 | 3115.00] | AMP | 4764.9 | -68.32 |
| 524734 | [DS-#21 | 3115.00] | AMP | 10765.2 | -78.36 |
| 524746 | [CASTRO_CNTY | 3115.00] | AMP | 11600.5 | -78.94 |
| 524764 | [NORRIS_TP | 3115.00] | AMP | 10204.7 | -79.52 |
| 524773 | [E_CLOVIS | 3115.00] | AMP | 8244.0 | -78.55 |
| 524776 | [N_CLOVIS_TP | 3115.00] | AMP | 7015.1 | -78.62 |
| 524821 | [CURRY | 269.000] | AMP | 4312.4 | -85.63 |
| 524831 | [FE-HOLLAND | 3115.00] | AMP | 8485.1 | -79.25 |
| 524838 | [FE-CLOVIS2 | 3115.00] | AMP | 9716.0 | -79.30 |
| 524874 | [OASIS | 3115.00] | AMP | 9361.3 | -81.67 |
| 524885 | [SN_JUAN_TAP | 6230.00] | AMP | 4609.0 | -83.05 |
| 524923 | [PORTALES | 269.000] | AMP | 7050.4 | -82.41 |
| 524935 | [KILGORE | 3115.00] | AMP | 5570.3 | -77.66 |
| 525018 | [EMULESH&VLY | 3115.00] | AMP | 4718.2 | -75.80 |
| 525028 | [BAILEYCO | 3115.00] | AMP | 4864.3 | -75.99 |
| 525050 | [BC-KELLEY | 3115.00] | AMP | 8328.8 | -76.40 |
| 525124 | [HART_INDUST | 3115.00] | AMP | 7540.1 | -76.43 |
| 525192 | [KRESS_INT | 3115.00] | AMP | 11023.2 | -79.49 |
| 525212 | [SWISHER | 3115.00] | AMP | 10173.6 | -81.31 |
| 525326 | [COX | 3115.00] | AMP | 5850.2 | -71.99 |
| 525393 | [SPRINGLAKE | 3115.00] | AMP | 9343.6 | -77.52 |
| 525414 | [LAMTON | 3115.00] | AMP | 7754.9 | -75.23 |
| 525440 | [LC-S_OLTON | 3115.00] | AMP | 7393.0 | -75.43 |
| 525453 | [HALE_CNTY | 269.000] | AMP | 6888.5 | -82.63 |
| 525613 | [W_LITTLFLD | 269.000] | AMP | 2970.9 | -73.96 |
| 525620 | [LTFLD_S&CTY | 269.000] | AMP | 4177.3 | -71.85 |
| 525650 | [LC-LITTLFLD | 269.000] | AMP | 4939.3 | -83.14 |

| | | | | |
|--------|----------------------|-----|---------|--------|
| 525687 | [LC-LUMSCHAP269.000] | AMP | 4618.8 | -79.94 |
| 525828 | [TUCO_INT 3115.00] | AMP | 18995.0 | -82.75 |
| 525832 | [TUCO_INT 7345.00] | AMP | 10079.1 | -85.98 |
| 525840 | [ANTELOPE_1 6230.00] | AMP | 19024.7 | -84.59 |
| 526019 | [HOCKLEY 269.000] | AMP | 5131.3 | -81.73 |
| 526036 | [LC-OPDYKE 3115.00] | AMP | 5764.7 | -76.42 |
| 526161 | [CARLISLE 6230.00] | AMP | 10295.2 | -83.06 |
| 526269 | [LUBBCK_STH 6230.00] | AMP | 16981.0 | -85.25 |
| 526337 | [JONES 6230.00] | AMP | 19159.6 | -86.25 |
| 526352 | [LEHMAN 3115.00] | AMP | 5961.0 | -77.51 |
| 526424 | [PACIFIC 3115.00] | AMP | 9502.5 | -79.54 |
| 526445 | [AMOCO_TP 3115.00] | AMP | 10560.7 | -80.10 |
| 526491 | [LG-CLAUENE 3115.00] | AMP | 8904.8 | -77.06 |
| 526524 | [WOLFFORTH 3115.00] | AMP | 11331.4 | -81.75 |
| 526735 | [TERRY_CNTY 269.000] | AMP | 6991.5 | -84.14 |
| 527036 | [SHELL_C2 3115.00] | AMP | 12005.5 | -80.17 |
| 527046 | [OXY_WILRD2 3115.00] | AMP | 9778.2 | -77.86 |
| 527051 | [ODC_TP 3115.00] | AMP | 12096.4 | -78.97 |
| 527080 | [EL_PASO 3115.00] | AMP | 14277.3 | -80.02 |
| 527105 | [SAN_ANDS_TP3115.00] | AMP | 15021.1 | -80.13 |
| 527125 | [DENVER_CTY 269.000] | AMP | 8386.1 | -87.00 |
| 527201 | [SEAGRAVES 269.000] | AMP | 5303.3 | -83.35 |
| 527238 | [ROZ 3115.00] | AMP | 8560.2 | -79.16 |
| 527242 | [AMERADA 3115.00] | AMP | 8649.8 | -79.22 |
| 527262 | [SULPHUR 3115.00] | AMP | 5546.5 | -75.37 |
| 527286 | [XTO_RUSSEL 3115.00] | AMP | 9605.2 | -75.02 |
| 527322 | [GAINES 3115.00] | AMP | 8071.6 | -77.36 |
| 527340 | [DOSS 3115.00] | AMP | 6757.6 | -77.45 |
| 527800 | [EDDY_SOUTH 6230.00] | AMP | 7095.7 | -83.44 |
| 527802 | [EDDY_CNTY 7345.00] | AMP | 4026.3 | -84.90 |
| 527864 | [CUNNINHAM 3115.00] | AMP | 24957.4 | -84.27 |
| 527963 | [POTASH_JCT 6230.00] | AMP | 6115.3 | -82.69 |
| 528333 | [LE-WEST_SUB3115.00] | AMP | 8426.7 | -81.60 |
| 528355 | [MADDOX 3115.00] | AMP | 24199.8 | -85.05 |
| 528433 | [NEW_NHOBBS 3115.00] | AMP | 7775.8 | -73.82 |
| 528435 | [MILLEN 3115.00] | AMP | 11035.1 | -74.47 |
| 528602 | [ANDREWS 3115.00] | AMP | 7719.9 | -82.01 |
| 528740 | [LE-PLANS_TP269.000] | AMP | 3573.3 | -80.02 |
| 560050 | [G15-031-TAP 230.00] | AMP | 8528.0 | -82.19 |
| 560058 | [G15-077-TAP 115.00] | AMP | 8041.0 | -76.46 |
| 577103 | [GEN-2008-022345.00] | AMP | 4960.1 | -85.92 |
| 583340 | [GEN-2012-020230.00] | AMP | 8643.8 | -84.17 |
| 584260 | [GEN-2014-047345.00] | AMP | 4249.5 | -83.87 |
| 599955 | [PNM-DC6 230.00] | AMP | 8577.2 | -82.08 |

Table F-2: GEN-2013-027 Short Circuit Analysis Results (2025SP)

PSS®E ASSC SHORT CIRCUIT CURRENTS

THU, AUG 17 2017 8:43

2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO

MDWG 2025S WITH MMWG 2024S, MRO & SERC 2025 SUMMER

OPTIONS USED:

- FLAT CONDITIONS
 - BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
 - GENERATOR P=0, Q=0
 - TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
 - LINE CHARGING=0.0 IN +/- /0 SEQUENCE
 - LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
 - LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/- /0 SEQUENCE
 - DC LINES AND FACTS DEVICES BLOCKED
 - TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

| THREE PHASE FAULT | | | | |
|-------------------|----------------------|-----|---------|--------|
| X-----X | BUS | | /I+/ | AN(I+) |
| 562480 | [G13-027-TAP 230.00] | AMP | 9007.4 | -83.10 |
| 525531 | [TOLK_WEST 6230.00] | AMP | 26092.0 | -86.11 |
| 526935 | [YOAKUM 6230.00] | AMP | 15294.9 | -84.79 |
| 583840 | [GEN-2013-027230.00] | AMP | 8549.5 | -83.20 |
| 524909 | [ROSEVELT_N 6230.00] | AMP | 8709.0 | -82.04 |
| 525481 | [PLANT_X 6230.00] | AMP | 23136.3 | -85.29 |
| 525543 | [TOLK_TAP 6230.00] | AMP | 26092.0 | -86.11 |
| 525637 | [LAMB_CNTY 6230.00] | AMP | 5529.7 | -82.22 |
| 526460 | [AMOCO_SS 6230.00] | AMP | 9522.2 | -82.61 |
| 526934 | [YOAKUM 3115.00] | AMP | 15965.7 | -82.65 |
| 526936 | [YOAKUM_345 345.00] | AMP | 8477.5 | -86.28 |
| 527010 | [OXYBRU_TP 6230.00] | AMP | 11988.4 | -84.20 |
| 527149 | [MUSTANG 6230.00] | AMP | 12048.0 | -84.63 |
| 560059 | [G1579&G1580T230.00] | AMP | 8951.1 | -83.41 |
| 524623 | [DEAFSMITH 6230.00] | AMP | 7765.4 | -81.18 |
| 524770 | [PLSNT_HILL 6230.00] | AMP | 6055.0 | -81.77 |
| 524908 | [ROOSEVELT 3115.00] | AMP | 10209.1 | -81.75 |
| 524915 | [SW_4K33 6230.00] | AMP | 8709.0 | -82.04 |
| 525461 | [NEWHART 6230.00] | AMP | 10763.7 | -81.83 |
| 525480 | [PLANT_X 3115.00] | AMP | 26550.5 | -85.01 |
| 525524 | [TOLK_EAST 6230.00] | AMP | 26092.0 | -86.11 |
| 525549 | [TOLK 7345.00] | AMP | 6932.9 | -87.53 |
| 525636 | [LAMB_CNTY 3115.00] | AMP | 9649.1 | -80.29 |
| 525832 | [TUCO_INT 7345.00] | AMP | 12275.3 | -86.20 |
| 526435 | [SUNDOWN 6230.00] | AMP | 10885.6 | -82.68 |
| 526784 | [AMOCOWASSON6230.00] | AMP | 11329.6 | -84.27 |
| 526792 | [PRENTICE 3115.00] | AMP | 5881.1 | -75.63 |
| 526928 | [PLAINS_INT 3115.00] | AMP | 9634.1 | -78.15 |
| 527041 | [ARCO_TP 3115.00] | AMP | 12556.5 | -78.95 |
| 527146 | [MUSTANG 3115.00] | AMP | 21048.0 | -83.90 |
| 527151 | [GS-MUSTANG 6230.00] | AMP | 12048.0 | -84.63 |
| 527194 | [LG-PLSHILL 3115.00] | AMP | 7392.4 | -76.30 |
| 527276 | [SEMINOLE 6230.00] | AMP | 6557.5 | -82.40 |
| 527894 | [HOBBS_INT 6230.00] | AMP | 18652.1 | -86.99 |
| 527896 | [HOBBS_INT 7345.00] | AMP | 8201.1 | -86.76 |
| 511456 | [O.K.U.-7 345.00] | AMP | 5100.7 | -84.33 |
| 515458 | [BORDER 7345.00] | AMP | 5055.5 | -86.21 |
| 523959 | [POTTER_CO 6230.00] | AMP | 20179.7 | -84.69 |
| 524267 | [BUSHLAND 6230.00] | AMP | 9628.8 | -82.95 |
| 524622 | [DEAFSMITH 3115.00] | AMP | 12155.4 | -80.48 |
| 524768 | [PLSNT_HILL 3115.00] | AMP | 9808.4 | -80.59 |
| 524822 | [CURRY 3115.00] | AMP | 10485.2 | -79.47 |
| 524875 | [OASIS 6230.00] | AMP | 7260.0 | -81.88 |
| 524911 | [ROSEVELT_S 6230.00] | AMP | 8709.0 | -82.04 |
| 524924 | [PORTALES 3115.00] | AMP | 7189.6 | -78.74 |
| 525019 | [EMU&VLY_TP 3115.00] | AMP | 6422.1 | -77.12 |
| 525056 | [BC-EARTH 3115.00] | AMP | 9135.5 | -76.32 |
| 525213 | [SWISHER 6230.00] | AMP | 10137.4 | -82.24 |
| 525446 | [SPGLAKE_TP3 115.00] | AMP | 11477.2 | -77.38 |
| 525454 | [HALE_CNTY 3115.00] | AMP | 10242.0 | -73.51 |
| 525460 | [NEWHART 3115.00] | AMP | 15076.2 | -81.48 |
| 525608 | [NEW_AMHERST3115.00] | AMP | 5308.3 | -80.60 |
| 525614 | [W_LITLFLDTP3115.00] | AMP | 8225.5 | -77.65 |
| 525635 | [LAMB_CNTY 269.000] | AMP | 6225.5 | -85.43 |
| 525830 | [TUCO_INT 6230.00] | AMP | 22220.0 | -85.13 |
| 526020 | [HOCKLEY 3115.00] | AMP | 5611.0 | -76.05 |
| 526434 | [SUNDOWN 3115.00] | AMP | 11455.4 | -80.87 |
| 526525 | [WOLFFORTH 6230.00] | AMP | 13451.1 | -83.45 |
| 526736 | [TERRY_CNTY 3115.00] | AMP | 10747.0 | -77.04 |
| 526944 | [LG-PLAINS 3115.00] | AMP | 7801.4 | -77.19 |
| 527018 | [BENNETT 3115.00] | AMP | 12643.0 | -78.98 |

| | | | | | |
|--------|--------------|----------|-----|---------|--------|
| 527047 | [OXY_WILRD1 | 3115.00] | AMP | 10169.3 | -77.84 |
| 527062 | [SHELL_CO2 | 3115.00] | AMP | 15155.9 | -80.19 |
| 527130 | [DENVER_N | 3115.00] | AMP | 19687.4 | -82.34 |
| 527136 | [DENVER_S | 3115.00] | AMP | 19687.4 | -82.34 |
| 527202 | [SEAGRAVES | 3115.00] | AMP | 8362.8 | -76.63 |
| 527275 | [SEMINOLE | 3115.00] | AMP | 10827.6 | -80.42 |
| 527656 | [CROSSROADS | 7345.00] | AMP | 5294.8 | -86.02 |
| 527865 | [CUNNINHAM | 6230.00] | AMP | 17020.5 | -86.67 |
| 527891 | [HOBBS_INT | 3115.00] | AMP | 32425.5 | -85.85 |
| 527965 | [KIOWA | 7345.00] | AMP | 5518.0 | -84.90 |
| 528611 | [GAINESGENTP | 6230.00] | AMP | 9822.3 | -85.44 |
| 528626 | [LE-PLNSINT | 269.000] | AMP | 4349.8 | -82.82 |
| 511468 | [L.E.S.-7 | 345.00] | AMP | 12244.9 | -84.70 |
| 515375 | [WWRDEHV7 | 345.00] | AMP | 18268.8 | -86.03 |
| 523309 | [MOORE_CNTY | 6230.00] | AMP | 6692.2 | -82.73 |
| 523869 | [CHAN/TASCOS | 6230.00] | AMP | 3841.5 | -82.07 |
| 523961 | [POTTER_CO | 7345.00] | AMP | 7424.0 | -86.52 |
| 523979 | [HARRNG_EST | 6230.00] | AMP | 25904.0 | -86.36 |
| 524010 | [ROLLHILLS | 6230.00] | AMP | 19215.9 | -84.80 |
| 524266 | [BUSHLAND | 3115.00] | AMP | 9323.5 | -83.80 |
| 524290 | [WILDOR2_JUS | 6230.00] | AMP | 6599.8 | -83.46 |
| 524502 | [NORTON | 3115.00] | AMP | 3310.9 | -81.49 |
| 524567 | [NE_HEREFORD | 3115.00] | AMP | 9687.9 | -78.92 |
| 524597 | [PANDAHFD | 3115.00] | AMP | 9054.6 | -80.09 |
| 524606 | [HEREFORD | 3115.00] | AMP | 10872.8 | -79.38 |
| 524669 | [DS-#20 | 3115.00] | AMP | 4804.7 | -68.23 |
| 524734 | [DS-#21 | 3115.00] | AMP | 10876.9 | -78.29 |
| 524746 | [CASTRO_CNTY | 3115.00] | AMP | 11734.2 | -78.85 |
| 524764 | [NORRIS_TP | 3115.00] | AMP | 10458.2 | -79.45 |
| 524773 | [E_CLOVIS | 3115.00] | AMP | 8408.9 | -78.44 |
| 524776 | [N_CLOVIS_TP | 3115.00] | AMP | 7124.9 | -78.50 |
| 524821 | [CURRY | 269.000] | AMP | 4339.1 | -85.66 |
| 524831 | [FE-HOLLAND | 3115.00] | AMP | 8661.0 | -79.14 |
| 524838 | [FE-CLOVIS2 | 3115.00] | AMP | 9945.4 | -79.23 |
| 524874 | [OASIS | 3115.00] | AMP | 9489.6 | -81.59 |
| 524885 | [SN_JUAN_TAP | 6230.00] | AMP | 4655.9 | -83.00 |
| 524923 | [PORTALES | 269.000] | AMP | 7094.6 | -82.38 |
| 524935 | [KILGORE | 3115.00] | AMP | 5905.7 | -77.79 |
| 524977 | [MARKET_ST | 3115.00] | AMP | 5477.7 | -77.42 |
| 525018 | [EMULESH&VLY | 3115.00] | AMP | 5850.2 | -76.77 |
| 525028 | [BAILEYCO | 3115.00] | AMP | 6363.0 | -77.42 |
| 525050 | [BC-KELLEY | 3115.00] | AMP | 8582.7 | -76.19 |
| 525124 | [HART_INDUST | 3115.00] | AMP | 7600.4 | -76.33 |
| 525192 | [KRESS_INT | 3115.00] | AMP | 11120.0 | -79.42 |
| 525212 | [SWISHER | 3115.00] | AMP | 10254.1 | -81.26 |
| 525326 | [COX | 3115.00] | AMP | 5891.5 | -71.89 |
| 525393 | [SPRINGLAKE | 3115.00] | AMP | 10104.7 | -77.25 |
| 525414 | [LAMTON | 3115.00] | AMP | 7936.2 | -75.05 |
| 525440 | [LC-S_OLTON | 3115.00] | AMP | 7644.3 | -75.21 |
| 525453 | [HALE_CNTY | 269.000] | AMP | 6939.8 | -82.63 |
| 525594 | [SUDANRURAL | 3115.00] | AMP | 4771.7 | -80.29 |
| 525607 | [NEW_AMHERST | 269.000] | AMP | 3221.7 | -85.76 |
| 525615 | [W_LITTLFLD | 3115.00] | AMP | 7690.4 | -76.65 |
| 525620 | [LTFLD_S&CTY | 269.000] | AMP | 4331.9 | -71.57 |
| 525650 | [LC-LITTLFLD | 269.000] | AMP | 5158.5 | -83.30 |
| 525687 | [LC-LUMSCHAP | 269.000] | AMP | 4810.4 | -79.95 |
| 525828 | [TUCO_INT | 3115.00] | AMP | 19868.4 | -83.04 |
| 525840 | [ANTELOPE_1 | 6230.00] | AMP | 22049.7 | -85.14 |
| 526019 | [HOCKLEY | 269.000] | AMP | 5208.7 | -81.72 |
| 526036 | [LC-OPDYKE | 3115.00] | AMP | 5895.8 | -76.27 |
| 526161 | [CARLISLE | 6230.00] | AMP | 13248.8 | -83.80 |
| 526269 | [LUBBCK_STH | 6230.00] | AMP | 18797.0 | -85.28 |
| 526337 | [JONES | 6230.00] | AMP | 20791.8 | -86.16 |
| 526352 | [LEHMAN | 3115.00] | AMP | 6038.6 | -77.45 |

| | | | | | |
|--------|---------------|----------|-----|---------|--------|
| 526424 | [PACIFIC | 3115.00] | AMP | 9684.7 | -79.47 |
| 526445 | [AMOCO_TP | 3115.00] | AMP | 10788.7 | -80.04 |
| 526491 | [LG-CLAUENE | 3115.00] | AMP | 9068.8 | -76.98 |
| 526524 | [WOLFFORTH | 3115.00] | AMP | 11595.6 | -81.87 |
| 526735 | [TERRY_CNTY | 269.000] | AMP | 7053.8 | -84.17 |
| 527036 | [SHELL_C2 | 3115.00] | AMP | 12399.1 | -80.06 |
| 527046 | [OXY_WILRD2 | 3115.00] | AMP | 10145.6 | -77.83 |
| 527051 | [ODC_TP | 3115.00] | AMP | 12657.9 | -78.99 |
| 527080 | [EL_PASO | 3115.00] | AMP | 14946.1 | -79.99 |
| 527105 | [SAN_ANDS_TP | 3115.00] | AMP | 15701.5 | -80.05 |
| 527125 | [DENVER_CTY | 269.000] | AMP | 8505.0 | -87.07 |
| 527201 | [SEAGRAVES | 269.000] | AMP | 5358.8 | -83.39 |
| 527238 | [ROZ | 3115.00] | AMP | 8871.6 | -79.15 |
| 527242 | [AMERADA | 3115.00] | AMP | 8967.9 | -79.21 |
| 527262 | [SULPHUR | 3115.00] | AMP | 5632.7 | -75.30 |
| 527286 | [XTO_RUSSEL | 3115.00] | AMP | 9850.9 | -74.72 |
| 527322 | [GAINES | 3115.00] | AMP | 8298.6 | -77.23 |
| 527340 | [DOSS | 3115.00] | AMP | 6934.3 | -77.37 |
| 527800 | [EDDY_SOUTH | 6230.00] | AMP | 7678.2 | -83.31 |
| 527802 | [EDDY_CNTY | 7345.00] | AMP | 4208.1 | -84.95 |
| 527864 | [CUNNINGHAM | 3115.00] | AMP | 29286.6 | -84.51 |
| 527962 | [POTASH_JCT | 3115.00] | AMP | 14128.8 | -83.23 |
| 527963 | [POTASH_JCT | 6230.00] | AMP | 6852.0 | -84.05 |
| 528027 | [RDRUNNER | 7345.00] | AMP | 3763.4 | -84.17 |
| 528185 | [N_LOVING | 7345.00] | AMP | 4392.3 | -84.47 |
| 528333 | [LE-WEST_SUB | 3115.00] | AMP | 8738.0 | -81.19 |
| 528355 | [MADDOX | 3115.00] | AMP | 27408.5 | -84.99 |
| 528433 | [NEW_NHOBBS | 3115.00] | AMP | 7972.9 | -73.45 |
| 528435 | [MILLEN | 3115.00] | AMP | 11569.2 | -73.87 |
| 528604 | [ANDREWS | 6230.00] | AMP | 6912.6 | -84.42 |
| 528610 | [GAINES_GEN | 6230.00] | AMP | 8510.8 | -85.63 |
| 528740 | [LE-PLANS_TP | 269.000] | AMP | 3610.0 | -79.84 |
| 560050 | [G15-031-TAP | 230.00] | AMP | 8630.0 | -82.17 |
| 560058 | [G15-077-TAP | 115.00] | AMP | 8175.9 | -76.38 |
| 577103 | [GEN-2008-022 | 345.00] | AMP | 5022.4 | -85.91 |
| 583090 | [G1149&G1504 | 345.00] | AMP | 4623.2 | -86.07 |
| 583340 | [GEN-2012-020 | 230.00] | AMP | 9103.3 | -84.27 |
| 584260 | [GEN-2014-047 | 345.00] | AMP | 4297.1 | -83.84 |
| 599955 | [PNM-DC6 | 230.00] | AMP | 8709.0 | -82.04 |