



SPP

*Southwest
Power Pool*

***System Impact Study
SPP-2014-005
For Transmission Service
Requested By:
CRGL***

From WFECC to ERCOTN

***For a Reserved Amount Of
25 MW***

For 5/1/2014 – 6/1/2014

And 185 MW

For 6/1/2014 – 9/1/2014

1. Executive Summary

CRGL has requested a system impact study for monthly firm transmission service from WFEC to ERCOTN. The period of the transaction is from 5/1/2014 00:00 to 9/1/2014 00:00. The request is for reservations 79461700 and 79464958.

The 25 MW and 185 MW transactions from WFEC have an impact on the following flowgates with no AFC: SPSNORTH_STH, ANACORSWSNOR and POTXFRHITXFR. To provide the AFC necessary for this transfer, the impact on these flowgates must be relieved.

After studying many scenarios using generation redispatch, there are several feasible scenarios that will relieve the flowgate(s) in question.

2. Introduction

CRGL has requested a system impact study for transmission service from WFEC to ERCOTN.

There are 3 constrained flowgates that require relief in order for this reservation to be accepted. The flowgates and the explanations are as follows:

- SPSNORTH_STH: SPS North to South interface.
- ANACORSWSNOR: Anadarko – Corn Tap 138 kV line for the loss of Southwestern Station – Norge 138 kV line
- POTXFRHITXFR: Potter County 345/230 kV transformer for the loss of the Hitchland 345/230 kV transformer

3. Study Methodology

A. Description

Southwest Power Pool used Transmission Adequacy & Reliability Assessment (TARA) to obtain possible unit pairings that would relieve the constraint. TARA calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

B. Model Updates

The 2014 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

C. Transfer Analysis

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using Transmission Adequacy & Reliability Assessment (TARA), specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by TARA is the amount of redispatch necessary to relieve the impact on the affected flowgate.

4. Study Results

After studying the impacts of the request, three flowgates require relief. The flowgates and associated amount of relief are as follows:

Table 1

Flowgate	Duration	Sensitivity (%)	Required Relief (MW)
5196 : SPSNORTH_STH	5/1/2014 - 6/1/2014	14.9%	4
5196 : SPSNORTH_STH	6/1/2014 - 9/1/2014	14.9%	28
5358 : ANACORSWSNOR	5/1/2014 - 6/1/2014	10.0%	3
5358 : ANACORSWSNOR	6/1/2014 - 9/1/2014	10.0%	19
5420 : POTXFRHITXFR	5/1/2014 - 6/1/2014	4.0%	1
5420 : POTXFRHITXFR	6/1/2014 - 9/1/2014	4.0%	7

Table 2 displays a list of generator pairs that are possible relief options for each flowgates in question and the amount of redispatch capacity needed.

Table 2

5196 : SPSNORTH_STH			5/1/2014 - 6/1/2014	6/1/2014 - 9/1/2014
Increment	Decrement	Sensitivity	DispatchMW	DispatchMW
PlantX SPS	Harrington SPS	81.6%	5	34
PlantX SPS	Nichols SPS	81.6%	5	34
Tolk SPS	Harrington SPS	80.4%	5	35
Tolk SPS	Nichols SPS	80.3%	5	35
Cunningham SPS	Harrington SPS	78.8%	5	36
PlantX SPS	Blackhawk SPS	78.8%	5	36
Cunningham SPS	Nichols SPS	78.8%	5	36
Hobbs SPS	Harrington SPS	78.7%	5	36
Hobbs SPS	Nichols SPS	78.7%	5	36
Maddox SPS	Harrington SPS	78.6%	5	36
Maddox SPS	Nichols SPS	78.6%	5	36
Tolk SPS	Blackhawk SPS	77.5%	5	36
Cunningham SPS	Blackhawk SPS	75.9%	5	37
Hobbs SPS	Blackhawk SPS	75.8%	5	37
Maddox SPS	Blackhawk SPS	75.8%	5	37

5358 : ANACORSWSNOR			5/1/2014 - 6/1/2014	6/1/2014 - 9/1/2014
Increment	Decrement	Sensitivity	DispatchMW	DispatchMW
Seminole OKGE	Anadarko/Genco/ORME WFEC	13.0%	23	146
Weleetka CSWS	Anadarko/Genco/ORME WFEC	12.9%	23	147
Hugo WFEC	Anadarko/Genco/ORME WFEC	12.7%	24	150
Mustang OKGE	Anadarko/Genco/ORME WFEC	12.7%	24	150
Horseshoe Lake OKGE	Anadarko/Genco/ORME WFEC	12.6%	24	151

5420 : POTXFRHITXFR			5/1/2014 - 6/1/2014	6/1/2014 - 9/1/2014
Increment	Decrement	Sensitivity	DispatchMW	DispatchMW
Harrington SPS	Holcomb SECI	35.7%	3	20
Harrington SPS	Garden City SECI	35.7%	3	20
Nichols SPS	Holcomb SECI	35.5%	3	20
Nichols SPS	Garden City SECI	35.5%	3	20
Blackhawk SPS	Holcomb SECI	29.9%	3	23
Blackhawk SPS	Garden City SECI	29.8%	3	23
PlantX SPS	Holcomb SECI	28.8%	3	24
PlantX SPS	Garden City SECI	28.8%	3	24

5. Conclusion

Generation redispatch options were studied in order to relieve the necessary constraints. The results of this study shows that the constraints on the flowgates in question could be relieved by executing one or more of the options described in the Study Results section of this document. Before the Transmission Provider accepts the reservations, agreement to the redispatch options must be presented to Southwest Power Pool. Noncompliance with this guideline will result in the refusal of the reservation.