



**Definitive Interconnection
System Impact Study for
Generation Interconnection
Requests
(DISIS-2015-002-1)**

August 2016

Generator Interconnection



Revision History

| Date | Author | Change Description |
|-----------|--------|---|
| 2/5/2016 | SPP | Draft issued to Transmission Owners for review |
| 2/12/2016 | SPP | Report Issued (DISIS-2015-002). Some stability analysis still pending. Group 2, 6, 7, 15 and 16 Interconnection Request Results not included in this issue. |
| 2/22/2016 | SPP | Draft issued to Transmission Owners for Group 2, 6, and 7 review |
| 2/29/2016 | SPP | Report Issued (DISIS-2015-002) to include Group 2, 6, and 7 Results. Some stability analysis still pending. 15 and 16 Interconnection Request Results not included in this issue. |
| 3/17/2016 | SPP | Draft issued to Transmission Owners for Group 15, and 16 review |
| 3/29/2016 | SPP | Report Issued (DISIS-2015-002) to include Group 15 and 16 Results. Group 16 stability analysis still pending. |
| 4/28/2016 | SPP | Report Issued to include Group 16 stability analysis |
| 8/01/2016 | SPP | ReStudy to account for withdrawn projects. |
| 8/05/2016 | SPP | DISIS-2015-002-1 reposted for AECI Affected System Cost Allocation correction and update to Introduction Section Stand-Alone Language |

Executive Summary

Pursuant to the Generator Interconnection Procedures (GIP) of the Southwest Power Pool (SPP) Open Access Transmission Tariff (OATT), SPP has conducted this Definitive Interconnection System Impact Study (DISIS). The Interconnection Customers' requests have been clustered together for the following System Impact Cluster Study window which closed September 30, 2015. The Interconnection Customers will be referred to in this study as the DISIS-2015-002 Interconnection Customers. This System Impact Study analyzes the interconnecting of multiple generation interconnection requests associated with new generation totaling approximately 7,340.9 MW of new generation which would be located within the transmission systems of American Electric Power – Western (AEPW), Basin Electric Power Cooperative (BPEC), Nebraska Public Power District (NPPD), Oklahoma Gas and Electric (OKGE), Southwestern Public Service (SPS), Southwestern Power Administration (SWPA), Sunflower Electric Power Corporation\Mid-Kansas Electric Company, LLC (SUNC\MKEC), Western Area Power Administration (WAPA), Westar Energy, Inc. (WERE), and Western Farmers Electric Cooperative (WFEC). The various generation interconnection requests have differing proposed in-service dates¹. The generation interconnection requests included in this System Impact Cluster Study are listed in Appendix A by their queue number, amount, requested interconnection service, area, requested interconnection point, proposed interconnection point, and the requested in-service date. This study represents the “Stand-Alone” analysis for remaining Interconnection Requests in the DISIS-2015-002 analysis.

Power flow analysis has indicated that for the power flow cases studied, 7,340.9 MW of nameplate generation may be interconnected with transmission system reinforcements within the SPP transmission system. For the analyses that has been completed, dynamic stability and power factor analysis has determined the need for reactive compensation in accordance with SPP stability and voltage recovery requirements including FERC Order #661-A for wind farm interconnection requests. Those reactive requirements are listed for each interconnection request within this report. Dynamic stability analysis has determined that the transmission system will remain stable with the assigned Network Upgrades and necessary reactive compensation requirements. A short circuit analysis has been performed with available short circuit values given in the stability study for each group in the appendices of this report. A short circuit analysis has been performed with available short circuit values given in the stability study for each group in the appendices of this report.

In no way does this study guarantee operation for all periods of time. This interconnection study identifies and assigns transmission reinforcements for Energy Resource Interconnection Service

¹ The generation interconnection requests in-service dates may need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customers that proceed to the Interconnection Facilities Study will be provided a new in-service date based on the Facility Study's time for completion of the Network Upgrades necessary or as otherwise provided for in the GIP.

(ERIS) interconnection injection constraints (defined as a 20% or greater distribution factor impact for outage based constraints and 3% or greater distribution factor impact for system intact constraints) and Network Resource Interconnection Service (NRIS) constraints (defined as 3% or greater distribution factor impact), if requested by the Customer. These constraints are listed in Appendix G-T (Thermal) and Appendix G-V (Voltage). This interconnection study does not assign transmission reinforcements for all potential transmission constraints. It should be noted that although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the Interconnection Customer(s) may be required to reduce their generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

The total estimated minimum cost for interconnecting the DISIS-2015-002 Interconnection Customers is estimated at \$677,958,271. The following costs are not included in this total –

- **Costs Not Included** – Costs on Affected Systems for particularly Associated Electric Cooperative Inc. (AECI), Mid-Continent Independent System Operator (MISO), and Minnkota Power Cooperative, Inc (MPC).

These costs determined at this time are shown in Appendix E and F. For Interconnection Requests that result in an interconnection to, or modification to, the transmission facilities of the Western-UGP (WAPA), a National Environmental Policy Act (NEPA) Environmental Review will be required. The Interconnection Customer will be required to execute and Environmental Review Agreement per Section 8.6.1 of the GIP.

Interconnection Service to DISIS-2015-002 Interconnection Customers is also contingent upon higher queued customers paying for certain required network upgrades. **The in-service date for the DISIS customers will be deferred until the construction of these network upgrades can be completed.** These costs also do not include the Interconnection Customer Interconnection Facilities as defined by the SPP Open Access Transmission Tariff (OATT) or the additional SPP transmission network constraints identified through this study and shown in Appendix H.

Constraints listed in Appendix H do not require transmission reinforcement for Interconnection Service, but could require Interconnection Customer to reduce generation in operational conditions. These transmission constraints occur when this study's generation is dispatched into the SPP footprint for Energy Resource Interconnection Service (ERIS) or when this study's generation is dispatched into the interconnecting Transmission Owner's (T.O.) area for Network Resource Interconnection Service (NRIS).

It should be noted that the additional network constraints identified in Appendix H may also be identified by a Transmission Service Request (TSR) and may need to be verified by associated studies. With a defined source and sink in a TSR, the list of network constraints will be refined and expanded to account for all Network Upgrade requirements. The required interconnection costs listed in Appendix E and F do not include costs associated with the deliverability of the energy to load or other customers. These costs are determined by separate studies should the Customer decide to submit a Transmission Service Request through SPP's Open Access Same Time

Information System (OASIS) as required by Attachment Z1 of the SPP OATT. Furthermore, this DISIS neither guarantees transmission service or deliverability of the requested resource.

When applicable, affected system thermal and voltage constraints are listed in Appendix H-T-AS and Appendix H-V-AS. Affected System constraints could require an affected system impact study review by the affected party or affected system parties. The affected system impact study could result in identifying additional affected transmission system reinforcement network upgrades required for interconnection.

NERC FAC-002-2 Compliance Statement

SPP, as Planning Coordinator has studied the reliability impact of interconnecting new or materially modified generation requesting interconnection to the Transmission System of SPP and any affected systems as requested by those entities. Affected systems include both the systems of SPP Transmission Owners and systems not included in the SPP Tariff footprint. The impact of the generation interconnection on affected systems will be further coordinated with the following systems as part of the coordinated planning procedures as described in Section 6 of this report and summarized below.

- Impacts on Associated Electric Cooperative Inc. (AECI) – For any observed violations of thermal overloads on AECI facilities, AECI has been notified by SPP to evaluate the violations for impacts on its transmission system.
- Impacts on Mid Continent Independent System Operation (MISO) – MISO has been contacted and provided a list of interconnection requests that proceed to move forward into the Interconnection Facilities Study Queue. MISO is evaluating the Interconnection Requests for impacts.
- Impacts on Minnkota Power Cooperative, Inc (MPC) – MPC has been contacted and provided a list of interconnection requests that proceed to move forward into the Interconnection Facilities Study Queue. MP is evaluating the Interconnection Requests for impacts.

This analysis adheres to NERC standards, regional, and Transmission Owner planning criteria, as related to generator interconnections. Facility interconnection requirements will be fully evaluated by the Transmission Owners during the Interconnection Facilities Study.

This analysis evaluates steady-state (Section 8), short-circuit (Section 9), and dynamic studies (Section 9) to evaluate system performance under both normal and contingency conditions. Study assumptions (Section 2) and system performance (Section 3) are documented in this report. Alternatives considered and coordinated recommendations are documented in Section 8 and Section 9.

Table of Contents

| | | |
|----------|---|-----------|
| 1 | Introduction | 1 |
| 2 | Model Development (Study Assumptions) | 2 |
| 2.2 | Development of Base Cases | 2 |
| 2.3 | Development of Analysis Cases..... | 5 |
| 3 | Identification of Network Constraints (System Performance) | 6 |
| 4 | Determination of Cost Allocated Network Upgrades | 9 |
| 5 | Required Interconnection Facilities | 10 |
| 6 | Affected Systems Coordination | 11 |
| 7 | Power Flow Analysis | 12 |
| 8 | Power Flow Results | 12 |
| 8.1 | Cluster Group 1 (Woodward Area) | 12 |
| 8.2 | Cluster Group 2 (Hitchland Area) | 14 |
| 8.3 | Cluster Group 3 (Spearville Area)..... | 15 |
| 8.4 | Cluster Group 4 (Northwest Kansas Area) | 15 |
| 8.5 | Cluster Group 6 (South Texas Panhandle/New Mexico Area) | 16 |
| 8.6 | Cluster Group 7 (Southwestern Oklahoma Area) | 18 |
| 8.7 | Cluster Group 8 (North Oklahoma/South Central Kansas Area)..... | 19 |
| 8.8 | Cluster Group 9 (Nebraska Area) | 21 |
| 8.9 | Cluster Group 10 (Southeast Oklahoma/Northeast Texas Area)..... | 22 |
| 8.10 | Cluster Group 12 (Northwest Arkansas Area) | 22 |
| 8.11 | Cluster Group 13 (Northeast Kansas/Northwest Missouri Area)..... | 22 |
| 8.12 | Cluster Group 14 (South Central Oklahoma Area) | 22 |
| 8.13 | Group 15 (Eastern South Dakota)..... | 22 |
| 8.14 | Group 16 (Western North Dakota) | 23 |
| 8.15 | Curtailment and System Reliability | 25 |
| 9 | Stability & Short Circuit Analysis | 26 |
| 9.1 | Cluster Group 1 (Woodward Area) | 26 |
| 9.2 | Cluster Group 2 (Hitchland Area) | 27 |
| 9.3 | Cluster Group 3 (Spearville Area)..... | 27 |
| 9.4 | Cluster Group 4 (Northwest Kansas)..... | 27 |
| 9.5 | Cluster Group 6 (South Texas Panhandle/New Mexico)..... | 28 |
| 9.6 | Cluster Group 7 (Southwest Oklahoma) | 29 |
| 9.7 | Cluster Group 8 (South Central Kansas/North Oklahoma) | 29 |
| 9.8 | Cluster Group 9 (Nebraska)..... | 29 |
| 9.9 | Cluster Group 10 (Southeast Oklahoma/Northeast Texas Area)..... | 30 |
| 9.10 | Cluster Group 12 (Northwest Arkansas Area) | 30 |
| 9.11 | Cluster Group 13 (Northeast Kansas/Northwest Missouri Area)..... | 30 |
| 9.12 | Cluster Group 14 (South Central Oklahoma)..... | 30 |
| 9.13 | Cluster Group 15 (Eastern South Dakota) | 31 |
| 9.14 | Cluster Group 16 (Western North Dakota)..... | 31 |

10 Conclusion..... 31

11 Appendices 33

11.1 A: Generation Interconnection Requests Considered for Impact StudyA-0

11.2 B: Prior Queued Interconnection Requests.....B-0

11.3 C: Study GroupingsC-0

11.4 D: Proposed Point of Interconnection One Line Diagrams..... D-0

11.5 E: Cost Allocation per Interconnection Request (Including Prior Queued Upgrades) E-0

11.6 F: Cost Allocation per Proposed Study Network Upgrade F-0

11.7 G-T: Thermal Power Flow Analysis (Constraints Requiring Transmission Reinforcement)..... G-T-0

11.8 G-V: Voltage Power Flow Analysis (Constraints Requiring Transmission Reinforcement)..... G-V-0

11.9 H-T: Thermal Power Flow Analysis (Other Constraints Not Requiring Transmission Reinforcement)..... H-T-0

11.10 H-T-AS: Affected System Thermal Power Flow Analysis (Constraints for Potential Upgrades)H-T-AS-0

11.11 H-V-AS: Affected System Voltage Power Flow Analysis(Constraints for Potential Upgrades)H-V-AS-0

11.12 I: Power Flow Analysis (Constraints from Multi-Contingencies) I-0

11.13 J: Group 1 Dynamic Stability Analysis ReportJ-0

11.14 K: Group 2 Dynamic Stability Analysis Report K-0

11.15 L: Group 6 Dynamic Stability Analysis Report L-0

11.16 M: Group 9 Dynamic Stability Analysis Report.....M-0

1 Introduction

Pursuant to the Southwest Power Pool (SPP) Open Access Transmission Tariff (OATT), SPP has conducted this Definitive Interconnection System Impact Study (DISIS) for certain generation interconnection requests in the SPP Generation Interconnection Queue. These interconnection requests have been clustered together for the following System Impact Study window which closed September 30, 2015. The customers will be referred to in this study as the DISIS-2015-002 Interconnection Customers. This DISIS analyzes the interconnecting of multiple generation interconnection requests associated with new generation totaling 7,340.9 MW of new generation which would be located within the transmission systems of American Electric Power – Western (AEPW), Basin Electric Power Cooperative (BPEC), Nebraska Public Power District (NPPD), Oklahoma Gas and Electric (OKGE), Southwestern Public Service (SPS), Southwestern Power Administration (SWPA), Sunflower Electric Power Corporation\Mid-Kansas Electric Company, LLC (SUNC\MKEC), Western Area Power Administration (WAPA), Westar Energy, Inc. (WERE), and Western Farmers Electric Cooperative (WFEC). The various generation interconnection requests have differing proposed in-service dates². The generation interconnection requests included in this System Impact Study are listed in Appendix A by their queue number, amount, requested interconnection service, area, requested interconnection point, proposed interconnection point, and the requested in-service date. This study represents the “Stand-Alone” analysis for remaining Interconnection Requests in the DISIS-2015-002 analysis.

The primary objective of this DISIS is to identify the system constraints, transient instabilities, and over-dutied equipment associated with connecting the generation to the area transmission system. The Impact Study and other subsequent Interconnection Studies are designed to identify required Transmission Owner Interconnection Facilities, Network Upgrades and other Direct Assignment Facilities needed to inject power into the grid at each specific point of interconnection.

² The generation interconnection requests in-service dates may need to be deferred based on the required lead time for the Network Upgrades necessary. The Interconnection Customers that proceed to the Facility Study will be provided a new in-service date based on the completion of the Facility Study or as otherwise provided for in the GIP.

2 Model Development (Study Assumptions)

2.1.1 Interconnection Requests Included in the Cluster

SPP included all interconnection requests that submitted a Definitive Interconnection System Impact Study Agreement no later than September 30, 2015 and were subsequently accepted by Southwest Power Pool under the terms of the Generator Interconnection Procedures (GIP) that were in effect at the time this study commenced on October 1, 2015. The interconnection requests that are included in this study are listed in Appendix A.

2.1.2 Affected System Interconnection Request

Also included in this Definitive Interconnection System Impact Study is one (1) Affected System Study. The Affected System Interconnection Requests have been given the designations with the “ASGI” prefix. These requests are listed in Appendix A. Affected System Interconnection Requests were only studied in “cluster” scenarios.

2.1.3 Previously Queued Interconnection Requests

The previous queued requests included in this study are listed in Appendix B. In addition to the Base Case Upgrades, the previous queued requests and associated upgrades were assumed to be in-service and added to the Base Case models. These projects were dispatched as Energy Resources Interconnection Service (ERIS) with equal distribution across the SPP footprint. Prior queued projects that requested Network Resource Interconnection Service (NRIS) were also dispatched in separate NRIS scenarios into the balancing authority of the interconnecting transmission owner.

2.2 Development of Base Cases

2.2.1 Power Flow

The 2015 series Integrated Transmission Planning models (used in the 2016 ITPNT) including the 2016 winter peak (16WP) season, the 2017 spring (17G) and 2017 summer peak (17SP) seasons, the 2020 light load (20L), summer (20SP) and winter peak (20WP) seasons, and the 2025 summer peak (25SP) season were the starting seasonal models for this study.

2.2.2 Dynamic Stability

The 2015 series SPP Model Development Working Group (MDWG) Models for 2016 winter peak (16WP) season, 2017 summer peak (17SP) season, and the 2025 summer peak (25SP) season cases were used as starting points for this study.

2.2.3 Short Circuit

The 2017 and 2025 summer peak stability cases are used for this analysis.

2.2.4 Base Case Upgrades

The following facilities are part of the SPP Transmission Expansion Plan, the Balanced Portfolio or recently approved Priority Projects. These facilities have an approved Notification to Construct (NTC) or are in construction stages and were assumed to be in-service at the time of dispatch and added to the base case models. The DISIS-2015-002 Interconnection Customers have not been assigned advancement costs for the below listed projects. The DISIS-2015-002 Interconnection

Customers Generation Facilities in service dates may need to be delayed until the completion of the following upgrades. In some cases, the in-service date is beyond the allowable time a customer can delay. In this case, the Interconnection Customer may move forward with Limited Operation or remain in the DISIS Queue for additional study cycles. If for some reason, construction on these projects is discontinued, additional restudies will be needed to determine the interconnection needs of the DISIS Interconnection Customers.

- 2012 Integrated Transmission Plan (2012 ITP10) Projects
 - Woodward-Tatonga-Mathewson-Cimarron 345kV transmission line circuit #2, scheduled for 2018 in-service³
 - Chisholm – Gracemont 345kV transmission line, and Chisholm 345/230kV transformer circuit #1, scheduled for 3/1/2018 in-service⁴
- 2015 Integrated Transmission Plan Near Term (2015 ITPNT) Projects
 - Potash Junction – Intrepid – IMC #1 – Livingston Ridge 115kV rebuild
 - National Enrichment Plant – Targa – Cardinal 115kV circuit #1 rebuild
- Gentleman – Thedford (Cherry County) – Holt County 345kV circuit #1 scheduled for 2018 in-service⁵
- Hoskins – Neligh East 345/115 kV Project⁶
 - Neligh East 345/115 kV substation and transformer
 - Neligh East Area 115 kV upgrades to support new station
 - Hoskins – Neligh East 345 kV circuit #1
- High Priority Incremental Loads (HPILs) Projects⁷:
 - TUCO Interchange – Yoakum – Hobbs Interchange 345/230 kV Project
 - TUCO Interchange – Yoakum – Hobbs Interchange 345 kV circuit #1 and associated terminal equipment upgrades
 - Hobbs 345/230/13 kV transformer circuit #1
 - Yoakum 345/230/13 kV transformer circuit #1
 - Chaves County – Price – CV Pines – Capitan 115 kV circuit #1
 - China Draw – Yeso Hills 115 kV circuit #1
 - Dollarhide – Toboso Flats 115 kV circuit #1
 - Hobbs Interchange – Kiowa 345 kV circuit #1
 - Kiowa – North Loving – China Draw 345/115 kV Projects
 - Kiowa – North Loving – China Draw circuit #1 and associated terminal equipment upgrades
 - China Draw 345/115/13 kV transformer circuit #1
 - North Loving 345/115/13 kV transformer circuit #1
 - Kiowa – Road Runner 345/230/115 kV Projects

³ SPP Notification to Construct (NTC) 200223

⁴ SPP Notification to Construct (NTC) 200240 and 200255

⁵ SPP Notification to Construct (NTC) 200220

⁶ SPP Regional Reliability 2012 ITP 10 Project Per SPP-NTC-200220

⁷ Per Network Upgrades assigned in High Priority Incremental Loads (HPILs) study, Including Direct Assigned Upgrades, Projects in SPP-NTC-200256 and SPP-NTC-200283.

- Kiowa 345/230 kV transformer circuit #1
- Road Runner 345/115/13 kV transformer circuit #1
- Livingston Ridge – Sage Brush – Lagarto – Cardinal 115 kV circuit #1
- North Loving – South Loving 115 kV circuit #1
- Ponderosa – Ponderosa Tap 115 kV circuit #1
- Nebraska City – Mullin Creek – Sibley 345kV circuit #1 build, scheduled for 12/31/2016 in-service⁸

2.2.5 Contingent Upgrades

The following facilities do not yet have approval. These facilities have been assigned to higher queued interconnection customers. These facilities have been included in the models for the DISIS-2015-002 study and are assumed to be in service. This list may not be all inclusive. The DISIS-2015-002 Interconnection Customers, at this time, do not have responsibility for these facilities but may later be assigned the cost of these facilities if higher queued customers terminate their Generation Interconnection Agreement or withdraw from the interconnection queue. The DISIS-2015-002 Interconnection Customer Generation Facilities in-service dates may need to be delayed until the completion of the following upgrades.

- Upgrades assigned to DISIS-2010-002 Interconnection Customers:
 - Twin Church – Dixon County 230 kV circuit #1 rerate (320 MVA).
 - Buckner – Spearville 345 kV circuit #1 terminal equipment.
- Upgrades assigned to DISIS-2011-001 Interconnection Customers:
 - Hoskins – Dixon County – Twin Church 230 kV circuit #1 conductor clearance increase.
 - (NRIS only) Woodward District EHV Phase Shifting Transformer.
- Upgrades assigned to DISIS-2012-002 Interconnection Customers:
 - Lake Creek – Lone Wolf 69 kV circuit #1 reset CT, placed in-service
- Upgrades assigned to DISIS-2013-002 Interconnection Customers:
 - Battle Creek – County Line – Neligh East 115kV circuit #1 rebuild.
- Upgrades assigned to DISIS-2014-002 Interconnection Customers:
 - Arnold – Ransom 115kV circuit #1, terminal equipment replacement.
 - Tolk – Plant X 230kV circuit #1 and circuit #2, re-conductor.
 - Tuco 345/230kV transformer replacement.
- Upgrades assigned to DISIS-2015-001 Interconnection Customers:
 - Beach – GEN-2010-048 Tap 115kV circuit #1 replace terminal equipment.
 - Cimarron River Tap – Kismet – Cudahy – Crooked Creek 115kV circuit #1 rebuild.
 - Greenburg – Shooting Star 115kV circuit #1 rebuild.
 - Kress Interchange – Swisher 115kV circuit #1 replace terminal equipment.
 - Oklaunion 345kV Reactive Power Support
 - Install two (2) 130Mvar Capacitor Bank(s).
 - (NRIS Only) Cox Interchange – Hale County 115kV circuit #1 rebuild.

⁸ SPP Notification to Construct (NTC) 20097 and 20098

- (NRIS Only) Potter County Interchange 345/230/13kV Transformer circuit #2, build.
- (NRIS Only) Renfrow – Renfrow 138kV circuit #1 rebuild.
- (NRIS Only) Sundown Interchange 230/115/13.8kV transformer circuit #1 replacement.
- (NRIS Only) Crawfish Draw Substation 345/230kV
 - Build new 345/230kV substation along TUCO – Border 345kV and TUCO – Swisher 230kV. Tie in and Terminate TUCO 345kV, Border 345kV, TUCO 230kV, and Swisher 230kV at Crawfish Draw (TUCO 2).
 - Build 345/230/13kV transformer
- (NRIS Only) Wolfforth – Terry County 115kV circuit #1 replace terminal equipment.
- (NRIS Only) Wolfforth Interchange 230/225/13.2kV circuit #1 replacement.

2.2.6 Potential Upgrades Not in the Base Case

Any potential upgrades that do not have a Notification to Construct (NTC) and are not explicitly listed within this report have not been included in the base case. These upgrades include any identified in the SPP Extra-High Voltage (EHV) overlay plan, or any other SPP planning study other than the upgrades listed above in the previous section.

2.2.7 Regional Groupings

The interconnection requests listed in Appendix A are grouped together into ten (10) active regional groups based on geographical and electrical impacts. These groupings are shown in Appendix C.

To determine interconnection impacts, ten (10) different generation dispatch scenarios of the spring, summer, and winter base case models are developed to accommodate the regional groupings.

2.3 Development of Analysis Cases

2.3.1 Power Flow

For Variable Energy Resources (VER) (solar/wind) in each power flow case, Energy Resource Interconnection Service (ERIS), is evaluated for the generating plants within a geographical area of the interconnection request(s) for the VERs dispatched at 100% nameplate of maximum generation. The VERs in the remote areas are dispatched at 20% nameplate of maximum generation. These projects are dispatched across the SPP footprint using load factor ratios.

Peaking units are not dispatched in the 2017 spring, 2020 light, or in the “High VER” summer and winter peaks. To study peaking units’ impacts, the 2016 winter peak and 2017 summer peak, 2020 summer and winter peaks, and 2025 summer peak models are developed with peaking units dispatched at 100% of the nameplate rating and VERs dispatched at 20% of the nameplate rating. Each interconnection request is also modeled separately at 100% nameplate for certain analyses.

All generators (VER and peaking) that requested Network Resource Interconnection Service (NRIS) are dispatched in an additional analysis into the interconnecting Transmission Owner’s (T.O.) area at 100% nameplate with Energy Resource Interconnection Service (ERIS) only requests at 80% nameplate. This method allows for identification of network constraints that are common between

regional groupings to have affecting requests share the mitigating upgrade costs throughout the cluster.

2.3.1.1 Additional Sensitivities Considered – The following sensitivities were run for situations prevalent to the local area for which they were considered

- North Dakota – Canadian border – The phase shifting transformer to Saskatchewan Power (also known as B-10T) and Miles City DC Tie were dispatched at the following levels
 - 2016 Winter Peak –
 - Miles City DC Tie– 200MW East to West transfer
 - B-10T – 65MW South to North transfer
 - 2017 Summer Peak –
 - Miles City DC Tie – 200MW East to West transfer
 - B-10T – 200MW North to South transfer
 - Other Seasons
 - Miles City DC Tie – 140MW East to West transfer (20WP)
 - Miles City DC Ties – 92MW East to West transfer (17G & 20L)
 - B-10T – 0MW

2.3.2 Dynamic Stability

For each group, all interconnection requests are dispatched at 100% nameplate output while the other groups are dispatched at 20% output for VERs and 100% output for thermal requests.

2.3.2.1 Additional Sensitivities Considered

- North Dakota – Canadian border – The phase shifting transformer to Saskatchewan Power (also known as B-10T) and Miles City DC Tie were dispatched at the following levels
 - 2016 Winter Peak –
 - Miles City DC Tie– 200MW East to West transfer
 - B-10T – 65MW South to North transfer
 - 2017 Summer Peak –
 - Miles City DC Tie – 200MW East to West transfer
 - B-10T – 200MW North to South transfer

2.3.3 Short Circuit

The dynamic stability models (2017 SP and 2025 SP) are used for this analysis.

3 Identification of Network Constraints (System Performance)

3.1.1 Thermal Overloads

Network constraints are found by using PSS/E AC Contingency Calculation (ACCC) analysis with PSS/E MUST First Contingency Incremental Transfer Capability (FCITC) analysis on the entire cluster grouping dispatched at the various levels previously mentioned.

For Energy Resource Interconnection Service (ERIS), thermal overloads are determined for system intact (n-0) (greater than 100% of Rate A - normal) and for contingency (n-1) (greater than 100% of Rate B – emergency) conditions.

The overloads are then screened to determine which of generator interconnection requests have at least

- 3% Distribution Factor (DF) for system intact conditions (n-0),
- 20% DF upon outage based conditions (n-1),
- or 3% DF on contingent elements that resulted in a non-converged solution.

Appropriate transmission support is then determined to mitigate the constraints.

Interconnection Requests that requested Network Resource Interconnection Service (NRIS) are also studied in a separate NRIS analysis to determine if any constraint measured greater than or equal to a 3% DF. If so, these constraints are also considered for transmission reinforcement under NRIS.

3.1.2 Voltage

For non-converged power flow solutions that are determined to be caused by lack of voltage support, appropriate transmission support will be determined to mitigate the constraint.

After all thermal overload and voltage support mitigations are determined; a full ACCC analysis is then performed to determine voltage constraints. The following voltage performance guidelines are used in accordance with the Transmission Owner local planning criteria.

SPP Areas (69kV+):

| Transmission Owner | Voltage Criteria (System Intact) | Voltage Criteria (Contingency) |
|---------------------------|---|---------------------------------------|
| AEPW | 0.95 – 1.05 pu | 0.92 – 1.05 pu |
| GRDA | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| SWPA | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| OKGE | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| OMPA | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| WFEC | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| SWPS | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| MIDW | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| SUNC | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| KCPL | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| INDN | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| SPRM | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| NPPD | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| WAPA | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| WERE L-V | 0.95 – 1.05 pu | 0.93 – 1.05 pu |

| | | |
|----------|----------------|----------------|
| WERE H-V | 0.95 – 1.05 pu | 0.95 – 1.05 pu |
| EMDE L-V | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| EMDE H-V | 0.95 – 1.05 pu | 0.92 – 1.05 pu |
| LES | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| OPPD | 0.95 – 1.05 pu | 0.90 – 1.05 pu |

SPP Buses with more stringent voltage criteria:

| Bus Name/Number | Voltage Criteria (System Intact) | Voltage Criteria (Contingency) |
|----------------------------|----------------------------------|--------------------------------|
| TUCO 230kV 525830 | 0.925 – 1.05 pu | 0.925 – 1.05 pu |
| Wolf Creek 230kV 532797 | 0.985 – 1.03 pu | 0.985 – 1.03 pu |
| FCS 646251 | 1.001 – 1.047 pu | 1.001 – 1.047 pu |

Affected System Areas (115kV+):

| Transmission Owner | Voltage Criteria (System Intact) | Voltage Criteria (Contingency) |
|--------------------|----------------------------------|--------------------------------|
| EES-EAI | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| LAGN | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| EES | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| AMMO | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| CLEC | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| Lafa | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| LEPA | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| XEL | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| MP | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| SMMPA | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| GRE | 0.95 – 1.05 pu | 0.90 – 1.10 pu |
| OTP | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| OTP-H (115kV+) | 0.97 – 1.05 pu | 0.92 – 1.10 pu |
| ALTW | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| MEC | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| MDU | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| SPC | 0.95 – 1.05 pu | 0.95 – 1.05 pu |
| DPC | 0.95 – 1.05 pu | 0.90 – 1.05 pu |
| ALTE | 0.95 – 1.05 pu | 0.90 – 1.05 pu |

The constraints identified through the voltage scan are then screened for the following for each interconnection request. 1) 3% DF on the contingent element and 2) 2% change in pu voltage. In certain conditions, engineering judgement was used to determine whether or not a generator had impacts to voltage constraints.

3.1.3 Dynamic Stability

Stability issues considered for transmission reinforcement under ERIS. Generators that fail to meet low voltage ride-through requirements (FERC Order #661-A) or SPP's stability criteria for damping or dynamic voltage recovery are assigned upgrades such that these requirements can be met.

3.1.4 Upgrades Assigned

Thermal overloads that require transmission support to mitigate are discussed in Section 8 and listed in Appendix G-T. Voltage constraints that may require transmission support are discussed in Section 8 and listed in Appendix G-V (Cluster Analysis). Constraints that are identified solely through the stability analysis are discussed in Section 8 and the appropriate appendix for the detailed stability study of that Interconnection Request. All of these upgrades are cost assigned in Appendix E and Appendix F.

Other network constraints not requiring transmission reinforcements are shown in Appendix H (Cluster Analysis). With a defined source and sink in a Transmission Service Request, this list of network constraints can be refined and expanded to account for all Network Upgrade requirements for firm transmission service. Additional constraints identified by multi-element contingencies are listed in Appendix I.

In no way does the list of constraints in Appendix G (Cluster Analysis) identify all potential constraints that guarantee operation for all periods of time. It should be noted that although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

4 Determination of Cost Allocated Network Upgrades

Cost Allocated Network Upgrades of Variable Energy Resources (VER) (solar/wind) generation interconnection requests are determined using the 2017 spring model. Cost Allocated Network Upgrades of peaking units is determined using the 2020 summer peak model. A PSS/E and MUST sensitivity analysis is performed to determine the Distribution Factors (DF), a distribution factor with no contingency that each generation interconnection request has on each new upgrade. The impact each generation interconnection request has on each upgrade project is weighted by the size of each request. Finally the costs due by each request for a particular project are then determined by allocating the portion of each request's impact over the impact of all affecting requests.

For example, assume that there are three Generation Interconnection requests, X, Y, and Z that are responsible for the costs of Upgrade Project '1'. Given that their respective PTDF for the project have been determined, the cost allocation for Generation Interconnection request 'X' for Upgrade Project 1 is found by the following set of steps and formulas:

- Determine an Impact Factor on a given project for all responsible GI requests:

$$\text{Request X Impact Factor on Upgrade Project 1} = \text{PTDF}(X) * \text{MW}(X) = X1$$

$$\text{Request Y Impact Factor on Upgrade Project 1} = \text{PTDF}(Y) * \text{MW}(Y) = Y1$$

$$\text{Request Z Impact Factor on Upgrade Project 1} = \text{PTDF}(Z) * \text{MW}(Z) = Z1$$

- Determine each request's Allocation of Cost for that particular project:

$$\text{Request X's Project 1 Cost Allocation (\$)} = \frac{\text{Network Upgrade Project 1 Cost(\$)} * X1}{X1 + Y1 + Z1}$$

- Repeat previous for each responsible GI request for each Project

The cost allocation of each needed Network Upgrade is determined by the size of each request and its impact on the given project. This allows for the most efficient and reasonable mechanism for sharing the costs of upgrades.

4.1.1 Credits/Compensation for Amounts Advanced for Network Upgrades

Interconnection Customer shall be entitled to either credits or potentially Long Term Congestion Rights (LTCR), otherwise known as compensation, in accordance with Attachment Z2 of the SPP Tariff for any Network Upgrades, including any tax gross-up or any other tax-related payments associated with the Network Upgrades, and not refunded to the Interconnection Customer.

5 Required Interconnection Facilities

The requirement to interconnect the 7,340.9 MW of generation into the existing and proposed transmission systems in the affected areas of the SPP transmission footprint consist of the necessary cost allocated shared facilities listed in Appendix F by upgrade. The interconnection requirements for the cluster total an estimated \$677,958,271 not including the following costs.

- **Costs Not Included** – Costs on Affected Systems for particularly Associated Electric Cooperative Inc. (AECI), Mid-Continent Independent System Operator (MISO), and Minnkota Power Cooperative, Inc (MPC).

Interconnection Facilities specific to each generation interconnection request are listed in Appendix E. A preliminary one-line drawing for each generation interconnection request are listed in Appendix D.

For an explanation of how required Network Upgrades and Interconnection Facilities were determined, refer to the section on "Identification of Network Constraints."

5.1.1 Facilities Analysis

The interconnecting Transmission Owner for each Interconnection Request has provided its preliminary analysis of required Transmission Owner Interconnection Facilities and the associated

Network Upgrades, shown in Appendix D. This analysis was limited only to the expected facilities to be constructed by the Transmission Owner at the Point of Interconnection. These costs are included within one-line diagrams in Appendix D and also listed in Appendix E and F as combined “Interconnection Costs”. If the one-lines and costs in Appendix D have been updated by the Transmission Owner’s Interconnection Facilities Study, those costs will be noted in the appendix. These costs will be further refined by the Transmission Owner as part of the Interconnection Facilities Study. Any additional Network Upgrades identified by this DISIS beyond the Point of Interconnection are defined and estimated by either the Transmission Owner or by SPP. These additional Network Upgrade costs will also be refined further by the Transmission Owner within the Interconnection Facilities Study.

5.1.2 Environmental Review

For Interconnection Requests that result in an interconnection to, or modification to, the transmission facilities of the Western-UGP, a National Environmental Policy Act (NEPA) Environmental Review will be required. The Interconnection Customer will be required to execute and Environmental Review Agreement per Section 8.6.1 of the GIP.

6 Affected Systems Coordination

The following procedures are in place to coordinate with Affected Systems.

- Impacts on Associated Electric Cooperative Inc. (AECI) – For any observed violations of thermal overloads on AECI facilities, AECI has been notified by SPP to evaluate the violations for impacts on its transmission system. AECI has instructed SPP to notify the affected Interconnection Customers after posting of this study to contact AECI for an Affected System Study Agreement to further study the impacts on the AECI system.
- Impacts on Mid Continent Independent System Operation (MISO) – Per SPP’s agreement with MISO, MISO has been contacted and provided a list of interconnection requests that proceed to move forward into the Interconnection Facilities Study Queue. MISO is evaluating the Interconnection Requests for impacts and will be in contact with affected Interconnection Customers.
 - For potential impacts see Appendix H-T – Affected System and Appendix H-V – Affected System
- Impacts on Minnkota Power Cooperative, Inc (MPC) – MPC has been contacted and provided a list of interconnection requests that proceed to move forward into the Interconnection Facilities Study Queue. MPC is evaluating the Interconnection Requests for impacts.
 - For potential impacts see Appendix H-T – Affected System and Appendix H-V – Affected System
- Impacts to other affected systems – For any observed violations of thermal overloads or voltage constraints, SPP will contact the owner of the facility for further information.

7 Power Flow Analysis

7.1.1 Power Flow Analysis Methodology

The ACCC function of PSS/E is used to simulate single element and special (i.e., breaker-to-breaker, multi-element, etc.) contingencies in portions or all of the modeled control areas of SPP, as well as, other control areas external to SPP and the resulting scenarios analyzed. Single element and multi-element contingencies are evaluated.

7.1.2 Power Flow Analysis

A power flow analysis is conducted for each Interconnection Customer's facility using modified versions of the 2016 winter peak (16WP) season, the 2017 spring (17G) and 2017 summer peak (17SP) seasons, the 2020 light load (20L), summer (20SP) and winter peak (20WP) seasons, and the 2025 summer peak (25SP) seasonal models. The output of the Interconnection Customer's facility is offset in each model by a reduction in output of existing online SPP generation. This method allows the request to be studied as an Energy Resource Interconnection Service request (ERIS). Certain requests that are also pursuing Network Resource Interconnection Service (NRIS) have an additional analysis conducted for displacing resources in the interconnecting Transmission Owner's balancing area.

8 Power Flow Results

8.1 Cluster Group 1 (Woodward Area)

In addition to the 4,377.5 MW of previously queued generation in the area, 1,162.8 MW of new interconnection service was studied.

Several ERIS thermal constraints were observed for system intact and N-1 conditions including Cleo Corner – Cleo Corner Tap 138kV circuit #1, Cimarron – Draper 345kV circuit #1, GEN-2015-095 Tap – Rose Valley – Noel SW 138kV circuit #1, Roman Nose – Southard 138kV circuit #1, and Woodward 345/138/13kV circuit #1 and circuit #2. To alleviate the thermal violations, terminal equipment upgrades will be required for Cleo Corner – Cleo Corner Tap 138kV circuit #1 and Cimarron – Draper Lake 345kV circuit #1. Cimarron – Draper Lake 345kV circuit #1 terminal equipment upgrade is currently assigned per SPP-NTC-200329. GEN-2015-095 Tap – Rose Valley – Noel SW 138kV will be required to be rebuilt and Woodward 345/138/13kV circuit #1 and circuit #2 transformers will need to be replaced with larger capacity transformers. Roman Nose – Southard 138kV overload can be alleviated by the advancement of Woodward – Tatonga – Mathewson – Cimarron 345kV transmission circuit #2. Woodward – Tatonga – Mathewson – Cimarron 345kV transmission circuit #2 has been previously cost allocated as a regional upgrade per SPP-NTC-200223 from the 2012 SPP Integrated Transmission Plan 10-Year (2012 ITP 10) with a current anticipated in-service date of July, 2018.

In addition to the ERIS constraints mitigations, NRIS constraints mitigation include higher queued assigned Woodward Phase Shifting Transformer and the advancement of Woodward – Tatonga – Mathewson – Cimarron 345kV transmission circuit #2.

For Group 1 Cluster Analysis cost allocation, please refer to Appendix E and F.

| Cluster ERIS Constraints | | | |
|--|-------------------------|--------------------|--|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| CIMARRON - DRAPER LAKE 345KV CKT 1 | 717 | 103.6296 | GRACEMONT - MINCO 345KV CKT 1 |
| | Mitigation | | Replace terminal equipment |
| CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 117.8972 | System Intact |
| CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 142.716 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| | Mitigation | | Replace terminal equipment |
| G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 120.4845 | System Intact |
| G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 228 | 113.7538 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 113.4116 | System Intact |
| NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 228 | 109.1245 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| | Mitigation | | Rebuild GEN-2015-095 Tap – Rose Valley – Noel 138kV circuit #1 |
| ROMAN NOSE - SOUTHARD 138KV CKT 1 | 153 | 106.4715 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| | Mitigation | | Woodward – Tatonga – Mathewson 345kV circuit #2 |
| WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 | 493 | 103.523 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493 | 103.9633 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| | Mitigation | | Replace Woodward 345/138/13kV transformer circuit #1 and #2 |

| Cluster NRIS Constraints | | | |
|---|-------------------------|--------------------|--|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| CLEARWATER - MILAN TAP 138KV CKT 1 | 110 | 101.4557 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| | Mitigation | | Woodward – Tatonga – Mathewson 345kV circuit #2 |
| CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 110.5718 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| ROMAN NOSE - SOUTHARD 138KV CKT 1 | 153 | 122.0403 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| | Mitigation | | Replace terminal equipment |
| FPL SWITCH - WOODWARD 138KV CKT 1 | 185 | 117.112 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| | Mitigation | | Woodward – Tatonga – Mathewson 345kV circuit #2, and Higher Queued Woodward Phase Shifting Transformer Upgrade |

8.1.1 Group 1 (Limited Operation)

Limited Operation results are listed below. While these results are based on the criteria listed in GIP 8.4.3, the Interconnection Customer may request additional scenarios for Limited Operation based on higher queued Interconnection Requests not being placed in service. All of these amounts listed are based on the assumption that the Woodward District Phase Shifting Transformer goes into service no later than June 1, 2017.

| Limited Operation Analysis | | |
|----------------------------|----------|---|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-048 | 80 | Cleo Corner – Cleo Corner Tap 138kV |
| GEN-2015-057 | 0 | Cimarron – Draper Lake 345KV |
| GEN-2015-059 | 0 | Cimarron – Draper Lake 345KV |
| GEN-2015-060 | 175 | GEN-2015-095 Tap – Rose Valley 138kV |
| GEN-2015-081 | 180 | None |
| | 0 (NRIS) | Several NRIS constraints |
| GEN-2015-093 | 250 | None |
| GEN-2015-095 | 126) | GEN-2015-095 Tap – Rose Valley 138kV & Noel - Rose Valley – Mooreland 138kV |

8.2 Cluster Group 2 (Hitchland Area)

In addition to the 3,616.20 MW of previously queued generation in the area, 200.0 MW of new interconnection service was studied. With the addition of the Group 2 Interconnection Requests, the contingency analysis observed non-convergence for Hitchland – Finney 345kV contingency. Review of the non-convergence results suggest potential voltage collapse(s) in the Beaver and Badger areas during the Hitchland – Finney 345kV contingency. The following transmission reinforcements were incrementally added or advanced from their proposed in-service dates to mitigate the potential voltage collapse:

- Woodward – Tatonga – Mathewson – Cimarron 345kV transmission circuit #2
- Walkemeyer 345/115kV project for non-competitive upgrades only
- Beaver County +125Mvar Static Var Compositor (SVC)

The Woodward – Tatonga – Mathewson – Cimarron 345kV transmission circuit #2 has been previously cost allocated as a regional upgrade per SPP-NTC-200223 from the 2012 SPP Integrated Transmission Plan 10-Year (2012 ITP 10) with a current anticipated in-service date of July, 2018.

Once the non-converged contingencies were solved, additional critical constraints requiring transmission reinforcements are listed below while the complete list of individual constraints requiring additional transmission reinforcements displayed in Appendix G-T.

| Cluster ERIS Constraints | | | |
|---|-------------------------|--------------------|--|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| Non Converged Contingency | N/A | N/A | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| Non Converged Contingency | N/A | N/A | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| | Mitigation | | Woodward – GEN-2011-051 – Tatonga – Mathewson 345kV circuit #2, Walkemeyer Project, and Beaver County Reactive Power Support. |
| POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 116.6448 | System Intact |
| | Mitigation | | Second Potter County Interchange 345/230/13kV Transformer assigned to higher queued request for NRIS only upgrades |

| Cluster NRIS Constraints | | | |
|---|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| No current study Group 02 NRIS requests | | | |

8.2.1 Group 2 (Limited Operation)

Limited Operation results are listed below. While these results are based on the criteria listed in GIP 8.4.3, the Interconnection Customer may request additional scenarios for Limited Operation based on higher queued Interconnection Requests not being placed in service.

| Limited Operation Analysis | | |
|----------------------------|-----|--|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2014-037 | 0 | Voltage Collapse for Finney-Hitchland 345kV System Intact – Bushland Interchange – Potter 345kV and Potter County 345/230/15V Transformer CKT 1 |
| | 110 | Voltage Collapse for Finney-Hitchland 345kV (assuming Bushland Interchange – Potter 345kV and Potter 345/230/13kV transformer are mitigated before 2025) |

8.3 Cluster Group 3 (Spearville Area)

In addition to the 3,235.83 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No current study DISIS-2015-002 Interconnection Customer(s) are located in this geographical group.

8.4 Cluster Group 4 (Northwest Kansas Area)

In addition to the 1,532.2 MW of previously queued generation in the area, 600.2 MW of new interconnection service was studied. No new constraints were observed at this time.

For Group 4 Cluster Analysis cost allocation, please refer to Appendix E and F.

| Cluster ERIS Constraints | | | |
|---|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| Current no new ERIS constraints in group 04 | | | |

| Cluster NRIS Constraints | | | |
|---|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| No current study Group 04 NRIS requests | | | |

8.4.1 Group 4 (Limited Operation)

Limited Operation results are listed below. While these results are based on the criteria listed in GIP 8.4.3, the Interconnection Customer may request additional scenarios for Limited Operation based on higher queued Interconnection Requests not being placed in service.

| Limited Operation Analysis | | |
|----------------------------|-------|----------------------------------|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-061 | 200 | None |
| GEN-2015-064 | 197.8 | None |
| GEN-2015-065 | 202.4 | None |

8.5 Cluster Group 6 (South Texas Panhandle/New Mexico Area)

In addition to the 4,550.77 MW of previously queued generation in the area, 1,011.68 MW of new interconnection service was studied. The large amount of new generation under study in addition to the previous generation already in the queue in this area resulted in potential voltage collapse throughout the entire study area and in all 345kV lines connecting the study area to the rest of the SPP footprint. Eris contingency analysis observed non-converged contingencies on lines leading to the north and east of the study area were encountered. To mitigate these non-converged contingencies, the following Network Upgrade(s) were required.

- New 345kV line from Tuco area to the proposed Chisolm 345kV substation near Sweetwater, OK. This is a second 345kV line that runs parallel to the existing Tuco-Woodward 345kV line. This project includes tapping the 345kV line into the existing Border 345kV station.
 - This project also includes the Crawfish Draw 345kV substation that includes a Crawfish Draw 345/230kV autotransformer. The Crawfish Draw 345kV substation has been assigned to DISIS-2015-001 Interconnection Customers.
- A new 345kV line/tie from the proposed Chisolm 345kV substation to a substation near Chisolm that would tap into the Border-Woodward 345kV line with a five terminal 345kV breaker-and-a-half substation.
 - This upgrade also includes advancing the previously assigned Chisolm – Gracemont 345kV Project.
- Add 600MVars of capacitive reactive compensation at Border 345kV substation. This reactive compensation includes 300MVars of capacitor banks (6 – 50 Mvar banks) and a +300Mvar Static Var Compensator (SVC).
- Add 100Mvars of capacitive and inductive reactive compensation at Oklaunion 345kV substation. This reactive compensation includes +/-100Mvar SVC.
 - Also included were the 2 x 130Mvar capacitor banks assigned to DISIS-2015-001 Interconnection Customers
- Advancement of the Hobbs-Yoakum-Tuco 345kV line to meet the in-service dates of the study generation.

Once the non-converged solutions were mitigated, additional overloads were observed and mitigated as described in the table below.

| Cluster ERIS Constraints | | | |
|---|-------------------------|--------------------|---|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| Non-Converged Contingency | N/A | N/A | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | P12:230:AEPW:ELKCITY6:SWEETWT6 |
| Non-Converged Contingency | N/A | N/A | P12:230:AEPW-SPS:SWEETWT6:WHEELER 6 |
| Non-Converged Contingency | N/A | N/A | P12:345:SPS:J07.1.FINN.HITCH |
| Non-Converged Contingency | N/A | N/A | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| Non-Converged Contingency | N/A | N/A | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| Non-Converged Contingency | N/A | N/A | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 | 360.92 | 100.6422 | NEWHART 230 - POTTER COUNTY INTERCHANGE 230KV CKT 1 |
| CARLISLE INTERCHANGE - LP-DOUD_TP 3115.00 115KV CKT 1 | 177 | 100.2975 | LUBBOCK SOUTH INTERCHANGE - WOLFFORTH INTERCHANGE 230KV CKT 1 |
| CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 105.6208 | System Intact |
| DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 | 350.6 | 102.0399 | NEWHART 230 - PLANT X STATION 230KV CKT 1 |
| | Mitigation | | Build Crawfish Draw – Border – Chisholm circuit #2, Chisholm tie into Border – Woodward, Build Border and Oklaunion reactive power support |
| CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 111.692 | System Intact |
| | Mitigation | | Replace transformer |
| GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 130.5235 | System Intact |
| | Mitigation | | Replace terminal equipment |
| GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 117.5205 | System Intact |
| STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 113.2775 | System Intact |
| STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 111.4968 | System Intact |
| | Mitigation | | Rebuild or re-conductor line |
| POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 109.8194 | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 |
| | Mitigation | | Install second Potter County 345/230/13kv transformer. Currently assigned costs to higher queued NRIS request(s). |
| TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 644 | 115.547 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 700 | 106.3032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |

| | | |
|--|-------------------|--|
| | Mitigation | Build Crawfish Draw 345/230kV Substation, Tie in TUCO – Swisher 230kV and TUCO – Border 345kV. Build Crawfish Draw 345/230/13kV Transformer. Current assigned costs to higher queued NRIS request(s) |
|--|-------------------|--|

| Cluster NRIS Constraints | | | |
|---|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| No current study Group 06 NRIS requests | | | |

8.5.1 Group 6 (Limited Operation)

Limited Operation results are listed below. While these results are based on the criteria listed in GIP 8.4.3, the Interconnection Customer may request additional scenarios for Limited Operation based on higher queued Interconnection Requests not being placed in service.

| Limited Operation Analysis | | |
|-----------------------------------|----|----------------------------------|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-020 | 0 | Multiple |
| GEN-2015-031 | 0 | Multiple |
| GEN-2015-056 | 0 | Multiple |
| GEN-2015-058 | 0 | Multiple |
| GEN-2015-068 | 0 | Multiple |
| GEN-2015-075 | 0 | Multiple |
| GEN-2015-079 | 0 | Multiple |
| GEN-2015-080 | 0 | Multiple |

8.6 Cluster Group 7 (Southwestern Oklahoma Area)

In addition to the 1,923.90 MW of previously queued generation in the area, 413.70 MW of new interconnection service was studied.

Several ERIS thermal constraints were observed for system intact and N-1 conditions including Sequoyah – Cornville Tap – Naples Tap - Payne 138kV circuit #1, Grapevine – Sweetwater 230kV circuit #1, and Norge Road – Southwestern 138kV circuit #1. To alleviate the thermal violations, rebuild or re-conductor will be required for Grapevine – Sweetwater 230kV circuit #1 and Norge Road – Southwestern 138kV circuit #1. WFEC has recent provided updating ratings for Anadarko – Sequoyah – Cornville Tap – Naples Tap – Payne 138kV circuit #1 to SPP GI. SPP GI has evaluated the updated ratings in this restudy analysis and determined the Cornville Tap – Naples Tap – Payne 138kV circuit is still a constraint for system intact conditions. To alleviate the overload, Cornville Tap – Naples Tap - Payne 138kV circuit #1 will be required to be rebuild or re-conducted.

| Cluster ERIS Constraints | | | |
|--|-------------------------|--------------------|---------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 124.6348 | System Intact |
| NAPLESTP 138.00 - PAYNE 138.00 138KV CKT 1 | 132 | 121.388 | System Intact |

| | | | |
|---|-------------------|----------|---|
| CORN TAP - SEQUOYAHJ4 138.00 138KV CKT 1 | 132 | 106.8338 | System Intact |
| | Mitigation | | Updated ratings & rebuild/re-conductor of Cornville Tap – Naples – Payne 138kV |
| GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 350.57 | 99.5 | CHISHOLM7 345.00 - GRACEMONT 345KV CKT 1 |
| STATELINE INTERCHANGE - STLN-DEMAR6 230KV CKT 1 | 381.24 | 127.0248 | CHISHOLM7 345.00 - GRACEMONT 345KV CKT 1 |
| STLN-DEMAR6 - SWEETWATER 230KV CKT 1 | 353 | 137.1842 | CHISHOLM7 345.00 - GRACEMONT 345KV CKT 1 |
| | Mitigation | | Rebuild or re-conductor line |
| NORGE ROAD - SOUTHWESTERN STATION 138KV CKT 1 | 136 | 100.904 | System Intact |
| | Mitigation | | Rebuild Norge Road – Southwestern Station 138kV |

| Cluster NRIS Constraints | | | |
|---|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| No current study Group 07 NRIS requests | | | |

8.6.1 Group 7 (Limited Operation)

Limited Operation results are listed below. While these results are based on the criteria listed in GIP 8.4.3, the Interconnection Customer may request additional scenarios for Limited Operation based on higher queued Interconnection Requests not being placed in service.

| Limited Operation Analysis | | |
|-----------------------------------|----|---|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-055 | 0 | Grapevine - Sweetwater 230kV CKT 1 |
| GEN-2015-071 | 0 | Grapevine - Sweetwater 230kV CKT 1 |
| GEN-2015-084 | 0 | Cornville Tap – Naples Tap – Sequoyah 138kV |
| GEN-2015-085 | 0 | Cornville Tap – Naples Tap – Sequoyah 138kV |

8.7 Cluster Group 8 (North Oklahoma/South Central Kansas Area)

In addition to the 5,226.06 MW of previously queued generation in the area, 2,348.00 MW of new interconnection service was studied. ERIS constraints were observed along the Mathewson – GEN-2015-063 Tap transmission circuit. The emergency rating for Mathewson – GEN-2015-063 Tap 345kV is planned to be 2000 amps (1195MVA) after Mathewson Substation is in-service. Mathewson Substation is currently planned to be in-service by June 2016. In additional, current study work will be required to replace terminal equipment to achieve conductor limit to alleviate the thermal overload on this transmission circuit. Emporia Energy Center – Swissvale – West Gardner 345kV circuit #1 constraints would require terminal equipment upgrades to alleviate the current study thermal overloads.

Although, several group 08 requests elected to not proceed with the Network Resource Interconnection Service (NRIS) service type prior to the execution of the Interconnection Facilities Studies (IFS), Associated Electric Cooperative Inc. (AECI) is still performing the Affected System Study. DISIS-2015-002-1 power flow analysis observed overloading impacts identified on the AECI system around the Cleveland area. These impacts could be below the SPP Generation Interconnection Energy Resource Interconnection Service (ERIS) outage distribution factor criteria of 20% or system intact power distribution factor criteria of 3%, but could be required for mitigation by the AECI’s Generation Interconnection criteria. These Interconnection Customers will

need to contract with AECl for Affected System Studies to determine whether AECl facilities are impacted.

- GEN-2015-034
- GEN-2015-047
- GEN-2015-052
- GEN-2015-062
- GEN-2015-063
- GEN-2015-066
- GEN-2015-067
- GEN-2015-083

For Group 8 Cluster Analysis cost allocation, please refer to Appendix E and F.

| Cluster ERIS Constraints | | | |
|---|-------------------------|--------------------|---|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| CLEVELAND - CLEVLND 4 138.00 138KV CKT Z1 | 371 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| CLEVELAND - SILVER CITY 138KV CKT 1 | 174 | 118.7603 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| | Mitigation | | Replace Cleveland – Cleveland bus tie terminal equipment and rebuild/re-conductor Cleveland – Silver City 138kV. These upgrades would be pending the AECl affected system study. |
| G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 125.2078 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| | Mitigation | | After the installation of Mathewson, the line will have an 1195 MVA rating. Additional current study will be required to upgrade terminal equipment to achieve conductor limit |
| SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 121.2614 | HOYT - STRANGER CREEK 345KV CKT 1 |
| | Mitigation | | Replace terminal equipment |
| EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1 | 717 | 119.2027 | HOYT - STRANGER CREEK 345KV CKT 1 |
| | Mitigation | | Replace terminal equipment |

| Cluster NRIS Constraints | | | |
|--------------------------------------|-------------------------|--------------------|-----------------------------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 100.7418 | HOYT - STRANGER CREEK 345KV CKT 1 |
| | Mitigation | | Replace terminal equipment |

8.7.1 Group 8 (Limited Operation)

Limited Operation results are listed below. While these results are based on the criteria listed in GIP 8.4.3, the Interconnection Customer may request additional scenarios for Limited Operation based on higher queued Interconnection Requests not being placed in service. Limited Operation amounts are calculated based on constraints with the SPP transmission system. Once the Affected System Impact studies are completed, these Limited Operation amounts could be further restricted by affected systems constraints.

| Limited Operation Analysis | | |
|----------------------------|-----|------------------------------------|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-034 | 200 | None |
| GEN-2015-047 | 282 | GEN-2015-063 Tap – Mathewson 345kV |
| GEN-2015-052 | 300 | None |
| GEN-2015-062 | 4.0 | GEN-2015-063 Tap – Mathewson 345kV |

| Limited Operation Analysis | | |
|----------------------------|-------|------------------------------------|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-063 | 282 | GEN-2015-063 Tap – Mathewson 345kV |
| GEN-2015-066 | 248.4 | None |
| GEN-2015-067 | 150 | None |
| GEN-2015-069 | 0 | Swissvale – W Gardner 345kV |
| GEN-2015-073 | 0 | Swissvale – W Gardner 345kV |
| GEN-2015-083 | 125 | None |
| GEN-2015-090 | 220 | None |

8.8 Cluster Group 9 (Nebraska Area)

In addition to the 2,927.7 MW of previously queued generation in the area, 574.4 MW of new interconnection service was studied. Eris analysis observed constraints on Gavins Point – Yankton Junction 115kV circuit #1 and Petersburg – North Petersburg 115kV circuit #1. Mitigations for the overloads include rebuilding or re-conductoring Gavins Point – Yankton 115kV circuit #1 and Petersburg – North Petersburg 115kV. Transmission facilities on the WAPA system will require National Environmental Policy Act (NEPA) review. For more information on the NEPA Environmental Review, please refer to Section 8.6.1 of the GIP.

| Cluster ERIS Constraints | | | |
|--|-------------------------|--------------------|---|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 118.2407 | GAVINS POINT - SPIRIT MOUND 115KV CKT 1 |
| | Mitigation | | Rebuild or re-conductor line |
| PETERSBRG.N7115.00 - PETERSBURG 115KV CKT Z1 | 137 | 102.2948 | ANTELOPE 3345.00 (ANTELOPE T1) 345/115/13.8KV TRANSFORMER CKT 1 |
| | Mitigation | | Rebuild or re-conductor line |

| Cluster NRIS Constraints | | | |
|---|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| Currently no additional NRIS only constraints | | | |

8.8.1 Group 9 (Limited Operation)

Limited Operation results are listed below. While these results are based on the criteria listed in GIP 8.4.3, the Interconnection Customer may request additional scenarios for Limited Operation based on higher queued Interconnection Requests not being placed in service. Limited Operation amounts are calculated based on constraints with the SPP transmission system. Once the Affected System Impact studies are completed, these Limited Operation amounts could be further restricted by affected systems constraints.

| Limited Operation Analysis | | |
|----------------------------|----|-------------------------------------|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-053 | 32 | Petersburg – North Petersburg 115kV |
| GEN-2015-076 | 66 | Gavins – Yankton 115kV |
| GEN-2015-087 | 66 | None |

| Limited Operation Analysis | | |
|----------------------------|-----|----------------------------------|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-088 | 300 | None |

8.9 Cluster Group 10 (Southeast Oklahoma/Northeast Texas Area)

There is no current study Interconnection Request(s) in the Group 10 geographical region.

8.10 Cluster Group 12 (Northwest Arkansas Area)

There is no current study Interconnection Request(s) in the Group 12 geographical region.

8.11 Cluster Group 13 (Northeast Kansas/Northwest Missouri Area)

There is no current study Interconnection Request(s) in the Group 13 geographical region.

8.12 Cluster Group 14 (South Central Oklahoma Area)

In addition to the 612.50 MW of previously queued generation in the area, 279.0 MW of new interconnection service was studied. Currently, no new ERIS constraints were found in this area.

| Cluster ERIS Constraints | | | |
|---|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| Currently, No ERIS Group 14 constraints | | | |

| Cluster NRIS Constraints | | | |
|---|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| No current study Group 14 NRIS requests | | | |

8.12.1 Group 14 (Limited Operation)

Limited Operation results are listed below. While these results are based on the criteria listed in GIP 8.4.3, the Interconnection Customer may request additional scenarios for Limited Operation based on higher queued Interconnection Requests not being placed in service.

| Limited Operation Analysis | | |
|----------------------------|-----|----------------------------------|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-045 | 20 | None |
| GEN-2015-092 | 250 | None |

8.13 Group 15 (Eastern South Dakota)

In addition to approximately 1,915.70 MW of previously queued generation in the area, 100 MW of new interconnection service was studied. ERIS contingency analysis observed thermal constraints for GI-1301 Tap – Watertown 115kV circuit #1 and Split Rock – White 345kV circuit #1. GI-1301 Tap – Watertown 115kV circuit will be required to be rebuilt or re-conducted and Split Rock – White will need terminal equipment upgrades. Transmission facilities on the WAPA system will require

National Environmental Policy Act (NEPA) review. For more information on the NEPA Environmental Review, please refer to Section 8.6.1 of the GIP. Also, certain constraints were found to be relieved in the short term by the MISO project, Ellendale MVP – Big Stone South 345kV line. MISO will need to perform an Affected System Study to determine potential impacts on their system.

| Cluster ERIS Constraints | | | |
|---|-------------------------|--------------------|---|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| G13_001ST 115.00 - WATERTOWN 115KV CKT 1' | 121 | 110.4503 | Groton 345/115kV transformer |
| | | Mitigation | Rebuild 26 miles of 115kV line |
| SPLIT ROCK - WHITE 345KV CKT 1 | 717 | 99.9 | BROOKING COUNTY - LYON COUNTY 345KV CKT 1 |
| | | Mitigation | Replace terminal equipment |

| Cluster NRIS Constraints | | | |
|---|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| No current study Group 15 NRIS requests | | | |

After constraints for transmission reinforcement upgrades were mitigated, the following steady-state voltage violations require mitigation. One step of 5.0Mvars at the Ordway 115kV capacitor bank(s) will be required to mitigate the steady state voltage observed after contingency.

| Cluster ERIS Voltage Constraints | | | | |
|----------------------------------|-----------------|-----------|------------|-----------------------------|
| MONITORED ELEMENT | TC Voltage (PU) | VMIN (PU) | VMAX (PU) | CONTINGENCY |
| ORDWAY 115KV | 0.80 | 0.9 | 1.05 | GROTON - ORDWAY 115KV CKT 1 |
| ORDWAY 69KV | 0.80 | 0.9 | 1.05 | GROTON - ORDWAY 115KV CKT 1 |
| | | | Mitigation | Groton – Ordway 115kV CKT 2 |

8.13.1 Group 15 (Limited Operation)

Limited Operation results are listed below. While these results are based on the criteria listed in GIP 8.4.3, the Interconnection Customer may request additional scenarios for Limited Operation based on higher queued Interconnection Requests not being placed in service. Limited Operation amounts are calculated based on constraints with the SPP transmission system. Once the Affected System Impact studies are completed, these Limited Operation amounts could be further restricted by affected systems constraints.

| Limited Operation Analysis | | |
|----------------------------|----|----------------------------------|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-097 | 34 | G13_001-Watertown 115kV |

8.14 Group 16 (Western North Dakota)

In addition to approximately 3,247.81 MW of previously queued generation in the area, 651.2 MW of new interconnection service was studied. Due to the amount of generation being interconnected in this group, large flows were observed on the Holt County – Grand Island 345kV line and potential voltage collapse was observed for the outage of that line. The mitigation is for Group 16 Interconnection Requests –to advance Holt – Thedford – Gentleman 345kV line that is also assigned to Group 9 Interconnection Requests. With the addition of 250MW of wind generation at the Daglum substation (currently under construction) on the Belfield – Rhame 230kV line, potential voltage collapse was observed for the outage of the Daglum – Belfield line. This will require a new 230kV line, approximately 28 miles long to be constructed from Daglum to Dickinson. The Dickinson 230/115kV auto was also shown to overload. This transformer replacement is cost assigned to current study requests. Transmission facilities on the WAPA system will require National Environmental Policy Act (NEPA) review. For more information on the NEPA Environmental Review, please refer to Section 8.6.1 of the GIP. Also, certain constraints were found to be relieved in the short term by the MISO project, Ellendale MVP – Big Stone South 345kV line. MISO will need to perform an Affected System Study to determine potential impacts on their system.

| Cluster ERIS Constraints | | | |
|---|-------------------------|--------------------|---|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| Non-converged contingency | N/A | N/A | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| | Mitigation | | Build new 28 mile line from Daglum – Dickinson 230kV |
| Non-converged contingency | N/A | N/A | G09_001IST 345.00 - GROTON 345KV CKT 1 |
| Non-converged contingency | N/A | N/A | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| | Mitigation | | Previously Allocated Upgrade for RoundUp – Patent Gate – Kummer Rdige Project |
| Non-converged contingency | n/a | n/a | HESKETT - WISHEK 230KV CKT 1 |
| Non-converged contingency | n/a | n/a | MERRCRT4 230.00 - WISHEK 230KV CKT 1 |
| Non-converged contingency | n/a | n/a | RIEL - ROSEAU 500KV CKT 1 |
| Non-converged contingency | n/a | n/a | ROSEAU - ROSEAU 2 500.00 500KV CKT 1 |
| Non-converged contingency | n/a | n/a | CENTER - CNTSHNT3 345.00 345KV CKT Z1 |
| Non-converged contingency | n/a | n/a | ELLENDALE - OAKES 230KV CKT 1 |
| Non-converged contingency | n/a | n/a | FORBES - ROSEAU 500KV CKT 1 |
| BUFFALO - JAMESTOWN 345KV CKT 1 | 705 | 109 | System Intact |
| ELLENDALE - OAKES 230KV CKT 1 | 319.0 | 118.6155 | System Intact |
| ELLENDLMVP4 230.00 - J316_SUB 230.00 230KV CKT 1 | 319.0 | 120.8457 | System Intact |
| | Mitigation | | MISO / MH Review |
| DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 121.2902 | System Intact |
| | Mitigation | | build second Dickinson 230/115/13kV transformer |
| NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 137.0638 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| | Mitigation | | New rating available |
| BROADLAND - HURON 230KV CKT 1 | 400 | 101.3711 | System Intact |
| | Mitigation | | New rating available |

| Cluster NRIS Constraints | | | |
|--------------------------|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |

| Cluster NRIS Constraints | | | |
|---|-------------------------|--------------------|-------------|
| MONITORED ELEMENT | Limiting Rate A/B (MVA) | TC%LOADING (% MVA) | CONTINGENCY |
| No current study Group 15 NRIS requests | | | |

| Cluster ERS Voltage Constraints | | | | |
|---------------------------------|-----------------|-----------|--|--|
| MONITORED ELEMENT | TC Voltage (PU) | VMIN (PU) | VMAX (PU) | CONTINGENCY |
| HANLON 69KV | 0.889 | 0.9 | 1.05 | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| | Mitigation | | Two (2) steps of 5Mvars totaling to 10Mvars at Hanlon 69kV | |

8.14.1 Group 16 (Limited Operation)

Limited Operation results are listed below. While these results are based on the criteria listed in GIP 8.4.3, the Interconnection Customer may request additional scenarios for Limited Operation based on higher queued Interconnection Requests not being placed in service. Limited Operation amounts are calculated based on constraints with the SPP transmission system. Once the Affected System Impact studies are completed, these Limited Operation amounts could be further restricted by affected systems constraints.

| Limited Operation Analysis | | |
|----------------------------|----|--|
| Interconnection Request | MW | Constraint that most limits LOIS |
| GEN-2015-046 | 0 | Dickinson 230/115/13kV Transformer |
| GEN-2015-091 | 0 | Belfield – Daglum non-convergence & Dickinson 230/115/13kV Transformer |
| GEN-2015-096 | 0 | Belfield – Daglum non-convergence & Dickinson 230/115/13kV Transformer |
| GEN-2015-098 | 0 | Belfield – Daglum non-convergence & Dickinson 230/115/13kV Transformer |

8.15 Curtailment and System Reliability

In no way does this study guarantee operation for all periods of time. It should be noted that although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

9 Stability & Short Circuit Analysis

A stability and short circuit analysis is conducted for each Interconnection Customer using modified versions of the 2015 series SPP Model Development Working Group (MDWG) Models 2016 winter (16WP), 2017 summer (17SP), and 2025 summer peak (25SP) dynamic cases⁹. The stability analysis is conducted with all upgrades in service that are identified in the power flow analysis unless otherwise noted in the individual group stability study. For each group, the interconnection requests are studied at 100% nameplate output while the other groups are dispatched at 20% output for Variable Energy Resource (VER) requests and 100% output for other requests. The output of the Interconnection Customer’s facility is offset in each model by a reduction in output of existing online SPP generation. Each Interconnection Request is studied in a Stand Alone scenario in addition to the cluster scenario. A synopsis is included for each group. The entire stability study for each group can be found in the Appendices.

Short-circuit analysis is performed but verification of over-dutied equipment is performed by the Transmission Owner within the Interconnection Facilities Study. Results of that analysis may require additional costs to replace circuit breakers and associated equipment.

9.1 Cluster Group 1 (Woodward Area)

The Group 1 stability analysis for this area is being performed by S&C Electric (S&C). It was determined that for certain prior outage conditions that study generation will need to be curtailed. Stability analysis has determined that with all previously assigned and currently assigned Network Upgrades placed in service the transmission system will remain stable and low voltage ride through requirements are satisfied for the probable contingencies studied. Power Factor requirements are listed in the table below. In addition, some Interconnection Requests may have requirements for reactors under low wind conditions as identified in the S&C Group 1 report.

Power Factor Requirements:

| Request | Size (MW) | Generator Model | Point of Interconnection | Power Factor Requirement at POI* | |
|--------------|-----------|-----------------|--|----------------------------------|---------------------|
| | | | | Lagging (supplying) | Leading (absorbing) |
| GEN-2015-048 | 200 | Vestas V110 | Cleo Corner 138kV | 0.95 | 0.95 |
| GEN-2015-057 | 100 | G.E. 2.3MW | Minco 345kV | 0.95 | 0.95 |
| GEN-2015-059 | 6.3 | G.E. 1.79MW | Minco 345kV | 0.95 | 0.95 |
| GEN-2015-060 | 250 | G.E. 1.79MW | Woodward EHV District 138kV | 0.95 | 0.95 |
| GEN-2015-081 | 180 | Vestas V110 | Tap on the Woodward - Tatonga 345kV line (G11_051-TAP) | 0.95 | 0.95 |

⁹ Short Circuit analysis performed only on the 2017 and 2025 Summer Peak seasonal model. Group 6 Stability Analysis also includes 2020 Summer and Winter Peak seasons.

| Request | Size (MW) | Generator Model | Point of Interconnection | Power Factor Requirement at POI* | |
|--------------|-----------|-----------------|------------------------------------|----------------------------------|---------------------|
| | | | | Lagging (supplying) | Leading (absorbing) |
| GEN-2015-093 | 250 | G.E. 2MW | Gracemont 345kV | 0.95 | 0.95 |
| GEN-2015-095 | 176 | Vestas V110 | Tap on Mooreland-Noel Switch 138kV | 0.95 | 0.95 |

*As reactive power is required for all projects, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.

** Requirement for reactors for low wind conditions

9.2 Cluster Group 2 (Hitchland Area)

The Group 2 stability analysis for this area was performed by ABB. Power Factor requirements are listed in the table below. Stability analysis has determined that with all previously assigned and currently assigned Network Upgrades placed in service the transmission system will remain stable and low voltage ride through requirements are satisfied for the probable contingencies studied. It was determined for prior outage conditions that Network Upgrades assigned in the powerflow analysis were required for a steady state solution prior to stability analysis. These prior outage conditions determined a need for curtailment of studied generation in the case of certain transmission outages. In addition, some Interconnection Requests may have requirements for reactors under low wind conditions as identified in the ABB Group 2 report.

Power Factor Requirements:

| Request | Size (MW) | Generator Model | Point of Interconnection | Power Factor Requirement at POI* | |
|--------------|-----------|-----------------------|---|----------------------------------|---------------------|
| | | | | Lagging (supplying) | Leading (absorbing) |
| GEN-2014-037 | 200.0 | Vestas V110 2.0 MW | Tap Hitchland – Beaver County 345kV (Optima 345kV) | 0.95 | 0.95 |

*As reactive power is required for all projects, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.

** Requirement for reactors for low wind conditions

9.3 Cluster Group 3 (Spearville Area)

In addition to the 3,235.83 MW of previously queued generation in the area, 0.0 MW of new interconnection service was studied. No current study DISIS-2015-002 Interconnection Customer(s) are located in this geographical group.

9.4 Cluster Group 4 (Northwest Kansas)

The Group 4 stability analysis was not performed again for this restudy. The original analysis in DISIS-2015-002 is still valid.

9.5 Cluster Group 6 (South Texas Panhandle/New Mexico)

The Group 6 stability analysis for this area was performed by Mitsubishi Electric Power Products Inc. (MEPPI). Power Factor requirements are listed in the table below. It was determined for prior outage conditions that Network Upgrades assigned in the powerflow analysis were required for a steady state solution prior to stability analysis. The Stability analysis has shown that the following upgrades are needed to mitigate certain contingencies:

- Tuco – Yoakum – Hobbs 345kV circuit 1
- Yoakum 345/230kV transformer and Hobb 345/230kV transformer
- OKU reactive power support
 - +/- 100Mvar SVC
- Border reactive power support (600Mvar total)
 - +300Mvar SVC
 - 300Mvar capacitor bank
- Seminole – Mustang 115kV circuit 1

The higher queued GEN-2014-074 tripped off line due to transient high voltage for a fault that takes the Tuco to Rio Blanco 345kV line out of service. An adjustment of the GEN-2014-074 substation transformer tap kept the generator on line for the fault. However, it is anticipated that a more robust dynamic reactive solution at GEN-2014-074 will be necessary.

With all previously assigned and currently assigned Network Upgrades placed in service the transmission system will remain stable and low voltage ride through requirements are satisfied for the probable contingencies studied. In addition, some Interconnection Requests may have requirements for reactors under low wind conditions as identified in the MEPPI Group 6 report.

Power Factor Requirements:

| Request | Size (MW) | Generator Model | Point of Interconnection | Power Factor Requirement at POI* | |
|--------------|-----------|----------------------------------|------------------------------|----------------------------------|---------------------|
| | | | | Lagging (supplying) | Leading (absorbing) |
| GEN-2015-020 | 100 | Eaton Power Xpert Solar 1.67MW | Oasis 115kV | 0.95 | 0.95 |
| GEN-2015-031 | 150.5 | GE 1.79 & GE 2.3 MW | Tap Amarillo – Swisher 230kV | 0.95 | 0.95 |
| GEN-2015-056 | 101.2 | GE 2.3 MW | Crossroads 345kV | 0.95 | 0.95 |
| GEN-2015-058 | 50 | Power Electronics Solar 1.667 MW | Atoka 115kV | 0.95 | 0.95 |
| GEN-2015-068 | 300 | GE 2.0 MW | Tuco 345kV | 0.95 | 0.95 |
| GEN-2015-075 | 51.48 | GE 3.96 MW | Carlisle 69kV | 0.95 | 0.95 |
| GEN-2015-079 | 129.2 | GE LV5 3.8 MW | Tap Yoakum-Hobbs 230kV | 0.95 | 0.95 |
| GEN-2015-080 | 129.2 | GE LV5 3.8 MW | Tap Yoakum-Hobbs 230kV | 0.95 | 0.95 |

- *As reactive power is required for all projects, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.
- ** Requirement for reactors for low wind conditions

9.6 Cluster Group 7 (Southwest Oklahoma)

The Group 7 stability analysis was not performed again for this restudy. The original analysis in DISIS-2015-002 is still valid.

9.7 Cluster Group 8 (South Central Kansas/North Oklahoma)

The Group 8 stability analysis was not performed again for this restudy. The original analysis in DISIS-2015-002 is still valid. GEN-2015-073 is currently being evaluated for wind turbine change modification impacts. This GEN-2015-073 turbine modification analysis will be posted once completed in another report posting.

9.8 Cluster Group 9 (Nebraska)

The Group 9 stability analysis for this area was performed by Mitsubishi Electric Power Products Inc. (MEPPI). The stability analysis has identified oscillation issues at the Fairbury generation facility and at the Broken Bow generation facility for certain contingencies. It was determined that these issues were not caused by the study generation, and that the issues are prior existing. Stability analysis has determined that with all previously assigned and currently assigned Network Upgrades placed in service the transmission system will remain stable and low voltage ride through requirements are satisfied for the probable contingencies studied. Power Factor requirements are listed in the table below. In addition, some Interconnection Requests may have requirements for reactors under low wind conditions as identified in the Group 9 report.

Power Factor Requirements:

| Request | Size (MW) | Generator Model | Point of Interconnection | Power Factor Requirement at POI* | |
|--------------|-----------|-----------------------|---------------------------------|----------------------------------|---------------------|
| | | | | Lagging (supplying) | Leading (absorbing) |
| GEN-2015-053 | 50 | GE 1.79 MW | Antelope 115kV | 0.95 | 0.95 |
| GEN-2015-076 | 158.4 | Vestas 3.3-117 3.3 MW | Belden 115kV | 0.95 | 0.95 |
| GEN-2015-087 | 66 | Vestas V100 2.0 MW | Tap on Fairbury to Hebron 115kV | 0.95 | 0.95 |
| GEN-2015-088 | 300 | Vestas V100 2.0 MW | Tap on Moore to Pauline 345kV | 0.95 | 0.95 |

*As reactive power is required for all projects, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.

** Requirement for reactors for low wind conditions

9.9 Cluster Group 10 (Southeast Oklahoma/Northeast Texas Area)

There is no current study Interconnection Request(s) in the Group 10 geographical region.

9.10 Cluster Group 12 (Northwest Arkansas Area)

There is no current study Interconnection Request(s) in the Group 12 geographical region.

9.11 Cluster Group 13 (Northeast Kansas/Northwest Missouri Area)

There is no current study Interconnection Request(s) in the Group 13 geographical region.

** Requirement for reactors for low wind conditions

9.12 Cluster Group 14 (South Central Oklahoma)

The Group 14 stability analysis was not performed again for this restudy. The original analysis in DISIS-2015-002 is still valid.

9.13 Cluster Group 15 (Eastern South Dakota)

The Group 15 stability analysis was not performed again for this restudy. The original analysis in DISIS-2015-002 is still valid.

9.14 Cluster Group 16 (Western North Dakota)

The Group 16 stability analysis was not performed again for this restudy. The original analysis in DISIS-2015-002 is still valid. GEN-2015-098 is currently being evaluated for wind turbine change modification impacts. This GEN-2015-098 turbine modification analysis will be posted once completed in another report posting.

10 Conclusion

The minimum cost of interconnecting 7,340.9 MW of new generation interconnection requests included in this Definitive Interconnection System Impact Study is estimated at \$677,958,271 not including the following costs.

- **Costs Not Included** – Costs on Affected Systems for particularly Associated Electric Cooperative Inc. (AECI) and the Mid-Continent Independent System Operator (MISO).

Interconnection Requests allocated Network Upgrades and Transmission Owner Interconnection Facilities listed in Appendix E and F. For Interconnection Requests that result in an interconnection to, or modification to, the transmission facilities of the Western-UGP (WAPA), a National Environmental Policy Act (NEPA) Environmental Review will be required. The Interconnection Customer will be required to execute and Environmental Review Agreement per Section 8.6.1 of the GIP.

These costs do not include the cost of upgrades of other transmission facilities listed in Appendix H which are Network Constraints. These interconnection costs do not include any cost of any Network Upgrades that are identified as required through the short circuit analysis. Potential over-duty circuit breakers capability will be identified by the Transmission Owner in the Interconnection Facilities Study.

Further refinement of total estimated interconnection costs will be provided, should the Interconnection Customer meet the requirements for acceptance and choose to move into the Interconnection Facilities Study following the posting of this DISIS. The Interconnection Facilities Study may include additional study analysis, additional facility upgrades not yet identified by this DISIS, such as circuit breaker replacements and affected system facilities, and further refinement of existing cost estimates.

The required interconnection costs listed in Appendices E, and F, and other upgrades associated with Network Constraints do not include all costs associated with the deliverability of the energy to

final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request (TSR) through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP Open Access Transmission Tariff (OATT).

11 Appendices

11.1 A: Generation Interconnection Requests Considered for Impact Study

See next page.

A: Generation Interconnection Requests Considered for Study

| Request | Amount | Service | Area | Requested Point of Interconnection | Proposed Point of Interconnection | Requested In-Service Date | In Service Date Delayed Until no earlier than* |
|---------------|--------|---------|----------|---|---|---------------------------|--|
| ASGI-2015-006 | 9.00 | ER | SWPA | Tupelo 138kV | Tupelo 138kV | | TBD |
| GEN-2014-037 | 200.00 | ER | SPS | Tap Hitchland - Beaver County Dbl Ckt (Optima) 345kV | Tap Hitchland - Beaver County Dbl Ckt (Optima) 345kV | 9/30/2017 | TBD |
| GEN-2015-020 | 100.00 | ER | SPS | Oasis 115kV | Oasis 115kV | 12/1/2016 | TBD |
| GEN-2015-031 | 150.50 | ER | SPS | Tap Amarillo South - Swisher 230kV | Tap Amarillo South - Swisher 230kV | 9/1/2017 | TBD |
| GEN-2015-034 | 200.00 | ER | OKGE | Ranch Road 345kV | Ranch Road 345kV | 10/31/2017 | TBD |
| GEN-2015-045 | 20.00 | ER | AEPW | Tap Lawton - Sunnyside (Terry Road) 345kV | Tap Lawton - Sunnyside (Terry Road) 345kV | 12/1/2017 | TBD |
| GEN-2015-046 | 300.00 | ER | WAPA | Tande 345kV | Tande 345kV | 12/1/2017 | TBD |
| GEN-2015-047 | 300.00 | ER | OKGE | Sooner 345kV | Sooner 345kV | 12/1/2017 | TBD |
| GEN-2015-048 | 200.00 | ER | OKGE | Cleo Corner 138kV | Cleo Corner 138kV | 12/1/2017 | TBD |
| GEN-2015-052 | 300.00 | ER | WERE | Tap Open Sky - Rose Hill 345kV | Tap Open Sky - Rose Hill 345kV | 12/1/2017 | TBD |
| GEN-2015-053 | 50.00 | ER | NPPD | Antelope 115kV | Antelope 115kV | 12/31/2017 | TBD |
| GEN-2015-055 | 40.00 | ER | WFEC | Erick 138kV | Erick 138kV | 10/30/2016 | TBD |
| GEN-2015-056 | 101.20 | ER | SPS | Crossroads 345kV | Crossroads 345kV | 12/1/2017 | TBD |
| GEN-2015-057 | 100.00 | ER | OKGE | Minco 345kV | Minco 345kV | 12/1/2016 | TBD |
| GEN-2015-058 | 50.00 | ER | SPS | Atoka 115kV | Atoka 115kV | 10/1/2017 | TBD |
| GEN-2015-059 | 6.30 | ER | OKGE | Minco 345kV | Minco 345kV | 2/1/2016 | TBD |
| GEN-2015-060 | 250.50 | ER | OKGE | Woodward EHV 138kV | Woodward EHV 138kV | 12/31/2021 | TBD |
| GEN-2015-061 | 200.00 | ER | SUNCMKEC | Mingo 345kV | Mingo 345kV | 12/31/2018 | TBD |
| GEN-2015-062 | 4.50 | ER | OKGE | Tap and Tie South 4th - Bunch Creek & Enid Tap - Fairmont (GEN-2012-033T) 138kV | Tap and Tie South 4th - Bunch Creek & Enid Tap - Fairmont (GEN-2012-033T) 138kV | 3/1/2016 | TBD |
| GEN-2015-063 | 300.00 | ER | OKGE | Tap Woodring - Mathewson 345kV | Tap Woodring - Mathewson 345kV | 12/1/2017 | TBD |
| GEN-2015-064 | 197.80 | ER | SUNCMKEC | Mingo 115kV | Mingo 115kV | 11/1/2017 | TBD |
| GEN-2015-065 | 202.40 | ER | SUNCMKEC | Mingo 345kV | Mingo 345kV | 11/1/2017 | TBD |
| GEN-2015-066 | 248.40 | ER | OKGE | Tap Cleveland - Sooner 345kV | Tap Cleveland - Sooner 345kV | 12/1/2017 | TBD |
| GEN-2015-067 | 150.00 | ER | OKGE | Sooner 138kV | Sooner 138kV | 10/1/2017 | TBD |
| GEN-2015-068 | 300.00 | ER | SPS | TUCO Interchange 345kV | TUCO Interchange 345kV | 12/1/2017 | TBD |
| GEN-2015-069 | 300.00 | ER | WERE | Union Ridge 230kV | Union Ridge 230kV | 12/1/2017 | TBD |
| GEN-2015-071 | 200.00 | ER | AEPW | Chisholm 345kV | Chisholm 345kV | 9/30/2017 | TBD |
| GEN-2015-073 | 200.10 | ER/NR | WERE | Emporia Energy Center 345kV | Emporia Energy Center 345kV | 12/31/2018 | TBD |
| GEN-2015-075 | 51.50 | ER | SPS | Carlisle 69kV | Carlisle 69kV | 12/1/2018 | TBD |
| GEN-2015-076 | 158.40 | ER | NPPD | Belden 115kV | Belden 115kV | 7/31/2017 | TBD |
| GEN-2015-079 | 129.20 | ER | SPS | Tap Yoakum - Hobbs Interchange 230kV | Tap Yoakum - Hobbs Interchange 230kV | 10/1/2018 | TBD |
| GEN-2015-080 | 129.20 | ER | SPS | Tap Yoakum - Hobbs Interchange 230kV | Tap Yoakum - Hobbs Interchange 230kV | 5/1/2019 | TBD |
| GEN-2015-081 | 180.00 | ER/NR | OKGE | Tap Woodward - Tatonga (GEN-2011-051 Tap) 345kV | Tap Woodward - Tatonga (GEN-2011-051 Tap) 345kV | 7/1/2018 | TBD |
| GEN-2015-083 | 125.00 | ER | WERE | Belle Plain 138kV | Belle Plain 138kV | 12/31/2017 | TBD |
| GEN-2015-084 | 51.30 | ER | AEPW | Hollis 138kV | Hollis 138kV | 12/10/2018 | TBD |
| GEN-2015-085 | 122.40 | ER | AEPW | Altus Junction 138kV | Altus Junction 138kV | 12/10/2018 | TBD |
| GEN-2015-087 | 66.00 | ER/NR | NPPD | Tap Fairbury - Hebron 115kV | Tap Fairbury - Hebron 115kV | 1/1/2019 | TBD |
| GEN-2015-088 | 300.00 | ER/NR | NPPD | Tap Moore - Pauline 345kV | Tap Moore - Pauline 345kV | 1/1/2019 | TBD |
| GEN-2015-090 | 220.00 | ER | WERE | Tap Thistle - Wichita 345kV Dbl CKT | Tap Thistle - Wichita 345kV Dbl CKT | 12/1/2017 | TBD |

| Request | Amount | Service | Area | Requested Point of Interconnection | Proposed Point of Interconnection | Requested In-Service Date | In Service Date Delayed Until no earlier than* |
|------------------------|--------|---------|------|---|---|---------------------------|--|
| GEN-2015-091 | 101.20 | ER | WAPA | Daglum 230kV | Daglum 230kV | 12/1/2017 | TBD |
| GEN-2015-092 | 250.00 | ER | AEPW | Tap Lawton - Sunnyside (Terry Road) 345kV | Tap Lawton - Sunnyside (Terry Road) 345kV | 12/1/2017 | TBD |
| GEN-2015-093 | 250.00 | ER | OKGE | Gracemont 345kV | Gracemont 345kV | 12/1/2017 | TBD |
| GEN-2015-095 | 176.00 | ER | WFEC | Tap Rose Valley - Mooreland 138kV | Tap Rose Valley - Mooreland 138kV | 12/1/2017 | TBD |
| GEN-2015-096 | 150.00 | ER | WAPA | Tap Belfied - Rhame 230kV | Tap Belfied - Rhame 230kV | 12/31/2017 | TBD |
| GEN-2015-097 | 100.00 | ER | WAPA | Groton 115kV | Groton 115kV | 12/31/2016 | TBD |
| GEN-2015-098 | 100.00 | ER | WAPA | Mingusville 230kV | Mingusville 230kV | 12/15/2017 | TBD |
| Total: 7,340.90 | | | | | | | |

*In-Service Date for each request is to be determined after the Interconnection Facility Study is completed.

11.2 B: Prior Queued Interconnection Requests

See next page.

B: Prior Queued Interconnection Requests

| Request | Amount | Area | Requested/Proposed Point of Interconnection | Status or In-Service Date |
|----------------|---------------|-------------|--|----------------------------------|
| ASGI-2010-006 | 150.00 | AECI | Remington 138kV | AECI queue Affected Study |
| ASGI-2010-010 | 42.20 | SPS | Lovington 115kV | Lea County Affected Study |
| ASGI-2010-020 | 30.00 | SPS | Tap LE-Tatum - LE-Crossroads 69kV | Lea County Affected Study |
| ASGI-2010-021 | 15.00 | SPS | Tap LE-Saunders Tap - LE-Anderson 69kV | Lea County Affected Study |
| ASGI-2011-001 | 27.30 | SPS | Lovington 115kV | On-Line |
| ASGI-2011-002 | 20.00 | SPS | Herring 115kV | On-Line |
| ASGI-2011-003 | 10.00 | SPS | Hendricks 69kV | On-Line |
| ASGI-2011-004 | 20.00 | SPS | Pleasant Hill 69kV | Under Study (DISIS-2011-002) |
| ASGI-2012-002 | 18.15 | SPS | FE-Clovis Interchange 115kV | Under Study (DISIS-2012-002) |
| ASGI-2012-006 | 22.50 | SUNCMKEC | Tap Hugoton - Rolla 69kV | Under Study (DISIS-2012-001) |
| ASGI-2013-001 | 11.50 | SPS | PanTex South 115kV | Under Study (DISIS-2013-001) |
| ASGI-2013-002 | 18.40 | SPS | FE Tucumcari 115kV | Under Study (DISIS-2013-001) |
| ASGI-2013-003 | 18.40 | SPS | FE Clovis 115kV | Under Study (DISIS-2013-001) |
| ASGI-2013-004 | 36.60 | SUNCMKEC | Morris 115kV | Under Study (DISIS-2013-002) |
| ASGI-2013-005 | 1.65 | SPS | FE Clovis 115kV | Under Study (DISIS-2013-002) |
| ASGI-2013-006 | 2.00 | SPS | SP-Erskine 115kV | |
| ASGI-2014-001 | 2.50 | SPS | SP-Erskine 115kV | Under Study (DISIS-2014-001) |
| ASGI-2014-014 | 56.40 | GRDA | Ferguson 69kV | Under Study (DISIS-2014-002) |
| ASGI-2015-001 | 6.13 | SUNCMKEC | Ninnescah 115kV | Under Study (DISIS-2015-001) |
| ASGI-2015-002 | 2.00 | SPS | SP-Yuma 69kV | Under Study (DISIS-2015-001) |
| ASGI-2015-004 | 56.36 | GRDA | Coffeyville City 69kV | Under Study (DISIS-2015-001) |
| G176 | 100.00 | XEL | Yankee 115kV | |
| G255 | 100.00 | XEL | Yankee 115kV | MISO Queued Request |
| G359 | 150.00 | MDU | MDU 230 kV system near Ellendale | MISO Queued Request |
| G380 | 150.00 | OTP | Rugby 115kV | MISO Queued Request |
| G408 | 12.00 | XEL | Tap McHenry - Souris 115kV | MISO Queued Request |
| G502 | 50.60 | MP | Milton Young 230kV | MISO Queued Request |
| G586 | 30.00 | XEL | Yankee 115kV | |
| G645 | 50.00 | GRE | Ladish 115kV | MISO Queued Request |
| G723 | 10.00 | MDU | Haskett 115kV | MISO Queued Request |
| G736 | 200.00 | OTP | Big Stone South 230kV | |
| G752 | 150.00 | MDU | Tap Bison - Hettinger 230kV | MISO Queued Request |
| G788 | 49.00 | GRE | Ladish 115kV | MISO Queued Request |
| G830 | 99.00 | GRE | GRE McHenry 115kV | MISO Queued Request |
| GEN-2001-014 | 96.00 | WFEC | Ft Supply 138kV | On-Line |
| GEN-2001-026 | 74.30 | WFEC | Washita 138kV | On-Line |
| GEN-2001-033 | 180.00 | SPS | San Juan Tap 230kV | On-Line at 120MW |
| GEN-2001-036 | 80.00 | SPS | Norton 115kV | On-Line |
| GEN-2001-037 | 100.00 | OKGE | FPL Moreland Tap 138kV | On-Line |
| GEN-2001-039A | 105.00 | SUNCMKEC | Shooting Star Tap 115kV | On-Line |
| GEN-2001-039M | 100.00 | SUNCMKEC | Central Plains Tap 115kV | On-Line |
| GEN-2002-004 | 200.00 | WERE | Latham 345kV | On-Line at 150MW |
| GEN-2002-005 | 120.00 | WFEC | Red Hills Tap 138kV | On-Line |
| GEN-2002-008 | 240.00 | SPS | Hitchland 345kV | On-Line at 120MW |
| GEN-2002-008IS | 40.50 | WAPA | Edgeley 115kV [Pomona 115kV] | Commercial Operation |
| GEN-2002-009 | 80.00 | SPS | Hansford 115kV | On-Line |

| Request | Amount | Area | Requested/Proposed Point of Interconnection | Status or In-Service Date |
|------------------|--------|----------|---|---------------------------|
| GEN-2002-009IS | 40.00 | WAPA | Ft Thompson 69kV [Hyde 69kV] | Commercial Operation |
| GEN-2002-022 | 240.00 | SPS | Bushland 230kV | On-Line |
| GEN-2002-023N | 0.80 | NPPD | Harmony 115kV | On-Line |
| GEN-2002-025A | 150.00 | SUNCMKEC | Spearville 230kV | On-Line |
| GEN-2003-004 | 100.00 | WFEC | Washita 138kV | On-Line |
| GEN-2003-005 | 100.00 | WFEC | Anadarko - Paradise (Blue Canyon) 138kV | On-Line |
| GEN-2003-006A | 200.00 | SUNCMKEC | Elm Creek 230kV | On-Line |
| GEN-2003-019 | 250.00 | MIDW | Smoky Hills Tap 230kV | On-Line |
| GEN-2003-020 | 160.00 | SPS | Martin 115kV | On-Line |
| GEN-2003-021N | 75.00 | NPPD | Ainsworth Wind Tap 115kV | On-Line |
| GEN-2003-022 | 120.00 | AEPW | Weatherford 138kV | On-Line |
| GEN-2004-014 | 154.50 | SUNCMKEC | Spearville 230kV | On-Line at 100MW |
| GEN-2004-020 | 27.00 | AEPW | Weatherford 138kV | On-Line |
| GEN-2004-023 | 20.60 | WFEC | Washita 138kV | On-Line |
| GEN-2004-023N | 75.00 | NPPD | Columbus Co 115kV | On-Line |
| GEN-2005-003 | 30.60 | WFEC | Washita 138kV | On-Line |
| GEN-2005-003IS | 100.00 | WAPA | Nelson 115kV | Commercial Operation |
| GEN-2005-008 | 120.00 | OKGE | Woodward 138kV | On-Line |
| GEN-2005-008IS | 50.00 | WAPA | Hilken 230kV [Ecklund 230kV] | Commercial Operation |
| GEN-2005-012 | 250.00 | SUNCMKEC | Ironwood 345kV | On-Line at 160MW |
| GEN-2005-013 | 201.00 | WERE | Caney River 345kV | On-Line |
| GEN-2006-001IS | 10.00 | XEL | Marshall 115kV | Commercial Operation |
| GEN-2006-002 | 101.00 | AEPW | Sweetwater 230kV | On-Line |
| GEN-2006-002IS | 51.00 | WAPA | Wessington Springs 230kV | Commercial Operation |
| GEN-2006-006IS | 10.00 | XEL | Marshall 115kV | Commercial Operation |
| GEN-2006-015IS | 50.00 | WAPA | Hilken 230kV [Ecklund 230kV] | Commercial Operation |
| GEN-2006-018 | 170.00 | SPS | TUCO Interchange 230kV | On-Line |
| GEN-2006-020N | 42.00 | NPPD | Bloomfield 115kV | On-Line |
| GEN-2006-020S | 18.90 | SPS | DWS Frisco 115kV | On-Line |
| GEN-2006-021 | 101.00 | SUNCMKEC | Flat Ridge Tap 138kV | On-Line |
| GEN-2006-024S | 19.80 | WFEC | Buffalo Bear Tap 69kV | On-Line |
| GEN-2006-026 | 502.00 | SPS | Hobbs 230kV & Hobbs 115kV | On-Line |
| GEN-2006-031 | 75.00 | MIDW | Knoll 115kV | On-Line |
| GEN-2006-035 | 225.00 | AEPW | Sweetwater 230kV | On-Line at 132MW |
| GEN-2006-037N1 | 75.00 | NPPD | Broken Bow 115kV | On-Line |
| GEN-2006-038N005 | 80.00 | NPPD | Broken Bow 115kV | On-Line |
| GEN-2006-038N019 | 80.00 | NPPD | Petersburg North 115kV | On-Line |
| GEN-2006-043 | 99.00 | AEPW | Sweetwater 230kV | On-Line |
| GEN-2006-044 | 370.00 | SPS | Hitchland 345kV | On-Line at 120MW |
| GEN-2006-044N | 40.50 | NPPD | North Petersburg 115kV | On-Line |
| GEN-2006-046 | 131.00 | OKGE | Dewey 138kV | On-Line |
| GEN-2007-011N08 | 81.00 | NPPD | Bloomfield 115kV | On-Line |
| GEN-2007-013IS | 50.00 | WAPA | Wessington Springs 230kV | Commercial Operation |
| GEN-2007-014IS | 100.00 | WAPA | Wessington Springs 230kV | Commercial Operation |
| GEN-2007-015IS | 100.00 | WAPA | Hilken 230kV [Ecklund 230kV] | Commercial Operation |
| GEN-2007-017IS | 166.00 | WAPA | Ft Thompson-Grand Island 345kV | On Schedule |
| GEN-2007-018IS | 234.00 | WAPA | Ft Thompson-Grand Island 345kV | On Schedule |
| GEN-2007-020IS | 16.00 | WAPA | Nelson 115kV | Commercial Operation |
| GEN-2007-021 | 201.00 | OKGE | Tatonga 345kV | On-Line |
| GEN-2007-023IS | 50.00 | WAPA | Formit-Summit 115kV | On Suspension |

| Request | Amount | Area | Requested/Proposed Point of Interconnection | Status or In-Service Date |
|-----------------|--------|----------|---|-------------------------------|
| GEN-2007-025 | 300.00 | WERE | Viola 345kV | On-Line |
| GEN-2007-027IS | 99.00 | WAPA | Bismarck-Garrison 230kV #1 | On Suspension |
| GEN-2007-040 | 200.00 | SUNCMKEC | Buckner 345kV | On-Line at 132MW |
| GEN-2007-043 | 200.00 | OKGE | Minco 345kV | On-Line |
| GEN-2007-044 | 300.00 | OKGE | Tatonga 345kV | On-Line at 199MW |
| GEN-2007-046 | 200.00 | SPS | Hitchland 115kV | On-Line |
| GEN-2007-050 | 170.00 | OKGE | Woodward EHV 138kV | On-Line at 150MW |
| GEN-2007-052 | 150.00 | WFEC | Anadarko 138kV | On-Line |
| GEN-2007-062 | 765.00 | OKGE | Woodward EHV 345kV | On Schedule for 2016 and 2017 |
| GEN-2008-003 | 101.00 | OKGE | Woodward EHV 138kV | On-Line |
| GEN-2008-008IS | 5.00 | WAPA | Nelson 115kV | Commercial Operation |
| GEN-2008-013 | 300.00 | OKGE | Hunter 345kV | On-Line at 235MW |
| GEN-2008-018 | 250.00 | SPS | Finney 345kV | On-Line |
| GEN-2008-021 | 42.00 | WERE | Wolf Creek 345kV | On-Line |
| GEN-2008-022 | 300.00 | SPS | Crossroads 345kV | On-Line |
| GEN-2008-023 | 150.00 | AEPW | Hobart Junction 138kV | On-Line |
| GEN-2008-037 | 101.00 | WFEC | Slick Hills 138kV | On-Line |
| GEN-2008-044 | 197.80 | OKGE | Tatonga 345kV | On-Line |
| GEN-2008-047 | 300.00 | OKGE | Beaver County 345kV | On-Line |
| GEN-2008-051 | 322.00 | SPS | Potter County 345kV | On-Line at 161MW |
| GEN-2008-079 | 99.20 | SUNCMKEC | Crooked Creek 115kV | On-Line |
| GEN-2008-086N02 | 201.00 | NPPD | Meadow Grove 230kV | On-Line |
| GEN-2008-092 | 200.60 | MIDW | Post Rock 230kV | On-Line |
| GEN-2008-098 | 100.80 | WERE | Waverly 345kV | On-Line |
| GEN-2008-119O | 60.00 | OPPD | S1399 161kV | On-Line |
| GEN-2008-123N | 89.70 | NPPD | Tap Pauline - Hildreth (Rosemont) 115kV | On Schedule for 2016 |
| GEN-2008-124 | 200.10 | SUNCMKEC | Ironwood 345kV | On Schedule for 2016 |
| GEN-2008-129 | 80.00 | KCPL | Pleasant Hill 161kV | On-Line |
| GEN-2009-001IS | 200.00 | WAPA | Groton-Watertown 345kV | On Schedule |
| GEN-2009-006IS | 90.00 | WAPA | Mission 115kV | On Suspension |
| GEN-2009-007IS | 100.00 | WAPA | Mission 115kV | On Suspension |
| GEN-2009-008 | 199.50 | MIDW | South Hays 230kV | On-Line |
| GEN-2009-018IS | 100.00 | WAPA | Groton 115kV | Commercial Operation |
| GEN-2009-020 | 48.30 | MIDW | Walnut Creek 69kV | On-Line |
| GEN-2009-020AIS | 130.50 | WAPA | Tripp Junction 115kV | Commercial Operation |
| GEN-2009-025 | 59.80 | OKGE | Nardins 69kV | On-Line |
| GEN-2009-026IS | 110.00 | WAPA | Dickenson-Heskett 230kV | On Schedule |
| GEN-2009-040 | 73.80 | WERE | Marshall 115kV | On Schedule for 2016 |
| GEN-2010-001 | 300.00 | OKGE | Beaver County 345kV | On-Line |
| GEN-2010-001IS | 99.00 | WAPA | Bismarck-Glenham 230kV | On Schedule |
| GEN-2010-003 | 100.80 | WERE | Waverly 345kV | On-Line |
| GEN-2010-003IS | 34.00 | WAPA | Wessington Springs 230kV | Commercial Operation |
| GEN-2010-005 | 299.20 | WERE | Viola 345kV | On-Line at 170MW |
| GEN-2010-006 | 205.00 | SPS | Jones 230kV | On-Line |
| GEN-2010-007IS | 172.50 | WAPA | Antelope Valley 345kV | On Suspension |
| GEN-2010-009 | 165.60 | SUNCMKEC | Buckner 345kV | On-Line |
| GEN-2010-011 | 29.70 | OKGE | Tatonga 345kV | On-Line |
| GEN-2010-014 | 358.80 | SPS | Hitchland 345kV | On Schedule for 2018 |
| GEN-2010-036 | 4.60 | WERE | 6th Street 115kV | On-Line |
| GEN-2010-040 | 300.00 | OKGE | Cimarron 345kV | On-Line |

| Request | Amount | Area | Requested/Proposed Point of Interconnection | Status or In-Service Date |
|----------------|--------|----------|---|---|
| GEN-2010-041 | 10.50 | OPPD | S1399 161kV | On Schedule for 2015 |
| GEN-2010-045 | 197.80 | SUNCMKEC | Buckner 345kV | On Schedule for 2017 |
| GEN-2010-046 | 56.00 | SPS | TUCO Interchange 230kV | On Schedule for 2016 |
| GEN-2010-048 | 70.00 | MIDW | Tap Beach Station - Redline 115kV | FACILITY STUDY STAGE |
| GEN-2010-051 | 200.00 | NPPD | Tap Hoskins - Twin Church (Dixon County) 230kV | On Suspension |
| GEN-2010-055 | 4.50 | AEPW | Wekiwa 138kV | On-Line |
| GEN-2010-057 | 201.00 | MIDW | Rice County 230kV | On-Line |
| GEN-2011-008 | 600.00 | SUNCMKEC | Clark County 345kV | On Schedule for 2016 |
| GEN-2011-010 | 100.80 | OKGE | Minco 345kV | On-Line |
| GEN-2011-011 | 50.00 | KCPL | Iatan 345kV | On-Line |
| GEN-2011-014 | 201.00 | OKGE | Tap Hitchland - Woodward Dbl Ckt (GEN-2011-014 Tap) 345kV | On Schedule for 2016 |
| GEN-2011-016 | 200.10 | SUNCMKEC | Ironwood 345kV | On Suspension |
| GEN-2011-018 | 73.60 | NPPD | Steele City 115kV | On-Line |
| GEN-2011-019 | 299.00 | OKGE | Woodward 345kV | On Schedule for 2017 |
| GEN-2011-020 | 299.00 | OKGE | Woodward 345kV | On Schedule for 2017 |
| GEN-2011-022 | 299.00 | SPS | Hitchland 345kV | On Schedule for 2016 (150MW) and 2017 (149MW) |
| GEN-2011-025 | 80.00 | SPS | Tap Floyd County - Crosby County 115kV | On Schedule for 2016 |
| GEN-2011-027 | 120.00 | NPPD | Tap Hoskins - Twin Church (Dixon County) 230kV | On Suspension |
| GEN-2011-037 | 7.00 | WFEC | Blue Canyon 5 138kV | On-Line |
| GEN-2011-040 | 111.00 | OKGE | Carter County 138kV | On-Line |
| GEN-2011-045 | 205.00 | SPS | Jones 230kV | On-Line |
| GEN-2011-046 | 27.00 | SPS | Lopez 115kV | On-Line |
| GEN-2011-048 | 175.00 | SPS | Mustang 230kV | On-Line |
| GEN-2011-049 | 250.70 | OKGE | Border 345kV | On Schedule for 2016 |
| GEN-2011-050 | 109.80 | AEPW | Santa Fe Tap 138kV | On Schedule for 2016 |
| GEN-2011-051 | 104.40 | OKGE | Tap Woodward - Tatonga 345kV (GEN-2011-051 Tap) | On Schedule for 2017 |
| GEN-2011-054 | 300.00 | OKGE | Cimarron 345kV | On-Line |
| GEN-2011-056 | 3.60 | NPPD | Jeffrey 115kV | On-Line |
| GEN-2011-056A | 3.60 | NPPD | John 1 115kV | On-Line |
| GEN-2011-056B | 4.50 | NPPD | John 2 115kV | On-Line |
| GEN-2011-057 | 150.40 | WERE | Creswell 138kV | On-Line |
| GEN-2012-001 | 61.20 | SPS | Cirrus Tap 230kV | On-Line |
| GEN-2012-004 | 41.40 | OKGE | Carter County 138kV | On-Line |
| GEN-2012-006IS | 125.01 | WAPA | Williston-Ch. Creek 230kV | On Schedule |
| GEN-2012-007 | 120.00 | SUNCMKEC | Rubart 115kV | On-Line |
| GEN-2012-009IS | 99.00 | WAPA | Fort Randall 115kV | On Suspension |
| GEN-2012-012IS | 75.00 | WAPA | Wolf Point-Circle 115kV | On Suspension |
| GEN-2012-014IS | 99.50 | WAPA | Groton 115kV | On Schedule |
| GEN-2012-020 | 478.00 | SPS | TUCO 230kV | On Schedule for 2016 |
| GEN-2012-021 | 4.80 | LES | Terry Bundy Generating Station 115kV | On-Line |
| GEN-2012-024 | 180.00 | SUNCMKEC | Clark County 345kV | On Schedule for 2016 |
| GEN-2012-028 | 74.80 | WFEC | Gotebo 69kV | On-Line |
| GEN-2012-032 | 300.00 | OKGE | Open Sky 345kV | On-Line |
| GEN-2012-033 | 98.10 | OKGE | Tap and Tie South 4th - Bunch Creek & Enid Tap - Fairmont (GEN-2012-033T) 138kV | On-Line |
| GEN-2012-034 | 7.00 | SPS | Mustang 230kV | On-Line |
| GEN-2012-035 | 7.00 | SPS | Mustang 230kV | On-Line |
| GEN-2012-036 | 7.00 | SPS | Mustang 230kV | On-Line |
| GEN-2012-037 | 203.00 | SPS | TUCO 345kV | On-Line |

| Request | Amount | Area | Requested/Proposed Point of Interconnection | Status or In-Service Date |
|----------------|--------|----------|---|---|
| GEN-2012-041 | 121.50 | OKGE | Ranch Road 345kV | On-Line |
| GEN-2013-001IS | 90.00 | WAPA | Summit-Watertown 115kV | On Suspension |
| GEN-2013-002 | 50.60 | LES | Tap Sheldon - Folsom & Pleasant Hill (GEN-2013-002 Tap) 115kV CKT 2 | On Schedule for 2016 |
| GEN-2013-007 | 100.30 | OKGE | Tap Prices Falls - Carter 138kV | On-Line |
| GEN-2013-008 | 1.20 | NPPD | Steele City 115kV | On-Line |
| GEN-2013-009IS | 19.50 | WAPA | Redfield NW 115kV | Commercial Operation |
| GEN-2013-010 | 99.00 | SUNCMKEC | Tap Spearville - Post Rock (North of GEN-2011-017 Tap) 345kV | On Schedule for 2018 |
| GEN-2013-011 | 30.00 | AEPW | Turk 138kV | On-Line |
| GEN-2013-012 | 147.00 | OKGE | Redbud 345kV | On-Line |
| GEN-2013-016 | 203.00 | SPS | TUCO 345kV | On Schedule for 2017 |
| GEN-2013-019 | 73.60 | LES | Tap Sheldon - Folsom & Pleasant Hill (GEN-2013-002 Tap) 115kV CKT 2 | On Schedule for 2016 |
| GEN-2013-022 | 25.00 | SPS | Norton 115kV | On Schedule for 2016 |
| GEN-2013-027 | 150.00 | SPS | Tap Tolk - Yoakum 230kV | IA Pending |
| GEN-2013-028 | 559.50 | GRDA | Tap N Tulsa - GRDA 1 345kV | On Schedule for 2017 |
| GEN-2013-029 | 300.00 | OKGE | Renfrow 345kV | On-Line for 151.6MW |
| GEN-2013-030 | 300.00 | OKGE | Beaver County 345kV | On Schedule for 2016 (200MW) and 2017 (100MW) |
| GEN-2013-032 | 204.00 | NPPD | Antelope 115kV | On Schedule for 2017 |
| GEN-2013-033 | 28.00 | MIDW | Knoll 115kV | On Schedule for 2016 |
| GEN-2014-001 | 200.60 | WERE | Tap Wichita - Emporia Energy Center (GEN-2014-001 Tap) 345kV | On Suspension |
| GEN-2014-001IS | 103.70 | WAPA | Newell-Maurine 115kV | FACILITY STUDY STAGE |
| GEN-2014-002 | 10.50 | OKGE | Tatonga 345kV (GEN-2007-021 POI) | On Schedule for 2015 |
| GEN-2014-003 | 15.80 | OKGE | Tatonga 345kV (GEN-2007-044 POI) | On Schedule for 2015 |
| GEN-2014-003IS | 91.00 | WAPA | Culbertson 115kV | On Schedule |
| GEN-2014-004 | 4.00 | NPPD | Steele City 115kV (GEN-2011-018 POI) | On-Line |
| GEN-2014-004IS | 384.20 | WAPA | Charlie Creek 345kV | FACILITY STUDY STAGE |
| GEN-2014-005 | 5.70 | OKGE | Minco 345kV (GEN-2011-010 POI) | On-Line |
| GEN-2014-006IS | 125.00 | WAPA | Williston 115kV | On Schedule |
| GEN-2014-010IS | 150.00 | WAPA | Neset 115kV | On Schedule |
| GEN-2014-012 | 225.00 | SPS | Tap Hobbs Interchange - Andrews 230kV | On Schedule for 2018 |
| GEN-2014-013 | 73.50 | NPPD | Meadow Grove (GEN-2008-086N2 Sub) 230kV | On-Line |
| GEN-2014-014IS | 151.50 | WAPA | Belfield-Rhame 230kV | On Schedule |
| GEN-2014-020 | 100.00 | AEPW | Tuttle 138kV | On Schedule for 2017 |
| GEN-2014-021 | 300.00 | KCPL | Tap Nebraska City - Mullin Creek 345kV | On Schedule for 2016 |
| GEN-2014-025 | 2.40 | MIDW | Walnut Creek 69kV | On-Line |
| GEN-2014-028 | 35.00 | EMDE | Riverton 161kV | On Schedule for 2016 |
| GEN-2014-031 | 35.80 | NPPD | Meadow Grove 230kV | On-Line |
| GEN-2014-032 | 10.20 | NPPD | Meadow Grove 230kV | On Schedule for 2016 |
| GEN-2014-033 | 70.00 | SPS | Chaves County 115kV | On Schedule for 2016 |
| GEN-2014-034 | 70.00 | SPS | Chaves County 115kV | On Schedule for 2016 |
| GEN-2014-035 | 30.00 | SPS | Chaves County 115kV | On Schedule for 2018 |
| GEN-2014-039 | 73.40 | NPPD | Friend 115kV | On Schedule for 2017 |
| GEN-2014-040 | 320.40 | SPS | Castro 115kV | On Schedule for 2016 |
| GEN-2014-041 | 120.80 | SUNCMKEC | Arnold 115kV | On Suspension |
| GEN-2014-047 | 40.00 | SPS | Crossroads 345kV | IA Pending |
| GEN-2014-056 | 250.00 | OKGE | Minco 345kV | On Schedule for 2016 |
| GEN-2014-057 | 250.00 | AEPW | Tap Lawton - Sunnyside (Terry Road) 345kV | On Schedule for 2016 |

| Request | Amount | Area | Requested/Proposed Point of Interconnection | Status or In-Service Date |
|---|--------|----------|---|-------------------------------------|
| GEN-2014-064 | 248.40 | OKGE | Otter 138kV | On Suspension |
| GEN-2014-074 | 152.00 | SPS | Tap TUCO Interchange - Oklaunion (GEN-2014-074 Tap) 345kV | FACILITY STUDY STAGE |
| GEN-2015-001 | 200.00 | OKGE | Ranch Road 345kV | On Schedule for 2016 |
| GEN-2015-004 | 52.90 | OKGE | Border 345kV | IA Pending |
| GEN-2015-005 | 200.10 | KCPL | Tap Nebraska City - Sibley 345kV | FACILITY STUDY STAGE |
| GEN-2015-007 | 160.00 | NPPD | Hoskins 345kV | FACILITY STUDY STAGE |
| GEN-2015-013 | 120.00 | WFEC | Synder 138kV | FACILITY STUDY STAGE |
| GEN-2015-014 | 150.00 | SPS | Tap Cochran - Lehman 115kV | FACILITY STUDY STAGE |
| GEN-2015-015 | 154.60 | OKGE | Tap Medford Tap - Coyote 138kV | FACILITY STUDY STAGE |
| GEN-2015-016 | 200.00 | KCPL | Tap Marmaton - Centerville 161kV | FACILITY STUDY STAGE |
| GEN-2015-021 | 20.00 | SUNCMKEC | Johnson Corner 115kV | FACILITY STUDY STAGE |
| GEN-2015-022 | 112.00 | SPS | Swisher 115kV | FACILITY STUDY STAGE |
| GEN-2015-023 | 300.70 | NPPD | Holt County 345kV | FACILITY STUDY STAGE |
| GEN-2015-024 | 220.00 | WERE | Tap Thistle - Wichita 345kV Dbl CKT | On Schedule for 2016 |
| GEN-2015-025 | 220.00 | WERE | Tap Thistle - Wichita 345kV Dbl CKT | FACILITY STUDY STAGE |
| GEN-2015-027 | 4.90 | SUNCMKEC | Crooked Creek 115kV | FACILITY STUDY STAGE |
| GEN-2015-029 | 161.00 | OKGE | Tatonga 345kV | IA Pending |
| GEN-2015-030 | 200.10 | OKGE | Sooner 345kV | IA Pending |
| Gray County Wind (Montezuma) | 110.00 | SUNCMKEC | Gray County Tap 115kV | On-Line |
| J003 | 20.00 | MDU | Baker 115kV | MISO Queued Request |
| J249 | 180.00 | MDU | MDU Tatanka 230kV | MISO Queued Request |
| J262 | 100.00 | OTP | Jamestown 345 | MISO Queued Request |
| J263 | 100.00 | OTP | Jamestown 345 | MISO Queued Request |
| J290 | 150.00 | XEL | Tap Glenboro South - Rugby 230kV | MISO Queued Request |
| J316 | 150.00 | MDU | MDU 230 kV Tatanka-Ellendale line | MISO Queued Request |
| J436 | 150.00 | OTP | Big Stone South 345kV | MISO Queued Request |
| J437 | 150.00 | OTP | Big Stone South 345kV | MISO Queued Request |
| J442 | 200.00 | OTP | Big Stone 230 kV | MISO Queued Request |
| Llano Estacado (White Deer) | 80.00 | SPS | Llano Wind 115kV | On-Line |
| MPC01200 | 98.90 | OTP | Maple River 230kV | On-line (54.9MW)/ IA Pending (44MW) |
| MPC02100 | 99.3 | OTP | Center- Mandan 230kV | On Schedule for 2016 |
| NPPD Distributed (Broken Bow) | 8.30 | NPPD | Broken Bow 115kV | On-Line |
| NPPD Distributed (Buffalo County Solar) | 10.00 | NPPD | Kearney Northeast | On-Line |
| NPPD Distributed (Burt County Wind) | 12.00 | NPPD | Tekamah & Oakland 115kV | On-Line |
| NPPD Distributed (Burwell) | 3.00 | NPPD | Ord 115kV | On-Line |
| NPPD Distributed (Columbus Hydro) | 45.00 | NPPD | Columbus 115kV | On-Line |
| NPPD Distributed (North Platte - Lexington) | 54.00 | NPPD | Multiple: Jeffrey 115kV, John_1 115kV, John_2 115kV | On-Line |
| NPPD Distributed (Ord) | 11.90 | NPPD | Ord 115kV | On-Line |
| NPPD Distributed (Stuart) | 2.10 | NPPD | Ainsworth 115kV | On-Line |
| SPS Distributed (Dumas 19th St) | 20.00 | SPS | Dumas 19th Street 115kV | On-Line |
| SPS Distributed (Etter) | 20.00 | SPS | Etter 115kV | On-Line |
| SPS Distributed (Hopi) | 10.00 | SPS | Hopi 115kV | On-Line |
| SPS Distributed (Jal) | 10.00 | SPS | S Jal 115kV | On-Line |
| SPS Distributed (Lea Road) | 10.00 | SPS | Lea Road 115kV | On-Line |
| SPS Distributed (Monument) | 10.00 | SPS | Monument 115kV | On-Line |
| SPS Distributed (Moore E) | 25.00 | SPS | Moore East 115kV | On-Line |
| SPS Distributed (Ocotillo) | 10.00 | SPS | S_Jal 115kV | On-Line |
| SPS Distributed (Sherman) | 20.00 | SPS | Sherman 115kV | On-Line |

| Request | Amount | Area | Requested/Proposed Point of Interconnection | Status or In-Service Date |
|-----------------------------------|-----------------|------|---|---------------------------|
| SPS Distributed (Spearman) | 10.00 | SPS | Spearman 69kV | On-Line |
| SPS Distributed (TC-Texas County) | 20.00 | SPS | Texas County 115kV | On-Line |
| SPS Distributed (Yuma) | 2.57 | SPS | SP-Yuma 69kV | On-Line |
| Total: | 34,482.9 | | | |

11.3 C: Study Groupings

See next page

C. Study Groups

| GROUP 1: WOODWARD AREA | | | |
|---------------------------------|-----------------|-------------|---|
| Request | Capacity | Area | Proposed Point of Interconnection |
| GEN-2001-014 | 96.00 | WFEC | Ft Supply 138kV |
| GEN-2001-037 | 100.00 | OKGE | FPL Moreland Tap 138kV |
| GEN-2005-008 | 120.00 | OKGE | Woodward 138kV |
| GEN-2006-024S | 19.80 | WFEC | Buffalo Bear Tap 69kV |
| GEN-2006-046 | 131.00 | OKGE | Dewey 138kV |
| GEN-2007-021 | 201.00 | OKGE | Tatonga 345kV |
| GEN-2007-043 | 200.00 | OKGE | Minco 345kV |
| GEN-2007-044 | 300.00 | OKGE | Tatonga 345kV |
| GEN-2007-050 | 170.00 | OKGE | Woodward EHV 138kV |
| GEN-2007-062 | 765.00 | OKGE | Woodward EHV 345kV |
| GEN-2008-003 | 101.00 | OKGE | Woodward EHV 138kV |
| GEN-2008-044 | 197.80 | OKGE | Tatonga 345kV |
| GEN-2010-011 | 29.70 | OKGE | Tatonga 345kV |
| GEN-2010-040 | 300.00 | OKGE | Cimarron 345kV |
| GEN-2011-010 | 100.80 | OKGE | Minco 345kV |
| GEN-2011-019 | 299.00 | OKGE | Woodward 345kV |
| GEN-2011-020 | 299.00 | OKGE | Woodward 345kV |
| GEN-2011-051 | 104.40 | OKGE | Tap Woodward - Tatonga 345kV (GEN-2011-051 Tap) |
| GEN-2011-054 | 300.00 | OKGE | Cimarron 345kV |
| GEN-2014-002 | 10.50 | OKGE | Tatonga 345kV (GEN-2007-021 POI) |
| GEN-2014-003 | 15.80 | OKGE | Tatonga 345kV (GEN-2007-044 POI) |
| GEN-2014-005 | 5.70 | OKGE | Minco 345kV (GEN-2011-010 POI) |
| GEN-2014-020 | 100.00 | AEPW | Tuttle 138kV |
| GEN-2014-056 | 250.00 | OKGE | Minco 345kV |
| GEN-2015-029 | 161.00 | OKGE | Tatonga 345kV |
| PRIOR QUEUED SUBTOTAL | 4,377.50 | | |
| GEN-2015-048 | 200.00 | OKGE | Cleo Corner 138kV |
| GEN-2015-057 | 100.00 | OKGE | Minco 345kV |
| GEN-2015-059 | 6.30 | OKGE | Minco 345kV |
| GEN-2015-060 | 250.50 | OKGE | Woodward EHV 138kV |
| GEN-2015-081 | 180.00 | OKGE | Tap Woodward - Tatonga (GEN-2011-051 Tap) 345kV |
| GEN-2015-093 | 250.00 | OKGE | Gracemont 345kV |
| GEN-2015-095 | 176.00 | WFEC | Tap Rose Valley - Mooreland 138kV |
| CURRENT CLUSTER SUBTOTAL | 1,162.80 | | |
| AREA TOTAL | 5,540.30 | | |

| GROUP 2: HITCHLAND AREA | | | |
|-----------------------------------|-----------------|-------------|---|
| Request | Capacity | Area | Proposed Point of Interconnection |
| ASGI-2011-002 | 20.00 | SPS | Herring 115kV |
| ASGI-2013-001 | 11.50 | SPS | PanTex South 115kV |
| GEN-2002-008 | 240.00 | SPS | Hitchland 345kV |
| GEN-2002-009 | 80.00 | SPS | Hansford 115kV |
| GEN-2002-022 | 240.00 | SPS | Bushland 230kV |
| GEN-2003-020 | 160.00 | SPS | Martin 115kV |
| GEN-2006-020S | 18.90 | SPS | DWS Frisco 115kV |
| GEN-2006-044 | 370.00 | SPS | Hitchland 345kV |
| GEN-2007-046 | 200.00 | SPS | Hitchland 115kV |
| GEN-2008-047 | 300.00 | OKGE | Beaver County 345kV |
| GEN-2008-051 | 322.00 | SPS | Potter County 345kV |
| GEN-2010-001 | 300.00 | OKGE | Beaver County 345kV |
| GEN-2010-014 | 358.80 | SPS | Hitchland 345kV |
| GEN-2011-014 | 201.00 | OKGE | Tap Hitchland - Woodward Dbl Ckt (GEN-2011-014 Tap) 345kV |
| GEN-2011-022 | 299.00 | SPS | Hitchland 345kV |
| GEN-2013-030 | 300.00 | OKGE | Beaver County 345kV |
| Llano Estacado (White Deer) | 80.00 | SPS | Llano Wind 115kV |
| SPS Distributed (Dumas 19th St) | 20.00 | SPS | Dumas 19th Street 115kV |
| SPS Distributed (Etter) | 20.00 | SPS | Etter 115kV |
| SPS Distributed (Moore E) | 25.00 | SPS | Moore East 115kV |
| SPS Distributed (Sherman) | 20.00 | SPS | Sherman 115kV |
| SPS Distributed (Spearman) | 10.00 | SPS | Spearman 69kV |
| SPS Distributed (TC-Texas County) | 20.00 | SPS | Texas County 115kV |
| PRIOR QUEUED SUBTOTAL | 3,616.20 | | |
| GEN-2014-037 | 200.00 | SPS | Tap Hitchland - Beaver County Dbl Ckt (Optima) 345kV |
| CURRENT CLUSTER SUBTOTAL | 200.00 | | |
| AREA TOTAL | 3,816.20 | | |

| GROUP 3: SPEARVILLE AREA | | | |
|---------------------------------|-----------------|-------------|--|
| Request | Capacity | Area | Proposed Point of Interconnection |
| ASGI-2012-006 | 22.50 | SUNCMKEC | Tap Hugoton - Rolla 69kV |
| ASGI-2015-001 | 6.13 | SUNCMKEC | Ninnescah 115kV |
| GEN-2001-039A | 105.00 | SUNCMKEC | Shooting Star Tap 115kV |
| GEN-2002-025A | 150.00 | SUNCMKEC | Spearville 230kV |
| GEN-2004-014 | 154.50 | SUNCMKEC | Spearville 230kV |
| GEN-2005-012 | 250.00 | SUNCMKEC | Ironwood 345kV |
| GEN-2006-021 | 101.00 | SUNCMKEC | Flat Ridge Tap 138kV |
| GEN-2007-040 | 200.00 | SUNCMKEC | Buckner 345kV |
| GEN-2008-018 | 250.00 | SPS | Finney 345kV |
| GEN-2008-079 | 99.20 | SUNCMKEC | Crooked Creek 115kV |
| GEN-2008-124 | 200.10 | SUNCMKEC | Ironwood 345kV |
| GEN-2010-009 | 165.60 | SUNCMKEC | Buckner 345kV |
| GEN-2010-045 | 197.80 | SUNCMKEC | Buckner 345kV |
| GEN-2011-008 | 600.00 | SUNCMKEC | Clark County 345kV |
| GEN-2011-016 | 200.10 | SUNCMKEC | Ironwood 345kV |
| GEN-2012-007 | 120.00 | SUNCMKEC | Rubart 115kV |
| GEN-2012-024 | 180.00 | SUNCMKEC | Clark County 345kV |
| GEN-2013-010 | 99.00 | SUNCMKEC | Tap Spearville - Post Rock (North of GEN-2011-017 Tap) 345kV |
| GEN-2015-021 | 20.00 | SUNCMKEC | Johnson Corner 115kV |
| GEN-2015-027 | 4.90 | SUNCMKEC | Crooked Creek 115kV |
| Gray County Wind (Montezuma) | 110.00 | SUNCMKEC | Gray County Tap 115kV |
| PRIOR QUEUED SUBTOTAL | 3,235.83 | | |
| AREA TOTAL | 3,235.83 | | |

| GROUP 4: NORTHWEST KANSAS AREA | | | |
|---------------------------------------|-----------------|-------------|--|
| Request | Capacity | Area | Proposed Point of Interconnection |
| ASGI-2013-004 | 36.60 | SUNCMKEC | Morris 115kV |
| GEN-2001-039M | 100.00 | SUNCMKEC | Central Plains Tap 115kV |
| GEN-2003-006A | 200.00 | SUNCMKEC | Elm Creek 230kV |
| GEN-2003-019 | 250.00 | MIDW | Smoky Hills Tap 230kV |
| GEN-2006-031 | 75.00 | MIDW | Knoll 115kV |
| GEN-2008-092 | 200.60 | MIDW | Post Rock 230kV |
| GEN-2009-008 | 199.50 | MIDW | South Hays 230kV |
| GEN-2009-020 | 48.30 | MIDW | Walnut Creek 69kV |
| GEN-2010-048 | 70.00 | MIDW | Tap Beach Station - Redline 115kV |
| GEN-2010-057 | 201.00 | MIDW | Rice County 230kV |
| GEN-2013-033 | 28.00 | MIDW | Knoll 115kV |
| GEN-2014-025 | 2.40 | MIDW | Walnut Creek 69kV |
| GEN-2014-041 | 120.80 | SUNCMKEC | Arnold 115kV |
| PRIOR QUEUED SUBTOTAL | 1,532.20 | | |
| GEN-2015-061 | 200.00 | SUNCMKEC | Mingo 345kV |
| GEN-2015-064 | 197.80 | SUNCMKEC | Mingo 115kV |
| GEN-2015-065 | 202.40 | SUNCMKEC | Mingo 345kV |
| CURRENT CLUSTER SUBTOTAL | 600.20 | | |
| AREA TOTAL | 2,132.40 | | |

GROUP 6: SOUTH TEXAS PANHANDLE/NEW MEXICO AREA

| Request | Capacity | Area | Proposed Point of Interconnection |
|------------------------------|-----------------|------|---|
| ASGI-2010-010 | 42.20 | SPS | Lovington 115kV |
| ASGI-2010-020 | 30.00 | SPS | Tap LE-Tatum - LE-Crossroads 69kV |
| ASGI-2010-021 | 15.00 | SPS | Tap LE-Saunders Tap - LE-Anderson 69kV |
| ASGI-2011-001 | 27.30 | SPS | Lovington 115kV |
| ASGI-2011-003 | 10.00 | SPS | Hendricks 69kV |
| ASGI-2011-004 | 20.00 | SPS | Pleasant Hill 69kV |
| ASGI-2012-002 | 18.15 | SPS | FE-Clovis Interchange 115kV |
| ASGI-2013-002 | 18.40 | SPS | FE Tucumcari 115kV |
| ASGI-2013-003 | 18.40 | SPS | FE Clovis 115kV |
| ASGI-2013-005 | 1.65 | SPS | FE Clovis 115kV |
| ASGI-2013-006 | 2.00 | SPS | SP-Erskine 115kV |
| ASGI-2014-001 | 2.50 | SPS | SP-Erskine 115kV |
| ASGI-2015-002 | 2.00 | SPS | SP-Yuma 69kV |
| GEN-2001-033 | 180.00 | SPS | San Juan Tap 230kV |
| GEN-2001-036 | 80.00 | SPS | Norton 115kV |
| GEN-2006-018 | 170.00 | SPS | TUCO Interchange 230kV |
| GEN-2006-026 | 502.00 | SPS | Hobbs 230kV & Hobbs 115kV |
| GEN-2008-022 | 300.00 | SPS | Crossroads 345kV |
| GEN-2010-006 | 205.00 | SPS | Jones 230kV |
| GEN-2010-046 | 56.00 | SPS | TUCO Interchange 230kV |
| GEN-2011-025 | 80.00 | SPS | Tap Floyd County - Crosby County 115kV |
| GEN-2011-045 | 205.00 | SPS | Jones 230kV |
| GEN-2011-046 | 27.00 | SPS | Lopez 115kV |
| GEN-2011-048 | 175.00 | SPS | Mustang 230kV |
| GEN-2012-001 | 61.20 | SPS | Cirrus Tap 230kV |
| GEN-2012-020 | 478.00 | SPS | TUCO 230kV |
| GEN-2012-034 | 7.00 | SPS | Mustang 230kV |
| GEN-2012-035 | 7.00 | SPS | Mustang 230kV |
| GEN-2012-036 | 7.00 | SPS | Mustang 230kV |
| GEN-2012-037 | 203.00 | SPS | TUCO 345kV |
| GEN-2013-016 | 203.00 | SPS | TUCO 345kV |
| GEN-2013-022 | 25.00 | SPS | Norton 115kV |
| GEN-2013-027 | 150.00 | SPS | Tap Tolk - Yoakum 230kV |
| GEN-2014-012 | 225.00 | SPS | Tap Hobbs Interchange - Andrews 230kV |
| GEN-2014-033 | 70.00 | SPS | Chaves County 115kV |
| GEN-2014-034 | 70.00 | SPS | Chaves County 115kV |
| GEN-2014-035 | 30.00 | SPS | Chaves County 115kV |
| GEN-2014-040 | 320.40 | SPS | Castro 115kV |
| GEN-2014-047 | 40.00 | SPS | Crossroads 345kV |
| GEN-2014-074 | 152.00 | SPS | Tap TUCO Interchange - Oklaunion (GEN-2014-074 Tap) 345kV |
| GEN-2015-014 | 150.00 | SPS | Tap Cochran - Lehman 115kV |
| GEN-2015-022 | 112.00 | SPS | Swisher 115kV |
| SPS Distributed (Hopi) | 10.00 | SPS | Hopi 115kV |
| SPS Distributed (Jal) | 10.00 | SPS | S Jal 115kV |
| SPS Distributed (Lea Road) | 10.00 | SPS | Lea Road 115kV |
| SPS Distributed (Monument) | 10.00 | SPS | Monument 115kV |
| SPS Distributed (Ocotillo) | 10.00 | SPS | S_Jal 115kV |
| SPS Distributed (Yuma) | 2.57 | SPS | SP-Yuma 69kV |
| PRIOR QUEUED SUBTOTAL | 4,550.77 | | |

| | | | |
|---------------------------------|-----------------|-----|--------------------------------------|
| GEN-2015-020 | 100.00 | SPS | Oasis 115kV |
| GEN-2015-031 | 150.50 | SPS | Tap Amarillo South - Swisher 230kV |
| GEN-2015-056 | 101.20 | SPS | Crossroads 345kV |
| GEN-2015-058 | 50.00 | SPS | Atoka 115kV |
| GEN-2015-068 | 300.00 | SPS | TUCO Interchange 345kV |
| GEN-2015-075 | 51.50 | SPS | Carlisle 69kV |
| GEN-2015-079 | 129.20 | SPS | Tap Yoakum - Hobbs Interchange 230kV |
| GEN-2015-080 | 129.20 | SPS | Tap Yoakum - Hobbs Interchange 230kV |
| CURRENT CLUSTER SUBTOTAL | 1,011.60 | | |
| AREA TOTAL | 5,562.37 | | |

| GROUP 7: SOUTHWEST OKLAHOMA AREA | | | |
|---|-----------------|-------------|--|
| Request | Capacity | Area | Proposed Point of Interconnection |
| GEN-2001-026 | 74.30 | WFEC | Washita 138kV |
| GEN-2002-005 | 120.00 | WFEC | Red Hills Tap 138kV |
| GEN-2003-004 | 100.00 | WFEC | Washita 138kV |
| GEN-2003-005 | 100.00 | WFEC | Anadarko - Paradise (Blue Canyon) 138kV |
| GEN-2003-022 | 120.00 | AEPW | Weatherford 138kV |
| GEN-2004-020 | 27.00 | AEPW | Weatherford 138kV |
| GEN-2004-023 | 20.60 | WFEC | Washita 138kV |
| GEN-2005-003 | 30.60 | WFEC | Washita 138kV |
| GEN-2006-002 | 101.00 | AEPW | Sweetwater 230kV |
| GEN-2006-035 | 225.00 | AEPW | Sweetwater 230kV |
| GEN-2006-043 | 99.00 | AEPW | Sweetwater 230kV |
| GEN-2007-052 | 150.00 | WFEC | Anadarko 138kV |
| GEN-2008-023 | 150.00 | AEPW | Hobart Junction 138kV |
| GEN-2008-037 | 101.00 | WFEC | Slick Hills 138kV |
| GEN-2011-037 | 7.00 | WFEC | Blue Canyon 5 138kV |
| GEN-2011-049 | 250.70 | OKGE | Border 345kV |
| GEN-2012-028 | 74.80 | WFEC | Gotebo 69kV |
| GEN-2015-004 | 52.90 | OKGE | Border 345kV |
| GEN-2015-013 | 120.00 | WFEC | Synder 138kV |
| PRIOR QUEUED SUBTOTAL | 1,923.90 | | |
| GEN-2015-055 | 40.00 | WFEC | Erick 138kV |
| GEN-2015-071 | 200.00 | AEPW | Chisholm 345kV |
| GEN-2015-084 | 51.30 | AEPW | Hollis 138kV |
| GEN-2015-085 | 122.40 | AEPW | Altus Junction 138kV |
| CURRENT CLUSTER SUBTOTAL | 413.70 | | |
| AREA TOTAL | 2,337.60 | | |

| GROUP 8: NORTH OKLAHOMA/SOUTH CENTRAL KANSAS AREA | | | |
|--|-----------------|-------------|---|
| Request | Capacity | Area | Proposed Point of Interconnection |
| ASGI-2010-006 | 150.00 | AECI | Remington 138kV |
| ASGI-2014-014 | 56.40 | GRDA | Ferguson 69kV |
| ASGI-2015-004 | 56.36 | GRDA | Coffeyville City 69kV |
| GEN-2002-004 | 200.00 | WERE | Latham 345kV |
| GEN-2005-013 | 201.00 | WERE | Caney River 345kV |
| GEN-2007-025 | 300.00 | WERE | Viola 345kV |
| GEN-2008-013 | 300.00 | OKGE | Hunter 345kV |
| GEN-2008-021 | 42.00 | WERE | Wolf Creek 345kV |
| GEN-2008-098 | 100.80 | WERE | Waverly 345kV |
| GEN-2009-025 | 59.80 | OKGE | Nardins 69kV |
| GEN-2010-003 | 100.80 | WERE | Waverly 345kV |
| GEN-2010-005 | 299.20 | WERE | Viola 345kV |
| GEN-2010-055 | 4.50 | AEPW | Wekiwa 138kV |
| GEN-2011-057 | 150.40 | WERE | Creswell 138kV |
| GEN-2012-032 | 300.00 | OKGE | Open Sky 345kV |
| GEN-2012-033 | 98.10 | OKGE | Tap and Tie South 4th - Bunch Creek & Enid Tap - Fairmont (GEN-2012-033T) 138kV |
| GEN-2012-041 | 121.50 | OKGE | Ranch Road 345kV |
| GEN-2013-012 | 147.00 | OKGE | Redbud 345kV |
| GEN-2013-028 | 559.50 | GRDA | Tap N Tulsa - GRDA 1 345kV |
| GEN-2013-029 | 300.00 | OKGE | Renfrow 345kV |
| GEN-2014-001 | 200.60 | WERE | Tap Wichita - Emporia Energy Center (GEN-2014-001 Tap) 345kV |

| | | | |
|---------------------------------|-----------------|------|---|
| GEN-2014-028 | 35.00 | EMDE | Riverton 161kV |
| GEN-2014-064 | 248.40 | OKGE | Otter 138kV |
| GEN-2015-001 | 200.00 | OKGE | Ranch Road 345kV |
| GEN-2015-015 | 154.60 | OKGE | Tap Medford Tap - Coyote 138kV |
| GEN-2015-016 | 200.00 | KCPL | Tap Marmaton - Centerville 161kV |
| GEN-2015-024 | 220.00 | WERE | Tap Thistle - Wichita 345kV Dbl CKT |
| GEN-2015-025 | 220.00 | WERE | Tap Thistle - Wichita 345kV Dbl CKT |
| GEN-2015-030 | 200.10 | OKGE | Sooner 345kV |
| PRIOR QUEUED SUBTOTAL | 5,226.06 | | |
| GEN-2015-034 | 200.00 | OKGE | Ranch Road 345kV |
| GEN-2015-047 | 300.00 | OKGE | Sooner 345kV |
| GEN-2015-052 | 300.00 | WERE | Tap Open Sky - Rose Hill 345kV |
| GEN-2015-062 | 4.50 | OKGE | Tap and Tie South 4th - Bunch Creek & Enid Tap - Fairmont (GEN-2012-033T) 138kV |
| GEN-2015-063 | 300.00 | OKGE | Tap Woodring - Mathewson 345kV |
| GEN-2015-066 | 248.40 | OKGE | Tap Cleveland - Sooner 345kV |
| GEN-2015-067 | 150.00 | OKGE | Sooner 138kV |
| GEN-2015-069 | 300.00 | WERE | Union Ridge 230kV |
| GEN-2015-073 | 200.10 | WERE | Emporia Energy Center 345kV |
| GEN-2015-083 | 125.00 | WERE | Belle Plain 138kV |
| GEN-2015-090 | 220.00 | WERE | Tap Thistle - Wichita 345kV Dbl CKT |
| CURRENT CLUSTER SUBTOTAL | 2,348.00 | | |
| AREA TOTAL | 7,574.06 | | |

GROUP 9: NEBRASKA AREA

| Request | Capacity | Area | Proposed Point of Interconnection |
|------------------|----------|------|---|
| GEN-2002-023N | 0.80 | NPPD | Harmony 115kV |
| GEN-2003-021N | 75.00 | NPPD | Ainsworth Wind Tap 115kV |
| GEN-2004-023N | 75.00 | NPPD | Columbus Co 115kV |
| GEN-2006-020N | 42.00 | NPPD | Bloomfield 115kV |
| GEN-2006-037N1 | 75.00 | NPPD | Broken Bow 115kV |
| GEN-2006-038N005 | 80.00 | NPPD | Broken Bow 115kV |
| GEN-2006-038N019 | 80.00 | NPPD | Petersburg North 115kV |
| GEN-2006-044N | 40.50 | NPPD | North Petersburg 115kV |
| GEN-2007-011N08 | 81.00 | NPPD | Bloomfield 115kV |
| GEN-2007-017IS | 166.00 | WAPA | Ft Thompson-Grand Island 345kV |
| GEN-2007-018IS | 234.00 | WAPA | Ft Thompson-Grand Island 345kV |
| GEN-2008-086N02 | 201.00 | NPPD | Meadow Grove 230kV |
| GEN-2008-119O | 60.00 | OPPD | S1399 161kV |
| GEN-2008-123N | 89.70 | NPPD | Tap Pauline - Hildreth (Rosemont) 115kV |
| GEN-2009-040 | 73.80 | WERE | Marshall 115kV |
| GEN-2010-041 | 10.50 | OPPD | S1399 161kV |
| GEN-2010-051 | 200.00 | NPPD | Tap Hoskins - Twin Church (Dixon County) 230kV |
| GEN-2011-018 | 73.60 | NPPD | Steele City 115kV |
| GEN-2011-027 | 120.00 | NPPD | Tap Hoskins - Twin Church (Dixon County) 230kV |
| GEN-2011-056 | 3.60 | NPPD | Jeffrey 115kV |
| GEN-2011-056A | 3.60 | NPPD | John 1 115kV |
| GEN-2011-056B | 4.50 | NPPD | John 2 115kV |
| GEN-2012-021 | 4.80 | LES | Terry Bundy Generating Station 115kV |
| GEN-2013-002 | 50.60 | LES | Tap Sheldon - Folsom & Pleasant Hill (GEN-2013-002 Tap) 115kV CKT 2 |
| GEN-2013-008 | 1.20 | NPPD | Steele City 115kV |
| GEN-2013-019 | 73.60 | LES | Tap Sheldon - Folsom & Pleasant Hill (GEN-2013-002 Tap) 115kV CKT 2 |
| GEN-2013-032 | 204.00 | NPPD | Antelope 115kV |
| GEN-2014-004 | 4.00 | NPPD | Steele City 115kV (GEN-2011-018 POI) |

| | | | |
|---|-----------------|------|---|
| GEN-2014-013 | 73.50 | NPPD | Meadow Grove (GEN-2008-086N2 Sub) 230kV |
| GEN-2014-031 | 35.80 | NPPD | Meadow Grove 230kV |
| GEN-2014-032 | 10.20 | NPPD | Meadow Grove 230kV |
| GEN-2014-039 | 73.40 | NPPD | Friend 115kV |
| GEN-2015-007 | 160.00 | NPPD | Hoskins 345kV |
| GEN-2015-023 | 300.70 | NPPD | Holt County 345kV |
| NPPD Distributed (Broken Bow) | 8.30 | NPPD | Broken Bow 115kV |
| NPPD Distributed (Buffalo County Solar) | 10.00 | NPPD | Kearney Northeast |
| NPPD Distributed (Burt County Wind) | 12.00 | NPPD | Tekamah & Oakland 115kV |
| NPPD Distributed (Burwell) | 3.00 | NPPD | Ord 115kV |
| NPPD Distributed (Columbus Hydro) | 45.00 | NPPD | Columbus 115kV |
| NPPD Distributed (North Platte - Lexington) | 54.00 | NPPD | Multiple: Jeffrey 115kV, John_1 115kV, John_2 115kV |
| NPPD Distributed (Ord) | 11.90 | NPPD | Ord 115kV |
| NPPD Distributed (Stuart) | 2.10 | NPPD | Ainsworth 115kV |
| PRIOR QUEUED SUBTOTAL | 2,927.70 | | |
| GEN-2015-053 | 50.00 | NPPD | Antelope 115kV |
| GEN-2015-076 | 158.40 | NPPD | Belden 115kV |
| GEN-2015-087 | 66.00 | NPPD | Tap Fairbury - Hebron 115kV |
| GEN-2015-088 | 300.00 | NPPD | Tap Moore - Pauline 345kV |
| CURRENT CLUSTER SUBTOTAL | 574.40 | | |
| AREA TOTAL | 3,502.10 | | |

GROUP 10: SOUTHEAST OKLAHOMA/NORTHEAST TEXAS AREA

| Request | Capacity | Area | Proposed Point of Interconnection |
|-------------------|-------------|------|-----------------------------------|
| AREA TOTAL | 0.00 | | |

GROUP 12: NORTHWEST ARKANSAS AREA

| Request | Capacity | Area | Proposed Point of Interconnection |
|------------------------------|--------------|------|-----------------------------------|
| GEN-2013-011 | 30.00 | AEPW | Turk 138kV |
| PRIOR QUEUED SUBTOTAL | 30.00 | | |
| AREA TOTAL | 30.00 | | |

GROUP 13: NORTHWEST MISSOURI AREA

| Request | Capacity | Area | Proposed Point of Interconnection |
|------------------------------|---------------|------|--|
| GEN-2008-129 | 80.00 | KCPL | Pleasant Hill 161kV |
| GEN-2010-036 | 4.60 | WERE | 6th Street 115kV |
| GEN-2011-011 | 50.00 | KCPL | Iatan 345kV |
| GEN-2014-021 | 300.00 | KCPL | Tap Nebraska City - Mullin Creek 345kV |
| GEN-2015-005 | 200.10 | KCPL | Tap Nebraska City - Sibley 345kV |
| PRIOR QUEUED SUBTOTAL | 634.70 | | |
| AREA TOTAL | 634.70 | | |

GROUP 14: SOUTH CENTRAL OKLAHOMA AREA

| Request | Capacity | Area | Proposed Point of Interconnection |
|---------------------------------|---------------|------|---|
| GEN-2011-040 | 111.00 | OKGE | Carter County 138kV |
| GEN-2011-050 | 109.80 | AEPW | Santa Fe Tap 138kV |
| GEN-2012-004 | 41.40 | OKGE | Carter County 138kV |
| GEN-2013-007 | 100.30 | OKGE | Tap Prices Falls - Carter 138kV |
| GEN-2014-057 | 250.00 | AEPW | Tap Lawton - Sunnyside (Terry Road) 345kV |
| PRIOR QUEUED SUBTOTAL | 612.50 | | |
| ASGI-2015-006 | 9.00 | SWPA | Tupelo 138kV |
| GEN-2015-045 | 20.00 | AEPW | Tap Lawton - Sunnyside (Terry Road) 345kV |
| GEN-2015-092 | 250.00 | AEPW | Tap Lawton - Sunnyside (Terry Road) 345kV |
| CURRENT CLUSTER SUBTOTAL | 279.00 | | |
| AREA TOTAL | 891.50 | | |

GROUP 15: E-SOUTH DAKOTA AREA

| Request | Capacity | Area | Proposed Point of Interconnection |
|---------------------------------|-----------------|------|-----------------------------------|
| G176 | 100.00 | XEL | Yankee 115kV |
| G255 | 100.00 | XEL | Yankee 115kV |
| G586 | 30.00 | XEL | Yankee 115kV |
| G736 | 200.00 | OTP | Big Stone South 230kV |
| GEN-2002-009IS | 40.00 | WAPA | Ft Thompson 69kV [Hyde 69kV] |
| GEN-2007-013IS | 50.00 | WAPA | Wessington Springs 230kV |
| GEN-2007-014IS | 100.00 | WAPA | Wessington Springs 230kV |
| GEN-2007-023IS | 50.00 | WAPA | Formit-Summit 115kV |
| GEN-2009-001IS | 200.00 | WAPA | Groton-Watertown 345kV |
| GEN-2009-018IS | 100.00 | WAPA | Groton 115kV |
| GEN-2010-001IS | 99.00 | WAPA | Bismarck-Glenham 230kV |
| GEN-2010-003IS | 34.00 | WAPA | Wessington Springs 230kV |
| GEN-2012-014IS | 99.50 | WAPA | Groton 115kV |
| GEN-2013-001IS | 90.00 | WAPA | Summit-Watertown 115kV |
| GEN-2013-009IS | 19.50 | WAPA | Redfield NW 115kV |
| GEN-2014-001IS | 103.70 | WAPA | Newell-Maurine 115kV |
| J436 | 150.00 | OTP | Big Stone South 345kV |
| J437 | 150.00 | OTP | Big Stone South 345kV |
| J442 | 200.00 | OTP | Big Stone 230 kV |
| PRIOR QUEUED SUBTOTAL | 1,915.70 | | |
| GEN-2015-097 | 100.00 | WAPA | Groton 115kV |
| CURRENT CLUSTER SUBTOTAL | 100.00 | | |
| AREA TOTAL | 2,015.70 | | |

GROUP 16: W-NORTH DAKOTA AREA

| Request | Capacity | Area | Proposed Point of Interconnection |
|---------------------------------|-----------------|------|-----------------------------------|
| G359 | 150.00 | MDU | MDU 230 kV system near Ellendale |
| G380 | 150.00 | OTP | Rugby 115kV |
| G408 | 12.00 | XEL | Tap McHenry - Souris 115kV |
| G502 | 50.60 | MP | Milton Young 230kV |
| G645 | 50.00 | GRE | Ladish 115kV |
| G723 | 10.00 | MDU | Haskett 115kV |
| G752 | 150.00 | MDU | Tap Bison - Hettinger 230kV |
| G788 | 49.00 | GRE | Ladish 115kV |
| G830 | 99.00 | GRE | GRE McHenry 115kV |
| GEN-2005-008IS | 50.00 | WAPA | Hilken 230kV [Ecklund 230kV] |
| GEN-2006-015IS | 50.00 | WAPA | Hilken 230kV [Ecklund 230kV] |
| GEN-2007-015IS | 100.00 | WAPA | Hilken 230kV [Ecklund 230kV] |
| GEN-2007-027IS | 99.00 | WAPA | Bismarck-Garrison 230kV #1 |
| GEN-2009-026IS | 110.00 | WAPA | Dickenson-Heskett 230kV |
| GEN-2010-007IS | 172.50 | WAPA | Antelope Valley 345kV |
| GEN-2012-006IS | 125.01 | WAPA | Williston-Ch. Creek 230kV |
| GEN-2012-012IS | 75.00 | WAPA | Wolf Point-Circle 115kV |
| GEN-2014-003IS | 91.00 | WAPA | Culbertson 115kV |
| GEN-2014-004IS | 384.20 | WAPA | Charlie Creek 345kV |
| GEN-2014-006IS | 125.00 | WAPA | Williston 115kV |
| GEN-2014-010IS | 150.00 | WAPA | Neset 115kV |
| GEN-2014-014IS | 151.50 | WAPA | Belfield-Rhame 230kV |
| J003 | 20.00 | MDU | Baker 115kV |
| J249 | 180.00 | MDU | MDU Tatanka 230kV |
| J262 | 100.00 | OTP | Jamestown 345 |
| J263 | 100.00 | OTP | Jamestown 345 |
| J290 | 150.00 | XEL | Tap Glenboro South - Rugby 230kV |
| J316 | 150.00 | MDU | MDU 230 kV Tatanka-Ellendale line |
| MPC01200 | 44.00 | OTP | Sidney 230kV |
| MPC02100 | 100.00 | OTP | Sidney 230kV |
| PRIOR QUEUED SUBTOTAL | 3,247.81 | | |
| GEN-2015-046 | 300.00 | WAPA | Tande 345kV |
| GEN-2015-091 | 101.20 | WAPA | Daglum 230kV |
| GEN-2015-096 | 150.00 | WAPA | Tap Belfied - Rhame 230kV |
| GEN-2015-098 | 100.00 | WAPA | Mingusville 230kV |
| CURRENT CLUSTER SUBTOTAL | 651.20 | | |
| AREA TOTAL | 0.00 | | |

| GROUP 17: W-SOUTH DAKOTA AREA | | | |
|--------------------------------------|---------------|------|-----------------------------------|
| Request | Capacity | Area | Proposed Point of Interconnection |
| GEN-2006-001IS | 10.00 | XEL | Marshall 115kV |
| GEN-2006-002IS | 51.00 | WAPA | Wessington Springs 230kV |
| GEN-2006-006IS | 10.00 | XEL | Marshall 115kV |
| GEN-2009-006IS | 90.00 | WAPA | Mission 115kV |
| GEN-2009-007IS | 100.00 | WAPA | Mission 115kV |
| GEN-2009-020AIS | 130.50 | WAPA | Tripp Junction 115kV |
| GEN-2012-009IS | 99.00 | WAPA | Fort Randall 115kV |
| PRIOR QUEUED SUBTOTAL | 490.50 | | |
| AREA TOTAL | 0.00 | | |

| GROUP 18: E-NORTH DAKOTA AREA | | | |
|--------------------------------------|---------------|------|-----------------------------------|
| Request | Capacity | Area | Proposed Point of Interconnection |
| GEN-2002-008IS | 40.50 | WAPA | Edgeley 115kV [Pomona 115kV] |
| GEN-2005-003IS | 100.00 | WAPA | Nelson 115kV |
| GEN-2007-020IS | 16.00 | WAPA | Nelson 115kV |
| GEN-2008-008IS | 5.00 | WAPA | Nelson 115kV |
| PRIOR QUEUED SUBTOTAL | 161.50 | | |
| AREA TOTAL | 0.00 | | |


| | | |
|---|-----------------|-----------|
| CLUSTER TOTAL (CURRENT STUDY) | 7,340.9 | MW |
| PQ TOTAL (PRIOR QUEUED) | 34,482.9 | MW |
| CLUSTER TOTAL (INCLUDING PRIOR QUEUED) | 41,823.8 | MW |

11.4 D: Proposed Point of Interconnection One Line Diagrams

See next page


*Note: If not denoted otherwise for Affected System Generator Interconnection Requests (ASGI) interconnection cost estimate could include distribution system or third party system network upgrades and costs estimates.

ASGI-2015-006
Estimated Cluster Analysis Interconnection Cost: \$0




* Interconnection Cost Estimate(s) only include Affected System Interconnection costs


GEN-2014-037
Estimated Cluster Analysis Interconnection Cost: \$20,334,923




GEN-2015-020
Estimated Cluster Analysis Interconnection Cost: \$9,984,058




GEN-2015-031
Estimated Cluster Analysis Interconnection Cost: \$7,567,148




GEN-2015-034
Estimated Cluster Analysis Interconnection Cost: \$2,112,500




GEN-2015-045
Estimated Cluster Analysis Interconnection Cost: \$0




GEN-2015-046
Estimated Cluster Analysis Interconnection Cost: \$3,759,097




GEN-2015-047
Estimated Cluster Analysis Interconnection Cost: \$2,540,000




GEN-2015-048
Estimated Cluster Analysis Interconnection Cost: \$2,968,000




GEN-2015-052
Estimated Cluster Analysis Interconnection Cost: \$15,582,434




GEN-2015-053
Estimated Cluster Analysis Interconnection Cost: \$1,000,000




GEN-2015-055
Estimated Cluster Analysis Interconnection Cost: \$1,900,000




GEN-2015-056
Estimated Cluster Analysis Interconnection Cost: \$5,080,273




GEN-2015-057
Estimated Cluster Analysis Interconnection Cost: \$20,000




GEN-2015-058
Estimated Cluster Analysis Interconnection Cost: \$2,751,641




GEN-2015-059
Estimated Cluster Analysis Interconnection Cost: \$0




GEN-2015-060
Estimated Cluster Analysis Interconnection Cost: \$943,000




GEN-2015-061
Estimated Cluster Analysis Interconnection Cost: \$6,988,986




GEN-2015-062
Estimated Cluster Analysis Interconnection Cost: \$0




GEN-2015-063
Estimated Cluster Analysis Interconnection Cost: \$10,613,000




GEN-2015-064
Estimated Cluster Analysis Interconnection Cost: \$4,638,823




GEN-2015-065
Estimated Cluster Analysis Interconnection Cost: \$6,988,986




GEN-2015-066
Estimated Cluster Analysis Interconnection Cost: \$10,613,000




GEN-2015-067
Estimated Cluster Analysis Interconnection Cost: \$3,521,000




GEN-2015-068
Estimated Cluster Analysis Interconnection Cost: \$3,303,965




GEN-2015-069
Estimated Cluster Analysis Interconnection Cost: \$2,755,752




GEN-2015-071
Estimated Cluster Analysis Interconnection Cost: \$14,623,541




GEN-2015-073
Estimated Cluster Analysis Interconnection Cost: \$2,576,628




GEN-2015-075
Estimated Cluster Analysis Interconnection Cost: \$5,000,000




GEN-2015-076
Estimated Cluster Analysis Interconnection Cost: \$2,600,000




GEN-2015-079
Estimated Cluster Analysis Interconnection Cost: \$3,687,384




GEN-2015-080
Estimated Cluster Analysis Interconnection Cost: \$3,687,384




GEN-2015-081
Estimated Cluster Analysis Interconnection Cost: \$3,005,000



GEN-2015-083
Estimated Cluster Analysis Interconnection Cost: \$6,713,963




GEN-2015-084
Estimated Cluster Analysis Interconnection Cost: \$14,665,056




*Remote end work is required at Sharmack and Childress substations for the addition of GEN-2015-084


GEN-2015-085
Estimated Cluster Analysis Interconnection Cost: \$8,406,414




GEN-2015-087
Estimated Cluster Analysis Interconnection Cost: \$5,300,000




GEN-2015-088
Estimated Cluster Analysis Interconnection Cost: \$15,000,000




GEN-2015-090
Estimated Cluster Analysis Interconnection Cost: \$16,021




GEN-2015-091
Estimated Cluster Analysis Interconnection Cost: \$3,224,682




GEN-2015-092
Estimated Cluster Analysis Interconnection Cost: \$1,110,612




GEN-2015-093
Estimated Cluster Analysis Interconnection Cost: \$2,125,000




GEN-2015-095
Estimated Cluster Analysis Interconnection Cost: \$4,400,000




GEN-2015-096
Estimated Cluster Analysis Interconnection Cost: \$0



GEN-2015-097
Estimated Cluster Analysis Interconnection Cost: \$3,000,000



GEN-2015-098
Estimated Cluster Analysis Interconnection Cost: \$3,000,000



11.5 E: Cost Allocation per Interconnection Request (Including Prior Queued Upgrades)

Important Note:

****WITHDRAWAL OF HIGHER QUEUED PROJECTS WILL CAUSE A RESTUDY
AND MAY RESULT IN HIGHER INTERCONNECTION COSTS****

This section shows each Generation Interconnection Request Customer, their current study impacted Network Upgrades, and the previously allocated upgrades upon which they rely to accommodate their interconnection to the transmission system.

The costs associated with the current study Network Upgrades are allocated to the Customers shown in this report.

In addition should a higher queued request, defined as one this study includes as a prior queued request, withdraw, the Network Upgrades assigned to the withdrawn request may be reallocated to the remaining requests that have an impact on the Network Upgrade under a restudy. Also, should an Interconnection Request choose to go into service prior to the operation date of any necessary Network Upgrades, the costs associated with those upgrades may be reallocated to the impacted Interconnection Request. The actual costs allocated to each Generation Interconnection Request Customer will be determined at the time of a restudy.

The required interconnection costs listed do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT. In addition, costs associated with a short circuit analysis will be allocated should the Interconnection Request Customer choose to execute a Facility Study Agreement.

There may be additional costs allocated to each Customer. See Appendix F for more details.

Appendix E. Cost Allocation Per Request

(Including Previously Allocated Network Upgrades*)

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|---------------------|---------------|
| ASGI-2015-006 | | | |
| ASGI-2015-006 Interconnection Costs See One-Line Diagram. | Current Study | \$0 | \$0 |
| | Current Study Total | \$0 | |
| GEN-2014-037 | | | |
| Beaver County 345kV Reactive Power Support Install +100Mvar SVC at Beaver County Substation. | Current Study | \$25,000,000 | \$25,000,000 |
| GEN-2014-037 Interconnection Costs See One-Line Diagram. | Current Study | \$20,334,923 | \$20,334,923 |
| Mathewson - Cimarron 345kV CKT 2 Build second 345kV circuit from Mathewson - Cimarron @ 3000 amps per ITP10. | Previously Allocated | | \$42,903,753 |
| Potter County Interchange 345/230/13kV Transformer CKT 2 Build second 345/230/13kV transformer at Potter County | Previously Allocated | | \$15,000,000 |
| Tatonga - Mathewson 345kV CKT 2 Build second 345kV circuit from Tatonga - Mathewson @ 3000 amps per ITP10. | Previously Allocated | | \$104,260,473 |
| Woodward - GEN-2011-051 Tap - Tatonga 345kV CKT 2 Build second 345kV circuit from Woodward - Tatonga @ 3000 amps per ITP10. | Previously Allocated | | \$71,876,622 |
| Woodward EHV Phase Shifting Transformer CKT 1 Install one phase shifting transformer at Woodward | Previously Allocated | | \$7,200,000 |
| | Current Study Total | \$45,334,923 | |
| GEN-2015-020 | | | |
| Border - Chisholm 345kV CKT 2 Build approximately 25 miles of second circuit 345kV from Border - Chisholm | Current Study | \$2,266,649 | \$25,000,000 |
| Border 345kV Reactive Power Support Install (6)Steps of 50Mvar Capacitor Bank(s) and +300Mvar SVC at Border Substation | Current Study | \$3,291,609 | \$35,000,000 |
| Chisholm Substation Upgrade 345kV Expand planned Chisholm Substation to tap and terminate Woodward - Border 345kV into the Chisholm Substation | Current Study | \$1,088,010 | \$12,000,000 |
| Crawfish Draw - Border 345kV CKT 2 Build approximately 194 miles of second circuit 345kV from TUCO 2 - Border | Current Study | \$17,621,703 | \$194,000,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------------|-----------------------|---------------------|
| GEN-2014-074 Tap Dynamic Reactive Power Support 34.5kV STATCOM at GEN-2014-074 | Current Study | \$282,138 | \$3,000,000 |
| GEN-2015-020 Interconnection Costs See One-Line Diagram. | Current Study | \$9,984,058 | \$9,984,058 |
| Grapevine - Nichols 230kV CKT 1 Replace terminal equipment | Current Study | \$51,213 | \$400,000 |
| Grapevine - Wheeler 230kV CKT 1 Replace terminal equipment | Current Study | \$32,133 | \$400,000 |
| Oklaunion 345kV Reactive Power Support Incremental Upgrade Install +/-100Mvar SVC at Oklaunion | Current Study | \$1,816,670 | \$20,000,000 |
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$460,332 | \$6,000,000 |
| 2016 ITPNT Upgrade(s) 2016 ITPNT Upgrade(s) for mitigation of stability constraints near Mustang and Seminole | Previously Allocated | | \$0 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |
| Crawfish Draw Substation Upgrade 345/230kV Tap Border-TUCO approximately 2 miles from TUCO and build Crawfish Draw 345kV substation and add 345/230/13.2kV transformer and tie on TUCO-Swisher 230kV. | Previously Allocated | | \$24,764,205 |
| Elk City 230/138/13kV Transformer CKT 1 Replace terminal equipment for Elk City Transformer to achieve transformer limit of 450MVA. | Previously Allocated | | \$15,000,000 |
| Oklaunion 345kV Reactive Power Install (2)-130Mvar Capacitor Bank(s) at Oklaunion | Previously Allocated | | \$10,000,000 |
| Potash Junction 230kV Reactive Power Support Build Potash Junction 100Mvar Capacitor bank per 2015 ITPNT. | Previously Allocated | | \$6,465,875 |
| Tolk - Plant X 230kV CKT 1 & 2 Rebuild circuit 1 and 2 between Tolk - Plant X 230kV to 1200 amps each. | Previously Allocated | | \$9,921,693 |
| TUCO 345/230/13.2kV Transformer CKT 1 Replace existing TUCO 345/230/13.2kV Transformer circuit #1 with 640MVA. | Previously Allocated | | \$3,347,036 |
| | Current Study Total | \$36,894,515 | |

GEN-2015-031

| | | | |
|--|---------------|-------------|--------------|
| Border - Chisholm 345kV CKT 2 Build approximately 25 miles of second circuit 345kV from Border - Chisholm | Current Study | \$1,943,934 | \$25,000,000 |
|--|---------------|-------------|--------------|

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------|-----------------------|---------------------|
| Border 345kV Reactive Power Support Install (6)Steps of 50Mvar Capacitor Bank(s) and +300Mvar SVC at Border Substation | Current Study | \$3,135,053 | \$35,000,000 |
| Chisholm Substation Upgrade 345kV Expand planned Chisholm Substation to tap and terminate Woodward - Border 345kV into the Chisholm Substation | Current Study | \$933,104 | \$12,000,000 |
| Crawfish Draw - Border 345kV CKT 2 Build approximately 194 miles of second circuit 345kV from TUCO 2 - Border | Current Study | \$16,076,755 | \$194,000,000 |
| GEN-2014-074 Tap Dynamic Reactive Power Support 34.5kV STATCOM at GEN-2014-074 | Current Study | \$268,719 | \$3,000,000 |
| GEN-2015-031 Interconnection Costs See One-Line Diagram. | Current Study | \$7,567,148 | \$7,567,148 |
| Grapevine - Nichols 230kV CKT 1 Replace terminal equipment | Current Study | \$66,836 | \$400,000 |
| Grapevine - Wheeler 230kV CKT 1 Replace terminal equipment | Current Study | \$41,940 | \$400,000 |
| Oklaunion 345kV Reactive Power Support Incremental Upgrade Install +/-100Mvar SVC at Oklaunion | Current Study | \$1,657,397 | \$20,000,000 |
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$600,726 | \$6,000,000 |
| 2016 ITPNT Upgrade(s) 2016 ITPNT Upgrade(s) for mitigation of stability constraints near Mustang and Seminole | Previously Allocated | | \$0 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |
| Crawfish Draw Substation Upgrade 345/230kV Tap Border-TUCO approximately 2 miles from TUCO and build Crawfish Draw 345kV substation and add 345/230/13.2kV transformer and tie on TUCO-Swisher 230kV. | Previously Allocated | | \$24,764,205 |
| Elk City 230/138/13kV Transformer CKT 1 Replace terminal equipment for Elk City Transformer to achieve transformer limit of 450MVA. | Previously Allocated | | \$15,000,000 |
| Kress Interchange - Swisher 115kV CKT 1 Replace terminal equipment | Previously Allocated | | \$500,000 |
| Oklaunion 345kV Reactive Power Install (2)-130Mvar Capacitor Bank(s) at Oklaunion | Previously Allocated | | \$10,000,000 |
| Potash Junction 230kV Reactive Power Support Build Potash Junction 100Mvar Capacitor bank per 2015 ITPNT. | Previously Allocated | | \$6,465,875 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| TUCO 345/230/13.2kV Transformer CKT 1 Replace existing TUCO 345/230/13.2kV Transformer circuit #1 with 640MVA. | Previously Allocated | | \$3,347,036 |
| | Current Study Total | \$32,291,613 | |
| GEN-2015-034 | | | |
| Cleveland - Cleveland 138kV CKT Z1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |
| Cleveland - Silver City 138kV CKT 1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |
| GEN-2015-034 Interconnection Costs See One-Line Diagram. | Current Study | \$2,112,500 | \$2,112,500 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$47,200 | \$750,000 |
| | Current Study Total | \$2,159,700 | |
| GEN-2015-045 | | | |
| GEN-2015-045 Interconnection Costs See One-Line Diagram. | Current Study | \$0 | \$0 |
| | Current Study Total | \$0 | |
| GEN-2015-046 | | | |
| Daglum - Dickinson 230kV CKT 1 Build new 230kV line from Daglum - Dickinson. | Current Study | \$2,033,296 | \$28,000,000 |
| Dickinson 230/115/13.8kV CKT 2 Build new 230/115/13.8kV Transformer circuit #2 at Dickinson. | Current Study | \$948,770 | \$3,500,000 |
| GEN-2015-046 Interconnection Costs See One-Line Diagram. | Current Study | \$3,759,097 | \$3,759,097 |
| Hanlon 69kV Reactive Support Install (1) 10Mvar Capacitor Bank at Hanlon 69kV. | Current Study | \$230,666 | \$500,000 |
| MISO Affected System Study See section 4 power flow analysis. | Current Study | \$TBD | \$TBD |
| Gentleman - Thedford 345kV CKT 1 Build approximately 76 Miles of 345kV from Gentleman to Thedford per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Neset - Tande 230kV CKT 1 Build new 230kV line from Neset - Tande | Previously Allocated | | \$3,000,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| Neset 230kV Terminal Upgrade(s) Install necessary terminal equipmentInstall necessary terminal upgrades at Neset 230kV to accommodate new 230kV line from new Tande substation | Previously Allocated | | \$4,000,000 |
| Patent Gate - Kummer Ridge - Roundup Project | Previously Allocated | | \$TBD |
| Tande 345/230 Substation Construct new 345kV Tande Substation & Tande 345/230/13kV transformer Construct new 345kV Tande Substation adjacent to the existing 230kV Neset Substation and | Previously Allocated | | \$18,000,000 |
| Theford - Holt County 345kV CKT 1 Build approximately 146 Miles of 345kV from Theford to Holt County per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Theford 345/115kV Transformer CKT 1 Install Theford 345/115kV transformer per SPP-NTC-200277 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| | Current Study Total | \$6,971,830 | |

GEN-2015-047

| | | | |
|---|----------------------------|-------------|-------------|
| Cleveland - Cleveland 138kV CKT Z1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |
| Cleveland - Silver City 138kV CKT 1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |
| GEN-2015-047 Interconnection Costs See One-Line Diagram. | Current Study | \$2,540,000 | \$2,540,000 |
| GEN-2015-063 Tap - Mathewson 345kV CKT 1 Replace terminal equipment to achieve conductor limit | Current Study | \$165,661 | \$1,000,000 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$93,274 | \$750,000 |
| | Current Study Total | \$2,798,935 | |

GEN-2015-048

| | | | |
|---|----------------------|-------------|--------------|
| Cleo Corner - Cleo Plant Tap 138kV CKT 1 Replace terminal equipment to at least 1200 amps | Current Study | \$401,615 | \$500,000 |
| GEN-2015-048 Interconnection Costs See One-Line Diagram. | Current Study | \$2,968,000 | \$2,968,000 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$2,089 | \$750,000 |
| Mathewson - Cimarron 345kV CKT 2 Build second 345kV circuit from Mathewson - Cimarron @ 3000 amps per ITP10. | Previously Allocated | | \$42,903,753 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------------|-----------------------|---------------------|
| Tatonga - Mathewson 345kV CKT 2 Build second 345kV circuit from Tatonga - Matthewson @ 3000 amps per ITP10. | Previously Allocated | | \$104,260,473 |
| Woodward - GEN-2011-051 Tap - Tatonga 345kV CKT 2 Build second 345kV circuit from Woodward - Tatonga @ 3000 amps per ITP10. | Previously Allocated | | \$71,876,622 |
| Woodward EHV Phase Shifting Transformer CKT 1 Install one phase shifting transformer at Woodward | Previously Allocated | | \$7,200,000 |
| | Current Study Total | \$3,371,703 | |
| GEN-2015-052 | | | |
| Cleveland - Cleveland 138kV CKT Z1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |
| GEN-2015-052 Interconnection Costs See One-Line Diagram. | Current Study | \$15,582,434 | \$15,582,434 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$43,569 | \$750,000 |
| | Current Study Total | \$15,626,003 | |
| GEN-2015-053 | | | |
| Albion - Petersburg - North Petersburg 115kV CKT 1 Reconductor 115kV lines and replace all terminal equipment for at least a 193MVA rate. | Current Study | \$3,500,000 | \$3,500,000 |
| GEN-2015-053 Interconnection Costs See One-Line Diagram. | Current Study | \$1,000,000 | \$1,000,000 |
| Battle Creek-County Line 115kV CKT 1 Rebuild approximately 11 miles of 115kV from Battle Creek to County Line. | Previously Allocated | | \$4,000,000 |
| County Line-Neligh East 115kV CKT 1 Rebuild approximately 12 miles of 115kV from County Line to Neligh East. | Previously Allocated | | \$8,050,000 |
| Gentleman - Thedford 345kV CKT 1 Build approximately 76 Miles of 345kV from Gentleman to Thedford per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Hoskins - Neligh 345/115kV Projects Per SPP 2014 ITP NT and NTC 200253 for 6/1/2016 in-service. | Previously Allocated | | \$98,697,720 |
| Thedford - Holt County 345kV CKT 1 Build approximately 146 Miles of 345kV from Thedford to Holt County per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Thedford 345/115kV Transformer CKT 1 Install Thedford 345/115kV transformer per SPP-NTC-200277 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| Twin Church - Dixon County 230kV Increase conductor clearances to accommodate 320MVA facility rating | Previously Allocated | | \$100,000 |
| | Current Study Total | \$4,500,000 | |
| GEN-2015-055 | | | |
| GEN-2015-055 Interconnection Costs See One-Line Diagram. | Current Study | \$1,900,000 | \$1,900,000 |
| Grapevine - Wheeler 230kV CKT 1 Replace terminal equipment | Current Study | \$20,807 | \$400,000 |
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$301,294 | \$6,000,000 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |
| | Current Study Total | \$2,222,101 | |
| GEN-2015-056 | | | |
| Border - Chisholm 345kV CKT 2 Build approximately 25 miles of second circuit 345kV from Border - Chisholm | Current Study | \$2,402,319 | \$25,000,000 |
| Border 345kV Reactive Power Support Install (6)Steps of 50Mvar Capacitor Bank(s) and +300Mvar SVC at Border Substation | Current Study | \$3,436,328 | \$35,000,000 |
| Chisholm Substation Upgrade 345kV Expand planned Chisholm Substation to tap and terminate Woodward - Border 345kV into the Chisholm Substation | Current Study | \$1,153,133 | \$12,000,000 |
| Crawfish Draw - Border 345kV CKT 2 Build approximately 194 miles of second circuit 345kV from TUCO 2 - Border | Current Study | \$18,627,649 | \$194,000,000 |
| GEN-2014-074 Tap Dynamic Reactive Power Support 34.5kV STATCOM at GEN-2014-074 | Current Study | \$294,542 | \$3,000,000 |
| GEN-2015-056 Interconnection Costs See One-Line Diagram. | Current Study | \$5,080,273 | \$5,080,273 |
| Grapevine - Nichols 230kV CKT 1 Replace terminal equipment | Current Study | \$48,587 | \$400,000 |
| Grapevine - Wheeler 230kV CKT 1 Replace terminal equipment | Current Study | \$30,428 | \$400,000 |
| Oklauion 345kV Reactive Power Support Incremental Upgrade Install +/-100Mvar SVC at Oklauion | Current Study | \$1,920,376 | \$20,000,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------------|-----------------------|---------------------|
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$435,826 | \$6,000,000 |
| 2016 ITPNT Upgrade(s) 2016 ITPNT Upgrade(s) for mitigation of stability constraints near Mustang and Seminole | Previously Allocated | | \$0 |
| Amoco Wasson - Oxy Tap 230kV CKT 1 Replace line traps at both terminals | Previously Allocated | | \$200,000 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |
| Crawfish Draw Substation Upgrade 345/230kV Tap Border-TUCO approximately 2 miles from TUCO and build Crawfish Draw 345kV substation and add 345/230/13.2kV transformer and tie on TUCO-Swisher 230kV. | Previously Allocated | | \$24,764,205 |
| Elk City 230/138/13kV Transformer CKT 1 Replace terminal equipment for Elk City Transformer to achieve transformer limit of 450MVA. | Previously Allocated | | \$15,000,000 |
| Oklunion 345kV Reactive Power Install (2)-130Mvar Capacitor Bank(s) at Oklaunion | Previously Allocated | | \$10,000,000 |
| Potash Junction 230kV Reactive Power Support Build Potash Junction 100Mvar Capacitor bank per 2015 ITPNT. | Previously Allocated | | \$6,465,875 |
| Tolk - Plant X 230kV CKT 1 & 2 Rebuild circuit 1 and 2 between Tolk - Plant X 230kV to 1200 amps each. | Previously Allocated | | \$9,921,693 |
| TUCO 345/230/13.2kV Transformer CKT 1 Replace existing TUCO 345/230/13.2kV Transformer circuit #1 with 640MVA. | Previously Allocated | | \$3,347,036 |
| | Current Study Total | \$33,429,463 | |

GEN-2015-057

| | | | |
|--|----------------------|-----------|-------------|
| GEN-2015-057 Interconnection Costs See One-Line Diagram. | Current Study | \$20,000 | \$20,000 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$108,819 | \$750,000 |
| Bucker - Spearville 345V CKT 1 Replace Terminal equipment | Previously Allocated | | \$1,480,238 |
| Cimarron - Draper Lake 345kV CKT 1 Replace terminal equipment to at least 2000A assigned in 2015 ITP10 per SPP-NTC-200329 | Previously Allocated | | \$1,500,000 |
| Woodward EHV Phase Shifting Transformer CKT 1 Install one phase shifting transformer at Woodward | Previously Allocated | | \$7,200,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------|----------------|---------------|
| | Current Study Total | \$128,819 | |
| GEN-2015-058 | | | |
| Border - Chisholm 345kV CKT 2 Build approximately 25 miles of second circuit 345kV from Border - Chisholm | Current Study | \$1,243,832 | \$25,000,000 |
| Border 345kV Reactive Power Support Install (6)Steps of 50Mvar Capacitor Bank(s) and +300Mvar SVC at Border Substation | Current Study | \$1,754,693 | \$35,000,000 |
| Chisholm Substation Upgrade 345kV Expand planned Chisholm Substation to tap and terminate Woodward - Border 345kV into the Chisholm Substation | Current Study | \$597,050 | \$12,000,000 |
| Crawfish Draw - Border 345kV CKT 2 Build approximately 194 miles of second circuit 345kV from TUCO 2 - Border | Current Study | \$9,626,112 | \$194,000,000 |
| GEN-2014-074 Tap Dynamic Reactive Power Support 34.5kV STATCOM at GEN-2014-074 | Current Study | \$150,402 | \$3,000,000 |
| GEN-2015-058 Interconnection Costs See One-Line Diagram. | Current Study | \$2,751,641 | \$2,751,641 |
| Grapevine - Nichols 230kV CKT 1 Replace terminal equipment | Current Study | \$22,262 | \$400,000 |
| Grapevine - Wheeler 230kV CKT 1 Replace terminal equipment | Current Study | \$13,921 | \$400,000 |
| Oklaunion 345kV Reactive Power Support Incremental Upgrade Install +/-100Mvar SVC at Oklaunion | Current Study | \$992,383 | \$20,000,000 |
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$199,353 | \$6,000,000 |
| 2016 ITPNT Upgrade(s) 2016 ITPNT Upgrade(s) for mitigation of stability constraints near Mustang and Seminole | Previously Allocated | | \$0 |
| Amoco Wasson - Oxy Tap 230kV CKT 1 Replace line traps at both terminals | Previously Allocated | | \$200,000 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |
| Crawfish Draw Substation Upgrade 345/230kV Tap Border-TUCO approximately 2 miles from TUCO and build Crawfish Draw 345kV substation and add 345/230/13.2kV transformer and tie on TUCO-Swisher 230kV. | Previously Allocated | | \$24,764,205 |
| Elk City 230/138/13kV Transformer CKT 1 Replace terminal equipment for Elk City Transformer to achieve transformer limit of 450MVA. | Previously Allocated | | \$15,000,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| Oklaunion 345kV Reactive Power Install (2)-130Mvar Capacitor Bank(s) at Oklaunion | Previously Allocated | | \$10,000,000 |
| Potash Junction 230kV Reactive Power Support Build Potash Junction 100Mvar Capacitor bank per 2015 ITPNT. | Previously Allocated | | \$6,465,875 |
| Tolk - Plant X 230kV CKT 1 & 2 Rebuild circuit 1 and 2 between Tolk - Plant X 230kV to 1200 amps each. | Previously Allocated | | \$9,921,693 |
| TUCO 345/230/13.2kV Transformer CKT 1 Replace existing TUCO 345/230/13.2kV Transformer circuit #1 with 640MVA. | Previously Allocated | | \$3,347,036 |
| | Current Study Total | \$17,351,649 | |

GEN-2015-059

| | | | |
|--|----------------------------|----------------|-------------|
| GEN-2015-059 Interconnection Costs See One-Line Diagram. | Current Study | \$0 | \$0 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$6,856 | \$750,000 |
| Bucker - Spearville 345V CKT 1 Replace Terminal equipment | Previously Allocated | | \$1,480,238 |
| Cimarron - Draper Lake 345kV CKT 1 Replace terminal equipment to at least 2000A assigned in 2015 ITP10 per SPP-NTC-200329 | Previously Allocated | | \$1,500,000 |
| Woodward EHV Phase Shifting Transformer CKT 1 Install one phase shifting transformer at Woodward | Previously Allocated | | \$7,200,000 |
| | Current Study Total | \$6,856 | |

GEN-2015-060

| | | | |
|--|---------------|-------------|--------------|
| Cleo Corner - Cleo Plant Tap 138kV CKT 1 Replace terminal equipment to at least 1200 amps | Current Study | \$26,015 | \$500,000 |
| GEN-2015-060 Interconnection Costs See One-Line Diagram. | Current Study | \$943,000 | \$943,000 |
| GEN-2015-095 Tap - Rose Valley 138kV CKT 1 Rebuild approximately 14 miles of 138kV from Rose Valley to GEN-2015-095 Tap | Current Study | \$1,035,126 | \$10,000,000 |
| Noel SW - Rose Valley 138kV CKT 1 Rebuild approximately 7 miles of 138kV from Noel SW to Rose Valley | Current Study | \$517,563 | \$5,000,000 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$45,653 | \$750,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------------|-----------------------|---------------------|
| Woodward 345/138/13kV Transformer CKT 1 Replace Woodward 345/138/13kV Transformer circuit #1 | Current Study | \$11,629,339 | \$15,000,000 |
| Woodward 345/138/13kV Transformer CKT 2 Replace Woodward 345/138/13kV Transformer circuit #2 | Current Study | \$11,629,289 | \$15,000,000 |
| Bucker - Spearville 345V CKT 1 Replace Terminal equipment | Previously Allocated | | \$1,480,238 |
| Mathewson - Cimarron 345kV CKT 2 Build second 345kV circuit from Mathewson - Cimarron @ 3000 amps per ITP10. | Previously Allocated | | \$42,903,753 |
| Tatonga - Mathewson 345kV CKT 2 Build second 345kV circuit from Tatonga - Mathewson @ 3000 amps per ITP10. | Previously Allocated | | \$104,260,473 |
| Woodward - GEN-2011-051 Tap - Tatonga 345kV CKT 2 Build second 345kV circuit from Woodward - Tatonga @ 3000 amps per ITP10. | Previously Allocated | | \$71,876,622 |
| Woodward EHV Phase Shifting Transformer CKT 1 Install one phase shifting transformer at Woodward | Previously Allocated | | \$7,200,000 |
| | Current Study Total | \$25,825,986 | |
| GEN-2015-061 | | | |
| GEN-2015-061 Interconnection Costs See One-Line Diagram. | Current Study | \$6,988,986 | \$6,988,986 |
| | Current Study Total | \$6,988,986 | |
| GEN-2015-062 | | | |
| Cleveland - Cleveland 138kV CKT Z1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |
| GEN-2015-062 Interconnection Costs See One-Line Diagram. | Current Study | \$TBD | \$TBD |
| GEN-2015-063 Tap - Mathewson 345kV CKT 1 Replace terminal equipment to achieve conductor limit | Current Study | \$4,142 | \$1,000,000 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$428 | \$750,000 |
| | Current Study Total | \$4,571 | |
| GEN-2015-063 | | | |
| Cleveland - Cleveland 138kV CKT Z1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| GEN-2015-063 Interconnection Costs See One-Line Diagram. | Current Study | \$10,613,000 | \$10,613,000 |
| GEN-2015-063 Tap - Mathewson 345kV CKT 1 Replace terminal equipment to achieve conductor limit | Current Study | \$830,196 | \$1,000,000 |
| | Current Study Total | \$11,443,196 | |
| <hr/> | | | |
| GEN-2015-064 | | | |
| GEN-2015-064 Interconnection Costs See One-Line Diagram. | Current Study | \$4,638,823 | \$4,638,823 |
| | Current Study Total | \$4,638,823 | |
| <hr/> | | | |
| GEN-2015-065 | | | |
| GEN-2015-065 Interconnection Costs See One-Line Diagram. | Current Study | \$6,988,986 | \$6,988,986 |
| | Current Study Total | \$6,988,986 | |
| <hr/> | | | |
| GEN-2015-066 | | | |
| Cleveland - Cleveland 138kV CKT Z1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |
| Cleveland - Silver City 138kV CKT 1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |
| GEN-2015-066 Interconnection Costs See One-Line Diagram. | Current Study | \$10,613,000 | \$10,613,000 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$70,168 | \$750,000 |
| | Current Study Total | \$10,683,168 | |
| <hr/> | | | |
| GEN-2015-067 | | | |
| Cleveland - Cleveland 138kV CKT Z1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |
| GEN-2015-067 Interconnection Costs See One-Line Diagram. | Current Study | \$3,521,000 | \$3,521,000 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$35,646 | \$750,000 |
| | Current Study Total | \$3,556,646 | |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------|----------------|---------------|
| GEN-2015-068 | | | |
| Border - Chisholm 345kV CKT 2 Build approximately 25 miles of second circuit 345kV from Border - Chisholm | Current Study | \$9,020,898 | \$25,000,000 |
| Border 345kV Reactive Power Support Install (6)Steps of 50Mvar Capacitor Bank(s) and +300Mvar SVC at Border Substation | Current Study | \$12,103,039 | \$35,000,000 |
| Chisholm Substation Upgrade 345kV Expand planned Chisholm Substation to tap and terminate Woodward - Border 345kV into the Chisholm Substation | Current Study | \$4,330,105 | \$12,000,000 |
| Crawfish Draw - Border 345kV CKT 2 Build approximately 194 miles of second circuit 345kV from TUCO 2 - Border | Current Study | \$69,318,271 | \$194,000,000 |
| GEN-2014-074 Tap Dynamic Reactive Power Support 34.5kV STATCOM at GEN-2014-074 | Current Study | \$1,037,403 | \$3,000,000 |
| GEN-2015-068 Interconnection Costs See One-Line Diagram. | Current Study | \$3,303,965 | \$3,303,965 |
| Grapevine - Nichols 230kV CKT 1 Replace terminal equipment | Current Study | \$85,608 | \$400,000 |
| Grapevine - Wheeler 230kV CKT 1 Replace terminal equipment | Current Study | \$52,883 | \$400,000 |
| Oklaunion 345kV Reactive Power Support Incremental Upgrade Install +/-100Mvar SVC at Oklaunion | Current Study | \$7,146,213 | \$20,000,000 |
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$756,014 | \$6,000,000 |
| 2016 ITPNT Upgrade(s) 2016 ITPNT Upgrade(s) for mitigation of stability constraints near Mustang and Seminole | Previously Allocated | | \$0 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |
| Elk City 230/138/13kV Transformer CKT 1 Replace terminal equipment for Elk City Transformer to achieve transformer limit of 450MVA. | Previously Allocated | | \$15,000,000 |
| Kress Interchange - Swisher 115kV CKT 1 Replace terminal equipment | Previously Allocated | | \$500,000 |
| National Enrichment Plant-Targa 115kV CKT 1 Rebuild approximately 4 miles of 115kV from National Enrichment Plant to Targa per 2015 ITPNT. | Previously Allocated | | \$2,909,669 |
| Oklaunion 345kV Reactive Power Install (2)-130Mvar Capacitor Bank(s) at Oklaunion | Previously Allocated | | \$10,000,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| Targa-Cardinal 115kV CKT 1 Rebuild approximately 3 miles of 115kV from Targa to Cardinal per 2015 ITPNT. | Previously Allocated | | \$2,049,062 |
| Tolk - Plant X 230kV CKT 1 & 2 Rebuild circuit 1 and 2 between Tolk - Plant X 230kV to 1200 amps each. | Previously Allocated | | \$9,921,693 |
| | Current Study Total | \$107,154,399 | |

GEN-2015-069

| | | | |
|---|----------------------------|-------------|-------------|
| Emporia Energy Center - Swissvale 345kV CKT 1 Replace terminal equipment to at least 1600 amps (Cost included in Swissvale - West Gardner 345kV Line Item) | Current Study | \$0 | \$0 |
| GEN-2015-069 Interconnection Costs See One-Line Diagram. | Current Study | \$2,755,752 | \$2,755,752 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$3,707 | \$750,000 |
| Swissvale - West Gardner 345kV CKT 1 Replace terminal equipment to at least 1600 amps | Current Study | \$489,514 | \$1,000,000 |
| | Current Study Total | \$3,248,974 | |

GEN-2015-071

| | | | |
|--|----------------------------|--------------|---------------|
| GEN-2015-071 Interconnection Costs See One-Line Diagram. | Current Study | \$14,623,541 | \$14,623,541 |
| Grapevine - Wheeler 230kV CKT 1 Replace terminal equipment | Current Study | \$129,592 | \$400,000 |
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$1,884,339 | \$6,000,000 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |
| | Current Study Total | \$16,637,472 | |

GEN-2015-073

| | | | |
|---|---------------|-------------|-------------|
| Emporia Energy Center - Swissvale 345kV CKT 1 Replace terminal equipment to at least 1600 amps (Cost included in Swissvale - West Gardner 345kV Line Item) | Current Study | \$0 | \$0 |
| GEN-2015-073 Interconnection Costs See One-Line Diagram. | Current Study | \$2,576,628 | \$2,576,628 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$4,366 | \$750,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| Swissvale - West Gardner 345kV CKT 1 Replace terminal equipment to at least 1600 amps | Current Study | \$510,486 | \$1,000,000 |
| | Current Study Total | \$3,091,479 | |
| GEN-2015-075 | | | |
| Border - Chisholm 345kV CKT 2 Build approximately 25 miles of second circuit 345kV from Border - Chisholm | Current Study | \$1,400,105 | \$25,000,000 |
| Border 345kV Reactive Power Support Install (6)Steps of 50Mvar Capacitor Bank(s) and +300Mvar SVC at Border Substation | Current Study | \$1,918,364 | \$35,000,000 |
| Carlisle 115/69/13kV Transformer CKT 1 Replace existing Carlisle 115/69/13kV Transformer circuit #1 | Current Study | \$4,000,000 | \$4,000,000 |
| Chisholm Substation Upgrade 345kV Expand planned Chisholm Substation to tap and terminate Woodward - Border 345kV into the Chisholm Substation | Current Study | \$671,856 | \$12,000,000 |
| Crawfish Draw - Border 345kV CKT 2 Build approximately 194 miles of second circuit 345kV from TUCO 2 - Border | Current Study | \$10,799,709 | \$194,000,000 |
| GEN-2014-074 Tap Dynamic Reactive Power Support 34.5kV STATCOM at GEN-2014-074 | Current Study | \$164,431 | \$3,000,000 |
| GEN-2015-075 Interconnection Costs See One-Line Diagram. | Current Study | \$5,000,000 | \$5,000,000 |
| Grapevine - Nichols 230kV CKT 1 Replace terminal equipment | Current Study | \$19,412 | \$400,000 |
| Grapevine - Wheeler 230kV CKT 1 Replace terminal equipment | Current Study | \$12,089 | \$400,000 |
| Oklauion 345kV Reactive Power Support Incremental Upgrade Install +/-100Mvar SVC at Oklauion | Current Study | \$1,113,372 | \$20,000,000 |
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$173,024 | \$6,000,000 |
| 2016 ITPNT Upgrade(s) 2016 ITPNT Upgrade(s) for mitigation of stability constraints near Mustang and Seminole | Previously Allocated | | \$0 |
| Amoco Wasson - Oxy Tap 230kV CKT 1 Replace line traps at both terminals | Previously Allocated | | \$200,000 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------------|-----------------------|---------------------|
| Crawfish Draw Substation Upgrade 345/230kV Tap Border-TUCO approximately 2 miles from TUCO and build Crawfish Draw 345kV substation and add 345/230/13.2kV transformer and tie on TUCO-Swisher 230kV. | Previously Allocated | | \$24,764,205 |
| Elk City 230/138/13kV Transformer CKT 1 Replace terminal equipment for Elk City Transformer to achieve transformer limit of 450MVA. | Previously Allocated | | \$15,000,000 |
| National Enrichment Plant-Targa 115kV CKT 1 Rebuild approximately 4 miles of 115kV from National Enrichment Plant to Targa per 2015 ITPNT. | Previously Allocated | | \$2,909,669 |
| Oklaunion 345kV Reactive Power Install (2)-130Mvar Capacitor Bank(s) at Oklaunion | Previously Allocated | | \$10,000,000 |
| Targa-Cardinal 115kV CKT 1 Rebuild approximately 3 miles of 115kV from Targa to Cardinal per 2015 ITPNT. | Previously Allocated | | \$2,049,062 |
| Tolk - Plant X 230kV CKT 1 & 2 Rebuild circuit 1 and 2 between Tolk - Plant X 230kV to 1200 amps each. | Previously Allocated | | \$9,921,693 |
| TUCO 345/230/13.2kV Transformer CKT 1 Replace existing TUCO 345/230/13.2kV Transformer circuit #1 with 640MVA. | Previously Allocated | | \$3,347,036 |
| | Current Study Total | \$25,272,363 | |
| GEN-2015-076 | | | |
| Gavins Point - Yankton Junction 115kV CKT 1 Rebuild approximately 5 miles of 115kV from Gavins to Yankton | Current Study | \$5,000,000 | \$5,000,000 |
| GEN-2015-076 Interconnection Costs See One-Line Diagram. | Current Study | \$2,600,000 | \$2,600,000 |
| Gentleman - Thedford 345kV CKT 1 Build approximately 76 Miles of 345kV from Gentleman to Thedford per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Hoskins - Dixon County - Twin Church 230kV Rerate per NPPD Facility Study | Previously Allocated | | \$500,000 |
| Hoskins - Neligh 345/115kV Projects Per SPP 2014 ITP NT and NTC 200253 for 6/1/2016 in-service. | Previously Allocated | | \$98,697,720 |
| Thedford - Holt County 345kV CKT 1 Build approximately 146 Miles of 345kV from Thedford to Holt County per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Thedford 345/115kV Transformer CKT 1 Install Thedford 345/115kV transformer per SPP-NTC-200277 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| | Current Study Total | \$7,600,000 | |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------|----------------|---------------|
| GEN-2015-079 | | | |
| Border - Chisholm 345kV CKT 2 Build approximately 25 miles of second circuit 345kV from Border - Chisholm | Current Study | \$3,361,132 | \$25,000,000 |
| Border 345kV Reactive Power Support Install (6)Steps of 50Mvar Capacitor Bank(s) and +300Mvar SVC at Border Substation | Current Study | \$4,680,457 | \$35,000,000 |
| Chisholm Substation Upgrade 345kV Expand planned Chisholm Substation to tap and terminate Woodward - Border 345kV into the Chisholm Substation | Current Study | \$1,613,371 | \$12,000,000 |
| Crawfish Draw - Border 345kV CKT 2 Build approximately 194 miles of second circuit 345kV from TUCO 2 - Border | Current Study | \$25,964,901 | \$194,000,000 |
| GEN-2014-074 Tap Dynamic Reactive Power Support 34.5kV STATCOM at GEN-2014-074 | Current Study | \$401,182 | \$3,000,000 |
| GEN-2015-079 Interconnection Costs See One-Line Diagram. | Current Study | \$3,687,384 | \$3,687,384 |
| Grapevine - Nichols 230kV CKT 1 Replace terminal equipment | Current Study | \$53,040 | \$400,000 |
| Grapevine - Wheeler 230kV CKT 1 Replace terminal equipment | Current Study | \$33,103 | \$400,000 |
| Oklaunion 345kV Reactive Power Support Incremental Upgrade Install +/-100Mvar SVC at Oklaunion | Current Study | \$2,676,794 | \$20,000,000 |
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$473,918 | \$6,000,000 |
| 2016 ITPNT Upgrade(s) 2016 ITPNT Upgrade(s) for mitigation of stability constraints near Mustang and Seminole | Previously Allocated | | \$0 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |
| Crawfish Draw Substation Upgrade 345/230kV Tap Border-TUCO approximately 2 miles from TUCO and build Crawfish Draw 345kV substation and add 345/230/13.2kV transformer and tie on TUCO-Swisher 230kV. | Previously Allocated | | \$24,764,205 |
| Elk City 230/138/13kV Transformer CKT 1 Replace terminal equipment for Elk City Transformer to achieve transformer limit of 450MVA. | Previously Allocated | | \$15,000,000 |
| National Enrichment Plant-Targa 115kV CKT 1 Rebuild approximately 4 miles of 115kV from National Enrichment Plant to Targa per 2015 ITPNT. | Previously Allocated | | \$2,909,669 |
| Oklaunion 345kV Reactive Power Install (2)-130Mvar Capacitor Bank(s) at Oklaunion | Previously Allocated | | \$10,000,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| Targa-Cardinal 115kV CKT 1 Rebuild approximately 3 miles of 115kV from Targa to Cardinal per 2015 ITPNT. | Previously Allocated | | \$2,049,062 |
| Tolk - Plant X 230kV CKT 1 & 2 Rebuild circuit 1 and 2 between Tolk - Plant X 230kV to 1200 amps each. | Previously Allocated | | \$9,921,693 |
| TUCO 345/230/13.2kV Transformer CKT 1 Replace existing TUCO 345/230/13.2kV Transformer circuit #1 with 640MVA. | Previously Allocated | | \$3,347,036 |
| | Current Study Total | \$42,945,282 | |

GEN-2015-080

| | | | |
|---|----------------------|--------------|---------------|
| Border - Chisholm 345kV CKT 2 Build approximately 25 miles of second circuit 345kV from Border - Chisholm | Current Study | \$3,361,132 | \$25,000,000 |
| Border 345kV Reactive Power Support Install (6)Steps of 50Mvar Capacitor Bank(s) and +300Mvar SVC at Border Substation | Current Study | \$4,680,457 | \$35,000,000 |
| Chisholm Substation Upgrade 345kV Expand planned Chisholm Substation to tap and terminate Woodward - Border 345kV into the Chisholm Substation | Current Study | \$1,613,371 | \$12,000,000 |
| Crawfish Draw - Border 345kV CKT 2 Build approximately 194 miles of second circuit 345kV from TUCO 2 - Border | Current Study | \$25,964,901 | \$194,000,000 |
| GEN-2014-074 Tap Dynamic Reactive Power Support 34.5kV STATCOM at GEN-2014-074 | Current Study | \$401,182 | \$3,000,000 |
| GEN-2015-080 Interconnection Costs See One-Line Diagram. | Current Study | \$3,687,384 | \$3,687,384 |
| Grapevine - Nichols 230kV CKT 1 Replace terminal equipment | Current Study | \$53,040 | \$400,000 |
| Grapevine - Wheeler 230kV CKT 1 Replace terminal equipment | Current Study | \$33,103 | \$400,000 |
| Oklauion 345kV Reactive Power Support Incremental Upgrade Install +/-100Mvar SVC at Oklauion | Current Study | \$2,676,794 | \$20,000,000 |
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$473,918 | \$6,000,000 |
| 2016 ITPNT Upgrade(s) 2016 ITPNT Upgrade(s) for mitigation of stability constraints near Mustang and Seminole | Previously Allocated | | \$0 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------------|-----------------------|---------------------|
| Crawfish Draw Substation Upgrade 345/230kV Tap Border-TUCO approximately 2 miles from TUCO and build Crawfish Draw 345kV substation and add 345/230/13.2kV transformer and tie on TUCO-Swisher 230kV. | Previously Allocated | | \$24,764,205 |
| Elk City 230/138/13kV Transformer CKT 1 Replace terminal equipment for Elk City Transformer to achieve transformer limit of 450MVA. | Previously Allocated | | \$15,000,000 |
| National Enrichment Plant-Targa 115kV CKT 1 Rebuild approximately 4 miles of 115kV from National Enrichment Plant to Targa per 2015 ITPNT. | Previously Allocated | | \$2,909,669 |
| Oklaunion 345kV Reactive Power Install (2)-130Mvar Capacitor Bank(s) at Oklaunion | Previously Allocated | | \$10,000,000 |
| Targa-Cardinal 115kV CKT 1 Rebuild approximately 3 miles of 115kV from Targa to Cardinal per 2015 ITPNT. | Previously Allocated | | \$2,049,062 |
| Tolk - Plant X 230kV CKT 1 & 2 Rebuild circuit 1 and 2 between Tolk - Plant X 230kV to 1200 amps each. | Previously Allocated | | \$9,921,693 |
| TUCO 345/230/13.2kV Transformer CKT 1 Replace existing TUCO 345/230/13.2kV Transformer circuit #1 with 640MVA. | Previously Allocated | | \$3,347,036 |
| | Current Study Total | \$42,945,282 | |
| GEN-2015-081 | | | |
| Cleo Corner - Cleo Plant Tap 138kV CKT 1 Replace terminal equipment to at least 1200 amps | Current Study | \$6,912 | \$500,000 |
| GEN-2015-081 Interconnection Costs See One-Line Diagram. | Current Study | \$3,005,000 | \$3,005,000 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$32,519 | \$750,000 |
| Bucker - Spearville 345V CKT 1 Replace Terminal equipment | Previously Allocated | | \$1,480,238 |
| Mathewson - Cimarron 345kV CKT 2 Build second 345kV circuit from Mathewson - Cimarron @ 3000 amps per ITP10. | Previously Allocated | | \$42,903,753 |
| Tatonga - Mathewson 345kV CKT 2 Build second 345kV circuit from Tatonga - Mathewson @ 3000 amps per ITP10. | Previously Allocated | | \$104,260,473 |
| Woodward - GEN-2011-051 Tap - Tatonga 345kV CKT 2 Build second 345kV circuit from Woodward - Tatonga @ 3000 amps per ITP10. | Previously Allocated | | \$71,876,622 |
| Woodward EHV Phase Shifting Transformer CKT 1 Install one phase shifting transformer at Woodward | Previously Allocated | | \$7,200,000 |
| | Current Study Total | \$3,044,432 | |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------------|-----------------------|---------------------|
| GEN-2015-083 | | | |
| Cleveland - Cleveland 138kV CKT Z1 AECI Affected System Study is required | Current Study | \$TBD | \$TBD |
| GEN-2015-083 Interconnection Costs See One-Line Diagram. | Current Study | \$6,713,963 | \$6,713,963 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$10,095 | \$750,000 |
| | Current Study Total | \$6,724,058 | |
| GEN-2015-084 | | | |
| Cornville Tap - Naples Tap 138kV CKT 1 Rebuild approximately 11 miles of 138kV from Cornville Tap to Naples Tap | Current Study | \$1,865,168 | \$7,700,000 |
| GEN-2015-084 Interconnection Costs See One-Line Diagram. | Current Study | \$14,665,056 | \$14,665,056 |
| Naples Tap - Payne 138kV CKT 1 Rebuild approximately 8 miles of 138kV from Naples Tap to Payne | Current Study | \$1,356,486 | \$5,600,000 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |
| | Current Study Total | \$17,886,710 | |
| GEN-2015-085 | | | |
| Cornville Tap - Naples Tap 138kV CKT 1 Rebuild approximately 11 miles of 138kV from Cornville Tap to Naples Tap | Current Study | \$5,834,832 | \$7,700,000 |
| GEN-2015-085 Interconnection Costs See One-Line Diagram. | Current Study | \$8,406,414 | \$8,406,414 |
| Naples Tap - Payne 138kV CKT 1 Rebuild approximately 8 miles of 138kV from Naples Tap to Payne | Current Study | \$4,243,514 | \$5,600,000 |
| Norge - Southwest Station 138kV CKT 1 Rebuild approximately 23 miles of 138kV from Norge to Southwest Station | Current Study | \$23,000,000 | \$23,000,000 |
| Wheeler - Sweetwater 230kV CKT 1 Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion | Current Study | \$241,254 | \$6,000,000 |
| Chisholm - Gracemont 345kV CKT 1 Per SPP-NTC-200255 and 200240 (Total Project E&C Cost Shown) | Previously Allocated | | \$162,952,357 |
| | Current Study Total | \$41,726,014 | |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------------|---------------------|---------------|
| GEN-2015-087 | | | |
| GEN-2015-087 Interconnection Costs See One-Line Diagram. | Current Study | \$5,300,000 | \$5,300,000 |
| Gentleman - Thedford 345kV CKT 1 Build approximately 76 Miles of 345kV from Gentleman to Thedford per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Gentleman - Thedford 345kV CKT 1 Build approximately 76 Miles of 345kV from Gentleman to Thedford per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Thedford - Holt County 345kV CKT 1 Build approximately 146 Miles of 345kV from Thedford to Holt County per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Twin Church - Dixon County 230kV Increase conductor clearances to accommodate 320MVA facility rating | Previously Allocated | | \$100,000 |
| | Current Study Total | \$5,300,000 | |
| GEN-2015-088 | | | |
| GEN-2015-088 Interconnection Costs See One-Line Diagram. | Current Study | \$15,000,000 | \$15,000,000 |
| Gentleman - Thedford 345kV CKT 1 Build approximately 76 Miles of 345kV from Gentleman to Thedford per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Gentleman - Thedford 345kV CKT 1 Build approximately 76 Miles of 345kV from Gentleman to Thedford per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Thedford - Holt County 345kV CKT 1 Build approximately 146 Miles of 345kV from Thedford to Holt County per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Thedford - Holt County 345kV CKT 1 Build approximately 146 Miles of 345kV from Thedford to Holt County per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Twin Church - Dixon County 230kV Increase conductor clearances to accommodate 320MVA facility rating | Previously Allocated | | \$100,000 |
| | Current Study Total | \$15,000,000 | |
| GEN-2015-090 | | | |
| GEN-2015-090 Interconnection Costs See One-Line Diagram. | Current Study | \$16,021 | \$16,021 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$1,877 | \$750,000 |
| | Current Study Total | \$17,898 | |
| GEN-2015-091 | | | |
| Daglum - Dickinson 230kV CKT 1 Build new 230kV line from Daglum - Dickinson. | Current Study | \$9,471,433 | \$28,000,000 |
| Dickinson 230/115/13.8kV CKT 2 Build new 230/115/13.8kV Transformer circuit #2 at Dickinson. | Current Study | \$794,317 | \$3,500,000 |
| GEN-2015-091 Interconnection Costs See One-Line Diagram. | Current Study | \$3,224,682 | \$3,224,682 |
| Hanlon 69kV Reactive Support Install (1) 10Mvar Capacitor Bank at Hanlon 69kV. | Current Study | \$77,492 | \$500,000 |
| MISO Affected System Study See section 4 power flow analysis. | Current Study | \$TBD | \$TBD |
| Gentleman - Thedford 345kV CKT 1 Build approximately 76 Miles of 345kV from Gentleman to Thedford per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Neset - Tande 230kV CKT 1 Build new 230kV line from Neset - Tande | Previously Allocated | | \$3,000,000 |
| Neset 230kV Terminal Upgrade(s) Install necessary terminal equInstall necessary terminal upgrades at Neset 230kV to accommodate new 230kV line from new Tande substation | Previously Allocated | | \$4,000,000 |
| Patent Gate - Kummer Ridge - Roundup Project | Previously Allocated | | \$TBD |
| Tande 345/230 Substation Construct new 345kV Tande Substation & Tande 345/230/13kV transformer Construct new 345kV Tande Substation adjacent to the existing 230kV Neset Substation and | Previously Allocated | | \$18,000,000 |
| Thedford - Holt County 345kV CKT 1 Build approximately 146 Miles of 345kV from Thedford to Holt County per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Thedford 345/115kV Transformer CKT 1 Install Thedford 345/115kV transformer per SPP-NTC-200277 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| | Current Study Total | \$13,567,924 | |

GEN-2015-092

| | | | |
|---|---------------|-------------|-------------|
| GEN-2015-092 Interconnection Costs See One-Line Diagram. | Current Study | \$1,110,612 | \$1,110,612 |
|---|---------------|-------------|-------------|

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|--|----------------------------|----------------|---------------|
| | Current Study Total | \$1,110,612 | |
| GEN-2015-093 | | | |
| GEN-2015-093 Interconnection Costs See One-Line Diagram. | Current Study | \$2,125,000 | \$2,125,000 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$220,608 | \$750,000 |
| Bucker - Spearville 345V CKT 1 Replace Terminal equipment | Previously Allocated | | \$1,480,238 |
| Woodward EHV Phase Shifting Transformer CKT 1 Install one phase shifting transformer at Woodward | Previously Allocated | | \$7,200,000 |
| | Current Study Total | \$2,345,608 | |
| GEN-2015-095 | | | |
| Cleo Corner - Cleo Plant Tap 138kV CKT 1 Replace terminal equipment to at least 1200 amps | Current Study | \$65,458 | \$500,000 |
| GEN-2015-095 Interconnection Costs See One-Line Diagram. | Current Study | \$4,400,000 | \$4,400,000 |
| GEN-2015-095 Tap - Rose Valley 138kV CKT 1 Rebuild approximately 14 miles of 138kV from Rose Valley to GEN-2015-095 Tap | Current Study | \$8,964,874 | \$10,000,000 |
| Noel SW - Rose Valley 138kV CKT 1 Rebuild approximately 7 miles of 138kV from Noel SW to Rose Valley | Current Study | \$4,482,437 | \$5,000,000 |
| Northwest 138kV Circuit Breaker Replace Northwest 138kV Circuit Breaker for short circuit requirements | Current Study | \$23,126 | \$750,000 |
| Woodward 345/138/13kV Transformer CKT 1 Replace Woodward 345/138/13kV Transformer circuit #1 | Current Study | \$3,370,661 | \$15,000,000 |
| Woodward 345/138/13kV Transformer CKT 2 Replace Woodward 345/138/13kV Transformer circuit #2 | Current Study | \$3,370,711 | \$15,000,000 |
| Mathewson - Cimarron 345kV CKT 2 Build second 345kV circuit from Mathewson - Cimarron @ 3000 amps per ITP10. | Previously Allocated | | \$42,903,753 |
| Tatonga - Mathewson 345kV CKT 2 Build second 345kV circuit from Tatonga - Mathewson @ 3000 amps per ITP10. | Previously Allocated | | \$104,260,473 |
| Woodward - GEN-2011-051 Tap - Tatonga 345kV CKT 2 Build second 345kV circuit from Woodward - Tatonga @ 3000 amps per ITP10. | Previously Allocated | | \$71,876,622 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| Woodward EHV Phase Shifting Transformer CKT 1 Install one phase shifting transformer at Woodward | Previously Allocated | | \$7,200,000 |
| | Current Study Total | \$24,677,267 | |
| GEN-2015-096 | | | |
| Daglum - Dickinson 230kV CKT 1 Build new 230kV line from Daglum - Dickinson. | Current Study | \$14,038,685 | \$28,000,000 |
| Dickinson 230/115/13.8kV CKT 2 Build new 230/115/13.8kV Transformer circuit #2 at Dickinson. | Current Study | \$1,177,348 | \$3,500,000 |
| GEN-2015-096 Interconnection Costs See One-Line Diagram. | Current Study | \$0 | \$0 |
| Hanlon 69kV Reactive Support Install (1) 10Mvar Capacitor Bank at Hanlon 69kV. | Current Study | \$114,859 | \$500,000 |
| MISO Affected System Study See section 4 power flow analysis. | Current Study | \$TBD | \$TBD |
| Gentleman - Thedford 345kV CKT 1 Build approximately 76 Miles of 345kV from Gentleman to Thedford per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Neset - Tande 230kV CKT 1 Build new 230kV line from Neset - Tande | Previously Allocated | | \$3,000,000 |
| Neset 230kV Terminal Upgrade(s) Install necessary terminal equInstall necessary terminal upgrades at Neset 230kV to accommodate new 230kV line from new Tande substation | Previously Allocated | | \$4,000,000 |
| Patent Gate - Kummer Ridge - Roundup Project | Previously Allocated | | \$TBD |
| Tande 345/230 Substation Construct new 345kV Tande Substation & Tande 345/230/13kV transformer Construct new 345kV Tande Substation adjacent to the existing 230kV Neset Substation and | Previously Allocated | | \$18,000,000 |
| Thedford - Holt County 345kV CKT 1 Build approximately 146 Miles of 345kV from Thedford to Holt County per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Thedford 345/115kV Transformer CKT 1 Install Thedford 345/115kV transformer per SPP-NTC-200277 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| | Current Study Total | \$15,330,892 | |

GEN-2015-097

| | | | |
|---|---------------|-------------|-------------|
| GEN-2015-097 Interconnection Costs See One-Line Diagram. | Current Study | \$3,000,000 | \$3,000,000 |
|---|---------------|-------------|-------------|

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| Interconnection Request and Upgrades | Upgrade Type | Allocated Cost | Upgrade Cost |
|---|----------------------------|-----------------------|---------------------|
| MISO Affected System Study See section 4 power flow analysis. | Current Study | \$TBD | \$TBD |
| | Current Study Total | \$3,000,000 | |
| GEN-2015-098 | | | |
| Daglum - Dickinson 230kV CKT 1 Build new 230kV line from Daglum - Dickinson. | Current Study | \$2,456,586 | \$28,000,000 |
| Dickinson 230/115/13.8kV CKT 2 Build new 230/115/13.8kV Transformer circuit #2 at Dickinson. | Current Study | \$579,565 | \$3,500,000 |
| GEN-2015-098 Interconnection Costs See One-Line Diagram. | Current Study | \$3,000,000 | \$3,000,000 |
| Hanlon 69kV Reactive Support Install (1) 10Mvar Capacitor Bank at Hanlon 69kV. | Current Study | \$76,983 | \$500,000 |
| MISO Affected System Study See section 4 power flow analysis. | Current Study | \$TBD | \$TBD |
| Gentleman - Thedford 345kV CKT 1 Build approximately 76 Miles of 345kV from Gentleman to Thedford per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Neset - Tande 230kV CKT 1 Build new 230kV line from Neset - Tande | Previously Allocated | | \$3,000,000 |
| Neset 230kV Terminal Upgrade(s) Install necessary terminal equInstall necessary terminal upgrades at Neset 230kV to accommodate new 230kV line from new Tande substation | Previously Allocated | | \$4,000,000 |
| Patent Gate - Kummer Ridge - Roundup Project | Previously Allocated | | \$TBD |
| Tande 345/230 Substation Construct new 345kV Tande Substation & Tande 345/230/13kV transformer Construct new 345kV Tande Substation adjacent to the existing 230kV Neset Substation and | Previously Allocated | | \$18,000,000 |
| Thedford - Holt County 345kV CKT 1 Build approximately 146 Miles of 345kV from Thedford to Holt County per SPP-NTC-200220 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| Thedford 345/115kV Transformer CKT 1 Install Thedford 345/115kV transformer per SPP-NTC-200277 (Total Project E&C Cost Shown). | Previously Allocated | | \$311,717,040 |
| | Current Study Total | \$6,113,133 | |
| TOTAL CURRENT STUDY COSTS: | | \$677,958,271* | |

* Does not include cost to mitigate possible AECl, MISO, and/or MPC Affected System Upgrade(s) or cost estimate(s)

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

11.6 F: Cost Allocation per Proposed Study Network Upgrade

Important Note:

****WITHDRAWAL OF HIGHER QUEUED PROJECTS WILL CAUSE A RESTUDY
AND MAY RESULT IN HIGHER INTERCONNECTION COSTS****

This section shows each Direct Assigned Facility and Network Upgrade and the Generation Interconnection Request Customer(s) which have an impact in this study assuming all higher queued projects remain in the queue and achieve commercial operation.

The required interconnection costs listed do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP OATT. In addition, costs associated with a short circuit analysis will be allocated should the Interconnection Request Customer choose to execute a Facility Study Agreement.

There may be additional costs allocated to each Customer. See Appendix E for more details.

Appendix F. Cost Allocation by Upgrade

ASGI-2015-006 Interconnection Costs \$0

See One-Line Diagram.

ASGI-2015-006 \$0

Total Allocated Costs \$0

Beaver County 345kV Reactive Power Support \$25,000,000

Install +100Mvar SVC at Beaver County Substation.

GEN-2014-037 \$25,000,000

Total Allocated Costs \$25,000,000

Border - Chisholm 345kV CKT 2 \$25,000,000

Build approximately 25 miles of second circuit 345kV from Border - Chisholm

GEN-2015-020 \$2,266,649

GEN-2015-031 \$1,943,934

GEN-2015-056 \$2,402,319

GEN-2015-058 \$1,243,832

GEN-2015-068 \$9,020,898

GEN-2015-075 \$1,400,105

GEN-2015-079 \$3,361,132

GEN-2015-080 \$3,361,132

Total Allocated Costs \$25,000,000

Border 345kV Reactive Power Support \$35,000,000

Install (6)Steps of 50Mvar Capacitor Bank(s) and +300Mvar SVC at Border Substation

GEN-2015-020 \$3,291,609

GEN-2015-031 \$3,135,053

GEN-2015-056 \$3,436,328

GEN-2015-058 \$1,754,693

GEN-2015-068 \$12,103,039

GEN-2015-075 \$1,918,364

GEN-2015-079 \$4,680,457

GEN-2015-080 \$4,680,457

Total Allocated Costs \$35,000,000

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Carlisle 115/69/13kV Transformer CKT 1 **\$4,000,000**

Replace existing Carlisle 115/69/13kV Transformer circuit #1

GEN-2015-075 \$4,000,000

Total Allocated Costs **\$4,000,000**

Chisholm Substation Upgrade 345kV **\$12,000,000**

Expand planned Chisholm Substation to tap and terminate Woodward - Border 345kV into the Chisholm Substation

GEN-2015-020 \$1,088,010

GEN-2015-031 \$933,104

GEN-2015-056 \$1,153,133

GEN-2015-058 \$597,050

GEN-2015-068 \$4,330,105

GEN-2015-075 \$671,856

GEN-2015-079 \$1,613,371

GEN-2015-080 \$1,613,371

Total Allocated Costs **\$12,000,000**

Cleo Corner - Cleo Plant Tap 138kV CKT 1 **\$500,000**

Replace terminal equipment to at least 1200 amps

GEN-2015-048 \$401,615

GEN-2015-060 \$26,015

GEN-2015-081 \$6,912

GEN-2015-095 \$65,458

Total Allocated Costs **\$500,000**

Cleveland - Cleveland 138kV CKT Z1 **\$TBD**

AECI Affected System Study is required

GEN-2015-034 \$TBD

GEN-2015-047 \$TBD

GEN-2015-052 \$TBD

GEN-2015-062 \$TBD

GEN-2015-063 \$TBD

GEN-2015-066 \$TBD

GEN-2015-067 \$TBD

GEN-2015-083 \$TBD

Total Allocated Costs **\$TBD**

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Cleveland - Silver City 138kV CKT 1**\$TBD**

AECI Affected System Study is required

| | |
|--------------|-------|
| GEN-2015-034 | \$TBD |
| GEN-2015-047 | \$TBD |
| GEN-2015-066 | \$TBD |

| | |
|------------------------------|--------------|
| Total Allocated Costs | \$TBD |
|------------------------------|--------------|

Cornville Tap - Naples Tap 138kV CKT 1**\$7,700,000**

Rebuild approximately 11 miles of 138kV from Cornville Tap to Naples Tap

| | |
|--------------|-------------|
| GEN-2015-084 | \$1,865,168 |
| GEN-2015-085 | \$5,834,832 |

| | |
|------------------------------|--------------------|
| Total Allocated Costs | \$7,700,000 |
|------------------------------|--------------------|

Crawfish Draw - Border 345kV CKT 2**\$194,000,000**

Build approximately 194 miles of second circuit 345kV from TUCO 2 - Border

| | |
|--------------|--------------|
| GEN-2015-020 | \$17,621,703 |
| GEN-2015-031 | \$16,076,755 |
| GEN-2015-056 | \$18,627,649 |
| GEN-2015-058 | \$9,626,112 |
| GEN-2015-068 | \$69,318,271 |
| GEN-2015-075 | \$10,799,709 |
| GEN-2015-079 | \$25,964,901 |
| GEN-2015-080 | \$25,964,901 |

| | |
|------------------------------|----------------------|
| Total Allocated Costs | \$194,000,000 |
|------------------------------|----------------------|

Daglum - Dickinson 230kV CKT 1**\$28,000,000**

Build new 230kV line from Daglum - Dickinson.

| | |
|--------------|--------------|
| GEN-2015-046 | \$2,033,296 |
| GEN-2015-091 | \$9,471,433 |
| GEN-2015-096 | \$14,038,685 |
| GEN-2015-098 | \$2,456,586 |

| | |
|------------------------------|---------------------|
| Total Allocated Costs | \$28,000,000 |
|------------------------------|---------------------|

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Dickinson 230/115/13.8kV CKT 2 **\$3,500,000**

Build new 230/115/13.8kV Transformer circuit #2 at Dickinson.

| | |
|--------------|-------------|
| GEN-2015-046 | \$948,770 |
| GEN-2015-091 | \$794,317 |
| GEN-2015-096 | \$1,177,348 |
| GEN-2015-098 | \$579,565 |

| | |
|------------------------------|--------------------|
| Total Allocated Costs | \$3,500,000 |
|------------------------------|--------------------|

Emporia Energy Center - Swissvale 345kV CKT 1 **\$0**

Replace terminal equipment to at least 1600 amps (Cost included in Swissvale - West Gardner 345kV Line Item)

| | |
|--------------|-----|
| GEN-2015-069 | \$0 |
| GEN-2015-073 | \$0 |

| | |
|------------------------------|------------|
| Total Allocated Costs | \$0 |
|------------------------------|------------|

Gavins Point - Yankton Junction 115kV CKT 1 **\$5,000,000**

Rebuild approximately 5 miles of 115kV from Gavins to Yankton

| | |
|--------------|-------------|
| GEN-2015-076 | \$5,000,000 |
|--------------|-------------|

| | |
|------------------------------|--------------------|
| Total Allocated Costs | \$5,000,000 |
|------------------------------|--------------------|

GEN-2014-037 Interconnection Costs **\$20,334,923**

See One-Line Diagram.

| | |
|--------------|--------------|
| GEN-2014-037 | \$20,334,923 |
|--------------|--------------|

| | |
|------------------------------|---------------------|
| Total Allocated Costs | \$20,334,923 |
|------------------------------|---------------------|

GEN-2014-074 Tap Dynamic Reactive Power Support **\$3,000,000**

34.5kV STATCOM at GEN-2014-074

| | |
|--------------|-------------|
| GEN-2015-020 | \$282,138 |
| GEN-2015-031 | \$268,719 |
| GEN-2015-056 | \$294,542 |
| GEN-2015-058 | \$150,402 |
| GEN-2015-068 | \$1,037,403 |
| GEN-2015-075 | \$164,431 |
| GEN-2015-079 | \$401,182 |
| GEN-2015-080 | \$401,182 |

| | |
|------------------------------|--------------------|
| Total Allocated Costs | \$3,000,000 |
|------------------------------|--------------------|

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| | | |
|---|------------------------------|---------------------|
| GEN-2015-020 Interconnection Costs | | \$9,984,058 |
| See One-Line Diagram. | | |
| | GEN-2015-020 | \$9,984,058 |
| | Total Allocated Costs | \$9,984,058 |
| GEN-2015-031 Interconnection Costs | | \$7,567,148 |
| See One-Line Diagram. | | |
| | GEN-2015-031 | \$7,567,148 |
| | Total Allocated Costs | \$7,567,148 |
| GEN-2015-034 Interconnection Costs | | \$2,112,500 |
| See One-Line Diagram. | | |
| | GEN-2015-034 | \$2,112,500 |
| | Total Allocated Costs | \$2,112,500 |
| GEN-2015-045 Interconnection Costs | | \$0 |
| See One-Line Diagram. | | |
| | GEN-2015-045 | \$0 |
| | Total Allocated Costs | \$0 |
| GEN-2015-046 Interconnection Costs | | \$3,759,097 |
| See One-Line Diagram. | | |
| | GEN-2015-046 | \$3,759,097 |
| | Total Allocated Costs | \$3,759,097 |
| GEN-2015-047 Interconnection Costs | | \$2,540,000 |
| See One-Line Diagram. | | |
| | GEN-2015-047 | \$2,540,000 |
| | Total Allocated Costs | \$2,540,000 |
| GEN-2015-048 Interconnection Costs | | \$2,968,000 |
| See One-Line Diagram. | | |
| | GEN-2015-048 | \$2,968,000 |
| | Total Allocated Costs | \$2,968,000 |
| GEN-2015-052 Interconnection Costs | | \$15,582,434 |
| See One-Line Diagram. | | |
| | GEN-2015-052 | \$15,582,434 |
| | Total Allocated Costs | \$15,582,434 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| | | |
|---|------------------------------|--------------------|
| GEN-2015-053 Interconnection Costs | | \$1,000,000 |
| See One-Line Diagram. | | |
| | GEN-2015-053 | \$1,000,000 |
| | Total Allocated Costs | \$1,000,000 |
| GEN-2015-055 Interconnection Costs | | \$1,900,000 |
| See One-Line Diagram. | | |
| | GEN-2015-055 | \$1,900,000 |
| | Total Allocated Costs | \$1,900,000 |
| GEN-2015-056 Interconnection Costs | | \$5,080,273 |
| See One-Line Diagram. | | |
| | GEN-2015-056 | \$5,080,273 |
| | Total Allocated Costs | \$5,080,273 |
| GEN-2015-057 Interconnection Costs | | \$20,000 |
| See One-Line Diagram. | | |
| | GEN-2015-057 | \$20,000 |
| | Total Allocated Costs | \$20,000 |
| GEN-2015-058 Interconnection Costs | | \$2,751,641 |
| See One-Line Diagram. | | |
| | GEN-2015-058 | \$2,751,641 |
| | Total Allocated Costs | \$2,751,641 |
| GEN-2015-059 Interconnection Costs | | \$0 |
| See One-Line Diagram. | | |
| | GEN-2015-059 | \$0 |
| | Total Allocated Costs | \$0 |
| GEN-2015-060 Interconnection Costs | | \$943,000 |
| See One-Line Diagram. | | |
| | GEN-2015-060 | \$943,000 |
| | Total Allocated Costs | \$943,000 |
| GEN-2015-061 Interconnection Costs | | \$6,988,986 |
| See One-Line Diagram. | | |
| | GEN-2015-061 | \$6,988,986 |
| | Total Allocated Costs | \$6,988,986 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| | | |
|---|------------------------------|---------------------|
| GEN-2015-062 Interconnection Costs | | \$0 |
| See One-Line Diagram. | | |
| | GEN-2015-062 | \$0 |
| | Total Allocated Costs | \$0 |
| GEN-2015-063 Interconnection Costs | | \$10,613,000 |
| See One-Line Diagram. | | |
| | GEN-2015-063 | \$10,613,000 |
| | Total Allocated Costs | \$10,613,000 |
| GEN-2015-063 Tap - Mathewson 345kV CKT 1 | | \$1,000,000 |
| Replace terminal equipment to achieve conductor limit | | |
| | GEN-2015-047 | \$165,661 |
| | GEN-2015-062 | \$4,142 |
| | GEN-2015-063 | \$830,196 |
| | Total Allocated Costs | \$1,000,000 |
| GEN-2015-064 Interconnection Costs | | \$4,638,823 |
| See One-Line Diagram. | | |
| | GEN-2015-064 | \$4,638,823 |
| | Total Allocated Costs | \$4,638,823 |
| GEN-2015-065 Interconnection Costs | | \$6,988,986 |
| See One-Line Diagram. | | |
| | GEN-2015-065 | \$6,988,986 |
| | Total Allocated Costs | \$6,988,986 |
| GEN-2015-066 Interconnection Costs | | \$10,613,000 |
| See One-Line Diagram. | | |
| | GEN-2015-066 | \$10,613,000 |
| | Total Allocated Costs | \$10,613,000 |
| GEN-2015-067 Interconnection Costs | | \$3,521,000 |
| See One-Line Diagram. | | |
| | GEN-2015-067 | \$3,521,000 |
| | Total Allocated Costs | \$3,521,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| | | |
|---|------------------------------|---------------------|
| GEN-2015-068 Interconnection Costs | | \$3,303,965 |
| See One-Line Diagram. | | |
| | GEN-2015-068 | \$3,303,965 |
| | Total Allocated Costs | \$3,303,965 |
| GEN-2015-069 Interconnection Costs | | \$2,755,752 |
| See One-Line Diagram. | | |
| | GEN-2015-069 | \$2,755,752 |
| | Total Allocated Costs | \$2,755,752 |
| GEN-2015-071 Interconnection Costs | | \$14,623,541 |
| See One-Line Diagram. | | |
| | GEN-2015-071 | \$14,623,541 |
| | Total Allocated Costs | \$14,623,541 |
| GEN-2015-073 Interconnection Costs | | \$2,576,628 |
| See One-Line Diagram. | | |
| | GEN-2015-073 | \$2,576,628 |
| | Total Allocated Costs | \$2,576,628 |
| GEN-2015-075 Interconnection Costs | | \$5,000,000 |
| See One-Line Diagram. | | |
| | GEN-2015-075 | \$5,000,000 |
| | Total Allocated Costs | \$5,000,000 |
| GEN-2015-076 Interconnection Costs | | \$2,600,000 |
| See One-Line Diagram. | | |
| | GEN-2015-076 | \$2,600,000 |
| | Total Allocated Costs | \$2,600,000 |
| GEN-2015-079 Interconnection Costs | | \$3,687,384 |
| See One-Line Diagram. | | |
| | GEN-2015-079 | \$3,687,384 |
| | Total Allocated Costs | \$3,687,384 |
| GEN-2015-080 Interconnection Costs | | \$3,687,384 |
| See One-Line Diagram. | | |
| | GEN-2015-080 | \$3,687,384 |
| | Total Allocated Costs | \$3,687,384 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| | | |
|---|------------------------------|---------------------|
| GEN-2015-081 Interconnection Costs | | \$3,005,000 |
| See One-Line Diagram. | | |
| | GEN-2015-081 | \$3,005,000 |
| | Total Allocated Costs | \$3,005,000 |
| GEN-2015-083 Interconnection Costs | | \$6,713,963 |
| See One-Line Diagram. | | |
| | GEN-2015-083 | \$6,713,963 |
| | Total Allocated Costs | \$6,713,963 |
| GEN-2015-084 Interconnection Costs | | \$14,665,056 |
| See One-Line Diagram. | | |
| | GEN-2015-084 | \$14,665,056 |
| | Total Allocated Costs | \$14,665,056 |
| GEN-2015-085 Interconnection Costs | | \$8,406,414 |
| See One-Line Diagram. | | |
| | GEN-2015-085 | \$8,406,414 |
| | Total Allocated Costs | \$8,406,414 |
| GEN-2015-087 Interconnection Costs | | \$5,300,000 |
| See One-Line Diagram. | | |
| | GEN-2015-087 | \$5,300,000 |
| | Total Allocated Costs | \$5,300,000 |
| GEN-2015-088 Interconnection Costs | | \$15,000,000 |
| See One-Line Diagram. | | |
| | GEN-2015-088 | \$15,000,000 |
| | Total Allocated Costs | \$15,000,000 |
| GEN-2015-090 Interconnection Costs | | \$16,021 |
| See One-Line Diagram. | | |
| | GEN-2015-090 | \$16,021 |
| | Total Allocated Costs | \$16,021 |
| GEN-2015-091 Interconnection Costs | | \$3,224,682 |
| See One-Line Diagram. | | |
| | GEN-2015-091 | \$3,224,682 |
| | Total Allocated Costs | \$3,224,682 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

| | | |
|--|------------------------------|---------------------|
| GEN-2015-092 Interconnection Costs | | \$1,110,612 |
| See One-Line Diagram. | | |
| | GEN-2015-092 | \$1,110,612 |
| | Total Allocated Costs | \$1,110,612 |
| GEN-2015-093 Interconnection Costs | | \$2,125,000 |
| See One-Line Diagram. | | |
| | GEN-2015-093 | \$2,125,000 |
| | Total Allocated Costs | \$2,125,000 |
| GEN-2015-095 Interconnection Costs | | \$4,400,000 |
| See One-Line Diagram. | | |
| | GEN-2015-095 | \$4,400,000 |
| | Total Allocated Costs | \$4,400,000 |
| GEN-2015-095 Tap - Rose Valley 138kV CKT 1 | | \$10,000,000 |
| Rebuild approximately 14 miles of 138kV from Rose Valley to GEN-2015-095 Tap | | |
| | GEN-2015-060 | \$1,035,126 |
| | GEN-2015-095 | \$8,964,874 |
| | Total Allocated Costs | \$10,000,000 |
| GEN-2015-096 Interconnection Costs | | \$0 |
| See One-Line Diagram. | | |
| | GEN-2015-096 | \$0 |
| | Total Allocated Costs | \$0 |
| GEN-2015-097 Interconnection Costs | | \$3,000,000 |
| See One-Line Diagram. | | |
| | GEN-2015-097 | \$3,000,000 |
| | Total Allocated Costs | \$3,000,000 |
| GEN-2015-098 Interconnection Costs | | \$3,000,000 |
| See One-Line Diagram. | | |
| | GEN-2015-098 | \$3,000,000 |
| | Total Allocated Costs | \$3,000,000 |

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Grapevine - Nichols 230kV CKT 1**\$400,000**

Replace terminal equipment

| | |
|--------------|----------|
| GEN-2015-020 | \$51,213 |
| GEN-2015-031 | \$66,836 |
| GEN-2015-056 | \$48,587 |
| GEN-2015-058 | \$22,262 |
| GEN-2015-068 | \$85,608 |
| GEN-2015-075 | \$19,412 |
| GEN-2015-079 | \$53,040 |
| GEN-2015-080 | \$53,040 |

Total Allocated Costs**\$400,000**

Grapevine - Wheeler 230kV CKT 1**\$400,000**

Replace terminal equipment

| | |
|--------------|-----------|
| GEN-2015-020 | \$32,133 |
| GEN-2015-031 | \$41,940 |
| GEN-2015-055 | \$20,807 |
| GEN-2015-056 | \$30,428 |
| GEN-2015-058 | \$13,921 |
| GEN-2015-068 | \$52,883 |
| GEN-2015-071 | \$129,592 |
| GEN-2015-075 | \$12,089 |
| GEN-2015-079 | \$33,103 |
| GEN-2015-080 | \$33,103 |

Total Allocated Costs**\$400,000**

Hanlon 69kV Reactive Support**\$500,000**

Install (1) 10Mvar Capacitor Bank at Hanlon 69kV.

| | |
|--------------|-----------|
| GEN-2015-046 | \$230,666 |
| GEN-2015-091 | \$77,492 |
| GEN-2015-096 | \$114,859 |
| GEN-2015-098 | \$76,983 |

Total Allocated Costs**\$500,000**

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

MISO Affected System Study**\$TBD**

See section 4 power flow analysis.

| | |
|--------------|-------|
| GEN-2015-046 | \$TBD |
| GEN-2015-091 | \$TBD |
| GEN-2015-096 | \$TBD |
| GEN-2015-097 | \$TBD |
| GEN-2015-098 | \$TBD |

| | |
|------------------------------|--------------|
| Total Allocated Costs | \$TBD |
|------------------------------|--------------|

Naples Tap - Payne 138kV CKT 1**\$5,600,000**

Rebuild approximately 8 miles of 138kV from Naples Tap to Payne

| | |
|--------------|-------------|
| GEN-2015-084 | \$1,356,486 |
| GEN-2015-085 | \$4,243,514 |

| | |
|------------------------------|--------------------|
| Total Allocated Costs | \$5,600,000 |
|------------------------------|--------------------|

Noel SW - Rose Valley 138kV CKT 1**\$5,000,000**

Rebuild approximately 7 miles of 138kV from Noel SW to Rose Valley

| | |
|--------------|-------------|
| GEN-2015-060 | \$517,563 |
| GEN-2015-095 | \$4,482,437 |

| | |
|------------------------------|--------------------|
| Total Allocated Costs | \$5,000,000 |
|------------------------------|--------------------|

Norge - Southwest Station 138kV CKT 1**\$23,000,000**

Rebuild approximately 23 miles of 138kV from Norge to Southwest Station

| | |
|--------------|--------------|
| GEN-2015-085 | \$23,000,000 |
|--------------|--------------|

| | |
|------------------------------|---------------------|
| Total Allocated Costs | \$23,000,000 |
|------------------------------|---------------------|

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Northwest 138kV Circuit Breaker**\$750,000**

Replace Northwest 138kV Circuit Breaker for short circuit requirements

| | |
|--------------|-----------|
| GEN-2015-034 | \$47,200 |
| GEN-2015-047 | \$93,274 |
| GEN-2015-048 | \$2,089 |
| GEN-2015-052 | \$43,569 |
| GEN-2015-057 | \$108,819 |
| GEN-2015-059 | \$6,856 |
| GEN-2015-060 | \$45,653 |
| GEN-2015-062 | \$428 |
| GEN-2015-066 | \$70,168 |
| GEN-2015-067 | \$35,646 |
| GEN-2015-069 | \$3,707 |
| GEN-2015-073 | \$4,366 |
| GEN-2015-081 | \$32,519 |
| GEN-2015-083 | \$10,095 |
| GEN-2015-090 | \$1,877 |
| GEN-2015-093 | \$220,608 |
| GEN-2015-095 | \$23,126 |

| | |
|------------------------------|------------------|
| Total Allocated Costs | \$750,000 |
|------------------------------|------------------|

Oklaunion 345kV Reactive Power Support Incremental Upgrade**\$20,000,000**

Install +/-100Mvar SVC at Oklaunion

| | |
|--------------|-------------|
| GEN-2015-020 | \$1,816,670 |
| GEN-2015-031 | \$1,657,397 |
| GEN-2015-056 | \$1,920,376 |
| GEN-2015-058 | \$992,383 |
| GEN-2015-068 | \$7,146,213 |
| GEN-2015-075 | \$1,113,372 |
| GEN-2015-079 | \$2,676,794 |
| GEN-2015-080 | \$2,676,794 |

| | |
|------------------------------|---------------------|
| Total Allocated Costs | \$20,000,000 |
|------------------------------|---------------------|

Albion - Petersburg - North Petersburg 115kV CKT 1**\$3,500,000**

Reconductor 115kV lines and replace all terminal equipment for at least a 193MVA rate.

| | |
|--------------|-------------|
| GEN-2015-053 | \$3,500,000 |
|--------------|-------------|

| | |
|------------------------------|--------------------|
| Total Allocated Costs | \$3,500,000 |
|------------------------------|--------------------|

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

Swissvale - West Gardner 345kV CKT 1 **\$1,000,000**

Replace terminal equipment to at least 1600 amps

| | |
|--------------|-----------|
| GEN-2015-069 | \$489,514 |
| GEN-2015-073 | \$510,486 |

| | |
|------------------------------|--------------------|
| Total Allocated Costs | \$1,000,000 |
|------------------------------|--------------------|

Wheeler - Sweetwater 230kV CKT 1 **\$6,000,000**

Rebuild AEP's portion of the circuit and replace terminal equipment on SPS portion

| | |
|--------------|-------------|
| GEN-2015-020 | \$460,332 |
| GEN-2015-031 | \$600,726 |
| GEN-2015-055 | \$301,294 |
| GEN-2015-056 | \$435,826 |
| GEN-2015-058 | \$199,353 |
| GEN-2015-068 | \$756,014 |
| GEN-2015-071 | \$1,884,339 |
| GEN-2015-075 | \$173,024 |
| GEN-2015-079 | \$473,918 |
| GEN-2015-080 | \$473,918 |
| GEN-2015-085 | \$241,254 |

| | |
|------------------------------|--------------------|
| Total Allocated Costs | \$6,000,000 |
|------------------------------|--------------------|

Woodward 345/138/13kV Transformer CKT 1 **\$15,000,000**

Replace Woodward 345/138/13kV Transformer circuit #1

| | |
|--------------|--------------|
| GEN-2015-060 | \$11,629,339 |
| GEN-2015-095 | \$3,370,661 |

| | |
|------------------------------|---------------------|
| Total Allocated Costs | \$15,000,000 |
|------------------------------|---------------------|

Woodward 345/138/13kV Transformer CKT 2 **\$15,000,000**

Replace Woodward 345/138/13kV Transformer circuit #2

| | |
|--------------|--------------|
| GEN-2015-060 | \$11,629,289 |
| GEN-2015-095 | \$3,370,711 |

| | |
|------------------------------|---------------------|
| Total Allocated Costs | \$15,000,000 |
|------------------------------|---------------------|

* Withdrawal of higher queued projects will cause a restudy and may result in higher costs

11.7 G-T: Thermal Power Flow Analysis (Constraints Requiring Transmission Reinforcement)

See next page.

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATE (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|---|------------|-------------|---------|--------------------|---|
| FDNSLock-Blown up | 02ALL | 0 | 17G | G14_037 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.24796 | - | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNSLock-Blown up | 02ALL | 0 | 17G | G14_037 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.24796 | - | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| FDNSLock-Blown up | 02ALL | 2 | 17G | G14_037 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.24796 | - | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNSLock-Blown up | 02ALL | 2 | 17G | G14_037 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.24796 | - | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| FDNSLock-Blown up | 02ALL | 3 | 17G | G14_037 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.24796 | - | FINNEY SWITCHING STATION - WALKTAP7 345.00 345KV CKT 1 |
| FDNS | 02ALL | 0 | 25SP | G14_037 | FROM->TO | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 560 | 0.11111 | 113.5155 | System Intact |
| FDNS | 02ALL | 0 | 25SP | G14_037 | FROM->TO | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 560 | 0.11111 | 116.6448 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 1792 | 1972 | 0.18031 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 1792 | 1972 | 0.18031 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 1022 | 1124 | 0.24122 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 1022 | 1124 | 0.24122 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.19496 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 987.16 | 1082.77 | 0.1568 | - | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.1568 | - | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 560 | 560 | 0.19496 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 435.02 | 457.73 | 0.11867 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 439 | 439 | 0.11867 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 439 | 439 | 0.11867 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_020 | | Non-Converged Contingency | 329.05 | 360.92 | 0.09669 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.39994 | 101.7566 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.39994 | 106.3032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 107.868 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 107.868 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 109.6833 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 109.6833 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 108.0801 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 108.0801 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 109.7267 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 109.7267 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 107.7709 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 107.7709 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 109.5653 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.32270 | 109.5653 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.39994 | 110.605 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.39994 | 115.547 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 117.2478 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 117.2478 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 119.2209 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 119.2209 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 117.4783 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 117.4783 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 119.2681 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 119.2681 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 117.1423 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 117.1423 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 119.0927 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.32270 | 119.0927 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_020 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.10037 | 105.8464 | System Intact |
| FDNS | 06ALL | 0 | 16WP | G15_020 | FROM->TO | BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.21753 | 100.1938 | NEWHART 230 - POTTER COUNTY INTERCHANGE 230KV CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_020 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.09669 | 119.5011 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_020 | | Non-Converged Contingency | 0 | 0 | 0.15281 | - | P12:230:AEPW-ELKICY6-SWEETWT6 |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_020 | | Non-Converged Contingency | 0 | 0 | 0.22916 | - | P12:230:AEPW-SPS-SWEETWT6-WHEELER 6 |
| FDNS | 06ALL | 0 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.38749 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.38749 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.38749 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.38749 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.31493 | 102.5642 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.31493 | 105.1317 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.31493 | 102.5642 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.31493 | 105.1317 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.31495 | 102.7136 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.31495 | 105.0661 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.31495 | 102.7136 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.31495 | 105.0661 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.31495 | 102.6492 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.31495 | 105.032 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.31495 | 102.6492 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 17G | G15_020 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.31495 | 105.032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_020 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.11458 | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|---|-------------|-------------|---------|--------------------|---|
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_020 | | Non-Converged Contingency | 956 | 1042 | 0.23927 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_020 | | Non-Converged Contingency | 956 | 1042 | 0.23927 | - | G14-074T 345.00 - TUCCO INTERCHANGE 345KV CKT 1 |
| FDNS | 06ALL | 0 | 17SP | G15_020 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.09478 | 113.0163 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 1792 | 1972 | 0.16545 | - | BORDER 7345.00 - TUCCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 1792 | 1972 | 0.16545 | - | BORDER 7345.00 - TUCCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 1792 | 1792 | 0.16545 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 1022 | 1124 | 0.20374 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 1022 | 1124 | 0.20374 | - | G14-074T 345.00 - TUCCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.15379 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.15379 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.12693 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.12693 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 560 | 560 | 0.15379 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 560 | 560 | 0.15379 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 421 | 439 | 0.08476 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 348.58 | 381.24 | 0.08476 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 353 | 353 | 0.08476 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 318.7 | 350.57 | 0.0688 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 318.7 | 350.57 | 0.0688 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 0 | 0 | 0.11437 | - | P12:230:AEPW-ELKCTY6:SWEETW6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 0 | 0 | 0.16952 | - | P12:230:AEPW-SPS:SWEETW6:WHEELER 6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_020 | | Non-Converged Contingency | 0 | 0 | 0.23764 | - | P12:345:SPS:J07.1.FINN.HITCH |
| FDNS | 06ALL | 2 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 124.5568 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 124.5568 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 126.1974 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 126.1974 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 124.5568 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 124.5568 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 126.1974 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 126.1974 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 124.7887 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 124.7887 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 126.2595 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 126.2595 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 124.7887 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 124.7887 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 124.7887 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 126.2595 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 126.2595 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 124.5715 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 124.5715 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 126.1329 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29022 | 126.1329 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 124.5715 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 124.5715 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 126.1329 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29022 | 126.1329 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 20L | G15_020 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.08476 | 109.5807 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_020 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.08476 | 109.5807 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_020 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.08476 | 107.8845 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_020 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.07166 | 112.5437 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_020 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.08476 | 105.6208 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_020 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.0688 | 119.8088 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_020 | | Non-Converged Contingency | 1792 | 1792 | 0.19282 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_020 | | Non-Converged Contingency | 956 | 1042 | 0.24111 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNS | 06ALL | 0 | 20SP | G15_020 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.08717 | 105.913 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 1792 | 1792 | 0.18879 | - | BORDER 7345.00 - TUCCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 1792 | 1792 | 0.18879 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 1022 | 1124 | 0.23568 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 1022 | 1124 | 0.23568 | - | G14-074T 345.00 - TUCCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.18241 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 987.2 | 1082.77 | 0.14785 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 560 | 560 | 0.18241 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 435.02 | 457.73 | 0.10345 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 439 | 439 | 0.10345 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 421 | 439 | 0.10345 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_020 | | Non-Converged Contingency | 329.05 | 360.92 | 0.08445 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.32115 | 123.1875 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.32115 | 123.1875 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.32115 | 125.4351 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.32115 | 125.4351 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_020 | FROM->TO | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.32117 | 123.3712 | TUCCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | | | | | | | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|---------|----------|--------|---------|-----------|--|-------------|-------------|---------|--------------------|---|
| FDNS | 06ALL | 4 | 16WP | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.36785 | 117.1423 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.36785 | 117.1423 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.36785 | 119.0927 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.36785 | 119.0927 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_031 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.11077 | 105.8464 | System Intact |
| FDNS | 06ALL | 0 | 16WP | G15_031 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.10704 | 119.5011 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_031 | | Non-Converged Contingency | 0 | 0 | 0.1686 | - | P12:230:AEPW:ELKCITY6:SWEETWT6 |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_031 | | Non-Converged Contingency | 0 | 0 | 0.25362 | - | P12:230:AEPW-SPS:SWEETWT6:WHEELER 6 |
| FDNS | 06ALL | 0 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.35047 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.35047 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.35047 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.35047 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.36009 | 102.5642 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.36009 | 105.1317 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.36009 | 102.5642 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.36009 | 105.1317 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.36010 | 102.7136 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.36010 | 105.0661 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.36010 | 102.7136 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.36010 | 105.0661 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.36010 | 102.6492 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.36010 | 105.032 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.36010 | 102.6492 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 17G | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.36010 | 105.032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_031 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.12681 | 113.2775 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_031 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.12681 | 111.4968 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_031 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.10732 | 117.5205 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_031 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 439 | 439 | 0.12681 | 103.2013 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_031 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.10378 | 130.5235 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_031 | | Non-Converged Contingency | 1792 | 1792 | 0.15969 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_031 | | Non-Converged Contingency | 956 | 1042 | 0.21792 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_031 | | Non-Converged Contingency | 956 | 1042 | 0.21792 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNS | 06ALL | 0 | 17SP | G15_031 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.10557 | 113.0163 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 1792 | 1972 | 0.13817 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 1792 | 1972 | 0.13817 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 1792 | 1972 | 0.13817 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 1022 | 1124 | 0.17462 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 1022 | 1124 | 0.17462 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.17183 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.17183 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.13576 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.13576 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 560 | 560 | 0.17183 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 560 | 560 | 0.17183 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 421 | 439 | 0.10104 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 348.58 | 381.24 | 0.10104 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 353 | 353 | 0.10104 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 318.7 | 350.57 | 0.08249 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 318.7 | 350.57 | 0.08249 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 0 | 0 | 0.13539 | - | P12:230:AEPW:ELKCITY6:SWEETWT6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 0 | 0 | 0.20208 | - | P12:230:AEPW-SPS:SWEETWT6:WHEELER 6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_031 | | Non-Converged Contingency | 0 | 0 | 0.2542 | - | P12:345:SPS:J07.1.FINN.HITCH |
| FDNS | 06ALL | 2 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.32834 | 124.5568 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.32834 | 124.5568 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.32834 | 126.1974 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.32834 | 126.1974 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.32834 | 124.5568 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.32834 | 124.5568 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.32834 | 126.1974 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.32834 | 126.1974 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.32834 | 124.7887 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.32834 | 124.7887 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.32834 | 126.2595 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.32834 | 126.2595 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.32834 | 124.7887 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.32834 | 124.7887 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.32834 | 126.2595 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.32834 | 126.2595 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.32834 | 124.5715 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_031 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.32834 | 124.5715 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL</ | | | | | | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|---|----------------|----------------|---------|-----------------------|---|
| FDNS | 08ALL | 2 | 17SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08540 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08540 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08540 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08540 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_034 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174 | 174 | 0.0302 | 118.7603 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_034 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174 | 174 | 0.0302 | 118.7603 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_034 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174.0 | 174.0 | 0.03020 | 118.7603 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_034 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174.0 | 174.0 | 0.03020 | 118.7603 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_034 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174.0 | 174.0 | 0.03019 | 118.4937 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_034 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174.0 | 174.0 | 0.03019 | 118.4937 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.07057 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.07057 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.07057 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.07057 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.07056 | 120.1206 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.07056 | 120.1206 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.08479 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.08479 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08479 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08479 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08479 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08479 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.0857 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.0857 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08570 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08570 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08571 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_034 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.08571 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNSLock-Blown up | 09ALL | 0 | 16WP | G15_046 | | Non-Converged Contingency | 720 | 720 | 0.11874 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 16WP | G15_046 | | Non-Converged Contingency | 720 | 720 | 0.11874 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNS | 16ALL | 0 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.37257 | 104.0325 | NESET 4 230.00 (I) 230/115/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 0 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.37892 | 117.2053 | JUDSON 3345.00 (JUDSON KU1A) 345/230/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 0 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.37892 | 117.2058 | JUDSON 4230.00 - WILLISTON 230KV CKT 1 |
| FDNS | 16ALL | 0 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90393 | 122.0297 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 0 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90393 | 122.0629 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 0 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90393 | 122.0629 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 2 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37248 | 103.8066 | NESET 4 230.00 (I) 230/115/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 2 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37887 | 117.0328 | JUDSON 3345.00 (JUDSON KU1A) 345/230/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 2 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37887 | 117.0335 | JUDSON 4230.00 - WILLISTON 230KV CKT 1 |
| FDNS | 16ALL | 2 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90394 | 122.0462 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 2 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90394 | 122.0781 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 2 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90394 | 122.0781 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 3 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37236 | 103.6024 | NESET 4 230.00 (I) 230/115/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 3 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37876 | 116.8354 | JUDSON 3345.00 (JUDSON KU1A) 345/230/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 3 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37876 | 116.8359 | JUDSON 4230.00 - WILLISTON 230KV CKT 1 |
| FDNS | 16ALL | 3 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90395 | 122.0682 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 3 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90395 | 122.0996 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 3 | 16WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90395 | 122.0996 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 0 | 16WP | G15_046 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.02965 | 102.9357 | System Intact |
| FDNS | 16ALL | 0 | 16WP | G15_046 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.02965 | 103.8937 | System Intact |
| FDNS | 16ALL | 2 | 16WP | G15_046 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.03095 | 108.8239 | System Intact |
| FDNS | 16ALL | 2 | 16WP | G15_046 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.03095 | 109.822 | System Intact |
| FDNSLock-Blown up | 09ALL | 0 | 17G | G15_046 | | Non-Converged Contingency | 720 | 720 | 0.12227 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 17G | G15_046 | | Non-Converged Contingency | 720 | 720 | 0.12227 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNS | 16ALL | 0 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.37856 | 118.8694 | JUDSON 3345.00 (JUDSON KU1A) 345/230/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 0 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.37856 | 118.8699 | JUDSON 4230.00 - WILLISTON 230KV CKT 1 |
| FDNS | 16ALL | 0 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90391 | 127.875 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 0 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90391 | 128.0071 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 0 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90391 | 128.0071 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 2 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37851 | 118.6912 | JUDSON 3345.00 (JUDSON KU1A) 345/230/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 2 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37851 | 118.6917 | JUDSON 4230.00 - WILLISTON 230KV CKT 1 |
| FDNS | 16ALL | 2 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90391 | 127.885 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 2 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90391 | 128.0161 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 2 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90391 | 128.0161 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 3 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37840 | 118.5027 | JUDSON 3345.00 (JUDSON KU1A) 345/230/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 3 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37840 | 118.5033 | JUDSON 4230.00 - WILLISTON 230KV CKT 1 |
| FDNS | 16ALL | 3 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90393 | 127.8968 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 3 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90393 | 128.0266 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 3 | 17G | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90393 | 128.0266 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNSLock-Blown up | 09ALL | 0 | 17SP | G15_046 | | Non-Converged Contingency | 720 | 720 | 0.12266 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 17SP | G15_046 | | Non-Converged Contingency | 720 | 720 | 0.12266 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_046 | | Non-Converged Contingency | 720 | 792 | 0.13951 | - | WATERTN-LNX3345.00 - WATERTOWN 345KV CKT Z |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_046 | | Non-Converged Contingency | 720 | 792 | 0.13951 | - | WATERTN-LNX3345.00 - WHITE 345KV CKT 1 |
| FD | | | | | | | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|---|----------------|----------------|---------|-----------------------|---|
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_046 | | Non-Converged Contingency | 717 | 789 | 0.11898 | - | G09_001IST 345.00 - GROTON 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_046 | | Non-Converged Contingency | 717 | 789 | 0.11898 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 2 | 17SP | G15_046 | | Non-Converged Contingency | 717.0 | 789.0 | 0.11897 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 3 | 17SP | G15_046 | | Non-Converged Contingency | 717.0 | 789.0 | 0.11841 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 4 | 17SP | G15_046 | | Non-Converged Contingency | 717.0 | 789.0 | 0.11916 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNS | 09ALL | 0 | 17SP | G15_046 | FROM->TO | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z | 720 | 720 | 0.1284 | 95.3 | KELLY - MEADOWGROVE4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 17SP | G15_046 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400 | 480 | 0.13637 | 101.3771 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_046 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400.0 | 480.0 | 0.13630 | 101.3206 | System Intact |
| FDNS | 16ALL | 3 | 17SP | G15_046 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400.0 | 480.0 | 0.13640 | 101.1661 | System Intact |
| FDNS | 16ALL | 0 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.37894 | 105.5018 | JUDSON 4230.00 - WILLISTON 230KV CKT 1 |
| FDNS | 16ALL | 0 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.37894 | 105.5073 | JUDSON 3345.00 (JUDSON KU1A) 345/230/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 0 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90397 | 130.908 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 0 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90397 | 130.9983 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 0 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90397 | 130.9983 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 2 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37889 | 105.3143 | JUDSON 4230.00 - WILLISTON 230KV CKT 1 |
| FDNS | 16ALL | 2 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37889 | 105.3198 | JUDSON 3345.00 (JUDSON KU1A) 345/230/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 2 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90397 | 130.9217 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 2 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90397 | 131.0096 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 2 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90397 | 131.0096 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 3 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37878 | 105.081 | JUDSON 4230.00 - WILLISTON 230KV CKT 1 |
| FDNS | 16ALL | 3 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.37878 | 105.0949 | JUDSON 3345.00 (JUDSON KU1A) 345/230/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 3 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90399 | 130.9475 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 3 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90399 | 131.0347 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 3 | 17SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90399 | 131.0347 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 0 | 17SP | G15_046 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.02974 | 103.7908 | System Intact |
| FDNS | 16ALL | 0 | 17SP | G15_046 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.02974 | 104.4544 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_046 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.03105 | 110.0005 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_046 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.03105 | 110.7028 | System Intact |
| FDNS | 16ALL | 0 | 20L | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90607 | 137.0158 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 0 | 20L | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90607 | 137.0458 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 0 | 20L | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90607 | 137.0458 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 2 | 20L | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90608 | 137.0294 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 2 | 20L | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90608 | 137.0469 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 2 | 20L | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90608 | 137.0469 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 3 | 20L | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90609 | 137.0459 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 3 | 20L | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90609 | 137.0638 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 3 | 20L | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90609 | 137.0638 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 0 | 20SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.9061 | 125.8607 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 0 | 20SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.9061 | 125.8787 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 0 | 20SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.9061 | 125.8787 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 2 | 20SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90610 | 125.8752 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 2 | 20SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90610 | 125.8928 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 2 | 20SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90610 | 125.8928 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 3 | 20SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90611 | 125.8967 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 3 | 20SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90611 | 125.9141 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 3 | 20SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90611 | 125.9141 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 0 | 20SP | G15_046 | TO->FROM | BISMARCK - HILKEN 4 230.00 230KV CKT 1 | 319 | 351 | 0.03682 | 107.6143 | System Intact |
| FDNS | 16ALL | 2 | 20SP | G15_046 | TO->FROM | BISMARCK - HILKEN 4 230.00 230KV CKT 1 | 319.0 | 351.0 | 0.03660 | 107.3131 | System Intact |
| FDNS | 16ALL | 3 | 20SP | G15_046 | TO->FROM | BISMARCK - HILKEN 4 230.00 230KV CKT 1 | 319.0 | 351.0 | 0.03665 | 107.3591 | System Intact |
| FDNS | 16ALL | 0 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.35051 | 103.5969 | NESET 4 230.00 () 230/115/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 0 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90607 | 114.8913 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 0 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90607 | 114.8913 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 0 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.90607 | 114.9119 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 2 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.35043 | 103.3976 | NESET 4 230.00 () 230/115/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 2 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90608 | 114.9072 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 2 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90608 | 114.9072 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 2 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90608 | 114.9282 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 3 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.35033 | 103.2004 | NESET 4 230.00 () 230/115/13.8KV TRANSFORMER CKT 1 |
| FDNS | 16ALL | 3 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90608 | 114.9278 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 3 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90608 | 114.9278 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 3 | 20WP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90608 | 114.949 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 0 | 25SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.9061 | 120.4442 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 0 | 25SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.9061 | 120.4442 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 0 | 25SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200 | 200 | 0.9061 | 120.4548 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 2 | 25SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90610 | 120.4599 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 2 | 25SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90610 | 120.4599 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 2 | 25SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90610 | 120.4705 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 3 | 25SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90611 | 120.4839 | JUDSON 3345.00 - TANDE-LNX 345.00 345KV CKT 1 |
| FDNS | 16ALL | 3 | 25SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90611 | 120.4839 | JUDSON-TANDE-TLINE-REACTORS-CKT1 |
| FDNS | 16ALL | 3 | 25SP | G15_046 | FROM->TO | NESET 4 230.00 - TIOGA 230KV CKT 1 | 200.0 | 200.0 | 0.90611 | 120.4945 | TANDE 3345.00 - TANDE-LNX 345.00 345KV CKT Z |
| FDNS | 16ALL | 0 | 25SP | G15_046 | TO->FROM | BISMARCK - HILKEN 4 230.00 230KV CKT 1 | 319 | 351 | 0.03709 | 107.4484 | System Intact |
| FDNS | 16ALL | 2 | 25SP | G15_046 | TO->FROM | BISMARCK - HILKEN 4 230.00 230KV CKT 1 | 319.0 | 351.0 | 0.03687 | 107.156 | System Intact |
| FDNS | 16ALL | 3 | 25SP | G15_046 | TO->FROM | BISMARCK - HILKEN 4 230.00 | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|----------|-------|----------|--------|---------|-----------|---|----------------|----------------|---------|-----------------------|--|
| FDNS | 08ALL | 0 | 16WP | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.19712 | 121.9421 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.19904 | 117.7802 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.19904 | 117.8392 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.11175 | 104.1008 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17G | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11175 | 104.1008 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17G | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11175 | 103.9839 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20155 | 117.3912 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20226 | 109.8071 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.1108 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.1108 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11080 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11080 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11080 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11080 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_047 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174 | 174 | 0.04043 | 118.7603 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_047 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174 | 174 | 0.04043 | 118.7603 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_047 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174.0 | 174.0 | 0.04043 | 118.7603 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_047 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174.0 | 174.0 | 0.04043 | 118.7603 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_047 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174.0 | 174.0 | 0.04042 | 118.4937 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_047 | FROM->TO | CLEAVELAND - SILVER CITY 138KV CKT 1 | 174.0 | 174.0 | 0.04042 | 118.4937 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.09578 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.09578 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.09578 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.09578 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.09578 | 120.1206 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.09578 | 120.1206 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.2044 | 104.7146 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.11001 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.11001 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11001 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11001 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11001 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11001 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20WP | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20124 | 109.6471 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20WP | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20124 | 109.7423 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 1192.0 | 1192.0 | 0.20284 | 100.4184 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 1192.0 | 1192.0 | 0.20279 | 100.0 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20284 | 125.2078 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_047 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20352 | 117.6504 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.11091 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.11091 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11091 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11091 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11092 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_047 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.11092 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.51648 | 110.0571 | IMO TAP - SOUTH 4TH ST 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.53825 | 120.4657 | WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56328 | 116.0328 | GLENWOOD - IMO TAP 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56328 | 116.2663 | GLENWOOD - NE ENID4 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56523 | 116.2313 | BRECKNR4 138.00 - BUNCH CREEK 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56786 | 119.999 | G15063 T 345.00 - WOODRING 345KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5691 | 115.5521 | P12-069:OKGE:3TERMA |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56996 | 115.8669 | HUNTERS7 345.00 - RENFROW7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57032 | 115.9215 | G15052 T 345.00 - ROSE HILL 345KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57064 | 121.5514 | CIMARRON - MINCO 345KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57093 | 122.6233 | NOEL_SW 138.00 - ROSE VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57093 | 122.7938 | G15095 T 138.00 - ROSE VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 108.0404 | GEN563292 1-G15095_3 0.6900 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 109.8861 | GEN520997 1-MORLND2 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 110.764 | GEN520998 1-MORLND3 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 111.802 | GEN515787 1-OKLA WIND ENERGY CENTER |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 112.4184 | GEN520922 1-SLEEPING BEAR |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 113.4319 | GEN515365 1-CENT 21 0.7000 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 114.0884 | GEN515389 1-TLWVND-WTG1 0.7000 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 114.9276 | GEN562023 1-G11_020_3 0.6900 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 114.9276 | GEN562026 1-G11_019_3 0.6900 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 115.3137 | GEN515393 1-OGEWIND2G |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 115.3336 | GEN525562 1-TOLK GEN #2 24 KV |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 115.3361 | GEN525561 1-TOLK GEN #1 24 KV |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 115.7557 | GEN562973 1-G15060_4 0.6900 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 115.7812 | GEN562974 1-G15060_5 0.6900 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 115.8759 | GEN515611 1-NBUFFRG1 0.6900 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 115.8759 | GEN560217 1-G07_062_6 0.6900 |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 115.8759 | GEN560218 1-G07_062_7 0.6900 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATE | | | TC%LOADING | | CONTINGENCY |
|----------|-------|----------|--------|---------|-----------|---|-------|------------|---------|------------|--|-------------|
| | | | | | | | (MVA) | RATEB(MVA) | TDF | (% MVA) | | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 117.8972 | System Intact | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 119.9669 | GEN514806 1-SOONER UNIT 2 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57101 | 121.2369 | GEN514805 1-SOONER UNIT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57114 | 120.3767 | G1524G1525 345.00 - THISTLE7 345.00 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57114 | 120.3767 | G1524G1525 345.00 - THISTLE7 345.00 345KV CKT 2 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57128 | 119.6565 | CZYCRVT2 69.000 - SALINE 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57128 | 120.3219 | CZYCRVT2 69.000 - KNOBHILL 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57133 | 120.0147 | G14-057T 345.00 - LAWTON EASTSIDE 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57133 | 120.4953 | G14-057T 345.00 - SUNNYSIDE 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57147 | 123.3971 | G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57147 | 142.716 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57157 | 120.5469 | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57157 | 120.9411 | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57157 | 120.9411 | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57176 | 123.3638 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57176 | 123.3638 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57176 | 123.3638 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57176 | 123.3638 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57211 | 116.0179 | FAIRVIEW - OKEENE 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57261 | 115.8687 | IODINE - WOODWARD EHV 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57261 | 116.0251 | DEWEY - IODINE 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57338 | 124.1574 | ROMAN NOSE - SOUTHARD 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57338 | 124.5537 | DEWEY - SOUTHARD 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57348 | 120.833 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57361 | 120.9883 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57379 | 115.4859 | KNOBHILL (KNOBHILL4) 138/69/13.2KV TRANSFORMER CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57379 | 115.4882 | KNOBHILL - NOEL_SW 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57395 | 126.6172 | DOVER SW - OKEENE 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57466 | 120.653 | CUSTER4 138.00 - RED HILLS WIND 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57466 | 120.7648 | CUSTER4 138.00 - ELLIS 4 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57466 | 121.2968 | ELLIS 4 138.00 - MOREWOOD SW 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57466 | 122.0071 | ELK CITY - RED HILLS WIND 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57466 | 122.0071 | ELK CITY - RED HILLS WIND 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5747 | 127.2353 | CDARDALE - OKEENE 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5747 | 127.4232 | CDARDALE - PIC4 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5747 | 127.4906 | P12:138:WFEC:MSL12 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5747 | 127.5164 | MOORELAND - PIC4 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57538 | 122.2179 | BYRON_138 138.00 - SANDY_CN_138138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57538 | 123.8971 | BYRON_138 138.00 - C_CITY_138 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57538 | 124.2001 | C_CITY_138 138.00 - SALT_PLAINS 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57538 | 125.7879 | NOEL_SW 138.00 - SALT_PLAINS 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57538 | 126.8546 | P12:138:WFEC:MSL15 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57626 | 116.4538 | RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5772 | 116.0694 | DEWEY - TALOGA 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57849 | 126.6019 | MOREWOOD SW - NINE MILE 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57849 | 127.2293 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57849 | 127.6959 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57849 | 127.7263 | P12:138:WFEC:MSL14 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58123 | 114.3461 | ALVA - KNOBHILL 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58582 | 110.1817 | FPL SWITCH - MOORELAND 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59343 | 121.5547 | RENFROW4 138.00 - RENFROW4 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59343 | 122.2023 | RENFROW4 138.00 - WAKITAS4 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59449 | 119.8332 | WOODWARD EHV - WWPARA 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59449 | 119.8333 | WOODWARD - WWPARA 138.00 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59909 | 121.1603 | NSAH - WAKITA 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59909 | 122.7302 | NSAH - RINGWOOD 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59909 | 124.8763 | CLEO JCT - RINGWOOD 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59909 | 124.8781 | CLEO CORNER - CLEO JCT 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59909 | 121.1 | WAKITAS4 138.00 (WAKITA_XMER) 138/69/13.8KV TRANSFORMER CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60242 | 121.3557 | ALINETP2 69.000 - ALVA 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60242 | 121.4545 | ALINETP2 69.000 - CLEOTP 2 69.000 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60242 | 121.6775 | CLEO CORNER - CLEOTP 2 69.000 69KV CKT 1 | |
| FDNS | 01ALL | 0 | 16WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.64083 | 130.3533 | CLEO CORNER (CLEOCOR1) 138/69/13.8KV TRANSFORMER CKT 1 | |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.51722 | 104.4723 | IMO TAP - SOUTH 4TH ST 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.53912 | 114.0868 | WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1 | |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5641 | 110.0058 | GLENWOOD - IMO TAP 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56604 | 109.9782 | BRECKNR4 138.00 - BUNCH CREEK 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56604 | 110.1653 | BLLNGTP4 138.00 - BUNCH CREEK 138KV CKT 1 | |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56862 | 113.9234 | G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56862 | 114.6044 | G15063_T 345.00 - WOODRING 345KV CKT 1 | |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.571 | 108.5813 | HUNTERS7 | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|----------|-------|----------|--------|---------|-----------|---|-------------|-------------|---------|--------------------|--|
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57125 | 110.0558 | OPENSKY7 345.00 - RANCHRD7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5715 | 115.3191 | CIMARRON - MINCO 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57178 | 116.5092 | NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57178 | 116.9412 | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 102.0186 | GEN563292 1-G15095_3 0.6900 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 105.7336 | GEN515787 1-OKLA WIND ENERGY CENTER |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 106.3519 | GEN520922 1-SLEEPING BEAR |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 106.9928 | GEN520997 1-MORLND2 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 106.995 | GEN520998 1-MORLND3 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 107.3978 | GEN515365 1-CENT 21 0.7000 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 108.0365 | GEN515389 1-TLWVND-WTG1 0.7000 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 108.9887 | GEN562023 1-G11_020_3 0.6900 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 108.9887 | GEN562026 1-G11_019_3 0.6900 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 109.2919 | GEN515393 1-OGEWND2G |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 109.4354 | GEN525561 1-TOLK GEN #1 24 KV |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 109.7238 | GEN562973 1-G15060_4 0.6900 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 109.7484 | GEN562974 1-G15060_5 0.6900 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 109.8789 | GEN515611 1-NBUFFRG1 0.6900 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 109.8789 | GEN560217 1-G07_062_6 0.6900 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 109.8789 | GEN560218 1-G07_062_7 0.6900 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 111.7985 | System Intact |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 114.3994 | GEN514806 1-SOONER UNIT 2 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57184 | 115.873 | GEN514805 1-SOONER UNIT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57197 | 114.3777 | G1524G1525 345.00 - THISTLE7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57197 | 114.3777 | G1524G1525 345.00 - THISTLE7 345.00 345KV CKT 2 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57209 | 113.7466 | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57215 | 113.895 | G14-057T 345.00 - LAWTON EASTSIDE 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57215 | 114.3577 | G14-057T 345.00 - SUNNYSIDE 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57216 | 114.0651 | CZYCRV2T 69.000 - KNOBHILL 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57232 | 114.2366 | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57232 | 114.6278 | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57248 | 116.0443 | G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57248 | 134.6206 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57255 | 117.2741 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57255 | 117.2741 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57295 | 110.0856 | FAIRVIEW - OKEENE 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57343 | 109.9092 | IODINE - WOODWARD EHV 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57427 | 117.4826 | ROMAN NOSE - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57427 | 117.9016 | DEWEY - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57431 | 114.7039 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57444 | 114.8518 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57461 | 109.7168 | KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57461 | 109.7185 | KNOBHILL - NOEL_SW 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57491 | 119.7462 | DOVER SW - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57554 | 113.693 | CUSTER4 138.00 - ELLIS 4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57554 | 114.2311 | ELLIS 4 138.00 - MOREWOOD SW 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57554 | 117.2743 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57565 | 120.2909 | CEDARDALE - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57565 | 120.47 | CEDARDALE - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57565 | 120.5629 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57624 | 115.9485 | BYRON 138 138.00 - SANDY_CN 138138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57624 | 117.681 | BYRON 138 138.00 - C_CITY 138 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57624 | 117.8899 | C_CITY 138 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57624 | 119.4917 | NOEL_SW 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57807 | 109.5968 | DEWEY - TALOGA 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57942 | 118.6212 | MOREWOOD SW - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57942 | 119.3787 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57942 | 119.8438 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58205 | 108.8595 | ALVA - KNOBHILL 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58669 | 103.4146 | FPL SWITCH - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58669 | 109.3192 | FPL SWITCH - WOODWARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59433 | 114.4019 | RENFROW4 138.00 - RENFROW4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59433 | 115.4413 | RENFROW4 138.00 - WAKITAS4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59991 | 114.5995 | NSAH - WAKITA 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59991 | 116.7539 | NSAH - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59991 | 118.8968 | CLEO JCT - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59991 | 118.8987 | CLEO CORNER - CLEO JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59991 | 114.8 | WAKITAS4 138.00 (WAKITA_XMER) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60323 | 115.2669 | ALINETP2 69.000 - ALVA 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60323 | 115.3577 | ALINETP2 69.000 - CLEOTP 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60323 | 115.5678 | CLEO CORNER - CLEOTP 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_0 | | | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|----------|-------|----------|--------|---------|-----------|---|----------------|----------------|---------|-----------------------|--|
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.51656 | 111.0533 | IMO TAP - SOUTH 4TH ST 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.53825 | 123.7503 | WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56338 | 115.5393 | GLENWOOD - IMO TAP 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56338 | 115.9059 | GLENWOOD - NE ENIDA 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56536 | 115.6319 | BRECKNR4 138.00 - BUNCH CREEK 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56536 | 115.9405 | BLLNGTP4 138.00 - BUNCH CREEK 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56789 | 120.044 | G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56789 | 120.7442 | G15063_T 345.00 - WOODRING 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56919 | 114.308 | P12:069:OKGE:3TERM4 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56997 | 114.9526 | HUNTERS7 345.00 - RENFROW7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57036 | 115.1795 | G15052_T 345.00 - ROSE HILL 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57036 | 115.5542 | G15052_T 345.00 - OPENSKEY7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57074 | 121.2114 | CIMARRON - MINCO 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57104 | 122.5681 | NOEL_SW 138.00 - ROSE VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57104 | 122.8537 | G15095_T 138.00 - ROSE VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 107.7611 | GEN563292 1-G15095_3 0.6900 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 109.0683 | GEN520998 1-MORLND3 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 109.5579 | GEN520997 1-MORLND2 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 111.4574 | GEN515787 1-OKLA WIND ENERGY CENTER |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 112.1021 | GEN520922 1-SLEEPING BEAR |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 113.1141 | GEN515365 1-CENT 21 0.7000 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 113.7727 | GEN515389 1-TLGWIND-WTG1 0.7000 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 114.6664 | GEN562023 1-G11_020_3 0.6900 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 114.6664 | GEN562026 1-G11_019_3 0.6900 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 114.8842 | GEN525562 1-TOLK GEN #2 24 KV |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 114.966 | GEN525561 1-TOLK GEN #1 24 KV |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 115.013 | GEN515393 1-OGEWIND2G |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 115.4494 | GEN562973 1-G15060_4 0.6900 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 115.4745 | GEN562974 1-G15060_5 0.6900 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 115.5883 | GEN515611 1-NBUFFRG1 0.6900 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 115.5883 | GEN560217 1-G07_062_6 0.6900 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 115.5883 | GEN560218 1-G07_062_7 0.6900 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 117.5578 | System Intact |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 119.7373 | GEN514806 1-SOONER UNIT 2 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57111 | 121.1297 | GEN514805 1-SOONER UNIT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57124 | 119.7284 | G1524G1525 345.00 - THISTLE7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57124 | 119.7284 | G1524G1525 345.00 - THISTLE7 345.00 345KV CKT 2 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57138 | 119.5243 | CZCYRVT2 69.000 - SALINE 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57138 | 120.1926 | CZCYRVT2 69.000 - KNOBHILL 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57141 | 119.6188 | G14-057T 345.00 - SUNNYSIDE 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57152 | 121.3075 | G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57152 | 139.7914 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57169 | 119.7019 | P12:345:SPS:J07.1.FINN.HITCH |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57169 | 119.7105 | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57169 | 119.7105 | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57185 | 122.7197 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57185 | 122.7197 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57185 | 122.7197 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57185 | 122.7197 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57221 | 116.1949 | FAIRVIEW - OKEENE 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57273 | 115.6755 | IODINE - WOODWARD EHV 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5735 | 123.1744 | ROMAN NOSE - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5735 | 123.7791 | DEWEY - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57361 | 120.526 | WOODWARD DISTRICT EHV (WVDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57373 | 120.678 | WOODWARD DISTRICT EHV (WVDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57389 | 115.3112 | KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57389 | 115.3131 | KNOBHILL - NOEL_SW 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57407 | 125.904 | DOVER SW - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5748 | 120.3099 | CUSTER4 138.00 - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5748 | 120.4212 | CUSTER4 138.00 - ELLIS 4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5748 | 120.9514 | ELLIS 4 138.00 - MOREWOOD SW 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5748 | 121.6555 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5748 | 121.6555 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57484 | 126.7872 | CEDARDALE - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57484 | 126.961 | CEDARDALE - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57484 | 127.036 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57484 | 127.0531 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57549 | 121.555 | BYRON_138 138.00 - SANDY_CN_138138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57549 | 123.294 | BYRON_138 138.00 - C_CITY_138 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57549 | 123.7002 | C_CITY_138 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57549 | 125.4819 | NOEL_SW 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57549 | 126.3272 | P12:138:WFEC:MSL15 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57641 | 114.8002 | RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57737 | 115.6465 | DEWEY - TALOGA 138KV CKT 1 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|----------|-------|----------|--------|---------|-----------|---|----------------|----------------|---------|-----------------------|--|
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57867 | 126.0279 | MOREWOOD SW - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57867 | 126.7836 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57867 | 127.2471 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57867 | 127.2753 | P12:138:WFEC:MSL14 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58133 | 114.2514 | ALVA - KNOBHILL 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58609 | 110.4648 | FPL SWITCH - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59358 | 120.8443 | RENFWOW4 138.00 - WAKITAS4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59485 | 119.6412 | WOODWARD EHV - WWP4R4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59485 | 119.6413 | WOODWARD - WWP4R4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5992 | 119.9093 | NSAH - WAKITA 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5992 | 122.2691 | NSAH - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5992 | 124.9981 | CLEO JCT - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5992 | 124.9999 | CLEO CORNER - CLEO JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60253 | 120.9642 | ALINETP2 69.000 - ALVA 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60253 | 121.1172 | ALINETP2 69.000 - CLEOTP 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60253 | 121.4699 | CLEO CORNER - CLEOTP 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.64096 | 130.7273 | CLEO CORNER (CLEOCOR1) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_048 | TO->FROM | ROMAN NOSE - SOUTHARD 138KV CKT 1 | 133 | 153 | 0.03172 | 106.118 | System Intact |
| FDNS | 01ALL | 2 | 17SP | G15_048 | TO->FROM | ROMAN NOSE - SOUTHARD 138KV CKT 1 | 133.0 | 153.0 | 0.03172 | 105.9209 | System Intact |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57072 | 102.5229 | G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57072 | 103.2411 | G15063_T 345.00 - WOODRING 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57353 | 102.0698 | CIMARRON - MINCO 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57366 | 99.8 | System Intact |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57366 | 101.8376 | GENS14806 1-SOONER UNIT 2 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57366 | 103.0932 | GENS14805 1-SOONER UNIT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57366 | 103.4987 | NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57366 | 103.6433 | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57383 | 105.4131 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57383 | 105.4131 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 2 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57388 | 101.7137 | G14-057T 345.00 - LAWTON EASTSIDE 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57388 | 102.1684 | G14-057T 345.00 - SUNNYSIDE 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57399 | 101.5298 | CZYCRVT2 69.000 - KNOBHILL 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57412 | 101.7586 | P12:345:SP5:J07.1.FINN.HITCH |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57412 | 101.7689 | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57412 | 101.7689 | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57419 | 103.116 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57419 | 103.116 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57419 | 103.116 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57419 | 103.116 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57592 | 104.2058 | ROMAN NOSE - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57592 | 104.4422 | DEWEY - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5763 | 103.0605 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57643 | 103.2285 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5769 | 106.2533 | DOVER SW - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57728 | 101.5595 | ELLIS 4 138.00 - MOREWOOD SW 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57728 | 104.5071 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57728 | 104.5071 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57757 | 106.2076 | CEDARDALE - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57757 | 106.3096 | CEDARDALE - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57757 | 106.3904 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57757 | 106.4023 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57819 | 103.0929 | BYRON 138 138.00 - SANDY_CN 138138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57819 | 104.6608 | BYRON 138 138.00 - C_CITY 138 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57819 | 104.8031 | C_CITY 138 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57819 | 106.5016 | NOEL_SW 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57819 | 107.3605 | P12:138:WFEC:MSL15 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58106 | 104.5759 | MOREWOOD SW - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58106 | 105.3148 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58106 | 105.7638 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58106 | 105.7886 | P12:138:WFEC:MSL14 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59643 | 101.8439 | RENFWOW4 138.00 - WAKITAS4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59816 | 102.4704 | WOODWARD - WWP4R4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59816 | 102.4704 | WOODWARD EHV - WWP4R4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60174 | 103.0025 | NSAH - WAKITA 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60174 | 104.5542 | NSAH - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60174 | 106.076 | CLEO JCT - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60174 | 106.0782 | CLEO CORNER - CLEO JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60508 | 103.0814 | ALINETP2 69.000 - ALVA 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60508 | 103.1299 | ALINETP2 69.000 - CLEOTP 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60508 | 103.2252 | CLEO CORNER - CLEOTP 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.64354 | 111.005 | CLEO CORNER (CLEOCOR1) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNSLock | 01ALL | 0 | 20L | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60174 | 101.6826 | WAKITAS4 138.00 (WAKITA_XMER) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.51645 | 102.0568 | IMO TAP - SOUTH 4TH ST 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.53824 | 114.5495 | WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|----------|-------|----------|--------|---------|-----------|---|-------------|-------------|---------|--------------------|--|
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56337 | 105.5519 | GLENWOOD - IMO TAP 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56538 | 105.4713 | BRECKNR4 138.00 - BUNCH CREEK 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56538 | 105.811 | BLLNGTP4 138.00 - BUNCH CREEK 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56782 | 112.0369 | G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56782 | 112.7955 | G15063_T 345.00 - WOODRING 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5692 | 104.0926 | P12:069:OKGE:3TERM4 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56989 | 102.8213 | HUNTERS7 345.00 - RENFROW7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56989 | 103.709 | HUNTERS7 345.00 - WOODRING 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57053 | 105.2419 | G15052_T 345.00 - ROSE HILL 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57053 | 105.5419 | G15052_T 345.00 - OPENSKY7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5708 | 110.3947 | CIMARRON - MINCO 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57105 | 111.9864 | NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57105 | 112.5408 | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 101.465 | GEN515787 1-OKLA WIND ENERGY CENTER |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 101.6199 | GEN520998 1-MORLND3 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 101.9572 | GEN520997 1-MORLND2 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 102.1131 | GEN520922 1-SLEEPING BEAR |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 103.2188 | GEN515365 1-CENT 21 0.7000 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 103.8238 | GEN515389 1-TLGWND-WT61 0.7000 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 105.2719 | GEN515393 1-OGEWND2G |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 105.3544 | GEN562023 1-G11_020_3 0.6900 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 105.3544 | GEN562026 1-G11_019_3 0.6900 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 105.3703 | GEN520996 1-MORLND1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 105.3807 | GEN525562 1-TOLK GEN #2 24 KV |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 105.5438 | GEN525561 1-TOLK GEN #1 24 KV |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 107.4428 | System Intact |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 109.566 | GEN514806 1-SOONER UNIT 2 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57112 | 110.949 | GEN514805 1-SOONER UNIT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57124 | 112.4822 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57124 | 112.4822 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 2 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57132 | 109.6907 | CZYCRVT2 69.000 - KNOBHILL 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5714 | 109.2779 | G14-057T 345.00 - SUNNYSIDE 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57168 | 111.0563 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57168 | 111.0563 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57168 | 111.0563 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5722 | 106.1114 | FAIRVIEW - RINGWOOD JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5722 | 106.112 | EAGLE CHIEF - RINGWOOD JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5722 | 109.7174 | ALVA - CHEROKEE SW 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57337 | 111.7429 | ROMAN NOSE - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57337 | 112.3196 | DEWEY - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57373 | 110.6849 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57386 | 110.8526 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57399 | 105.113 | KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57404 | 114.1311 | DOVER SW - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57476 | 109.2965 | CUSTER4 138.00 - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57476 | 109.4077 | CUSTER4 138.00 - ELLIS 4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57476 | 109.9308 | ELLIS 4 138.00 - MOREWOOD SW 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57476 | 110.6278 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57476 | 110.6278 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57482 | 115.3974 | CEDARDALE - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57482 | 115.597 | CEDARDALE - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57482 | 115.6624 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57482 | 115.6872 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57552 | 110.7642 | BYRON_138 138.00 - SANDY_CN_138138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57552 | 112.6037 | BYRON_138 138.00 - C_CITY_138 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57552 | 113.1581 | C_CITY_138 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57552 | 114.7224 | NOEL_SW 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57552 | 115.7095 | P12:138:WFEC:MSL15 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57643 | 104.6609 | RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57747 | 105.154 | DEWEY - TALOGA 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57856 | 114.2017 | MOREWOOD SW - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57856 | 114.9332 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57856 | 115.3825 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57856 | 115.414 | P12:138:WFEC:MSL14 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58142 | 103.4846 | ALVA - KNOBHILL 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58648 | 100.8458 | FPL SWITCH - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59535 | 110.4733 | WOODWARD EHV - WWP4R4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59535 | 110.4734 | WOODWARD - WWP4R4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59919 | 112.0015 | NSAH - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59919 | 115.651 | CLEO CORNER - CLEO JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59919 | 115.6522 | CLEO JCT - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60264 | 111.3443 | ALINETP2 69.000 - ALVA 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60264 | 111.4954 | ALINETP2 69.000 - CLEOPT 2 69.000 69KV CKT 1 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|----------|-------|----------|--------|---------|-----------|---|-------------|-------------|---------|--------------------|--|
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.60264 | 111.8484 | CLEO CORNER - CLEO2P 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OSP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.64111 | 122.1299 | CLEO CORNER (CLEOCOR1) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.51614 | 102.8837 | IMO TAP - SOUTH 4TH ST 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.53795 | 113.8293 | WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56303 | 108.0748 | GLENWOOD - IMO TAP 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56502 | 107.9966 | BRECKNR4 138.00 - BUNCH CREEK 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56502 | 108.2141 | BLLNGTP4 138.00 - BUNCH CREEK 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56752 | 113.2926 | G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56752 | 114.0234 | G15063_T 345.00 - WOODRING 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56886 | 107.4786 | P12:069:OKGE:3TERM4 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5696 | 106.2883 | HUNTERS7 345.00 - RENFROW7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5696 | 107.1982 | HUNTERS7 345.00 - WOODRING 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57021 | 108.1844 | G15052_T 345.00 - ROSE HILL 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57041 | 113.1345 | CIMARRON - MINCO 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57069 | 114.3056 | NOEL_SW 138.00 - ROSE VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57069 | 114.704 | G15095_T 138.00 - ROSE VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 100.1787 | GEN563292 1-G15095_3 0.6900 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 103.8849 | GEN515787 1-OKLA WIND ENERGY CENTER |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 104.5154 | GEN520922 1-SLEEPING BEAR |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 104.7113 | GEN520998 1-MORLND3 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 105.0095 | GEN520997 1-MORLND2 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 105.6251 | GEN515365 1-CENT 21 0.7000 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 106.206 | GEN515389 1-TLWVND-WTG1 0.7000 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 107.6456 | GEN515393 1-OGVWVND2G |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 107.6724 | GEN562023 1-G11_020_3 0.6900 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 107.6724 | GEN562026 1-G11_019_3 0.6900 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 107.8893 | GEN525562 1-TOLK GEN #2 24 KV |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 108.0279 | GEN520996 1-MORLND1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 109.8581 | System Intact |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 111.8532 | GEN514806 1-SOONER UNIT 2 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57078 | 113.1185 | GEN514805 1-SOONER UNIT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57086 | 115.9629 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57086 | 115.9629 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 2 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57096 | 112.0292 | CZYCRVT2 69.000 - KNOBHILL 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57104 | 112.1581 | G14-057T 345.00 - LAWTON EASTSIDE 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57104 | 112.6197 | G14-057T 345.00 - SUNNYSIDE 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57122 | 111.9495 | P12:345-SPS-J07.1.FINN.HITCH |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57122 | 111.962 | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57122 | 111.962 | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 2 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57131 | 113.6317 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57131 | 113.6317 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57131 | 113.6317 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57185 | 107.8206 | FAIRVIEW - OKEENE 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57255 | 108.0197 | IODINE - WOODWARD EHV 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57297 | 114.891 | ROMAN NOSE - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57297 | 115.2584 | DEWEY - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57338 | 112.9877 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57351 | 113.1472 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57363 | 117.2643 | DOVER SW - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57365 | 107.4299 | KNOBHILL (KNOBHIL4) 138/69/13.2KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5744 | 111.7586 | CUSTER4 138.00 - ELLIS 4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5744 | 112.2837 | ELLIS 4 138.00 - MOREWOOD SW 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5744 | 112.989 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5744 | 112.989 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57441 | 118.246 | CEDARDALE - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57441 | 118.4454 | CEDARDALE - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57441 | 118.5102 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57441 | 118.536 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57513 | 113.5687 | BYRON_138 138.00 - SANDY_CN_138138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57513 | 115.2886 | BYRON_138 138.00 - C_CITY_138 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57513 | 115.6951 | C_CITY_138 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57513 | 117.2493 | NOEL_SW 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57513 | 118.2849 | P12:138:WFEC:MSL15 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57605 | 107.9055 | RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57708 | 107.6729 | DEWEY - TALOGA 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57819 | 116.5914 | MOREWOOD SW - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57819 | 117.3261 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57819 | 117.778 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57819 | 117.8035 | P12:138:WFEC:MSL14 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58107 | 105.7088 | ALVA - KNOBHILL 69KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.58608 | 102.3567 | FPL SWITCH - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 2OWP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|----------|-------|----------|--------|---------|-----------|--|-------------|-------------|---------|--------------------|--|
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59493 | 112.339 | WOODWARD EHV - WWP4R4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59493 | 112.3391 | WOODWARD - WWP4R4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59883 | 112.4959 | NSAH - WAKITA 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59883 | 114.5809 | NSAH - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59883 | 117.4501 | CLEO JCT - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59883 | 117.4521 | CLEO CORNER - CLEO JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59883 | 112.3 | WAKITAS4 138.00 (WAKITA_XMR) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.6023 | 113.7719 | ALINETP2 69.000 - ALVA 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.6023 | 113.8669 | ALINETP2 69.000 - CLEOTP 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.6023 | 114.0931 | CLEO CORNER - CLEOTP 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.64075 | 123.5758 | CLEO CORNER (CLEOCOR1) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.53849 | 106.2062 | WOODRING (WOODRNG2) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56812 | 101.3108 | G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.56812 | 102.0623 | G15063_T 345.00 - WOODRING 345KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57132 | 102.8246 | NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57132 | 103.3152 | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57138 | 100.9426 | GEN514806 1-SOONER UNIT 2 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57138 | 102.3349 | GEN514805 1-SOONER UNIT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57153 | 102.6389 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57153 | 102.6389 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 2 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5716 | 100.6517 | CZYCRVT2 69.000 - KNOBHILL 69KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57196 | 101.2199 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57196 | 101.2199 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57196 | 101.2199 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57364 | 102.6811 | ROMAN NOSE - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57364 | 103.2844 | DEWEY - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57399 | 102.3677 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57412 | 102.5556 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57434 | 104.0266 | DOVER SW - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57501 | 101.4993 | CUSTER4 138.00 - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57501 | 101.6081 | CUSTER4 138.00 - ELLIS 4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57501 | 102.1258 | ELLIS 4 138.00 - MOREWOOD SW 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57501 | 102.8149 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57501 | 102.8149 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5751 | 105.7207 | CEDARDALE - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5751 | 105.9128 | CEDARDALE - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5751 | 105.98 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5751 | 106.0042 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5758 | 101.2558 | BYRON 138 138.00 - SANDY_CN 138138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5758 | 103.0187 | BYRON 138 138.00 - C_CITY 138 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5758 | 103.5168 | C_CITY 138 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5758 | 105.0668 | NOEL_SW 138.00 - SALT_PLAINS 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.5758 | 106.1181 | P12:138:WFEC:MSL15 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57879 | 107.2816 | MOREWOOD SW - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57879 | 108.021 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57879 | 108.471 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.57879 | 108.494 | P12:138:WFEC:MSL14 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59557 | 104.4209 | WOODWARD - WWP4R4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59557 | 104.4209 | WOODWARD EHV - WWP4R4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59947 | 102.7512 | NSAH - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59947 | 106.0634 | CLEO JCT - RINGWOOD 69KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.59947 | 106.0657 | CLEO CORNER - CLEO JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.6029 | 102.6822 | ALINETP2 69.000 - ALVA 69KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.6029 | 102.8403 | ALINETP2 69.000 - CLEOTP 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.6029 | 103.2162 | CLEO CORNER - CLEOTP 2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_048 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.64137 | 112.5653 | CLEO CORNER (CLEOCOR1) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05558 | 104.1008 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17G | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05558 | 104.1008 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17G | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05558 | 103.9839 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05462 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05462 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05462 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05462 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05462 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.04002 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.04002 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.04002 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.04002 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.04002 | 120.1206 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.04002 | 120.1206 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05424 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_052 | TO->FROM | CLEAVELAND - CLEVIND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05424 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|--|-------------|-------------|---------|--------------------|---|
| FDNS | 08ALL | 2 | 20SP | G15_052 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05424 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_052 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05424 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_052 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05424 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_052 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05424 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_052 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05515 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_052 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05515 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_052 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05515 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_052 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05515 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_052 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05516 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_052 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05516 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 09ALL | 0 | 17SP | G15_053 | FROM->TO | PETERSBRG.N7115.00 - PETERSBURG 115KV CKT Z1 | 137 | 137 | 0.22059 | 101.715 | ANTELOPE 3345.00 - HOSKINS 345KV CKT 1 |
| FDNS | 09ALL | 0 | 17SP | G15_053 | FROM->TO | PETERSBRG.N7115.00 - PETERSBURG 115KV CKT Z1 | 137 | 137 | 0.22059 | 101.7543 | ANTELOPE 3345.00 (ANTELOPE T1) 345/115/13.8KV TRANSFORMER CKT 1 |
| FDNS | 09ALL | 2 | 17SP | G15_053 | FROM->TO | PETERSBRG.N7115.00 - PETERSBURG 115KV CKT Z1 | 137 | 137 | 0.2192 | 102.2592 | ANTELOPE 3345.00 - HOSKINS 345KV CKT 1 |
| FDNS | 09ALL | 2 | 17SP | G15_053 | FROM->TO | PETERSBRG.N7115.00 - PETERSBURG 115KV CKT Z1 | 137 | 137 | 0.2192 | 102.2948 | ANTELOPE 3345.00 (ANTELOPE T1) 345/115/13.8KV TRANSFORMER CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_055 | TO->FROM | STALINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.13275 | 120.2549 | System Intact |
| FDNS | 07ALL | 0 | 25SP | G15_055 | TO->FROM | STALINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.25266 | 106.1201 | CHISHOLM7 345.00 (I) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_055 | TO->FROM | STALINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.25266 | 127.0248 | CHISHOLM7 345.00 - GRACEMONT 345KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_055 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.13275 | 118.7492 | System Intact |
| FDNS | 07ALL | 0 | 25SP | G15_055 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.25266 | 114.6098 | CHISHOLM7 345.00 (I) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_055 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.25266 | 137.1842 | CHISHOLM7 345.00 - GRACEMONT 345KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_055 | TO->FROM | GRAPEVINE INTERCHANGE - STALINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.21098 | 99.5 | CHISHOLM7 345.00 - GRACEMONT 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 1792 | 1972 | 0.18592 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 1792 | 1792 | 0.18592 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 1022 | 1124 | 0.24703 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 1022 | 1124 | 0.24703 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.19041 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 987.16 | 1082.77 | 0.15487 | - | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.15487 | - | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 560 | 560 | 0.19041 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 435.02 | 457.73 | 0.1159 | - | STALINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 439 | 439 | 0.1159 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 439 | 439 | 0.1159 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_056 | | Non-Converged Contingency | 329.05 | 360.92 | 0.09446 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.41078 | 101.7566 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.41078 | 106.3032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 107.868 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 107.868 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 109.6833 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 109.6833 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 108.0801 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 108.0801 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 109.7267 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 109.7267 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 107.7709 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 107.7709 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 109.5653 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.30302 | 109.5653 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.41078 | 110.605 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.41078 | 115.547 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 117.2478 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 117.2478 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 119.2209 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 119.2209 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 117.4783 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 117.4783 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 119.2681 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 119.2681 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 117.1423 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 117.1423 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 119.0927 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.30302 | 119.0927 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_056 | FROM->TO | GRAPEVINE INTERCHANGE - STALINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.09803 | 105.8464 | System Intact |
| FDNS | 06ALL | 0 | 16WP | G15_056 | FROM->TO | BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.20477 | 100.1938 | NEWHART 230 - POTTER COUNTY INTERCHANGE 230KV CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_056 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.09446 | 119.5011 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_056 | | Non-Converged Contingency | 0 | 0 | 0.14927 | - | P12:230:AEWP-ELKCITY6:SWEETW6 |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_056 | | Non-Converged Contingency | 0 | 0 | 0.22362 | - | P12:230:AEWP-SPS:SWEETW6:WHEELER 6 |
| FDNS | 06ALL | 0 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.39833 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.39833 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.39833 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_056 | FROM->TO | TUCO INTER | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|--|-------------|-------------|---------|--------------------|---|
| FDNS | 06ALL | 3 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29527 | 102.7136 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29527 | 105.0661 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29527 | 102.7136 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29527 | 105.0661 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29527 | 102.6492 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.29527 | 105.032 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29527 | 102.6492 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 17G | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.29527 | 105.032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_056 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.11181 | 113.2775 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_056 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.11181 | 111.4968 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_056 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.09458 | 117.5205 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_056 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 439 | 439 | 0.11181 | 103.2013 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_056 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.0912 | 130.5235 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_056 | | Non-Converged Contingency | 1792 | 1792 | 0.18555 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_056 | | Non-Converged Contingency | 956 | 1042 | 0.24532 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_056 | | Non-Converged Contingency | 956 | 1042 | 0.24532 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNS | 06ALL | 0 | 17SP | G15_056 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.09247 | 113.0163 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 1792 | 1792 | 0.17431 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 1792 | 1792 | 0.17431 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 1792 | 1792 | 0.17431 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 1022 | 1124 | 0.21303 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 1022 | 1124 | 0.21303 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.14655 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.14655 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.12381 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.12381 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 560 | 560 | 0.14655 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 560 | 560 | 0.14655 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 421 | 439 | 0.08039 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 348.58 | 381.24 | 0.08039 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 353 | 353 | 0.08039 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 318.7 | 350.57 | 0.06526 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 318.7 | 350.57 | 0.06526 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 0 | 0 | 0.10877 | - | P12:230:AEPW-ELKCITY6-SWEETW6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 0 | 0 | 0.16078 | - | P12:230:AEPW-SPS-SWEETW6:WHEELER 6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_056 | | Non-Converged Contingency | 0 | 0 | 0.2318 | - | P12:345:SPS:J07.1.FINN.HITCH |
| FDNS | 06ALL | 2 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.26832 | 124.5568 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.26832 | 124.5568 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.26832 | 126.1974 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.26832 | 126.1974 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 124.5568 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 124.5568 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 126.1974 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 126.1974 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.26832 | 124.7887 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.26832 | 124.7887 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.26832 | 126.2595 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.26832 | 126.2595 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 124.7887 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 126.2595 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 126.2595 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.26832 | 124.5715 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.26832 | 124.5715 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 126.1329 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 126.1329 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 124.5715 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 124.5715 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_056 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.26832 | 126.1329 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 20L | G15_056 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.08039 | 109.5807 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_056 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.08039 | 107.8845 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_056 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.06797 | 112.5437 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_056 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.08039 | 105.6208 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_056 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.06526 | 119.8088 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_056 | | Non-Converged Contingency | 1792 | 1792 | 0.20168 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_056 | | Non-Converged Contingency | 956 | 1042 | 0.25041 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNS | 06ALL | 0 | 20SP | G15_056 | TO->FROM | DEAF SMITH COUNTY INTERCHANGE - PLANT X STATION 230KV CKT 1 | 318.7 | 350.6 | 0.19576 | 102.0399 | NEWARTH 230 - PLANT X STATION 230KV CKT 1 |
| FDNS | 06ALL | 0 | 20SP | G15_056 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.08364 | 105.913 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_056 | | Non-Converged Contingency | 1792 | 1792 | 0.19765 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_056 | | Non-Converged Contingency | 1792 | 1792 | 0.19765 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_056 | | Non-Converged Contingency | 1022 | 1124 | 0.24498 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_056 | | Non-Converged Contingency | 1022 | 1124 | 0.24498 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_056 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.17517 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|--|-------------|-------------|---------|--------------------|---|
| FDNS | 06ALL | 2 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 117.2478 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 119.2209 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 119.2209 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 117.4783 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 117.4783 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 119.2681 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 119.2681 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 117.1423 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 117.1423 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 119.0927 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.24161 | 119.0927 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_058 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.09673 | 105.8464 | System Intact |
| FDNS | 06ALL | 0 | 16WP | G15_058 | FROM->TO | BUSHLAND INTERCHANGE - POTTER COUNTY INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.19992 | 100.1938 | NEWHART 230 - POTTER COUNTY INTERCHANGE 230KV CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_058 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.0932 | 119.5011 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_058 | | Non-Converged Contingency | 0 | 0 | 0.14732 | - | P12:230:AEPW-ELKCITY6:SWEETWT6 |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_058 | | Non-Converged Contingency | 0 | 0 | 0.22054 | - | P12:230:AEPW-SPS:SWEETWT6:WHEELER 6 |
| FDNS | 06ALL | 0 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.40443 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.40443 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.40443 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.40443 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.23385 | 102.5642 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.23385 | 105.1317 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.23385 | 102.5642 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.23385 | 105.1317 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.23387 | 102.7136 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.23387 | 105.0661 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.23387 | 102.7136 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.23387 | 105.0661 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.23387 | 102.6492 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.23387 | 105.032 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.23387 | 102.6492 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 17G | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.23387 | 105.032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_058 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.11027 | 113.2775 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_058 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.11027 | 111.4968 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_058 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.09328 | 117.5205 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_058 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 439 | 439 | 0.11027 | 103.2013 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_058 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.08994 | 130.5235 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_058 | | Non-Converged Contingency | 1792 | 1792 | 0.18915 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_058 | | Non-Converged Contingency | 956 | 1042 | 0.24905 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_058 | | Non-Converged Contingency | 956 | 1042 | 0.24905 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNS | 06ALL | 0 | 17SP | G15_058 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.09104 | 113.0163 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 1792 | 1792 | 0.18555 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 1792 | 1792 | 0.18555 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 1792 | 1792 | 0.18555 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 1022 | 1124 | 0.22482 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 1022 | 1124 | 0.22482 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.1373 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.1373 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.11985 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.11985 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 560 | 560 | 0.1373 | - | POTTER COUNTY INTERCHANGE (WAWK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 560 | 560 | 0.1373 | - | POTTER COUNTY INTERCHANGE (WAWK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 421 | 439 | 0.07488 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 348.58 | 381.24 | 0.07488 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 353 | 353 | 0.07488 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 318.7 | 350.57 | 0.06074 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 318.7 | 350.57 | 0.06074 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 0 | 0 | 0.10117 | - | P12:230:AEPW-ELKCITY6:SWEETWT6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 0 | 0 | 0.14975 | - | P12:230:AEPW-SPS:SWEETWT6:WHEELER 6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_058 | | Non-Converged Contingency | 0 | 0 | 0.22438 | - | P12:345:SPS:J07.1.FINN.HITCH |
| FDNS | 06ALL | 2 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19688 | 124.5568 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19688 | 124.5568 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19688 | 126.1974 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19688 | 126.1974 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.19688 | 124.5568 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.19688 | 124.5568 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.19688 | 126.1974 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.19688 | 126.1974 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19688 | 124.7887 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19688 | 124.7887 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_058 | FROM | | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|--|----------------|----------------|---------|-----------------------|---|
| FDNS | 06ALL | 3 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.19688 | 126.2595 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.19688 | 126.2595 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19688 | 124.5715 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19688 | 124.5715 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19688 | 126.1329 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19688 | 126.1329 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.19688 | 124.5715 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.19688 | 124.5715 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.19688 | 126.1329 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.19688 | 126.1329 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 20L | G15_058 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.07488 | 109.5807 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_058 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.07488 | 107.8845 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_058 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.0633 | 112.5437 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_058 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.07488 | 105.6208 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_058 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.06074 | 119.8088 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_058 | | Non-Converged Contingency | 1792 | 1792 | 0.21293 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_058 | | Non-Converged Contingency | 956 | 1042 | 0.2622 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNS | 06ALL | 0 | 20SP | G15_058 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.07912 | 105.913 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 1792 | 1792 | 0.20889 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 1792 | 1972 | 0.20889 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 1022 | 1124 | 0.25677 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 1022 | 1124 | 0.25677 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.16592 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 987.16 | 1082.77 | 0.14078 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 560 | 560 | 0.16592 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 435.02 | 457.73 | 0.09357 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 439 | 439 | 0.09357 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 421 | 439 | 0.09357 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_058 | | Non-Converged Contingency | 329.05 | 360.92 | 0.07639 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22782 | 123.1875 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22782 | 123.1875 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22782 | 125.4351 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22782 | 125.4351 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22784 | 123.3712 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22784 | 123.3712 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22784 | 125.4088 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22784 | 125.4088 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22784 | 123.0816 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22784 | 123.0816 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22784 | 125.2246 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.22784 | 125.2246 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22782 | 133.8994 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22782 | 133.8994 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22782 | 136.3425 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22782 | 136.3425 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22784 | 134.0991 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22784 | 134.0991 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22784 | 136.3139 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22784 | 136.3139 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22784 | 133.7844 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22784 | 133.7844 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22784 | 136.1137 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_058 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.22784 | 136.1137 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 20WP | G15_058 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.07917 | 113.3624 | System Intact |
| FDNS | 06ALL | 0 | 20WP | G15_058 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.09357 | 105.3667 | System Intact |
| FDNS | 06ALL | 0 | 20WP | G15_058 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.07639 | 128.5448 | System Intact |
| FDNS | 06ALL | 2 | 20WP | G15_058 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05869 | 100.0 | System Intact |
| FDNS | 06ALL | 3 | 20WP | G15_058 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05869 | 99.9 | System Intact |
| FDNS | 06ALL | 4 | 20WP | G15_058 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05869 | 100.0 | System Intact |
| FDNS | 01ALL | 3 | 16WP | G15_059 | FROM->TO | CIMARRON - DRAPER LAKE 345KV CKT 1 | 717.0 | 717.0 | 0.20083 | 103.6296 | GRACEMONT - MINCO 345KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_060 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.03259 | 117.8972 | System Intact |
| FDNS | 01ALL | 0 | 17G | G15_060 | FROM->TO | G15095 T 138.00 - ROSE VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.02986 | 114.036 | System Intact |
| FDNS | 01ALL | 0 | 17G | G15_060 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.03342 | 111.7985 | System Intact |
| FDNS | 01ALL | 0 | 17G | G15_060 | TO->FROM | NOEL SW 138.00 - ROSE VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.02986 | 108.0387 | System Intact |
| FDNS | 01ALL | 0 | 17G | G15_060 | TO->FROM | ROMAN NOSE - SOUTHARD 138KV CKT 1 | 133 | 153 | 0.0492 | 106.4715 | System Intact |
| FDNS | 01ALL | 2 | 17G | G15_060 | TO->FROM | ROMAN NOSE - SOUTHARD 138KV CKT 1 | 133.0 | 153.0 | 0.04916 | 106.284 | System Intact |
| FDNS | 01ALL | 0 | 17SP | G15_060 | FROM->TO | G15095 T 138.00 - ROSE VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.02954 | 120.4845 | System Intact |
| FDNS | 01ALL | 0 | 17SP | G15_060 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.03264 | 117.5578 | System Intact |
| FDNS | 01ALL | 0 | 17SP | G15_060 | TO->FROM | NOEL SW 138.00 - ROSE VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.02954 | 113.4116 | System Intact |
| FDNS | 01ALL | 0 | 17SP | G15_060 | TO->FROM | ROMAN NOSE - SOUTHARD 138KV CKT 1 | 133 | 153 | 0.04876 | 106.118 | System Intact |
| FDNS | 01ALL | 2 | 17SP | G15_060 | TO->FROM | ROMAN NOSE - SOUTHARD 138KV CKT 1 | 133.0 | 153 | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATE | | | TC%LOADING (% MVA) | CONTINGENCY |
|----------|-------|----------|--------|---------|-----------|--|--------|--------|---------|-----------------------|--|
| | | | | | | | (MVA) | (MVA) | TDF | | |
| FDNS | 01ALL | 0 | 25SP | G15_060 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493 | 493 | 0.75077 | 100 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 2 | 25SP | G15_060 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493.0 | 493.0 | 0.75051 | 99.7 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 3 | 25SP | G15_060 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493.0 | 493.0 | 0.75051 | 99.7 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 4 | 25SP | G15_060 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 | 493.0 | 493.0 | 0.75560 | 102.6172 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 4 | 25SP | G15_060 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 | 493.0 | 493.0 | 0.75560 | 103.523 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 4 | 25SP | G15_060 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493.0 | 493.0 | 0.75915 | 103.0825 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 4 | 25SP | G15_060 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493.0 | 493.0 | 0.75915 | 103.9633 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.19572 | 100.2451 | LACYGNE - WAVERLY7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.1998 | 100.2015 | MORISNT4 138.00 - STILLWATER 138KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20084 | 100.1579 | P12:138:OKGE:3TERM2 |
| FDNS | 08ALL | 0 | 16WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20362 | 121.8649 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20362 | 121.9421 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20789 | 103.2273 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20789 | 103.2273 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.21303 | 104.9344 | G15066 T 345.00 - SOONER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.21303 | 109.3441 | CLEVELAND - G15066 T 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.24216 | 114.4247 | VIOLA 7 345.00 - WICHITA 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20554 | 117.7802 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20554 | 117.8392 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20938 | 100.7373 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.21446 | 102.5154 | G15066 T 345.00 - SOONER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.21446 | 106.8931 | CLEVELAND - G15066 T 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.2423 | 111.9483 | VIOLA 7 345.00 - WICHITA 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03817 | 104.1008 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17G | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03817 | 104.1008 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17G | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03817 | 103.9839 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20815 | 117.3912 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20885 | 109.8071 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.21554 | 101.0864 | CLEVELAND - G15066 T 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.24659 | 104.6493 | VIOLA 7 345.00 - WICHITA 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03722 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03722 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03722 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03722 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03722 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03722 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03722 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.21043 | 104.7146 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03629 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03629 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03629 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03629 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03629 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03629 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20727 | 109.6471 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20727 | 109.7423 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20WP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.21465 | 100.5721 | CLEVELAND - G15066 T 345.00 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 1192.0 | 1192.0 | 0.20888 | 100.4184 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 1192.0 | 1192.0 | 0.20883 | 100.0 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20888 | 125.2078 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.20956 | 117.6504 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_062 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.21607 | 103.7341 | CLEVELAND - G15066 T 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.0372 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.0372 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03720 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03720 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03721 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_062 | TO->FROM | CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03721 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.55814 | 100.2329 | G11_051T 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.55814 | 105.5175 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.56499 | 121.8649 | NORTHWEST - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.56499 | 121.9421 | SOONER - SPRING CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.58501 | 100.2015 | MORISNT4 138.00 - STILLWATER 138KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.58517 | 100.1579 | P12:138:OKGE:3TERM2 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.5857 | 100.2451 | LACYGNE - WAVERLY7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.59663 | 103.2273 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.59663 | 103.2273 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.60318 | 104.9344 | G15066 T 345.00 - SOONER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.60318 | 109.3441 | CLEVELAND - G15066 T 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_063 | FROM->TO | G15063 T 345.00 - MATHWSN7 345.00 345KV CKT 1 | 956 | 956 | 0.63105 | 114.4247 | VIOLA 7 345.00 - WICH |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|---|-------------|-------------|---------|--------------------|---|
| FDNS | 08ALL | 3 | 25SP | G15_066 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.15326 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05507 | 104.1008 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17G | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05507 | 104.1008 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17G | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05507 | 103.9839 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05412 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05412 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05412 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05412 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05412 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05412 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03948 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20L | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03948 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03948 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20L | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03948 | 120.3301 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03948 | 120.1206 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20L | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03948 | 120.1206 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.0537 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.0537 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05370 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05370 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05370 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05370 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05462 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.05462 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05462 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05462 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05463 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_067 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.05463 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 1792 | 1972 | 0.26284 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 1792 | 1792 | 0.26284 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 1022 | 1124 | 0.32673 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 1022 | 1124 | 0.32673 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.12803 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 987.16 | 1082.77 | 0.12845 | - | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.12845 | - | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 560 | 560 | 0.12803 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 435.02 | 457.73 | 0.07778 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 439 | 439 | 0.07778 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 439 | 439 | 0.07778 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_068 | | Non-Converged Contingency | 329.05 | 360.92 | 0.06326 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_068 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.06577 | 105.8464 | System Intact |
| FDNS | 06ALL | 0 | 16WP | G15_068 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.06326 | 119.5011 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_068 | | Non-Converged Contingency | 0 | 0 | 0.10064 | - | P12:230:AEPW-ELKCITY6-SWEETWT6 |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_068 | | Non-Converged Contingency | 0 | 0 | 0.14737 | - | P12:230:AEPW-SPS-SWEETWT6:WHEELER 6 |
| FDNS | 06ALL | 0 | 17G | G15_068 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.07369 | 113.2775 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_068 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.07369 | 111.4968 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_068 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.06232 | 117.5205 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_068 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 439 | 439 | 0.07369 | 103.2013 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_068 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.06 | 130.5235 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_068 | | Non-Converged Contingency | 1792 | 1792 | 0.26025 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_068 | | Non-Converged Contingency | 956 | 1042 | 0.3228 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_068 | | Non-Converged Contingency | 956 | 1042 | 0.3228 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNS | 06ALL | 0 | 17SP | G15_068 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.06227 | 113.0163 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 1792 | 1972 | 0.22992 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 1792 | 1972 | 0.22992 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 1792 | 1792 | 0.22992 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 1022 | 1124 | 0.27138 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 1022 | 1124 | 0.27138 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.10099 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.10426 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.10426 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 560 | 560 | 0.10099 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 560 | 560 | 0.10099 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 421 | 439 | 0.05298 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 348.58 | 381.24 | 0.05298 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 353 | 353 | 0.05298 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 318.7 | 350.57 | 0.04283 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 318.7 | 350.57 | 0.04283 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 0 | 0 | 0.07365 | - | P12:230:AEPW-ELKCITY6-SWEETWT6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 0 | 0 | 0.10597 | - | P12:230:AEPW-SPS-SWEETWT6:WHEELER 6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_068 | | Non-Converged Contingency | 0 | 0 | 0.19515 | - | P12:345:SPS:J07.1.FINN.HITCH |
| FDNS | 06ALL | 0 | 20L | G15_068 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.05298 | 109.5807 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_068 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.05298 | 107.8845 | System Intact |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|--|-------------|-------------|---------|--------------------|---|
| FDNS | 06ALL | 0 | 20L | G15_068 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.04478 | 112.5437 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_068 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.05298 | 105.6208 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_068 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.04283 | 119.8088 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_068 | | Non-Converged Contingency | 1792 | 1792 | 0.25731 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_068 | | Non-Converged Contingency | 956 | 1042 | 0.30877 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNS | 06ALL | 0 | 20SP | G15_068 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.0612 | 105.913 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 1792 | 1972 | 0.25327 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 1792 | 1792 | 0.25327 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 1022 | 1124 | 0.30334 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 1022 | 1124 | 0.30334 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.1296 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 987.16 | 1082.77 | 0.12518 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 560 | 560 | 0.1296 | - | POTTER COUNTY INTERCHANGE (WALK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 435.02 | 457.73 | 0.07167 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 439 | 439 | 0.07167 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 421 | 439 | 0.07167 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_068 | | Non-Converged Contingency | 329.05 | 360.92 | 0.05847 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 0 | 20WP | G15_068 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.06064 | 113.3624 | System Intact |
| FDNS | 06ALL | 0 | 20WP | G15_068 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.07167 | 105.3667 | System Intact |
| FDNS | 06ALL | 0 | 20WP | G15_068 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05847 | 128.5448 | System Intact |
| FDNS | 06ALL | 2 | 20WP | G15_068 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.03577 | 100.0 | System Intact |
| FDNS | 06ALL | 3 | 20WP | G15_068 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.03577 | 99.9 | System Intact |
| FDNS | 06ALL | 4 | 20WP | G15_068 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.03577 | 100.0 | System Intact |
| FDNS | 0 | 0 | 25SP | G15_068 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.29988 | 100 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 0 | 0 | 25SP | G15_068 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.29988 | 100 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 0 | 0 | 25SP | G15_068 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.29988 | 101.6287 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 0 | 0 | 25SP | G15_068 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.29988 | 101.6287 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 0 | 0 | 25SP | G15_068 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.29988 | 100 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 0 | 0 | 25SP | G15_068 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.29988 | 100 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 0 | 0 | 25SP | G15_068 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.29988 | 101.6287 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 0 | 0 | 25SP | G15_068 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.29988 | 101.6287 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_069 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.19846 | 103.8355 | LACYGNE - WAVERLY7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_069 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.24081 | 102.9837 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_069 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.25703 | 105.4782 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_069 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.23354 | 108.0149 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_069 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.2491 | 111.817 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_069 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.23285 | 118.6866 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_069 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.24824 | 121.2614 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_069 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.23138 | 107.8953 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_069 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.24702 | 109.3373 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20WP | G15_069 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.25093 | 101.1626 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.16629 | 120.2549 | System Intact |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.19885 | 114.6045 | GRACEMONT - MINCO 345KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.19885 | 117.6017 | CIMARRON - MINCO 345KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.2225 | 112.0392 | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.2225 | 112.0392 | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.2225 | 112.0471 | CHISHOLM6 230.00 - ELK CITY 230KV 230KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.41266 | 127.0248 | CHISHOLM7 345.00 - GRACEMONT 345KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.16629 | 118.7492 | System Intact |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.19885 | 123.7728 | GRACEMONT - MINCO 345KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.19885 | 127.0096 | CIMARRON - MINCO 345KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.2225 | 121.0015 | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.2225 | 121.0015 | ELK CITY 230KV (ELKCTY-6) 230/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.2225 | 121.0101 | CHISHOLM6 230.00 - ELK CITY 230KV 230KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.41266 | 137.1842 | CHISHOLM7 345.00 - GRACEMONT 345KV CKT 1 |
| FDNS | 07ALL | 0 | 25SP | G15_071 | TO->FROM | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.3437 | 99.5 | CHISHOLM7 345.00 - GRACEMONT 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.30317 | 103.8355 | LACYGNE - WAVERLY7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.3372 | 102.9837 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.35274 | 105.4782 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 16WP | G15_073 | FROM->TO | EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1 | 717 | 717 | 0.40618 | 100.1228 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.29731 | 107.0623 | LACYGNE - WAVERLY7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.32992 | 108.0149 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.34481 | 111.817 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08NR | 0 | 17G | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717.0 | 717.0 | 0.08663 | 100.7418 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.29527 | 111.8642 | LACYGNE - WAVERLY7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.32883 | 118.6866 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.34359 | 121.2614 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_073 | FROM->TO | EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1 | 717 | 717 | 0.37494 | 108.005 | LACYGNE - WAVERLY7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_073 | FROM->TO | EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1 | 717 | 717 | 0.39953 | 107.1159 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_073 | FROM->TO | EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1 | 717 | 717 | 0.40387 | 119.2027 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.29349 | 101.3957 | LACYGNE - WAVERLY7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.32768 | 107.8953 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.34276 | 109.3373 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_073 | FROM->TO | EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1 | 717 | 717 | 0.3742 | 101.3698 | LACYGNE - WAVERLY7 345.00 345KV CKT 1 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|---------|----------|--------|---------|-----------|--|-------------|-------------|---------|--------------------|---|
| FDNS | 08ALL | 0 | 20SP | G15_073 | FROM->TO | EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1 | 717 | 717 | 0.39913 | 100 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_073 | FROM->TO | EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1 | 717 | 717 | 0.40351 | 111.7784 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20WP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.29681 | 100.5666 | LACYGNE - WAVERLY 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20WP | G15_073 | FROM->TO | SWISSVALE - WEST GARDNER 345KV CKT 1 | 717 | 717 | 0.34667 | 101.1626 | HOYT - STRANGER CREEK 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_073 | FROM->TO | EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1 | 717 | 717 | 0.40405 | 102.547 | HOYT - JEFFREY ENERGY CENTER 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 1792 | 1972 | 0.22163 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 1792 | 1972 | 0.22163 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 1022 | 1124 | 0.28398 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 1022 | 1124 | 0.28398 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.16101 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 987.16 | 1082.77 | 0.14253 | - | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.14253 | - | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 560 | 560 | 0.16101 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 435.02 | 457.73 | 0.09848 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 439 | 439 | 0.09848 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 439 | 439 | 0.09848 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_075 | | Non-Converged Contingency | 329.05 | 360.92 | 0.08021 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 0 | 0 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE - LP-DOUD_TP 3115.00 115KV CKT 1 | 165 | 177 | 0.24869 | 100.2975 | LUBBOCK SOUTH INTERCHANGE - WOLFFORTH INTERCHANGE 230KV CKT 1 |
| FDNS | 0 | 0 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE - LP-DOUD_TP 3115.00 115KV CKT 1 | 165 | 177 | 0.24869 | 100.2975 | LUBBOCK SOUTH INTERCHANGE - WOLFFORTH INTERCHANGE 230KV CKT 1 |
| FDNS | 00 | 2 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE - LP-DOUD_TP 3115.00 115KV CKT 1 | 165.0 | 177.0 | 0.24870 | 100.2966 | LUBBOCK SOUTH INTERCHANGE - WOLFFORTH INTERCHANGE 230KV CKT 1 |
| FDNS | 00 | 2 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE - LP-DOUD_TP 3115.00 115KV CKT 1 | 165.0 | 177.0 | 0.24870 | 100.2966 | LUBBOCK SOUTH INTERCHANGE - WOLFFORTH INTERCHANGE 230KV CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.47972 | 101.7566 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.47972 | 106.3032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 107.868 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 107.868 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 109.6833 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 109.6833 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 108.0801 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 108.0801 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 109.7267 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 109.7267 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 107.7709 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 107.7709 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 109.5653 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.48319 | 109.5653 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.47972 | 110.605 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.47972 | 115.547 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 117.2478 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 117.2478 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 119.2209 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 119.2209 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 117.4783 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 117.4783 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 119.2681 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 119.2681 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 117.1423 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 117.1423 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 119.0927 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 16WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.48319 | 119.0927 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_075 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.08329 | 105.8464 | System Intact |
| FDNS | 06ALL | 0 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1 | 106.1556 | System Intact |
| FDNS | 06ALL | 0 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1 | 107.7303 | System Intact |
| FDNS | 06ALL | 2 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 106.3056 | System Intact |
| FDNS | 06ALL | 2 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 108.0994 | System Intact |
| FDNS | 06ALL | 3 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 106.3201 | System Intact |
| FDNS | 06ALL | 3 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 108.1331 | System Intact |
| FDNS | 06ALL | 4 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 106.3084 | System Intact |
| FDNS | 06ALL | 4 | 16WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 108.106 | System Intact |
| FDNS | 06ALL | 0 | 16WP | G15_075 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.08021 | 119.5011 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_075 | | Non-Converged Contingency | 0 | 0 | 0.12707 | - | P12:230:AEPW-ELKCITY6-SWEETW6 |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_075 | | Non-Converged Contingency | 0 | 0 | 0.18877 | - | P12:230:AEPW-SPS-SWEETW6-WHEELER 6 |
| FDNS | 06ALL | 0 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.46727 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.46727 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.46727 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.46727 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47543 | 102.5642 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47543 | 103.1317 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.47543 | 102.5642 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.47543 | 103.1317 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL</ | | | | | | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|--|----------------|----------------|---------|-----------------------|---|
| FDNS | 06ALL | 4 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47545 | 105.032 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.47545 | 102.6492 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 17G | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.47545 | 105.032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_075 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.09439 | 113.2775 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_075 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.09439 | 111.4968 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_075 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.07984 | 117.5205 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1 | 102.1212 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1 | 103.7811 | System Intact |
| FDNS | 06ALL | 2 | 17G | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 102.3166 | System Intact |
| FDNS | 06ALL | 2 | 17G | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 104.2107 | System Intact |
| FDNS | 06ALL | 3 | 17G | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 102.3366 | System Intact |
| FDNS | 06ALL | 3 | 17G | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 104.2526 | System Intact |
| FDNS | 06ALL | 4 | 17G | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 102.3352 | System Intact |
| FDNS | 06ALL | 4 | 17G | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 104.2498 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_075 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 439 | 439 | 0.09439 | 103.2013 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_075 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.07695 | 130.5235 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_075 | | Non-Converged Contingency | 1792 | 1792 | 0.21905 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_075 | | Non-Converged Contingency | 956 | 1042 | 0.28002 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_075 | | Non-Converged Contingency | 956 | 1042 | 0.28002 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNS | 06ALL | 0 | 17SP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1 | 99.7 | System Intact |
| FDNS | 06ALL | 2 | 17SP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 99.6 | System Intact |
| FDNS | 06ALL | 3 | 17SP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 99.6 | System Intact |
| FDNS | 06ALL | 4 | 17SP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 99.5 | System Intact |
| FDNS | 06ALL | 0 | 17SP | G15_075 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.07915 | 113.0163 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 1792 | 1972 | 0.19848 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 1792 | 1972 | 0.19848 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 1792 | 1792 | 0.19848 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 1022 | 1124 | 0.23834 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 1022 | 1124 | 0.23834 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.12634 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.12634 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.11524 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.11524 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 560 | 560 | 0.12634 | - | POTTER COUNTY INTERCHANGE (WAKU 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 560 | 560 | 0.12634 | - | POTTER COUNTY INTERCHANGE (WAKU 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 421 | 439 | 0.06875 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 348.58 | 381.24 | 0.06875 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 353 | 353 | 0.06875 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 318.7 | 350.57 | 0.05574 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 318.7 | 350.57 | 0.05574 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 0 | 0 | 0.09386 | - | P12:230:AEPW:ELKCITY6:SWEETW76 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 0 | 0 | 0.13749 | - | P12:230:AEPW-SPS:SWEETW76:WHEELER 6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_075 | | Non-Converged Contingency | 0 | 0 | 0.21574 | - | P12:345:SPS:J07.1.FINN.HITCH |
| FDNS | 06ALL | 2 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 124.5568 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 124.5568 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 126.1974 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 126.1974 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 124.5568 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 124.5568 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 126.1974 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 126.1974 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 124.7887 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 124.7887 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 126.2595 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 126.2595 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 124.7887 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 124.7887 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 126.2595 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 126.2595 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 124.5715 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 124.5715 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 126.1329 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.44099 | 126.1329 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 124.5715 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 124.5715 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20L | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560.0 | 644.0 | 0.44099 | 126.1329 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 20L | G15_075 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.06875 | 109.5807 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_075 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.06875 | 107.8845 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_075 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.05812 | 112.5437 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1 | 109.7696 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1 | 111.692 | System Intact |
| FDNS | 06ALL | 2 | 20L | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 109.8168 | System Intact |
| FDNS | 06ALL | 2 | 20L | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|--|----------------|----------------|---------|-----------------------|---|
| FDNS | 06ALL | 3 | 20L | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 109.8264 | System intact |
| FDNS | 06ALL | 4 | 20L | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 111.8326 | System intact |
| FDNS | 06ALL | 4 | 20L | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 109.8223 | System intact |
| FDNS | 06ALL | 4 | 20L | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 111.8225 | System intact |
| FDNS | 06ALL | 0 | 20L | G15_075 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.06875 | 105.6208 | System intact |
| FDNS | 06ALL | 0 | 20L | G15_075 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.05574 | 119.8088 | System intact |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_075 | | Non-Converged Contingency | 1792 | 1792 | 0.22582 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_075 | | Non-Converged Contingency | 956 | 1042 | 0.27569 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNS | 06ALL | 0 | 20SP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1 | 99.6 | System intact |
| FDNS | 06ALL | 2 | 20SP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 99.7 | System intact |
| FDNS | 06ALL | 3 | 20SP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 99.6 | System intact |
| FDNS | 06ALL | 4 | 20SP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 99.6 | System intact |
| FDNS | 06ALL | 0 | 20SP | G15_075 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.07413 | 105.913 | System intact |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 1792 | 1792 | 0.22178 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 1792 | 1972 | 0.22178 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 1022 | 1124 | 0.27026 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 1022 | 1124 | 0.27026 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.15498 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 987.2 | 1082.77 | 0.13618 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 560 | 560 | 0.15498 | - | POTTER COUNTY INTERCHANGE (WAWK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 435.02 | 457.73 | 0.08746 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 439 | 439 | 0.08746 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 421 | 439 | 0.08746 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_075 | | Non-Converged Contingency | 329.05 | 360.92 | 0.0714 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47182 | 123.1875 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47182 | 123.1875 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47182 | 125.4351 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47182 | 125.4351 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47183 | 123.3712 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47183 | 123.3712 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47183 | 125.4088 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47183 | 125.4088 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47183 | 123.0816 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47183 | 123.0816 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47183 | 125.2246 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.47183 | 125.2246 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.39595 | 103.3651 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.39595 | 103.3651 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.39595 | 107.5535 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.39595 | 107.5535 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47182 | 133.8994 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47182 | 133.8994 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47182 | 136.3425 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47182 | 136.3425 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47183 | 134.0991 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47183 | 134.0991 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47183 | 136.3139 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47183 | 136.3139 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47183 | 133.7844 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47183 | 133.7844 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47183 | 136.1137 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_075 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.47183 | 136.1137 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 20WP | G15_075 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.074 | 113.3624 | System intact |
| FDNS | 06ALL | 0 | 20WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1 | 105.7037 | System intact |
| FDNS | 06ALL | 0 | 20WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1 | 107.6194 | System intact |
| FDNS | 06ALL | 2 | 20WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 105.7468 | System intact |
| FDNS | 06ALL | 2 | 20WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 107.7169 | System intact |
| FDNS | 06ALL | 3 | 20WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 105.7597 | System intact |
| FDNS | 06ALL | 3 | 20WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 107.7458 | System intact |
| FDNS | 06ALL | 4 | 20WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 105.7537 | System intact |
| FDNS | 06ALL | 4 | 20WP | G15_075 | FROM->TO | CARLISLE INTERCHANGE (WH RLP38371) 115/69/13.2KV TRANSFORMER CKT 1 | 44.37 | 44.4 | 1.00000 | 107.7325 | System intact |
| FDNS | 06ALL | 0 | 20WP | G15_075 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.08746 | 105.3667 | System intact |
| FDNS | 06ALL | 0 | 20WP | G15_075 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.0714 | 128.5448 | System intact |
| FDNS | 06ALL | 2 | 20WP | G15_075 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05227 | 100.0 | System intact |
| FDNS | 06ALL | 3 | 20WP | G15_075 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05228 | 99.9 | System intact |
| FDNS | 06ALL | 4 | 20WP | G15_075 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05228 | 100.0 | System intact |
| FDNS | 09ALL | 0 | 16WP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21653 | 106.426 | GAVINS POINT - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 2 | 16WP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21678 | 106.5505 | GAVINS POINT - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 0 | 17G | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21542 | 103.2626 | GAVINS POINT - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 2 | 17G | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21567 | 103.673 | GAVINS POINT - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 0 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.20497 | 103.1197 | SIOUX CITY - TWIN CHURCH 230KV CKT 1 |
| FDNS | 09ALL | 0 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | | | | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|--|-------------|-------------|---------|--------------------|---|
| FDNS | 09ALL | 0 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21135 | 118.2407 | GAVINS POINT - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 0 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21237 | 100.7949 | BLOOMFIELD - CREIGHTON 115KV CKT 1 |
| FDNS | 09ALL | 0 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.25751 | 102.1569 | BELDEN - TWIN CHURCH 115KV CKT 1 |
| FDNS | 09ALL | 0 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.30216 | 102.5652 | BELDEN - HOSKINS 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.20497 | 103.1197 | SIOUX CITY - TWIN CHURCH 230KV CKT 1 |
| FDNS | 09ALL | 2 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21135 | 100.2637 | BERSFORD - SIOUX FALLS 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21135 | 107.5992 | BERSFORD - MANNING 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21135 | 111.0021 | MANNING - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21135 | 118.2407 | GAVINS POINT - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21237 | 100.7949 | BLOOMFIELD - CREIGHTON 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.25751 | 102.1569 | BELDEN - TWIN CHURCH 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20L | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.30216 | 102.5653 | BELDEN - HOSKINS 115KV CKT 1 |
| FDNS | 09ALL | 0 | 20SP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.2157 | 100.5815 | BERSFORD - MANNING 115KV CKT 1 |
| FDNS | 09ALL | 0 | 20SP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.2157 | 105.1321 | MANNING - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 0 | 20SP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21776 | 105.854 | BLOOMFIELD - CREIGHTON 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20SP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.2157 | 100.5815 | BERSFORD - MANNING 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20SP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.2157 | 105.1321 | MANNING - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20SP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21776 | 105.854 | BLOOMFIELD - CREIGHTON 115KV CKT 1 |
| FDNS | 09ALL | 0 | 20WP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21687 | 107.5067 | GAVINS POINT - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 2 | 20WP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.21687 | 107.5067 | GAVINS POINT - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 0 | 25SP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.2157 | 103.8743 | MANNING - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 0 | 25SP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.2178 | 106.1762 | BLOOMFIELD - CREIGHTON 115KV CKT 1 |
| FDNS | 09ALL | 2 | 25SP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.2157 | 103.8743 | MANNING - SPIRIT MOUND 115KV CKT 1 |
| FDNS | 09ALL | 2 | 25SP | G15_076 | FROM->TO | GAVINS POINT - YANKON JCT 115KV CKT 1 | 120 | 120 | 0.2178 | 106.1762 | BLOOMFIELD - CREIGHTON 115KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 1792 | 1792 | 0.19306 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 1792 | 1792 | 0.19306 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 1022 | 1124 | 0.25442 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 1022 | 1124 | 0.25442 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.18453 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 987.16 | 1082.77 | 0.1524 | - | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.1524 | - | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 560 | 560 | 0.18453 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 435.02 | 457.73 | 0.11242 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 439 | 439 | 0.11242 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 439 | 439 | 0.11242 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_079 | | Non-Converged Contingency | 329.05 | 360.92 | 0.09161 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.42456 | 101.7566 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.42456 | 106.3032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.42456 | 110.605 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.42456 | 115.547 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_079 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.09509 | 105.8464 | System Intact |
| FDNS | 06ALL | 0 | 16WP | G15_079 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.09161 | 119.5011 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_079 | | Non-Converged Contingency | 0 | 0 | 0.14484 | - | P12:230:AEPW-ELKCITY6-SWEETWT6 |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_079 | | Non-Converged Contingency | 0 | 0 | 0.21666 | - | P12:230:AEPW-SPS-SWEETWT6-WHEELER 6 |
| FDNS | 06ALL | 0 | 17G | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.41211 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.41211 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.41211 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.41211 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_079 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.10833 | 113.2775 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_079 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.10833 | 111.4968 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_079 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.09164 | 117.5205 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_079 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 439 | 439 | 0.10833 | 103.2013 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_079 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.08835 | 130.5235 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_079 | | Non-Converged Contingency | 1792 | 1792 | 0.19362 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_079 | | Non-Converged Contingency | 956 | 1042 | 0.25368 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_079 | | Non-Converged Contingency | 956 | 1042 | 0.25368 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNS | 06ALL | 0 | 17SP | G15_079 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.08926 | 113.0163 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 1792 | 1792 | 0.19277 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 1792 | 1792 | 0.19277 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 1792 | 1792 | 0.19277 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 1022 | 1124 | 0.23239 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 1022 | 1124 | 0.23239 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.13135 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.13135 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.11731 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.11731 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 560 | 560 | 0.13135 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 560 | 560 | 0.13135 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 421 | 439 | 0.07134 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 348.58 | 381.24 | 0.07134 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 353 | 353 | 0.07134 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 318.7 | 350.57 | 0.05785 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 318.7 | 350.57 | 0.05785 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 0 | 0 | 0.09717 | - | P12:230:AEPW-ELKCITY6-SWEETWT6 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATE (MVA) | RATE (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|--|------------|------------|---------|--------------------|---|
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 0 | 0 | 0.14268 | - | P12:230:AEPW-SPS-SWEETWT6:WHEELER 6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_079 | | Non-Converged Contingency | 0 | 0 | 0.21961 | - | P12:345:SPS-J07.1.FINN.HITCH |
| FDNS | 06ALL | 0 | 20L | G15_079 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.07134 | 109.5807 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_079 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.07134 | 107.8845 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_079 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.06031 | 112.5437 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_079 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.07134 | 105.6208 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_079 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.05785 | 119.8088 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_079 | | Non-Converged Contingency | 1792 | 1792 | 0.22015 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_079 | | Non-Converged Contingency | 956 | 1042 | 0.26977 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNS | 06ALL | 0 | 20SP | G15_079 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.07623 | 105.913 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 1792 | 1792 | 0.21611 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 1792 | 1792 | 0.21611 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 1022 | 1124 | 0.26434 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 1022 | 1124 | 0.26434 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.15997 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 987.16 | 1082.77 | 0.13823 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 560 | 560 | 0.15997 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 435.02 | 457.73 | 0.09003 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 439 | 439 | 0.09003 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 421 | 439 | 0.09003 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_079 | | Non-Converged Contingency | 329.05 | 360.92 | 0.0735 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19669 | 123.1875 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19669 | 123.1875 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19669 | 125.4351 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19669 | 125.4351 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 123.3712 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 123.3712 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 125.4088 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 125.4088 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 123.0816 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 123.0816 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 125.2246 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 125.2246 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19669 | 133.8994 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19669 | 133.8994 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19669 | 136.3425 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19669 | 136.3425 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 134.0991 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 134.0991 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 136.3139 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 136.3139 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 133.7844 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 133.7844 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 136.1137 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_079 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 136.1137 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 20WP | G15_079 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.07618 | 113.3624 | System Intact |
| FDNS | 06ALL | 0 | 20WP | G15_079 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.09003 | 105.3667 | System Intact |
| FDNS | 06ALL | 0 | 20WP | G15_079 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.0735 | 128.5448 | System Intact |
| FDNS | 06ALL | 2 | 20WP | G15_079 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05498 | 100.0 | System Intact |
| FDNS | 06ALL | 3 | 20WP | G15_079 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05499 | 99.9 | System Intact |
| FDNS | 06ALL | 4 | 20WP | G15_079 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05499 | 100.0 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 1792 | 1792 | 0.19306 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 1792 | 1792 | 0.19306 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 1022 | 1124 | 0.25442 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 1022 | 1124 | 0.25442 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.18453 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 987.16 | 1082.77 | 0.1524 | - | FINNEY SWITCHING STATION - Hitchland Interchange 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.1524 | - | FINNEY SWITCHING STATION - HOLCOMB 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 560 | 560 | 0.18453 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 435.02 | 457.73 | 0.11242 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 439 | 439 | 0.11242 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 439 | 439 | 0.11242 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 16WP | G15_080 | | Non-Converged Contingency | 329.05 | 360.92 | 0.09161 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.42456 | 101.7566 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616 | 700 | 0.42456 | 106.3032 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 16WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.42456 | 110.605 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.42456 | 115.547 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 16WP | G15_080 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.09509 | 105.8464 | System Intact |
| FDNS | 06ALL | 0 | 16WP | G15_080 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.09161 | 119.5011 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_080 | | Non-Converged Contingency | 0 | 0 | 0.14484 | - | P12:230:AEPW-ELKCTY6:SWEETWT6 |
| FDNSLock-Blown up | 06ALL | 0 | 17G | G15_080 | | Non-Converged Contingency | 0 | 0 | 0.21666 | - | P12:230:AEPW-SPS-SWEETWT6:WHEELER 6 |
| FDNS | 06ALL | 0 | 17G | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.41211 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 17G | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560 | 644 | 0.41211 | 100.1714 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|-------|----------|--------|---------|-----------|--|----------------|----------------|---------|-----------------------|---|
| FDNS | 06ALL | 0 | 17G | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 560 | 644 | 0.41211 | 100.1713 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 0 | 17G | G15_080 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.10833 | 113.2775 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_080 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.10833 | 111.4968 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_080 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.09164 | 117.5205 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_080 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 439 | 439 | 0.10833 | 103.2013 | System Intact |
| FDNS | 06ALL | 0 | 17G | G15_080 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.08835 | 130.5235 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_080 | | Non-Converged Contingency | 1792 | 1792 | 0.19362 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_080 | | Non-Converged Contingency | 956 | 1042 | 0.25368 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 17SP | G15_080 | | Non-Converged Contingency | 956 | 1042 | 0.25368 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNS | 06ALL | 0 | 17SP | G15_080 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.08926 | 113.0163 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 1792 | 1972 | 0.19277 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 1792 | 1972 | 0.19277 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 1792 | 1972 | 0.19277 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 1022 | 1124 | 0.23239 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 1022 | 1124 | 0.23239 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.13135 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 956.1 | 1051.7 | 0.13135 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.11731 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 956.09 | 1051.7 | 0.11731 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 560 | 560 | 0.13135 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 560 | 560 | 0.13135 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 421 | 439 | 0.07134 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 348.58 | 381.24 | 0.07134 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 353 | 353 | 0.07134 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 318.7 | 350.57 | 0.05785 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 318.7 | 350.57 | 0.05785 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 0 | 0 | 0.09717 | - | P12:230:AEPW:ELKITY6:SWEETWT6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 0 | 0 | 0.14268 | - | P12:230:AEPW-SPS:SWEETWT6:WHEELER 6 |
| FDNSLock-Blown up | 06ALL | 0 | 20L | G15_080 | | Non-Converged Contingency | 0 | 0 | 0.21961 | - | P12:345:SPS:J07.1.FINN.HITCH |
| FDNS | 06ALL | 0 | 20L | G15_080 | FROM->TO | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.07134 | 109.5807 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_080 | FROM->TO | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.07134 | 107.8845 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_080 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 318.7 | 350.57 | 0.06031 | 112.5437 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_080 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.07134 | 105.6208 | System Intact |
| FDNS | 06ALL | 0 | 20L | G15_080 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.05785 | 119.8088 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_080 | | Non-Converged Contingency | 1792 | 1792 | 0.22015 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20SP | G15_080 | | Non-Converged Contingency | 956 | 1042 | 0.26977 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNS | 06ALL | 0 | 20SP | G15_080 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 318.7 | 350.57 | 0.07623 | 105.913 | System Intact |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 1792 | 1972 | 0.21611 | - | BORDER 7345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 1792 | 1972 | 0.21611 | - | BORDER 7345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 1022 | 1124 | 0.26434 | - | G14-074T 345.00 - OKLAUNION 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 1022 | 1124 | 0.26434 | - | G14-074T 345.00 - TUCO INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 987.2 | 1082.8 | 0.15997 | - | Hitchland Interchange - POTTER COUNTY INTERCHANGE 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 987.16 | 1082.77 | 0.13823 | - | Hitchland Interchange - WALKTAP7 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 560 | 560 | 0.15997 | - | POTTER COUNTY INTERCHANGE (WAUK 90343-A) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 435.02 | 457.73 | 0.09003 | - | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 439 | 439 | 0.09003 | - | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 421 | 439 | 0.09003 | - | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 |
| FDNSLock-Blown up | 06ALL | 0 | 20WP | G15_080 | | Non-Converged Contingency | 329.05 | 360.92 | 0.0735 | - | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19669 | 123.1875 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19669 | 123.1875 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19669 | 125.4351 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19669 | 125.4351 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 123.3712 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 123.3712 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 125.4088 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 3 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 125.4088 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 123.0816 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 123.0816 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 125.2246 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 4 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 | 616.0 | 700.0 | 0.19671 | 125.2246 | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 |
| FDNS | 06ALL | 2 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19669 | 133.8994 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19669 | 133.8994 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19669 | 136.3425 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 2 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19669 | 136.3425 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 134.0991 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 134.0991 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 136.3139 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 3 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 136.3139 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 133.7844 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 133.7844 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 136.1137 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 4 | 20WP | G15_080 | FROM->TO | TUCO INTERCHANGE (GE M1022338) 345/230/13.2KV TRANSFORMER CKT 1 | 560.0 | 644.0 | 0.19671 | 136.1137 | TUCO INTERCHANGE (SIEM 8743066) 345/230/13.2KV TRANSFORMER CKT 2 |
| FDNS | 06ALL | 0 | 20WP | G15_080 | FROM->TO | GRAPEVINE INTERCHANGE - STATELINE INTERCHANGE 230KV CKT 1 | 329.05 | 360.92 | 0.07618 | 113.3624 | System Intact |
| FDNS | 06ALL | 0 | 20WP | G15_080 | TO->FROM | CHISHOLM6 230.00 - SWEETWATER 230KV CKT 1 | 421 | 439 | 0.09003 | 105.3667 | System Intact |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|------------------|----------|--------|---------|-----------|---|-------------|-------------|---------|--------------------|--|
| FDNS | 06ALL | 0 | 20WP | G15_080 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.0735 | 128.5448 | System Intact |
| FDNS | 06ALL | 2 | 20WP | G15_080 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05498 | 100.0 | System Intact |
| FDNS | 06ALL | 3 | 20WP | G15_080 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05499 | 99.9 | System Intact |
| FDNS | 06ALL | 4 | 20WP | G15_080 | TO->FROM | GRAPEVINE INTERCHANGE - NICHOLS STATION 230KV CKT 1 | 329.05 | 360.92 | 0.05499 | 100.0 | System Intact |
| FDNS | 00NR | 0 | 16WP | G15_081 | TO->FROM | FPL SWITCH - WOODWARD 138KV CKT 1 | 171.0 | 185.0 | 0.10306 | 103.1564 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01NR | 0 | 17G | G15_081 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191.0 | 191.0 | 0.03610 | 110.5718 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01NR | 0 | 17G | G15_081 | TO->FROM | ROMAN NOSE - SOUTHWARD 138KV CKT 1 | 133.0 | 153.0 | 0.05383 | 122.0403 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01NR | 0 | 17G | G15_081 | TO->FROM | FPL SWITCH - WOODWARD 138KV CKT 1 | 133.0 | 153.0 | 0.10307 | 117.112 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01NR | 2 | 17G | G15_081 | TO->FROM | ROMAN NOSE - SOUTHWARD 138KV CKT 1 | 133.0 | 153.0 | 0.05379 | 121.9486 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01NR | 2 | 17G | G15_081 | TO->FROM | FPL SWITCH - WOODWARD 138KV CKT 1 | 133.0 | 153.0 | 0.10323 | 118.1529 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 00NR | 0 | 17SP | G15_081 | TO->FROM | CLEARWATER - MILAN TAP 138KV CKT 1 | 110.0 | 110.0 | 0.03033 | 101.4557 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17G | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03161 | 104.1008 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17G | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03161 | 104.1008 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17G | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03161 | 103.9839 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03065 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 17SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03065 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03065 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 17SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03065 | 115.6132 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03065 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 17SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03065 | 115.5486 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03132 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 20SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03132 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03132 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 20SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03132 | 116.3733 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03132 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 20SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03132 | 116.3151 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03222 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 0 | 25SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305 | 371 | 0.03222 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03222 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 2 | 25SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03222 | 101.705 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03223 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 08ALL | 3 | 25SP | G15_083 | TO->FROM | CLEAVELAND - CLEVELND 4 138.00 138KV CKT Z1 | 305.0 | 371.0 | 0.03223 | 101.453 | CLEVELAND - TULSA NORTH 345KV CKT 1 |
| FDNS | 07ALL | 0 | 16WP | G15_084 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.0312 | 120.9895 | System Intact |
| FDNS | 07ALL | 0 | 16WP | G15_084 | FROM->TO | NAPLESTP 138.00 - PAYNE 138.00 138KV CKT 1 | 132 | 143 | 0.0312 | 117.7635 | System Intact |
| FDNS | 07ALL | 0 | 17G | G15_084 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.0314 | 102.6428 | System Intact |
| FDNS | 07ALL | 0 | 17SP | G15_084 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.03201 | 115.5962 | System Intact |
| FDNS | 07ALL | 0 | 17SP | G15_084 | FROM->TO | NAPLESTP 138.00 - PAYNE 138.00 138KV CKT 1 | 132 | 143 | 0.03201 | 112.3563 | System Intact |
| FDNS | 07ALL | 0 | 20SP | G15_084 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.03187 | 116.194 | System Intact |
| FDNS | 07ALL | 0 | 20SP | G15_084 | FROM->TO | NAPLESTP 138.00 - PAYNE 138.00 138KV CKT 1 | 132 | 143 | 0.03187 | 112.9333 | System Intact |
| FDNS | 0 | 0 | 20WP | G15_084 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.03139 | 100.5885 | System Intact |
| FDNS | 07ALL | 0 | 20WP | G15_084 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.03129 | 124.6348 | System Intact |
| FDNS | 07ALL | 0 | 20WP | G15_084 | FROM->TO | NAPLESTP 138.00 - PAYNE 138.00 138KV CKT 1 | 132 | 143 | 0.03129 | 121.388 | System Intact |
| FDNS | 07ALL | 0 | 25SP | G15_084 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.03223 | 100.2054 | System Intact |
| FDNS | 07ALL | 0 | 16WP | G15_085 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.04097 | 120.9895 | System Intact |
| FDNS | 07ALL | 0 | 16WP | G15_085 | FROM->TO | NAPLESTP 138.00 - PAYNE 138.00 138KV CKT 1 | 132 | 143 | 0.04097 | 117.7635 | System Intact |
| FDNS | 07ALL | 0 | 17G | G15_085 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.04117 | 102.6428 | System Intact |
| FDNS | 07ALL | 0 | 17SP | G15_085 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.04209 | 115.5962 | System Intact |
| FDNS | 07ALL | 0 | 17SP | G15_085 | FROM->TO | NAPLESTP 138.00 - PAYNE 138.00 138KV CKT 1 | 132 | 143 | 0.04209 | 112.3563 | System Intact |
| FDNS | 07ALL | 0 | 17SP | G15_085 | TO->FROM | CORN TAP - SEQUOYAHJ4 138.00 138KV CKT 1 | 132 | 143 | 0.03459 | 106.8338 | System Intact |
| FDNS | 07ALL | 0 | 17SP | G15_085 | TO->FROM | NORGE ROAD - SOUTHWESTERN STATION 138KV CKT 1 | 136 | 136 | 0.03477 | 99.5 | System Intact |
| FDNS | 07ALL | 0 | 20SP | G15_085 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.04204 | 116.194 | System Intact |
| FDNS | 07ALL | 0 | 20SP | G15_085 | FROM->TO | NAPLESTP 138.00 - PAYNE 138.00 138KV CKT 1 | 132 | 143 | 0.04204 | 112.9333 | System Intact |
| FDNS | 07ALL | 0 | 20SP | G15_085 | TO->FROM | CORN TAP - SEQUOYAHJ4 138.00 138KV CKT 1 | 132 | 143 | 0.03452 | 105.0447 | System Intact |
| FDNS | 07ALL | 0 | 20SP | G15_085 | TO->FROM | NORGE ROAD - SOUTHWESTERN STATION 138KV CKT 1 | 136 | 136 | 0.0348 | 100.904 | System Intact |
| FDNS | 0 | 0 | 20WP | G15_085 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.04156 | 100.5885 | System Intact |
| FDNS | 07ALL | 0 | 20WP | G15_085 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.04146 | 124.6348 | System Intact |
| FDNS | 07ALL | 0 | 20WP | G15_085 | FROM->TO | NAPLESTP 138.00 - PAYNE 138.00 138KV CKT 1 | 132 | 143 | 0.04146 | 121.388 | System Intact |
| FDNS | 07ALL | 0 | 25SP | G15_085 | FROM->TO | CORN TAP - NAPLESTP 138.00 138KV CKT 1 | 132 | 143 | 0.0424 | 100.2054 | System Intact |
| FDNS | 07ALL | 0 | 25SP | G15_085 | TO->FROM | STATELINE INTERCHANGE - STLN-DEMARC6 230KV CKT 1 | 348.58 | 381.24 | 0.03138 | 120.2549 | System Intact |
| FDNS | 07ALL | 0 | 25SP | G15_085 | TO->FROM | STLN-DEMARC6 - SWEETWATER 230KV CKT 1 | 353 | 353 | 0.03138 | 118.7492 | System Intact |
| FDNS | 07ALL | 0 | 25SP | G15_085 | TO->FROM | CORN TAP - SEQUOYAHJ4 138.00 138KV CKT 1 | 132 | 143 | 0.0348 | 102.5111 | System Intact |
| FDNSLock-Blown up | 09ALL | 0 | 16WP | G15_091 | | Non-Converged Contingency | 720 | 720 | 0.11621 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 16WP | G15_091 | | Non-Converged Contingency | 720 | 720 | 0.11621 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 16WP | G15_091 | | Non-Converged Contingency | 460 | 460 | 0.80636 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 16ALL_B10T_DCTIE | 0 | 16WP | G15_091 | | Non-Converged Contingency | 460 | 460 | 0.80638 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 16WP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05771 | 102.9357 | System Intact |
| FDNS | 16ALL | 0 | 16WP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05771 | 103.8937 | System Intact |
| FDNS | 16ALL | 2 | 16WP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07672 | 108.8239 | System Intact |
| FDNS | 16ALL | 2 | 16WP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07672 | 109.822 | System Intact |
| FDNSLock-Blown up | 09ALL | 0 | 17G | G15_091 | | Non-Converged Contingency | 720 | 720 | 0.11978 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 17G | G15_091 | | Non-Converged Contingency | 720 | 720 | 0.11978 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17G | G15_091 | | Non-Converged Contingency | 460 | 460 | 0.80665 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 09ALL | 0 | 17SP | G15_091 | | Non-Converged Contingency | 720 | 720 | 0.12012 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 17SP | G15_091 | | Non-Converged Contingency | 720 | 720 | 0.12012 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|------------------|----------|--------|---------|-----------|---|----------------|----------------|---------|-----------------------|---|
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_091 | | Non-Converged Contingency | 720 | 792 | 0.13178 | - | WATERTN-LNX3345.00 - WATERTOWN 345KV CKT Z |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_091 | | Non-Converged Contingency | 720 | 792 | 0.13178 | - | WATERTN-LNX3345.00 - WHITE 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 2 | 17SP | G15_091 | | Non-Converged Contingency | 720.0 | 792.0 | 0.13172 | - | WATERTN-LNX3345.00 - WHITE 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_091 | | Non-Converged Contingency | 717 | 789 | 0.10813 | - | G09_001IST 345.00 - GROTON 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_091 | | Non-Converged Contingency | 717 | 789 | 0.10813 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 2 | 17SP | G15_091 | | Non-Converged Contingency | 717.0 | 789.0 | 0.10804 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 3 | 17SP | G15_091 | | Non-Converged Contingency | 717.0 | 789.0 | 0.10738 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 4 | 17SP | G15_091 | | Non-Converged Contingency | 717.0 | 789.0 | 0.10747 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_091 | | Non-Converged Contingency | 460 | 460 | 0.80634 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 16ALL_B10T_DCTIE | 0 | 17SP | G15_091 | | Non-Converged Contingency | 460 | 460 | 0.80631 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 09ALL | 0 | 17SP | G15_091 | FROM->TO | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z | 720 | 720 | 0.12586 | 95.3 | KELLY - MEADOWGROVE4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 17SP | G15_091 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400 | 480 | 0.12029 | 101.3771 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_091 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400.0 | 480.0 | 0.11918 | 101.3206 | System Intact |
| FDNS | 16ALL | 3 | 17SP | G15_091 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400.0 | 480.0 | 0.11902 | 101.1661 | System Intact |
| FDNS | 16ALL | 0 | 17SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05781 | 103.7908 | System Intact |
| FDNS | 16ALL | 0 | 17SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05781 | 104.4544 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07683 | 110.005 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07683 | 110.7028 | System Intact |
| FDNSLock-Blown up | 16ALL | 0 | 20L | G15_091 | | Non-Converged Contingency | 460 | 460 | 0.80717 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 20SP | G15_091 | | Non-Converged Contingency | 460 | 460 | 0.8078 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 20SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05717 | 105.6005 | System Intact |
| FDNS | 16ALL | 0 | 20SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05717 | 106.7149 | System Intact |
| FDNS | 16ALL | 2 | 20SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07628 | 111.2513 | System Intact |
| FDNS | 16ALL | 2 | 20SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07628 | 112.4108 | System Intact |
| FDNSLock-Blown up | 16ALL | 0 | 20WP | G15_091 | | Non-Converged Contingency | 460 | 460 | 0.80792 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 20WP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05697 | 104.2487 | System Intact |
| FDNS | 16ALL | 0 | 20WP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05697 | 104.5453 | System Intact |
| FDNS | 16ALL | 2 | 20WP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07607 | 109.8008 | System Intact |
| FDNS | 16ALL | 2 | 20WP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07607 | 110.0761 | System Intact |
| FDNSLock-Blown up | 16ALL | 0 | 25SP | G15_091 | | Non-Converged Contingency | 460 | 460 | 0.80754 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 25SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05726 | 115.0089 | System Intact |
| FDNS | 16ALL | 0 | 25SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05726 | 115.754 | System Intact |
| FDNS | 16ALL | 2 | 25SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07636 | 120.5287 | System Intact |
| FDNS | 16ALL | 2 | 25SP | G15_091 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07636 | 121.2902 | System Intact |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.30273 | 100.7002 | RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32342 | 100.3246 | CLEO CORNER (CLEOCOR1) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32477 | 100.7277 | FAIRVIEW - OKEENE 69KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32888 | 100.2472 | FREEDOM - WEST 69KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32888 | 100.8548 | BUFFALO - WEST 69KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32888 | 101.7659 | BUFBEAR2 - BUFFALO 69KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33284 | 118.7348 | System Intact |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33426 | 101.2397 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33426 | 101.2397 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33426 | 101.2397 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33426 | 101.2397 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33477 | 113.7538 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33679 | 100.3137 | ROMAN NOSE - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33679 | 100.6341 | DEWEY - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33742 | 101.0751 | IMO TAP - MEN TAP 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33742 | 101.1789 | CLEOPLT4 138.00 - MEN TAP 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33742 | 101.3065 | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34417 | 103.7112 | CEDARDALE - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34417 | 103.8817 | CEDARDALE - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34417 | 103.9343 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34417 | 103.9681 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34565 | 102.6911 | MOREWOOD SW - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34565 | 103.3276 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34565 | 103.7163 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34565 | 103.7392 | P12:138:WFEC:MSL14 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34798 | 100.6456 | CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34798 | 100.8874 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.10656 | 117.8972 | System Intact |
| FDNS | 01ALL | 0 | 16WP | G15_095 | TO->FROM | NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33284 | 113.2141 | System Intact |
| FDNS | 01ALL | 0 | 16WP | G15_095 | TO->FROM | NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33477 | 109.1245 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | TO->FROM | NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34417 | 99.5 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 16WP | G15_095 | TO->FROM | NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34417 | 99.5 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 17G | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33335 | 114.036 | System Intact |
| FDNS | 01ALL | 0 | 17G | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33542 | 108.4167 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_095 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.10739 | 111.7985 | System Intact |
| FDNS | 01ALL | 0 | 17G | G15_095 | TO->FROM | NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33335 | 108.0387 | System Intact |
| FDNS | 01ALL | 0 | 17G | G15_095 | TO->FROM | NOEL_SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33542 | 103.4035 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17G | G15_095 | TO->FROM | ROMAN NOSE - SOUTHARD 138KV CKT 1 | 133 | 153 | 0.06083 | 106.4715 | System Intact |
| FDNS | 01ALL | 2 | 17G | G15_095 | TO->FROM | ROMAN NOSE - SOUTHARD 138KV CKT 1 | 133.0 | 153.0 | 0.06036 | 106.284 | System Intact |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095 T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.30279 | 106.7315 | RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1 |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|----------|-------|----------|--------|---------|-----------|------------------------|---|----------------|----------------|---------|-----------------------|---|
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32365 | 102.071 | CLEO CORNER (CLEOCOR1) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32498 | 100.4136 | EAGLE CHIEF - RINGWOOD JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32498 | 100.4148 | FAIRVIEW - RINGWOOD JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32498 | 104.9492 | FAIRVIEW - OKEENE 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3291 | 99.5 | FT SUPPLY - STOCKHOLM2 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3291 | 99.7 | ALVA - WINCH_TAP 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3291 | 100.8207 | FREEDOM - WINCH_TAP 69.000 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3291 | 101.3603 | FREEDOM - WEST 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3291 | 102.1615 | BUFFALO - WEST 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3291 | 103.2086 | BUFBEAR2 - BUFFALO 69KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33041 | 99.7 | HUNTERS7 345.00 - RENFROW7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33305 | 120.4845 | System Intact |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33447 | 102.2167 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33447 | 102.2167 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33447 | 102.2167 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33447 | 102.2167 | THISTLE7 345.00 - WOODWARD DISTRICT EHV 345KV CKT 2 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33494 | 112.9711 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33703 | 101.2164 | ROMAN NOSE - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33703 | 101.7019 | DEWEY - SOUTHARD 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33764 | 102.556 | IMO TAP - MEN TAP 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33764 | 102.7137 | CLEOPLT4 138.00 - MEN TAP 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33764 | 102.8463 | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33935 | 99.6 | ELLIS 4 138.00 - MOREWOOD SW 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33935 | 100.1712 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33935 | 100.1712 | ELK CITY - RED HILLS WIND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33957 | 100.1795 | DOVER SW - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34442 | 105.0044 | CEDARDALE - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34442 | 105.1618 | CEDARDALE - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34442 | 105.224 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34442 | 105.2477 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34596 | 103.9031 | MOREWOOD SW - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34596 | 104.5564 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34596 | 104.9431 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34596 | 104.9642 | P12:138:WFEC:MSL14 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34822 | 102.0923 | CLEO CORNER - GLASS MOUNTAIN 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34822 | 102.492 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | FROM->TO | CLEO CORNER - CLEOPLT4 | 138.00 138KV CKT 1 | 191 | 191 | 0.10663 | 117.5578 | System Intact |
| FDNS | 01ALL | 0 | 17SP | G15_095 | TO->FROM | NOEL_SW | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.30279 | 100.7175 | RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | TO->FROM | NOEL_SW | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33305 | 113.4116 | System Intact |
| FDNS | 01ALL | 0 | 17SP | G15_095 | TO->FROM | NOEL_SW | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33494 | 107.0666 | MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | TO->FROM | NOEL_SW | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34442 | 99.5 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | TO->FROM | NOEL_SW | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34442 | 99.5 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 17SP | G15_095 | TO->FROM | ROMAN NOSE - SOUTHARD | 138KV CKT 1 | 133 | 153 | 0.06041 | 106.118 | System Intact |
| FDNS | 01ALL | 2 | 17SP | G15_095 | TO->FROM | ROMAN NOSE - SOUTHARD | 138KV CKT 1 | 133.0 | 153.0 | 0.05994 | 105.9209 | System Intact |
| FDNS | 01ALL | 0 | 20L | G15_095 | FROM->TO | CLEO CORNER - CLEOPLT4 | 138.00 138KV CKT 1 | 191 | 191 | 0.10839 | 99.8 | System Intact |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.30392 | 105.6898 | RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32431 | 101.3095 | CLEO CORNER (CLEOCOR1) 138/69/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32556 | 101.3008 | FAIRVIEW - RINGWOOD JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.32556 | 101.3061 | EAGLE CHIEF - RINGWOOD JCT 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3297 | 99.5 | FREEDOM - WEST 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3297 | 100.6253 | BUFFALO - WEST 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3297 | 101.8922 | BUFBEAR2 - BUFFALO 69KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33196 | 99.6 | HUNTERS7 345.00 - WOODRING 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33196 | 100.7309 | HUNTERS7 345.00 - RENFROW7 345.00 345KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33391 | 118.3696 | System Intact |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33822 | 100 | IMO TAP - MEN TAP 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33822 | 100.1244 | CLEOPLT4 138.00 - MEN TAP 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33822 | 100.2791 | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34505 | 102.1618 | CEDARDALE - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34505 | 102.3372 | CEDARDALE - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34505 | 102.3926 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34505 | 102.4201 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34656 | 100.7373 | MOREWOOD SW - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34656 | 101.3645 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34656 | 101.7386 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34656 | 101.7589 | P12:138:WFEC:MSL14 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | G15095_T | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34876 | 99.5 | GLASS MOUNTAIN - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20SP | G15_095 | FROM->TO | CLEO CORNER - CLEOPLT4 | 138.00 138KV CKT 1 | 191 | 191 | 0.10586 | 107.4428 | System Intact |
| FDNS | 01ALL | 0 | 20SP | G15_095 | TO->FROM | NOEL_SW | 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33391 | | |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|------------------|----------|--------|---------|-----------|--|-------------|-------------|---------|--------------------|--|
| FDNS | 01ALL | 0 | 20WP | G15_095 | FROM->TO | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3335 | 117.0576 | System Intact |
| FDNS | 01ALL | 0 | 20WP | G15_095 | FROM->TO | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34458 | 101.4726 | CEDARDALE - OKEENE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_095 | FROM->TO | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34458 | 101.6509 | CEDARDALE - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_095 | FROM->TO | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34458 | 101.7029 | P12:138:WFEC:MSL12 |
| FDNS | 01ALL | 0 | 20WP | G15_095 | FROM->TO | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34458 | 101.7343 | MOORELAND - PIC4 138.00 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_095 | FROM->TO | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34612 | 99.7 | MOREWOOD SW - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_095 | FROM->TO | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34612 | 100.298 | BEARCAT 138.00 - NINE MILE 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_095 | FROM->TO | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34612 | 100.6741 | BEARCAT 138.00 - MOORELAND 138KV CKT 1 |
| FDNS | 01ALL | 0 | 20WP | G15_095 | FROM->TO | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.34612 | 100.6937 | P12:138:WFEC:MSL14 |
| FDNS | 01ALL | 0 | 20WP | G15_095 | FROM->TO | CLEO CORNER - CLEOPLT4 138.00 138KV CKT 1 | 191 | 191 | 0.10551 | 109.8581 | System Intact |
| FDNS | 01ALL | 0 | 20WP | G15_095 | TO->FROM | NOEL SW 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.3335 | 111.2334 | System Intact |
| FDNS | 01ALL | 0 | 25SP | G15_095 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 | 493 | 493 | 0.3112 | 99.5 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 0 | 25SP | G15_095 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493 | 493 | 0.31263 | 99.6 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_095 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493 | 493 | 0.31263 | 100 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 2 | 25SP | G15_095 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493.0 | 493.0 | 0.31020 | 99.7 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 3 | 25SP | G15_095 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493.0 | 493.0 | 0.31020 | 99.7 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 4 | 25SP | G15_095 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 | 493.0 | 493.0 | 0.30837 | 102.6172 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 4 | 25SP | G15_095 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 | 493.0 | 493.0 | 0.30837 | 103.523 | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 |
| FDNS | 01ALL | 4 | 25SP | G15_095 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493.0 | 493.0 | 0.30982 | 103.0825 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 4 | 25SP | G15_095 | FROM->TO | WOODWARD DISTRICT EHV (WWDEHV-T2) 345/138/13.8KV TRANSFORMER CKT 2 | 493.0 | 493.0 | 0.30982 | 103.9633 | WOODWARD DISTRICT EHV (WWDEHV) 345/138/13.8KV TRANSFORMER CKT 1 |
| FDNS | 01ALL | 0 | 25SP | G15_095 | FROM->TO | G15095_T 138.00 - ROSE_VALLEY 138.00 138KV CKT 1 | 183 | 228 | 0.33419 | 106.2212 | System Intact |
| FDNSLock-Blown up | 09ALL | 0 | 16WP | G15_096 | | Non-Converged Contingency | 720 | 720 | 0.11621 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 16WP | G15_096 | | Non-Converged Contingency | 720 | 720 | 0.11621 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 16WP | G15_096 | | Non-Converged Contingency | 460 | 460 | 0.80636 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 16ALL_B10T_DCTIE | 0 | 16WP | G15_096 | | Non-Converged Contingency | 460 | 460 | 0.80638 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 16WP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05771 | 102.9357 | System Intact |
| FDNS | 16ALL | 0 | 16WP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05771 | 103.8937 | System Intact |
| FDNS | 16ALL | 2 | 16WP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07672 | 108.8239 | System Intact |
| FDNS | 16ALL | 2 | 16WP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07672 | 109.822 | System Intact |
| FDNSLock-Blown up | 09ALL | 0 | 17G | G15_096 | | Non-Converged Contingency | 720 | 720 | 0.11978 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 17G | G15_096 | | Non-Converged Contingency | 720 | 720 | 0.11978 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17G | G15_096 | | Non-Converged Contingency | 460 | 460 | 0.80665 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 09ALL | 0 | 17SP | G15_096 | | Non-Converged Contingency | 720 | 720 | 0.12012 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 17SP | G15_096 | | Non-Converged Contingency | 720 | 720 | 0.12012 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_096 | | Non-Converged Contingency | 720 | 792 | 0.13178 | - | WATERTN-LNX3345.00 - WATERTOWN 345KV CKT Z |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_096 | | Non-Converged Contingency | 720 | 792 | 0.13178 | - | WATERTN-LNX3345.00 - WHITE 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 2 | 17SP | G15_096 | | Non-Converged Contingency | 720.0 | 792.0 | 0.13172 | - | WATERTN-LNX3345.00 - WHITE 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_096 | | Non-Converged Contingency | 717 | 789 | 0.10813 | - | G09_001IST 345.00 - GROTON 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_096 | | Non-Converged Contingency | 717 | 789 | 0.10813 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 2 | 17SP | G15_096 | | Non-Converged Contingency | 717.0 | 789.0 | 0.10804 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 3 | 17SP | G15_096 | | Non-Converged Contingency | 717.0 | 789.0 | 0.10738 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 4 | 17SP | G15_096 | | Non-Converged Contingency | 717.0 | 789.0 | 0.10747 | - | G09_001IST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_096 | | Non-Converged Contingency | 460 | 460 | 0.80634 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 16ALL_B10T_DCTIE | 0 | 17SP | G15_096 | | Non-Converged Contingency | 460 | 460 | 0.80631 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 09ALL | 0 | 17SP | G15_096 | FROM->TO | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z | 720 | 720 | 0.12586 | 95.3 | KELLY - MEADOWGROVE4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 17SP | G15_096 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400 | 480 | 0.12029 | 101.3771 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_096 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400.0 | 480.0 | 0.11918 | 101.3206 | System Intact |
| FDNS | 16ALL | 3 | 17SP | G15_096 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400.0 | 480.0 | 0.11902 | 101.1661 | System Intact |
| FDNS | 16ALL | 0 | 17SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05781 | 103.7908 | System Intact |
| FDNS | 16ALL | 0 | 17SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05781 | 104.4544 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07683 | 110.005 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07683 | 110.7028 | System Intact |
| FDNSLock-Blown up | 16ALL | 0 | 20L | G15_096 | | Non-Converged Contingency | 460 | 460 | 0.80717 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 20SP | G15_096 | | Non-Converged Contingency | 460 | 460 | 0.8078 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 20SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05717 | 105.6005 | System Intact |
| FDNS | 16ALL | 0 | 20SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05717 | 106.7149 | System Intact |
| FDNS | 16ALL | 2 | 20SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07628 | 111.2513 | System Intact |
| FDNS | 16ALL | 2 | 20SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07628 | 112.4108 | System Intact |
| FDNSLock-Blown up | 16ALL | 0 | 20WP | G15_096 | | Non-Converged Contingency | 460 | 460 | 0.80792 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 20WP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05697 | 104.2487 | System Intact |
| FDNS | 16ALL | 0 | 20WP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05697 | 104.5453 | System Intact |
| FDNS | 16ALL | 2 | 20WP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07607 | 109.8008 | System Intact |
| FDNS | 16ALL | 2 | 20WP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07607 | 110.0761 | System Intact |
| FDNSLock-Blown up | 16ALL | 0 | 25SP | G15_096 | | Non-Converged Contingency | 460 | 460 | 0.80754 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 25SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05726 | 115.0089 | System Intact |
| FDNS | 16ALL | 0 | 25SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05726 | 115.754 | System Intact |
| FDNS | 16ALL | 2 | 25SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07636 | 120.5287 | System Intact |
| FDNS | 16ALL | 2 | 25SP | G15_096 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.07636 | 121.2902 | System Intact |
| FDNSLock-Blown up | 09ALL | 0 | 16WP | G15_097 | | Non-Converged Contingency | 720 | 720 | 0.09982 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 16WP | G15_097 | | Non-Converged Contingency | 720 | 720 | 0.09982 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 09ALL | 0 | 17G | G15_097 | | Non-Converged Contingency | 720 | 720 | 0.10324 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 17G | G15_097 | | Non-Converged Contingency | 720 | 720 | 0.10324 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNS | 15ALL | 0 | 17G | G15_097 | FROM->TO | G13_001IST 115.00 - WATERTOWN 115KV CKT 1 | 120 | 121 | 0.19656 | 106.2058 | GROTON (GROTON KU2A) 345/115/13.8KV TRANSFORMER CKT 1 |
| FDNSLock-Blown up | 09ALL | 0 | 17SP | G15_097 | | Non-Converged Contingency | 720 | 720 | 0.10368 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |

| SOLUTION | GROUP | SCENARIO | SEASON | SOURCE | DIRECTION | MONITORED ELEMENT | RATEA (MVA) | RATEB (MVA) | TDF | TC%LOADING (% MVA) | CONTINGENCY |
|-------------------|------------------|----------|--------|---------|-----------|---|----------------|----------------|---------|-----------------------|---|
| FDNSLock-Blown up | 09ALL | 0 | 17SP | G15_097 | | Non-Converged Contingency | 720 | 720 | 0.10368 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNS | 09ALL | 0 | 17SP | G15_097 | FROM->TO | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z | 720 | 720 | 0.10912 | 95.3 | KELLY - MEADOWGROVE4230.00 230KV CKT 1 |
| FDNS | 15ALL | 0 | 17SP | G15_097 | FROM->TO | G13_0011ST 115.00 - WATERTOWN 115KV CKT 1 | 120 | 121 | 0.19657 | 110.4503 | GROTON (GROTON KU2A) 345/115/13.8KV TRANSFORMER CKT 1 |
| FDNS | 15ALL | 0 | 20SP | G15_097 | TO->FROM | SPUT ROCK - WHITE 345KV CKT 1 | 717 | 717 | 0.24257 | 99.9 | BROOKING COUNTY - LYON COUNTY 345KV CKT 1 |
| FDNSLock-Blown up | 09ALL | 0 | 16WP | G15_098 | | Non-Converged Contingency | 720 | 720 | 0.11649 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 16WP | G15_098 | | Non-Converged Contingency | 720 | 720 | 0.11649 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 16WP | G15_098 | | Non-Converged Contingency | 460 | 460 | 0.03826 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 16ALL_B10T_DCTIE | 0 | 16WP | G15_098 | | Non-Converged Contingency | 460 | 460 | 0.03828 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 16WP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05177 | 102.9357 | System Intact |
| FDNS | 16ALL | 0 | 16WP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05177 | 103.8937 | System Intact |
| FDNS | 16ALL | 2 | 16WP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.05665 | 108.8239 | System Intact |
| FDNS | 16ALL | 2 | 16WP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.05665 | 109.822 | System Intact |
| FDNSLock-Blown up | 09ALL | 0 | 17G | G15_098 | | Non-Converged Contingency | 720 | 720 | 0.12006 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 17G | G15_098 | | Non-Converged Contingency | 720 | 720 | 0.12006 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17G | G15_098 | | Non-Converged Contingency | 460 | 460 | 0.03855 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 09ALL | 0 | 17SP | G15_098 | | Non-Converged Contingency | 720 | 720 | 0.1204 | - | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z |
| FDNSLock-Blown up | 09ALL | 0 | 17SP | G15_098 | | Non-Converged Contingency | 720 | 720 | 0.1204 | - | GR ISLD-LNX3345.00 - HOLT.CO3 345.00 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_098 | | Non-Converged Contingency | 720 | 792 | 0.13253 | - | WATERTN-LNX3345.00 - WATERTOWN 345KV CKT Z |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_098 | | Non-Converged Contingency | 720 | 792 | 0.13253 | - | WATERTN-LNX3345.00 - WHITE 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 2 | 17SP | G15_098 | | Non-Converged Contingency | 720.0 | 792.0 | 0.13251 | - | WATERTN-LNX3345.00 - WHITE 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_098 | | Non-Converged Contingency | 717 | 789 | 0.10919 | - | G09_0011ST 345.00 - GROTON 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_098 | | Non-Converged Contingency | 717 | 789 | 0.10919 | - | G09_0011ST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 2 | 17SP | G15_098 | | Non-Converged Contingency | 717.0 | 789.0 | 0.10916 | - | G09_0011ST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 3 | 17SP | G15_098 | | Non-Converged Contingency | 717.0 | 789.0 | 0.10857 | - | G09_0011ST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 4 | 17SP | G15_098 | | Non-Converged Contingency | 717.0 | 789.0 | 0.10873 | - | G09_0011ST 345.00 - WATERTOWN 345KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 17SP | G15_098 | | Non-Converged Contingency | 460 | 460 | 0.03824 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 16ALL_B10T_DCTIE | 0 | 17SP | G15_098 | | Non-Converged Contingency | 460 | 460 | 0.0382 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 09ALL | 0 | 17SP | G15_098 | FROM->TO | GR ISLD-LNX3345.00 - GRAND ISLAND 345KV CKT Z | 720 | 720 | 0.12615 | 95.3 | KELLY - MEADOWGROVE4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 17SP | G15_098 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400 | 480 | 0.12198 | 101.3771 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_098 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400.0 | 480.0 | 0.12169 | 101.3206 | System Intact |
| FDNS | 16ALL | 3 | 17SP | G15_098 | FROM->TO | BROADLAND - HURON 230KV CKT 1 | 400.0 | 480.0 | 0.12164 | 101.1661 | System Intact |
| FDNS | 16ALL | 0 | 17SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05186 | 103.7908 | System Intact |
| FDNS | 16ALL | 0 | 17SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05186 | 104.4544 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.05676 | 110.005 | System Intact |
| FDNS | 16ALL | 2 | 17SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.05676 | 110.7028 | System Intact |
| FDNSLock-Blown up | 16ALL | 0 | 20L | G15_098 | | Non-Converged Contingency | 460 | 460 | 0.03901 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNSLock-Blown up | 16ALL | 0 | 20SP | G15_098 | | Non-Converged Contingency | 460 | 460 | 0.03964 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 20SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05121 | 105.6005 | System Intact |
| FDNS | 16ALL | 0 | 20SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05121 | 106.7149 | System Intact |
| FDNS | 16ALL | 2 | 20SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.05617 | 111.2513 | System Intact |
| FDNS | 16ALL | 2 | 20SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.05617 | 112.4108 | System Intact |
| FDNSLock-Blown up | 16ALL | 0 | 20WP | G15_098 | | Non-Converged Contingency | 460 | 460 | 0.03977 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 20WP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05101 | 104.2487 | System Intact |
| FDNS | 16ALL | 0 | 20WP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.05101 | 104.5453 | System Intact |
| FDNS | 16ALL | 2 | 20WP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.05595 | 109.8008 | System Intact |
| FDNS | 16ALL | 2 | 20WP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.05595 | 110.0761 | System Intact |
| FDNSLock-Blown up | 16ALL | 0 | 25SP | G15_098 | | Non-Converged Contingency | 460 | 460 | 0.0394 | - | BELFIELD - DAGLUM 4230.00 230KV CKT 1 |
| FDNS | 16ALL | 0 | 25SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.0513 | 115.0089 | System Intact |
| FDNS | 16ALL | 0 | 25SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100 | 125 | 0.0513 | 115.754 | System Intact |
| FDNS | 16ALL | 2 | 25SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.05625 | 120.5287 | System Intact |
| FDNS | 16ALL | 2 | 25SP | G15_098 | FROM->TO | DICKINSON (KW1A 100) 230/115/13.8KV TRANSFORMER CKT 1 | 100.0 | 125.0 | 0.05625 | 121.2902 | System Intact |

11.8 G-V: Voltage Power Flow Analysis (Constraints Requiring Transmission Reinforcement)

Available upon request. Contact SPP Generation Interconnection Studies for details.

11.9 H-T: Thermal Power Flow Analysis (Other Constraints Not Requiring Transmission Reinforcement)

Available upon request. Contact SPP Generation Interconnection Studies for details.

11.10 H-T-AS: Affected System Thermal Power Flow Analysis (Constraints for Potential Upgrades)

Available upon request. Contact SPP Generation Interconnection Studies for details.

11.11 H-V-AS: Affected System Voltage Power Flow Analysis(Constraints for Potential Upgrades)

Available upon request. Contact SPP Generation Interconnection Studies for details.

11.12 I: Power Flow Analysis (Constraints from Multi-Contingencies)

Available upon request. Contact SPP Generation Interconnection Studies for details.

11.13 J: Group 1 Dynamic Stability Analysis Report

See next page



DISIS-2015-002-1 (GROUP 1)

LITTLE ROCK, AR

SOUTHWEST POWER POOL

DEFINITIVE INTERCONNECTION SYSTEM IMPACT RE-STUDY

S&C PROJECT NUMBER: 10627

DOCUMENT NUMBER: E-857

REVISION: 0

FINAL REPORT

CONFIDENTIAL

JULY 6, 2016



DISCLAIMER

THIS DOCUMENT WAS PREPARED AND PROVIDED PURSUANT TO A CONTRACT WITH CUSTOMER AND/OR END USER THAT DEFINES THE PARTIES' RESPECTIVE RIGHTS TO WORK PRODUCT AND INTELLECTUAL PROPERTY. ANY OTHER USE OF THIS DOCUMENT IS STRICTLY PROHIBITED. ALL OTHER RIGHTS ARE RESERVED AND NO LICENSE OR RIGHTS TO THE SUBJECT MATTER OF THIS DOCUMENT ARE GRANTED BY POSSESSION THEREOF.

REPORT REVISION HISTORY:

| REV | DATE | PREPARED BY | REVIEWED BY | APPROVED BY | DESCRIPTION |
|-----|------------|-------------|-------------|-------------|---------------------------|
| A | 06/21/2016 | MA | SK | SK | Preliminary report issued |
| 0 | 07/05/2016 | MA | SK | SK | Final report issued |

AUTHORS:

Prepared By:

Reviewed and Approved By:

Matthew Artus
Design Engineer
S&C Electric Company

Saeed Kamalinia
Assistant Manager – Consulting and
Analytical Services
S&C Electric Company



TABLE OF CONTENTS

1. Executive Summary 5

2. Introduction..... 6

3. Transmission System and Study Area 8

4. Power Flow Base Cases 9

5. Power Flow Model..... 10

6. Dynamic Stability Analysis 13

 6.1. Assumptions..... 13

 6.2. Stability Criteria 13

 6.3. Dynamic Stability Results..... 14

7. Power Factor Analysis 20

8. Low Wind/Low irradiance Conditions Analysis 22

9. Short-Circuit Study 23

10. Conclusions and Recommendations 24

LIST OF FIGURES

Figure 1: One-line Diagrams of the Interconnection Request Projects 12

Figure 2: Post-Transient Voltage at Bus #584893 (GEN-2015-048) 18

Figure 3: Post-Transient Voltage at Bus #599002 (GEN-2001-014) 19

LIST OF TABLES

Table 1: Group 1 Generation Interconnection Requests..... 6

Table 2: Prior-Queued Projects..... 6

Table 3: Group 1 Dynamic Stability Results 15

Table 4: Base Case Voltages at the Interconnection Request POI Bus 20

Table 5: Summary of Power Factor Analysis at the POI..... 21

Table 6: Shunt Reactor Mvar Determined by Low Wind/Low Irradiance Study..... 22



LIST OF APPENDICES

Appendix A

SPP Group 1 Fault Definitions (Submitted in a Separate File)

Appendix B

Southwest Power Pool Disturbance Performance Requirements (Submitted in a Separate File)

Appendix C

Dynamic Stability Plots For Cluster Scenario (Submitted in Separate Files from Appendix C-1 to C-3)

Appendix D

Power Factor Analysis Results (Submitted in Separate File from Appendix D-1 to D-6)

Appendix E

Short-Circuit Study Results (Submitted in a Separate File from appendix E-1 to E-2)



1. EXECUTIVE SUMMARY

S&C Electric Company (S&C) has performed a Definitive Interconnection System Impact Re-Study, DISIS-2015-002-1 (Group 1), in response to a request through Southwest Power Pool (SPP) Tariff. Group 1 now consists of seven (7) new interconnection requests (GEN-2015-048, GEN-2015-057, GEN-2015-059, GEN-2015-060, GEN-2015-081, GEN-2015-093, and GEN-2015-095). All seven (7) interconnection requests consist of wind farm projects.

S&C has performed dynamic stability analysis for Group 1 only under the Cluster scenario. The cluster studies were performed using three (3) cluster base cases (2016 Winter Peak, 2017 Summer Peak, and 2025 Summer Peak) provided by SPP. In the cluster studies, all seven new interconnection requests and prior-queued projects in Group 1 were studied at 100% of nameplate MW capacity. The dynamic stability studies revealed that Group 1 projects met the SPP transient voltage requirements, with the solutions illustrated in the dynamic stability results section of this report.

S&C has performed power factor analysis on Group 1 Cluster scenarios. Power factor analysis reported the power factors at the study projects point of interconnection (POI) for all N-1 three-phase contingences and marked the contingency at which the required power factor at the POI of study projects to maintain the voltages at the desired level is beyond the normal required capability (from 0.95 lagging to 0.95 leading) of the studied projects. The power factor requirement for GEN-2015-048, GEN-2015-057, GEN-2015-059, GEN-2015-060, GEN-2015-081, GEN-2015-093, and GEN-2015-095 interconnection requests is from 0.95 lagging to 0.95 leading power factor at the POIs.

S&C has performed an analysis of low wind condition for all the interconnection requests. The low wind analysis was performed under the cluster cases by taking the interconnection generation out of service and determining the Mvar size of a shunt reactor to offset the reactive power that comes from the capacitance of the project's transmission lines and collector cables. The shunt reactor Mvars are given in Section 8.

S&C has performed a short-circuit analysis for the 2017 Summer Peak and 2025 Summer Peak under Group 1 Cluster and reported short-circuit results at all buses up to five (5) levels away from the POI of the study projects.

**2. INTRODUCTION**

S&C has performed a Definitive Interconnection System Impact Re-Study, DISIS-2015-002-1 (Group 1), in response to a request through the SPP Tariff. Group 1 consists of seven (7) new interconnection requests listed in

Table 1 and twenty-five (25) prior-queued projects listed in Table 2.

Table 1: Group 1 Generation Interconnection Requests

| Project | Size (MW) | Generator Model | Generator Bus(es) | Point of Interconnection (POI) | POI Bus |
|--------------|-----------|--------------------|-------------------|---|---------|
| GEN-2015-048 | 200 | Vestas V110 (wind) | 584893 | Cleo Corner 138 kV | 514778 |
| GEN-2015-057 | 100 | GE 2.3 MW (wind) | 584953 | Minco 345 kV | 514801 |
| GEN-2015-059 | 6.3 | GE 1.79 MW (wind) | 599117 | Minco 345 kV | 514801 |
| GEN-2015-060 | 250 | GE 1.79 MW (wind) | 584983 & 584986 | Woodward EHV District 138 kV | 515376 |
| GEN-2015-081 | 180 | Vestas V110 (wind) | 585183 | Tap on the Woodward - Tatonga 345 kV line (G11_051-TAP) | 562075 |
| GEN-2015-093 | 250 | GE 2 MW (wind) | 585273 & 585274 | Gracemont 345 kV | 515800 |
| GEN-2015-095 | 176 | Vestas V110 (wind) | 585303 | Tap on Mooreland-Noel Switch 138 kV | 560066 |

Table 2: Prior-Queued Projects

| Request | Size (MW) | Generator Model | Point of Interconnection |
|---------------|-----------|--|-------------------------------------|
| GEN-2001-014 | 94.5 | Suzlon 2.1 MW (599002) | Fort Supply 138 kV (520920) |
| GEN-2001-037 | 102 | GE 1.5 MW (599012) | Moorland – Woodward 138 kV (515785) |
| GEN-2005-008 | 120 | GE 1.5 MW (579353) | Woodward 138 kV (514785) |
| GEN-2006-024S | 18.9 | Suzlon 2.1 MW (599057) | Buffalo Bear 69 kV (521120) |
| GEN-2006-046 | 132 | Mitsubishi 2.4 MW (599053) | Dewey 138 kV (514787) |
| GEN-2007-021 | 200 | GE 1.6 MW (599136) | Tatonga 345 kV (515407) |
| GEN-2007-043 | 200 | GE 1.6 MW (599062) | Minco 345 kV (514801) |
| GEN-2007-044 | 299.2 | GE 1.6 MW (599059 & 579275) | Tatonga 345 kV (515407) |
| GEN-2007-050 | 170.2 | Siemens 2.3 MW (599064 & 599065) | Woodward 138 kV (515376) |
| GEN-2007-062 | 765 | GE 1.5 MW (599070, 599073, 599077 & 599080) | Woodward 345 kV (515375) |
| GEN-2008-003 | 101.2 | Siemens 2.3 MW (599081) | Woodward 138 kV (515376) |
| GEN-2008-044 | 197.8 | Siemens SWT 2.3 MW (599101, 599103 & 599099) | Tatonga 345 kV (515407) |



S&C ELECTRIC COMPANY

Excellence Through Innovation

| | | | |
|--------------|-----------------------------|--------------------------------------|--|
| GEN-2010-011 | 29.7 | Siemens SWT 2.3 MW (599101 & 599103) | Tatonga 345 kV (515407) (Addition to Gen-2008-044 34.5kV bus (515450)) |
| GEN-2010-040 | 298.5 | RePower 2.05MW (599114 & 599116) | Cimarron 345 kV (514901) |
| GEN-2011-010 | 100.8 | GE 1.6 MW (599117) | Minco 345 kV (514801) |
| GEN-2011-019 | 299 | Siemens 2.3 MW (582319) | Woodward 345 kV (515375) |
| GEN-2011-020 | 299 | Siemens 2.3 MW (582320) | Woodward 345 kV (515375) |
| GEN-2011-051 | 104.4 | Vestas V90 1.8 MW (583113) | Tap on the Woodward - Tatonga 345 kV line (G11_051-TAP, 562075) |
| GEN-2011-054 | 298 | Vestas V100 2.0 MW (599122 & 599124) | Cimarron 345 kV (514901) |
| GEN-2014-002 | 10.53 increase (Pmax=209.4) | GE 97.4m 1.79 MW (599136) | Tatonga 345 kV (515407) |
| GEN-2014-003 | 15.84 increase (Pmax=315) | GE 97.4m 1.79 MW (599059,579275) | Tatonga 345 kV (515407) |
| GEN-2014-005 | 5.67 increase (Pmax=106.5) | GE 97.4m 1.79 MW (599117) | Minco 345 kV (514801) |
| GEN-2014-020 | 100.0 | Vestas V110 2.0 MW (583903) | Tuttle 138 kV (511501) |
| GEN-2014-056 | 250.0 | GE 2.0 MW (584063) | Minco 345 kV (514801) |
| GEN-2015-029 | 161.0 | GE 2.3 MW (584703) | Tatonga 345 kV (515407) |



3. TRANSMISSION SYSTEM AND STUDY AREA

The interconnection requests in Group 1 will interconnect into Oklahoma Gas & Electric (OKGE, Area #524) and Western Farmers Electric Cooperative (WFEC, Area #525). In addition to Areas #524 and #525, the following areas were monitored also:

- American Electric Power West (AEPW, Area #520)
- Southwestern Public Service (SPS, Area #526)
- Midwest Energy (MIDW, Area #531)
- Sunflower Electric Power Corporation (SUNC, Area #534)
- Westar Energy, Inc. (WERE, Area #536)




4. POWER FLOW BASE CASES


DISIS-2015-002-1 (Group 1) and prior-queued projects were modeled as aggregated generating units in the base cases from SPP.

Cluster Scenario Base Cases


- **MDWG15-16WP_DIS15021_G01.sav** – 2016 Winter Peak Cluster Base Case for Group 1. New interconnection requests and prior-queued projects at 100% output power.
- **MDWG15-17SP_DIS15021_G01.sav** – 2017 Summer Peak Cluster Base Case for Group 1. New interconnection requests and prior-queued projects at 100% output power.
- **MDWG15-25SP_DIS15021_G01.sav** – 2025 Summer Peak Cluster Base Case for Group 1. New interconnection requests and prior-queued projects at 100% output power.




(c) Interconnection request GEN-2015-059




(d) Interconnection request GEN-2015-060



(e) Interconnection request GEN-2015-081



(f) Interconnection request GEN-2015-093



(g) Interconnection request GEN-2015-095

Figure 1: One-line Diagrams of the Interconnection Request Projects



6. DYNAMIC STABILITY ANALYSIS

6.1. ASSUMPTIONS

Dynamic stability analysis was performed for all the SPP contingencies listed in Appendix A. Three-phase faults were simulated as bolted faults, while single line-to-ground faults were simulated under the assumption that a single line-to-ground fault will cause a 60% drop in the positive-sequence voltage at the fault location.

6.2. STABILITY CRITERIA

Dynamic stability studies were performed to ensure system stability following critical faults on the system. The system is considered stable if the following conditions are met:

- (1) Disturbances including three-phase and single-phase to ground faults, should not cause synchronous and asynchronous plants to disconnect from the transmission grid.
- (2) The angular positions of synchronous machine rotor become constant following an aperiodic system disturbance.
- (3) Voltage magnitudes and frequencies at terminals of asynchronous generators should not exceed magnitudes and durations that will cause protection elements to operate. Furthermore, the response after the disturbance needs to be studied at the terminals of the machine to ensure that there are no sustained oscillations in power output, speed, frequency, etc.
- (4) Voltage magnitudes and angles after the disturbance should settle to a constant and acceptable operating level. Frequencies should settle to the acceptable range within nominal 60 Hz power frequency.

In addition, performance of the transmission system is measured against the SPP Disturbance Criteria Requirements on Angular oscillations and Transient Voltage Recovery, detailed in Appendix B.



6.3. DYNAMIC STABILITY RESULTS

Multiple concerns surfaced during preliminary dynamic stability simulations. These issues were also addressed in the DISIS-2015-002 study report issued on March 11, 2016. A summary list of such concerns and how they were addressed is shown below.

- The prior outage for FLT40 caused the power flow simulation to “blow up” in 25SP case
 - Per SPP recommendation from the original Group 1 study, GEN-2015-048 was curtailed from 200 MW to 100 MW to resolve the issue.
- Gamesa WTGs at bus 599049 and 599050 tripped due to under-voltage protection.
 - This issue was resolved using the SPP provided IDV file from the original Group 1 study (GEN-2006-035_UV_Protection_Modification.idv).

Dynamic stability simulations were performed once again after implementing the solutions described above. Table 3 below summarizes the dynamic stability results for each contingency and each season.



Table 3: Group 1 Dynamic Stability Results
(YES = STABLE, NO = UNSTABLE, '-' Not applicable)

| Cont. No. | Cont. Name | 16WP: Cluster | 17SP: Cluster | 25SP: Cluster |
|-----------|--------------------------|---------------|---------------|--------------------|
| 1 | FLT01-3PH | YES | YES | YES ¹ |
| 2 | FLT02-3PH | YES | YES | YES ¹ |
| 3 | FLT03-3PH | YES | YES | YES ¹ |
| 4 | FLT04-3PH | YES | YES | YES ¹ |
| 5 | FLT05-3PH 2025SP Only | - | - | YES ¹ |
| 6 | FLT06-3PH | YES | YES | YES ¹ |
| 7 | FLT07-3PH | YES | YES | YES ¹ |
| 8 | FLT08-3PH | YES | YES | YES ¹ |
| 9 | FLT09-3PH | - | - | - |
| 10 | FLT10-3PH | YES | YES | YES ¹ |
| 11 | FLT11-3PH | YES | YES | YES ¹ |
| 12 | FLT12-3PH | YES | YES | YES ¹ |
| 13 | FLT13-3PH | YES | YES | YES ¹ |
| 14 | FLT14-3PH | YES | YES | YES ¹ |
| 15 | FLT15-3PH 2025SP Only | - | - | YES ¹ |
| 16 | FLT16-3PH | YES | YES | YES ¹ |
| 17 | FLT17-3PH | YES | YES | YES ¹ |
| 18 | FLT18-3PH | YES | YES | YES ¹ |
| 19 | FLT19-3PH | YES | YES | YES ¹ |
| 20 | FLT20-3PH | YES | YES | YES ¹ |
| 21 | FLT21-3PH | YES | YES | YES ¹ |
| 22 | FLT22-SB | YES | YES | YES ¹ |
| 23 | FLT23-SB | YES | YES | YES ¹ |
| 24 | FLT24-PO | YES | YES | YES ¹ |
| 25 | FLT25-PO | YES | YES | YES ¹ |
| 26 | FLT26-PO | YES | YES | YES ¹ |
| 27 | FLT27-3PH | YES | YES | YES ^{1,2} |
| 28 | FLT28-3PH 2025SP Only | - | - | YES ^{1,2} |
| 29 | FLT29-3PH | - | - | - |
| 30 | FLT30-SB | YES | YES | YES ¹ |

¹ Machine power kept at P=200 MW and react. power set to Q=40 Mvar at Bus #584893 (Gen Inter Req GEN-2015-048)

² Relay SLNOS #1 protecting line #523779-511451 was taken out of service to prevent tripping



S&C ELECTRIC COMPANY

Excellence Through Innovation

| Cont. No. | Cont. Name | 16WP: Cluster | 17SP: Cluster | 25SP: Cluster |
|-----------|--------------------------|------------------|------------------|------------------|
| 31 | FLT31-SB | YES | YES | YES ¹ |
| 32 | FLT32-PO | YES | YES | YES ¹ |
| 33 | FLT33-3PH | YES | YES | YES ¹ |
| 34 | FLT34-3PH | YES | YES | YES ¹ |
| 35 | FLT35-3PH | YES ³ | YES | YES ¹ |
| 36 | FLT36-3PH | YES | YES | YES ¹ |
| 37 | FLT37-3PH | YES ³ | YES | YES ¹ |
| 38 | FLT38-3PH | YES | YES | YES ¹ |
| 39 | FLT39-3PH | YES | YES | YES ¹ |
| 40 | FLT40-PO | YES ³ | YES ⁴ | YES ⁴ |
| 41 | FLT41-PO | YES ⁵ | YES ⁵ | YES ⁵ |
| 42 | FLT42-3PH | YES | YES | YES ¹ |
| 43 | FLT43-3PH | YES | YES | YES ¹ |
| 44 | FLT44-3PH | YES | YES | YES ¹ |
| 45 | FLT45-3PH | YES | YES | YES ¹ |
| 46 | FLT46-3PH | YES | YES | YES ¹ |
| 47 | FLT47-3PH | YES | YES | YES ¹ |
| 48 | FLT48-3PH | YES | YES | YES ¹ |
| 49 | FLT49-3PH | YES | YES | YES ¹ |
| 50 | FLT50-3PH | YES | YES | YES ¹ |
| 51 | FLT51-3PH | YES | YES | YES ¹ |
| 52 | FLT52-3PH | YES | YES | YES ¹ |
| 53 | FLT53-SB | YES | YES | YES ¹ |
| 54 | FLT54-SB | YES | YES | YES ¹ |
| 55 | FLT55-PO | YES | YES | YES ¹ |
| 56 | FLT56-PO | YES | YES | YES ¹ |
| 57 | FLT57-3PH | YES | YES | YES ¹ |
| 58 | FLT58-3PH 2025SP Only | - | - | YES ¹ |
| 59 | FLT59-3PH 2025SP Only | - | - | YES ¹ |
| 60 | FLT60-3PH 2025SP Only | - | - | YES ¹ |
| 61 | FLT61-SB 2025SP Only | - | - | YES ¹ |

³ Machine power kept at P=200 MW and react. power set to Q=10 Mvar at Bus #584893 (Gen Inter Req GEN-2015-048)

⁴ Machine power curtailed to P=100 MW and react. power set to Q=0 Mvar at Bus #584983 (Gen Inter Req GEN-2015-048)

⁵ Machine power curtailed to P=100 MW and react. power set to Q= -15 Mvar at Bus #584893 (Gen Inter Req GEN-2015-048)



| Cont. No. | Cont. Name | 16WP: Cluster | 17SP: Cluster | 25SP: Cluster |
|-----------|-------------------------|---------------|------------------|--------------------|
| 62 | FLT62-PO 2025SP Only | - | - | YES ¹ |
| 63 | FLT63-3PH | - | - | - |
| 64 | FLT64-3PH | - | - | - |
| 65 | FLT65-3PH | - | - | - |
| 66 | FLT66-3PH | YES | YES | YES ¹ |
| 67 | FLT67-3PH | YES | YES | YES ¹ |
| 68 | FLT68-3PH | YES | YES ⁶ | YES ^{1,6} |
| 69 | FLT69-3PH | YES | YES | YES ¹ |
| 70 | FLT70-3PH | YES | YES | YES ¹ |
| 71 | FLT71-3PH | YES | YES | YES ¹ |
| 72 | FLT72-3PH | YES | YES | YES ¹ |
| 73 | FLT73-3PH | YES | YES | YES ¹ |
| 74 | FLT74-3PH | - | - | - |
| 75 | FLT75-3PH | YES | YES | YES ¹ |
| 76 | FLT76-3PH | YES | YES | YES ¹ |
| 77 | FLT77-3PH | YES | YES | YES ¹ |
| 78 | FLT78-3PH | YES | YES | YES ¹ |
| 79 | FLT79-3PH | YES | YES | YES ¹ |
| 80 | FLT80-3PH | YES | YES | YES ¹ |
| 81 | FLT81-SB | - | - | - |
| 82 | FLT82-SB | - | - | - |
| 83 | FLT83-SB | YES | YES | YES ¹ |
| 84 | FLT84-SB | YES | YES | YES ¹ |
| 85 | FLT85-SB | - | - | - |
| 86 | FLT86-SB | YES | YES | YES ¹ |
| 87 | FLT87-SB | - | - | - |
| 88 | FLT88-SB | - | - | - |
| 89 | FLT89-SB | - | - | - |

⁶ Machine power kept at P=176 MW and react. power set to Q=10 Mvar at Bus #585303 (Gen Inter Req GEN-2015-095)



As shown in Table 3, the real power (P) and reactive power (Q) of the machine at bus #584893 (Generation Interconnection Request GEN-2015-048) were changed for various faults. These changes were made to resolve various issues, including generator tripping on overvoltage, and sustained power oscillations. It should be noted, however, that this interconnection project exhibited various abnormalities prior to dynamic simulations. A brief list of these abnormalities is shown below:

- Prior outage for FLT40 caused power flow to “blow up” in 25SP case (mentioned above)
- Prior outage for FLT40 resulted in high voltages at POI bus #514778 in 16WP/17SP cases
- Low voltage witnessed at POI bus #514778 in 25SP base case and prior outage cases

Furthermore, interconnection request project GEN-2015-048 (bus #584893) occasionally exhibited slight post-transient voltages greater than 1.1 p.u. during certain fault contingencies. An example of this situation is shown using Figure 2 below and was observed for FLT35 (17SP/25SP), FLT37 (17SP/25SP), and FLT40 (17SP/25SP).




Figure 2: Post-Transient Voltage at Bus #584893 (GEN-2015-048)



7. POWER FACTOR ANALYSIS

The power factor analysis was performed under the cluster bases and for all N-1 three-phase contingencies shown in the Fault Definition table in Appendix A. Single-phase contingencies, N-1-1 contingencies and N-2 contingencies were excluded from the study. Prior to the run, the cluster base cases were altered, by turning off the reactive capability of the renewable energy projects and by placing a new var generator at each renewable energy high voltage bus for supporting the reactive power. The var generators were set to hold the voltage schedule at the interconnection project consistent with the voltage schedules in the provided base case or 1.0 p.u. voltage (whichever is higher).

Table 4 gives the voltage schedule at each interconnection request location in the original cluster base cases. Note that the base case voltage for the GEN-2015-048’s 138-kV POI bus #514778 falls below the recommended 0.95 p.u. value in 2025 summer peak case.

Table 4: Base Case Voltages at the Interconnection Request POI Bus

| Request | POI | 2016 Winter Peak (p.u.) | 2017 Summer Peak (p.u.) | 2025 Summer Peak (p.u.) |
|------------------|--------|----------------------------|----------------------------|----------------------------|
| GEN-2015-048 | 514778 | 0.975 | 0.968 | 0.932 |
| GEN-2015-057/059 | 514801 | 1.003 | 1.008 | 1.010 |
| GEN-2015-060 | 515376 | 1.000 | 0.987 | 0.994 |
| GEN-2015-081 | 562075 | 0.991 | 0.992 | 1.006 |
| GEN-2015-093 | 515800 | 1.013 | 1.015 | 1.016 |
| GEN-2015-095 | 560066 | 0.987 | 0.978 | 0.979 |

The power factor analysis results for Group 1 interconnection requests for each N-1 three phase contingency were presented in Appendix D. We marked in pink color the contingencies at which the required power factor at the POI of the study project is beyond the normal required capability (from 0.95 lagging to 0.95 leading) of the studied renewable energy project. We also provided a summary Table 5 of the maximum leading/lagging reactive power demand and power factor found by the power factor analysis at the POIs.

The power factor requirement for GEN-2015-048, GEN-2015-057, GEN-2015-059, GEN-2015-060, GEN-2015-081, GEN-2015-093, and GEN-2015-095 interconnection requests is from 0.95 lagging to 0.95 leading power factor at the POIs.



Table 5: Summary of Power Factor Analysis at the POI

| Request | Capacity | POI | Reactive Power/Power Factor at POI | |
|------------------|----------|--------|------------------------------------|-----------------------------|
| | | | Leading (absorbing vars) | Lagging (providing vars) |
| GEN-2015-048 | 200 MW | 514778 | -33.6 Mvar / 0.986 | 48.7 Mvar / 0.971 |
| GEN-2015-057/059 | 106.3 MW | 514801 | -138.5 Mvar / 0.958* | 102.5 Mvar / 0.976* |
| GEN-2015-060 | 250 MW | 515376 | -73.8 Mvar / 0.958 | 94.7 Mvar / 0.934 |
| GEN-2015-081 | 180 MW | 562075 | -59.5 Mvar / 0.949 | 104.2 Mvar / 0.865 |
| GEN-2015-093 | 250 MW | 515800 | -122.9 Mvar / 0.897 | 81.3 Mvar / 0.951 |
| GEN-2015-095 | 176 MW | 560066 | -39.5 Mvar / 0.976 | 32.6 Mvar / 0.983 |

** Note that two (2) interconnection requests GEN-2015-057 and GEN-2015-059 have the same POI bus (514801) as the prior-queued project Gen-2014-056. The aggregated MW of these three (3) generators is 462.8 MW at the high-side bus downstream of the POI.*

NOTE: Per the SPP Tariff as reactive power is required for all projects, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.



8. LOW WIND/LOW IRRADIANCE CONDITIONS ANALYSIS

S&C has performed an analysis of low wind condition for the interconnection requests. The low wind analysis was performed under the Cluster scenarios by taking the interconnection renewable energy project out of service and placing a shunt reactor at the project substation high side bus to offset the reactive power that comes from the capacitance of the project’s transmission lines and collector cables. The size of the shunt reactor was adjusted such that the net Mvar flow into the POI from the studied renewable energy project was approximately zero. Table 6 gives the shunt reactor Mvars for the studied projects.

Table 6: Shunt Reactor Mvar Determined by Low Wind/Low Irradiance Study

| Request | POI | 2016 Winter Peak | 2017 Summer Peak | 2025 Summer Peak |
|------------------|--------|------------------|------------------|------------------|
| GEN-2015-048 | 514778 | 20.3 | 20.3 | 20.3 |
| GEN-2015-057/059 | 514801 | 35.8 | 35.8 | 35.8 |
| GEN-2015-060 | 515376 | 13.9 | 13.9 | 13.9 |
| GEN-2015-081 | 562075 | 8.4 | 8.4 | 8.4 |
| GEN-2015-093 | 515800 | 16.6 | 16.6 | 16.6 |
| GEN-2015-095 | 560066 | 14.6 | 14.6 | 14.6 |



9. SHORT-CIRCUIT STUDY

A short-circuit study has been performed on the power flow models for the 2017 Summer Peak and 2025 Summer Peak Seasons for each generator using the Cluster Scenario model. Short-circuit analysis includes applying a 3-phase fault on buses up to 5 levels away from the POI of each interconnection request project. PSS/E “Automatic Sequence Fault Calculation (ASCC)” fault analysis module was used for the purpose of short-circuit analysis. The results of the short-circuit analysis have been recorded for all the buses up to five levels away from the point of interconnection of each interconnection request project. Detailed results of the short-circuit study are provided in Appendix E.



10. CONCLUSIONS AND RECOMMENDATIONS

With the adjustments mentioned in Section 6, Group 1's dynamic results (Cluster) indicated that the interconnection request projects are expected to successfully ride through all N-1 and N-2 fault contingencies specified by SPP, retaining angular, frequency and voltage stability at the nearby areas and meeting the transient voltage recovery requirement by SPP, with the solutions illustrated in the dynamic stability results section of this report. With the implementation of these solutions or similar alternatives, it is thus concluded that Group 1 study projects are expected to successfully interconnect into the transmission system at their desired locations for 100% power outputs.

The results of power factor analysis indicate that all interconnection requests are required to maintain a power factor of 0.95 lagging to 0.95 leading at the POI to meet SPP's requirements.

The low wind study suggested that to offset the reactive power from the capacitance of the project's transmission lines and collector cables during the low wind conditions, GEN-2015-048 project requires a 20.3 Mvar shunt reactor, GEN-2015-057/059 projects require a 35.8 Mvar shunt reactor, GEN-2015-060 project requires a 13.9 Mvar shunt reactor, GEN-2015-081 project requires a 8.4 Mvar shunt reactor, GEN-2015-093 project requires a 16.6 Mvar shunt reactor, and GEN-2015-095 project requires a 14.6 Mvar shunt reactor.

A short-circuit study has been performed on the power flow models for the 2017 Summer Peak Season and 2025 Summer Peak Season for each generator using the Cluster Scenario model. A 3-phase fault is applied on buses up to 5 levels away from the POI of each interconnection request project and the results of the study have been presented.



S&C ELECTRIC COMPANY

Excellence Through Innovation

APPENDIX A

SPP GROUP 1 FAULT DEFINITIONS (SUBMITTED IN A SEPARATE FILE)



S&C ELECTRIC COMPANY

Excellence Through Innovation

APPENDIX B

SOUTHWEST POWER POOL DISTURBANCE PERFORMANCE REQUIREMENTS (SUBMITTED IN A SEPARATE FILE)



APPENDIX C

DYNAMIC STABILITY PLOTS FOR CLUSTER SCENARIO (SUBMITTED IN SEPARATE FILES FROM APPENDIX C-1 TO C-3)

C-1 Group 1 Cluster Dynamic Stability Plots For 2016 Winter Peak Case

C-2 Group 1 Cluster Dynamic Stability Plots For 2017 Summer Peak Case

C-3 Group 1 Cluster Dynamic Stability Plots For 2025 Summer Peak Case

Each contingency consists of (48) subplots:

- Subplot #1 shows the system phase angle channels
- Subplot #2 to Subplot #40 are results for (39) generators in the scope of study.
- Subplots #41 to Subplot #44 are voltages at the POI buses in the scope of study.
- Subplots #45 to Subplot #48 are frequencies at the POI buses in the scope of study.



APPENDIX D

POWER FACTOR ANALYSIS RESULTS (SUBMITTED IN SEPARATE FILE FROM APPENDIX D-1 TO D-6)

D-1 Group 1 Power Factor Results for Interconnection Request GEN-2015-048 (#514778)

D-2 Group 1 Power Factor Results for Interconnection Request GEN-2015-057/59 (#514801)

D-3 Group 1 Power Factor Results for Interconnection Request GEN-2015-060 (#515376)

D-4 Group 1 Power Factor Results for Interconnection Request GEN-2015-081 (#562075)

D-5 Group 1 Power Factor Results for Interconnection Request GEN-2015-093 (#515800)

D-6 Group 1 Power Factor Results for Interconnection Request GEN-2015-095 (#560066)



S&C ELECTRIC COMPANY

Excellence Through Innovation

APPENDIX E


SHORT-CIRCUIT STUDY RESULTS (SUBMITTED IN A SEPARATE FILE FROM APPENDIX E-1 TO E-2)

E-1 GROUP 1 17SP Short-Circuit Study Results

E-2 GROUP 1 25SP Short-Circuit Study Results

11.14 K: Group 2 Dynamic Stability Analysis Report

See ABB report next page



Southwest Power Pool DEFINITIVE IMPACT STUDY DISIS-2015-002-1 (GROUP 02)

Final Report

Report No. r00

23 June 2016

CONFIDENTIAL

Contains Proprietary Information
DO NOT RELEASE

LEGAL NOTICE

This document, prepared by ABB Inc, is an account of work sponsored by Southwest Power Pool (SPP). Neither SPP nor ABB Inc nor any person or persons acting on behalf of either party: (i) makes any warranty or representation, expressed or implied, with respect to the use of any information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights, or (ii) assumes any liabilities with respect to the use of or for damages resulting from the use of any information, apparatus, method, or process disclosed in this document.

CONFIDENTIAL

This report contains proprietary information and is not to be released or reproduced without the express, written consent of ABB and SPP.

Prepared for: Southwest Power Pool
Report No.: r00
Date: 23 June 2016
Revised:

Author(s): Lang Chen
Reviewed by: Shu Liu
Approved by: Willie Wong

ABB Inc.
Power Systems Division
Grid Systems Consulting
901 Main Campus Drive, Suite 300
Raleigh, NC 27606

| <i>Rev No.</i> | <i>Revision Description</i> | <i>Date</i> | <i>Authored by</i> | <i>Reviewed by</i> | <i>Approved by</i> |
|----------------|-----------------------------|-------------|--------------------|--------------------|--------------------|
| | | | | | |
| | | | | | |
| | | | | | |

SUMMARY

Southwest Power Pool (SPP) has commissioned ABB Inc., to perform a Definitive Impact Study for DISIS-2015-002_1 (Group 02) which includes generation interconnection request GEN-2014-037 (200 MW wind farm connected on the tap from Hitchland to Beaver County 345kV line).

| Request | Size (MW) | Generator Model | POI |
|--------------|-----------|-------------------|---|
| GEN-2014-037 | 200.0 | Vestas V110 2.0MW | Tap on Hitchland to Beaver County 345kV (Optima 345kV – 560010) |

The objective of this study is to evaluate the impact of project GEN-2014-037 on the existing and future planning system. The study is performed on three system scenarios provided by SPP:

- 2016 Winter Peak Case
- 2017 Summer Peak Case
- 2025 Summer Peak Case

Fault FLT08-3PH in all three seasons showed high voltage violations. Those bus voltages have little spike right after fault clearing and the peak values are slightly over 1.2 p.u. Pre-project case was created for the 2016 Winter Peak case which presents the most the voltage violations. The simulation results show no over voltage violations for the pre-project case; therefore, it can be concluded that this high voltage violations are caused by the studied generators.

For FLT04-3PH and FLT06-3PH, the studied generators and several pre-queued projects showed undamped oscillations. And a couple of bus voltages and machine responses also showed wiggling response following these two faults for all three seasons. Pre-project cases were created for all three study season to simulate the above two faults. For FLT06-3PH, undamped oscillations were observed for all the pre-project study cases. For FLT04-3PH, only 2016 winter peak pre-project case presents undamped oscillation. In discussions with SPP since FLT04-3PH, FLT06-3PH, and FLT 08-3PH are double circuit faults, the mitigation will be the curtailment of generation in the area.

For the rest of the studied faults, the simulation results showed no instability problems and no voltage violations for all three seasons. All the simulation results were summarized in Table 2-2.

System short-circuit current levels at up to five buses away from the point of interconnection were calculated and tabulated for SPP’s reference.

Power Factor Analysis was performed to ensure the studied project meets FERC and SPP power factor requirements for wind farm interconnections. The results show significant need for reactive power from the study project following the critical contingencies. The proposed GEN-

2014-037 need to design their facility to meet the SPP pro-forma 95% lagging (providing vars) and 95% leading (absorbing vars) power factor requirements at the Point of Interconnection.

The Low/No Wind analysis shows that a 13.55 MVAR shunt reactor is required to bring the MVAR flow in the POI down to approximate zero under low/no wind conditions. The reactor bank size is approximate and the final size will be determined in the final facility and collector system design.

The results of this analysis are based on available data and assumptions made at the time of conducting this study. If any of the data and/or assumptions made in developing the study model change, the results provided in this report may not apply.

Contents

| | | |
|-----|---|----|
| 1 | Introduction..... | 1 |
| 2 | STABILITY ANALYSIS | 4 |
| 2.1 | STABILITY ANALYSIS METHODOLOGY | 4 |
| 2.2 | STUDY RESULTS..... | 12 |
| 3 | SHORT CIRCUIT ANALYSIS | 18 |
| 4 | POWER FACTOR ANALYSIS | 23 |
| 4.1 | POWER FACTOR ANALYSIS METHODOLOGY..... | 23 |
| 4.2 | STUDY RESULTS..... | 23 |
| 5 | LOW WIND/NO WIND ANALYSIS | 25 |
| 5.1 | LOW/NO WIND ANALYSIS METHODOLOGY | 25 |
| 5.2 | STUDY RESULTS..... | 25 |
| 6 | CONCLUSIONS..... | 26 |
| | APPENDIX A SOUTHWEST POWER POOL DISTURBANCE PERFORMANCE CRITERIA REQUIREMENTS..... | 28 |
| | APPENDIX B SIMULATION PLOTS FOR STABILITY ANALYSIS | 30 |
| | APPENDIX C POWER FACTOR ANALYSIS RESULTS..... | 31 |

1 Introduction

Southwest Power Pool (SPP) has commissioned ABB Inc., to perform a Definitive Impact Study for DISIS-2015-002_1 (Group 02) which includes generation interconnection request GEN-2014-037 (200 MW wind farm connected on the tap from Hitchland to Beaver County 345kV line) as shown in Table 1-1.

Table 1-1: Group 02 Generation Interconnection Requests

| Request | Size (MW) | Generator Model | POI |
|--------------|-----------|-------------------|---|
| GEN-2014-037 | 200.0 | Vestas V110 2.0MW | Tap on Hitchland to Beaver County 345kV (Optima 345kV – 560010) |

The objective of this study is to evaluate the impact of project GEN-2014-037 on the existing and future planning system. The study is performed on three system scenarios provided by SPP:

- 2016 Winter Peak Case
- 2017 Summer Peak Case
- 2025 Summer Peak Case

In the process of the study, SPP provided following changes to the fault and system conditions:

- The definitions of FLT31-3PH, FLT32-3PH, FLT39-PO, FLT40-PO, FLT42-PO and FLT43-PO were changed. The updated information are shown as in Table 2-1.
- The dispatch of GEN-2002-022 and GEN-2008-051 are down to 20% for all three seasons.

SPP provided the study cases for all three system scenarios with GEN-2014-037 included. One line diagrams of the local area for all three seasons are shown in Figure 1-1. The studied generator is circled red.

The three system scenarios supplied by SPP included the following prior queued projects for Group 02:

Table 1-2: Group 02 Prior Queued Projects

| Request | Size (MW) | Wind Turbine Model | Point of Interconnection |
|-----------------------------|------------------|-------------------------------------|--|
| Llano Estacado (White Deer) | 80.0 | CIMTR1 | Tap on Kingsmill (523712) to MIDSTRM Tap (523817) (523815) |
| GEN-2002-008 | 240 | GE 1.5MW | Hitchland 345kV (523097) |
| GEN-2002-009 | 79.8 | Suzlon 2.1MW | Hansford 115kV (523195) |
| GEN-2003-020 | 159.1 | GE 1.5/1.6 MW | Carson Co. 115kV (523928) |
| GEN-2006-020S | 20 | D8.2 2.0MW | Frisco Wind 115kV (523160) |
| GEN-2006-044 | 370 | DeWind D9.2 2.0MW | Hitchland 345kV (523097) |
| GEN-2007-046 | 200.0 | Vestas V100/V110 2.0MW | Hitchland 115kV (523093) |
| GEN-2008-047 | 300 | GE 1.7MW | Beaver County 345kV (515554) |
| GEN-2010-001 | 300 | GE 1.85MW | Beaver County 345kV (515554) |
| GEN-2010-014 | 358.8 | Siemens SWT 2.3MW | Hitchland 345kV (523097) |
| ASGI-2011-002 | 20 | DeWind D8.2 2.0MW | Herring 115kV (523359) |
| GEN-2011-014 | 198 | Vestas V117 3.3MW | Beaver County 345kV (515554) |
| GEN-2011-022 | 299 | Siemens 2.3MW | Hitchland 345kV (523097) |
| ASGI-2013-001 | 11.5 | Siemens 2.3 | PanTex South 115kV(523945) |
| GEN-2013-030 | 300 | Vestas 2.0 MW VCSS (583763, 583766) | Beaver County 345kV (515554) |

Figure 1-2 (b): One Line Diagram of Group 02 Area for 2017 Summer Peak Case





Figure 1-3 (c): One Line Diagram of Group 02 Area for 2025 Summer Peak Case



2 STABILITY ANALYSIS

In this study, ABB investigated the stability of the system for faults in the vicinity of the proposed plant as defined by SPP. The studied faults involve three-phase transformer faults with normal clearing, three-phase line faults with normal clearing and re-closing test, and single-line-to-ground (SLG) faults with stuck breaker.

2.1 STABILITY ANALYSIS METHODOLOGY

Stability analysis is performed to determine whether the electric system would meet stability criteria following the addition of the GEN-2014-037 project.

According to the latest version of Disturbance Performance Requirements, the electric system shall meet the following voltage criteria:

After a disturbance is cleared; bus voltages on the Bulk Electric System shall recover above 0.70 per unit, 2.5 seconds after the fault is cleared. Bus voltages shall not swing above 1.20 per unit after the fault is cleared, unless affected transmission system elements are designed to handle the rise above 1.2 per unit.

Stability analysis was performed using Siemens-PTI's PSS/E dynamics program V32.2.0.

All the faults listed in Table 2-1 were simulated for 20 seconds.

Table 2-1: List of Faults for Stability Analysis

| Cont. No. | Cont. Name | Description |
|-----------|------------|---|
| 1 | FLT01-3PH | 3 phase fault on Optima 345kV (560010) to Beaver County 345kV (515554) CKT 1, near Optima. a. Apply fault at the Optima 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 2 | FLT02-3PH | 3 phase fault on Optima 345kV (560010) to Hitchland 345kV (523097) CKT 1, near G14-037 Tap. a. Apply fault at the Optima 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 3 | FLT03-3PH | 3 phase fault on the Beaver County 345kV (515554) to G11-14-Tap 345kV (560000) CKT 1, near Beaver County. a. Apply fault at the Beaver County 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 4 | FLT04-3PH | 3 phase fault on the Beaver County 345kV (515554) to G11-014-Tap 345kV (560000) CKT 1 & 2, near Beaver County. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|---|
| | | a. Apply fault at the Beaver County 345kV bus. b. Clear fault after 5 cycles and trip the faulted lines (CKT 1 and 2). |
| 5 | FLT05-3PH | 3 phase fault on the G11-014-Tap 345kV (560000) to Woodward 345kV (515375) CKT 1, near G11-014-Tap. a. Apply fault at the G11-014-Tap 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 6 | FLT06-3PH | 3 phase fault on the G11-014-Tap 345kV (560000) to Woodward 345kV (515375) CKT 1 & 2, near G11-014-Tap. a. Apply fault at the G11-014-Tap 345kV bus. b. Clear fault after 5 cycles and trip the faulted lines (CKT 1 and 2). |
| 7 | FLT07-3PH | 3 phase fault on the Optima 345kV (560010) to Beaver County 345kV (515554) CKT 1 and 2, near Optima. a. Apply fault at the Optima 345kV bus. b. Clear fault after 5 cycles and trip the faulted lines (CKT 1 and 2). |
| 8 | FLT08-3PH | 3 phase fault on the Optima 345kV (560010) to Hitchland 345kV (523097) CKT 1 and 2, near Optima. a. Apply fault at the Optima 345kV bus. b. Clear fault after 5 cycles and trip the faulted lines (CKT 1 and 2). |
| 9 | FLT09-3PH | 3 phase fault on the Thistle 345kV (539801) to Woodward 345kV (515375) CKT 1, near Thistle. a. Apply fault at the Thistle 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 10 | FLT10-3PH | 3 phase fault on the Thistle 345kV (539801) to Woodward 345kV (515375) CKT 1 and 2, near Thistle. a. Apply fault at the Thistle 345kV bus. b. Clear fault after 5 cycles and trip the faulted lines (CKT 1 and 2). |
| 11 | FLT11-3PH | 3 phase fault on the Woodward 345kV (515375) to Border 345kV (515458) CKT 1, near Woodward. a. Apply fault at the Woodward 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 12 | FLT12-3PH | 3 phase fault on the Woodward 345kV (515375) to G11-051 Tap 345kV (562075) CKT 1, near Woodward. a. Apply fault at the Woodward 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

| Cont. No. | Cont. Name | Description |
|-----------|--------------------------|--|
| 13 | FLT13-3PH (25SP Only) | 3 phase fault on the Woodward 345kV (515375) to G11-051-Tap 345kV (562075) CKT 1 and 2, near Woodward. a. Apply fault at the Woodward 345kV bus. b. Clear fault after 5 cycles and trip the faulted lines (CKT 1 and 2). |
| 14 | FLT14-3PH | 3 phase fault on the Woodward 345kV (515375) to Woodward 138kV (515376) Woodward 13.8kV (515799) XFMR CKT 2, near Woodward 345kV. a. Apply fault at the Woodward 345kV bus. b. Clear fault after 5 cycles and trip the faulted transformer. |
| 15 | FLT15-3PH | 3 phase fault on the Border 345kV (515458) to Tuco 345kV (525832) CKT 1, near Border. a. Apply fault at the Border 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 16 | FLT16-3PH | 3 phase fault on the Tuco 345kV (525832) to G14-074-Tap 345kV (560027) CKT 1, near Tuco. a. Apply fault at the Tuco 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 17 | FLT17-3PH | 3 phase fault on the G14-074-Tap 345kV (560027) to OKU 345kV (511456) CKT 1, near G14-074-Tap. a. Apply fault at the G14-074-Tap 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 18 | | DELETED |
| 19 | FLT19-3PH | 3 phase fault on the Thistle 345kV (539801) to G1524&G1525T 345kV (560033) CKT 1, near Thistle. a. Apply fault at the Thistle 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 20 | FLT20-3PH | 3 phase fault on the Thistle 345kV (539801) to G1524&G1525T 345kV (560033) CKT 1 and 2, near Thistle. a. Apply fault at the Thistle 345kV bus. b. Clear fault after 5 cycles and trip the faulted lines (CKT 1 and 2). |
| 21 | FLT21-3PH | 3 phase fault on the Thistle 345kV (539801) to Clark County 345kV (539800) CKT 1, near Thistle. a. Apply fault at the Thistle 345kV bus. |

| Cont. No. | Cont. Name | Description |
|-----------|--------------------------|--|
| | | <p>b. Clear fault after 5 cycles and trip the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 22 | FLT22-3PH | <p>3 phase fault on the Thistle 345kV (539801) to Clark County 345kV (539800) CKT 1 and 2, near Thistle.</p> <p>a. Apply fault at the Thistle 345kV bus.</p> <p>b. Clear fault after 5 cycles and trip the faulted lines (CKT 1 and 2).</p> |
| 23 | FLT23-3PH | <p>3 phase fault on the Thistle 345kV (539801) to Thistle 138kV (539804) Thistle 13.8kV (539802) XFMR CKT 1, near Thistle 345kV.</p> <p>a. Apply fault at the Thistle 345kV bus.</p> <p>b. Clear fault after 5 cycles and trip the faulted transformer.</p> |
| 24 | FLT24-3PH (16WP Only) | <p>3 phase fault on the Hitchland 345kV (523097) to Finney 345kV (523853) CKT 1, near Hitchland.</p> <p>a. Apply fault at the Hitchland 345kV bus.</p> <p>b. Clear fault after 5 cycles and trip the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 25 | FLT25-3PH | <p>3 phase fault on the Hitchland 345kV (523097) to Hitchland 230kV (523095) Hitchland 13.2kV (523091) XFMR CKT 1, near Hitchland 345kV.</p> <p>a. Apply fault at the Hitchland 345kV bus.</p> <p>b. Clear fault after 5 cycles and trip the faulted transformer.</p> |
| 26 | FLT26-3PH | <p>3 phase fault on the Potter County 345kV (523961) to Potter County 230kV (523959) Potter County 13.2kV (523957) XFMR CKT 1, near Potter County 345kV.</p> <p>a. Apply fault at the Potter County 345kV bus.</p> <p>b. Clear fault after 5 cycles and trip the faulted transformer.</p> |
| 27 | FLT27-3PH | <p>3 phase fault on the Hitchland 230kV (523095) to Ochiltree 230kV (523155) CKT 1, near Hitchland.</p> <p>a. Apply fault at the Hitchland 230kV bus.</p> <p>b. Clear fault after 5 cycles and trip the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 28 | FLT28-3PH | <p>3 phase fault on the Hitchland 230kV (523095) to Moore County 230kV (523309) CKT 1, near Hitchland.</p> <p>a. Apply fault at the Hitchland 230kV bus.</p> <p>b. Clear fault after 5 cycles and trip the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 29 | FLT29-3PH | <p>3 phase fault on the Finney 345kV (523853) to Holcomb 345kV (531449) CKT 1, near Finney.</p> <p>a. Apply fault at the Finney 345kV bus.</p> <p>b. Clear fault after 5 cycles and trip the faulted line.</p> |

| Cont. No. | Cont. Name | Description |
|-----------|------------|--|
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 30 | FLT30-3PH | 3 phase fault on the Holcomb 345kV (531449) to Buckner 345kV (531501) CKT 1, near Holcomb. a. Apply fault at the Holcomb 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 31 | FLT31-3PH | 3 phase fault on Hitchland 345kV (523097) to Potter 345kV (523961) CKT 1, near Hitchland. a. Apply fault at the Hitchland 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 32 | | DELETED |
| 33 | FLT33-3PH | 3 phase fault on Potter County 230kV (523959) to Moore County 230kV (523309) CKT 1, near Potter County. a. Apply fault at the Potter County 230kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 34 | FLT34-3PH | 3 phase fault on Potter County 230kV (523959) to Harrington East 230kV (523979) CKT 1, near Potter County. a. Apply fault at the Potter County 230kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 35 | FLT35-3PH | 3 phase fault on Potter County 230kV (523959) to Rolling Hills 230kV (524010) CKT 1, near Potter County. a. Apply fault at the Potter County 230kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 36 | FLT36-3PH | 3 phase fault on Potter County 230kV (523959) to Bushland 230kV (524267) CKT 1, near Potter County. a. Apply fault at the Potter County 230kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 37 | FLT37-3PH | 3 phase fault on Potter County 230kV (523959) to Newhart 230kV (525461) CKT 1, near Potter County. a. Apply fault at the Potter County 230kV bus. |

| Cont. No. | Cont. Name | Description |
|-----------|----------------------------------|---|
| | | <ul style="list-style-type: none"> b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 38 | FLT38-3PH | <p>3 phase fault on the Finney 345kV (523853) to Lamar 345kV (599950) CKT 1, near Finney.</p> <ul style="list-style-type: none"> a. Apply fault at the Finney 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. |
| 39 | FLT39-PO (16WP Only) | <p>Prior outage on the Hitchland (523097) - Finney (523853)</p> <p>3 phase fault on Potter County 345kV (523961) to Hitchland 345kV (523097) CKT 1, near Potter County.</p> <ul style="list-style-type: none"> a. Apply fault at the Potter County 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 40 | FLT40-PO (17SP and 25SP Only) | <p>Prior outage on the Hitchland (523097) – Walk Tap (531512)</p> <p>3 phase fault on Potter County 345kV (523961) to Hitchland 345kV (523097) CKT 1, near Potter County.</p> <ul style="list-style-type: none"> a. Apply fault at the Potter County 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 41 | FLT41-PO (17SP and 25SP Only) | <p>Prior outage on the Hitchland (523097) - Walk Tap (531512)</p> <p>3 phase fault on Hitchland 345kV (523097) to G14-037-Tap 345kV (560010) CKT 1, near G14-037 Tap.</p> <ul style="list-style-type: none"> a. Apply fault at the G14-037-Tap 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 42 | | DELETED |
| 43 | FLT43-PO (17SP and 25SP Only) | <p>Prior outage on the Hitchland 345kV (523097) to Potter 345kV (523961)</p> <p>3 phase fault on Hitchland (523097) – Walk Tap (531512) CKT 1, near Hitchland.</p> <ul style="list-style-type: none"> a. Apply fault at the Hitchland 345kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 44 | FLT44-PO | <p>Prior outage on the Woodward 345kV (515375) to Thistle (539801) 345kV line</p> <p>3 phase fault on Tatonga (515407) to G11-051-Tap (562075)</p> <ul style="list-style-type: none"> a. Apply fault on the Tatonga (515407) 345kV to G11-051-Tap (562075) near Tatonga b. Clear fault after 5 cycles and trip the faulted line. |

| Cont. No. | Cont. Name | Description |
|-----------|-------------------------|--|
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 45 | FLT45-SB | Woodward 345kV Stuck Breaker a. Apply single phase fault at the Woodward (515375) 345kV bus on the Woodward – G11-051-Tap (562075) 345kV line b. Wait 16 cycles, and then drop Woodward (515375) 345kV to Thistle (539801) 345kV ckt 1 c. Trip Woodward to G11-051-Tap 345kV and remove the fault |
| 46 | FLT46-SB | Hitchland 345kV Stuck Breaker a. Apply single phase fault at the Hitchland (523097) 345kV bus b. Wait 16 cycles, and then drop Hitchland – Optima (560010) 345kV circuit 1 and remove fault |
| 47 | FLT47-SB (16WP Only) | Hitchland 345kV Stuck Breaker a. Apply single phase fault at the Hitchland (523097) 345kV bus b. Wait 16 cycles, and then drop Hitchland – Finney (523853) 345kV circuit 1 and remove fault |
| 48 | FLT48-PO | Prior outage on the Woodward 345kV (515375) to Thistle (539801) 345kV line 3 phase fault on Tatonga (515407) to Mathewson (515497) a. Apply 3 phase fault on the Tatonga (515407) 345kV to Mathewson (515497) line near Tatonga b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 49 | FLT49-SB | Beaver 345kV Stuck Breaker a. Apply single phase fault at the Beaver County (515554) 345kV bus b. Wait 16 cycles, and then drop Beaver County – G11-14-Tap (560000) 345kV circuit 1 and remove fault |
| 50 | FLT50-SB | G11-14-Tap 345kV Stuck Breaker a. Apply single phase fault at the G11-14-Tap (560000) 345kV bus b. Wait 16 cycles, and then drop G11-14-Tap (560000) – Woodward (515375) 345kV circuit 1 and remove fault |
| 51 | FLT51-SB | Woodward 345kV Stuck Breaker a. Apply single phase fault at the Woodward (515375) 345kV bus b. Wait 16 cycles, and then drop Woodward (515375) – Border (515458) 345kV circuit 1 and remove fault |
| 52 | FLT52-SB | Additional stuck breaker contingency determined by Consultant (with review from SPP) for GEN-2014-037 |
| 53 | FLT53-SB | Additional stuck breaker contingency determined by Consultant (with review from SPP) for GEN-2014-038 |
| 54 | FLT54-SB | Additional stuck breaker contingency determined by Consultant (with review from SPP) for GEN-2015-082 |

Single- line-to-ground faults were simulated with the standard method of applying fault impedance to the positive sequence network to represent the effect of the negative and zero

sequence networks on the positive sequence network. The SLG fault impedance was computed by using PSS/E function “SCMU” as suggested by SPP.

The Southwest Power Pool Disturbance Performance Criteria Requirements in Appendix A were used to evaluate the system response during the initial transient period following a disturbance on the system. Generator response and bus voltages (115 kV and above) in Areas 520, 524, 525, 526, 531, 534, and 536 were monitored to ensure the system performance meets criteria requirements. Rotor angles of the nearby synchronous machines were investigated to make sure they maintained synchronism and had adequate damping following system faults.

Any wind generator must comply with FERC Order 661A on low voltage ride through requirements for wind farms. Therefore, the wind generators should not be tripped off line for faults by under voltage relay actuation. Generator speed of pre-queued projects was also monitored to ensure they stay online under system contingencies. For contingencies that result in a prior queued project tripping off-line; the contingency shall be re-run with the prior queued project's voltage and frequency tripping disabled.

2.2 STUDY RESULTS

All fault results are summarized in Table 2-2. The “Low Voltage Violation” in the table refers to bus voltages are lower than 0.7 pu. 2.5 second after the fault clearing and the “High Voltage” refers to bus voltage are higher than 1.2 pu. right after fault clearing. All violations are highlighted with **red**.

Table 2-2 Study Results Summary

| Fault File Name | 16WP Case | | | Fault File Name | 17SP Case | | | Fault File Name | 25SP Case | | |
|--------------------|-------------------------|--------------------------|---------------------------|--------------------|-------------------------|--------------------------|---------------------------|--------------------|-------------------------|--------------------------|---------------------------|
| | Stable? | Low Voltage Violation | High Voltage Violation | | Stable? | Low Voltage Violation | High Voltage Violation | | Stable? | Low Voltage Violation | High Voltage Violation |
| FLT01-3PH | Stable | No | No | FLT01-3PH | Stable | No | No | FLT01-3PH | Stable | No | No |
| FLT02-3PH | Stable | No | No | FLT02-3PH | Stable | No | No | FLT02-3PH | Stable | No | No |
| FLT03-3PH | Stable | No | No | FLT03-3PH | Stable | No | No | FLT03-3PH | Stable | No | No |
| FLT04-3PH | Undamped Oscillation | No | No | FLT04-3PH | Undamped Oscillation | No | No | FLT04-3PH | Undamped Oscillation | No | No |
| FLT05-3PH | Stable | No | No | FLT05-3PH | Stable | No | No | FLT05-3PH | Stable | No | No |
| FLT06-3PH | Undamped Oscillation | No | No | FLT06-3PH | Undamped Oscillation | No | No | FLT06-3PH | Undamped Oscillation | No | No |
| FLT07-3PH | Stable | No | No | FLT07-3PH | Stable | No | No | FLT07-3PH | Stable | No | No |
| FLT08-3PH | Stable | No | Yes | FLT08-3PH | Stable | No | Yes | FLT08-3PH | Stable | No | Yes |
| FLT09-3PH | Stable | No | No | FLT09-3PH | Stable | No | No | FLT09-3PH | Stable | No | No |
| FLT10-3PH | Stable | No | No | FLT10-3PH | Stable | No | No | FLT10-3PH | Stable | No | No |
| FLT11-3PH | Stable | No | No | FLT11-3PH | Stable | No | No | FLT11-3PH | Stable | No | No |
| FLT12-3PH | Stable | No | No | FLT12-3PH | Stable | No | No | FLT12-3PH | Stable | No | No |
| FLT14-3PH | Stable | No | No | FLT14-3PH | Stable | No | No | FLT13-3PH | Stable | No | No |
| FLT15-3PH | Stable | No | No | FLT15-3PH | Stable | No | No | FLT14-3PH | Stable | No | No |
| FLT16-3PH | Stable | No | No | FLT16-3PH | Stable | No | No | FLT15-3PH | Stable | No | No |
| FLT17-3PH | Stable | No | No | FLT17-3PH | Stable | No | No | FLT16-3PH | Stable | No | No |
| FLT19-3PH | Stable | No | No | FLT19-3PH | Stable | No | No | FLT17-3PH | Stable | No | No |
| FLT20-3PH | Stable | No | No | FLT20-3PH | Stable | No | No | FLT19-3PH | Stable | No | No |
| FLT21-3PH | Stable | No | No | FLT21-3PH | Stable | No | No | FLT20-3PH | Stable | No | No |
| FLT22-3PH | Stable | No | No | FLT22-3PH | Stable | No | No | FLT21-3PH | Stable | No | No |
| FLT23-3PH | Stable | No | No | FLT23-3PH | Stable | No | No | FLT22-3PH | Stable | No | No |
| FLT24-3PH | Stable | No | No | FLT25-3PH | Stable | No | No | FLT23-3PH | Stable | No | No |
| FLT25-3PH | Stable | No | No | FLT26-3PH | Stable | No | No | FLT25-3PH | Stable | No | No |
| FLT26-3PH | Stable | No | No | FLT27-3PH | Stable | No | No | FLT26-3PH | Stable | No | No |
| FLT27-3PH | Stable | No | No | FLT28-3PH | Stable | No | No | FLT27-3PH | Stable | No | No |
| FLT28-3PH | Stable | No | No | FLT29-3PH | Stable | No | No | FLT28-3PH | Stable | No | No |
| FLT29-3PH | Stable | No | No | FLT30-3PH | Stable | No | No | FLT29-3PH | Stable | No | No |
| FLT30-3PH | Stable | No | No | FLT31-3PH | Stable | No | No | FLT30-3PH | Stable | No | No |

| Fault File Name | 16WP Case | | | Fault File Name | 17SP Case | | | Fault File Name | 25SP Case | | |
|-----------------|-----------|-----------------------|------------------------|-----------------|-----------|-----------------------|------------------------|-----------------|-----------|-----------------------|------------------------|
| | Stable? | Low Voltage Violation | High Voltage Violation | | Stable? | Low Voltage Violation | High Voltage Violation | | Stable? | Low Voltage Violation | High Voltage Violation |
| FLT31-3PH | Stable | No | No | FLT33-3PH | Stable | No | No | FLT31-3PH | Stable | No | No |
| FLT33-3PH | Stable | No | No | FLT34-3PH | Stable | No | No | FLT33-3PH | Stable | No | No |
| FLT34-3PH | Stable | No | No | FLT35-3PH | Stable | No | No | FLT34-3PH | Stable | No | No |
| FLT35-3PH | Stable | No | No | FLT36-3PH | Stable | No | No | FLT35-3PH | Stable | No | No |
| FLT36-3PH | Stable | No | No | FLT37-3PH | Stable | No | No | FLT36-3PH | Stable | No | No |
| FLT37-3PH | Stable | No | No | FLT38-3PH | Stable | No | No | FLT37-3PH | Stable | No | No |
| FLT38-3PH | Stable | No | No | FLT40-PO | Stable | No | No | FLT38-3PH | Stable | No | No |
| FLT39-PO | Stable | No | No | FLT41-PO | Stable | No | No | FLT40-PO | Stable | No | No |
| FLT44-PO | Stable | No | No | FLT43-PO | Stable | No | No | FLT41-PO | Stable | No | No |
| FLT45-SB | Stable | No | No | FLT44-PO | Stable | No | No | FLT43-PO | Stable | No | No |
| FLT46-SB | Stable | No | No | FLT45-SB | Stable | No | No | FLT44-PO | Stable | No | No |
| FLT47-SB | Stable | No | No | FLT46-SB | Stable | No | No | FLT45-SB | Stable | No | No |
| FLT48-PO | Stable | No | No | FLT48-PO | Stable | No | No | FLT46-SB | Stable | No | No |
| FLT49-SB | Stable | No | No | FLT49-SB | Stable | No | No | FLT48-PO | Stable | No | No |
| FLT50-SB | Stable | No | No | FLT50-SB | Stable | No | No | FLT49-SB | Stable | No | No |
| FLT51-SB | Stable | No | No | FLT51-SB | Stable | No | No | FLT50-SB | Stable | No | No |
| | | | | | | | | FLT51-SB | Stable | No | No |

Figure 2-1 shows an example for the response of one studied generator following fault FLT01-3PH for 2016 Winter Peak case. The machine speed, active and reactive power output and terminal voltage are plotted to show the generator response.

All the simulation plots are included in Appendix B.




Figure 2-1: GEN-2014-037 Response Following Fault FLT01-3PH for 2016 Winter Peak Case

As shown in the results summary table, fault FLT08-3PH in all three seasons showed high voltage violations. Figure 2-2 shows the plots. Those bus voltages have little spike right after fault clearing and the peak values are slightly over 1.2 p.u. Pre-project case was created for the 2016 Winter Peak case which presents the most voltage violations. The simulation results show no over voltage violations for the pre-project case; therefore, it can be concluded that this high voltage violations are caused by the studied generators.






Figure 2-2 High Voltage Violation Plots

For FLT04-3PH and FLT06-3PH, the studied generators showed undamped oscillations as plotted in Figure 2-3. Several pre-queued projects also showed undamped oscillations similar to the studied generators. A couple of bus voltages and machine responses also showed wiggling response following these two faults for all three seasons. Figure 2-4 presents an example for bus voltage.




Figure 2-3 GEN-2014-037 Response for FLT04-3PH 2016 Winter Peak




Figure 2-4 Bus Voltage and Machine Speed Wiggling Example

Pre-project cases were created for all three study season to simulate the above two faults. The simulation results are shown in Table 2-3. For FLT06-3PH, undamped oscillations were observed for all the pre-project study cases. For FLT04-3PH, only 2016 winter peak pre-project case presents undamped oscillation.

Table 2-3 Pre-Project Cases Simulation Results

| | 2016 WP Pre-Project | 2017 SP Pre-Project | 2025SP Pre-Project |
|-----------|--------------------------------|--------------------------------|-------------------------------|
| FLT04-3PH | Undamped Oscillation | Stable | Stable |
| FLT06-3PH | Undamped Oscillation | Undamped Oscillation | Undamped Oscillation |

In discussions with SPP since FLT04-3PH, FLT06-3PH, and FLT 08-3PH are double circuit faults, the mitigation will be the curtailment of generation in the area.

For the rest of the studied faults, the simulation results showed no instability problems and no voltage violations for all three seasons.

3 SHORT CIRCUIT ANALYSIS

Short circuit analysis was performed on the 2017 Summer Peak and 2025 Summer Peak power flow cases using the PSS/E program. Only three-phase symmetrical fault current levels were calculated at up to five buses away from the point of interconnection.

Table 3-1 tabulates all the three-phase fault current levels, and the calculated values were listed here for SPP's reference.

Table 3-1: Three-Phase Fault Currents

| 2017 SP | | | 2025 SP | | |
|---------|--------------------|----------|---------|--------------------|----------|
| Number | Name | 3PH(Amp) | Number | Name | 3PH(Amp) |
| 599041 | DEWIND-HV 115.00 | 6953.8 | 599041 | DEWIND-HV 115.00 | 6926.2 |
| 524290 | WILDOR2_JUS6230.00 | 6546.3 | 524290 | WILDOR2_JUS6230.00 | 6520.6 |
| 523267 | PRINGLE 6230.00 | 4301.9 | 523267 | PRINGLE 6230.00 | 4310.4 |
| 515590 | PALDR2W7 345.00 | 11765.0 | 515590 | PALDR2W7 345.00 | 12025.0 |
| 524295 | SPNSPUR_WND134.500 | 14590.4 | 524295 | SPNSPUR_WND134.500 | 14414.3 |
| 515592 | PALDRW21 34.500 | 8079.7 | 515592 | PALDRW21 34.500 | 8103.8 |
| 515593 | PALDRWT1 13.200 | 62352.1 | 515593 | PALDRWT1 13.200 | 62616.5 |
| 515594 | PALDRWT2 13.800 | 13911.7 | 515594 | PALDRWT2 13.800 | 13945.9 |
| 523277 | VALERO 3115.00 | 9706.0 | 523277 | VALERO 3115.00 | 9738.2 |
| 515599 | NBUFFRG7 345.00 | 8163.9 | 515599 | NBUFFRG7 345.00 | 8628.6 |
| 584210 | GEN-2014-037345.00 | 10690.0 | 584210 | GEN-2014-037345.00 | 10823.7 |
| 584211 | G14-037XFMR134.500 | 15970.5 | 584211 | G14-037XFMR134.500 | 16025.2 |
| 584212 | G14-037-GSU134.500 | 15230.7 | 584212 | G14-037-GSU134.500 | 15279.8 |
| 584213 | G14-037-GEN10.6900 | 717591.2 | 584213 | G14-037-GEN10.6900 | 719673.4 |
| 584214 | G14-037XFMR234.500 | 17072.8 | 584214 | G14-037XFMR234.500 | 17131.2 |
| 584215 | G14-037-GSU234.500 | 16916.3 | 584215 | G14-037-GSU234.500 | 16973.0 |
| 584216 | G14-037-GEN20.6900 | 813607.2 | 584216 | G14-037-GEN20.6900 | 816052.4 |
| 531481 | HUGOTON3 115.00 | 5941.1 | 531481 | HUGOTON3 115.00 | 5956.9 |
| 581148 | GEN-2011-022345.00 | 9121.3 | 581148 | GEN-2011-022345.00 | 9209.1 |
| 581149 | G11-022XFMR134.500 | 18249.4 | 581149 | G11-022XFMR134.500 | 18280.2 |
| 581150 | G11-022XFMR234.500 | 18142.2 | 581150 | G11-022XFMR234.500 | 18173.4 |
| 581151 | G11-022-GSU134.500 | 17453.9 | 581151 | G11-022-GSU134.500 | 17479.4 |
| 581152 | G11-022-GSU234.500 | 17036.4 | 581152 | G11-022-GSU234.500 | 17060.5 |
| 581153 | G11-022-GEN10.6900 | 754003.9 | 581153 | G11-022-GEN10.6900 | 754593.8 |
| 581154 | G11-022-GEN20.6900 | 740239.3 | 581154 | G11-022-GEN20.6900 | 740801.1 |
| 523301 | MOORE_E 113.200 | 12874.3 | 523301 | MOORE_E 113.200 | 12670.2 |
| 523302 | MOORE_TR1 113.200 | 20042.4 | 523302 | MOORE_TR1 113.200 | 20261.1 |
| 523304 | MOORE_W 3115.00 | 10665.9 | 523304 | MOORE_W 3115.00 | 10716.2 |
| 515591 | PALDRW11 34.500 | 32240.2 | 515591 | PALDRW11 34.500 | 32417.0 |
| 523308 | MOORE_E 3115.00 | 10665.9 | 523308 | MOORE_E 3115.00 | 10716.2 |
| 523309 | MOORE_CNTY 6230.00 | 6672.9 | 523309 | MOORE_CNTY 6230.00 | 6640.2 |
| 524296 | SPNSPUR_WND7345.00 | 4427.3 | 524296 | SPNSPUR_WND7345.00 | 4389.5 |
| 515634 | PALDR1W7 345.00 | 10132.3 | 515634 | PALDR1W7 345.00 | 10328.0 |

| 2017 SP | | | 2025 SP | | |
|---------|--------------------|-----------|---------|--------------------|-----------|
| Number | Name | 3PH(Amp) | Number | Name | 3PH(Amp) |
| 531510 | WALKTAP3 115.00 | 10290.3 | 531510 | WALKTAP3 115.00 | 10360.3 |
| 531511 | WALKETP-T 13.800 | 26693.4 | 531511 | WALKETP-T 13.800 | 26725.7 |
| 531512 | WALKTAP7 345.00 | 7717.2 | 531512 | WALKTAP7 345.00 | 7815.1 |
| 599105 | SPNSPUR-CB1 34.500 | 13396.6 | 599105 | SPNSPUR-CB1 34.500 | 13233.8 |
| 573509 | G08-047-GSU234.500 | 6838.8 | 573509 | G08-047-GSU234.500 | 6853.0 |
| 573510 | G08-047-GEN20.6900 | 271080.4 | 573510 | G08-047-GEN20.6900 | 271230.4 |
| 523853 | FINNEY 7345.00 | 10409.7 | 523853 | FINNEY 7345.00 | 10524.0 |
| 583760 | GEN-2013-030345.00 | 10799.3 | 583760 | GEN-2013-030345.00 | 11017.8 |
| 583761 | G13-030XFMR134.500 | 22204.6 | 583761 | G13-030XFMR134.500 | 22356.8 |
| 583762 | G13-030-GSU134.500 | 22042.4 | 583762 | G13-030-GSU134.500 | 22189.8 |
| 583763 | G13-030-GEN10.5750 | 1314338.0 | 583763 | G13-030-GEN10.5750 | 1322335.4 |
| 583764 | G13-030XFMR234.500 | 21956.3 | 583764 | G13-030XFMR234.500 | 22107.6 |
| 583765 | G13-030-GSU234.500 | 21610.5 | 583765 | G13-030-GSU234.500 | 21753.0 |
| 583766 | G13-030-GEN20.5750 | 1303725.0 | 583766 | G13-030-GEN20.5750 | 1311586.1 |
| 523866 | CHANNING 134.500 | 6178.2 | 523866 | CHANNING 134.500 | 6107.1 |
| 523869 | CHAN/TASCOS6230.00 | 3843.9 | 523869 | CHAN/TASCOS6230.00 | 3814.9 |
| 523115 | BUFF_DN_TR2113.200 | 513957.3 | 523115 | BUFF_DN_TR2113.200 | 520329.2 |
| 525458 | NEWHART_TR2113.200 | 16867.6 | 525458 | NEWHART_TR2113.200 | 16709.8 |
| 525459 | NEWHART_TR1113.200 | 16867.6 | 525459 | NEWHART_TR1113.200 | 16709.8 |
| 525460 | NEWHART 3115.00 | 14722.7 | 525460 | NEWHART 3115.00 | 14707.5 |
| 525461 | NEWHART 6230.00 | 10814.7 | 525461 | NEWHART 6230.00 | 10866.0 |
| 539800 | CLARKCOUNTY7345.00 | 11517.4 | 539800 | CLARKCOUNTY7345.00 | 11667.6 |
| 539801 | THISTLE7 345.00 | 14952.6 | 539801 | THISTLE7 345.00 | 15476.2 |
| 539802 | THISTLE T1 13.800 | 7898.3 | 539802 | THISTLE T1 13.800 | 7947.7 |
| 539804 | THISTLE4 138.00 | 16229.7 | 539804 | THISTLE4 138.00 | 16626.0 |
| 599068 | NTHBUF_XFMR134.500 | 20330.2 | 599068 | NTHBUF_XFMR134.500 | 20680.1 |
| 523957 | POTTER_TR 113.200 | 6637.3 | 523957 | POTTER_TR 113.200 | 6655.4 |
| 523959 | POTTER_CO 6230.00 | 20146.9 | 523959 | POTTER_CO 6230.00 | 20171.2 |
| 523961 | POTTER_CO 7345.00 | 7361.7 | 523961 | POTTER_CO 7345.00 | 7330.8 |
| 599071 | NTHBUF_XFMR234.500 | 20290.9 | 599071 | NTHBUF_XFMR234.500 | 20638.7 |
| 523186 | SPEARMAN 3115.00 | 8930.1 | 523186 | SPEARMAN 3115.00 | 8958.2 |
| 523973 | HARRNGTON3 124.000 | 112694.2 | 523973 | HARRNGTON3 124.000 | 113803.8 |
| 523977 | HARRNG_WST 6230.00 | 26083.1 | 523977 | HARRNG_WST 6230.00 | 26300.0 |
| 523978 | HARRNG_MID 6230.00 | 26083.1 | 523978 | HARRNG_MID 6230.00 | 26300.0 |
| 523979 | HARRNG_EST 6230.00 | 26083.1 | 523979 | HARRNG_EST 6230.00 | 26300.0 |
| 599074 | NTHBUF_EHV2 345.00 | 6332.1 | 599074 | NTHBUF_EHV2 345.00 | 6604.4 |
| 515795 | WWDEHV31 13.800 | 61117.3 | 515795 | WWDEHV31 13.800 | 61898.0 |
| 515799 | WWDEHV21 13.800 | 60747.4 | 515799 | WWDEHV21 13.800 | 61545.1 |
| 579296 | G07-046-XF-134.500 | 13866.9 | 579296 | G07-046-XF-134.500 | 13950.6 |
| 514785 | WOODWRD4 138.00 | 20111.0 | 514785 | WOODWRD4 138.00 | 20792.2 |
| 579299 | G07-046-XF-234.500 | 11210.5 | 579299 | G07-046-XF-234.500 | 11276.5 |
| 524007 | ROLLHILLS 3115.00 | 19015.1 | 524007 | ROLLHILLS 3115.00 | 19065.4 |
| 524008 | ROLHILLS_TR113.200 | 17095.9 | 524008 | ROLHILLS_TR113.200 | 17048.0 |

| 2017 SP | | | 2025 SP | | |
|---------|--------------------|----------|---------|--------------------|----------|
| Number | Name | 3PH(Amp) | Number | Name | 3PH(Amp) |
| 524010 | ROLLHILLS 6230.00 | 19266.9 | 524010 | ROLLHILLS 6230.00 | 19343.7 |
| 514796 | IODINE-4 138.00 | 7313.2 | 514796 | IODINE-4 138.00 | 7406.0 |
| 576398 | G10-014XFMR134.500 | 16603.8 | 576398 | G10-014XFMR134.500 | 16622.4 |
| 531465 | SETAB 7 345.00 | 7186.0 | 531465 | SETAB 7 345.00 | 7262.0 |
| 531501 | BUCKNER7 345.00 | 9678.3 | 531501 | BUCKNER7 345.00 | 9762.4 |
| 539654 | CIM-PLT3 115.00 | 7250.9 | 539654 | CIM-PLT3 115.00 | 7269.7 |
| 584980 | GEN-2015-060138.00 | 5765.7 | 584980 | GEN-2015-060138.00 | 5817.5 |
| 523140 | TXFARMS 3115.00 | 5108.7 | 523140 | TXFARMS 3115.00 | 5104.4 |
| 579375 | G06-044GSU2A34.500 | 17167.9 | 579375 | G06-044GSU2A34.500 | 17217.1 |
| 523087 | TC-TXCOUNTY134.500 | 4627.9 | 523087 | TC-TXCOUNTY134.500 | 4628.1 |
| 525832 | TUCO_INT 7345.00 | 10160.2 | 525832 | TUCO_INT 7345.00 | 12469.4 |
| 579369 | G06-044GSU1B34.500 | 17972.7 | 579369 | G06-044GSU1B34.500 | 17990.5 |
| 579370 | G06-044-MV1A115.00 | 8311.3 | 579370 | G06-044-MV1A115.00 | 8328.8 |
| 579371 | G06-044-XF1A34.500 | 14231.2 | 579371 | G06-044-XF1A34.500 | 14240.7 |
| 579374 | G06-044-XF2A34.500 | 17376.5 | 579374 | G06-044-XF2A34.500 | 17407.8 |
| 515375 | WWRDEHV7 345.00 | 17556.9 | 515375 | WWRDEHV7 345.00 | 20066.1 |
| 515376 | WWRDEHV4 138.00 | 24267.7 | 515376 | WWRDEHV4 138.00 | 25444.1 |
| 579377 | G06-044-MV2B115.00 | 10350.6 | 579377 | G06-044-MV2B115.00 | 10374.8 |
| 579378 | G06-044-XF2B34.500 | 22774.0 | 579378 | G06-044-XF2B34.500 | 22790.0 |
| 531252 | WALKMYR1 13.800 | 16033.9 | 531252 | WALKMYR1 13.800 | 16025.2 |
| 515394 | KEENAN 4 138.00 | 8279.5 | 515394 | KEENAN 4 138.00 | 8425.6 |
| 523147 | WADE 3115.00 | 3569.8 | 523147 | WADE 3115.00 | 3567.0 |
| 515398 | OUSPRT 4 138.00 | 9107.5 | 515398 | OUSPRT 4 138.00 | 9284.2 |
| 523085 | TC-TXCN_TR1113.200 | 5755.0 | 523085 | TC-TXCN_TR1113.200 | 5758.7 |
| 523086 | TC-TXCN_TR2113.200 | 5756.0 | 523086 | TC-TXCN_TR2113.200 | 5759.8 |
| 515407 | TATONGA7 345.00 | 10659.2 | 515407 | TATONGA7 345.00 | 16336.8 |
| 523089 | TC-TXCOUNTY269.000 | 8196.7 | 523089 | TC-TXCOUNTY269.000 | 8325.2 |
| 523090 | TEXAS_CNTY 3115.00 | 8724.8 | 523090 | TEXAS_CNTY 3115.00 | 8713.2 |
| 523091 | HITCHLD_TR0113.200 | 32988.4 | 523091 | HITCHLD_TR0113.200 | 33011.3 |
| 523092 | HITCHLD_TR1113.200 | 20460.4 | 523092 | HITCHLD_TR1113.200 | 21289.1 |
| 523093 | HITCHLAND 3115.00 | 17430.1 | 523093 | HITCHLAND 3115.00 | 17390.5 |
| 523094 | HITCHLD_TR2113.200 | 22554.6 | 523094 | HITCHLD_TR2113.200 | 22565.5 |
| 523095 | HITCHLAND 6230.00 | 14683.8 | 523095 | HITCHLAND 6230.00 | 14808.3 |
| 523097 | HITCHLAND 7345.00 | 15018.9 | 523097 | HITCHLAND 7345.00 | 15255.4 |
| 523098 | HITCHLD_TR4113.200 | 22108.3 | 523098 | HITCHLD_TR4113.200 | 21289.1 |
| 523099 | TC-WHITING 3115.00 | 2202.4 | 523099 | TC-WHITING 3115.00 | 2208.5 |
| 523101 | NOBLE_WND 7345.00 | 14957.0 | 523101 | NOBLE_WND 7345.00 | 15191.7 |
| 523102 | NOBLE_TR 113.800 | 32327.6 | 523102 | NOBLE_TR 113.800 | 32403.5 |
| 523103 | NOBLE_WND 3115.00 | 10526.2 | 523103 | NOBLE_WND 3115.00 | 10569.4 |
| 523106 | TXPHSF 3115.00 | 3954.2 | 523106 | TXPHSF 3115.00 | 3978.4 |
| 523107 | NOVUS_WND 14.1600 | 171592.4 | 523107 | NOVUS_WND 14.1600 | 171723.0 |
| 523109 | NOVUS1 134.500 | 17972.7 | 523109 | NOVUS1 134.500 | 17990.5 |
| 523110 | NOVUS1_TR1 113.800 | 535233.4 | 523110 | NOVUS1_TR1 113.800 | 544750.5 |

| 2017 SP | | | 2025 SP | | |
|---------|--------------------|----------|---------|--------------------|----------|
| Number | Name | 3PH(Amp) | Number | Name | 3PH(Amp) |
| 523111 | NOVUS1 3115.00 | 19407.0 | 523111 | NOVUS1 3115.00 | 19504.8 |
| 523112 | NOVUS1 7345.00 | 14752.3 | 523112 | NOVUS1 7345.00 | 14980.0 |
| 523113 | TC-MCMURRY 3115.00 | 6629.6 | 523113 | TC-MCMURRY 3115.00 | 6629.7 |
| 523114 | BUFF_DN_TR1113.200 | 518520.3 | 523114 | BUFF_DN_TR1113.200 | 524991.8 |
| 524263 | BSHLND_TR1 113.200 | 20292.5 | 524263 | BSHLND_TR1 113.200 | 20310.3 |
| 523116 | BUFF_DUNES1134.500 | 26495.0 | 523116 | BUFF_DUNES1134.500 | 26549.6 |
| 523118 | BUFF_DUNES 7345.00 | 6299.3 | 523118 | BUFF_DUNES 7345.00 | 6345.4 |
| 523120 | COLE 3115.00 | 4104.5 | 523120 | COLE 3115.00 | 4108.5 |
| 523125 | NBLWND-CB2 134.500 | 8116.9 | 523125 | NBLWND-CB2 134.500 | 8123.6 |
| 523127 | NBLWND-LV1 134.500 | 8355.3 | 523127 | NBLWND-LV1 134.500 | 8363.8 |
| 523128 | NBLWND-LV2 134.500 | 10006.5 | 523128 | NBLWND-LV2 134.500 | 10020.0 |
| 523129 | NBLWND-LV3 134.500 | 9500.2 | 523129 | NBLWND-LV3 134.500 | 9511.3 |
| 523130 | NBLWND-HV2 3115.00 | 5145.3 | 523130 | NBLWND-HV2 3115.00 | 5157.3 |
| 523131 | NBLWND-HV3 3115.00 | 7943.6 | 523131 | NBLWND-HV3 3115.00 | 7969.7 |
| 560000 | G11-14-TAP 345.00 | 12639.2 | 560000 | G11-14-TAP 345.00 | 13091.7 |
| 515458 | BORDER 7345.00 | 5040.1 | 515458 | BORDER 7345.00 | 5167.4 |
| 582019 | GEN-2011-019345.00 | 17556.9 | 582019 | GEN-2011-019345.00 | 20066.1 |
| 582020 | GEN-2011-020345.00 | 17556.9 | 582020 | GEN-2011-020345.00 | 20066.1 |
| 573505 | G08-047-GSU134.500 | 29576.0 | 573505 | G08-047-GSU134.500 | 29707.7 |
| 560010 | G14-037-TAP 345.00 | 14733.7 | 560010 | G14-037-TAP 345.00 | 14986.0 |
| 576395 | GEN-2010-014345.00 | 11100.7 | 576395 | GEN-2010-014345.00 | 11229.0 |
| 576396 | G10-014-XFMR115.00 | 13147.4 | 576396 | G10-014-XFMR115.00 | 13204.9 |
| 576397 | G10-014-XF-1115.00 | 9181.6 | 576397 | G10-014-XF-1115.00 | 9209.7 |
| 599950 | LAMAR7 345.00 | 2445.0 | 599950 | LAMAR7 345.00 | 2458.8 |
| 523151 | OCHLTRE_TR1113.200 | 10320.7 | 523151 | OCHLTRE_TR1113.200 | 10266.8 |
| 576408 | G10-014XFMR234.500 | 18446.4 | 576408 | G10-014XFMR234.500 | 18470.2 |
| 523154 | OCHILTREE 3115.00 | 5860.4 | 523154 | OCHILTREE 3115.00 | 5854.0 |
| 523155 | OCHILTREE 6230.00 | 4197.0 | 523155 | OCHILTREE 6230.00 | 4200.3 |
| 523158 | PERRYTON 3115.00 | 5590.8 | 523158 | PERRYTON 3115.00 | 5584.5 |
| 576407 | G10-014-XF-2115.00 | 12390.7 | 576407 | G10-014-XF-2115.00 | 12441.8 |
| 523160 | FRISCO_WND 3115.00 | 6953.8 | 523160 | FRISCO_WND 3115.00 | 6926.2 |
| 562075 | G11-051-TAP 345.00 | 11948.6 | 562075 | G11-051-TAP 345.00 | 17039.7 |
| 525213 | SWISHER 6230.00 | 10315.7 | 525213 | SWISHER 6230.00 | 10419.0 |
| 560033 | G1524&G1525T345.00 | 19095.1 | 560033 | G1524&G1525T345.00 | 19759.1 |
| 523174 | GOODWELLWND3115.00 | 6570.9 | 523174 | GOODWELLWND3115.00 | 6600.9 |
| 523175 | LASLEY 3115.00 | 5643.8 | 523175 | LASLEY 3115.00 | 5592.8 |
| 523177 | RB-SPURLOCK3115.00 | 5642.5 | 523177 | RB-SPURLOCK3115.00 | 5610.6 |
| 583090 | G1149&G1504 345.00 | 4619.4 | 583090 | G1149&G1504 345.00 | 4723.4 |
| 578547 | G10-001-GSU234.500 | 16781.3 | 578547 | G10-001-GSU234.500 | 16835.8 |
| 523195 | HANSFORD 3115.00 | 10214.1 | 523195 | HANSFORD 3115.00 | 10227.6 |
| 523197 | EXCELN4-HV23115.00 | 4722.6 | 523197 | EXCELN4-HV23115.00 | 4733.2 |
| 583110 | GEN-2011-051345.00 | 11948.6 | 583110 | GEN-2011-051345.00 | 17039.7 |
| 531404 | WALKMYR2 69.000 | 8227.9 | 531404 | WALKMYR2 69.000 | 8322.2 |

| 2017 SP | | | 2025 SP | | |
|---------|--------------------|----------|---------|--------------------|----------|
| Number | Name | 3PH(Amp) | Number | Name | 3PH(Amp) |
| 531405 | WALKMYR3 115.00 | 9889.6 | 531405 | WALKMYR3 115.00 | 9954.5 |
| 523216 | RB-HOGUE 3115.00 | 3636.2 | 523216 | RB-HOGUE 3115.00 | 3578.7 |
| 523256 | ETTER 3115.00 | 5245.0 | 523256 | ETTER 3115.00 | 5207.0 |
| 523221 | XIT_INTG 6230.00 | 2608.2 | 523221 | XIT_INTG 6230.00 | 2574.1 |
| 581113 | G11-014XFMR134.500 | 13790.7 | 581113 | G11-014XFMR134.500 | 13930.3 |
| 579412 | G08-051-GSU234.500 | 16068.7 | 579412 | G08-051-GSU234.500 | 15866.4 |
| 524623 | DEAFSMITH 6230.00 | 7732.1 | 524623 | DEAFSMITH 6230.00 | 7854.4 |
| 585180 | GEN-2015-081345.00 | 10459.4 | 585180 | GEN-2015-081345.00 | 14085.3 |
| 531450 | HOLCTER1 13.800 | 18136.0 | 531450 | HOLCTER1 13.800 | 18291.9 |
| 515554 | BVRCNTY7 345.00 | 13760.2 | 515554 | BVRCNTY7 345.00 | 14111.8 |
| 582119 | G11-019XFMR134.500 | 37552.4 | 582119 | G11-019XFMR134.500 | 38292.8 |
| 582120 | G11-020XFMR134.500 | 37570.8 | 582120 | G11-020XFMR134.500 | 38311.1 |
| 524266 | BUSHLAND 3115.00 | 9120.3 | 524266 | BUSHLAND 3115.00 | 9153.6 |
| 524267 | BUSHLAND 6230.00 | 9507.9 | 524267 | BUSHLAND 6230.00 | 9487.0 |
| 578542 | GEN-2010-001345.00 | 11360.6 | 578542 | GEN-2010-001345.00 | 11603.9 |
| 578543 | G10-001XFMR134.500 | 17052.5 | 578543 | G10-001XFMR134.500 | 17109.9 |
| 578544 | G10-001-GSU134.500 | 16930.5 | 578544 | G10-001-GSU134.500 | 16986.1 |
| 578545 | G10-001-GEN10.6900 | 672498.4 | 578545 | G10-001-GEN10.6900 | 673290.0 |
| 578546 | G10-001XFMR234.500 | 17009.1 | 578546 | G10-001XFMR234.500 | 17066.7 |
| 579411 | G08-051XFMR234.500 | 16639.5 | 579411 | G08-051XFMR234.500 | 16430.9 |
| 578548 | G10-001-GEN20.6900 | 668172.0 | 578548 | G10-001-GEN20.6900 | 668953.2 |
| 531448 | HOLCOMB3 115.00 | 22230.9 | 531448 | HOLCOMB3 115.00 | 22412.8 |
| 525481 | PLANT_X 6230.00 | 22368.2 | 525481 | PLANT_X 6230.00 | 23630.6 |
| 581112 | GEN-2011-014345.00 | 11389.6 | 581112 | GEN-2011-014345.00 | 11762.8 |
| 531449 | HOLCOMB7 345.00 | 10500.3 | 531449 | HOLCOMB7 345.00 | 10615.9 |
| 581114 | G11-014-GSU134.500 | 13186.3 | 581114 | G11-014-GSU134.500 | 13316.1 |
| 581117 | G11-014XFMR234.500 | 12834.4 | 581117 | G11-014XFMR234.500 | 12966.1 |
| 581118 | G11-014-GSU234.500 | 12101.2 | 581118 | G11-014-GSU234.500 | 12221.7 |

4 POWER FACTOR ANALYSIS

Since the studied project is a renewable energy project, power factor analysis was performed on three provided cluster scenarios upon SPP's request.

4.1 POWER FACTOR ANALYSIS METHODOLOGY

Power Factor Analysis was performed for the studied wind farm under system intact and contingency conditions. All N-1, three phase stability faults shown in Table 2-1 were analyzed as power flow contingencies. The power factor requirements for the wind farm were determined to maintain the voltage at the POI to the schedule voltage which is the higher of the POI voltage in the provided base case or 1.0 per unit. Fictitious var generator was added to the studied wind farm to maintain the scheduled voltage following all studied contingencies. The MW and Mvar injections from the studied wind farm at the POI were recorded and the power factors were calculated for all contingencies. The most lagging and most leading power factors determine the minimum power factor range capability required for the studied wind farm.

If more than one studied project share the same POI, the projects were grouped together and common power factor requirements were determined for this group of studied projects. With this method, none of the studied projects is required to provide more or less than its fair share of the reactive power requirements at the same POI. If a prior-queued project is connected at the same POI as the studied project, the prior-queued project was not grouped with the studied project since its reactive power requirements was determined in previous studies. However, the voltage schedules of the prior-queued project and the studied project at the same POI were coordinated and the local existing capacitor banks were set to their maximum capability, if necessary.

Per FERC and SPP requirements, if the power factor needed to maintain the scheduled voltage is less than 0.95 lagging or leading, the requirements is limited to 0.95 lagging or leading.

If the required power factor at the POI is beyond the capability of the studied wind turbine, the approximate size of the additional capacitors were determined.

4.2 STUDY RESULTS

Power Factor Analysis was performed to ensure the studied project meets FERC and SPP power factor requirements for wind farm interconnections.

Table 4-1 summarizes the power factor analysis results. The detailed power factor analysis results for each studied contingency are provided in Appendix C.

There are several cases which the wind project was observed to require less than 95% power factor (providing vars) at the Point of Interconnection. Per SPP and FERC requirements, the generating facility shall be designed to meet the requirement of 95% lagging (providing vars) and 95% leading (absorbing vars) to the Point of Interconnection.

These capacitor bank sizes are only estimates based on the information provided by the Interconnection Customer for its collector system design. Final needs will be based on final designs of the collector system determined by the Interconnection Customer to meet the power factor requirement.

Table 4-1 Power Factor Analysis Results

| Request | Size | Generator | POI | Scenario | PF Analysis Worst Scenario | | Final PF Requirement | |
|--------------|------|-------------------|---|----------|----------------------------|----------------------|----------------------|----------------------|
| | (MW) | Model | | | Leading ¹ | Lagging ² | Leading ¹ | Lagging ² |
| GEN-2014-037 | 200 | Vestas V110 2.0MW | Tap on Hitchland to Beaver County 345kV (Optima 345kV – 560010) | 16WP | N/A | 0.506 | 1.0 | 0.95 |
| | | | | 17SP | N/A | 0.721 | 1.0 | 0.95 |
| | | | | 25SP | 1.0 | 0.780 | 1.0 | 0.95 |

Notes:

1. Leading is when the generator is absorbing reactive power from the transmission grid.
2. Lagging is when the generator is providing reactive power to the transmission grid.

5 LOW WIND/NO WIND ANALYSIS

In this study, ABB investigated the GEN-2014-037 project for low wind/no wind conditions, since the interconnected wind farm is connected at a 345kV bus.

5.1 LOW/NO WIND ANALYSIS METHODOLOGY

Low wind/No wind analysis is performed to determine the required shunt reactor size at the study project substation high side bus to bring the MVar flow into the POI down to approximately zero.

For each studied scenario, the studied wind generator and capacitor bank (none in this case) was switched out of service with the collector system as modeled remaining in service. The resulting reactive power injection into the transmission network coming from the capacitance of the project's transmission lines and collector cables was measured. Then, the required shunt reactor size was calculated to bring the MVar flow into the POI down to approximately zero.

5.2 STUDY RESULTS

Table 5-1 summarizes the Low/No Wind analysis results. It is shown that 13.55 MVar shunt reactor at the substation high side bus (560010) is required to bring the MVar flow in the POI down to approximately zero under low/no wind conditions for all three studied seasons. This reactor bank size is approximate to be finalized during final facility and collector system design.

Table 5-1 Low/No Wind Analysis Results

| Scenario | Reactive Power Injection at POI (MVar) | Bus 560010 Volt (pu) | Required Shunt Reactor (MVar) |
|----------|--|----------------------|-------------------------------|
| 16WP | 13.6 | 1.0018 | 13.55 |
| 17SP | 13.6 | 1.0042 | 13.49 |
| 25SP | 13.7 | 1.0057 | 13.55 |

6 CONCLUSIONS

Southwest Power Pool (SPP) has commissioned ABB Inc., to perform a Definitive Impact Study for DISIS-2015-002_1 (Group 02) which includes generation interconnection request GEN-2014-037 (200 MW wind farm connected on the tap from Hitchland to Beaver County 345kV line).

| Request | Size (MW) | Generator Model | POI |
|--------------|-----------|-------------------|---|
| GEN-2014-037 | 200.0 | Vestas V110 2.0MW | Tap on Hitchland to Beaver County 345kV (Optima 345kV – 560010) |

The objective of this study is to evaluate the impact of project GEN-2014-037 on the existing and future planning system. The study is performed on three system scenarios provided by SPP:

- 2016 Winter Peak Case
- 2017 Summer Peak Case
- 2025 Summer Peak Case

Fault FLT08-3PH in all three seasons showed high voltage violations. Those bus voltages have little spike right after fault clearing and the peak values are slightly over 1.2 p.u. Pre-project case was created for the 2016 Winter Peak case which presents the most the voltage violations. The simulation results show no over voltage violations for the pre-project case; therefore, it can be concluded that this high voltage violations are caused by the studied generators.

For FLT04-3PH and FLT06-3PH, the studied generators and several pre-queued projects showed undamped oscillations. And a couple of bus voltages and machine responses also showed wiggling response following these two faults for all three seasons. Pre-project cases were created for all three study season to simulate the above two faults. For FLT06-3PH, undamped oscillations were observed for all the pre-project study cases. For FLT04-3PH, only 2016 winter peak pre-project case presents undamped oscillation. In discussions with SPP since FLT04-3PH, FLT06-3PH, and FLT 08-3PH are double circuit faults, the mitigation will be the curtailment of generation in the area.

For the rest of the studied faults, the simulation results showed no instability problems and no voltage violations for all three seasons. All the simulation results were summarized in Table 2-2.

System short-circuit current levels at up to five buses away from the point of interconnection were calculated and tabulated for SPP's reference.

Power Factor Analysis was performed to ensure the studied project meets FERC and SPP power factor requirements for wind farm interconnections. The results show significant need for reactive power from the study project following the critical contingencies. The proposed GEN-2014-037 need to design their facility to meet the SPP pro-forma 95% lagging (providing vars) and 95% leading (absorbing vars) power factor requirements at the Point of Interconnection.

The Low/No Wind analysis shows that a 13.55 MVAR shunt reactor is required to bring the MVAR flow in the POI down to approximate zero under low/no wind conditions. The reactor bank size is approximate and the final size will be determined in the final facility and collector system design.

The results of this analysis are based on available data and assumptions made at the time of conducting this study. If any of the data and/or assumptions made in developing the study model change, the results provided in this report may not apply.

APPENDIX A SOUTHWEST POWER POOL DISTURBANCE PERFORMANCE CRITERIA REQUIREMENTS

OVERVIEW

These Disturbance Performance Requirements (“Requirements”) shall be applicable to the Bulk Electric System within the Southwest Power Pool Planning Area. Utilization of these Requirements applies to all registered entities within the Southwest Power Pool Planning Area. These Requirements shall not be applicable to facilities that are not part of Bulk Electric System. More stringent Requirements are at the sole discretion of each Transmission Owner.

Transient and dynamic stability assessments are generally performed to assure adequate avoidance of loss of generator synchronism and prevention of system voltage collapse within the first 20 seconds after a system disturbance. These Requirements provide a basis for evaluating the system response during the initial transient period following a disturbance on the Bulk Electric System by establishing minimum requirements for machine rotor angle damping and transient voltage recovery.

ROTOR ANGLE DAMPING REQUIREMENT

Machine Rotor Angles shall exhibit well damped angular oscillations [as defined below] and acceptable power swings following a disturbance on the Bulk Electric System for all NERC Category A, B and C events.

Well damped angular oscillations shall meet one of the following two requirements when calculated directly from the rotor angle:

1. Successive Positive Peak Ratio (SPPR) must be less than or equal to 0.95 where SPPR is calculated as follows:

$$\text{SPPR} = \frac{\text{Peak Rotor Angle of 2}^{\text{nd}} \text{ Positive Swing Peak}}{\text{Peak Rotor Angle of 1}^{\text{st}} \text{ Positive Swing Peak}} \leq 0.95$$

-or- Damping Factor % = $(1 - \text{SPPR}) \times 100\% \geq 5\%$

The machine rotor angle damping ratio may be determined by appropriate modal analysis (i.e. Prony Analysis) where the following equivalent requirement must be met:

$$\text{Damping Ratio} \geq 0.0081633$$

2. Successive Positive Peak Ratio Five (SPPR5) must be less than or equal to 0.774 where SPPR5 is calculated as follows:


$$\text{SPPR5} = \frac{\text{Peak Rotor Angle of 5}^{\text{th}} \text{ Positive Swing Peak}}{\text{Peak Rotor Angle of 1}^{\text{st}} \text{ Positive Swing Peak}} \leq 0.774$$

-or- Damping Factor % = $(1 - \text{SPPR5}) \times 100\% \geq 22.6\%$

The machine rotor angle damping ratio may be determined by appropriate modal analysis (i.e. Prony Analysis) where the following equivalent requirement must be met:

Damping Ratio ≥ 0.0081633


Qualitatively, these Requirements are shown in Figure 1 below.



TRANSIENT VOLTAGE RECOVERY REQUIREMENT

After a disturbance is cleared; bus voltages on the Bulk Electric System shall recover above 0.70 per unit, 2.5 seconds after the fault is cleared. Bus voltages shall not swing above 1.20 per unit after the fault is cleared, unless affected transmission system elements are designed to handle the rise above 1.2 per unit.

Qualitatively, this Requirement is shown in Figure 2 below.



APPENDIX B SIMULATION PLOTS FOR STABILITY ANALYSIS

APPENDIX C POWER FACTOR ANALYSIS RESULTS

All the contingency numbers shown in this appendix match with the fault numbers shown in Table 2-1.

C.1 GEN-2014-037 2016 Winter Peak Case

The GEN-2014-037 POI voltage is 0.9905 pu in the provided 2016 winter peak case. Therefore, the power factor requirements for the wind farm were determined to maintain the voltage at 1.0 pu. The lowest lagging and leading power factors are highlighted in the table below.

| Outage No. | | MW | Mvar | PF | |
|---------------|----|--------|--------|--------------|---------|
| System Intact | 0 | -196.4 | -59.4 | 0.957 | lagging |
| Contingency | 1 | -196.4 | -64.9 | 0.950 | lagging |
| Contingency | 2 | -196.3 | -65.1 | 0.949 | lagging |
| Contingency | 3 | -196.3 | -109.5 | 0.873 | lagging |
| Contingency | 4 | -195.4 | -249.4 | 0.617 | lagging |
| Contingency | 5 | -196.5 | -73.3 | 0.937 | lagging |
| Contingency | 6 | -196.4 | -74.3 | 0.935 | lagging |
| Contingency | 7 | -196.4 | -90.1 | 0.909 | lagging |
| Contingency | 8 | -196.4 | -66.7 | 0.947 | lagging |
| Contingency | 9 | -196.3 | -56.0 | 0.962 | lagging |
| Contingency | 10 | -196.3 | -104.1 | 0.884 | lagging |
| Contingency | 11 | -196.3 | -110.7 | 0.871 | lagging |
| Contingency | 12 | -196.4 | -62.9 | 0.952 | lagging |
| Contingency | 13 | -196.4 | -62.0 | 0.954 | lagging |
| Contingency | 14 | -196.4 | -63.3 | 0.952 | lagging |
| Contingency | 15 | -194.4 | -331.7 | 0.506 | lagging |
| Contingency | 16 | -196.4 | -62.8 | 0.953 | lagging |
| Contingency | 17 | -196.3 | -109.3 | 0.874 | lagging |
| Contingency | 18 | -196.5 | -73.9 | 0.936 | lagging |
| Contingency | 19 | -196.4 | -81.1 | 0.924 | lagging |
| Contingency | 20 | -195.3 | -258.3 | 0.603 | lagging |
| Contingency | 21 | -196.3 | -106.8 | 0.879 | lagging |
| Contingency | 22 | -196.3 | -143.6 | 0.807 | lagging |
| Contingency | 23 | -196.5 | -72.9 | 0.937 | lagging |
| Contingency | 24 | -196.4 | -59.4 | 0.957 | lagging |
| Contingency | 25 | -196.3 | -55.9 | 0.962 | lagging |
| Contingency | 26 | -196.4 | -66.0 | 0.948 | lagging |
| Contingency | 27 | -196.5 | -73.0 | 0.937 | lagging |
| Contingency | 28 | -196.5 | -70.0 | 0.942 | lagging |

C.2 GEN-2014-037 2017 Summer Peak Case

The GEN-2014-037 POI voltage is 0.9948 pu in the provided 2017 summer peak case. Therefore, the power factor requirements for the wind farm were determined to maintain the voltage at 1.0 pu. The lowest lagging and leading power factors are highlighted in the table below.

| Outage No. | | MW | Mvar | PF | |
|---------------|----|--------|--------|--------------|---------|
| System Intact | 0 | -196.3 | -18.2 | 0.996 | lagging |
| Contingency | 1 | -196.3 | -28.1 | 0.990 | lagging |
| Contingency | 2 | -196.3 | -23.8 | 0.993 | lagging |
| Contingency | 3 | -196.4 | -64.7 | 0.950 | lagging |
| Contingency | 4 | -196.0 | -188.6 | 0.721 | lagging |
| Contingency | 5 | -196.3 | -24.2 | 0.993 | lagging |
| Contingency | 6 | -196.3 | -30.4 | 0.988 | lagging |
| Contingency | 7 | -196.4 | -41.7 | 0.978 | lagging |
| Contingency | 8 | -196.3 | -25.0 | 0.992 | lagging |
| Contingency | 9 | -196.3 | -18.4 | 0.996 | lagging |
| Contingency | 10 | -196.4 | -38.0 | 0.982 | lagging |
| Contingency | 11 | -196.4 | -41.4 | 0.978 | lagging |
| Contingency | 12 | -196.3 | -22.0 | 0.994 | lagging |
| Contingency | 13 | -196.3 | -22.6 | 0.993 | lagging |
| Contingency | 14 | -196.3 | -20.7 | 0.994 | lagging |
| Contingency | 15 | -196.3 | -24.0 | 0.993 | lagging |
| Contingency | 16 | -196.4 | -79.9 | 0.926 | lagging |
| Contingency | 17 | -196.3 | -33.0 | 0.986 | lagging |
| Contingency | 18 | -196.3 | -35.6 | 0.984 | lagging |
| Contingency | 19 | -196.3 | -127.5 | 0.839 | lagging |
| Contingency | 20 | -196.4 | -61.6 | 0.954 | lagging |
| Contingency | 21 | -196.3 | -112.2 | 0.868 | lagging |
| Contingency | 22 | -196.4 | -40.4 | 0.979 | lagging |
| Contingency | 23 | -196.3 | -22.3 | 0.994 | lagging |
| Contingency | 24 | -196.3 | -17.7 | 0.996 | lagging |
| Contingency | 25 | -196.3 | -25.9 | 0.991 | lagging |
| Contingency | 26 | -196.3 | -26.9 | 0.991 | lagging |
| Contingency | 27 | -196.3 | -26.0 | 0.991 | lagging |

C.3 GEN-2014-037 2025 Summer Peak Case

The GEN-2014-037 POI voltage is 0.9972 pu in the provided 2025 summer peak case. Therefore, the power factor requirements for the wind farm were determined to maintain the voltage at 1.0 pu. The lowest lagging and leading power factors are highlighted in the table below.

| Outage No. | | MW | Mvar | PF | |
|---------------|----|--------|--------|--------------|---------|
| System Intact | 0 | -196.2 | 4.4 | 1.000 | leading |
| Contingency | 1 | -196.4 | -13.1 | 0.998 | lagging |
| Contingency | 2 | -196.3 | 0.9 | 1.000 | leading |
| Contingency | 3 | -196.4 | -41.4 | 0.978 | lagging |
| Contingency | 4 | -196.2 | -157.6 | 0.780 | lagging |
| Contingency | 5 | -196.3 | 2.9 | 1.000 | leading |
| Contingency | 6 | -196.3 | -4.4 | 1.000 | lagging |
| Contingency | 7 | -196.3 | -3.6 | 1.000 | lagging |
| Contingency | 8 | -196.2 | 1.3 | 1.000 | leading |
| Contingency | 9 | -196.3 | 0.6 | 1.000 | leading |
| Contingency | 10 | -196.2 | 5.4 | 1.000 | leading |
| Contingency | 11 | -196.2 | 4.9 | 1.000 | leading |
| Contingency | 12 | -196.2 | 1.3 | 1.000 | leading |
| Contingency | 13 | -196.2 | 1.1 | 1.000 | leading |
| Contingency | 14 | -196.2 | 3.6 | 1.000 | leading |
| Contingency | 15 | -196.3 | -5.7 | 1.000 | lagging |
| Contingency | 16 | -196.4 | -58.2 | 0.959 | lagging |
| Contingency | 17 | -196.4 | -12.1 | 0.998 | lagging |
| Contingency | 18 | -196.3 | -24.5 | 0.992 | lagging |
| Contingency | 19 | -196.4 | -78.9 | 0.928 | lagging |
| Contingency | 20 | -196.4 | -34.5 | 0.985 | lagging |
| Contingency | 21 | -196.4 | -87.3 | 0.914 | lagging |
| Contingency | 22 | -196.4 | -12.5 | 0.998 | lagging |
| Contingency | 23 | -196.3 | -3.0 | 1.000 | lagging |
| Contingency | 24 | -196.2 | 2.2 | 1.000 | leading |
| Contingency | 25 | -196.3 | 0.8 | 1.000 | leading |
| Contingency | 26 | -196.3 | 0.6 | 1.000 | leading |
| Contingency | 27 | -196.3 | -1.5 | 1.000 | lagging |

11.15 L: Group 6 Dynamic Stability Analysis Report

See next page

Southwest Power Pool, Inc. (SPP)

DISIS-2015-002-1 (Group 06) Definitive Impact Study

Final Report

**PXE-1302
Revision #00**

August 2016

**Submitted By:
Mitsubishi Electric Power Products, Inc. (MEPPI)
Power Systems Engineering Services Department
Warrendale, PA**

Title: DISIS-2015-002-1 (Group 06) Definitive Impact Study: Final Report PXE-1302
Date: August 2016
Author: Nicholas W. Tenza; Engineer II, Power Systems Engineering Dept. Nicholas W. Tenza
Approved: Rajat Majumder; Section Manager, Power Systems Engineering Dept. Rajat Majumder

EXECUTIVE SUMMARY

SPP requested a Definitive Interconnection System Impact Study (DISIS). The DISIS required a Stability Analysis, Short Circuit Analysis, Power Factor Analysis, and Low Wind/No Wind Analysis detailing the impacts of the interconnecting projects as shown in Table ES-1.

Table ES-1
Interconnection Projects Evaluated

| Request | Size (MW) | Generator Model | Point of Interconnection |
|--------------|-----------|---|--|
| GEN-2015-020 | 100.0 | Eaton Power Xpert Solar 1.67MW (584623) (solar) | Oasis 115kV (524874) |
| GEN-2015-031 | 150.53 | GE 1.79 MW (wind) | Swisher (525213) to Amarillo South (524415) 230 kV (560050) |
| GEN-2015-056 | 101 | GE 2.3 MW (wind) | Crossroads 345kV (527656) (Tap Eddy (527802) to Tolk(525549) |
| GEN-2015-058 | 50 | Power Electronics Solar 1.667 MW (solar) | Atoka 115kV (527786) |
| GEN-2015-068 | 300 | GE 2.0 MW (wind) | Tuco 345kV (525832) |
| GEN-2015-075 | 50 | GE 4.0MVA Inverter (solar) | Carlisle 69kV (526159) |
| GEN-2015-079 | 129.2 | GE LV5 3.8 MW (solar) | Tap Yoakum (526935) to Hobbs (527894) 230 kV (560059) |
| GEN-2015-080 | 129.2 | GE LV5 3.8 MW (solar) | Tap Yoakum (526935) to Hobbs (527894) 230 kV (560059) |

SUMMARY OF STABILITY ANALYSIS

The Stability Analysis determined that there were multiple contingencies across all seasons that resulted in system/voltage instability, generation tripping offline, and poor post-fault voltage recovery when all generation interconnection requests were at 100% output.

To mitigate the system/voltage instability, voltage violations, generation tripping offline, and poor post-fault steady-state voltages, the following upgrades were provided by SPP and implemented in each season:

- Tuco – Yoakum – Hobbs 345kV circuit #1 (**16WP and 17SP**)
- Yoakum 345/230 kV transformer and Hobbs 345/230 kV transformer (**16WP and 17SP**)
- GEN-2014-074 345/34.5 kV transformer low side tap ratio set to 0.95 p.u.
- OKU Reactive Power Support
 - +/- 100 Mvar SVC
- Border Reactive Power Support (600 Mvar total)
 - +300 Mvar SVC
 - 300 Mvar capacitor bank
- Seminole – Mustang 115 kV circuit #1

Note for GEN-2015-058, for a three-phase fault at the point of interconnection (Atoka 115 kV), the TMEIC photovoltaic inverter model (ITMEIC) tripped offline due to over frequency protection and over voltage protection. For this study, the over frequency and over voltage protection were set to 75 Hz and 1.8 p.u., respectively, to avoid instantaneous tripping. It is recommended the supplier of the TMEIC photovoltaic inverter model examine this model for three-phase faults that cause the model to trip on over frequency and over voltage protection.

After implementing the above upgrades, the contingency analysis was re-simulated for all contingencies. With the upgrades, the Stability Analysis determined that there was no wind turbine tripping or system instability observed as a result of interconnecting all study projects at 100% output.

SUMMARY OF THE SHORT CIRCUIT ANALYSIS

The short circuit analysis was performed on the 2017 Summer Peak and 2025 Summer Peak power flows for all study projects. Refer to Table ES-2 and Table ES-3 for a list of maximum fault currents observed for each study project for the 17SP and 25SP cases, respectively.

Table ES-2
2017SP: List of Maximum Fault Currents Observed for Each Study Project

| Study Project | Fault Current at POI (kA) | Maximum Fault Current (kA) | Fault Location | Bus Voltage (kV) |
|---------------|---------------------------|----------------------------|----------------|------------------|
| GEN-2015-020 | 9.57 | 25.84 | Tolk East/West | 230 kV |
| GEN-2015-031 | 9.03 | 30.52 | LP - Cook | 69 kV |
| GEN-2015-056 | 5.42 | 26.24 | Cunnigham | 115 kV |
| GEN-2015-058 | 6.59 | 26.24 | Cunnigham | 115 kV |
| GEN-2015-068 | 13.36 | 30.52 | LP - Cook | 69 kV |
| GEN-2015-075 | 2.57 | 25.84 | Tolk East | 230 kV |
| GEN-2015-079 | 8.97 | 29.89 | Hobbs Int | 115 kV |
| GEN-2015-080 | 8.97 | 29.89 | Hobbs Int | 115 kV |

Table ES-3
2025SP: List of Maximum Fault Currents Observed for Each Study Project

| Study Project | Fault Current at POI (kA) | Maximum Fault Current (kA) | Fault Location | Bus Voltage (kV) |
|---------------|---------------------------|----------------------------|----------------|------------------|
| GEN-2015-020 | 9.75 | 26.48 | Tolk East/West | 230 kV |
| GEN-2015-031 | 9.05 | 34.97 | LP - Cook | 69 kV |
| GEN-2015-056 | 5.48 | 29.66 | Cunnigham | 115 kV |
| GEN-2015-058 | 6.97 | 29.66 | Cunnigham | 115 kV |
| GEN-2015-068 | 13.55 | 34.97 | LP - Cook | 69 kV |
| GEN-2015-075 | 2.58 | 26.48 | Tolk East | 230 kV |
| GEN-2015-079 | 9.26 | 32.92 | Hobbs Int | 115 kV |
| GEN-2015-080 | 9.26 | 32.92 | Hobbs Int | 115 kV |

SUMMARY OF POWER FACTOR ANALYSIS

The upgrades identified in the Stability Analysis were implemented in the power flow cases and utilized for the Power Factor Analysis.

Study Generator GEN-2015-020

The Power Factor Analysis shows that GEN-2015-020 has a power factor range of 0.970 leading (absorbing) to 0.990 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.973 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, a power factor range of 0.979 leading (absorbing) to 1.00 (unity) for the 2020 Summer Peak conditions, a power factor range of 0.973 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.976 leading (absorbing) to 1.00 (unity) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-031

The Power Factor Analysis shows that GEN-2015-031 has a power factor range of 0.983 leading (absorbing) to 0.784 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.991 leading (absorbing) to 0.646 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.991 leading (absorbing) to 0.744 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.979 leading (absorbing) to 0.840 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.997 leading (absorbing) to 0.782 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-056

The Power Factor Analysis shows that GEN-2015-056 has a power factor range of 0.997 leading (absorbing) to 0.965 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.998 lagging (supplying) to 1.00 (unity) for the 2017 Summer Peak conditions, a power factor range of 0.983 lagging (supplying) to 1.00 (unity) for the 2020 Summer Peak conditions, a power factor range of 0.998 leading (absorbing) to 0.974 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.979 lagging (supplying) to 1.00 (unity) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-058

The Power Factor Analysis shows that GEN-2015-058 has a power factor range of 0.971 leading (absorbing) to 0.962 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.975 leading (absorbing) to 0.947 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.976 leading (absorbing) to 0.989 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.990 leading (absorbing) to 0.993 lagging

(supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.972 leading (absorbing) to 0.964 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-068

The Power Factor Analysis shows that GEN-2015-068 has a power factor range of 0.738 to 0.916 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.709 to 0.954 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.859 to 0.997 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.782 to 0.949 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.913 to 0.998 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-075

The Power Factor Analysis shows that GEN-2015-075 has a power factor range of 0.994 leading (absorbing) to 0.998 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.988 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, a power factor range of 0.996 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.995 leading (absorbing) to 1.00 (unity) for the 2020 Winter Peak conditions, and a power factor range of 0.989 leading (absorbing) to 0.995 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-079

The Power Factor Analysis shows that GEN-2015-079 has a power factor range of 0.986 leading (absorbing) to 0.999 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.982 leading (absorbing) to 0.996 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.984 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.989 leading (absorbing) to 1.00 (unity) for the 2020 Winter Peak conditions, and a power factor range of 0.971 leading (absorbing) to 0.994 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-080

The Power Factor Analysis shows that GEN-2015-080 has a power factor range of 0.986 leading (absorbing) to 0.999 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.982 leading (absorbing) to 0.996 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.984 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.989 leading (absorbing) to 1.00 (unity) for the 2020 Winter Peak conditions, and a power factor range of 0.971 leading (absorbing) to 0.994 lagging (supplying) for the 2025 Summer Peak conditions.

SUMMARY OF LOW WIND/NO WIND ANALYSIS

The amount of reactive power injected into the transmission network was recorded at the point of interconnection for each wind and solar powered interconnection request for each season. The maximum reactance needed for zero Mvar flow was 58 Mvar for GEN-2015-068 (Tuco 345 kV). The minimum reactance needed for zero Mvar flow was 0.4 Mvar for GEN-2015-058 (Atoka 115 kV).

Table of Contents

| | |
|--|----|
| Section 1: Objectives | 1 |
| Section 2: Background | 1 |
| Section 3: Stability Analysis | 30 |
| 3.1 Approach | 30 |
| 3.2 Stability Analysis Results | 32 |
| Section 4: Short Circuit Analysis | 44 |
| 4.1 Approach | 44 |
| 4.2 Short Circuit Analysis Results: 2017 Summer Peak | 44 |
| 4.3 Short Circuit Analysis Results: 2025 Summer Peak | 50 |
| Section 5: Power Factor Analysis | 57 |
| 5.1 Approach | 57 |
| 5.2 Power Factor Analysis Results | 59 |
| Section 6: Low Wind/No Wind Analysis | 76 |
| 6.1 Approach | 76 |
| 6.2 Low Wind/No Wind Analysis Results | 76 |
| Section 7: Conclusions..... | 78 |

SECTION 1: OBJECTIVES

The objective of this report is to provide Southwest Power Pool, Inc. (SPP) with the deliverables for the “DISIS-2015-002-1 (Group 06) Definitive Impact Study.” SPP requested an Interconnection System Impact Study for eight (8) generation interconnections for 2016 Winter Peak, 2017 Summer Peak, 2020 Summer Peak, 2020 Winter Peak, and 2025 Summer Peak, which requires a Stability Analysis, Short Circuit Analysis, Power Factor Analysis, Low Wind/No Wind Analysis, and an Impact Study Report.

SECTION 2: BACKGROUND

The Siemens Power Technologies International PSS/E power system simulation program Version 32.2.0 was used for this study. SPP provided the stability database cases for 2016 Winter Peak, 2017 Summer Peak, 2020 Summer Peak, 2020 Winter Peak, and 2025 Summer Peak conditions and a list of contingencies to be examined. The model includes the study projects shown in Table 2-1 and the previously queued projects listed in Table 2-2. Refer to Appendix A for the steady-state and dynamic model data for the study projects. A power flow one-line diagram for each generation interconnection project is shown in Figures 2-1 through 2-7. Note that the one-line diagrams represent the 2017 Summer Peak case.

The Stability Analysis determined the impacts of the new interconnecting projects on the stability and voltage recovery of the nearby system and the ability of the interconnecting projects to meet FERC Order 661A. If problems with stability or voltage recovery are identified, the need for reactive compensation or system upgrades were investigated. Three-phase faults and single line-to-ground faults were examined as listed in Table 2-3.

A Short Circuit Analysis was performed on the 2017 Summer Peak and 2025 Summer Peak study years for each study generator. The study was performed five buses out from the study generator’s point of interconnection and results were documented.

The Power Factor Analysis determined the power factor at the point of interconnection for the wind or solar interconnection projects for pre-contingency and post-contingency conditions. Table 2-3 lists the contingencies developed from the three-phase fault definitions provided in the group’s interconnection impact study request.

The Low Wind/No Wind Analysis was completed for all wind farm and solar farm interconnections. This analysis determined if reactive support was needed to have an Mvar flow of approximately zero at the point of interconnection (POI).

**Table 2-1
Interconnection Projects Evaluated**

| Request | Size (MW) | Generator Model | Point of Interconnection |
|----------------|----------------------|---|---|
| GEN-2015-020 | 100.0 | Eaton Power Xpert Solar 1.67MW (584623) (solar) | Oasis 115kV (524874) |
| GEN-2015-031 | 150.53 | GE 1.79 MW (wind) | Swisher (525213) to Amarillo South (524415) 230 kV (560050) |
| GEN-2015-056 | 101 | GE 2.3 MW (wind) | Crossroads 345kV (527656) (Tap Eddy (527802) to Tolk(525549) |
| GEN-2015-058 | 50 | Power Electronics Solar 1.667 MW (solar) | Atoka 115kV (527786) |
| GEN-2015-068 | 300 | GE 2.0 MW (wind) | Tuco 345kV (525832) |
| GEN-2015-075 | 50 | GE 4.0MVA Inverter (solar) | Carlisle 69kV (526159) |
| GEN-2015-079 | 129.2 | GE LV5 3.8 MW (solar) | Tap Yoakum (526935) to Hobbs (527894) 230 kV (560059) |
| GEN-2015-080 | 129.2 | GE LV5 3.8 MW (solar) | Tap Yoakum (526935) to Hobbs (527894) 230 kV (560059) |

Table 2-2
Previously Queued Nearby Interconnection Projects Included

| Request | Size (MW) | Generator Model | Point of Interconnection |
|----------------|--------------------------|---------------------------------|--|
| GEN-2001-033 | 180 | Mitsubishi 1000 | San Juan Mesa 230kV (524885) |
| GEN-2001-036 | 80 | Mitsubishi 1000 | Norton 115kV (524502) |
| GEN-2006-018 | 170 | GENSAL | Tuco 230kV (525830) |
| GEN-2006-026 | 502 | GENROU (527901, 527902, 527903) | Hobbs 115kV(527891) Hobbs 230kV (527894) |
| GEN-2008-022 | 300 | Vestas | Tap on Eddy County – Tolk 345kV line (G08-022-POI, 560007) |
| GEN-2010-006 | 180 Summer 205 Winter | GENROU | Jones_bus2 230kV(526337) |
| ASGI-2010-010 | 42 | GENSAL | Lovington 115kV (528334) |
| ASGI-2010-020 | 30 | Nordex 2.5MW | Tap LE-Tatum to LE-Crsroads 69kV (AS10-020-POI, 560360) |
| ASGI-2010-021 | 15 | Mitsubishi MPS-1000A 1.0MW | Tap LE-Saundrtp to LE-Anderson 69kV (ASGI-021-POI, 560364) |
| GEN-2010-046 | 56 | GENSAL | Tuco 230kV (525830) |
| ASGI-2011-001 | 27.3 | Suzlon 2.1MW | Lovington 115kV (528334) |
| ASGI-2011-003 | 10 | Sany 2.0MW | Hendricks 69kV (525943) |
| ASGI-2011-004 | 19.8 | Sany 1.8MW | Crosby 69kV (525915) |
| GEN-2011-025 | 80 | GE 1.6MW | Tap on Floyd County - Crosby County 115kV line (G11-025-POI, 562004) |
| GEN-2011-045 | 180 Summer 205 Winter | GENROU | Jones_bus2 230kV (526337) |
| GEN-2011-046 | 23 Summer 27 Winter | GENROU | Quay County 115kV (524472) |
| GEN-2011-048 | 165 Summer 175 Winter | GENROU | Mustang 230kV (527151) |
| GEN-2012-001 | 61.2 | CCWE 3.6MW (WT4) | Tap Grassland to Borden 230kV (526679) |
| ASGI-2012-002 | 18 | Vestas 1.65MW V82 | Clovis 115kV (524808) |
| GEN-2012-020 | 478 | GE 1.68MW | Tuco 230kV (525830) |

| Request | Size (MW) | Generator Model | Point of Interconnection |
|----------------|---|----------------------------|--------------------------------------|
| GEN-2012-034 | 7 MW increase (Pgen=157MW) | GENROU | Mustang 230kV (527151) |
| GEN-2012-035 | 7 MW increase (Pgen=157MW) | GENROU | Mustang 230kV (527151) |
| GEN-2012-036 | 7 MW increase (Pgen=172MW Summer/182 MW Winter) | GENROU | Mustang 230kV (527151) |
| GEN-2012-037 | 196 Summer 203 Winter | GENROU | Tuco 345kV (525832) |
| ASGI-2012-002 | 18 | Vestas 1.65MW V82 | Clovis 115kV (524808) |
| GEN-2013-016 | 191 Summer 203 Winter | GENROU (583456) | Tuco 345kV (525832) |
| ASGI-2013-002 | 18.4 | Siemens 2.3MW VS (583613) | Tucumcari 115kV (524509) |
| ASGI-2013-003 | 18.4 | Siemens 2.3MW VS (583623) | Clovis 115kV (524808) |
| ASGI-2013-005 | 19.8 (1.65 MW Uprate) | Vestas V82 1.65MW (583283) | FE-Clovis 115kV (524808) |
| ASGI-2013-006 | 2.0 | Gamesa G114 2MW (583813) | Erskine 115kV (526109) |
| GEN-2013-022 | 25.0 | Solaron 500kW (583313) | Caprock 115kV (524486) |
| GEN-2013-027 | 150.0 | Siemens 2.3/2.415 | Tap on Yoakum to Tolk 230kV (562480) |

| Request | Size (MW) | Generator Model | Point of Interconnection |
|----------------|--------------------------|---------------------------------|---|
| GEN-2014-012 | 186 Summer 225 Winter | GENROU (528607) | Tap Hobbs (527894 in 2015SP/WP, 527896 in 2025SP) to Andrews (528604) 230kV (345kV in 2025SP) (Tap bus is 528611) |
| ASGI-2014-001 | 2.3 | GE 107m 2.3MW (583816) | Erskine 69kV (526109) |
| GEN-2014-033 | 70 | SC 500HE/CP 0.5MVA inverter | Chaves County 115kV |
| GEN-2014-034 | 70 | SC 500HE/CP 0.5MVA inverter | Chaves County 115kV |
| GEN-2014-035 | 30 | SC 500HE/CP 0.5MVA inverter | Chaves County 115kV |
| GEN-2014-047 | 40 | AE 500NX 0.5 MW PV inverters | Tap Tolk - Eddy County (Crossroads) 345kV |
| GEN-2014-074 | 152.0 | Vestas V110 2.0MW (584443) | Tap Tuco – OKU 345kV (560027) |
| GEN-2015-014 | 150.0 | Vestas V110 2.0MW (584563) | Tap on Cochran – LG Plains 115kV (560030) |
| GEN-2015-022 | 112.0 | GE LV5 4.0MW Inverters (584643) | Swisher 115kV (525212) |
| ASGI-2015-002 | 2.0 | GE 2.0MW (584723) | Yuma Interchange 115/69kV (526469) |




Figure 2-1. Power flow one-line diagram for interconnection project at the Oasis 115 kV POI (GEN-2015-020).




Figure 2-2. Power flow one-line diagram for interconnection project at the Swisher to Amarillo South 230 kV POI (GEN-2015-031).




Figure 2-3. Power flow one-line diagram for interconnection project at the Crossroads 345 kV POI (GEN-2015-056).




Figure 2-4. Power flow one-line diagram for interconnection project at Atoka 115 kV POI (GEN-2015-058).




Figure 2-5. Power flow one-line diagram for interconnection project at the Tuco 345 kV POI (GEN-2015-068).




Figure 2-6. Power flow one-line diagram for interconnection project at the Carlisle 69 kV POI (GEN-2015-075).




Figure 2-7. Power flow one-line diagram for interconnection project at Yoakum to Hobbs 230 kV POI (GEN-2015-079 and GEN-2015-080).

**Table 2-3
Case List with Contingency Description**

| Cont. No. | Cont. Name | Description |
|------------------|-------------------|--|
| 1 | FLT01-3PH | 3 phase fault on Chaves County 115 kV (527482) to Samson 115 kV (527546) CKT 1, near Chaves County. a. Apply fault at the Chaves County 115 kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 2 | FLT02-3PH | 3 phase fault on Chaves County 115 kV (527482) to Urton 115 kV (527501) CKT 1, near Chaves County. a. Apply fault at the Chaves County 115 kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 3 | FLT03-3PH | 3 phase fault on the Chaves County 115 kV (527482) to Chaves County 230 kV (527483) to Chaves County 13.2 kV (527478) XFMR CKT 1, near Chaves County 115 kV. a. Apply fault at the Chaves County 115 kV bus. b. Clear fault after 5 cycles and trip the faulted transformer. |
| 4 | FLT04-3PH | 3 phase fault on Chaves County 230 kV (527483) to San Juan Tap 230 kV (524885) CKT 1, near Chaves County. a. Apply fault at the Chaves County 230 kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 5 | FLT05-3PH | 3 phase fault on Chaves County 230 kV (527483) to Eddy North 230 kV (527799) CKT 1, near Chaves County. a. Apply fault at the Chaves County 230 kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 6 | FLT06-3PH | 3 phase fault on Samson 115 kV (527546) to Roswell_Int 115 kV (527564) CKT 1, near Samson. a. Apply fault at the Samson 115 kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 7 | FLT07-3PH | 3 phase fault on Urton 115 kV (527501) to Roswell City 115 kV (527522) CKT 1, near Urton. a. Apply fault at the Urton 115 kV bus. b. Clear fault after 5 cycles and trip the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|---|
| 8 | FLT10-SB | Single phase fault with stuck breaker at Chaves County (527482) a. Apply fault at the Chaves 115 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Chaves County 115 kV (527482)/ 230 kV (527483)/13.2 kV (527479) transformer d. Chaves County (527482) - Samson (527546) 115 kV |
| 9 | FLT11-3PH | 3 phase fault on the G15-018T (560032) to FE-Curry (524822) 115 kV line circuit 1, near G15-018T. a. Apply fault at the G15-018T 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 10 | FLT12-3PH | 3 phase fault on the G15-018T (560032) to FE-Bailey County (525028) 115 kV line circuit 1, near G15-018T. a. Apply fault at the G15-018T 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 11 | FLT13-3PH | 3 phase fault on the FE-Bailey County 115 kV (525028) to Bailey County 2 69 kV (525027) to Bailey transformer 1 13.2 kV (525025) XFMR CKT 1, near FE-Bailey County 115 kV. a. Apply fault at the FE-Bailey County 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 12 | FLT14-3PH | 3 phase fault on the FE-Bailey County (525028) to EMU&VLY Tap (525019) 115 kV line circuit 1, near FE-Bailey County. a. Apply fault at the FE-Bailey County 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 13 | FLT15-3PH | 3 phase fault on the FE-Curry (524822) to DS#20 (524669) 115 kV line circuit 1, near FE-Curry. a. Apply fault at the FE-Curry 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 14 | FLT16-3PH | 3 phase fault on the FE-Curry (524822) to Norris Tap (524764) 115 kV line circuit 1, near FE-Curry. a. Apply fault at the FE-Curry 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 15 | FLT17-3PH | 3 phase fault on the FE-Curry (524822) to E_Clovis (524773) 115 kV line circuit 1, near FE-Curry. a. Apply fault at the FE-Curry 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|---|
| 16 | FLT18-3PH | 3 phase fault on the FE-Curry (524822) to FE_Clovis2 (524838) 115 kV line circuit 1, near FE-Curry. a. Apply fault at the FE-Curry 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 17 | FLT19-3PH | 3 phase fault on the FE-Curry (524822) to Roosevelt (524908) 115 kV line circuit 1, near FE-Curry. a. Apply fault at the FE-Curry 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 18 | FLT20-3PH | 3 phase fault on the FE-Curry 115 kV (524822) to Curry 69 kV (524821) to Curry 13.2 kV (524819) XFMR CKT 1, near FE-Curry 115 kV. a. Apply fault at the FE-Curry 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 19 | FLT21-3PH | 3 phase fault on the Oasis (524874) to Perimeter (524797) 115 kV line circuit 1, near Oasis. a. Apply fault at the Oasis 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 20 | FLT22-3PH | 3 phase fault on the Oasis (524874) to FE-Chzplt (524863) 115 kV line circuit 1, near Oasis. a. Apply fault at the Oasis 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 21 | FLT23-3PH | 3 phase fault on the FE-Chzplt (524863) to Norris Tap (524764) 115 kV line circuit 1, near FE-Chzplt. a. Apply fault at the FE-Chzplt 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 22 | FLT24-3PH | 3 phase fault on the Perimeter (524797) to Cannon Top (524790) 115 kV line circuit 1, near Perimeter. a. Apply fault at the Perimeter 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 23 | FLT25-3PH | 3 phase fault on the Oasis (524874) to Portales (524924) 115 kV line circuit 1, near Oasis. a. Apply fault at the Oasis 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|--|
| 24 | FLT26-3PH | 3 phase fault on the Portales (524924) to Roosevelt (524908) 115 kV line circuit 1, near Oasis. a. Apply fault at the Portales 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 25 | FLT27-3PH | 3 phase fault on the Portales 115 kV (524924) to Portales 69 kV (524923) to Portales 13.2 kV (524921) XFMR CKT 1, near Portales 115 kV. a. Apply fault at the Portales 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 26 | FLT28-3PH | 3 phase fault on the Oasis 115 kV (524874) to Oasis 230 kV (524875) to Oasis 13.2 kV (524872) XFMR CKT 1, near Oasis 115 kV. a. Apply fault at the Oasis 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 27 | FLT29-3PH | 3 phase fault on the Oasis (524875) to San Juan Tap (524885) 230 kV line circuit 1, near Oasis. a. Apply fault at the Oasis 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 28 | FLT30-3PH | 3 phase fault on the Oasis (524875) to SW_4k33 (524915) 230 kV line circuit 1, near Oasis. a. Apply fault at the Oasis 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 29 | FLT31-3PH | 3 phase fault on the Oasis (524875) to Pleasant Hill (524770) 230 kV line circuit 1, near Oasis. a. Apply fault at the Oasis 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 30 | FLT32-PO | Prior Outage of the Oasis 115 kV (524874) to Oasis 230 kV (524875) to Oasis 13.2 kV (524872) XFMR CKT 1; 3 phase fault on the Oasis (524874) to Perimeter (524797) 115 kV line circuit 1, near Oasis 115 kV. a. Apply fault at the Oasis 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|--|
| 31 | FLT33-PO | Prior Outage of the Oasis (524874) to Perimeter (524797) 115 kV line circuit 1; 3 phase fault on the Oasis 115 kV (524874) to Oasis 230 kV (524875) to Oasis 13.2 kV (524872) XFMR CKT 1, near Oasis 115 kV. a. Apply fault at the Oasis 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 32 | FLT34-3PH | 3 phase fault on the Gen-2015-031 Tap (560050) to Amarillo South (524415) 230 kV line circuit 1, near Gen-2015-031 Tap. a. Apply fault at the Gen-2015-031 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 33 | FLT35-3PH | 3 phase fault on the Gen-2015-031 Tap (560050) to Swisher (525213) 230 kV line circuit 1, near Gen-2015-031 Tap. a. Apply fault at the Gen-2015-031 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 34 | FLT36-3PH | 3 phase fault on the Swisher 230 kV (525213) to Swisher 115 kV (525212) to Swisher 13.2 kV (525211) XFMR CKT 1, near Swisher 230 kV. a. Apply fault at the Swisher 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 35 | FLT37-3PH | 3 phase fault on the Swisher (525213) to Tuco Int (525830) 230 kV line circuit 1, near Swisher. a. Apply fault at the Swisher 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 36 | FLT38-3PH | 3 phase fault on the Swisher (525213) to Newhart (525461) 230 kV line circuit 1, near Swisher. a. Apply fault at the Swisher 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 37 | FLT39-3PH | 3 phase fault on the Amarillo South 230 kV (524415) to Amarillo South 115 kV (524414) to Amarillo South 13.2 kV (524410) XFMR CKT 1, near Amarillo South 230 kV. a. Apply fault at the Amarillo 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |

| Cont. No. | Cont. Name | Description |
|-----------|------------------------------------|---|
| 38 | FLT40-3PH | 3 phase fault on the Amarillo South (524415) to Nichols (524044) 230 kV line circuit 1, near Amarillo South. a. Apply fault at the Amarillo South 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 39 | FLT41-3PH | 3 phase fault on the Amarillo South (524415) to Randal (524365) 230 kV line circuit 1, near Amarillo South. a. Apply fault at the Amarillo South 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 40 | FLT42-SB | Single phase fault with stuck breaker at Swisher (525213) a. Apply fault at the Swisher 230 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Swisher 230 kV (525213)/ 115 kV (525212)/13.2 kV (525211) transformer d. Swisher (525213) – Tuco2 (560021) 230 kV |
| 41 | FLT43-3PH | 3 phase fault on the Rio Blanco 345 kV (560027) to Tuco (525832) 345 kV line circuit 1, near Rio Blanco. a. Apply fault at the Rio Blanco 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 42 | FLT44-3PH | 3 phase fault on the Rio Blanco 345 kV (560027) to OKU (511456) 345 kV line circuit 1, near Rio Blanco. a. Apply fault at the Rio Blanco 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 43 | FLT45-3PH | 3 phase fault on the Tuco Int (525832) to Border (515458) 345 kV line circuit 1, near Tuco. a. Apply fault at the Tuco 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 44 | FLT46-3PH | 3 phase fault on the Tuco 345 kV (525832) to Tuco 230 kV (525830) to Tuco 13.2 kV (525824) XFMR CKT 1, near Tuco 345 kV bus. a. Apply fault at the Tuco 345 kV bus. b. Clear fault after 5 cycles by tripping the transformer |
| 45 | FLT47-3PH (20WP, 20SP, 25SP) | 3 phase fault on the Tuco (525832) to Yoakam (526936) 345 kV line circuit 1, near Tuco. a. Apply fault at the Tuco (525832) 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|--|
| 46 | FLT48-3PH | 3 phase fault on the OKU (511456) to Oklaun (599891) 345 kV line circuit 1, near OKU. a. Apply fault at the OKU 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line and remove the fault. c. Block the DC tie at OKU. |
| 47 | FLT49-3PH | 3 phase fault on the OKU (511456) to L.E.S (511468) 345 kV line circuit 1, near OKU. a. Apply fault at the OKU 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 48 | FLT50-PO | Prior Outage of the Tuco 345 kV (525832) to Tuco 230 kV (525830) to Tuco 13.2 kV (525824) XFMR CKT 1; 3 phase fault on the Rio Blanco 345 kV (560027) to OKU (511456) 345 kV line circuit 1, near Rio Blanco. a. Apply fault at the Rio Blanco 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 49 | FLT51-PO | Prior Outage of the Tuco 345 kV (525832) to Tuco 230 kV (525830) to Tuco 13.2 kV (525824) XFMR CKT 1; 3 phase fault on the Tuco Int (525832) to Border (515458) 345 kV line circuit 1, near Tuco. a. Apply fault at the Tuco 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 50 | FLT52-3PH | 3 phase fault on the Plant X (525481) to Deaf Smith (524623) 230 kV line circuit 1, near Plant X. a. Apply fault at the Plant X 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 51 | FLT54-3PH | 3 phase fault on the Deaf Smith (524623) to Bushland (524267) 230 kV line circuit 1, near Deaf Smith. a. Apply fault at the Deaf Smith 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 52 | FLT55-3PH | 3 phase fault on the Deaf Smith 230 kV (524623) to Deaf Smith 115 kV (524622) to Deaf Smith 13.2 kV (524620) XFMR CKT 1, near Deaf Smith 230 kV. a. Apply fault at the Deaf Smith 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 53 | FLT56-3PH | 3 phase fault on the Plant X (525481) to Tolk East (525524) 230 kV line circuit 2, near Plant X. a. Apply fault at the Plant X 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 54 | FLT57-3PH | 3 phase fault on the Plant X (525481) to Newhart (525461) 230 kV line circuit 1, near Plant X. a. Apply fault at the Plant X 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|--|
| 55 | FLT58-3PH | 3 phase fault on the Plant X (525481) to Tolk West (525531) 230 kV line circuit 1, near Plant X. a. Apply fault at the Plant X 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 56 | FLT59-3PH | 3 phase fault on the Plant X (525481) to Sundown (526435) 230 kV line circuit 1, near Plant X. a. Apply fault at the Plant X 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 57 | FLT60-3PH | 3 phase fault on the Plant X 230 kV (525481) to Plant X 115 kV (525480) to Plant X 13.2 kV (525479) XFMR CKT 1, near Plant X 230 kV. a. Apply fault at the Plant X 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 58 | FLT61-SB | Single phase fault with stuck breaker on the Tolk West (525531) to Plant X (525481) 230 kV circuit #1 line, near Tolk West. a. Apply fault at the Tolk West 230 kV bus. b. Run 5 cycles, and then open Plant X end of the faulted line. c. Run 10 cycles, and then clear the fault and disconnect Tolk West 230 kV bus (525531). |
| 59 | FLT62-SB | Single phase fault with stuck breaker on the Tolk East (525524) to Plant X (525481) 230 kV line circuit #2, near Tolk East. a. Apply fault at the Tolk East 230 kV bus. b. Run 5 cycles, and then open Plant X end of the faulted line. c. Run 10 cycles, and then clear the fault and disconnect Tolk East 230 kV bus (525524). |
| 60 | FLT63-3PH | 3 phase fault on the Mustang (527149) to Amocowasson (526784) 230 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 61 | FLT64-3PH | 3 phase fault on the Mustang 230 kV (527149) to Mustang 115 kV (527146) to Mustang 13.2 kV (527143) XFMR CKT 1, near Mustang 230 kV. a. Apply fault at the Mustang 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 62 | FLT65-3PH | 3 phase fault on the Mustang (527149) to Yoakum (526935) 230 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|---|
| 63 | FLT66-3PH | 3 phase fault on the Mustang (527149) to Seminole (527276) 230 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 64 | FLT67-3PH | 3 phase fault on the Seminole 230 kV (527276) to Seminole 115 kV (527275) to Seminole 13.2 kV (527273) XFMR CKT 1, near Seminole 230 kV. a. Apply fault at the Seminole 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 65 | FLT68-3PH | 3 phase fault on the Amocowasson (526784) to OxyBru Tap (527010) 230 kV line circuit 1, near Amocowasson. a. Apply fault at the Amocowasson 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 66 | FLT69-3PH | 3 phase fault on the Yoakum (526935) to G13-027-TAP (562480) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 67 | FLT70-3PH | 3 phase fault on the Yoakum 230 kV (526935) to Yoakum 115 kV (526934) to Yoakum 13.2 kV (526932) XFMR CKT 2, near Yoakum 230 kV. a. Apply fault at the Yoakum 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 68 | FLT71-3PH | 3 phase fault on the Mustang (527146) to Denver North (527130) 115 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 69 | FLT72-3PH | 3 phase fault on the Mustang (527146) to Seagraves (527202) 115 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 70 | FLT73-3PH | 3 phase fault on the Mustang (527146) to Denver South (527136) 115 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

| Cont. No. | Cont. Name | Description |
|-----------|-------------------------------------|--|
| 71 | FLT74-3PH (2017SP & 2025SP Only) | 3 phase fault on the Mustang (527146) to Shell Co (527062) 115 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 72 | FLT75-3PH | 3 phase fault on the Yoakum (526935) to Amoco-SS (526460) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 73 | FLT76-3PH | 3 phase fault on the Yoakum (526935) to OxyBru Tap (527010) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 74 | FLT77-3PH | 3 phase fault on the Yoakum (526935) to GEN-2015-079 Tap (560059) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 75 | FLT78-SB | Single phase fault with stuck breaker at Mustang (527149) a. Apply fault at the Mustang 230 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Mustang 230 kV (527149) /115 kV (527146)/13.2 kV (527143) transformer d. Mustang (527149) - Amocowasson (526784) 230 kV |
| 76 | FLT79-SB | Single phase fault with stuck breaker on the Tolk West (525531) to GEN-2013-027 (562480) 230 kV line, near Tolk West. a. Apply fault at the Tolk West 230 kV bus. b. Run 5 cycles, and then open GEN-2013-027 end of the faulted line. c. Run 10 cycles, and then clear the fault and disconnect Tolk West 230 kV bus (525531). |
| 77 | FLT80-SB | Single phase fault with stuck breaker on the Yoakum (526935) to GEN-2013-027 (562480) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230 kV bus. b. Run 5 cycles, and then open GEN-2013-027 end of the faulted line. c. Run 10 cycles, and then clear the fault and open Yoakum end of the line in (b) and trip Yoakum (526935) to Yoakum 115 (526934)/13.2 kV (526931) transformer circuit #1. |
| 78 | FLT81-SB | Single phase fault with stuck breaker on the Yoakum (526935) to Amoco-SS (526460) 230 kV line, near Yoakum. a. Apply fault at the Yoakum 230 kV bus. b. Run 5 cycles, and then open Amoco-SS end of the faulted line. c. Run 10 cycles, and then clear the fault and trip Yoakum 230 kV (526935) bus. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|--|
| 79 | FLT82-PO | Prior Outage of the Mustang (527149) to Seminole (527276) 230 kV line circuit 1; 3 phase fault on the Mustang (527149) to Yoakum (526935) 230 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 80 | FLT83-PO | Prior Outage of the Mustang (527149) to Yoakum (526935) 230 kV line circuit 1; 3 phase fault on the Mustang (527149) to Seminole (527276) 230 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 81 | FLT84-3PH | 3 phase fault on the Woodward (515375) to Chisholm (511553) 345 kV line circuit 1, near Border. a. Apply fault at the Woodward 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 82 | FLT85-3PH | 3 phase fault on the Tuco (525830) to Carlisle (526161) 230 kV line circuit 1, near Tuco. a. Apply fault at the Tuco 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 83 | FLT86-3PH | 3 phase fault on the Tuco (525830) to Tolk East (525524) 230 kV line circuit 1, near Tuco. a. Apply fault at the Tuco 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 84 | FLT87-3PH | 3 phase fault on the Tuco (525830) to Jones (526337) 230 kV line circuit 1, near Tuco. a. Apply fault at the Tuco 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 85 | FLT88-3PH | 3 phase fault on the Tuco 230 kV (525830) to Tuco 115 kV (525828) to Tuco 13.2 kV (525819) XFMR CKT 2, near Tuco 230 kV. a. Apply fault at the Tuco 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 86 | FLT89-PO | Prior Outage of the Tuco 345 kV (525832) to Tuco 230 kV (525830) to Tuco 13.2 kV (525824) XFMR CKT 1; 3 phase fault on the Tuco 345 kV (525832) to Tuco 230 kV (525830) to Tuco 13.2 kV (525825) XFMR CKT 2, near Tuco 345 kV. a. Apply fault at the Tuco 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 87 | FLT90-PO | Prior Outage of the Tuco 345 kV (525832) to Tuco 230 kV (525830) to Tuco 13.2 kV (525825) XFMR CKT 2; 3 phase fault on the Tuco 345 kV (525832) to Tuco 230 kV (525830) to Tuco 13.2 kV (525824) XFMR CKT 1, near Tuco 345 kV. a. Apply fault at the Tuco 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|---|
| 88 | FLT91-SB | Single phase fault with stuck breaker at Tuco (525832) a. Apply fault at the Tuco 345 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Tuco 345 kV (525832) /230 kV (525830) /13.2 kV (525824) transformer d. Tuco (525832) - Rio Blanco (560027) 345 kV |
| 89 | FLT92-3PH | 3 phase fault on the Crossroads (527656) to Tolk (525549) 345 kV line circuit 1, near Crossroads. a. Apply fault at the Crossroads 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 90 | FLT93-3PH | 3 phase fault on the Crossroads (527656) to Eddy County (527802) 345 kV line circuit 1, near Crossroads. a. Apply fault at the Crossroads 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 91 | FLT94-3PH | 3 phase fault on the Tolk 345 kV (525549) to Tolk Tap 230 kV (525543) to Tolk 13.2 kV (525537) XFMR CKT 1, near Tolk 345 kV. a. Apply fault at the Tolk 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer |
| 92 | FLT95-3PH | 3 phase fault on the Eddy County 345 kV (527802) to Eddy North 230 kV (527799) to Eddy 13.2 kV (527796) XFMR CKT 1, near Eddy County 345 kV. a. Apply fault at the Eddy County 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer |
| 93 | FLT96-3PH | 3 phase fault on the Atoka (527786) to CV-Dayton (527821) 115 kV line circuit 1, near Atoka. a. Apply fault at the Atoka 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 94 | FLT97-3PH | 3 phase fault on the Atoka (527786) to CV-Irishhill (528116) 115 kV line circuit 1, near Atoka. a. Apply fault at the Atoka 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 95 | FLT98-3PH | 3 phase fault on the Atoka (527786) to Eagle Creek (527711) 115 kV line circuit 1, near Atoka. a. Apply fault at the Atoka 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|---|
| 96 | FLT99-3PH | 3 phase fault on the CV-Dayton (527821) to Eddy South (527793) 115 kV line circuit 1, near CV-Dayton. a. Apply fault at the CV-Dayton 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 97 | FLT100-3PH | 3 phase fault on the CV-Irishhill (528116) to CV-Lakewood (528109) 115 kV line circuit 1, near CV-Irishhill. a. Apply fault at the CV-Irishhill 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 98 | FLT101-3PH | 3 phase fault on the Eagle Creek (527711) to Seven Rivers (528094) 115 kV line circuit 1, near Eagle Creek. a. Apply fault at the Eagle Creek 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 99 | FLT102-3PH | 3 phase fault on the Eagle Creek (527711) to Eddy North (527798) 115 kV line circuit 1, near Eagle Creek. a. Apply fault at the Eagle Creek 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 100 | FLT103-PO | Prior Outage of the Atoka (527786) to CV-Dayton (527821) 115 kV line circuit 1; 3 phase fault on the Atoka (527786) to Eagle Creek (527711) 115 kV line circuit 1, near Atoka. a. Apply fault at the Atoka 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 101 | FLT104-PO | Prior Outage of the Atoka (527786) to Eagle Creek (527711) 115 kV line circuit 1; 3 phase fault on the Atoka (527786) to CV-Dayton (527821) 115 kV line circuit 1, near Atoka. a. Apply fault at the Atoka 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 102 | FLT105-3PH | 3 phase fault on the Carlisle (526160) to LP-Doud Tap (526162) 115 kV line circuit 1, near Carlisle. a. Apply fault at the Carlisle 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 103 | FLT106-3PH | 3 phase fault on the Carlisle 115 kV (526160) to Carlisle 230 kV (526161) to Carlisle 13.2 kV (526157) XFMR CKT 1, near Carlisle 115 kV bus. a. Apply fault at the Carlisle 115 kV bus. b. Clear fault after 5 cycles by tripping the transformer |

| Cont. No. | Cont. Name | Description |
|-----------|------------|--|
| 104 | FLT107-3PH | 3 phase fault on the Carlisle (526160) to SP-Erskine (526109) 115 kV line circuit 1, near Carlisle. a. Apply fault at the Carlisle 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 105 | FLT108-3PH | 3 phase fault on the Carlisle (526160) to Murphy (526192) 115 kV line circuit 1, near Carlisle. a. Apply fault at the Carlisle 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 106 | FLT109-3PH | 3 phase fault on the GEN-2015-077 Tap (560058) to Terry County (526736) 115 kV line circuit 1, near GEN-2015-077 Tap. a. Apply fault at the GEN-2015-077 Tap 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 107 | FLT110-3PH | 3 phase fault on the GEN-2015-077 Tap (560058) to LG-Clauene (526491) 115 kV line circuit 1, near GEN-2015-077 Tap. a. Apply fault at the GEN-2015-077 Tap 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 108 | FLT111-3PH | 3 phase fault on the Terry County (526736) to Prentice (526792) 115 kV line circuit 1, near Terry County. a. Apply fault at the Terry County 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 109 | FLT112-3PH | 3 phase fault on the Terry County (526736) to Denver North (527130) 115 kV line circuit 1, near Terry County. a. Apply fault at the Terry County 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 110 | FLT113-3PH | 3 phase fault on the Terry County (526736) to Sulphur (527262) 115 kV line circuit 1, near Terry County. a. Apply fault at the Terry County 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 111 | FLT114-3PH | 3 phase fault on the Terry County 115 kV (526736) to Terry County 69 kV (526735) to Terry County 13.2 kV (526733) XFMR CKT 1, near Terry County 115 kV. a. Apply fault at the Terry County 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |

| Cont. No. | Cont. Name | Description |
|-----------|------------|---|
| 112 | FLT115-3PH | 3 phase fault on the Terry County (526736) to Wolf Forth (526524) 115 kV line circuit 1, near Terry County. a. Apply fault at the Terry County 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 113 | FLT116-3PH | 3 phase fault on the LG-Clauene (526491) to LG-Leveland (526484) 115 kV line circuit 1, near LG-Clauene. a. Apply fault at the LG-Clauene 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 114 | FLT117-3PH | 3 phase fault on the Seagraves (527202) to Sulphur (527262) 115 kV line circuit 1, near Seagraves. a. Apply fault at the Seagraves 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 115 | FLT118-3PH | 3 phase fault on the Seagraves (527202) to LG-Plshill (527194) 115 kV line circuit 1, near Seagraves. a. Apply fault at the Seagraves 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 116 | FLT119-3PH | 3 phase fault on the Denver South (527136) to San Andreas (527105) 115 kV line circuit 1, near Denver South. a. Apply fault at the Denver South 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 117 | FLT120-3PH | 3 phase fault on the Denver South (527136) to Shell C2 (527036) 115 kV line circuit 1, near Denver South. a. Apply fault at the Denver South 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 118 | FLT121-3PH | 3 phase fault on the Denver South 115 kV (527136) to Denver City 69 kV (527125) to Denver South 13.2 kV (527123) XFMR CKT 2, near Denver South 115 kV. a. Apply fault at the Denver South 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 119 | FLT122-PO | Prior Outage of the Mustang 115 kV (527146) to Mustang 230 kV (527149) to Mustang 13.2 kV (527143) XFMR CKT 1; 3 phase fault on the Mustang (527146) to Denver South (527136) 115 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |

| Cont. No. | Cont. Name | Description |
|-----------|--------------------|---|
| 120 | FLT123-PO | Prior Outage of the Mustang 115 kV (527146) to Mustang 230 kV (527149) to Mustang 13.2 kV (527143) XFMR CKT 1; 3 phase fault on the Mustang (527146) to Denver North (527130) 115 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 121 | FLT124-PO | Prior Outage of the Mustang (527146) to Denver South (527136) 115 kV line circuit 1; 3 phase fault on the Mustang (527146) to Denver North (527130) 115 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 122 | FLT125-PO | Prior Outage of the Mustang (527146) to Denver North (527130) 115 kV line circuit 1; 3 phase fault on the Mustang (527146) to Denver South (527136) 115 kV line circuit 1, near Mustang. a. Apply fault at the Mustang 115 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 123 | FLT126-3PH | 3 phase fault on the GEN-2015-079 Tap (560059) to Hobbs (527894) 230 kV line circuit 1, near GEN-2015-079 Tap. a. Apply fault at the GEN-2015-079 Tap 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 124 | FLT127-3PH | 3 phase fault on the Hobbs (527894) to Andrews (528604) 230 kV line circuit 1, near Hobbs. a. Apply fault at the Hobbs 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 125 | FLT128-3PH | 3 phase fault on the Hobbs (527894) to Cunningham (527865) 230 kV line circuit 1, near Hobbs. a. Apply fault at the Hobbs 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 126 | FLT129-3PH | 3 phase fault on the Hobbs 230 kV (527894) to Hobbs 115 kV (527891) to Hobbs 13.2 kV (527889) XFMR CKT 2, near Hobbs 230 kV. a. Apply fault at the Hobbs 230 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer. |
| 127 | FLT130-PO (2025SP) | Prior Outage of the GEN-2015-079 Tap (560059) to Hobbs (527894) 230 kV line circuit 1; 3 phase fault on the Yoakum (526936) to Tuco (525832) 345 kV line circuit 1, near Yoakum. a. Apply fault at the Yoakum 345 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. |
| 128 | FLT131-SB | Single phase fault with stuck breaker at Chaves County (527482) a. Apply fault at the Chaves 115 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Chaves County 230 kV (527483)/ 115 kV (527482)/13.2 kV (527478) transformer d. Chaves County (527482) - Urton (527501) 115 kV |

| Cont. No. | Cont. Name | Description |
|-----------|------------------------------------|--|
| 129 | FLT132-SB | Single phase fault with stuck breaker at Bailey Co (525028) a. Apply fault at the Bailey County 115 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Bailey County 115 kV (525028)/ 69 kV (525027)/13.2 kV (525026) transformer d. Bailey County (525028) - G15-018T (560032) 115 kV |
| 130 | FLT133-SB | Single phase fault with stuck breaker at Oasis (524874) a. Apply fault at the Oasis 115 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Oasis (524874) - FE-CHZPLT (524863) 115 kV d. Oasis (524874) - Portales (524924) 115 kV |
| 131 | FLT134-SB | Single phase fault with stuck breaker at Amarillo South (524415) a. Apply fault at the Amarillo South 230 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Amarillo South (524415) - Nichols (524044) 230 kV d. Amarillo South (524415) - Randall (524365) 230 kV |
| 132 | FLT135-SB (20WP, 20SP, 25SP) | Single phase fault with stuck breaker at Tuco Int (525832) a. Apply fault at the Tuco Int 345 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Tuco Int (525832) - Border (515458) 345 kV d. Tuco Int (525832) - Yoakum (526936) 345 kV |
| 133 | FLT136-SB | Single phase fault with stuck breaker at Deafsmith (524623) a. Apply fault at the Deafsmith 230 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Deafsmith 230 kV (524623)/115 kV (524622)/13.8 kV (524620) transformer d. Deafsmith (524623) - Bushland (524267) 230 kV |
| 134 | FLT137-SB | Single phase fault with stuck breaker at Mustang (527149) a. Apply fault at the Mustang 230 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Mustang (527149) - Seminole (527276) 230 kV d. Mustang (527149) - Yoakum (526935) 230 kV |
| 135 | FLT138-SB | Single phase fault with stuck breaker at Crossroads (527656) a. Apply fault at the Crossroads 345 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Crossroads (527656) - Eddy County (527802) 345 kV d. Crossroads (527656) - Tolk (525549) 345 kV |
| 136 | FLT139-SB | Single phase fault with stuck breaker at Atoka (527786) a. Apply fault at the Atoka 115 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Atoka (527786) - Eagle Creek (527711) 115 kV d. Atoka (527786) - Irish Hill (528116) 115 kV |
| 137 | FLT140-SB | Single phase fault with stuck breaker at Carlisle (526160) a. Apply fault at the Carlisle 115 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Carlisle (526160) - Murphy (526192) 115 kV d. Carlisle (526160) - Erskine (526109) 115 kV |

| Cont. No. | Cont. Name | Description |
|-----------|------------|--|
| 138 | FLT141-SB | Single phase fault with stuck breaker at Terry County (526736) a. Apply fault at the Terry County 115 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Terry County (526736) - Wolfforth (526524) 115 kV d. Terry County (526736) - Denver (527130) 115 kV |
| 139 | FLT142-SB | Single phase fault with stuck breaker at Mustang (527146) a. Apply fault at the Mustang 115 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Mustang (527146) - Seagraves (527202) 115 kV d. Mustang (527146) - Denver S (527136) 115 kV |
| 140 | FLT143-SB | Single phase fault with stuck breaker at Hobbs (527894) a. Apply fault at the Hobbs 230 kV bus. b. Clear fault after 16 cycles and trip the following elements c. Hobbs (527894) - Andrews (528604) 230 kV d. Hobbs (527894) - Cunningham (527865) 230 kV |

SECTION 3: STABILITY ANALYSIS

The objective of the Stability Analysis was to determine the impacts of the generator interconnections on the stability and voltage recovery on the SPP transmission system. If problems with stability or voltage recovery were identified, the need for reactive compensation or system upgrades was investigated.

3.1 Approach

SPP provided MEPPi with the following five power flow cases¹:

- MDWG15-16WP_DIS15021_G06
- MDWG15-17SP_DIS15021_G06
- MDWG15-20SP_DIS15021_G06
- MDWG15-20WP_DIS15021_G06
- MDWG15-25SP_DIS15021_G06

Each case was examined prior to the Stability Analysis to ensure the case contained the proposed study projects and any previously queued projects listed in Tables 2-1 and 2-2 respectively. There was no suspect power flow data in the study area. The dynamic datasets were also verified and stable initial system conditions (i.e., “flat lines”) were achieved. Three-phase and single phase-to-ground faults listed in Table 2-3 were examined. Single-phase fault impedances were calculated

¹ The models include certain upgrades that SPP identified as necessary prior to starting the analysis

for each season to result in a voltage of approximately 60% of the pre-fault voltage. Refer to Table 3-1 for a list of the calculated single-phase fault impedances utilized.

**Table 3-1
Calculated Single-Phase Fault Impedances**

| Cont. No.* | Cont. Name | Single-Phase Fault Impedance (MVA) | | | | |
|------------|------------|------------------------------------|-------------|-------------|-------------|-------------|
| | | 2016 Winter | 2017 Summer | 2020 Summer | 2020 Winter | 2025 Summer |
| 8 | FLT10-SB | -812.5 | -812.5 | -812.5 | -812.5 | -812.5 |
| 40 | FLT42-SB | -2609.4 | -2609.4 | -2609.4 | -2812.5 | 2609.4 |
| 58 | FLT61-SB | -6875.0 | -6168.8 | -6875.0 | -6875.0 | -6875.0 |
| 59 | FLT62-SB | -6875.0 | -6468.8 | -6875.0 | -6875.0 | -6875.0 |
| 75 | FLT78-SB | -3625.0 | -3625.0 | -4234.4 | -4234.4 | -4234.4 |
| 76 | FLT79-SB | -6875.0 | -6468.8 | -6875.0 | -6875.0 | -6875.0 |
| 77 | FLT80-SB | -3625.0 | -3625.0 | -4437.5 | -4437.5 | -4437.5 |
| 78 | FLT81-SB | -3625.0 | -3625.0 | -4437.5 | -4437.5 | -4437.5 |
| 88 | FLT91-SB | -4437.5 | -4843.8 | -6062.5 | -5250.0 | -6062.5 |
| 128 | FLT131-SB | -812.5 | -812.5 | -812.5 | -812.5 | -812.5 |
| 129 | FLT132-SB | -812.5 | -812.5 | -937.5 | -1000.0 | -937.5 |
| 130 | FLT133-SB | -1312.5 | -1250.0 | -1312.5 | -1312.5 | -1312.5 |
| 131 | FLT134-SB | -3421.9 | -3625.0 | -3625.0 | -3625.0 | -3625.0 |
| 132 | FLT135-SB | -4437.5 | -4843.8 | -6062.5 | -5250.0 | 6062.5 |
| 133 | FLT136-SB | -1875.0 | -1750.0 | -1875.0 | -1875.0 | -1875.0 |
| 134 | FLT137-SB | -3625.0 | -3625.0 | -4234.4 | -4234.4 | -4234.4 |
| 135 | FLT138-SB | -2101.6 | -2101.6 | -2203.1 | -2203.1 | -2203.1 |
| 136 | FLT139-SB | -812.5 | -875.0 | -937.5 | -937.5 | -937.5 |
| 137 | FLT140-SB | -1625.0 | -1750.0 | -1750.0 | -1750.0 | -1750.0 |
| 138 | FLT141-SB | -1375.0 | -1375.0 | -1375.0 | -1375.0 | -1375.0 |
| 139 | FLT142-SB | -2812.5 | -2812.5 | -3015.6 | -3015.6 | -2812.5 |
| 140 | FLT143-SB | -3015.6 | -3828.1 | -4843.8 | -4843.8 | -5250.0 |

*Refer to Table 2-3 for a description of the contingency

Bus voltages, machine rotor angles, and previously queued generation in the study area were monitored in addition to bus voltages and machine rotor angles in the following areas:

- 520 AEPW
- 524 OKGE
- 525 WFEC
- 526 SPS
- 531 MIDW
- 534 SUNC
- 536 WERE

Requested and previously queued generation outside the above study area was also monitored.

The results of the analysis determined if reactive compensation or system upgrades were required to obtain acceptable system performance. If additional reactive compensation was required, the size, type, and location were determined. The proposed reactive reinforcements would ensure the wind or solar farm meets FERC Order 661A low voltage requirements and return the wind or solar farm to its pre-disturbance operating voltage. If the results indicated the need for fast responding reactive support, dynamic support such as an SVC or STATCOM was investigated. If tripping of the prior queued projects was observed during the stability analysis (for under/over voltage or under/over frequency) the simulations were re-ran with the prior queued project's voltage and frequency tripping disabled.

3.2 Stability Analysis Results

The Stability Analysis determined that there were multiple contingencies across all seasons that resulted in system/voltage instability, generation tripping offline, and poor post-fault voltage recovery when all generation interconnection requests were at 100% output.

Refer to Table 3-2 for a summary of the Stability Analysis results for the contingencies listed in Table 2-3. Table 3-2 is a summary of the stability results for the 2016 Winter Peak, 2017 Summer Peak, 2020 Summer Peak, 2020 Winter Peak, and 2025 Summer Peak conditions and states whether the system remained stable or generation tripped offline, if acceptable voltage recovery was observed after the fault was cleared, and if the voltage recovered to above 0.9 p.u. and below 1.1 p.u. post fault steady-state conditions. Voltage recovery criteria includes ensuring that the transient voltage recovery is between 0.7 p.u. and 1.2 p.u. and ending in a steady-state voltage (for N-1 contingencies) at the pre-contingent level or at least above 0.9 p.u. and below 1.1. p.u.

Refer to Appendix B, Appendix C, Appendix D, Appendix E, and Appendix F for a complete set of plots for all contingencies for 2016 Winter Peak, 2017 Summer Peak, 2020 Summer Peak, 2020 Winter Peak, and 2025 Summer Peak conditions, respectively.

Table 3-2
Stability Analysis Summary of Results for 2016 Winter, 2017 Summer, 2020 Summer, 2020 Winter,
and 2025 Summer Peak Conditions

| Cont. No. | Cont. Name | 2016 Winter Peak | | | | 2017 Summer Peak | | | | 2020 Summer Peak | | | | 2020 Winter Peak | | | | 2025 Summer Peak | | | |
|-----------|------------|--------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|------------------|
| | | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability |
| | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | |
| 1 | FLT01-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 2 | FLT02-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 3 | FLT03-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 4 | FLT04-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 5 | FLT05-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 6 | FLT06-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 7 | FLT07-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 8 | FLT10-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 9 | FLT11-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 10 | FLT12-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 11 | FLT13-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 12 | FLT14-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 13 | FLT15-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 14 | FLT16-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 15 | FLT17-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 16 | FLT18-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 17 | FLT19-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 18 | FLT20-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 19 | FLT21-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 20 | FLT22-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 21 | FLT23-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 22 | FLT24-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 23 | FLT25-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 24 | FLT26-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 25 | FLT27-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 26 | FLT28-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 27 | FLT29-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 28 | FLT30-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 29 | FLT31-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 30 | FLT32-PO | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 31 | FLT33-PO | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 32 | FLT34-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 33 | FLT35-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 34 | FLT36-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 35 | FLT37-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 36 | FLT38-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 37 | FLT39-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 38 | FLT40-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |

Note 1: Generator tripping observed

Note 2: Poor voltage damping

Note 3: Low voltage observed as a result of a radial system not serving load

Table 3-2 (continued)
**Stability Analysis Summary of Results for 2016 Winter, 2017 Summer, 2020 Summer, 2020 Winter,
 and 2025 Summer Peak Conditions**

| Cont. No. | Cont. Name | 2016 Winter Peak | | | | 2017 Summer Peak | | | | 2020 Summer Peak | | | | 2020 Winter Peak | | | | 2025 Summer Peak | | | |
|-----------|-------------------------|---------------------|------------------------|---------------------------------|------------------|---------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|------------------|---------------------|------------------------|---------------------------------|-----------------------|--------------------|------------------------|---------------------------------|------------------|
| | | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability |
| | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | |
| 39 | FLT41-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 40 | FLT42-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 41 | FLT43-3PH | - | - | V > 1.1 p.u. | Gen Trip | - | - | V > 1.1 p.u. | Gen Trip | - | - | V > 1.1 p.u. | Gen Trip | - | - | V > 1.1 p.u. | Gen Trip | - | - | V > 1.1 p.u. | Gen Trip |
| 42 | FLT44-3PH | - | - | V > 1.1 p.u. | Unstable | - | - | V > 1.1 p.u. V < 0.9 p.u. | Stable | - | - | V > 1.1 p.u. | Stable | - | - | V > 1.1 p.u. | Unstable ² | - | - | Compliant | Stable |
| 43 | FLT45-3PH | - | - | V < 0.9 p.u. | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Unstable ² | - | - | Compliant | Stable |
| 44 | FLT46-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 45 | FLT47-3PH (2025SP) | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | - | - | Compliant | Stable |
| 46 | FLT48-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 47 | FLT49-3PH | Voltage Instability | | | | Voltage Instability | | | | - | - | V > 1.1 p.u. | Gen Trip | Voltage Instability | | | | - | - | V > 1.1 p.u. | Stable |
| 48 | FLT50-PO | Voltage Instability | | | | - | - | V > 1.1 p.u. V < 0.9 p.u. | Stable | - | - | V > 1.1 p.u. | Stable | Voltage Instability | | | | - | - | Compliant | Stable |
| 49 | FLT51-PO | - | - | V < 0.9 p.u. | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | Voltage Instability | | | | - | - | Compliant | Stable |
| 50 | FLT52-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 51 | FLT54-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 52 | FLT55-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 53 | FLT56-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 54 | FLT57-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 55 | FLT58-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 56 | FLT59-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 57 | FLT60-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 58 | FLT61-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 59 | FLT62-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 60 | FLT63-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 61 | FLT64-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 62 | FLT65-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 63 | FLT66-3PH | - | - | Compliant | Stable | - | - | Compliant ³ | Stable | - | - | Compliant ³ | Stable | - | - | Compliant ³ | Stable | - | - | V < 0.9 p.u. | Stable |
| 64 | FLT67-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 65 | FLT68-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 66 | FLT69-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 67 | FLT70-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 68 | FLT71-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 69 | FLT73-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 70 | FLT72-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 71 | FLT74-3PH (17SP & 25SP) | N/A | N/A | N/A | N/A | No | No | No | Yes | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | - | - | Compliant | Stable |

Note 1: Generator tripping observed

Note 2: Poor voltage damping

Note 3: Low voltage observed as a result of a radial system not serving load

Table 3-2 (continued)
Stability Analysis Summary of Results for 2016 Winter, 2017 Summer, 2020 Summer, 2020 Winter,
and 2025 Summer Peak Conditions

| Cont. No. | Cont. Name | 2016 Winter Peak | | | | 2017 Summer Peak | | | | 2020 Summer Peak | | | | 2020 Winter Peak | | | | 2025 Summer Peak | | | |
|-----------|------------|--------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|-----------------------|--------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|------------------|
| | | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability |
| | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | |
| 72 | FLT75-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 73 | FLT76-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 74 | FLT77-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 75 | FLT78-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 76 | FLT79-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 77 | FLT80-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 78 | FLT81-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 79 | FLT82-PO | - | - | Compliant | Stable | - | - | Compliant ³ | Stable | - | - | Compliant ³ | Stable | - | - | Compliant ³ | Stable | - | - | Compliant | Stable |
| 80 | FLT83-PO | - | - | Compliant | Stable | - | - | Compliant ³ | Stable | - | - | Compliant ³ | Stable | - | - | Compliant ³ | Stable | - | - | V < 0.9 p.u. | Stable |
| 81 | FLT84-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 82 | FLT85-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 83 | FLT86-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 84 | FLT87-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 85 | FLT88-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 86 | FLT89-PO | - | - | Compliant | Stable | - | - | Compliant | Unstable ² | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 87 | FLT90-PO | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 88 | FLT91-SB | - | - | V > 1.1 p.u. | Gen Trip | - | - | V > 1.1 p.u. | Gen Trip | - | - | V > 1.1 p.u. | Gen Trip | - | - | V > 1.1 p.u. | Gen Trip | - | - | V > 1.1 p.u. | Gen Trip |
| 89 | FLT92-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 90 | FLT93-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 91 | FLT94-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 92 | FLT95-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 93 | FLT96-3PH | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip |
| 94 | FLT97-3PH | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip |
| 95 | FLT98-3PH | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip |
| 96 | FLT99-3PH | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip |
| 97 | FLT100-3PH | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip |
| 98 | FLT101-3PH | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 99 | FLT102-3PH | - | - | Compliant | Gen Trip | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 100 | FLT103-PO | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip |
| 101 | FLT104-PO | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip | - | - | Compliant | Gen Trip |
| 102 | FLT105-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 103 | FLT106-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 104 | FLT107-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 105 | FLT108-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 106 | FLT109-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 107 | FLT110-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |

Note 1: Generator tripping observed

Note 2: Poor voltage damping

Note 3: Low voltage observed as a result of a radial system not serving load

Table 3-2 (continued)
Stability Analysis Summary of Results for 2016 Winter, 2017 Summer, 2020 Summer, 2020 Winter,
and 2025 Summer Peak Conditions

| Cont. No. | Cont. Name | 2016 Winter Peak | | | | 2017 Summer Peak | | | | 2020 Summer Peak | | | | 2020 Winter Peak | | | | 2025 Summer Peak | | | |
|-----------|--------------------|--------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|------------------|--------------------|------------------------|---------------------------------|-----------------------|--------------------|------------------------|---------------------------------|------------------|
| | | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability |
| | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | | Less than .70 p.u. | Greater than 1.20 p.u. | | |
| 108 | FLT111-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 109 | FLT112-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 110 | FLT113-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 111 | FLT114-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 112 | FLT115-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 113 | FLT116-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 114 | FLT117-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 115 | FLT118-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 116 | FLT119-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 117 | FLT120-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 118 | FLT121-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 119 | FLT122-PO | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 120 | FLT123-PO | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 121 | FLT124-PO | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 122 | FLT125-PO | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 123 | FLT126-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 124 | FLT127-3PH | - | - | Compliant | Stable | - | - | Yes ³ | Stable | - | - | Compliant | Stable | - | - | Yes ³ | Yes | - | - | Yes ³ | Stable |
| 125 | FLT128-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 126 | FLT129-3PH | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 127 | FLT130-PO (2025SP) | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | - | - | Compliant | Stable |
| 128 | FLT131-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 129 | FLT132-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 130 | FLT133-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 131 | FLT134-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 132 | FLT135-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | V < 0.9 p.u. | Unstable ² | - | - | Compliant | Stable |
| 133 | FLT136-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 134 | FLT137-SB | - | - | Compliant | Stable | - | - | Yes ³ | Stable | - | - | Yes ³ | Stable | - | - | Yes ³ | Stable | - | - | Yes ³ | Stable |
| 135 | FLT138-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 136 | FLT139-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 137 | FLT140-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 138 | FLT141-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 139 | FLT142-SB | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |
| 140 | FLT143-SB | - | - | Compliant | Stable | - | - | Yes ³ | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable | - | - | Compliant | Stable |

Note 1: Generator tripping observed

Note 2: Poor voltage damping

Note 3: Low voltage observed as a result of a radial system not serving load

The following faults were observed to have system/voltage instability, generation tripping offline, and/or poor post-fault steady-state voltages:

- **FLT43-3PH:** 3PH fault resulting in the loss of Rio Blanco to Tuco 345 kV (All study years)
- **FLT44-3PH:** 3PH fault resulting in the loss of Rio Blanco to OKU 345 kV (16WP, 17SP, 20SP, 20WP)
- **FLT45-3PH:** 3PH fault resulting in the loss of Tuco to Border 345 kV (16WP, 20WP)
- **FLT49-3PH:** 3PH fault resulting in the loss of OKU to LES 345 kV (All study years)
- **FLT50-PO:** Prior outage of Tuco 345/230 kV transformer followed by a 3PH fault resulting in the loss of Rio Blanco to OKU 345 kV (16WP, 17SP, 20SP, 20WP)
- **FLT51-PO:** Prior outage of Tuco 345/230 kV transformer followed by a 3PH fault resulting in the loss of Tuco to Border 345 kV (16WP, 20WP)
- **FLT66-3PH:** 3PH fault resulting in the loss of Mustang to Seminole 230 kV (17SP, 20SP, 20WP, 25SP)
- **FLT82-PO:** Prior outage of Mustang to Seminole 230 kV followed by a 3PH fault resulting in the loss of Mustang to Yoakum 230 kV (17SP, 20SP, 20WP, 25SP)
- **FLT83-PO:** Prior outage of Mustang to Yoakum 230 kV followed by a 3PH fault resulting in the loss of Mustang to Seminole 230 kV (17SP, 20SP, 20WP, 25SP)
- **FLT89-PO:** Prior outage Tuco 345/230 kV transformer followed by 3-PH fault resulting in the loss of Tuco 345/230 kV transformer #2 (17SP)
- **FLT91-SB:** 1PH stuck breaker fault resulting in the loss of Tuco 345/230 kV transformer and Tuco to Rio Blanco 345 kV (All study years)
- **FLT96-3PH:** 3PH fault resulting in the loss of Atoka to CV-Dayton 115 kV (All study years)
- **FLT97-3PH:** 3PH fault resulting in the loss of Atoka to CV-Irish Hill 115 kV (All study years)
- **FLT98-3PH:** 3PH fault resulting in the loss of Atoka to Eagle Creek 116 kV (All study years)
- **FLT99-3PH:** 3PH fault resulting in the loss of CV-Dayton to Eddy South 115 kV (All study years)
- **FLT100-3PH:** 3PH fault resulting in the loss of CV-Irish Hill to CV-Lakewood 115 kV (All study years)
- **FLT101-3PH:** 3PH fault resulting in the loss of Eagle Creek to Seven Rivers 115 kV (16WP, 17SP)
- **FLT102-3PH:** 3PH fault resulting in the loss of Eagle Creek to Eddy North 115 kV (16WP, 17SP)
- **FLT103-PO:** Prior outage of Atoka to CV-Dayton 115 kV followed by a 3PH fault resulting in the loss of Atoka to Eagle Creek 115 kV (All study years)

-
- **FLT104-PO:** Prior outage of Atoka to Eagle Creek 115 kV followed by a 3PH fault resulting in the loss of Atoka to CV-Dayton 115 kV (All study years)
 - **FLT127-3PH:** 3PH fault resulting in the loss of Hobbs to Andrews 230 kV (17SP, 20WP, 25SP)
 - **FLT135-SB:** 1PH stuck breaker fault resulting in the loss of Tuco to Border 345 kV and Tuco to Yoakum 345 kV (20WP)
 - **FLT137-SB:** 1PH stuck breaker fault resulting in the loss of Mustang to Seminole 230 kV and Mustang to Yoakum 230 kV (17SP, 20SP, 20WP, 25SP)
 - **FLT143-SB:** 1PH stuck breaker fault resulting in the loss of Hobbs to Andrews 230 kV and Hobbs to Cunningham 230 kV (17SP)

Note for the following faults, the post-fault steady-steady voltage violations are not a concern because the bus in violation is at the end of a radial line segment and is not serving load (except 25SP):

- **FLT66-3PH:** 3PH fault resulting in the loss of Mustang to Seminole 230 kV (17SP, 20SP, 20WP, 25SP)
- **FLT82-PO:** Prior outage of Mustang to Seminole 230 kV followed by a 3PH fault resulting in the loss of Mustang to Yoakum 230 kV (20SP, 20WP, 25SP)
- **FLT83-PO:** Prior outage of Mustang to Yoakum 230 kV followed by a 3PH fault resulting in the loss of Mustang to Seminole 230 kV (17SP, 20SP, 20WP, 25SP)
- **FLT127-3PH:** 3PH fault resulting in the loss of Hobbs to Andrews 230 kV (17SP, 25SP)
- **FLT137-SB:** 1PH stuck breaker fault resulting in the loss of Mustang to Seminole 230 kV and Mustang to Yoakum 230 kV (17SP, 20SP, 20WP, 25SP)
- **FLT143-SB:** 1PH stuck breaker fault resulting in the loss of Hobbs to Andrews 230 kV and Hobbs to Cunningham 230 kV (17SP)

Refer to Figure 3-1 and Figure 3-2 for a one-line diagram of the post-fault topology near Seminole 230 kV and Andrews 230 kV, respectively. It can be observed that both buses are at the end of a radial segment and do not serve load, therefore, are not a cause for concern.

- Seminole – Mustang 115 kV circuit #1

FLT43-3PH, a 3PH fault resulting in the loss of Rio Blanco to Tuco 345 kV, was observed to have voltages above 1.1 p.u. post fault steady-state, poor voltage damping, and generation tripping offline (due to high voltage protection settings). Refer to Figure 3-3 for a representative comparison plot of Oklaunion and Border area voltages for the 2016 Winter Peak case with and without system upgrades. Refer to Figure 3-4 for comparison plot of GEN-2014-074’s real power for the 2016 Winter Peak case with and without system upgrades. Note for the voltage to settle below 1.1 p.u. at the Oklaunion 345 kV bus for post fault steady-state conditions, the capacitor bank at Oklaunion 345 kV is required to be switched offline.




Figure 3-3: Representative plot of Oklaunion and Border area voltages for 2016 Winter Peak conditions with and without system upgrades.




Figure 3-4: Comparison plot of GEN-2014-074's real power for 2016 Winter Peak conditions with and without system upgrades.

FLT44-3PH, a 3PH fault resulting in the loss of Rio Blanco to OKU 345 kV, was observed to have voltage instability (growing voltage oscillations near Border 345 kV). Refer to Figure 3-5 for a representative comparison plot of Oklaunion and Border 345 kV bus voltages for the 2016 Winter Peak case with and without system upgrades.




Figure 3-5: Representative plot of Border and Tuco 345 kV voltages for 2016 Winter Peak conditions with and without system upgrades.

For the 25SP case, low voltages were observed in the Seminole and Mustang 230 kV area for faults resulting in the loss of Seminole to Mustang 230 kV or Mustang to Yoakum 230 kV. With the addition of the Seminole to Mustang 115 kV circuit #1, these low voltage were mitigated. Refer to Figure 3-6 for a representative comparison plot of bus voltages in the Seminole 230 kV area for FLT66-3PH (3PH fault resulting in loss of Seminole to Mustang 230 kV circuit #1) with and without system upgrades.




Figure 3-6: Representative plot of Seminole 230 kV bus voltages for 2025 Summer Peak conditions with and without system upgrades.

For faults FLT96 through FLT104, which are three-phase faults at Atoka 115 kV and adjacent buses, GEN-2015-058 trips offline due to over frequency and over voltage protection. For this study, the over frequency and over voltage protection of the TMEIC photovoltaic inverter model (ITMEIC) were set to 75 Hz and 1.8 p.u., respectively, to avoid instantaneous tripping. It is recommended the developer of the TMEIC photovoltaic inverter model examine this model for three-phase faults that cause the model to trip on over frequency and over voltage protection.

After the upgrades were implemented, the Stability Analysis was re-simulated to determine system stability. With the required upgrade, the Stability Analysis determined that there was no wind turbine tripping or system instability as a result of interconnected all study projects at 100% output.

SECTION 4: SHORT CIRCUIT ANALYSIS

The objective of this task is to quantify the three-phase to ground fault currents for the 2017 Summer Peak and 2025 Summer Peak seasons for each interconnecting generator.

4.1 Approach

The short-circuit analysis will assess breaker adequacy and fault duties for the generator interconnection bus and five buses away from the point of interconnection. MEPPi will assume no outages to find maximum short-circuit currents that flow through the breaker. The Automatic Sequencing Fault Calculation (ASCC) function in PSS/E was utilized to perform this task. FLAT conditions were applied to pre-fault conditions and the following adjustments were utilized:

- All synchronous and asynchronous machine P and Q output was set to zero
- All transformer tap ratios were set to 1.0 p.u. and all phase shift angles were set to zero
- All generator reactance's were fixed to the subtransient reactance
- All line charging was set to zero
- All shunts were set to zero
- All loads were set to zero
- All pre-fault bus voltages were set to 1.0 p.u. and a phase shift angle of zero

Note upgrades found to be necessary for the Stability Analysis were included in the Short-Circuit Analysis.

4.2 Short Circuit Results: 2017 Summer Peak

The maximum fault current for each bus is provided for the 2017 Summer Peak conditions. The following tables show the short circuit results for the study generators for the 2017 Summer Peak condition:

- Table 4-1: Short Circuit Analysis for GEN-2015-020 (17SP)
- Table 4-2: Short Circuit Analysis for GEN-2015-031 (17SP)
- Table 4-3: Short Circuit Analysis for GEN-2015-056 (17SP)
- Table 4-4: Short Circuit Analysis for GEN-2015-058 (17SP)
- Table 4-5: Short Circuit Analysis for GEN-2015-068 (17SP)
- Table 4-6: Short Circuit Analysis for GEN-2015-075 (17SP)
- Table 4-7: Short Circuit Analysis for GEN-2015-079 and GEN-2015-080 (17SP)

Table 4-1
Short Circuit Analysis for Study Project GEN-2015-020 (17SP)

| Study Generator GEN-2015-020 | | | | | | | | | | | |
|------------------------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 524486 | CAPROCK 3 | 115 | 2.86 | 524863 | FE-CHZPLT 3 | 115 | 7.72 | 525531 | TOLK_WEST 6 | 230 | 25.84 |
| 524502 | NORTON 3 | 115 | 2.72 | 524874 | OASIS 3 | 115 | 9.57 | 525543 | TOLK_TAP 6 | 230 | 25.84 |
| 524509 | FE-TUCMCARI3 | 115 | 1.93 | 524875 | OASIS 6 | 230 | 7.30 | 525637 | LAMB_CNTY 6 | 230 | 5.34 |
| 524662 | PARMER_CO 3 | 115 | 4.10 | 524885 | SN_JUAN_TAP6 | 230 | 4.64 | 525830 | TUCO_INT 6 | 230 | 22.92 |
| 524669 | DS-#20 3 | 115 | 4.83 | 524889 | SN_JUAN_WND6 | 230 | 4.45 | 527481 | CHAVES_CNTY2 | 69 | 2.26 |
| 524764 | NORRIS_TP 3 | 115 | 10.72 | 524908 | ROOSEVELT 3 | 115 | 10.33 | 527482 | CHAVES_CNTY3 | 115 | 6.18 |
| 524768 | PLSNT_HILL 3 | 115 | 9.87 | 524909 | ROSEVELT_N 6 | 230 | 8.76 | 527483 | CHAVES_CNTY6 | 230 | 3.99 |
| 524770 | PLSNT_HILL 6 | 230 | 6.09 | 524911 | ROSEVELT S 6 | 230 | 8.76 | 527501 | URTON 3 | 115 | 5.25 |
| 524773 | E_CLOVIS 3 | 115 | 8.51 | 524915 | SW_4K33 6 | 230 | 8.76 | 527546 | SAMSON 3 | 115 | 4.91 |
| 524776 | N_CLOVIS_TP3 | 115 | 7.16 | 524923 | PORTALES 2 | 69 | 7.13 | 527793 | EDDY_STH 3 | 115 | 10.18 |
| 524777 | N_CLOVIS 3 | 115 | 6.49 | 524924 | PORTALES 3 | 115 | 7.24 | 527799 | EDDY_NORTH 6 | 230 | 7.28 |
| 524783 | W_CLOVIS 2 | 69 | 2.42 | 524929 | RO-PORT_MTR2 | 69 | 7.13 | 527800 | EDDY_SOUTH 6 | 230 | 7.28 |
| 524784 | W_CLOVIS 3 | 115 | 6.11 | 524934 | ZODIAC 2 | 69 | 5.31 | 527802 | EDDY_CNTY 7 | 345 | 4.11 |
| 524790 | CANNON_TP 3 | 115 | 5.82 | 524935 | KILGORE 3 | 115 | 5.65 | 560032 | G15-018T | 115 | 5.19 |
| 524794 | CANNONAFB 3 | 115 | 5.47 | 524941 | PORTALES#1 2 | 69 | 5.50 | 562480 | G13-027-TAP | 230 | 9.13 |
| 524797 | PERIMETER 3 | 115 | 6.34 | 524948 | PORTALES#2 2 | 69 | 4.68 | 583280 | ASGI2012-002 | 115 | 1.05 |
| 524801 | NORRIS 3 | 115 | 9.83 | 524962 | S_PORTALES 2 | 69 | 4.17 | 583950 | GEN-2014-033 | 115 | 6.18 |
| 524808 | FE-CLVS_INT3 | 115 | 6.68 | 524976 | MARKET_ST 2 | 69 | 3.95 | 583970 | GEN-2014-035 | 115 | 5.89 |
| 524821 | CURRY 2 | 69 | 4.37 | 525019 | EMU&VLY_TP 3 | 115 | 6.09 | 584620 | GEN-2015-020 | 115 | 9.33 |
| 524822 | CURRY 3 | 115 | 10.75 | 525027 | BAILEYCO 2 | 69 | 5.38 | 599955 | PNM-DC6 | 230 | 8.76 |
| 524831 | FE-HOLLAND 3 | 115 | 8.76 | 525028 | BAILEYCO 3 | 115 | 5.99 | 599960 | EPTNP-D6 | 230 | 7.28 |
| 524838 | FE-CLOVIS2 3 | 115 | 10.17 | 525481 | PLANT_X 6 | 230 | 22.25 | | | | |
| 524846 | FARWELL 2 | 69 | 2.08 | 525524 | TOLK_EAST 6 | 230 | 25.84 | | | | |

Table 4-2
Short Circuit Analysis for Study Project GEN-2015-031 (17SP)

| Study Generator GEN-2015-031 | | | | | | | | | | | |
|------------------------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 511456 | O.K.U.-7 | 345 | 5.46 | 524185 | PIERCE_TP 3 | 115 | 18.96 | 525480 | PLANT_X 3 | 115 | 21.23 |
| 511553 | CHISHOLM7 | 345 | 12.26 | 524224 | MANHATTAN 3 | 115 | 18.36 | 525481 | PLANT_X 6 | 230 | 22.25 |
| 515458 | BORDER 7 | 345 | 10.18 | 524266 | BUSHLAND 3 | 115 | 9.33 | 525524 | TOLK_EAST 6 | 230 | 25.84 |
| 522800 | MU-TULIA 3 | 115 | 5.09 | 524267 | BUSHLAND 6 | 230 | 9.63 | 525531 | TOLK_WEST 6 | 230 | 25.84 |
| 522823 | LP-MILWAKEE6 | 230 | 10.03 | 524282 | 34TH_ST 3 | 115 | 14.90 | 525543 | TOLK_TAP 6 | 230 | 25.84 |
| 522828 | LP-MILWAKEE2 | 69 | 7.49 | 524290 | WILDOR2_JUS6 | 230 | 6.60 | 525549 | TOLK 7 | 345 | 6.98 |
| 522861 | LP-SOUTHST6 | 230 | 13.76 | 524296 | SPNSPUR_WND7 | 345 | 4.45 | 525636 | LAMB_CNTY 3 | 115 | 8.51 |
| 522866 | LP-COOK 2 | 69 | 30.52 | 524306 | COULTER 3 | 115 | 15.13 | 525637 | LAMB_CNTY 6 | 230 | 5.34 |
| 522870 | LP-HOLLY 6 | 230 | 14.76 | 524321 | GEORGIA 2 | 69 | 6.64 | 525731 | SP-ABERNTHY2 | 69 | 3.02 |
| 522888 | LP-WADSWRTH6 | 230 | 12.05 | 524322 | GEORGIA 3 | 115 | 16.32 | 525738 | HALECENTER 2 | 69 | 2.46 |
| 523095 | HITCHLAND 6 | 230 | 14.86 | 524331 | PULLMAN 3 | 115 | 7.10 | 525779 | FLOYD_CNTY 2 | 69 | 5.31 |
| 523097 | HITCHLAND 7 | 345 | 15.59 | 524338 | SOUTHEAST 3 | 115 | 10.97 | 525780 | FLOYD_CNTY 3 | 115 | 6.03 |
| 523221 | XT_INTG 6 | 230 | 2.60 | 524345 | OSAGE 3 | 115 | 13.72 | 525816 | TUCO_INT2 2 | 69 | 4.67 |
| 523267 | PRINGLE 6 | 230 | 4.26 | 524364 | RANDALL 3 | 115 | 20.81 | 525826 | TUCO_INT 2 | 69 | 7.92 |
| 523308 | MOORE_E 3 | 115 | 10.99 | 524365 | RANDALL 6 | 230 | 14.20 | 525828 | TUCO_INT 3 | 115 | 20.01 |
| 523309 | MOORE_CNTY 6 | 230 | 6.69 | 524377 | FARMERS 3 | 115 | 15.05 | 525830 | TUCO_INT 6 | 230 | 22.92 |
| 523332 | EXELL_TP 3 | 115 | 4.81 | 524388 | CROUSE_HIND3 | 115 | 15.05 | 525832 | TUCO_INT 7 | 345 | 13.36 |
| 523339 | FAIN 3 | 115 | 5.27 | 524397 | ARROWHEAD 3 | 115 | 13.55 | 525840 | ANTELOPE 1 6 | 230 | 22.74 |
| 523344 | BLKHAWK_W 3 | 115 | 11.81 | 524404 | OWENSCORN 3 | 115 | 14.76 | 525853 | LH-WIL&ELLN2 | 69 | 2.58 |
| 523377 | RIVERVIEW 3 | 115 | 13.27 | 524414 | AMA_SOUTH 3 | 115 | 16.55 | 525885 | SP-NEWDEAL 2 | 69 | 3.39 |
| 523410 | CRMWA_#4 3 | 115 | 9.70 | 524415 | AMA_SOUTH 6 | 230 | 13.39 | 525926 | CROSBY 3 | 115 | 4.49 |
| 523485 | CAMX/AGR TP3 | 115 | 13.90 | 524425 | ESTACADO_TP3 | 115 | 13.17 | 526076 | STANTON_W 3 | 115 | 9.40 |
| 523494 | MEREDITH 3 | 115 | 7.72 | 524432 | ESTACADO 3 | 115 | 11.60 | 526109 | SP-ERSKINE 3 | 115 | 11.41 |
| 523543 | HUTCHISON 2 | 69 | 9.04 | 524516 | CANYON_WEST3 | 115 | 4.91 | 526146 | INDIANA 3 | 115 | 9.75 |
| 523544 | HUTCH_N 3 | 115 | 15.58 | 524522 | CANYON_E_TP3 | 115 | 5.15 | 526159 | CARLISLE 2 | 69 | 2.57 |
| 523546 | HUTCH_S 3 | 115 | 15.58 | 524523 | CANYON_EAST3 | 115 | 4.79 | 526160 | CARLISLE 3 | 115 | 13.24 |
| 523551 | HUTCHISON 6 | 230 | 7.19 | 524530 | PALO_DURO 3 | 115 | 6.54 | 526161 | CARLISLE 6 | 230 | 10.68 |
| 523636 | GRAY_CNTY 3 | 115 | 3.90 | 524544 | SPRING_DRW 3 | 115 | 6.36 | 526162 | LP-DOUD_TP 3 | 115 | 11.67 |
| 523748 | BOWERS 3 | 115 | 6.88 | 524622 | DEAFSMITH 3 | 115 | 11.95 | 526192 | MURPHY 3 | 115 | 10.67 |
| 523770 | GRAPEVINE 3 | 115 | 7.89 | 524623 | DEAFSMITH 6 | 230 | 7.70 | 526268 | LUBBCK_STH 3 | 115 | 18.90 |
| 523771 | GRAPEVINE 6 | 230 | 5.73 | 524694 | DS-#22 3 | 115 | 4.96 | 526269 | LUBBCK_STH 6 | 230 | 17.45 |
| 523776 | WHEELER 3 | 115 | 6.41 | 524734 | DS-#21 3 | 115 | 10.79 | 526297 | LUBBCK_EST 2 | 69 | 8.03 |
| 523777 | WHEELER 6 | 230 | 5.87 | 524745 | CASTRO_CNTY2 | 69 | 9.59 | 526298 | LUBBCK_EST 3 | 115 | 15.21 |
| 523779 | STLN-DEMARC6 | 230 | 7.02 | 524746 | CASTRO_CNTY3 | 115 | 11.64 | 526299 | LUBBCK_EST 6 | 230 | 12.89 |
| 523815 | LLANO_WND 3 | 115 | 9.43 | 524909 | ROSEVELT_N 6 | 230 | 8.76 | 526337 | JONES 6 | 230 | 19.72 |
| 523817 | MIDSTRM_TP 3 | 115 | 6.71 | 524911 | ROSEVELT_S 6 | 230 | 8.76 | 526434 | SUNDOWN 3 | 115 | 11.48 |
| 523869 | CHAN/TASCOS6 | 230 | 3.84 | 524915 | SW_4K33 6 | 230 | 8.76 | 526435 | SUNDOWN 6 | 230 | 10.95 |
| 523928 | MARTIN 3 | 115 | 7.47 | 525019 | EMU&VLY_TP 3 | 115 | 6.09 | 526460 | AMOCO_SS 6 | 230 | 9.62 |
| 523931 | HIGHLAND_TP3 | 115 | 11.36 | 525050 | BC-KELLEY 3 | 115 | 8.36 | 526524 | WOLFFORTH 3 | 115 | 11.51 |
| 523959 | POTTER_CO 6 | 230 | 20.20 | 525056 | BC-EARTH 3 | 115 | 8.78 | 526525 | WOLFFORTH 6 | 230 | 13.12 |
| 523961 | POTTER_CO 7 | 345 | 7.42 | 525124 | HART_INDUST3 | 115 | 7.58 | 526676 | GRASSLAND 3 | 115 | 6.12 |
| 523977 | HARRNG_WST 6 | 230 | 25.94 | 525154 | HAPPY_INT 3 | 115 | 5.35 | 526677 | GRASSLAND 6 | 230 | 6.41 |
| 523978 | HARRNG_MID 6 | 230 | 25.94 | 525179 | TULIA_TP 3 | 115 | 6.29 | 526679 | CIRRUS_WND 6 | 230 | 5.00 |
| 523979 | HARRNG_EST 6 | 230 | 25.94 | 525191 | KRESS_INT 2 | 69 | 4.43 | 526935 | YOAKUM 6 | 230 | 17.12 |
| 524007 | ROLLHILLS 3 | 115 | 19.29 | 525192 | KRESS_INT 3 | 115 | 11.16 | 526936 | YOAKUM_345 | 345 | 8.47 |
| 524009 | CHERRY 3 | 115 | 18.45 | 525203 | SW-KRESS 2 | 69 | 4.43 | 527896 | HOBBS_INT 7 | 345 | 7.14 |
| 524010 | ROLLHILLS 6 | 230 | 19.24 | 525212 | SWISHER 3 | 115 | 10.31 | 560027 | G14-074-TAP | 345 | 6.71 |
| 524016 | ASARCO 3 | 115 | 26.38 | 525213 | SWISHER 6 | 230 | 10.48 | 560050 | G15-031-TAP | 230 | 9.03 |
| 524018 | ASARCO_TP 3 | 115 | 28.52 | 525224 | KRESS_RURL 2 | 69 | 2.51 | 562004 | G11-025-TAP | 115 | 4.60 |
| 524043 | NICHOLS 3 | 115 | 30.48 | 525225 | KRESS_RURAL3 | 115 | 6.24 | 562480 | G13-027-TAP | 230 | 9.13 |
| 524044 | NICHOLS 6 | 230 | 25.21 | 525257 | N_PLAINVEV 3 | 115 | 5.08 | 583090 | G1149&G1504 | 345 | 8.37 |
| 524058 | WHITAKER 3 | 115 | 21.85 | 525326 | COX 3 | 115 | 5.89 | 583340 | GEN-2012-020 | 230 | 9.20 |
| 524079 | CONWAY 3 | 115 | 5.00 | 525414 | LAMTON 3 | 115 | 7.80 | 584220 | GEN-2014-040 | 115 | 10.35 |
| 524088 | KIRBY 3 | 115 | 5.42 | 525446 | SPGLAKE_TP3 | 115 | 10.60 | 584440 | GEN-2014-074 | 345 | 6.31 |
| 524106 | NORTHWEST 3 | 115 | 11.24 | 525453 | HALE_CNTY 2 | 69 | 6.92 | 584640 | GEN-2015-022 | 115 | 10.31 |
| 524136 | HASTINGS 3 | 115 | 13.69 | 525454 | HALE_CNTY 3 | 115 | 10.17 | 584750 | GEN-2015-031 | 230 | 9.03 |
| 524162 | EAST_PLANT 3 | 115 | 22.83 | 525460 | NEWHART 3 | 115 | 15.13 | 585060 | GEN-2015-068 | 345 | 10.65 |
| 524163 | EAST_PLANT 6 | 230 | 13.64 | 525461 | NEWHART 6 | 230 | 10.87 | 599955 | PNM-DC6 | 230 | 8.76 |

Table 4-3
Short Circuit Analysis for Study Project GEN-2015-056 (17SP)

| Study Generator GEN-2015-056 | | | | | | | | | | | |
|------------------------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 524623 | DEAFSMITH 6 | 230 | 7.70 | 526161 | CARLISLE 6 | 230 | 10.68 | 527963 | POTASH_JCT 6 | 230 | 6.31 |
| 524770 | PLSNT_HILL 6 | 230 | 6.09 | 526337 | JONES 6 | 230 | 19.72 | 528070 | CV-AZMESA 3 | 115 | 6.66 |
| 524875 | OASIS 6 | 230 | 7.30 | 526435 | SUNDOWN 6 | 230 | 10.95 | 528094 | 7-RIVERS 3 | 115 | 7.49 |
| 524885 | SN_JUAN_TAP6 | 230 | 4.64 | 526935 | YOAKUM 6 | 230 | 17.12 | 528095 | 7-RIVERS 6 | 230 | 5.51 |
| 524889 | SN_JUAN_WND6 | 230 | 4.45 | 527481 | CHAVES_CNTY2 | 69 | 2.26 | 528132 | OCOTILLO 3 | 115 | 5.35 |
| 524908 | ROOSEVELT 3 | 115 | 10.33 | 527482 | CHAVES_CNTY3 | 115 | 6.18 | 528137 | N_CANAL 3 | 115 | 7.14 |
| 524909 | ROSEVELT_N 6 | 230 | 8.76 | 527483 | CHAVES_CNTY6 | 230 | 3.99 | 528160 | CARLSBAD 3 | 115 | 8.68 |
| 524911 | ROSEVELT_S 6 | 230 | 8.76 | 527501 | URTON 3 | 115 | 5.25 | 528178 | PECOS 3 | 115 | 9.15 |
| 524915 | SW_4K33 6 | 230 | 8.76 | 527546 | SAMSON 3 | 115 | 4.91 | 528179 | PECOS 6 | 230 | 5.70 |
| 525213 | SWISHER 6 | 230 | 10.48 | 527597 | TWEEDY 3 | 115 | 4.68 | 528226 | HOP1_SUB 3 | 115 | 3.91 |
| 525461 | NEWHART 6 | 230 | 10.87 | 527656 | CROSSROADS 7 | 345 | 5.42 | 562480 | G13-027-TAP | 230 | 9.13 |
| 525480 | PLANT_X 3 | 115 | 21.23 | 527711 | EAGLE_CREEK3 | 115 | 6.84 | 577103 | GEN-2008-022 | 345 | 5.13 |
| 525481 | PLANT_X 6 | 230 | 22.25 | 527786 | ATOKA 3 | 115 | 6.59 | 577104 | G08-022-WEST | 345 | 4.81 |
| 525524 | TOLK_EAST 6 | 230 | 25.84 | 527793 | EDDY_STH 3 | 115 | 10.18 | 583340 | GEN-2012-020 | 230 | 9.20 |
| 525531 | TOLK_WEST 6 | 230 | 25.84 | 527798 | EDDY_NTH 3 | 115 | 10.18 | 583840 | GEN-2013-027 | 230 | 8.12 |
| 525543 | TOLK_TAP 6 | 230 | 25.84 | 527799 | EDDY_NORTH 6 | 230 | 7.28 | 583950 | GEN-2014-033 | 115 | 6.18 |
| 525549 | TOLK 7 | 345 | 6.98 | 527800 | EDDY_SOUTH 6 | 230 | 7.28 | 583970 | GEN-2014-035 | 115 | 5.89 |
| 525636 | LAMB_CNTY 3 | 115 | 8.51 | 527802 | EDDY_CNTY 7 | 345 | 4.11 | 584260 | GEN-2014-047 | 345 | 4.38 |
| 525637 | LAMB_CNTY 6 | 230 | 5.34 | 527809 | CV-8_MILE 3 | 115 | 5.07 | 584940 | GEN-2015-056 | 345 | 4.79 |
| 525828 | TUCO_INT 3 | 115 | 20.01 | 527821 | CV-DAYTON 3 | 115 | 6.51 | 599955 | PNM-DC6 | 230 | 8.76 |
| 525830 | TUCO_INT 6 | 230 | 22.92 | 527864 | CUNNINGHAM 3 | 115 | 26.24 | 599960 | EPTNP-D6 | 230 | 7.28 |
| 525832 | TUCO_INT 7 | 345 | 13.36 | 527865 | CUNNINGHAM 6 | 230 | 16.06 | | | | |
| 525840 | ANTELOPE_1 6 | 230 | 22.74 | 527894 | HOBBS_INT 6 | 230 | 17.20 | | | | |

Table 4-4
Short Circuit Analysis for Study Project GEN-2015-058 (17SP)

| Study Generator GEN-2015-058 | | | | | | | | | | | |
|------------------------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 524885 | SN_JUAN_TAP6 | 230 | 4.64 | 527754 | CV-ARTESIA 2 | 69 | 3.07 | 527930 | PCA 3 | 115 | 8.14 |
| 527482 | CHAVES_CNTY3 | 115 | 6.18 | 527757 | ARTESIA_TP 2 | 69 | 3.64 | 527962 | POTASH_JCT 3 | 115 | 8.69 |
| 527483 | CHAVES_CNTY6 | 230 | 3.99 | 527761 | ARTESIA_W 2 | 69 | 3.32 | 527963 | POTASH_JCT 6 | 230 | 6.31 |
| 527534 | BRASHER_TP 3 | 115 | 4.98 | 527762 | ARTSA_CC_TP2 | 69 | 1.90 | 528003 | CV-DAGGR&IH2 | 69 | 1.62 |
| 527541 | CAPITAN 3 | 115 | 3.36 | 527763 | CV-W_ARTSIA2 | 69 | 1.60 | 528070 | CV-AZMESA 3 | 115 | 6.66 |
| 527546 | SAMSON 3 | 115 | 4.91 | 527768 | ARTESIA_CC 2 | 69 | 1.74 | 528076 | CV-WALTCYN 3 | 115 | 4.23 |
| 527563 | ROSWLL_INT 2 | 69 | 3.46 | 527772 | ARTSA_SR_TP2 | 69 | 1.97 | 528079 | CV-CONEBUTE3 | 115 | 3.17 |
| 527564 | ROSWLL_INT 3 | 115 | 5.00 | 527775 | ARTESIA_SR 2 | 69 | 1.90 | 528093 | 7-RIVERS 2 | 69 | 2.35 |
| 527597 | TWEEDY 3 | 115 | 4.68 | 527785 | ATOKA 2 | 69 | 2.33 | 528094 | 7-RIVERS 3 | 115 | 7.49 |
| 527656 | CROSSROADS 7 | 345 | 5.42 | 527786 | ATOKA 3 | 115 | 6.59 | 528095 | 7-RIVERS 6 | 230 | 5.51 |
| 527664 | CV-CTTNWOOD2 | 69 | 2.65 | 527793 | EDDY_STH 3 | 115 | 10.18 | 528109 | CV-LAKEWOOD3 | 115 | 5.97 |
| 527678 | SMITH 2 | 69 | 3.77 | 527798 | EDDY_NTH 3 | 115 | 10.18 | 528116 | CV-IRISHHIL3 | 115 | 5.99 |
| 527701 | ARTESIA 2 | 69 | 3.78 | 527799 | EDDY_NORTH 6 | 230 | 7.28 | 528132 | OCOTILLO 3 | 115 | 5.35 |
| 527707 | ARTESIA 3 | 115 | 6.33 | 527800 | EDDY_SOUTH 6 | 230 | 7.28 | 528137 | N_CANAL 3 | 115 | 7.14 |
| 527710 | EAGLE_CREEK2 | 69 | 2.29 | 527802 | EDDY_CNTY 7 | 345 | 4.11 | 528151 | FIESTA 3 | 115 | 7.77 |
| 527711 | EAGLE_CREEK3 | 115 | 6.84 | 527808 | CV-8_MILE 2 | 67 | 1.80 | 528159 | CARLSBAD 2 | 69 | 4.15 |
| 527715 | NAVAJO_2TP 3 | 115 | 6.55 | 527809 | CV-8_MILE 3 | 115 | 5.07 | 528160 | CARLSBAD 3 | 115 | 8.68 |
| 527717 | NAVAJO_2 3 | 115 | 6.47 | 527810 | CV-ABO 2 | 67 | 1.59 | 528178 | PECOS 3 | 115 | 9.15 |
| 527720 | NAVAJO_3 3 | 115 | 6.51 | 527811 | CV-KEWAN_TP3 | 115 | 2.82 | 528179 | PECOS 6 | 230 | 5.70 |
| 527733 | NAVAJO_1 2 | 69 | 2.15 | 527821 | CV-DAYTON 3 | 115 | 6.51 | 528182 | NORTH_LOVNG3 | 115 | 2.31 |
| 527736 | NAVAJO_5TP 3 | 115 | 6.51 | 527822 | CV-TURKYTRK3 | 115 | 3.31 | 528226 | HOP1_SUB 3 | 115 | 3.91 |
| 527739 | NAVAJO_4 3 | 115 | 6.50 | 527864 | CUNNINGHAM 3 | 115 | 26.24 | 584960 | GEN-2015-058 | 115 | 6.50 |
| 527743 | NAVAJO_5 3 | 115 | 6.50 | 527865 | CUNNINGHAM 6 | 230 | 16.06 | | | | |
| 527747 | ARTESIA_TWN2 | 69 | 2.11 | 527894 | HOBBS_INT 6 | 230 | 17.20 | | | | |

Table 4-5
Short Circuit Analysis for Study Project GEN-2015-068 (17SP)

| Study Generator GEN-2015-068 | | | | | | | | | | | |
|------------------------------|---------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 511423 | FLE TAP4 | 138 | 8.31 | 525225 | KRESS_RURAL3 | 115 | 6.24 | 526679 | CIRRUS_WND 6 | 230 | 5.00 |
| 511437 | COMANC-4 | 138 | 17.45 | 525272 | KISER 3 | 115 | 5.09 | 526694 | GRAHAM 3 | 115 | 2.68 |
| 511439 | LWSTAP 4 | 138 | 11.03 | 525291 | PLAINVW_TP 2 | 69 | 6.49 | 526736 | TERRY_CNTY 3 | 115 | 10.86 |
| 511456 | O.K.U.-7 | 345 | 5.46 | 525298 | S_PLAINVW 2 | 69 | 2.58 | 526784 | AMOCOWASSON6 | 230 | 13.69 |
| 511458 | ELKCTY-4 | 138 | 11.55 | 525325 | COX 2 | 69 | 3.36 | 526792 | PRENTICE 3 | 115 | 5.94 |
| 511466 | L.E.S.-2 | 69 | 16.33 | 525326 | COX 3 | 115 | 5.89 | 526928 | PLAINS_INT 3 | 115 | 9.83 |
| 511467 | L.E.S.-4 | 138 | 23.32 | 525413 | LAMTON 2 | 69 | 5.22 | 526934 | YOAKUM 3 | 115 | 16.64 |
| 511468 | L.E.S.-7 | 345 | 12.38 | 525414 | LAMTON 3 | 115 | 7.80 | 526935 | YOAKUM 6 | 230 | 17.12 |
| 511474 | SHERID4 | 138 | 11.84 | 525432 | SP-HALFWAY 2 | 69 | 5.87 | 526936 | YOAKUM_345 | 345 | 8.47 |
| 511486 | ELGINJ4 | 138 | 9.68 | 525440 | LC-S_OLTON 3 | 115 | 7.43 | 526944 | LG-PLAINS 3 | 115 | 7.92 |
| 511490 | ELKCTY6 | 230 | 7.81 | 525446 | SPGLAKE_TP3 | 115 | 10.60 | 527010 | OXYBRU_TP 6 | 230 | 13.70 |
| 511494 | COMMTAP4 | 138 | 20.55 | 525453 | HALE_CNTY 2 | 69 | 6.92 | 527018 | BENNETT 3 | 115 | 13.14 |
| 511541 | SWEETW6 | 230 | 7.82 | 525454 | HALE_CNTY 3 | 115 | 10.17 | 527041 | ARCO_TP 3 | 115 | 13.04 |
| 511542 | BUFFCK6 | 230 | 5.74 | 525460 | NEWHART 3 | 115 | 15.13 | 527047 | OXY_WILRD1 3 | 115 | 10.48 |
| 511544 | DEMPSEY6 | 230 | 4.94 | 525461 | NEWHART 6 | 230 | 10.87 | 527062 | SHELL_CO2 3 | 115 | 15.93 |
| 511547 | ROARK6 | 230 | 4.47 | 525480 | PLANT_X 3 | 115 | 21.23 | 527130 | DENVER_N 3 | 115 | 20.86 |
| 511553 | CHISHOLM7 | 345 | 12.26 | 525481 | PLANT_X 6 | 230 | 22.25 | 527136 | DENVER_S 3 | 115 | 20.86 |
| 511557 | CHISHOLM6 | 230 | 11.60 | 525524 | TOLK_EAST 6 | 230 | 25.84 | 527146 | MUSTANG 3 | 115 | 23.16 |
| 514785 | WOODWRD4 | 138 | 12.14 | 525531 | TOLK_WEST 6 | 230 | 25.84 | 527149 | MUSTANG 6 | 230 | 15.45 |
| 514796 | IODINE-4 | 138 | 7.20 | 525543 | TOLK_TAP 6 | 230 | 25.84 | 527151 | GS-MUSTANG 6 | 230 | 15.45 |
| 514801 | MINCO 7 | 345 | 16.24 | 525549 | TOLK 7 | 345 | 6.98 | 527194 | LG-PLSHILL 3 | 115 | 7.55 |
| 514901 | CIMARON7 | 345 | 27.65 | 525636 | LAMB_CNTY 3 | 115 | 8.51 | 527202 | SEAGRAVES 3 | 115 | 8.57 |
| 515136 | SUNNYSD7 | 345 | 9.88 | 525637 | LAMB_CNTY 6 | 230 | 5.34 | 527275 | SEMINOLE 3 | 115 | 14.43 |
| 515375 | WWRDEHV7 | 345 | 19.16 | 525724 | COUNTYLINE 2 | 69 | 2.21 | 527276 | SEMINOLE 6 | 230 | 7.65 |
| 515376 | WWRDEHV4 | 138 | 23.29 | 525731 | SP-ABERNTHY2 | 69 | 3.02 | 527656 | CROSSROADS 7 | 345 | 5.42 |
| 515394 | KEENAN 4 | 138 | 8.06 | 525738 | HALECENTER 2 | 69 | 2.46 | 527800 | EDDY_SOUTH 6 | 230 | 7.28 |
| 515398 | OUSPRT 4 | 138 | 8.86 | 525745 | LH-HALECTR 2 | 69 | 2.43 | 527864 | CUNNINHAM 3 | 115 | 26.24 |
| 515407 | TATONGA7 | 345 | 10.26 | 525769 | BARWISE 2 | 69 | 3.76 | 527865 | CUNNINHAM 6 | 230 | 16.06 |
| 515444 | MCNOWND7 | 345 | 16.20 | 525779 | FLOYD_CNTY 2 | 69 | 5.31 | 527891 | HOBBS_INT 3 | 115 | 29.89 |
| 515458 | BORDER 7 | 345 | 10.18 | 525780 | FLOYD_CNTY 3 | 115 | 6.03 | 527894 | HOBBS_INT 6 | 230 | 17.20 |
| 515549 | MNCWIND37 | 345 | 11.31 | 525790 | FLOYDADA_TP2 | 69 | 2.49 | 527896 | HOBBS_INT 7 | 345 | 7.14 |
| 515554 | BVRCNTY7 | 345 | 14.45 | 525811 | LH-HARMONY 2 | 69 | 4.25 | 527963 | POTASH_JCT 6 | 230 | 6.31 |
| 515599 | NBUFRG7 | 345 | 8.41 | 525816 | TUCO_INT2 2 | 69 | 4.67 | 528333 | LE-WEST_SUB3 | 115 | 8.54 |
| 515800 | GRACMNT7 | 345 | 15.72 | 525826 | TUCO_INT 2 | 69 | 7.92 | 528355 | MADDOX 3 | 115 | 25.33 |
| 515802 | GRACMNT4 | 138 | 25.99 | 525828 | TUCO_INT 3 | 115 | 20.01 | 528433 | NEW_NHOBBS 3 | 115 | 7.91 |
| 515997 | WWPAR4 | 138 | 16.93 | 525830 | TUCO_INT 6 | 230 | 22.92 | 528435 | MILLEN 3 | 115 | 11.30 |
| 520814 | ANADARK4 | 138 | 27.99 | 525832 | TUCO_INT 7 | 345 | 13.36 | 528602 | ANDREWS 3 | 115 | 7.93 |
| 521089 | WASHITA4 | 138 | 24.49 | 525840 | ANTELOPE_1 6 | 230 | 22.74 | 528604 | ANDREWS 6 | 230 | 6.02 |
| 522819 | LP-NORTHEST2 | 69 | 10.09 | 525853 | LH-WIL&ELLN2 | 69 | 2.58 | 528626 | LE-PLNSINT 2 | 69 | 4.36 |
| 522822 | LP-NORTHWEST2 | 69 | 4.34 | 525860 | SP-BECTON 2 | 69 | 2.29 | 539800 | CLARKCOUNTY7 | 345 | 11.52 |
| 522823 | LP-MILWAKEE6 | 230 | 10.03 | 525885 | SP-NEUDEAL 2 | 69 | 3.39 | 539801 | THISTLE7 | 345 | 15.19 |
| 522828 | LP-MILWAKEE2 | 69 | 7.49 | 525892 | WHITE&MONRO2 | 69 | 2.56 | 539804 | THISTLE4 | 138 | 16.22 |
| 522832 | LP-VICKSBRG2 | 69 | 11.44 | 525925 | CROSBY 2 | 69 | 4.77 | 560000 | G11-14-TAP | 345 | 13.36 |
| 522857 | LP-SOUTHEST2 | 69 | 21.47 | 525926 | CROSBY 3 | 115 | 4.49 | 560013 | G14-057T | 345 | 9.49 |
| 522861 | LP-SOUTHEST6 | 230 | 13.76 | 526076 | STANTON_W 3 | 115 | 9.40 | 560027 | G14-074-TAP | 345 | 6.71 |
| 522866 | LP-COOK 2 | 69 | 30.52 | 526109 | SP-ERSKINE 3 | 115 | 11.41 | 560033 | G1524&G1525T | 345 | 19.06 |
| 522870 | LP-HOLLY 6 | 230 | 14.76 | 526130 | SP-CARLISLE2 | 69 | 2.11 | 560050 | G15-031-TAP | 230 | 9.03 |
| 522879 | LP-WADSWRTH2 | 69 | 19.67 | 526146 | INDIANA 3 | 115 | 9.75 | 560059 | G1579&G1580T | 230 | 8.97 |
| 522888 | LP-WADSWRTH6 | 230 | 12.05 | 526159 | CARLISLE 2 | 69 | 2.57 | 562004 | G11-025-TAP | 115 | 4.60 |
| 523309 | MOORE_CNTY 6 | 230 | 6.69 | 526160 | CARLISLE 3 | 115 | 13.24 | 562075 | G11-051-TAP | 345 | 12.07 |
| 523779 | STLN-DEMARC6 | 230 | 7.02 | 526161 | CARLISLE 6 | 230 | 10.68 | 562480 | G13-027-TAP | 230 | 9.13 |
| 523869 | CHAN/TASCOS6 | 230 | 3.84 | 526162 | LP-DOUD_TP 3 | 115 | 11.67 | 581112 | GEN-2011-014 | 345 | 11.99 |
| 523959 | POTTER_CO 6 | 230 | 20.20 | 526176 | LP-DOUD 3 | 115 | 9.06 | 581137 | GEN-2011-025 | 115 | 4.60 |
| 523961 | POTTER_CO 7 | 345 | 7.42 | 526184 | SW_6878 2 | 69 | 2.16 | 582019 | GEN-2011-019 | 345 | 19.16 |
| 523979 | HARRNG_EST 6 | 230 | 25.94 | 526192 | MURPHY 3 | 115 | 10.67 | 582020 | GEN-2011-020 | 345 | 19.16 |
| 524010 | ROLLHILLS 6 | 230 | 19.24 | 526199 | SP-FRANKFRD3 | 115 | 9.68 | 583090 | G1149&G1504 | 345 | 8.37 |
| 524044 | NICHOLS 6 | 230 | 25.21 | 526213 | ALLEN 3 | 115 | 10.72 | 583110 | GEN-2011-051 | 345 | 12.07 |
| 524267 | BUSHLAND 6 | 230 | 9.63 | 526267 | LUBBCK_STH 2 | 69 | 4.35 | 583340 | GEN-2012-020 | 230 | 9.20 |
| 524365 | RANDALL 6 | 230 | 14.20 | 526268 | LUBBCK_STH 3 | 115 | 18.90 | 583819 | ASG2014-001 | 115 | 11.41 |
| 524414 | AMA_SOUTH 3 | 115 | 16.55 | 526269 | LUBBCK_STH 6 | 230 | 17.45 | 583840 | GEN-2013-027 | 230 | 8.12 |
| 524415 | AMA_SOUTH 6 | 230 | 13.39 | 526284 | PLANTERS 2 | 69 | 6.31 | 584070 | GEN-2014-057 | 345 | 6.58 |
| 524622 | DEAFSMITH 3 | 115 | 11.95 | 526297 | LUBBCK_EST 2 | 69 | 8.03 | 584440 | GEN-2014-074 | 345 | 6.31 |
| 524623 | DEAFSMITH 6 | 230 | 7.70 | 526298 | LUBBCK_EST 3 | 115 | 15.21 | 584640 | GEN-2015-022 | 115 | 10.31 |
| 524746 | CASTRO_CNTY3 | 115 | 11.64 | 526299 | LUBBCK_EST 6 | 230 | 12.89 | 584750 | GEN-2015-031 | 230 | 9.03 |
| 524770 | PLSNT_HILL 6 | 230 | 6.09 | 526310 | CLUTTER 2 | 69 | 5.44 | 584980 | GEN-2015-060 | 138 | 5.66 |
| 524875 | OASIS 6 | 230 | 7.30 | 526337 | JONES 6 | 230 | 19.72 | 585060 | GEN-2015-068 | 345 | 10.65 |
| 524908 | ROOSEVELT 3 | 115 | 10.33 | 526434 | SUNDOWN 3 | 115 | 11.48 | 585080 | GEN-2015-071 | 345 | 10.25 |

Table 4-5 (continued)
Short Circuit Analysis for Study Project GEN-2015-068 (17SP)

| Study Generator GEN-2015-056 | | | | | | | | | | | |
|------------------------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 524623 | DEAFSMITH 6 | 230 | 7.70 | 526161 | CARLISLE 6 | 230 | 10.68 | 527963 | POTASH_JCT 6 | 230 | 6.31 |
| 524770 | PLSNT_HILL 6 | 230 | 6.09 | 526337 | JONES 6 | 230 | 19.72 | 528070 | CV-AZMESA 3 | 115 | 6.66 |
| 524875 | OASIS 6 | 230 | 7.30 | 526435 | SUNDOWN 6 | 230 | 10.95 | 528094 | 7-RIVERS 3 | 115 | 7.49 |
| 524885 | SN_JUAN_TAP6 | 230 | 4.64 | 526935 | YOAKUM 6 | 230 | 17.12 | 528095 | 7-RIVERS 6 | 230 | 5.51 |
| 524889 | SN_JUAN_WND6 | 230 | 4.45 | 527481 | CHAVES_CNTY2 | 69 | 2.26 | 528132 | OCOTILLO 3 | 115 | 5.35 |
| 524908 | ROOSEVELT 3 | 115 | 10.33 | 527482 | CHAVES_CNTY3 | 115 | 6.18 | 528137 | N_CANAL 3 | 115 | 7.14 |
| 524909 | ROSEVELT_N 6 | 230 | 8.76 | 527483 | CHAVES_CNTY6 | 230 | 3.99 | 528160 | CARLSBAD 3 | 115 | 8.68 |
| 524911 | ROSEVELT_S 6 | 230 | 8.76 | 527501 | URTON 3 | 115 | 5.25 | 528178 | PECOS 3 | 115 | 9.15 |
| 524915 | SW_4K33 6 | 230 | 8.76 | 527546 | SAMSON 3 | 115 | 4.91 | 528179 | PECOS 6 | 230 | 5.70 |
| 525213 | SWISHER 6 | 230 | 10.48 | 527597 | TWEEDY 3 | 115 | 4.68 | 528226 | HOPI_SUB 3 | 115 | 3.91 |
| 525461 | NEWHART 6 | 230 | 10.87 | 527656 | CROSSROADS 7 | 345 | 5.42 | 562480 | G13-027-TAP | 230 | 9.13 |
| 525480 | PLANT_X 3 | 115 | 21.23 | 527711 | EAGLE_CREEK3 | 115 | 6.84 | 577103 | GEN-2008-022 | 345 | 5.13 |
| 525481 | PLANT_X 6 | 230 | 22.25 | 527786 | ATOKA 3 | 115 | 6.59 | 577104 | G08-022-WEST | 345 | 4.81 |
| 525524 | TOLK_EAST 6 | 230 | 25.84 | 527793 | EDDY_STH 3 | 115 | 10.18 | 583340 | GEN-2012-020 | 230 | 9.20 |
| 525531 | TOLK_WEST 6 | 230 | 25.84 | 527798 | EDDY_NTH 3 | 115 | 10.18 | 583840 | GEN-2013-027 | 230 | 8.12 |
| 525543 | TOLK_TAP 6 | 230 | 25.84 | 527799 | EDDY_NORTH 6 | 230 | 7.28 | 583950 | GEN-2014-033 | 115 | 6.18 |
| 525549 | TOLK 7 | 345 | 6.98 | 527800 | EDDY_SOUTH 6 | 230 | 7.28 | 583970 | GEN-2014-035 | 115 | 5.89 |
| 525636 | LAMB_CNTY 3 | 115 | 8.51 | 527802 | EDDY_CNTY 7 | 345 | 4.11 | 584260 | GEN-2014-047 | 345 | 4.38 |
| 525637 | LAMB_CNTY 6 | 230 | 5.34 | 527809 | CV-8_MILE 3 | 115 | 5.07 | 584940 | GEN-2015-056 | 345 | 4.79 |
| 525828 | TUCO_INT 3 | 115 | 20.01 | 527821 | CV-DAYTON 3 | 115 | 6.51 | 599555 | PNM-DC6 | 230 | 8.76 |
| 525830 | TUCO_INT 6 | 230 | 22.92 | 527864 | CUNNINGHAM 3 | 115 | 26.24 | 599960 | EPTNP-D6 | 230 | 7.28 |
| 525832 | TUCO_INT 7 | 345 | 13.36 | 527865 | CUNNINGHAM 6 | 230 | 16.06 | | | | |
| 525840 | ANTELOPE_1 6 | 230 | 22.74 | 527894 | HOBBS_INT 6 | 230 | 17.20 | | | | |

Table 4-6
Short Circuit Analysis for Study Project GEN-2015-075 (17SP)

| Study Generator GEN-2015-075 | | | | | | | | | | | |
|------------------------------|---------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|---------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 515458 | BORDER 7 | 345 | 10.18 | 526076 | STANTON W 3 | 115 | 9.40 | 526299 | LUBBCK_EST 6 | 230 | 12.89 |
| 522822 | LP-NORTHWEST2 | 69 | 4.34 | 526109 | SP-ERSKINE 3 | 115 | 11.41 | 526337 | JONES 6 | 230 | 19.72 |
| 522823 | LP-MILWAKEE6 | 230 | 10.03 | 526130 | SP-CARLISLE2 | 69 | 2.11 | 526434 | SUNDOWN 3 | 115 | 11.48 |
| 522828 | LP-MILWAKEE2 | 69 | 7.49 | 526146 | INDIANA 3 | 115 | 9.75 | 526435 | SUNDOWN 6 | 230 | 10.95 |
| 522832 | LP-VICKSBRG2 | 69 | 11.44 | 526159 | CARLISLE 2 | 69 | 2.57 | 526460 | AMOCO_SS 6 | 230 | 9.62 |
| 522861 | LP-SOUTHEST6 | 230 | 13.76 | 526160 | CARLISLE 3 | 115 | 13.24 | 526469 | SP-YUMA 2 | 69 | 3.07 |
| 522870 | LP-HOLLY 6 | 230 | 14.76 | 526161 | CARLISLE 6 | 230 | 10.68 | 526475 | YUMA_INT 3 | 115 | 11.00 |
| 524911 | ROSEVELT_S 6 | 230 | 8.76 | 526162 | LP-DOUD_TP 3 | 115 | 11.67 | 526481 | SP-WOLF_TP 3 | 115 | 11.18 |
| 525212 | SWISHER 3 | 115 | 10.31 | 526176 | LP-DOUD 3 | 115 | 9.06 | 526483 | SP-WOLFFORTH3 | 115 | 8.67 |
| 525213 | SWISHER 6 | 230 | 10.48 | 526184 | SW_6878 2 | 69 | 2.16 | 526524 | WOLFFORTH 3 | 115 | 11.51 |
| 525454 | HALE_CNTY 3 | 115 | 10.17 | 526192 | MURPHY 3 | 115 | 10.67 | 526525 | WOLFFORTH 6 | 230 | 13.12 |
| 525461 | NEWHART 6 | 230 | 10.87 | 526199 | SP-FRANKFRD3 | 115 | 9.68 | 526677 | GRASSLAND 6 | 230 | 6.41 |
| 525481 | PLANT_X 6 | 230 | 22.25 | 526205 | IVORY 2 | 69 | 3.93 | 526736 | TERRY_CNTY 3 | 115 | 10.86 |
| 525524 | TOLK_EAST 6 | 230 | 25.84 | 526213 | ALLEN 3 | 115 | 10.72 | 526936 | YOAKUM_345 | 345 | 8.47 |
| 525543 | TOLK_TAP 6 | 230 | 25.84 | 526221 | BATTON_N 2 | 69 | 1.78 | 560027 | G14-074-TAP | 345 | 6.71 |
| 525780 | FLOYD_CNTY 3 | 115 | 6.03 | 526228 | BATTON_S 2 | 69 | 2.72 | 560050 | G15-031-TAP | 230 | 9.03 |
| 525816 | TUCO_INT2 2 | 69 | 4.67 | 526243 | SP-QUAKER 3 | 115 | 9.73 | 583340 | GEN-2012-020 | 230 | 9.20 |
| 525826 | TUCO_INT 2 | 69 | 7.92 | 526256 | IVORY_TP 2 | 69 | 3.93 | 583810 | ASG12013-006 | 115 | 8.67 |
| 525828 | TUCO_INT 3 | 115 | 20.01 | 526267 | LUBBCK_STH 2 | 69 | 4.35 | 583819 | ASG12014-001 | 115 | 11.41 |
| 525830 | TUCO_INT 6 | 230 | 22.92 | 526268 | LUBBCK_STH 3 | 115 | 18.90 | 585060 | GEN-2015-068 | 345 | 10.65 |
| 525832 | TUCO_INT 7 | 345 | 13.36 | 526269 | LUBBCK_STH 6 | 230 | 17.45 | 585120 | GEN-2015-075 | 69 | 1.55 |
| 525840 | ANTELOPE_1 6 | 230 | 22.74 | 526298 | LUBBCK_EST 3 | 115 | 15.21 | | | | |

Table 4-7
Short Circuit Analysis for Study Project GEN-2015-079 and GEN-2015-080 (17SP)

| Study Generator GEN-2015-079 and GEN-2015-080 | | | | | | | | | | | |
|---|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 511456 | O.K.U.-7 | 345 | 5.46 | 527041 | ARCO_TP 3 | 115 | 13.04 | 528094 | 7-RIVERS 3 | 115 | 7.49 |
| 511553 | CHISHOLM7 | 345 | 12.26 | 527046 | OXY_WILRD2 3 | 115 | 10.46 | 528095 | 7-RIVERS 6 | 230 | 5.51 |
| 515458 | BORDER 7 | 345 | 10.18 | 527047 | OXY_WILRD1 3 | 115 | 10.48 | 528160 | CARLSBAD 3 | 115 | 8.68 |
| 524623 | DEAFSMITH 6 | 230 | 7.70 | 527051 | ODC_TP 3 | 115 | 13.15 | 528178 | PECOS 3 | 115 | 9.15 |
| 524770 | PLSNT_HILL 6 | 230 | 6.09 | 527062 | SHELL_CO2 3 | 115 | 15.93 | 528179 | PECOS 6 | 230 | 5.70 |
| 524908 | ROOSEVELT 3 | 115 | 10.33 | 527080 | EL_PASO 3 | 115 | 15.68 | 528317 | ENRON_TP 3 | 115 | 6.28 |
| 524909 | ROSEVELT_N 6 | 230 | 8.76 | 527105 | SAN_ANDS_TP3 | 115 | 16.34 | 528325 | LE-WAITS 3 | 115 | 6.68 |
| 524911 | ROSEVELT_S 6 | 230 | 8.76 | 527125 | DENVER_CTY 2 | 69 | 8.63 | 528333 | LE-WEST_SUB3 | 115 | 8.54 |
| 524915 | SW_4K33 6 | 230 | 8.76 | 527130 | DENVER_N 3 | 115 | 20.86 | 528334 | LE-LOVINTON3 | 115 | 8.45 |
| 525213 | SWISHER 6 | 230 | 10.48 | 527136 | DENVER_S 3 | 115 | 20.86 | 528348 | BUCKEYE_TP 3 | 115 | 8.12 |
| 525461 | NEWHART 6 | 230 | 10.87 | 527146 | MUSTANG 3 | 115 | 23.16 | 528355 | MADDOX 3 | 115 | 25.33 |
| 525480 | PLANT_X 3 | 115 | 21.23 | 527149 | MUSTANG 6 | 230 | 15.45 | 528385 | BUCKEYE 3 | 115 | 7.31 |
| 525481 | PLANT_X 6 | 230 | 22.25 | 527151 | GS-MUSTANG 6 | 230 | 15.45 | 528392 | PEARLE 3 | 115 | 6.16 |
| 525524 | TOLK_EAST 6 | 230 | 25.84 | 527194 | LG-PLSHILL 3 | 115 | 7.55 | 528394 | QUAHADA 3 | 115 | 7.26 |
| 525531 | TOLK_WEST 6 | 230 | 25.84 | 527201 | SEAGRAVES 2 | 69 | 5.41 | 528399 | LEA_NATIONL3 | 115 | 6.31 |
| 525543 | TOLK_TAP 6 | 230 | 25.84 | 527202 | SEAGRAVES 3 | 115 | 8.57 | 528413 | TAYLOR 3 | 115 | 14.03 |
| 525549 | TOLK 7 | 345 | 6.98 | 527238 | ROZ 3 | 115 | 11.16 | 528422 | DCP_ZIA_TP 3 | 115 | 6.37 |
| 525636 | LAMB_CNTY 3 | 115 | 8.51 | 527242 | AMERADA 3 | 115 | 11.31 | 528433 | NEW_NHOBS 3 | 115 | 7.91 |
| 525637 | LAMB_CNTY 6 | 230 | 5.34 | 527262 | SULPHUR 3 | 115 | 5.70 | 528435 | MILLEN 3 | 115 | 11.30 |
| 525828 | TUCO_INT 3 | 115 | 20.01 | 527275 | SEMINOLE 3 | 115 | 14.43 | 528442 | NE_HOBS 3 | 115 | 11.58 |
| 525830 | TUCO_INT 6 | 230 | 22.92 | 527276 | SEMINOLE 6 | 230 | 7.65 | 528463 | SANGER_SW 3 | 115 | 15.41 |
| 525832 | TUCO_INT 7 | 345 | 13.36 | 527284 | RUSSELL 3 | 115 | 8.99 | 528484 | SW_4J44 3 | 115 | 10.72 |
| 525840 | ANTELOPE_1 6 | 230 | 22.74 | 527286 | XTO_RUSSEL 3 | 115 | 9.92 | 528491 | MONUMENT 3 | 115 | 14.86 |
| 526036 | LC-OPDYKE 3 | 115 | 5.81 | 527322 | GAINES 3 | 115 | 9.31 | 528498 | W_HOBS 3 | 115 | 11.21 |
| 526161 | CARLISLE 6 | 230 | 10.68 | 527340 | DOSS 3 | 115 | 7.97 | 528568 | MONUMNT_TP 3 | 115 | 9.63 |
| 526269 | LUBBCK_STH 6 | 230 | 17.45 | 527362 | JOHNSON_DRW3 | 115 | 10.58 | 528575 | OXYPERMIAN 3 | 115 | 14.81 |
| 526337 | JONES 6 | 230 | 19.72 | 527363 | HIGG 3 | 115 | 10.09 | 528582 | BYRD 3 | 115 | 7.72 |
| 526352 | LEHMAN 3 | 115 | 6.07 | 527483 | CHAVES_CNTY6 | 230 | 3.99 | 528589 | DRINKARD 3 | 115 | 6.95 |
| 526424 | PACIFIC 3 | 115 | 9.71 | 527597 | TWEEDY 3 | 115 | 4.68 | 528602 | ANDREWS 3 | 115 | 7.93 |
| 526434 | SUNDOWN 3 | 115 | 11.48 | 527711 | EAGLE_CREEK3 | 115 | 6.84 | 528603 | NA_ENRICH 3 | 115 | 7.89 |
| 526435 | SUNDOWN 6 | 230 | 10.95 | 527793 | EDDY_STH 3 | 115 | 10.18 | 528604 | ANDREWS 6 | 230 | 6.02 |
| 526445 | AMOCO_TP 3 | 115 | 10.82 | 527798 | EDDY_NTH 3 | 115 | 10.18 | 528605 | TARGA 3 | 115 | 6.48 |
| 526460 | AMOCO_SS 6 | 230 | 9.62 | 527799 | EDDY_NORTH 6 | 230 | 7.28 | 528618 | LE-LOVINTON2 | 69 | 7.18 |
| 526491 | LG-CLAUENE 3 | 115 | 9.13 | 527800 | EDDY_SOUTH 6 | 230 | 7.28 | 528626 | LE-PLNSINT 2 | 69 | 4.36 |
| 526524 | WOLFFORTH 3 | 115 | 11.51 | 527802 | EDDY_CNTY 7 | 345 | 4.11 | 528627 | LE-TXACO_TP3 | 115 | 7.01 |
| 526525 | WOLFFORTH 6 | 230 | 13.12 | 527809 | CV-8_MILE 3 | 115 | 5.07 | 528740 | LE-PLANS_TP2 | 69 | 3.61 |
| 526735 | TERRY_CNTY 2 | 69 | 7.08 | 527864 | CUNNINHAM 3 | 115 | 26.24 | 560027 | G14-074-TAP | 345 | 6.71 |
| 526736 | TERRY_CNTY 3 | 115 | 10.86 | 527865 | CUNNINHAM 6 | 230 | 16.06 | 560058 | G15-077-TAP | 115 | 8.23 |
| 526784 | AMOCOWASSON6 | 230 | 13.69 | 527891 | HOBBS_INT 3 | 115 | 29.89 | 560059 | G1579&G1580T | 230 | 8.97 |
| 526792 | PRENTICE 3 | 115 | 5.94 | 527894 | HOBBS_INT 6 | 230 | 17.20 | 562480 | G13-027-TAP | 230 | 9.13 |
| 526928 | PLAINS_INT 3 | 115 | 9.83 | 527896 | HOBBS_INT 7 | 345 | 7.14 | 583090 | G1149&G1504 | 345 | 8.37 |
| 526934 | YOAKUM 3 | 115 | 16.64 | 527930 | PCA 3 | 115 | 8.14 | 583340 | GEN-2012-020 | 230 | 9.20 |
| 526935 | YOAKUM 6 | 230 | 17.12 | 527961 | POTASH_JCT 2 | 69 | 6.94 | 583840 | GEN-2013-027 | 230 | 8.12 |
| 526936 | YOAKUM_345 | 345 | 8.47 | 527962 | POTASH_JCT 3 | 115 | 8.69 | 584440 | GEN-2014-074 | 345 | 6.31 |
| 526944 | LG-PLAINS 3 | 115 | 7.92 | 527963 | POTASH_JCT 6 | 230 | 6.31 | 585060 | GEN-2015-068 | 345 | 10.65 |
| 527010 | OXYBRU_TP 6 | 230 | 13.70 | 527999 | INTREPDW_TP3 | 115 | 7.93 | 585160 | G1579&G1580 | 230 | 8.52 |
| 527018 | BENNETT 3 | 115 | 13.14 | 528025 | RDRUNNER 3 | 115 | 5.89 | 599960 | EPTNP-D6 | 230 | 7.28 |
| 527036 | SHELL_C2 3 | 115 | 12.78 | 528027 | RDRUNNER 6 | 230 | 3.59 | | | | |

4.3 Short Circuit Results: 2025 Summer Peak

The maximum fault current for each bus is provided for the 2025 Summer Peak conditions. The following tables show the short circuit results for the study generators for the 2025 Summer Peak conditions:

- Table 4-8: Short Circuit Analysis for GEN-2015-020 (25SP)
- Table 4-9: Short Circuit Analysis for GEN-2015-031 (25SP)
- Table 4-10: Short Circuit Analysis for GEN-2015-056 (25SP)
- Table 4-11: Short Circuit Analysis for GEN-2015-058 (25SP)

- Table 4-12: Short Circuit Analysis for GEN-2015-068 (25SP)
- Table 4-13: Short Circuit Analysis for GEN-2015-075 (25SP)
- Table 4-14: Short Circuit Analysis for GEN-2015-079 and GEN-2015-080 (25SP)

Table 4-8
Short Circuit Analysis for Study Project GEN-2015-020 (25SP)

| Study Generator GEN-2015-020 | | | | | | | | | | | |
|------------------------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 524486 | CAPROCK 3 | 115 | 3.22 | 524874 | OASIS 3 | 115 | 9.75 | 525524 | TOLK_EAST 6 | 230 | 26.48 |
| 524502 | NORTON 3 | 115 | 3.32 | 524875 | OASIS 6 | 230 | 7.42 | 525531 | TOLK_WEST 6 | 230 | 26.48 |
| 524509 | FE-TUCMCARIB | 115 | 2.61 | 524885 | SN_JUAN_TAP6 | 230 | 4.69 | 525543 | TOLK_TAP 6 | 230 | 26.48 |
| 524662 | PARMER_CO 3 | 115 | 4.14 | 524889 | SN_JUAN_WND6 | 230 | 4.49 | 525637 | LAMB_CNTY 6 | 230 | 5.56 |
| 524669 | DS-#20 3 | 115 | 4.89 | 524908 | ROOSEVELT 3 | 115 | 10.56 | 525830 | TUCO_INT 6 | 230 | 23.39 |
| 524764 | NORRIS_TP 3 | 115 | 11.14 | 524909 | ROSEVELT_N 6 | 230 | 8.91 | 527482 | CHAVES_CNTY3 | 115 | 6.31 |
| 524768 | PLSNT_HILL 3 | 115 | 10.19 | 524911 | ROSEVELT_S 6 | 230 | 8.91 | 527483 | CHAVES_CNTY6 | 230 | 4.08 |
| 524770 | PLSNT_HILL 6 | 230 | 6.19 | 524915 | SW_4K33 6 | 230 | 8.91 | 527501 | URTON 3 | 115 | 5.34 |
| 524773 | E_CLOVIS 3 | 115 | 8.75 | 524923 | PORTALES 2 | 69 | 7.19 | 527508 | PRICE 3 | 115 | 4.95 |
| 524776 | N_CLOVIS_TP3 | 115 | 7.31 | 524924 | PORTALES 3 | 115 | 7.35 | 527546 | SAMSON 3 | 115 | 5.07 |
| 524777 | N_CLOVIS 3 | 115 | 6.61 | 524929 | RO-PORT_MTR2 | 69 | 7.19 | 527793 | EDDY_STH 3 | 115 | 10.95 |
| 524783 | W_CLOVIS 2 | 69 | 2.43 | 524934 | ZODIAC 2 | 69 | 5.34 | 527799 | EDDY_NORTH 6 | 230 | 7.76 |
| 524784 | W_CLOVIS 3 | 115 | 6.21 | 524935 | KILGORE 3 | 115 | 6.01 | 527800 | EDDY_SOUTH 6 | 230 | 7.76 |
| 524790 | CANNON_TP 3 | 115 | 5.90 | 524941 | PORTALES#1 2 | 69 | 5.53 | 527802 | EDDY_CNTY 7 | 345 | 4.26 |
| 524794 | CANNONAFB 3 | 115 | 5.54 | 524948 | PORTALES#2 2 | 69 | 4.70 | 560032 | G15-018T | 115 | 5.48 |
| 524797 | PERIMETER 3 | 115 | 6.42 | 524962 | S_PORTALES 2 | 69 | 4.19 | 562480 | G13-027-TAP | 230 | 9.19 |
| 524801 | NORRIS 3 | 115 | 10.19 | 524963 | S_PORTALES 3 | 115 | 5.65 | 583280 | ASGI2012-002 | 115 | 1.05 |
| 524808 | FE-CLVS_INT3 | 115 | 6.81 | 524976 | MARKET_ST 2 | 69 | 3.97 | 583950 | GEN-2014-033 | 115 | 6.31 |
| 524821 | CURRY 2 | 69 | 4.41 | 524977 | MARKET_ST 3 | 115 | 5.57 | 583970 | GEN-2014-035 | 115 | 6.00 |
| 524822 | CURRY 3 | 115 | 11.18 | 525019 | EMU&VLY_TP 3 | 115 | 7.33 | 584620 | GEN-2015-020 | 115 | 9.50 |
| 524831 | FE-HOLLAND 3 | 115 | 9.01 | 525027 | BAILEYCO 2 | 69 | 6.01 | 599955 | PNM-DC6 | 230 | 8.91 |
| 524838 | FE-CLOVIS2 3 | 115 | 10.54 | 525028 | BAILEYCO 3 | 115 | 7.46 | 599960 | EPTNP-D6 | 230 | 7.76 |
| 524846 | FARWELL 2 | 69 | 2.09 | 525040 | BAILEY_PMP 3 | 115 | 5.25 | | | | |
| 524863 | FE-CHZPLT 3 | 115 | 7.89 | 525481 | PLANT_X 6 | 230 | 23.40 | | | | |

Table 4-9
Short Circuit Analysis for Study Project GEN-2015-031 (25SP)

| Study Generator GEN-2015-031 | | | | | | | | | | | |
|------------------------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 511456 | O.K.U.-7 | 345 | 5.49 | 524185 | PIERCE_TP 3 | 115 | 19.01 | 525480 | PLANT_X 3 | 115 | 26.91 |
| 511553 | CHISHOLM7 | 345 | 12.40 | 524224 | MANHATTAN 3 | 115 | 18.43 | 525481 | PLANT_X 6 | 230 | 23.40 |
| 515458 | BORDER 7 | 345 | 10.26 | 524266 | BUSHLAND 3 | 115 | 9.33 | 525524 | TOLK_EAST 6 | 230 | 26.48 |
| 522800 | MU-TULIA 3 | 115 | 5.10 | 524267 | BUSHLAND 6 | 230 | 9.64 | 525531 | TOLK_WEST 6 | 230 | 26.48 |
| 522823 | LP-MILWAKEE6 | 230 | 13.04 | 524282 | 34TH_ST 3 | 115 | 14.94 | 525543 | TOLK_TAP 6 | 230 | 26.48 |
| 522828 | LP-MILWAKEE2 | 69 | 8.30 | 524290 | WILDOR2_JUS6 | 230 | 6.61 | 525549 | TOLK 7 | 345 | 7.05 |
| 522861 | LP-SOUTHEST6 | 230 | 17.10 | 524296 | SPNSPUR_WND7 | 345 | 4.45 | 525614 | W_LITLFLDTP3 | 115 | 8.29 |
| 522866 | LP-COOK 2 | 69 | 34.97 | 524306 | COULTER 3 | 115 | 15.17 | 525637 | LAMB_CNTY 6 | 230 | 5.56 |
| 522870 | LP-HOLLY 6 | 230 | 16.91 | 524321 | GEORGIA 2 | 69 | 6.65 | 525731 | SP-ABERNTHY2 | 69 | 3.02 |
| 522888 | LP-WADSWRTH6 | 230 | 12.59 | 524322 | GEORGIA 3 | 115 | 16.37 | 525738 | HALECENTER 2 | 69 | 2.46 |
| 523095 | HITCHLAND 6 | 230 | 14.92 | 524331 | PULLMAN 3 | 115 | 7.12 | 525779 | FLOYD_CNTY 2 | 69 | 5.31 |
| 523097 | HITCHLAND 7 | 345 | 15.73 | 524338 | SOUTHEAST 3 | 115 | 11.02 | 525780 | FLOYD_CNTY 3 | 115 | 6.04 |
| 523221 | XIT_INTG 6 | 230 | 2.60 | 524345 | OSAGE 3 | 115 | 13.75 | 525816 | TUCO_INT2 2 | 69 | 4.68 |
| 523267 | PRINGLE 6 | 230 | 4.26 | 524364 | RANDALL 3 | 115 | 20.98 | 525826 | TUCO_INT 2 | 69 | 7.93 |
| 523308 | MOORE_E 3 | 115 | 11.00 | 524365 | RANDALL 6 | 230 | 14.24 | 525828 | TUCO_INT 3 | 115 | 20.18 |
| 523309 | MOORE_CNTY 6 | 230 | 6.70 | 524377 | FARMERS 3 | 115 | 15.09 | 525830 | TUCO_INT 6 | 230 | 23.39 |
| 523332 | EXELL_TP 3 | 115 | 4.81 | 524388 | CROUSE_HIND3 | 115 | 15.09 | 525832 | TUCO_INT 7 | 345 | 13.55 |
| 523339 | FAIN 3 | 115 | 5.27 | 524397 | ARROWHEAD 3 | 115 | 13.58 | 525840 | ANTELOPE 1 6 | 230 | 23.20 |
| 523344 | BLKHAWK_W 3 | 115 | 11.82 | 524404 | OWENSCORN 3 | 115 | 14.79 | 525853 | LH-WIL&ELLN2 | 69 | 2.58 |
| 523377 | RIVERVIEW 3 | 115 | 13.30 | 524414 | AMA_SOUTH 3 | 115 | 16.59 | 525885 | SP-NEWDEAL 2 | 69 | 3.39 |
| 523410 | CRMWA_#4 3 | 115 | 9.71 | 524415 | AMA_SOUTH 6 | 230 | 13.43 | 525926 | CROSBY 3 | 115 | 4.50 |
| 523485 | CAMX/AGR TP3 | 115 | 13.95 | 524425 | ESTACADO_TP3 | 115 | 13.19 | 526076 | STANTON_W 3 | 115 | 9.52 |
| 523494 | MEREDITH 3 | 115 | 7.73 | 524432 | ESTACADO 3 | 115 | 11.63 | 526109 | SP-ERSKINE 3 | 115 | 11.63 |
| 523543 | HUTCHISON 2 | 69 | 9.05 | 524516 | CANYON_WEST3 | 115 | 5.32 | 526146 | INDIANA 3 | 115 | 9.89 |
| 523544 | HUTCH_N 3 | 115 | 15.65 | 524522 | CANYON_E_TP3 | 115 | 5.48 | 526159 | CARLISLE 2 | 69 | 2.58 |
| 523546 | HUTCH_S 3 | 115 | 15.65 | 524523 | CANYON_EAST3 | 115 | 5.07 | 526160 | CARLISLE 3 | 115 | 13.56 |
| 523551 | HUTCHISON 6 | 230 | 7.20 | 524530 | PALO_DURO 3 | 115 | 6.55 | 526161 | CARLISLE 6 | 230 | 13.44 |
| 523636 | GRAY_CNTY 3 | 115 | 3.90 | 524544 | SPRING_DRW 3 | 115 | 6.36 | 526162 | LP-DOUD_TP 3 | 115 | 11.90 |
| 523748 | BOWERS 3 | 115 | 6.88 | 524622 | DEAFSMITH 3 | 115 | 12.18 | 526192 | MURPHY 3 | 115 | 10.81 |
| 523770 | GRAPEVINE 3 | 115 | 7.90 | 524623 | DEAFSMITH 6 | 230 | 7.78 | 526268 | LUBBCK_STH 3 | 115 | 19.38 |
| 523771 | GRAPEVINE 6 | 230 | 5.74 | 524694 | DS-#22 3 | 115 | 4.98 | 526269 | LUBBCK_STH 6 | 230 | 19.02 |
| 523776 | WHEELER 3 | 115 | 6.42 | 524734 | DS-#21 3 | 115 | 10.90 | 526297 | LUBBCK_EST 2 | 69 | 8.07 |
| 523777 | WHEELER 6 | 230 | 5.88 | 524745 | CASTRO_CNTY2 | 69 | 9.64 | 526298 | LUBBCK_EST 3 | 115 | 15.43 |
| 523779 | STLN-DEMARC6 | 230 | 7.03 | 524746 | CASTRO_CNTY3 | 115 | 11.76 | 526299 | LUBBCK_EST 6 | 230 | 13.48 |
| 523815 | LLANO_WND 3 | 115 | 9.43 | 524909 | ROSEVELT_N 6 | 230 | 8.91 | 526337 | JONES 6 | 230 | 21.04 |
| 523817 | MIDSTRM_TP 3 | 115 | 6.71 | 524911 | ROSEVELT_S 6 | 230 | 8.91 | 526434 | SUNDOWN 3 | 115 | 11.59 |
| 523869 | CHAN/TASCOS6 | 230 | 3.84 | 524915 | SW_4K33 6 | 230 | 8.91 | 526435 | SUNDOWN 6 | 230 | 11.12 |
| 523928 | MARTIN 3 | 115 | 7.88 | 525019 | EMU&VLY_TP 3 | 115 | 7.33 | 526460 | AMOCO_SS 6 | 230 | 9.75 |
| 523931 | HIGHLAND_TP3 | 115 | 11.52 | 525050 | BC-KELLEY 3 | 115 | 8.60 | 526524 | WOLFFORTH 3 | 115 | 11.68 |
| 523959 | POTTER_CO 6 | 230 | 20.24 | 525056 | BC-EARTH 3 | 115 | 9.16 | 526525 | WOLFFORTH 6 | 230 | 13.63 |
| 523961 | POTTER_CO 7 | 345 | 7.43 | 525124 | HART_INDUST3 | 115 | 7.63 | 526676 | GRASSLAND 3 | 115 | 6.17 |
| 523977 | HARRNG_WST 6 | 230 | 26.01 | 525154 | HAPPY_INT 3 | 115 | 5.36 | 526677 | GRASSLAND 6 | 230 | 6.53 |
| 523978 | HARRNG_MID 6 | 230 | 26.01 | 525179 | TULIA_TP 3 | 115 | 6.30 | 526679 | CIRRUS_WND 6 | 230 | 5.07 |
| 523979 | HARRNG_EST 6 | 230 | 26.01 | 525191 | KRESS_INT 2 | 69 | 4.44 | 526935 | YOAKUM 6 | 230 | 17.62 |
| 524007 | ROLLHILLS 3 | 115 | 19.33 | 525192 | KRESS_INT 3 | 115 | 11.21 | 526936 | YOAKUM_345 | 345 | 8.97 |
| 524009 | CHERRY 3 | 115 | 18.48 | 525203 | SW-KRESS 2 | 69 | 4.44 | 527896 | HOBBS_INT 7 | 345 | 8.43 |
| 524010 | ROLLHILLS 6 | 230 | 19.27 | 525212 | SWISHER 3 | 115 | 10.34 | 560027 | G14-074-TAP | 345 | 6.75 |
| 524016 | ASARCO 3 | 115 | 26.48 | 525213 | SWISHER 6 | 230 | 10.52 | 560050 | G15-031-TAP | 230 | 9.05 |
| 524018 | ASARCO_TP 3 | 115 | 28.64 | 525224 | KRESS_RURL 2 | 69 | 2.51 | 562004 | G11-025-TAP | 115 | 4.61 |
| 524043 | NICHOLS 3 | 115 | 30.61 | 525225 | KRESS_RURAL3 | 115 | 6.26 | 562480 | G13-027-TAP | 230 | 9.19 |
| 524044 | NICHOLS 6 | 230 | 25.27 | 525257 | N_PLAINVEW 3 | 115 | 5.10 | 583090 | G1149&G1504 | 345 | 8.42 |
| 524058 | WHITAKER 3 | 115 | 21.91 | 525326 | COX 3 | 115 | 5.91 | 583340 | GEN-2012-020 | 230 | 9.26 |
| 524079 | CONWAY 3 | 115 | 5.00 | 525414 | LAMTON 3 | 115 | 7.96 | 584220 | GEN-2014-040 | 115 | 10.42 |
| 524088 | KIRBY 3 | 115 | 5.43 | 525446 | SPGLAKE_TP3 | 115 | 11.54 | 584440 | GEN-2014-074 | 345 | 6.34 |
| 524106 | NORTHWEST 3 | 115 | 11.26 | 525453 | HALE_CNTY 2 | 69 | 6.95 | 584640 | GEN-2015-022 | 115 | 10.34 |
| 524136 | HASTINGS 3 | 115 | 13.72 | 525454 | HALE_CNTY 3 | 115 | 10.29 | 584750 | GEN-2015-031 | 230 | 9.05 |
| 524162 | EAST_PLANT 3 | 115 | 22.91 | 525460 | NEWHART 3 | 115 | 15.20 | 585060 | GEN-2015-068 | 345 | 10.76 |
| 524163 | EAST_PLANT 6 | 230 | 13.66 | 525461 | NEWHART 6 | 230 | 10.92 | 599955 | PNM-DC6 | 230 | 8.91 |

Table 4-10
Short Circuit Analysis for Study Project GEN-2015-056 (25SP)

| Study Generator GEN-2015-056 | | | | | | | | | | | |
|------------------------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 524908 | ROOSEVELT 3 | 115 | 10.56 | 583950 | GEN-2014-033 | 115 | 6.31 | 527483 | CHAVES_CNTY6 | 230 | 4.08 |
| 525480 | PLANT_X 3 | 115 | 26.91 | 583970 | GEN-2014-035 | 115 | 6.00 | 527799 | EDDY_NORTH 6 | 230 | 7.76 |
| 525636 | LAMB_CNTY 3 | 115 | 9.76 | 524623 | DEAFSMITH 6 | 230 | 7.78 | 527800 | EDDY_SOUTH 6 | 230 | 7.76 |
| 525828 | TUCO_INT 3 | 115 | 20.18 | 524770 | PLSNT_HILL 6 | 230 | 6.19 | 527865 | CUNNINGHAM 6 | 230 | 17.33 |
| 527482 | CHAVES_CNTY3 | 115 | 6.31 | 524875 | OASIS 6 | 230 | 7.42 | 527894 | HOBBS_INT 6 | 230 | 19.11 |
| 527501 | URTON 3 | 115 | 5.34 | 524885 | SN_JUAN_TAP6 | 230 | 4.69 | 527963 | POTASH_JCT 6 | 230 | 6.91 |
| 527508 | PRICE 3 | 115 | 4.95 | 524889 | SN_JUAN_WND6 | 230 | 4.49 | 528095 | 7-RIVERS 6 | 230 | 5.99 |
| 527546 | SAMSON 3 | 115 | 5.07 | 524909 | ROSEVELT_N 6 | 230 | 8.91 | 528179 | PECOS 6 | 230 | 6.35 |
| 527597 | TWEEDY 3 | 115 | 4.93 | 524911 | ROSEVELT_S 6 | 230 | 8.91 | 562480 | G13-027-TAP | 230 | 9.19 |
| 527711 | EAGLE_CREEK3 | 115 | 7.23 | 524915 | SW_4K33 6 | 230 | 8.91 | 583340 | GEN-2012-020 | 230 | 9.26 |
| 527786 | ATOKA 3 | 115 | 6.97 | 525213 | SWISHER 6 | 230 | 10.52 | 583840 | GEN-2013-027 | 230 | 8.17 |
| 527793 | EDDY_STH 3 | 115 | 10.95 | 525461 | NEWHART 6 | 230 | 10.92 | 599955 | PNM-DC6 | 230 | 8.91 |
| 527798 | EDDY_NTH 3 | 115 | 10.95 | 525481 | PLANT_X 6 | 230 | 23.40 | 599960 | EPTNP-D6 | 230 | 7.76 |
| 527809 | CV-8_MILE 3 | 115 | 5.25 | 525524 | TOLK_EAST 6 | 230 | 26.48 | 525549 | TOLK 7 | 345 | 7.05 |
| 527821 | CV-DAYTON 3 | 115 | 6.87 | 525531 | TOLK_WEST 6 | 230 | 26.48 | 525832 | TUCO_INT 7 | 345 | 13.55 |
| 527864 | CUNNINGHAM 3 | 115 | 29.66 | 525543 | TOLK_TAP 6 | 230 | 26.48 | 527656 | CROSSROADS 7 | 345 | 5.48 |
| 528070 | CV-AZMESA 3 | 115 | 7.34 | 525637 | LAMB_CNTY 6 | 230 | 5.56 | 527802 | EDDY_CNTY 7 | 345 | 4.26 |
| 528094 | 7-RIVERS 3 | 115 | 8.16 | 525830 | TUCO_INT 6 | 230 | 23.39 | 577103 | GEN-2008-022 | 345 | 5.18 |
| 528132 | OCOTILLO 3 | 115 | 6.13 | 525840 | ANTELOPE_1 6 | 230 | 23.20 | 577104 | G08-022-WEST | 345 | 4.86 |
| 528137 | N_CANAL 3 | 115 | 8.59 | 526161 | CARLISLE 6 | 230 | 13.44 | 584260 | GEN-2014-047 | 345 | 4.42 |
| 528160 | CARLSBAD 3 | 115 | 11.08 | 526337 | JONES 6 | 230 | 21.04 | 584940 | GEN-2015-056 | 345 | 4.84 |
| 528178 | PECOS 3 | 115 | 11.67 | 526435 | SUNDOWN 6 | 230 | 11.12 | | | | |
| 528226 | HOPI_SUB 3 | 115 | 6.64 | 526935 | YOAKUM 6 | 230 | 17.62 | | | | |

Table 4-11
Short Circuit Analysis for Study Project GEN-2015-058 (25SP)

| Study Generator GEN-2015-058 | | | | | | | | | | | |
|------------------------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 524885 | SN_JUAN_TAP6 | 230 | 4.69 | 527757 | ARTESIA_TP 2 | 69 | 3.70 | 527930 | PCA 3 | 115 | 11.08 |
| 527482 | CHAVES_CNTY3 | 115 | 6.31 | 527761 | ARTESIA_W 2 | 69 | 3.37 | 527962 | POTASH_JCT 3 | 115 | 14.26 |
| 527483 | CHAVES_CNTY6 | 230 | 4.08 | 527762 | ARTSA_CC_TP2 | 69 | 1.92 | 527963 | POTASH_JCT 6 | 230 | 6.91 |
| 527552 | RIAC 2 | 115 | 4.53 | 527763 | CV-W_ARTSIA2 | 69 | 1.62 | 528003 | CV-DAGGR&IH2 | 69 | 1.63 |
| 527564 | ROSWLL_INT 3 | 115 | 5.30 | 527768 | ARTESIA_CC 2 | 69 | 1.75 | 528070 | CV-AZMESA 3 | 115 | 7.34 |
| 527596 | RIACTWY_TP3 | 115 | 5.06 | 527772 | ARTSA_SR_TP2 | 69 | 1.99 | 528076 | CV-WALTCYN 3 | 115 | 4.50 |
| 527597 | TWEEDY 3 | 115 | 4.93 | 527775 | ARTESIA_SR 2 | 69 | 1.92 | 528079 | CV-CONEBUTE3 | 115 | 3.32 |
| 527656 | CROSSROADS 7 | 345 | 5.48 | 527785 | ATOKA 2 | 69 | 2.36 | 528093 | 7-RIVERS 2 | 69 | 2.39 |
| 527664 | CV-CTTNWOOD2 | 69 | 2.68 | 527786 | ATOKA 3 | 115 | 6.97 | 528094 | 7-RIVERS 3 | 115 | 8.16 |
| 527678 | SMITH 2 | 69 | 3.84 | 527793 | EDDY_STH 3 | 115 | 10.95 | 528095 | 7-RIVERS 6 | 230 | 5.99 |
| 527701 | ARTESIA 2 | 69 | 3.85 | 527798 | EDDY_NTH 3 | 115 | 10.95 | 528109 | CV-LAKEWOOD3 | 115 | 6.32 |
| 527707 | ARTESIA 3 | 115 | 6.66 | 527799 | EDDY_NORTH 6 | 230 | 7.76 | 528116 | CV-IRISHHIL3 | 115 | 6.32 |
| 527710 | EAGLE_CREEK2 | 69 | 2.31 | 527800 | EDDY_SOUTH 6 | 230 | 7.76 | 528132 | OCOTILLO 3 | 115 | 6.13 |
| 527711 | EAGLE_CREEK3 | 115 | 7.23 | 527802 | EDDY_CNTY 7 | 345 | 4.26 | 528137 | N_CANAL 3 | 115 | 8.59 |
| 527715 | NAVAJO_2TP 3 | 115 | 6.90 | 527808 | CV-8_MILE 2 | 67 | 1.81 | 528151 | FIESTA 3 | 115 | 9.65 |
| 527717 | NAVAJO_2 3 | 115 | 6.82 | 527809 | CV-8_MILE 3 | 115 | 5.25 | 528159 | CARLSBAD 2 | 69 | 4.86 |
| 527720 | NAVAJO_3 3 | 115 | 6.86 | 527810 | CV-ABO 2 | 67 | 1.60 | 528160 | CARLSBAD 3 | 115 | 11.08 |
| 527733 | NAVAJO_1 2 | 69 | 2.17 | 527811 | CV-KEWAN_TP3 | 115 | 2.88 | 528178 | PECOS 3 | 115 | 11.67 |
| 527736 | NAVAJO_5TP 3 | 115 | 6.86 | 527821 | CV-DAYTON 3 | 115 | 6.87 | 528179 | PECOS 6 | 230 | 6.35 |
| 527739 | NAVAJO_4 3 | 115 | 6.84 | 527822 | CV-TURKYTRK3 | 115 | 3.38 | 528182 | NORTH_LOVNG3 | 115 | 8.40 |
| 527743 | NAVAJO_5 3 | 115 | 6.84 | 527864 | CUNNINGHAM 3 | 115 | 29.66 | 528226 | HOPI_SUB 3 | 115 | 6.64 |
| 527747 | ARTESIA_TWN2 | 69 | 2.14 | 527865 | CUNNINGHAM 6 | 230 | 17.33 | 584960 | GEN-2015-058 | 115 | 6.86 |
| 527754 | CV-ARTESIA 2 | 69 | 3.12 | 527894 | HOBBS_INT 6 | 230 | 19.11 | 599960 | EPTNP-D6 | 230 | 7.76 |

Table 4-12
Short Circuit Analysis for Study Project GEN-2015-068 (25SP)

| Study Generator GEN-2015-068 | | | | | | | | | | | |
|------------------------------|---------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 511423 | FLE TAP4 | 138 | 8.55 | 525325 | COX 2 | 69 | 3.37 | 526936 | YOAKUM_345 | 345 | 8.97 |
| 511437 | COMANC-4 | 138 | 17.74 | 525326 | COX 3 | 115 | 5.91 | 526944 | LG-PLAINS 3 | 115 | 7.95 |
| 511439 | LWSTAP 4 | 138 | 11.17 | 525413 | LAMTON 2 | 69 | 5.27 | 527010 | OXYBRU_TP 6 | 230 | 13.98 |
| 511456 | O.K.U.-7 | 345 | 5.49 | 525414 | LAMTON 3 | 115 | 7.96 | 527018 | BENNETT 3 | 115 | 13.23 |
| 511458 | ELKCTY-4 | 138 | 11.64 | 525432 | SP-HALFWAY 2 | 69 | 5.90 | 527041 | ARCO_TP 3 | 115 | 13.13 |
| 511466 | L.E.S.-2 | 69 | 16.47 | 525440 | LC-S_OLTON 3 | 115 | 7.67 | 527047 | OXY_WILRD1 3 | 115 | 10.54 |
| 511467 | L.E.S.-4 | 138 | 23.90 | 525446 | SPGLAKE_TP3 | 115 | 11.54 | 527062 | SHELL_CO2 3 | 115 | 16.06 |
| 511468 | L.E.S.-7 | 345 | 12.63 | 525453 | HALE_CNTY 2 | 69 | 6.95 | 527130 | DENVER_N 3 | 115 | 21.10 |
| 511474 | SHERID4 | 138 | 11.99 | 525454 | HALE_CNTY 3 | 115 | 10.29 | 527136 | DENVER_S 3 | 115 | 21.10 |
| 511486 | ELGINJT4 | 138 | 9.95 | 525460 | NEWHART 3 | 115 | 15.20 | 527146 | MUSTANG 3 | 115 | 23.41 |
| 511490 | ELKCITY6 | 230 | 7.86 | 525461 | NEWHART 6 | 230 | 10.92 | 527149 | MUSTANG 6 | 230 | 15.71 |
| 511494 | COMMTAP4 | 138 | 20.99 | 525480 | PLANT_X 3 | 115 | 26.91 | 527151 | GS-MUSTANG 6 | 230 | 15.71 |
| 511541 | SWEETWT6 | 230 | 7.84 | 525481 | PLANT_X 6 | 230 | 23.40 | 527194 | LG-PLSHILL 3 | 115 | 7.57 |
| 511542 | BUFFCK6 | 230 | 5.75 | 525524 | TOLK_EAST 6 | 230 | 26.48 | 527202 | SEAGRAVES 3 | 115 | 8.60 |
| 511544 | DEMPSEY6 | 230 | 4.95 | 525531 | TOLK_WEST 6 | 230 | 26.48 | 527275 | SEMINOLE 3 | 115 | 14.56 |
| 511547 | ROARK6 | 230 | 4.47 | 525543 | TOLK_TAP 6 | 230 | 26.48 | 527276 | SEMINOLE 6 | 230 | 7.72 |
| 511553 | CHISHOLM7 | 345 | 12.40 | 525549 | TOLK 7 | 345 | 7.05 | 527656 | CROSSROADS 7 | 345 | 5.48 |
| 511557 | CHISHOLM6 | 230 | 11.67 | 525614 | W_LITFLDTP3 | 115 | 8.29 | 527800 | EDDY_SOUTH 6 | 230 | 7.76 |
| 514785 | WOODWRD4 | 138 | 12.24 | 525637 | LAMB_CNTY 6 | 230 | 5.56 | 527864 | CUNNNINHAM 3 | 115 | 29.66 |
| 514796 | IODINE-4 | 138 | 7.25 | 525724 | COUNTYLINE 2 | 69 | 2.21 | 527865 | CUNNNINHAM 6 | 230 | 17.33 |
| 514801 | MINCO 7 | 345 | 16.88 | 525731 | SP-ABERNTHY2 | 69 | 3.02 | 527891 | HOBBS_INT 3 | 115 | 32.92 |
| 514901 | CIMARON7 | 345 | 31.14 | 525738 | HALECENTER 2 | 69 | 2.46 | 527894 | HOBBS_INT 6 | 230 | 19.11 |
| 515136 | SUNNYS7 | 345 | 9.92 | 525745 | LH-HALECTR 2 | 69 | 2.44 | 527896 | HOBBS_INT 7 | 345 | 8.43 |
| 515375 | WWRDEHV7 | 345 | 21.53 | 525769 | BARWISE 2 | 69 | 3.76 | 527930 | PCA 3 | 115 | 11.08 |
| 515376 | WWRDEHV4 | 138 | 24.18 | 525779 | FLOYD_CNTY 2 | 69 | 5.31 | 527961 | POTASH_JCT 2 | 69 | 8.41 |
| 515394 | KEENAN 4 | 138 | 8.16 | 525780 | FLOYD_CNTY 3 | 115 | 6.04 | 527962 | POTASH_JCT 3 | 115 | 14.26 |
| 515398 | OUSPRN 4 | 138 | 8.98 | 525790 | FLOYDADA_TP2 | 69 | 2.50 | 527963 | POTASH_JCT 6 | 230 | 6.91 |
| 515407 | TATONGA7 | 345 | 16.58 | 525811 | LH-HARMONY 2 | 69 | 4.25 | 527965 | KIOWA 7 | 345 | 5.60 |
| 515444 | MCNOWND7 | 345 | 16.83 | 525816 | TUCO_INT2 2 | 69 | 4.68 | 527999 | INTREPDW_TP3 | 115 | 12.39 |
| 515458 | BORDER 7 | 345 | 10.26 | 525826 | TUCO_INT 2 | 69 | 7.93 | 528025 | RDRUNNER 3 | 115 | 8.88 |
| 515549 | MNCWIND37 | 345 | 11.60 | 525828 | TUCO_INT 3 | 115 | 20.18 | 528027 | RDRUNNER 7 | 345 | 3.80 |
| 515554 | BVRCNTY7 | 345 | 14.68 | 525830 | TUCO_INT 6 | 230 | 23.39 | 528160 | CARLSBAD 3 | 115 | 11.08 |
| 515599 | NBUFRG7 | 345 | 8.75 | 525832 | TUCO_INT 7 | 345 | 13.55 | 528182 | NORTH_LOVNG3 | 115 | 8.40 |
| 515800 | GRACMNT7 | 345 | 16.23 | 525840 | ANTELOPE 1 6 | 230 | 23.20 | 528185 | N_LOVING 7 | 345 | 4.44 |
| 515802 | GRACMNT4 | 138 | 28.52 | 525853 | LH-WIL&ELLN2 | 69 | 2.58 | 528223 | CHINA_DRAW 7 | 345 | 3.63 |
| 515997 | WWPAR4 | 138 | 17.31 | 525860 | SP-BECTON 2 | 69 | 2.29 | 528333 | LE-WEST_SUB3 | 115 | 8.79 |
| 520814 | ANADARK4 | 138 | 31.21 | 525885 | SP-NEWDEAL 2 | 69 | 3.39 | 528355 | MADDOX 3 | 115 | 27.76 |
| 521089 | WASHITA4 | 138 | 27.77 | 525892 | WHITE&MONRO2 | 69 | 2.56 | 528433 | NEW_NHOBBS 3 | 115 | 8.04 |
| 522819 | LP-NORTHEST2 | 69 | 13.12 | 525925 | CROSBY 2 | 69 | 4.78 | 528435 | MILLEN 3 | 115 | 11.67 |
| 522822 | LP-NORTHWEST2 | 69 | 4.60 | 525926 | CROSBY 3 | 115 | 4.50 | 528604 | ANDREWS 6 | 230 | 6.96 |
| 522823 | LP-MILWAKEE6 | 230 | 13.04 | 526076 | STANTON_W 3 | 115 | 9.52 | 528610 | GAINES_GEN 6 | 230 | 8.58 |
| 522828 | LP-MILWAKEE2 | 69 | 8.30 | 526109 | SP-ERSKINE 3 | 115 | 11.63 | 528611 | GAINESGENTP6 | 230 | 9.92 |
| 522832 | LP-VICKSBRG2 | 69 | 14.09 | 526130 | SP-CARLISLE2 | 69 | 2.11 | 528626 | LE-PLNSNT 2 | 69 | 4.37 |
| 522857 | LP-SOUTHEST2 | 69 | 24.55 | 526146 | INDIANA 3 | 115 | 9.89 | 539800 | CLARKCOUNTY7 | 345 | 11.60 |
| 522861 | LP-SOUTHEST6 | 230 | 17.10 | 526159 | CARLISLE 2 | 69 | 2.58 | 539801 | THISTLE7 | 345 | 15.50 |
| 522866 | LP-COOK 2 | 69 | 34.97 | 526160 | CARLISLE 3 | 115 | 13.56 | 539804 | THISTLE4 | 138 | 16.43 |
| 522870 | LP-HOLLY 6 | 230 | 16.91 | 526161 | CARLISLE 6 | 230 | 13.44 | 560000 | G11-14-TAP | 345 | 13.67 |
| 522879 | LP-WADSWRTH2 | 69 | 22.78 | 526162 | LP-DOUD_TP 3 | 115 | 11.90 | 560013 | G14-057T | 345 | 9.58 |
| 522888 | LP-WADSWRTH6 | 230 | 12.59 | 526176 | LP-DOUD 3 | 115 | 9.20 | 560027 | G14-074-TAP | 345 | 6.75 |
| 523309 | MOORE_CNTY 6 | 230 | 6.70 | 526184 | SW_6878 2 | 69 | 2.17 | 560033 | G15248G1525T | 345 | 19.59 |
| 523779 | STLN-DEMARC6 | 230 | 7.03 | 526192 | MURPHY 3 | 115 | 10.81 | 560050 | G15-031-TAP | 230 | 9.05 |
| 523869 | CHAN/TASCOS6 | 230 | 3.84 | 526199 | SP-FRANKFRD3 | 115 | 9.76 | 560059 | G1579&G1580T | 230 | 9.26 |
| 523959 | POTTER_CO 6 | 230 | 20.24 | 526213 | ALLEN 3 | 115 | 10.81 | 562004 | G11-025-TAP | 115 | 4.61 |
| 523961 | POTTER_CO 7 | 345 | 7.43 | 526267 | LUBBCK_STH 2 | 69 | 4.37 | 562075 | G11-051-TAP | 345 | 17.57 |
| 523979 | HARRNG_EST 6 | 230 | 26.01 | 526268 | LUBBCK_STH 3 | 115 | 19.38 | 562480 | G13-027-TAP | 230 | 9.19 |
| 524010 | ROLLHILLS 6 | 230 | 19.27 | 526269 | LUBBCK_STH 6 | 230 | 19.02 | 581112 | GEN-2011-014 | 345 | 12.24 |
| 524044 | NICHOLS 6 | 230 | 25.27 | 526284 | PLANTERS 2 | 69 | 6.34 | 581137 | GEN-2011-025 | 115 | 4.61 |
| 524267 | BUSHLAND 6 | 230 | 9.64 | 526297 | LUBBCK_EST 2 | 69 | 8.07 | 582019 | GEN-2011-019 | 345 | 21.53 |
| 524365 | RANDALL 6 | 230 | 14.24 | 526298 | LUBBCK_EST 3 | 115 | 15.43 | 582020 | GEN-2011-020 | 345 | 21.53 |
| 524414 | AMA_SOUTH 3 | 115 | 16.59 | 526299 | LUBBCK_EST 6 | 230 | 13.48 | 583090 | G1149&G1504 | 345 | 8.42 |
| 524415 | AMA_SOUTH 6 | 230 | 13.43 | 526310 | CLUTTER 2 | 69 | 5.46 | 583110 | GEN-2011-051 | 345 | 17.57 |
| 524622 | DEAFSMITH 3 | 115 | 12.18 | 526337 | JONES 6 | 230 | 21.04 | 583340 | GEN-2012-020 | 230 | 9.26 |
| 524623 | DEAFSMITH 6 | 230 | 7.78 | 526434 | SUNDOWN 3 | 115 | 11.59 | 583819 | ASG12014-001 | 115 | 11.63 |
| 524746 | CASTRO_CNTY3 | 115 | 11.76 | 526435 | SUNDOWN 6 | 230 | 11.12 | 583840 | GEN-2013-027 | 230 | 8.17 |
| 524770 | PLSNT_HILL 6 | 230 | 6.19 | 526460 | AMOCO_SS 6 | 230 | 9.75 | 584070 | GEN-2014-057 | 345 | 6.62 |
| 524875 | OASIS 6 | 230 | 7.42 | 526475 | YUMA_INT 3 | 115 | 11.19 | 584440 | GEN-2014-074 | 345 | 6.34 |
| 524908 | ROOSEVELT 3 | 115 | 10.56 | 526481 | SP-WOLF_TP 3 | 115 | 11.38 | 584640 | GEN-2015-022 | 115 | 10.34 |

Table 4-12 (continued)
Short Circuit Analysis for Study Project GEN-2015-068 (25SP)

| Study Generator GEN-2015-068 | | | | | | | | | | | |
|------------------------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 524909 | ROSEVELT_N 6 | 230 | 8.91 | 526524 | WOLFFORTH 3 | 115 | 11.68 | 584750 | GEN-2015-031 | 230 | 9.05 |
| 524911 | ROSEVELT_S 6 | 230 | 8.91 | 526525 | WOLFFORTH 6 | 230 | 13.63 | 584980 | GEN-2015-060 | 138 | 5.70 |
| 524915 | SW_4K33 6 | 230 | 8.91 | 526562 | SLATON 2 | 69 | 2.48 | 585060 | GEN-2015-068 | 345 | 10.76 |
| 525019 | EMU&VLY_TP 3 | 115 | 7.33 | 526602 | SP-WOODROW 3 | 115 | 9.48 | 585080 | GEN-2015-071 | 345 | 10.34 |
| 525056 | BC-EARTH 3 | 115 | 9.16 | 526656 | LYNN_CNTY 3 | 115 | 5.66 | 585120 | GEN-2015-075 | 69 | 1.55 |
| 525124 | HART_INDUST3 | 115 | 7.63 | 526676 | GRASSLAND 3 | 115 | 6.17 | 585160 | G1579&G1580 | 230 | 8.78 |
| 525179 | TULIA_TP 3 | 115 | 6.30 | 526677 | GRASSLAND 6 | 230 | 6.53 | 585180 | GEN-2015-081 | 345 | 14.39 |
| 525191 | KRESS_INT 2 | 69 | 4.44 | 526679 | CIRRUS_WND 6 | 230 | 5.07 | 585270 | GEN-2015-093 | 345 | 9.54 |
| 525192 | KRESS_INT 3 | 115 | 11.21 | 526694 | GRAHAM 3 | 115 | 2.69 | 590001 | OKLEHV24 | 138 | 4.79 |
| 525212 | SWISHER 3 | 115 | 10.34 | 526736 | TERRY_CNTY 3 | 115 | 10.93 | 590003 | OKLEHV14 | 138 | 4.80 |
| 525213 | SWISHER 6 | 230 | 10.52 | 526784 | AMOCOWASSON6 | 230 | 13.92 | 599074 | NTHBUF_EHV2 | 345 | 6.63 |
| 525225 | KRESS_RURAL3 | 115 | 6.26 | 526792 | PRENTICE 3 | 115 | 5.96 | 599891 | OKLAUN 7 | 345 | 4.04 |
| 525272 | KISER 3 | 115 | 5.10 | 526928 | PLAINS_INT 3 | 115 | 9.89 | 599955 | PNM-DC6 | 230 | 8.91 |
| 525291 | PLAINVW_TP 2 | 69 | 6.52 | 526934 | YOAKUM 3 | 115 | 16.81 | | | | |
| 525298 | S_PLAINVEW 2 | 69 | 2.59 | 526935 | YOAKUM 6 | 230 | 17.62 | | | | |
| 525272 | KISER 3 | 115 | 5.10 | 526298 | LUBBCK_EST 3 | 115 | 15.24 | | | | |

Table 4-13
Short Circuit Analysis for Study Project GEN-2015-075 (25SP)

| Study Generator GEN-2015-075 | | | | | | | | | | | |
|------------------------------|---------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 515458 | BORDER 7 | 345 | 10.26 | 525840 | ANTELOPE_1 6 | 230 | 23.20 | 526298 | LUBBCK_EST 3 | 115 | 15.43 |
| 522822 | LP-NORTHWEST2 | 69 | 4.60 | 526076 | STANTON_W 3 | 115 | 9.52 | 526299 | LUBBCK_EST 6 | 230 | 13.48 |
| 522823 | LP-MILWAKEE6 | 230 | 13.04 | 526109 | SP-ERSKINE 3 | 115 | 11.63 | 526337 | JONES 6 | 230 | 21.04 |
| 522828 | LP-MILWAKEE2 | 69 | 8.30 | 526130 | SP-CARLISLE2 | 69 | 2.11 | 526434 | SUNDOWN 3 | 115 | 11.59 |
| 522832 | LP-VICKSBRG2 | 69 | 14.09 | 526146 | INDIANA 3 | 115 | 9.89 | 526435 | SUNDOWN 6 | 230 | 11.12 |
| 522857 | LP-SOUTHEST2 | 69 | 24.55 | 526159 | CARLISLE 2 | 69 | 2.58 | 526460 | AMOCO_SS 6 | 230 | 9.75 |
| 522861 | LP-SOUTHEST6 | 230 | 17.10 | 526160 | CARLISLE 3 | 115 | 13.56 | 526469 | SP-YUMA 2 | 69 | 3.07 |
| 522870 | LP-HOLLY 6 | 230 | 16.91 | 526161 | CARLISLE 6 | 230 | 13.44 | 526475 | YUMA_INT 3 | 115 | 11.19 |
| 524911 | ROSEVELT_S 6 | 230 | 8.91 | 526162 | LP-DOUD_TP 3 | 115 | 11.90 | 526481 | SP-WOLF_TP 3 | 115 | 11.38 |
| 525212 | SWISHER 3 | 115 | 10.34 | 526176 | LP-DOUD 3 | 115 | 9.20 | 526483 | SP-WOLFORTH3 | 115 | 8.80 |
| 525213 | SWISHER 6 | 230 | 10.52 | 526184 | SW_6878 2 | 69 | 2.17 | 526524 | WOLFFORTH 3 | 115 | 11.68 |
| 525454 | HALE_CNTY 3 | 115 | 10.29 | 526192 | MURPHY 3 | 115 | 10.81 | 526525 | WOLFFORTH 6 | 230 | 13.63 |
| 525461 | NEWHART 6 | 230 | 10.92 | 526199 | SP-FRANKFRD3 | 115 | 9.76 | 526677 | GRASSLAND 6 | 230 | 6.53 |
| 525481 | PLANT_X 6 | 230 | 23.40 | 526205 | IVORY 2 | 69 | 3.94 | 526736 | TERRY_CNTY 3 | 115 | 10.93 |
| 525524 | TOLK_EAST 6 | 230 | 26.48 | 526213 | ALLEN 3 | 115 | 10.81 | 526936 | YOAKUM_345 | 345 | 8.97 |
| 525543 | TOLK_TAP 6 | 230 | 26.48 | 526221 | BATTON_N 2 | 69 | 1.78 | 560027 | G14-074-TAP | 345 | 6.75 |
| 525780 | FLOYD_CNTY 3 | 115 | 6.04 | 526228 | BATTON_S 2 | 69 | 2.72 | 560050 | G15-031-TAP | 230 | 9.05 |
| 525816 | TUCO_INT2 2 | 69 | 4.68 | 526243 | SP-QUAKER 3 | 115 | 9.80 | 583340 | GEN-2012-020 | 230 | 9.26 |
| 525826 | TUCO_INT 2 | 69 | 7.93 | 526256 | IVORY_TP 2 | 69 | 3.94 | 583810 | ASG2013-006 | 115 | 8.80 |
| 525828 | TUCO_INT 3 | 115 | 20.18 | 526267 | LUBBCK_STH 2 | 69 | 4.37 | 583819 | ASG2014-001 | 115 | 11.63 |
| 525830 | TUCO_INT 6 | 230 | 23.39 | 526268 | LUBBCK_STH 3 | 115 | 19.38 | 585060 | GEN-2015-068 | 345 | 10.76 |
| 525832 | TUCO_INT 7 | 345 | 13.55 | 526269 | LUBBCK_STH 6 | 230 | 19.02 | 585120 | GEN-2015-075 | 69 | 1.55 |

Table 4-14
Short Circuit Analysis for Study Project GEN-2015-079 and GEN-2015-080 (25SP)

| Study Generator GEN-2015-079 and GEN-2015-080 | | | | | | | | | | | |
|---|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
| 511456 | O.K.U.-7 | 345 | 5.49 | 527046 | OXY_WILRD2 3 | 115 | 10.52 | 528095 | 7-RIVERS 6 | 230 | 5.99 |
| 511553 | CHISHOLM7 | 345 | 12.40 | 527047 | OXY_WILRD1 3 | 115 | 10.54 | 528160 | CARLSBAD 3 | 115 | 11.08 |
| 515458 | BORDER 7 | 345 | 10.26 | 527051 | ODC_TP 3 | 115 | 13.24 | 528178 | PECOS 3 | 115 | 11.67 |
| 524623 | DEAFSMITH 6 | 230 | 7.78 | 527062 | SHELL_CO2 3 | 115 | 16.06 | 528179 | PECOS 6 | 230 | 6.35 |
| 524770 | PLSNT_HILL 6 | 230 | 6.19 | 527080 | EL_PASO 3 | 115 | 15.81 | 528182 | NORTH_LOVNG3 | 115 | 8.40 |
| 524908 | ROOSEVELT 3 | 115 | 10.56 | 527105 | SAN_ANDS_TP3 | 115 | 16.48 | 528185 | N_LOVING 7 | 345 | 4.44 |
| 524909 | ROSEVELT_N 6 | 230 | 8.91 | 527125 | DENVER_CTY 2 | 69 | 8.65 | 528223 | CHINA_DRAW 7 | 345 | 3.63 |
| 524911 | ROSEVELT_S 6 | 230 | 8.91 | 527130 | DENVER_N 3 | 115 | 21.10 | 528317 | ENRON_TP 3 | 115 | 6.98 |
| 524915 | SW_4K33 6 | 230 | 8.91 | 527136 | DENVER_S 3 | 115 | 21.10 | 528325 | LE-WAITS 3 | 115 | 6.76 |
| 525213 | SWISHER 6 | 230 | 10.52 | 527146 | MUSTANG 3 | 115 | 23.41 | 528333 | LE-WEST_SUB3 | 115 | 8.79 |
| 525461 | NEWHART 6 | 230 | 10.92 | 527149 | MUSTANG 6 | 230 | 15.71 | 528334 | LE-LOVINTON3 | 115 | 8.71 |
| 525480 | PLANT_X 3 | 115 | 26.91 | 527151 | GS-MUSTANG 6 | 230 | 15.71 | 528348 | BUCKEYE_TP 3 | 115 | 8.43 |
| 525481 | PLANT_X 6 | 230 | 23.40 | 527194 | LG-PLSHILL 3 | 115 | 7.57 | 528355 | MADDOX 3 | 115 | 27.76 |
| 525524 | TOLK_EAST 6 | 230 | 26.48 | 527201 | SEAGRAVES 2 | 69 | 5.42 | 528385 | BUCKEYE 3 | 115 | 7.56 |
| 525531 | TOLK_WEST 6 | 230 | 26.48 | 527202 | SEAGRAVES 3 | 115 | 8.60 | 528392 | PEARLE 3 | 115 | 6.41 |
| 525543 | TOLK_TAP 6 | 230 | 26.48 | 527238 | ROZ 3 | 115 | 11.23 | 528394 | QUAHADA 3 | 115 | 8.40 |
| 525549 | TOLK 7 | 345 | 7.05 | 527242 | AMERADA 3 | 115 | 11.39 | 528399 | LEA_NATIONL3 | 115 | 7.03 |
| 525636 | LAMB_CNTY 3 | 115 | 9.76 | 527262 | SULPHUR 3 | 115 | 5.72 | 528413 | TAYLOR 3 | 115 | 14.61 |
| 525637 | LAMB_CNTY 6 | 230 | 5.56 | 527275 | SEMINOLE 3 | 115 | 14.56 | 528422 | DCP_ZIA_TP 3 | 115 | 7.25 |
| 525828 | TUCO_INT 3 | 115 | 20.18 | 527276 | SEMINOLE 6 | 230 | 7.72 | 528433 | NEW_NHOBBS 3 | 115 | 8.04 |
| 525830 | TUCO_INT 6 | 230 | 23.39 | 527284 | RUSSELL 3 | 115 | 9.09 | 528435 | MILLEN 3 | 115 | 11.67 |
| 525832 | TUCO_INT 7 | 345 | 13.55 | 527286 | XTO_RUSSEL 3 | 115 | 10.03 | 528442 | NE_HOBBS 3 | 115 | 11.97 |
| 525840 | ANTELOPE_1 6 | 230 | 23.20 | 527322 | GAINES 3 | 115 | 9.39 | 528463 | SANGER_SW 3 | 115 | 16.22 |
| 526036 | LC-OPDYKE 3 | 115 | 5.93 | 527340 | DOSS 3 | 115 | 8.02 | 528484 | SW_4J44 3 | 115 | 11.19 |
| 526161 | CARLISLE 6 | 230 | 13.44 | 527362 | JOHNSON_DRW3 | 115 | 10.76 | 528491 | MONUMENT 3 | 115 | 15.68 |
| 526269 | LUBBCK_STH 6 | 230 | 19.02 | 527363 | HIGG 3 | 115 | 10.22 | 528498 | W_HOBBS 3 | 115 | 11.75 |
| 526337 | JONES 6 | 230 | 21.04 | 527483 | CHAVES_CNTY6 | 230 | 4.08 | 528568 | MONUMNT_TP 3 | 115 | 10.10 |
| 526352 | LEHMAN 3 | 115 | 6.08 | 527597 | TWEEDY 3 | 115 | 4.93 | 528575 | OXYPERMIAN 3 | 115 | 15.54 |
| 526424 | PACIFIC 3 | 115 | 9.78 | 527711 | EAGLE_CREEK3 | 115 | 7.23 | 528582 | BYRD 3 | 115 | 8.05 |
| 526434 | SUNDOWN 3 | 115 | 11.59 | 527793 | EDDY_STH 3 | 115 | 10.95 | 528602 | ANDREWS 3 | 115 | 9.05 |
| 526435 | SUNDOWN 6 | 230 | 11.12 | 527798 | EDDY_NTH 3 | 115 | 10.95 | 528603 | NA_ENRICH 3 | 115 | 9.12 |
| 526445 | AMOCO_TP 3 | 115 | 10.92 | 527799 | EDDY_NORTH 6 | 230 | 7.76 | 528604 | ANDREWS 6 | 230 | 6.96 |
| 526460 | AMOCO_SS 6 | 230 | 9.75 | 527800 | EDDY_SOUTH 6 | 230 | 7.76 | 528610 | GAINES_GEN 6 | 230 | 8.58 |
| 526491 | LG-CLAUENE 3 | 115 | 9.18 | 527802 | EDDY_CNTY 7 | 345 | 4.26 | 528611 | GAINESGENTP6 | 230 | 9.92 |
| 526524 | WOLFFORTH 3 | 115 | 11.68 | 527809 | CV-8_MILE 3 | 115 | 5.25 | 528618 | LE-LOVINTON2 | 69 | 9.31 |
| 526525 | WOLFFORTH 6 | 230 | 13.63 | 527864 | CUNNINGHAM 3 | 115 | 29.66 | 528626 | LE-PLNSINT 2 | 69 | 4.37 |
| 526735 | TERRY_CNTY 2 | 69 | 7.10 | 527865 | CUNNINGHAM 6 | 230 | 17.33 | 528627 | LE-TXACO_TP3 | 115 | 7.25 |
| 526736 | TERRY_CNTY 3 | 115 | 10.93 | 527891 | HOBBS_INT 3 | 115 | 32.92 | 528740 | LE-PLANS_TP2 | 69 | 3.62 |
| 526784 | AMOCOWASSON6 | 230 | 13.92 | 527894 | HOBBS_INT 6 | 230 | 19.11 | 560027 | G14-074-TAP | 345 | 6.75 |
| 526792 | PRENTICE 3 | 115 | 5.96 | 527896 | HOBBS_INT 7 | 345 | 8.43 | 560058 | G15-077-TAP | 115 | 8.27 |
| 526928 | PLAINS_INT 3 | 115 | 9.89 | 527930 | PCA 3 | 115 | 11.08 | 560059 | G1579&G1580T | 230 | 9.26 |
| 526934 | YOAKUM 3 | 115 | 16.81 | 527961 | POTASH_JCT 2 | 69 | 8.41 | 562480 | G13-027-TAP | 230 | 9.19 |
| 526935 | YOAKUM 6 | 230 | 17.62 | 527962 | POTASH_JCT 3 | 115 | 14.26 | 583090 | G1149&G1504 | 345 | 8.42 |
| 526936 | YOAKUM_345 | 345 | 8.97 | 527963 | POTASH_JCT 6 | 230 | 6.91 | 583340 | GEN-2012-020 | 230 | 9.26 |
| 526944 | LG-PLAINS 3 | 115 | 7.95 | 527965 | KIOWA 7 | 345 | 5.60 | 583840 | GEN-2013-027 | 230 | 8.17 |
| 527010 | OXYBRU_TP 6 | 230 | 13.98 | 527999 | INTREPDW_TP3 | 115 | 12.39 | 584440 | GEN-2014-074 | 345 | 6.34 |
| 527018 | BENNETT 3 | 115 | 13.23 | 528025 | RDRUNNER 3 | 115 | 8.88 | 585060 | GEN-2015-068 | 345 | 10.76 |
| 527036 | SHELL_C2 3 | 115 | 12.88 | 528027 | RDRUNNER 7 | 345 | 3.80 | 585160 | G1579&G1580 | 230 | 8.78 |
| 527041 | ARCO_TP 3 | 115 | 13.13 | 528094 | 7-RIVERS 3 | 115 | 8.16 | 599960 | EPTNP-D6 | 230 | 7.76 |

SECTION 5: POWER FACTOR ANALYSIS

The objective of this task is to quantify the power factor at the point of interconnection for the wind farms during base case and system contingencies. SPP transmission planning practice requires interconnecting generation projects to maintain the power factor (pf) at the Point of Interconnection (POI) within +/- 0.95 pf for system intact conditions and for post-contingency conditions. This is analyzed by having the wind farm maintain a prescribed voltage schedule at the point of interconnection of 1.0 p.u. voltage.

The 2016 Winter Peak, 2017 Summer Peak, 2020 Summer Peak, 2020 Winter Peak, and 2025 Summer Peak power flows provided by SPP were examined prior to the Power Factor Analysis to ensure they contained the proposed study project modeled at 100% of the nameplate rating and any previously queued projects listed in Table 2-2. There was no suspect power flow data in the study area. The proposed study project and any previously queued projects at the same point of interconnection were turned off during the power factor analysis. The wind farm(s) were then replaced by a generator modeled at the high side bus with the same real power (MW) capability as the wind farm(s) and open limits for the reactive power set points (Mvar). The generator was set to hold the POI scheduled bus voltage. All N-1, three-phase fault contingencies from Table 2-3 were then applied and the reactive power required to maintain the bus voltage was recorded.

5.1 Approach

The upgrades that were identified in the Stability Analysis were implemented to each power case for the power factor analysis. Refer to Section 3 for the necessary upgrades.

GEN-2015-020 was disabled and a generator was placed at the study project's high side bus. The generator was modeled with $P_{GEN} = 100.0$ MW, $Q_{Min} = -9999$ Mvar, and $Q_{Max} = 9999$ Mvar. All buses and transformers connected from the study project's high side bus to GEN-2015-020 were disabled. The scheduled voltage was set to 1.0327 p.u. for 2016 Winter Peak conditions, 1.0276 p.u. for 2017 Summer Peak conditions, 1.0179 p.u. for 2020 Summer Peak conditions, 1.0287 p.u. for 2020 Winter Peak conditions, and 1.0213 p.u. for 2025 Summer Peak conditions.

GEN-2015-031 was disabled and a generator was placed at the study project's high side bus. The generator was modeled with $P_{GEN} = 150.53$ MW, $Q_{Min} = -9999$ Mvar, and $Q_{Max} = 9999$ Mvar. All buses and transformers connected from the study project's high side bus to GEN-2015-031 were disabled. The scheduled voltage was set to 1.001 for 2020 Winter Peak conditions and 1.00 p.u. for the 2016 Winter Peak, 2017 Summer Peak, 2020 Summer Peak, and 2025 Summer Peak conditions.

GEN-2015-056 and GEN-2014-047 were disabled and a generator was placed at the corresponding project's high side bus. GEN-2015-056 was modeled with $P_{GEN} = 101.0$ MW and GEN-2014-

047 was modeled with PGEN = 40.0 MW. Both generators reactive capability was modeled with QMin = -9999 Mvar and QMax = 9999 Mvar. All buses and transformers connected from the project's high side bus to the corresponding project were disabled. The scheduled voltage was set to 1.0059 p.u. for 2016 Winter Peak conditions, 1.0027 p.u. for 2017 Summer Peak conditions, 1.0125 p.u. for 2020 Summer Peak conditions, 1.0119 p.u. for 2020 Winter Peak conditions, and 1.0084 p.u. for 2025 Summer Peak conditions.

GEN-2015-058 was disabled and a generator was placed at the study project's high side bus. The generator was modeled with PGEN = 50.0 MW, QMin = -9999 Mvar, and QMax = 9999 Mvar. All buses and transformers connected from the study project's high side bus to GEN-2015-058 were disabled. The scheduled voltage was set to 1.0175 p.u. for 2016 Winter Peak conditions, 1.0216 p.u. for 2017 Summer Peak conditions, 1.0274 p.u. for 2020 Summer Peak conditions, 1.0127 p.u. for 2020 Winter Peak conditions, and 1.0281 p.u. for 2025 Summer Peak conditions.

GEN-2015-068 and the ELK generation was disabled and a generator was placed at the study project's high side bus and the ELK generation high side bus (GEN-2015-068 POI). The GEN-2015-068 generator was modeled with PGEN = 300.0 MW, Qmin = -9999 Mvar, Qmax = 9999 Mvar. The ELK generator was modeled with PGEN = 411.0 MW, QMin = -9999 Mvar, and QMax = 9999 Mvar. All buses and transformers connected from the study project's high side bus to both projects were disabled. The scheduled voltage was set to 1.0047 p.u. for 2020 Summer Peak conditions and 1.0079 p.u. for 2025 Summer Peak conditions. The scheduled voltage was set to 1.00 p.u. for 2016 Winter Peak conditions, 2017 Summer Peak conditions, and 2020 Winter Peak conditions.

GEN-2015-075 was disabled and a generator was placed at the study project's high side bus. The generator was modeled with PGEN = 50.0 MW, QMin = -9999 Mvar, and QMax = 9999 Mvar. All buses and transformers connected from the study project's high side bus to GEN-2015-075 were disabled. The scheduled voltage was set to 1.0044 p.u. for 2016 Winter Peak conditions, 1.0071 p.u. for 2017 Summer Peak conditions, 1.0006 p.u. for 2020 Summer Peak conditions, 1.0027 p.u. for 2020 Winter Peak conditions, and 1.0049 p.u. for 2025 Summer Peak conditions.

GEN-2015-079 and GEN-2015-080 were disabled and a generator was placed at the corresponding study project's high side bus. Both generators were modeled with PGEN = 129.2 MW, QMin = -9999 Mvar, and QMax = 9999 Mvar. All buses and transformers connected from the study project's high side bus to GEN-2015-079 and GEN-2015-080 were disabled. The scheduled voltage was set to 1.0019 p.u. for 2016 Winter Peak conditions, 1.00 p.u. for 2017 Summer Peak conditions, 1.0012 p.u. for 2020 Summer Peak conditions, 1.0022 p.u. for 2020 Winter Peak conditions, and 1.0045 p.u. for 2025 Summer Peak conditions.

5.2 Power Factor Analysis Results

The power factor was calculated for the 2016 Winter Peak, 2017 Summer Peak, 2020 Summer Peak, 2020 Winter Peak, and 2025 Summer Peak condition. The following tables show the power factor results for the study generators:

- Table 5-1: Power Factor Analysis for GEN-2015-020
- Table 5-2: Power Factor Analysis for GEN-2015-031
- Table 5-3: Power Factor Analysis for GEN-2015-056
- Table 5-4: Power Factor Analysis for GEN-2015-058
- Table 5-5: Power Factor Analysis for GEN-2015-068
- Table 5-6: Power Factor Analysis for GEN-2015-075
- Table 5-7: Power Factor Analysis for GEN-2015-079
- Table 5-8: Power Factor Analysis for GEN-2015-080

Note that a positive Q (Mvar) output illustrates that the generator is absorbing reactive power from the system, implying a leading power factor; a negative Q (Mvar) illustrates that the generator is supplying reactive power to the system, implying a lagging power factor.

**Table 5-1
Power Factor Analysis: GEN-2015-020**

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|-----------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|
| | | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) |
| 0 | Base | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.60 |
| 1 | FLT01-3PH | 0.986 | Leading | 16.99 | 0.990 | Leading | 14.23 | 0.996 | Leading | 9.52 | 0.989 | Leading | 14.87 | 0.994 | Leading | 11.34 |
| 2 | FLT02-3PH | 0.986 | Leading | 16.80 | 0.990 | Leading | 14.00 | 0.996 | Leading | 9.34 | 0.989 | Leading | 14.72 | 0.994 | Leading | 11.14 |
| 3 | FLT03-3PH | 0.984 | Leading | 18.08 | 0.989 | Leading | 15.11 | 0.994 | Leading | 11.28 | 0.986 | Leading | 17.19 | 0.993 | Leading | 11.78 |
| 4 | FLT04-3PH | 0.996 | Leading | 9.44 | 1.000 | Leading | 1.36 | 0.999 | Leading | 3.85 | 0.998 | Leading | 6.57 | 0.999 | Leading | 4.71 |
| 5 | FLT05-3PH | 0.989 | Leading | 14.81 | 0.988 | Leading | 15.38 | 0.996 | Leading | 9.31 | 0.996 | Leading | 9.20 | 0.994 | Leading | 11.08 |
| 6 | FLT06-3PH | 0.986 | Leading | 17.05 | 0.990 | Leading | 14.27 | 0.995 | Leading | 9.57 | 0.989 | Leading | 14.94 | 0.994 | Leading | 11.39 |
| 7 | FLT07-3PH | 0.986 | Leading | 17.03 | 0.990 | Leading | 14.26 | 0.995 | Leading | 9.55 | 0.989 | Leading | 14.91 | 0.994 | Leading | 11.37 |
| 8 | FLT11-3PH | 0.986 | Leading | 17.10 | 0.986 | Leading | 16.88 | 0.993 | Leading | 11.64 | 0.990 | Leading | 14.46 | 0.989 | Leading | 15.27 |
| 9 | FLT12-3PH | 0.985 | Leading | 17.36 | 0.986 | Leading | 17.15 | 0.993 | Leading | 11.97 | 0.989 | Leading | 14.79 | 0.988 | Leading | 15.61 |
| 10 | FLT13-3PH | 0.986 | Leading | 17.09 | 0.991 | Leading | 13.56 | 0.996 | Leading | 9.00 | 0.989 | Leading | 15.05 | 0.994 | Leading | 10.63 |
| 11 | FLT14-3PH | 0.987 | Leading | 16.57 | 0.999 | Leading | 5.32 | 0.998 | Leading | 5.72 | 0.993 | Leading | 11.72 | 0.998 | Leading | 5.96 |
| 12 | FLT15-3PH | 0.994 | Leading | 11.38 | 0.990 | Leading | 14.34 | 0.999 | Leading | 4.91 | 0.998 | Leading | 5.98 | 0.998 | Leading | 7.04 |
| 13 | FLT16-3PH | 0.982 | Leading | 19.13 | 0.982 | Leading | 19.02 | 0.990 | Leading | 14.48 | 0.984 | Leading | 17.91 | 0.987 | Leading | 16.43 |
| 14 | FLT17-3PH | 0.986 | Leading | 16.75 | 0.990 | Leading | 14.21 | 0.996 | Leading | 9.51 | 0.989 | Leading | 14.64 | 0.994 | Leading | 11.32 |
| 15 | FLT18-3PH | 0.986 | Leading | 16.94 | 0.989 | Leading | 14.63 | 0.995 | Leading | 9.96 | 0.989 | Leading | 14.81 | 0.993 | Leading | 11.75 |
| 16 | FLT19-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.60 |
| 17 | FLT20-3PH | 0.986 | Leading | 16.96 | 0.990 | Leading | 14.25 | 0.995 | Leading | 9.74 | 0.989 | Leading | 15.09 | 0.993 | Leading | 11.51 |
| 18 | FLT21-3PH | 0.970 | Leading | 25.02 | 0.973 | Leading | 23.73 | 0.979 | Leading | 20.71 | 0.973 | Leading | 23.77 | 0.976 | Leading | 22.54 |
| 19 | FLT22-3PH | 0.980 | Leading | 20.50 | 0.978 | Leading | 21.29 | 0.980 | Leading | 20.13 | 0.981 | Leading | 19.55 | 0.981 | Leading | 19.74 |
| 20 | FLT23-3PH | 0.981 | Leading | 19.52 | 0.981 | Leading | 19.82 | 0.988 | Leading | 15.54 | 0.983 | Leading | 18.46 | 0.985 | Leading | 17.76 |
| 21 | FLT24-3PH | 0.971 | Leading | 24.74 | 0.974 | Leading | 23.21 | 0.980 | Leading | 20.06 | 0.974 | Leading | 23.43 | 0.977 | Leading | 21.80 |
| 22 | FLT25-3PH | 0.984 | Leading | 17.90 | 0.992 | Leading | 12.99 | 0.997 | Leading | 8.12 | 0.991 | Leading | 13.25 | 0.995 | Leading | 10.39 |
| 23 | FLT26-3PH | 0.994 | Leading | 11.09 | 0.994 | Leading | 11.30 | 0.998 | Leading | 6.37 | 0.990 | Leading | 14.49 | 0.997 | Leading | 7.38 |
| 24 | FLT27-3PH | 0.987 | Leading | 16.02 | 0.992 | Leading | 12.81 | 0.996 | Leading | 8.56 | 0.990 | Leading | 14.28 | 0.995 | Leading | 10.06 |
| 25 | FLT28-3PH | 0.990 | Lagging | -14.51 | 0.998 | Leading | 6.94 | 1.000 | Leading | 2.94 | 0.997 | Lagging | -7.72 | 1.000 | Leading | 0.96 |
| 26 | FLT29-3PH | 0.996 | Leading | 9.13 | 1.000 | Leading | 2.05 | 0.999 | Leading | 3.24 | 0.996 | Leading | 8.64 | 1.000 | Lagging | -2.04 |
| 27 | FLT30-3PH | 0.993 | Leading | 12.03 | 0.987 | Leading | 16.49 | 0.995 | Leading | 9.87 | 0.995 | Leading | 10.37 | 0.992 | Leading | 12.56 |
| 28 | FLT31-3PH | 0.992 | Leading | 12.46 | 0.994 | Leading | 10.81 | 0.998 | Leading | 5.99 | 0.994 | Leading | 10.55 | 0.997 | Leading | 8.06 |
| 29 | FLT34-3PH | 0.988 | Leading | 15.45 | 0.991 | Leading | 13.35 | 0.996 | Leading | 8.55 | 0.991 | Leading | 13.22 | 0.994 | Leading | 10.70 |
| 30 | FLT35-3PH | 0.987 | Leading | 16.42 | 0.990 | Leading | 14.19 | 0.996 | Leading | 9.35 | 0.990 | Leading | 14.30 | 0.994 | Leading | 11.38 |
| 31 | FLT36-3PH | 0.986 | Leading | 17.05 | 0.990 | Leading | 14.58 | 0.995 | Leading | 9.72 | 0.989 | Leading | 15.00 | 0.993 | Leading | 11.51 |
| 32 | FLT37-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.60 |
| 33 | FLT38-3PH | 0.986 | Leading | 16.88 | 0.990 | Leading | 14.44 | 0.995 | Leading | 9.58 | 0.989 | Leading | 14.81 | 0.994 | Leading | 11.38 |
| 34 | FLT39-3PH | 0.985 | Leading | 17.24 | 0.990 | Leading | 14.58 | 0.995 | Leading | 9.71 | 0.989 | Leading | 15.06 | 0.993 | Leading | 11.48 |
| 35 | FLT40-3PH | 0.986 | Leading | 17.12 | 0.989 | Leading | 14.61 | 0.995 | Leading | 9.76 | 0.989 | Leading | 15.06 | 0.993 | Leading | 11.50 |
| 36 | FLT41-3PH | 0.986 | Leading | 17.11 | 0.989 | Leading | 14.62 | 0.995 | Leading | 9.76 | 0.989 | Leading | 15.04 | 0.993 | Leading | 11.56 |
| 37 | FLT43-3PH | 0.989 | Leading | 15.00 | 0.992 | Leading | 12.64 | 0.997 | Leading | 8.20 | 0.992 | Leading | 13.01 | 0.994 | Leading | 10.82 |
| 38 | FLT44-3PH | 0.990 | Leading | 14.48 | 0.993 | Leading | 11.80 | 0.997 | Leading | 7.55 | 0.992 | Leading | 12.83 | 0.995 | Leading | 10.41 |
| 39 | FLT45-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.60 |
| 40 | FLT46-3PH | 0.986 | Leading | 16.91 | 0.990 | Leading | 14.50 | 0.995 | Leading | 9.71 | 0.989 | Leading | 14.90 | 0.993 | Leading | 11.46 |
| 41 | FLT47-3PH | 0.986 | Leading | 16.63 | 0.991 | Leading | 13.56 | 0.996 | Leading | 8.72 | 0.990 | Leading | 13.96 | 0.993 | Leading | 11.58 |
| 42 | FLT48-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.60 |
| 43 | FLT49-3PH | 0.990 | Leading | 14.39 | 0.995 | Leading | 9.90 | 0.998 | Leading | 6.16 | 0.993 | Leading | 12.25 | 0.995 | Leading | 9.69 |
| 44 | FLT52-3PH | 0.993 | Leading | 12.29 | 0.998 | Leading | 6.37 | 1.000 | Leading | 1.25 | 0.996 | Leading | 9.50 | 0.999 | Leading | 5.06 |
| 45 | FLT54-3PH | 0.987 | Leading | 16.53 | 0.992 | Leading | 12.66 | 0.997 | Leading | 8.03 | 0.990 | Leading | 14.15 | 0.997 | Leading | 7.98 |
| 46 | FLT55-3PH | 0.988 | Leading | 15.65 | 0.992 | Leading | 12.36 | 0.997 | Leading | 7.64 | 0.991 | Leading | 13.52 | 0.996 | Leading | 9.19 |
| 47 | FLT56-3PH | 0.985 | Leading | 17.52 | 0.990 | Leading | 14.15 | 0.996 | Leading | 9.43 | 0.988 | Leading | 15.52 | 0.994 | Leading | 11.33 |
| 48 | FLT57-3PH | 0.986 | Leading | 16.88 | 0.991 | Leading | 13.56 | 0.996 | Leading | 8.84 | 0.989 | Leading | 14.71 | 0.994 | Leading | 10.76 |
| 49 | FLT58-3PH | 0.985 | Leading | 17.54 | 0.990 | Leading | 14.11 | 0.996 | Leading | 9.39 | 0.988 | Leading | 15.54 | 0.994 | Leading | 11.30 |
| 50 | FLT59-3PH | 0.986 | Leading | 17.09 | 0.990 | Leading | 14.58 | 0.996 | Leading | 9.47 | 0.989 | Leading | 15.05 | 0.994 | Leading | 10.61 |
| 51 | FLT60-3PH | 0.985 | Leading | 17.43 | 0.990 | Leading | 14.34 | 0.996 | Leading | 9.43 | 0.988 | Leading | 15.37 | 0.993 | Leading | 11.69 |
| 52 | FLT63-3PH | 0.986 | Leading | 17.18 | 0.989 | Leading | 14.65 | 0.995 | Leading | 9.82 | 0.989 | Leading | 15.07 | 0.993 | Leading | 11.59 |
| 53 | FLT64-3PH | 0.986 | Leading | 17.15 | 0.989 | Leading | 14.69 | 0.995 | Leading | 9.82 | 0.989 | Leading | 15.13 | 0.993 | Leading | 11.56 |
| 54 | FLT65-3PH | 0.986 | Leading | 17.18 | 0.989 | Leading | 14.66 | 0.995 | Leading | 9.79 | 0.989 | Leading | 15.08 | 0.993 | Leading | 11.60 |
| 55 | FLT66-3PH | 0.986 | Leading | 17.12 | 0.989 | Leading | 14.65 | 0.995 | Leading | 9.82 | 0.989 | Leading | 15.08 | 0.993 | Leading | 11.49 |
| 56 | FLT67-3PH | 0.986 | Leading | 17.15 | 0.989 | Leading | 14.66 | 0.995 | Leading | 9.80 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.58 |
| 57 | FLT68-3PH | 0.986 | Leading | 17.18 | 0.989 | Leading | 14.66 | 0.995 | Leading | 9.80 | 0.989 | Leading | 15.08 | 0.993 | Leading | 11.60 |
| 58 | FLT69-3PH | 0.986 | Leading | 17.16 | 0.990 | Leading | 14.55 | 0.995 | Leading | 9.72 | 0.989 | Leading | 15.15 | 0.994 | Leading | 11.05 |
| 59 | FLT70-3PH | 0.986 | Leading | 17.17 | 0.989 | Leading | 14.66 | 0.995 | Leading | 9.80 | 0.989 | Leading | 15.07 | 0.993 | Leading | 11.51 |
| 60 | FLT71-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.80 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.58 |
| 61 | FLT72-3PH | 0.986 | Leading | 17.19 | 0.989 | Leading | 14.65 | 0.995 | Leading | 9.75 | 0.989 | Leading | 15.08 | 0.993 | Leading | 11.55 |
| 62 | FLT73-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.60 |
| 63 | FLT74-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.66 | 0.995 | Leading | 9.79 | 0.989 | Leading | 15.09 | 0.993 | Leading | 11.59 |
| 64 | FLT75-3PH | 0.985 | Leading | 17.29 | 0.990 | Leading | 14.47 | 0.996 | Leading | 9.30 | 0.989 | Leading | 14.86 | 0.994 | Leading | 11.40 |
| 65 | FLT76-3PH | 0.986 | Leading | 17.18 | 0.989 | Leading | 14.66 | 0.995 | Leading | 9.80 | 0.989 | Leading | 15.08 | 0.993 | Leading | 11.60 |
| 66 | FLT77-3PH | 0.985 | Leading | 17.23 | 0.990 | Leading | 14.50 | 0.996 | Leading | 9.48 | 0.989 | Leading | 14.92 | 0.993 | Leading | 11.66 |
| 67 | FLT84-3PH | 0.986 | Leading | 16.65 | 0.990 | Leading | 14.12 | 0.996 | Leading | 9.32 | 0.990 | Leading | 14.46 | 0.994 | Leading | 11.27 |
| 68 | FLT85-3PH | 0.986 | Leading | 17.18 | 0.989 | Leading | 14.69 | 0.995 | Leading | 9.85 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.53 |
| 69 | FLT86-3PH | 0.986 | Leading | 17.06 | 0.990 | Leading | 13.89 | 0.996 | Leading | 9.15 | 0.989 | Leading | 14.89 | 0.994 | Leading | 10.78 |
| 70 | FLT87-3PH | 0.986 | Leading | 17.18 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.82 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.59 |
| 71 | FLT88-3PH | 0.986 | Leading | 17.18 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.80 | 0.989 | Leading | 15.12 | 0.993 | Leading | 11.62 |
| 72 | FLT92-3PH | 0.992 | Leading | 12.66 | 0.994 | Leading | 11.41 | 0.998 | Leading | 6.08 | 0.994 | Leading | 10.80 | 0.994 | Leading | 11.28 |
| 73 | FLT93-3PH | 0.989 | Leading | 14.96 | 0.994 | Leading | 11.38 | 0.997 | Leading | 8.06 | 0.991 | Leading | 13.67 | 0.995 | Leading | 9.67 |
| 74 | FLT94-3PH | 0.992 | Leading | 12.65 | 0.994 | Leading | 11.41 | 0.998 | Leading | 6.08 | 0.994 | Leading | 10.80 | 0.994 | Leading | 11.28 |

Table 5-1 (continued)
Power Factor Analysis: GEN-2015-020

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|
| | | Power Factor | Leading | Q (MVAR) | Power Factor | Leading | Q (MVAR) | Power Factor | Leading | Q (MVAR) | Power Factor | Leading | Q (MVAR) | Power Factor | Leading | Q (MVAR) |
| 75 | FLT95-3PH | 0.989 | Leading | 14.96 | 0.994 | Leading | 11.38 | 0.997 | Leading | 8.06 | 0.991 | Leading | 13.67 | 0.995 | Leading | 9.67 |
| 76 | FLT96-3PH | 0.986 | Leading | 17.06 | 0.989 | Leading | 14.63 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.60 |
| 77 | FLT97-3PH | 0.986 | Leading | 16.95 | 0.990 | Leading | 14.49 | 0.995 | Leading | 9.71 | 0.989 | Leading | 15.03 | 0.994 | Leading | 11.45 |
| 78 | FLT98-3PH | 0.986 | Leading | 17.08 | 0.989 | Leading | 14.64 | 0.995 | Leading | 9.79 | 0.989 | Leading | 15.09 | 0.993 | Leading | 11.58 |
| 79 | FLT99-3PH | 0.986 | Leading | 17.06 | 0.989 | Leading | 14.63 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.61 |
| 80 | FLT100-3PH | 0.986 | Leading | 16.93 | 0.990 | Leading | 14.49 | 0.995 | Leading | 9.71 | 0.989 | Leading | 15.02 | 0.994 | Leading | 11.44 |
| 81 | FLT101-3PH | 0.986 | Leading | 17.01 | 0.990 | Leading | 14.57 | 0.995 | Leading | 9.74 | 0.989 | Leading | 15.05 | 0.993 | Leading | 11.50 |
| 82 | FLT102-3PH | 0.986 | Leading | 17.05 | 0.989 | Leading | 14.62 | 0.995 | Leading | 9.78 | 0.989 | Leading | 15.08 | 0.993 | Leading | 11.62 |
| 83 | FLT105-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.83 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.51 |
| 84 | FLT106-3PH | 0.986 | Leading | 17.17 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.79 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.55 |
| 85 | FLT107-3PH | 0.986 | Leading | 17.17 | 0.989 | Leading | 14.66 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.62 |
| 86 | FLT108-3PH | 0.986 | Leading | 17.18 | 0.989 | Leading | 14.68 | 0.995 | Leading | 9.84 | 0.989 | Leading | 15.09 | 0.993 | Leading | 11.64 |
| 87 | FLT109-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.82 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.61 |
| 88 | FLT110-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.82 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.61 |
| 89 | FLT111-3PH | 0.986 | Leading | 17.17 | 0.989 | Leading | 14.66 | 0.995 | Leading | 9.78 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.58 |
| 90 | FLT112-3PH | 0.986 | Leading | 17.19 | 0.989 | Leading | 14.65 | 0.995 | Leading | 9.75 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.60 |
| 91 | FLT113-3PH | 0.986 | Leading | 17.17 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.84 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.63 |
| 92 | FLT114-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.80 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.59 |
| 93 | FLT115-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.60 |
| 94 | FLT116-3PH | 0.986 | Leading | 17.14 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.96 | 0.989 | Leading | 15.13 | 0.993 | Leading | 11.70 |
| 95 | FLT117-3PH | 0.986 | Leading | 17.19 | 0.989 | Leading | 14.64 | 0.995 | Leading | 9.73 | 0.989 | Leading | 15.06 | 0.993 | Leading | 11.52 |
| 96 | FLT118-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.59 |
| 97 | FLT119-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.82 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.60 |
| 98 | FLT120-3PH | 0.986 | Leading | 17.13 | 0.989 | Leading | 14.69 | 0.995 | Leading | 9.89 | 0.989 | Leading | 15.16 | 0.993 | Leading | 11.59 |
| 99 | FLT121-3PH | 0.986 | Leading | 17.16 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.60 |
| 100 | FLT126-3PH | 0.986 | Leading | 17.15 | 0.989 | Leading | 14.70 | 0.995 | Leading | 9.94 | 0.989 | Leading | 15.17 | 0.994 | Leading | 11.36 |
| 101 | FLT127-3PH | 0.986 | Leading | 17.12 | 0.989 | Leading | 14.68 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.11 | 0.993 | Leading | 11.60 |
| 102 | FLT128-3PH | 0.986 | Leading | 17.10 | 0.989 | Leading | 14.70 | 0.995 | Leading | 9.71 | 0.989 | Leading | 15.06 | 0.993 | Leading | 11.65 |
| 103 | FLT129-3PH | 0.986 | Leading | 17.14 | 0.989 | Leading | 14.67 | 0.995 | Leading | 9.81 | 0.989 | Leading | 15.10 | 0.993 | Leading | 11.61 |

Study Generator GEN-2015-020

The Power Factor Analysis shows that GEN-2015-020 has a power factor range of 0.970 leading (absorbing) to 0.990 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.973 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, a power factor range of 0.979 leading (absorbing) to 1.00 (unity) for the 2020 Summer Peak conditions, a power factor range of 0.973 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.976 leading (absorbing) to 1.00 (unity) for the 2025 Summer Peak conditions.

Table 5-2
Power Factor Analysis: GEN-2015-031

| Cont. No. | Case | 2016 Winter Peak | | 2017 Summer Peak | | 2020 Summer Peak | | 2020 Winter Peak | | 2025 Summer Peak | |
|-----------|-----------|------------------|-----------------|------------------|-----------------|------------------|-----------------|------------------|----------------|------------------|-----------------|
| | | Power Factor | Q (MVAR) | Power Factor | Q (MVAR) | Power Factor | Q (MVAR) | Power Factor | Q (MVAR) | Power Factor | Q (MVAR) |
| 0 | Base | 0.994 | Lagging -16.41 | 0.897 | Lagging -74.37 | 0.938 | Lagging -55.49 | 1.000 | Lagging -1.37 | 0.893 | Lagging -75.97 |
| 1 | FLT01-3PH | 0.994 | Lagging -16.43 | 0.897 | Lagging -74.37 | 0.938 | Lagging -55.50 | 1.000 | Lagging -1.40 | 0.893 | Lagging -75.98 |
| 2 | FLT02-3PH | 0.994 | Lagging -16.46 | 0.896 | Lagging -74.40 | 0.938 | Lagging -55.52 | 1.000 | Lagging -1.43 | 0.893 | Lagging -75.99 |
| 3 | FLT03-3PH | 0.994 | Lagging -16.46 | 0.896 | Lagging -74.41 | 0.938 | Lagging -55.56 | 1.000 | Lagging -1.52 | 0.893 | Lagging -75.98 |
| 4 | FLT04-3PH | 0.994 | Lagging -16.69 | 0.895 | Lagging -74.85 | 0.938 | Lagging -55.65 | 1.000 | Lagging -2.10 | 0.892 | Lagging -76.25 |
| 5 | FLT05-3PH | 0.994 | Lagging -16.40 | 0.897 | Lagging -74.25 | 0.938 | Lagging -55.60 | 1.000 | Lagging -1.70 | 0.892 | Lagging -76.09 |
| 6 | FLT06-3PH | 0.994 | Lagging -16.43 | 0.897 | Lagging -74.37 | 0.938 | Lagging -55.50 | 1.000 | Lagging -1.39 | 0.893 | Lagging -75.98 |
| 7 | FLT07-3PH | 0.994 | Lagging -16.44 | 0.897 | Lagging -74.38 | 0.938 | Lagging -55.50 | 1.000 | Lagging -1.40 | 0.893 | Lagging -75.98 |
| 8 | FLT11-3PH | 0.994 | Lagging -16.32 | 0.897 | Lagging -74.29 | 0.938 | Lagging -55.43 | 1.000 | Lagging -1.29 | 0.893 | Lagging -75.90 |
| 9 | FLT12-3PH | 0.994 | Lagging -16.32 | 0.897 | Lagging -74.29 | 0.938 | Lagging -55.43 | 1.000 | Lagging -1.28 | 0.893 | Lagging -75.90 |
| 10 | FLT13-3PH | 0.994 | Lagging -16.43 | 0.896 | Lagging -74.51 | 0.938 | Lagging -55.60 | 1.000 | Lagging -1.38 | 0.893 | Lagging -76.06 |
| 11 | FLT14-3PH | 0.994 | Lagging -16.32 | 0.895 | Lagging -74.84 | 0.938 | Lagging -55.69 | 1.000 | Lagging -1.50 | 0.892 | Lagging -76.20 |
| 12 | FLT15-3PH | 0.992 | Lagging -18.88 | 0.886 | Lagging -78.73 | 0.930 | Lagging -59.38 | 1.000 | Lagging -3.55 | 0.886 | Lagging -78.78 |
| 13 | FLT16-3PH | 0.994 | Lagging -16.45 | 0.896 | Lagging -74.45 | 0.938 | Lagging -55.57 | 1.000 | Lagging -1.41 | 0.893 | Lagging -76.03 |
| 14 | FLT17-3PH | 0.994 | Lagging -16.39 | 0.896 | Lagging -74.42 | 0.938 | Lagging -55.47 | 1.000 | Lagging -1.34 | 0.893 | Lagging -75.95 |
| 15 | FLT18-3PH | 0.994 | Lagging -16.38 | 0.896 | Lagging -74.40 | 0.938 | Lagging -55.45 | 1.000 | Lagging -1.34 | 0.893 | Lagging -75.93 |
| 16 | FLT19-3PH | 0.994 | Lagging -16.41 | 0.897 | Lagging -74.37 | 0.938 | Lagging -55.49 | 1.000 | Lagging -1.37 | 0.893 | Lagging -75.97 |
| 17 | FLT20-3PH | 0.994 | Lagging -16.41 | 0.897 | Lagging -74.36 | 0.938 | Lagging -55.48 | 1.000 | Lagging -1.36 | 0.893 | Lagging -75.96 |
| 18 | FLT21-3PH | 0.994 | Lagging -16.53 | 0.896 | Lagging -74.55 | 0.938 | Lagging -55.65 | 1.000 | Lagging -1.50 | 0.892 | Lagging -76.09 |
| 19 | FLT22-3PH | 0.994 | Lagging -16.52 | 0.896 | Lagging -74.60 | 0.938 | Lagging -55.71 | 1.000 | Lagging -1.49 | 0.892 | Lagging -76.14 |
| 20 | FLT23-3PH | 0.994 | Lagging -16.48 | 0.896 | Lagging -74.52 | 0.938 | Lagging -55.64 | 1.000 | Lagging -1.45 | 0.892 | Lagging -76.08 |
| 21 | FLT24-3PH | 0.994 | Lagging -16.51 | 0.896 | Lagging -74.51 | 0.938 | Lagging -55.61 | 1.000 | Lagging -1.47 | 0.893 | Lagging -76.06 |
| 22 | FLT25-3PH | 0.994 | Lagging -16.47 | 0.896 | Lagging -74.46 | 0.939 | Lagging -55.29 | 1.000 | Lagging -1.39 | 0.893 | Lagging -76.03 |
| 23 | FLT26-3PH | 0.994 | Lagging -16.46 | 0.896 | Lagging -74.40 | 0.938 | Lagging -55.48 | 1.000 | Lagging -1.38 | 0.893 | Lagging -75.99 |
| 24 | FLT27-3PH | 0.994 | Lagging -16.46 | 0.896 | Lagging -74.40 | 0.938 | Lagging -55.49 | 1.000 | Lagging -1.36 | 0.893 | Lagging -75.97 |
| 25 | FLT28-3PH | 0.994 | Lagging -16.63 | 0.896 | Lagging -74.51 | 0.938 | Lagging -55.57 | 1.000 | Lagging -1.61 | 0.893 | Lagging -76.07 |
| 26 | FLT29-3PH | 0.995 | Lagging -15.56 | 0.898 | Lagging -73.88 | 0.940 | Lagging -54.46 | 1.000 | Lagging -0.27 | 0.894 | Lagging -75.63 |
| 27 | FLT30-3PH | 0.994 | Lagging -16.40 | 0.897 | Lagging -74.31 | 0.938 | Lagging -55.44 | 1.000 | Lagging -1.33 | 0.893 | Lagging -75.96 |
| 28 | FLT31-3PH | 0.994 | Lagging -16.51 | 0.896 | Lagging -74.50 | 0.938 | Lagging -55.55 | 1.000 | Lagging -1.45 | 0.893 | Lagging -76.04 |
| 29 | FLT34-3PH | 0.991 | Lagging -19.86 | 0.891 | Lagging -76.70 | 0.933 | Lagging -58.14 | 0.998 | Lagging -9.56 | 0.908 | Lagging -69.37 |
| 30 | FLT35-3PH | 0.983 | Leading 27.76 | 0.991 | Leading 20.71 | 0.991 | Leading 20.72 | 0.979 | Leading 31.48 | 0.997 | Leading 10.74 |
| 31 | FLT36-3PH | 1.000 | Leading 1.66 | 0.990 | Lagging -21.62 | 1.000 | Leading 0.75 | 0.995 | Leading 15.83 | 0.993 | Lagging -17.49 |
| 32 | FLT37-3PH | 0.994 | Lagging -16.41 | 0.897 | Lagging -74.37 | 0.938 | Lagging -55.49 | 1.000 | Lagging -1.37 | 0.893 | Lagging -75.97 |
| 33 | FLT38-3PH | 0.994 | Leading 17.04 | 0.986 | Lagging -25.12 | 0.998 | Lagging -8.83 | 0.981 | Leading 29.78 | 0.985 | Lagging -26.46 |
| 34 | FLT39-3PH | 0.992 | Lagging -18.77 | 0.900 | Lagging -72.97 | 0.942 | Lagging -53.86 | 1.000 | Lagging -1.15 | 0.899 | Lagging -73.45 |
| 35 | FLT40-3PH | 0.996 | Lagging -12.78 | 0.894 | Lagging -75.31 | 0.936 | Lagging -56.73 | 1.000 | Leading 0.06 | 0.876 | Lagging -82.88 |
| 36 | FLT41-3PH | 0.995 | Lagging -14.83 | 0.895 | Lagging -75.13 | 0.937 | Lagging -56.34 | 1.000 | Lagging -3.81 | 0.904 | Lagging -71.28 |
| 37 | FLT43-3PH | 0.871 | Lagging -84.88 | 0.787 | Lagging -117.93 | 0.856 | Lagging -90.72 | 0.916 | Lagging -65.96 | 0.847 | Lagging -94.67 |
| 38 | FLT44-3PH | 0.784 | Lagging -119.14 | 0.744 | Lagging -135.32 | 0.825 | Lagging -103.06 | 0.840 | Lagging -97.34 | 0.822 | Lagging -104.14 |
| 39 | FLT45-3PH | 0.994 | Lagging -16.41 | 0.897 | Lagging -74.37 | 0.938 | Lagging -55.49 | 1.000 | Lagging -1.37 | 0.893 | Lagging -75.97 |
| 40 | FLT46-3PH | 0.992 | Lagging -19.21 | 0.893 | Lagging -76.01 | 0.932 | Lagging -58.35 | 0.999 | Lagging -5.14 | 0.887 | Lagging -78.42 |
| 41 | FLT47-3PH | 0.981 | Lagging -30.02 | 0.874 | Lagging -83.68 | 0.918 | Lagging -65.24 | 0.993 | Lagging -17.60 | 0.889 | Lagging -77.53 |
| 42 | FLT48-3PH | 0.994 | Lagging -16.41 | 0.897 | Lagging -74.37 | 0.938 | Lagging -55.49 | 1.000 | Lagging -1.37 | 0.893 | Lagging -75.97 |
| 43 | FLT49-3PH | 0.805 | Lagging -111.03 | 0.646 | Lagging -178.06 | 0.744 | Lagging -135.01 | 0.854 | Lagging -91.74 | 0.782 | Lagging -120.04 |
| 44 | FLT52-3PH | 0.938 | Lagging -55.72 | 0.807 | Lagging -110.30 | 0.854 | Lagging -91.85 | 0.965 | Lagging -40.84 | 0.830 | Lagging -100.98 |
| 45 | FLT54-3PH | 0.899 | Lagging -73.29 | 0.817 | Lagging -106.34 | 0.876 | Lagging -82.79 | 0.942 | Lagging -53.82 | 0.852 | Lagging -92.59 |
| 46 | FLT55-3PH | 0.994 | Lagging -17.16 | 0.895 | Lagging -75.03 | 0.937 | Lagging -56.17 | 1.000 | Lagging -2.02 | 0.891 | Lagging -76.73 |
| 47 | FLT56-3PH | 0.992 | Lagging -18.56 | 0.888 | Lagging -78.10 | 0.933 | Lagging -57.88 | 1.000 | Lagging -3.00 | 0.889 | Lagging -77.54 |
| 48 | FLT57-3PH | 0.969 | Lagging -38.10 | 0.853 | Lagging -92.30 | 0.890 | Lagging -77.15 | 0.989 | Lagging -22.50 | 0.846 | Lagging -94.96 |
| 49 | FLT58-3PH | 0.992 | Lagging -18.70 | 0.887 | Lagging -78.33 | 0.933 | Lagging -58.03 | 1.000 | Lagging -3.10 | 0.889 | Lagging -77.63 |
| 50 | FLT59-3PH | 0.993 | Lagging -18.49 | 0.891 | Lagging -76.61 | 0.933 | Lagging -57.86 | 1.000 | Lagging -2.79 | 0.889 | Lagging -77.46 |
| 51 | FLT60-3PH | 0.994 | Lagging -16.09 | 0.901 | Lagging -72.46 | 0.936 | Lagging -56.51 | 1.000 | Lagging -2.20 | 0.893 | Lagging -75.84 |
| 52 | FLT63-3PH | 0.994 | Lagging -16.69 | 0.896 | Lagging -74.76 | 0.938 | Lagging -55.68 | 1.000 | Lagging -1.47 | 0.893 | Lagging -76.02 |
| 53 | FLT64-3PH | 0.994 | Lagging -16.30 | 0.897 | Lagging -74.17 | 0.938 | Lagging -55.44 | 1.000 | Lagging -1.23 | 0.893 | Lagging -75.81 |
| 54 | FLT65-3PH | 0.994 | Lagging -16.61 | 0.896 | Lagging -74.63 | 0.938 | Lagging -55.60 | 1.000 | Lagging -1.44 | 0.893 | Lagging -75.99 |
| 55 | FLT66-3PH | 0.994 | Lagging -16.89 | 0.895 | Lagging -75.13 | 0.937 | Lagging -56.13 | 1.000 | Lagging -2.25 | 0.891 | Lagging -76.51 |
| 56 | FLT67-3PH | 0.994 | Lagging -16.55 | 0.896 | Lagging -74.60 | 0.938 | Lagging -55.70 | 1.000 | Lagging -1.63 | 0.892 | Lagging -76.14 |
| 57 | FLT68-3PH | 0.994 | Lagging -16.56 | 0.896 | Lagging -74.57 | 0.938 | Lagging -55.54 | 1.000 | Lagging -1.40 | 0.893 | Lagging -75.97 |
| 58 | FLT69-3PH | 0.993 | Lagging -17.71 | 0.893 | Lagging -75.87 | 0.935 | Lagging -56.93 | 1.000 | Lagging -2.83 | 0.890 | Lagging -77.20 |
| 59 | FLT70-3PH | 0.994 | Lagging -16.54 | 0.896 | Lagging -74.65 | 0.938 | Lagging -55.64 | 1.000 | Lagging -1.50 | 0.892 | Lagging -76.20 |
| 60 | FLT71-3PH | 0.994 | Lagging -16.56 | 0.896 | Lagging -74.45 | 0.938 | Lagging -55.58 | 1.000 | Lagging -1.47 | 0.893 | Lagging -76.02 |
| 61 | FLT72-3PH | 0.994 | Lagging -16.33 | 0.896 | Lagging -74.65 | 0.938 | Lagging -55.67 | 1.000 | Lagging -1.30 | 0.893 | Lagging -75.98 |
| 62 | FLT73-3PH | 0.994 | Lagging -16.41 | 0.897 | Lagging -74.37 | 0.938 | Lagging -55.49 | 1.000 | Lagging -1.37 | 0.893 | Lagging -75.97 |
| 63 | FLT74-3PH | 0.994 | Lagging -16.41 | 0.896 | Lagging -74.52 | 0.938 | Lagging -55.62 | 1.000 | Lagging -1.49 | 0.893 | Lagging -75.99 |
| 64 | FLT75-3PH | 0.994 | Lagging -16.67 | 0.894 | Lagging -75.56 | 0.936 | Lagging -56.68 | 1.000 | Lagging -1.85 | 0.891 | Lagging -76.86 |
| 65 | FLT76-3PH | 0.994 | Lagging -16.55 | 0.896 | Lagging -74.55 | 0.938 | Lagging -55.53 | 1.000 | Lagging -1.39 | 0.893 | Lagging -75.97 |
| 66 | FLT77-3PH | 0.994 | Lagging -16.98 | 0.895 | Lagging -75.20 | 0.938 | Lagging -55.79 | 1.000 | Lagging -1.56 | 0.892 | Lagging -76.17 |
| 67 | FLT84-3PH | 0.983 | Lagging -27.91 | 0.878 | Lagging -81.96 | 0.922 | Lagging -63.02 | 0.996 | Lagging -13.13 | 0.875 | Lagging -83.35 |
| 68 | FLT85-3PH | 0.995 | Lagging -15.69 | 0.901 | Lagging -72.28 | 0.941 | Lagging -54.22 | 1.000 | Leading 0.30 | 0.892 | Lagging -76.12 |
| 69 | FLT86-3PH | 0.989 | Lagging -22.70 | 0.886 | Lagging -78.97 | 0.928 | Lagging -60.36 | 0.998 | Lagging -9.21 | 0.883 | Lagging -79.92 |
| 70 | FLT87-3PH | 0.995 | Lagging -15.25 | 0.900 | Lagging -73.08 | 0.940 | Lagging -54.53 | 1.000 | Lagging -1.83 | 0.893 | Lagging -75.87 |
| 71 | FLT88-3PH | 0.994 | Lagging -16.49 | 0.894 | Lagging -75.35 | 0.936 | Lagging -56.62 | 1.000 | Lagging -1.43 | 0.888 | Lagging -77.81 |
| 72 | FLT92-3PH | 0.996 | Lagging -13.65 | 0.902 | Lagging -72.03 | 0.944 | Lagging -52.61 | 1.000 | Leading 2.33 | 0.897 | Lagging -74.33 |
| 73 | FLT93-3PH | 0.993 | Lagging -17.68 | 0.893 | Lagging -75.88 | 0.934 | Lagging -57.51 | 1.000 | Lagging -3.48 | 0.888 | Lagging -77.83 |
| 74 | FLT94-3PH | 0.996 | Lagging -13.67 | 0.902 | Lagging -72.04 | 0.944 | Lagging -52.62 | 1.000 | Leading 2.32 | 0.897 | Lagging -74.33 |

Table 5-2 (continued)
Power Factor Analysis: GEN-2015-031

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|
| | | Power Factor | Lagging | Q (MVAR) | Power Factor | Lagging | Q (MVAR) | Power Factor | Lagging | Q (MVAR) | Power Factor | Lagging | Q (MVAR) | Power Factor | Lagging | Q (MVAR) |
| 75 | FLT95-3PH | 0.993 | Lagging | -17.72 | 0.893 | Lagging | -75.91 | 0.934 | Lagging | -57.54 | 1.000 | Lagging | -3.51 | 0.888 | Lagging | -77.85 |
| 76 | FLT96-3PH | 0.994 | Lagging | -16.39 | 0.897 | Lagging | -74.35 | 0.938 | Lagging | -55.50 | 1.000 | Lagging | -1.37 | 0.893 | Lagging | -75.97 |
| 77 | FLT97-3PH | 0.994 | Lagging | -16.44 | 0.896 | Lagging | -74.43 | 0.938 | Lagging | -55.50 | 1.000 | Lagging | -1.38 | 0.893 | Lagging | -76.03 |
| 78 | FLT98-3PH | 0.994 | Lagging | -16.43 | 0.897 | Lagging | -74.38 | 0.938 | Lagging | -55.48 | 1.000 | Lagging | -1.36 | 0.893 | Lagging | -75.96 |
| 79 | FLT99-3PH | 0.994 | Lagging | -16.39 | 0.897 | Lagging | -74.36 | 0.938 | Lagging | -55.51 | 1.000 | Lagging | -1.38 | 0.893 | Lagging | -75.98 |
| 80 | FLT100-3PH | 0.994 | Lagging | -16.50 | 0.896 | Lagging | -74.45 | 0.938 | Lagging | -55.50 | 1.000 | Lagging | -1.39 | 0.893 | Lagging | -76.04 |
| 81 | FLT101-3PH | 0.994 | Lagging | -16.46 | 0.896 | Lagging | -74.42 | 0.938 | Lagging | -55.52 | 1.000 | Lagging | -1.40 | 0.893 | Lagging | -76.00 |
| 82 | FLT102-3PH | 0.994 | Lagging | -16.34 | 0.897 | Lagging | -74.32 | 0.938 | Lagging | -55.55 | 1.000 | Lagging | -1.41 | 0.893 | Lagging | -76.00 |
| 83 | FLT105-3PH | 0.995 | Lagging | -15.22 | 0.898 | Lagging | -73.80 | 0.939 | Lagging | -54.90 | 1.000 | Lagging | -0.70 | 0.893 | Lagging | -75.87 |
| 84 | FLT106-3PH | 0.996 | Lagging | -13.63 | 0.896 | Lagging | -74.45 | 0.937 | Lagging | -55.97 | 1.000 | Lagging | -1.50 | 0.891 | Lagging | -76.70 |
| 85 | FLT107-3PH | 0.993 | Lagging | -17.31 | 0.896 | Lagging | -74.79 | 0.937 | Lagging | -56.23 | 1.000 | Lagging | -1.42 | 0.891 | Lagging | -76.52 |
| 86 | FLT108-3PH | 0.996 | Lagging | -13.35 | 0.900 | Lagging | -73.06 | 0.940 | Lagging | -54.70 | 1.000 | Lagging | -1.83 | 0.893 | Lagging | -75.74 |
| 87 | FLT109-3PH | 0.994 | Lagging | -16.44 | 0.897 | Lagging | -74.39 | 0.938 | Lagging | -55.50 | 1.000 | Lagging | -1.39 | 0.893 | Lagging | -75.97 |
| 88 | FLT110-3PH | 0.994 | Lagging | -16.43 | 0.897 | Lagging | -74.38 | 0.938 | Lagging | -55.50 | 1.000 | Lagging | -1.38 | 0.893 | Lagging | -75.97 |
| 89 | FLT111-3PH | 0.994 | Lagging | -16.34 | 0.897 | Lagging | -74.37 | 0.938 | Lagging | -55.51 | 1.000 | Lagging | -1.35 | 0.893 | Lagging | -75.97 |
| 90 | FLT112-3PH | 0.994 | Lagging | -16.25 | 0.896 | Lagging | -74.43 | 0.938 | Lagging | -55.53 | 1.000 | Lagging | -1.33 | 0.893 | Lagging | -75.97 |
| 91 | FLT113-3PH | 0.994 | Lagging | -16.41 | 0.897 | Lagging | -74.37 | 0.938 | Lagging | -55.39 | 1.000 | Lagging | -1.37 | 0.893 | Lagging | -75.94 |
| 92 | FLT114-3PH | 0.994 | Lagging | -16.43 | 0.896 | Lagging | -74.46 | 0.938 | Lagging | -55.54 | 1.000 | Lagging | -1.36 | 0.893 | Lagging | -75.98 |
| 93 | FLT115-3PH | 0.994 | Lagging | -16.41 | 0.897 | Lagging | -74.37 | 0.938 | Lagging | -55.49 | 1.000 | Lagging | -1.37 | 0.893 | Lagging | -75.97 |
| 94 | FLT116-3PH | 0.994 | Lagging | -16.51 | 0.896 | Lagging | -74.47 | 0.938 | Lagging | -55.47 | 1.000 | Lagging | -1.43 | 0.893 | Lagging | -75.95 |
| 95 | FLT117-3PH | 0.994 | Lagging | -16.28 | 0.896 | Lagging | -74.65 | 0.938 | Lagging | -55.67 | 1.000 | Lagging | -1.34 | 0.893 | Lagging | -76.03 |
| 96 | FLT118-3PH | 0.994 | Lagging | -16.41 | 0.896 | Lagging | -74.41 | 0.938 | Lagging | -55.45 | 1.000 | Lagging | -1.36 | 0.893 | Lagging | -75.98 |
| 97 | FLT119-3PH | 0.994 | Lagging | -16.48 | 0.896 | Lagging | -74.40 | 0.938 | Lagging | -55.56 | 1.000 | Lagging | -1.45 | 0.893 | Lagging | -76.00 |
| 98 | FLT120-3PH | 0.994 | Lagging | -16.36 | 0.897 | Lagging | -74.28 | 0.939 | Lagging | -55.35 | 1.000 | Lagging | -1.34 | 0.893 | Lagging | -75.95 |
| 99 | FLT121-3PH | 0.994 | Lagging | -16.46 | 0.896 | Lagging | -74.43 | 0.938 | Lagging | -55.55 | 1.000 | Lagging | -1.42 | 0.893 | Lagging | -76.00 |
| 100 | FLT126-3PH | 0.994 | Lagging | -16.58 | 0.896 | Lagging | -74.76 | 0.938 | Lagging | -55.87 | 1.000 | Lagging | -1.68 | 0.892 | Lagging | -76.11 |
| 101 | FLT127-3PH | 0.994 | Lagging | -16.46 | 0.897 | Lagging | -74.25 | 0.938 | Lagging | -55.49 | 1.000 | Lagging | -1.37 | 0.893 | Lagging | -75.97 |
| 102 | FLT128-3PH | 0.995 | Lagging | -15.55 | 0.897 | Lagging | -74.23 | 0.938 | Lagging | -55.59 | 1.000 | Lagging | -1.46 | 0.893 | Lagging | -76.05 |
| 103 | FLT129-3PH | 0.994 | Lagging | -16.42 | 0.896 | Lagging | -74.41 | 0.938 | Lagging | -55.52 | 1.000 | Lagging | -1.40 | 0.893 | Lagging | -75.99 |

Study Generator GEN-2015-031

The Power Factor Analysis shows that GEN-2015-031 has a power factor range of 0.983 leading (absorbing) to 0.784 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.991 leading (absorbing) to 0.646 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.991 leading (absorbing) to 0.744 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.979 leading (absorbing) to 0.840 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.997 leading (absorbing) to 0.782 lagging (supplying) for the 2025 Summer Peak conditions.

**Table 5-3
Power Factor Analysis: GEN-2015-056**

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|-----------|------------------|----------|--------|------------------|----------|--------|------------------|----------|--------|------------------|----------|--------|------------------|----------|--------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 0 | Base | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 1 | FLT01-3PH | 1.000 | Lagging | -1.12 | 1.000 | Lagging | -1.71 | 1.000 | Leading | 0.43 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.44 |
| 2 | FLT02-3PH | 1.000 | Lagging | -1.12 | 1.000 | Lagging | -1.71 | 1.000 | Leading | 0.43 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.45 |
| 3 | FLT03-3PH | 1.000 | Lagging | -0.78 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.42 |
| 4 | FLT04-3PH | 1.000 | Lagging | -1.09 | 1.000 | Lagging | -3.04 | 1.000 | Lagging | -0.39 | 1.000 | Lagging | -0.41 | 1.000 | Lagging | -3.13 |
| 5 | FLT05-3PH | 1.000 | Lagging | -1.65 | 1.000 | Lagging | -2.23 | 1.000 | Leading | 0.10 | 1.000 | Lagging | -0.02 | 1.000 | Lagging | -1.30 |
| 6 | FLT06-3PH | 1.000 | Lagging | -1.12 | 1.000 | Lagging | -1.70 | 1.000 | Leading | 0.43 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.44 |
| 7 | FLT07-3PH | 1.000 | Lagging | -1.12 | 1.000 | Lagging | -1.71 | 1.000 | Leading | 0.43 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.44 |
| 8 | FLT11-3PH | 1.000 | Lagging | -1.01 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.40 |
| 9 | FLT12-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.40 |
| 10 | FLT13-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 11 | FLT14-3PH | 1.000 | Lagging | -1.02 | 1.000 | Lagging | -1.69 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.45 |
| 12 | FLT15-3PH | 1.000 | Lagging | -1.09 | 1.000 | Lagging | -1.65 | 1.000 | Leading | 0.46 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.37 |
| 13 | FLT16-3PH | 1.000 | Lagging | -0.99 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.41 |
| 14 | FLT17-3PH | 1.000 | Lagging | -1.06 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.41 |
| 15 | FLT18-3PH | 1.000 | Lagging | -1.05 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.41 |
| 16 | FLT19-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 17 | FLT20-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 18 | FLT21-3PH | 1.000 | Lagging | -0.97 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.41 |
| 19 | FLT22-3PH | 1.000 | Lagging | -1.01 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.39 |
| 20 | FLT23-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.40 |
| 21 | FLT24-3PH | 1.000 | Lagging | -0.97 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.41 |
| 22 | FLT25-3PH | 1.000 | Lagging | -1.07 | 1.000 | Lagging | -1.66 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.38 |
| 23 | FLT26-3PH | 1.000 | Lagging | -1.03 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.43 |
| 24 | FLT27-3PH | 1.000 | Lagging | -1.02 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 25 | FLT28-3PH | 1.000 | Lagging | -0.51 | 1.000 | Lagging | -1.66 | 1.000 | Leading | 0.46 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.38 |
| 26 | FLT29-3PH | 1.000 | Lagging | -1.05 | 1.000 | Lagging | -1.17 | 1.000 | Leading | 0.59 | 1.000 | Leading | 0.28 | 1.000 | Leading | 0.78 |
| 27 | FLT30-3PH | 1.000 | Lagging | -1.05 | 1.000 | Lagging | -1.64 | 1.000 | Leading | 0.47 | 1.000 | Leading | 0.37 | 1.000 | Lagging | -0.41 |
| 28 | FLT31-3PH | 1.000 | Lagging | -1.10 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.40 |
| 29 | FLT34-3PH | 1.000 | Lagging | -1.01 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.42 |
| 30 | FLT35-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 31 | FLT36-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 32 | FLT37-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 33 | FLT38-3PH | 1.000 | Lagging | -1.07 | 1.000 | Lagging | -1.71 | 1.000 | Leading | 0.42 | 1.000 | Leading | 0.31 | 1.000 | Lagging | -0.44 |
| 34 | FLT39-3PH | 1.000 | Lagging | -0.99 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.41 |
| 35 | FLT40-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 36 | FLT41-3PH | 1.000 | Lagging | -0.99 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 37 | FLT43-3PH | 1.000 | Lagging | -0.57 | 1.000 | Lagging | -1.48 | 1.000 | Leading | 0.56 | 1.000 | Leading | 0.43 | 1.000 | Lagging | -0.14 |
| 38 | FLT44-3PH | 1.000 | Lagging | -0.44 | 1.000 | Lagging | -1.42 | 1.000 | Leading | 0.59 | 1.000 | Leading | 0.44 | 1.000 | Lagging | -0.03 |
| 39 | FLT45-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 40 | FLT46-3PH | 1.000 | Lagging | -1.19 | 1.000 | Lagging | -1.80 | 1.000 | Leading | 0.36 | 1.000 | Leading | 0.25 | 1.000 | Lagging | -0.59 |
| 41 | FLT47-3PH | 1.000 | Leading | 0.07 | 1.000 | Lagging | -1.17 | 1.000 | Leading | 0.66 | 1.000 | Leading | 0.41 | 1.000 | Leading | 0.12 |
| 42 | FLT48-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 43 | FLT49-3PH | 1.000 | Lagging | -0.46 | 1.000 | Lagging | -1.33 | 1.000 | Leading | 0.64 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.13 |
| 44 | FLT52-3PH | 1.000 | Lagging | -1.27 | 1.000 | Lagging | -1.99 | 1.000 | Leading | 0.21 | 1.000 | Leading | 0.18 | 1.000 | Lagging | -0.92 |
| 46 | FLT54-3PH | 1.000 | Lagging | -1.24 | 1.000 | Lagging | -1.85 | 1.000 | Leading | 0.32 | 1.000 | Leading | 0.21 | 1.000 | Lagging | -0.68 |
| 47 | FLT55-3PH | 1.000 | Lagging | -1.03 | 1.000 | Lagging | -1.69 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.43 |
| 48 | FLT56-3PH | 1.000 | Lagging | -1.21 | 1.000 | Lagging | -1.88 | 1.000 | Leading | 0.29 | 1.000 | Leading | 0.24 | 1.000 | Lagging | -0.79 |
| 49 | FLT57-3PH | 1.000 | Lagging | -1.28 | 1.000 | Lagging | -2.00 | 1.000 | Leading | 0.19 | 1.000 | Leading | 0.16 | 1.000 | Lagging | -0.90 |
| 50 | FLT58-3PH | 1.000 | Lagging | -1.21 | 1.000 | Lagging | -1.90 | 1.000 | Leading | 0.28 | 1.000 | Leading | 0.23 | 1.000 | Lagging | -0.82 |
| 51 | FLT59-3PH | 1.000 | Lagging | -1.31 | 1.000 | Lagging | -2.14 | 1.000 | Leading | 0.05 | 1.000 | Leading | 0.10 | 1.000 | Lagging | -1.45 |
| 52 | FLT60-3PH | 1.000 | Lagging | -1.01 | 1.000 | Lagging | -1.75 | 1.000 | Leading | 0.39 | 1.000 | Leading | 0.32 | 1.000 | Lagging | -0.46 |
| 53 | FLT63-3PH | 1.000 | Lagging | -0.92 | 1.000 | Lagging | -1.65 | 1.000 | Leading | 0.46 | 1.000 | Leading | 0.35 | 1.000 | Lagging | -0.37 |
| 54 | FLT64-3PH | 1.000 | Lagging | -1.08 | 1.000 | Lagging | -1.73 | 1.000 | Leading | 0.41 | 1.000 | Leading | 0.32 | 1.000 | Lagging | -0.50 |
| 55 | FLT65-3PH | 1.000 | Lagging | -0.93 | 1.000 | Lagging | -1.66 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.39 |
| 56 | FLT66-3PH | 1.000 | Lagging | -1.14 | 1.000 | Lagging | -1.75 | 1.000 | Leading | 0.39 | 1.000 | Leading | 0.31 | 1.000 | Lagging | -0.62 |
| 57 | FLT67-3PH | 1.000 | Lagging | -1.03 | 1.000 | Lagging | -1.70 | 1.000 | Leading | 0.43 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.48 |
| 58 | FLT68-3PH | 1.000 | Lagging | -0.93 | 1.000 | Lagging | -1.66 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.39 |
| 59 | FLT69-3PH | 1.000 | Lagging | -1.27 | 1.000 | Lagging | -2.05 | 1.000 | Leading | 0.13 | 1.000 | Leading | 0.15 | 1.000 | Lagging | -1.47 |
| 60 | FLT70-3PH | 1.000 | Lagging | -0.99 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.38 |
| 61 | FLT71-3PH | 1.000 | Lagging | -1.02 | 1.000 | Lagging | -1.69 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.44 |
| 62 | FLT72-3PH | 1.000 | Lagging | -0.91 | 1.000 | Lagging | -1.63 | 1.000 | Leading | 0.48 | 1.000 | Leading | 0.35 | 1.000 | Lagging | -0.33 |
| 63 | FLT73-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 64 | FLT74-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.41 |
| 65 | FLT75-3PH | 1.000 | Lagging | -0.41 | 1.000 | Lagging | -1.34 | 1.000 | Leading | 0.65 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.18 |
| 66 | FLT76-3PH | 1.000 | Lagging | -0.93 | 1.000 | Lagging | -1.66 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.39 |
| 67 | FLT77-3PH | 1.000 | Lagging | -0.52 | 1.000 | Lagging | -1.34 | 1.000 | Leading | 0.64 | 1.000 | Leading | 0.43 | 1.000 | Leading | 0.19 |
| 68 | FLT84-3PH | 1.000 | Lagging | -0.88 | 1.000 | Lagging | -1.62 | 1.000 | Leading | 0.48 | 1.000 | Leading | 0.37 | 1.000 | Lagging | -0.29 |
| 69 | FLT85-3PH | 1.000 | Lagging | -1.02 | 1.000 | Lagging | -1.70 | 1.000 | Leading | 0.43 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.46 |
| 70 | FLT86-3PH | 1.000 | Lagging | -1.47 | 1.000 | Lagging | -2.30 | 1.000 | Lagging | -0.05 | 1.000 | Lagging | -0.09 | 1.000 | Lagging | -1.32 |
| 71 | FLT87-3PH | 1.000 | Lagging | -1.01 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.43 |
| 72 | FLT88-3PH | 1.000 | Lagging | -0.99 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.40 |
| 73 | FLT92-3PH | 0.965 | Lagging | -27.25 | 0.980 | Lagging | -20.43 | 0.994 | Lagging | -11.54 | 0.974 | Lagging | -23.40 | 0.996 | Lagging | -9.47 |
| 74 | FLT93-3PH | 0.998 | Lagging | -6.55 | 0.990 | Lagging | -14.06 | 0.983 | Lagging | -19.01 | 0.997 | Lagging | -7.75 | 0.979 | Lagging | -21.10 |
| 75 | FLT94-3PH | 0.969 | Lagging | -25.76 | 0.983 | Lagging | -18.95 | 0.995 | Lagging | -10.03 | 0.977 | Lagging | -21.89 | 0.997 | Lagging | -7.98 |

Table 5-3 (continued)
Power Factor Analysis: GEN-2015-056

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|----------|-------|------------------|----------|-------|------------------|----------|-------|------------------|----------|------|------------------|----------|-------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 76 | FLT95-3PH | 0.997 | Leading | 7.71 | 1.000 | Leading | 0.12 | 0.999 | Lagging | -4.54 | 0.998 | Leading | 6.69 | 0.998 | Lagging | -6.74 |
| 77 | FLT96-3PH | 1.000 | Lagging | -1.10 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.40 |
| 78 | FLT97-3PH | 1.000 | Lagging | -1.10 | 1.000 | Lagging | -1.66 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.38 |
| 79 | FLT98-3PH | 1.000 | Lagging | -1.11 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 80 | FLT99-3PH | 1.000 | Lagging | -1.10 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.39 |
| 81 | FLT100-3PH | 1.000 | Lagging | -1.09 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.38 |
| 82 | FLT101-3PH | 1.000 | Lagging | -1.10 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.41 |
| 83 | FLT102-3PH | 1.000 | Lagging | -1.09 | 1.000 | Lagging | -1.66 | 1.000 | Leading | 0.46 | 1.000 | Leading | 0.35 | 1.000 | Lagging | -0.34 |
| 84 | FLT105-3PH | 1.000 | Lagging | -0.98 | 1.000 | Lagging | -1.69 | 1.000 | Leading | 0.43 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.46 |
| 85 | FLT106-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.69 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.43 |
| 86 | FLT107-3PH | 1.000 | Lagging | -0.98 | 1.000 | Lagging | -1.67 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.41 |
| 87 | FLT108-3PH | 1.000 | Lagging | -0.99 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.41 |
| 88 | FLT109-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 89 | FLT110-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 90 | FLT111-3PH | 1.000 | Lagging | -0.97 | 1.000 | Lagging | -1.66 | 1.000 | Leading | 0.46 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.38 |
| 91 | FLT112-3PH | 1.000 | Lagging | -0.91 | 1.000 | Lagging | -1.62 | 1.000 | Leading | 0.48 | 1.000 | Leading | 0.35 | 1.000 | Lagging | -0.33 |
| 92 | FLT113-3PH | 1.000 | Lagging | -0.99 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.43 |
| 93 | FLT114-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 94 | FLT115-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 95 | FLT116-3PH | 1.000 | Lagging | -1.04 | 1.000 | Lagging | -1.71 | 1.000 | Leading | 0.43 | 1.000 | Leading | 0.32 | 1.000 | Lagging | -0.47 |
| 96 | FLT117-3PH | 1.000 | Lagging | -0.92 | 1.000 | Lagging | -1.63 | 1.000 | Leading | 0.48 | 1.000 | Leading | 0.35 | 1.000 | Lagging | -0.32 |
| 97 | FLT118-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 98 | FLT119-3PH | 1.000 | Lagging | -1.00 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.44 |
| 99 | FLT120-3PH | 1.000 | Lagging | -1.17 | 1.000 | Lagging | -1.77 | 1.000 | Leading | 0.37 | 1.000 | Leading | 0.28 | 1.000 | Lagging | -0.65 |
| 100 | FLT121-3PH | 1.000 | Lagging | -0.99 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.41 |
| 101 | FLT126-3PH | 1.000 | Lagging | -1.39 | 1.000 | Lagging | -1.98 | 1.000 | Leading | 0.22 | 1.000 | Leading | 0.10 | 1.000 | Lagging | -1.18 |
| 102 | FLT127-3PH | 1.000 | Lagging | -1.12 | 1.000 | Lagging | -1.72 | 1.000 | Leading | 0.44 | 1.000 | Leading | 0.33 | 1.000 | Lagging | -0.42 |
| 103 | FLT128-3PH | 1.000 | Lagging | -1.79 | 1.000 | Lagging | -1.89 | 1.000 | Leading | 0.55 | 1.000 | Leading | 0.38 | 1.000 | Lagging | -0.15 |
| 104 | FLT129-3PH | 1.000 | Lagging | -1.04 | 1.000 | Lagging | -1.68 | 1.000 | Leading | 0.45 | 1.000 | Leading | 0.34 | 1.000 | Lagging | -0.38 |

Study Generator GEN-2015-056

The Power Factor Analysis shows that GEN-2015-056 has a power factor range of 0.997 leading (absorbing) to 0.965 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.998 lagging (supplying) to 1.00 (unity) for the 2017 Summer Peak conditions, a power factor range of 0.983 lagging (supplying) to 1.00 (unity) for the 2020 Summer Peak conditions, a power factor range of 0.998 leading (absorbing) to 0.974 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.979 lagging (supplying) to 1.00 (unity) for the 2025 Summer Peak conditions.

Table 5-4
Power Factor Analysis: GEN-2015-058

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|-----------|------------------|----------|------|------------------|----------|------|------------------|----------|------|------------------|----------|-------|------------------|----------|------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 0 | Base | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 1 | FLT01-3PH | 0.998 | Leading | 3.33 | 0.994 | Leading | 5.28 | 0.990 | Leading | 6.96 | 0.998 | Leading | 2.87 | 0.990 | Leading | 7.24 |
| 2 | FLT02-3PH | 0.998 | Leading | 3.00 | 0.995 | Leading | 4.86 | 0.991 | Leading | 6.71 | 0.999 | Leading | 2.63 | 0.991 | Leading | 6.93 |
| 3 | FLT03-3PH | 0.996 | Leading | 4.52 | 0.994 | Leading | 5.44 | 0.992 | Leading | 6.46 | 0.999 | Leading | 2.06 | 0.989 | Leading | 7.61 |
| 4 | FLT04-3PH | 0.990 | Leading | 7.19 | 0.991 | Leading | 6.74 | 0.987 | Leading | 8.18 | 0.998 | Leading | 3.54 | 0.983 | Leading | 9.48 |
| 5 | FLT05-3PH | 1.000 | Leading | 0.49 | 0.999 | Leading | 2.65 | 0.996 | Leading | 4.67 | 1.000 | Lagging | -0.68 | 0.994 | Leading | 5.46 |
| 6 | FLT06-3PH | 0.997 | Leading | 3.56 | 0.994 | Leading | 5.60 | 0.990 | Leading | 7.18 | 0.998 | Leading | 3.03 | 0.989 | Leading | 7.50 |
| 7 | FLT07-3PH | 0.998 | Leading | 3.29 | 0.995 | Leading | 5.21 | 0.991 | Leading | 6.93 | 0.998 | Leading | 2.84 | 0.990 | Leading | 7.19 |
| 8 | FLT11-3PH | 0.996 | Leading | 4.39 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.14 | 0.989 | Leading | 7.62 |
| 9 | FLT12-3PH | 0.996 | Leading | 4.41 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.14 | 0.989 | Leading | 7.62 |
| 10 | FLT13-3PH | 0.996 | Leading | 4.42 | 0.994 | Leading | 5.64 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.59 |
| 11 | FLT14-3PH | 0.996 | Leading | 4.34 | 0.994 | Leading | 5.57 | 0.990 | Leading | 7.20 | 0.998 | Leading | 3.12 | 0.989 | Leading | 7.58 |
| 12 | FLT15-3PH | 0.997 | Leading | 3.90 | 0.994 | Leading | 5.54 | 0.990 | Leading | 7.07 | 0.998 | Leading | 2.96 | 0.989 | Leading | 7.44 |
| 13 | FLT16-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.61 |
| 14 | FLT17-3PH | 0.996 | Leading | 4.27 | 0.994 | Leading | 5.63 | 0.990 | Leading | 7.20 | 0.998 | Leading | 3.13 | 0.989 | Leading | 7.58 |
| 15 | FLT18-3PH | 0.996 | Leading | 4.28 | 0.994 | Leading | 5.63 | 0.990 | Leading | 7.20 | 0.998 | Leading | 3.13 | 0.989 | Leading | 7.58 |
| 16 | FLT19-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 17 | FLT20-3PH | 0.996 | Leading | 4.42 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 18 | FLT21-3PH | 0.996 | Leading | 4.48 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.24 | 0.998 | Leading | 3.17 | 0.989 | Leading | 7.61 |
| 19 | FLT22-3PH | 0.996 | Leading | 4.38 | 0.994 | Leading | 5.64 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.14 | 0.989 | Leading | 7.59 |
| 20 | FLT23-3PH | 0.996 | Leading | 4.40 | 0.994 | Leading | 5.64 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.15 | 0.989 | Leading | 7.60 |
| 21 | FLT24-3PH | 0.996 | Leading | 4.48 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.24 | 0.998 | Leading | 3.17 | 0.989 | Leading | 7.62 |
| 22 | FLT25-3PH | 0.996 | Leading | 4.22 | 0.994 | Leading | 5.59 | 0.990 | Leading | 7.15 | 0.998 | Leading | 3.11 | 0.989 | Leading | 7.53 |
| 23 | FLT26-3PH | 0.996 | Leading | 4.34 | 0.994 | Leading | 5.64 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.59 |
| 24 | FLT27-3PH | 0.996 | Leading | 4.37 | 0.994 | Leading | 5.64 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.59 |
| 25 | FLT28-3PH | 0.994 | Leading | 5.64 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.21 | 0.998 | Leading | 3.32 | 0.989 | Leading | 7.60 |
| 26 | FLT29-3PH | 0.999 | Leading | 1.95 | 0.998 | Leading | 2.93 | 0.993 | Leading | 6.05 | 1.000 | Leading | 0.57 | 0.993 | Leading | 5.86 |
| 27 | FLT30-3PH | 0.997 | Leading | 3.71 | 0.994 | Leading | 5.64 | 0.990 | Leading | 7.16 | 0.998 | Leading | 2.84 | 0.989 | Leading | 7.63 |
| 28 | FLT31-3PH | 0.997 | Leading | 3.95 | 0.994 | Leading | 5.58 | 0.990 | Leading | 7.15 | 0.998 | Leading | 3.05 | 0.989 | Leading | 7.54 |
| 29 | FLT34-3PH | 0.996 | Leading | 4.39 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.19 | 0.998 | Leading | 3.11 | 0.989 | Leading | 7.59 |
| 30 | FLT35-3PH | 0.996 | Leading | 4.41 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.21 | 0.998 | Leading | 3.13 | 0.989 | Leading | 7.60 |
| 31 | FLT36-3PH | 0.996 | Leading | 4.41 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 32 | FLT37-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 33 | FLT38-3PH | 0.996 | Leading | 4.29 | 0.994 | Leading | 5.64 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.14 | 0.989 | Leading | 7.59 |
| 34 | FLT39-3PH | 0.996 | Leading | 4.44 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 35 | FLT40-3PH | 0.996 | Leading | 4.42 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 36 | FLT41-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 37 | FLT43-3PH | 0.995 | Leading | 5.19 | 0.994 | Leading | 5.72 | 0.990 | Leading | 7.21 | 0.998 | Leading | 3.17 | 0.989 | Leading | 7.62 |
| 38 | FLT44-3PH | 0.994 | Leading | 5.45 | 0.993 | Leading | 5.73 | 0.990 | Leading | 7.21 | 0.998 | Leading | 3.14 | 0.989 | Leading | 7.64 |
| 39 | FLT45-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 40 | FLT46-3PH | 0.997 | Leading | 4.01 | 0.994 | Leading | 5.61 | 0.990 | Leading | 7.15 | 0.998 | Leading | 3.00 | 0.989 | Leading | 7.57 |
| 41 | FLT47-3PH | 0.991 | Leading | 6.84 | 0.993 | Leading | 5.86 | 0.990 | Leading | 7.06 | 0.997 | Leading | 3.73 | 0.989 | Leading | 7.44 |
| 42 | FLT48-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 43 | FLT49-3PH | 0.994 | Leading | 5.41 | 0.993 | Leading | 5.76 | 0.990 | Leading | 7.12 | 0.998 | Leading | 3.17 | 0.989 | Leading | 7.63 |
| 44 | FLT52-3PH | 0.997 | Leading | 4.01 | 0.994 | Leading | 5.55 | 0.990 | Leading | 7.05 | 0.998 | Leading | 3.01 | 0.989 | Leading | 7.48 |
| 46 | FLT54-3PH | 0.997 | Leading | 3.93 | 0.994 | Leading | 5.55 | 0.990 | Leading | 7.10 | 0.998 | Leading | 2.93 | 0.989 | Leading | 7.48 |
| 47 | FLT55-3PH | 0.996 | Leading | 4.33 | 0.994 | Leading | 5.63 | 0.990 | Leading | 7.21 | 0.998 | Leading | 3.15 | 0.989 | Leading | 7.58 |
| 48 | FLT56-3PH | 0.997 | Leading | 4.03 | 0.994 | Leading | 5.61 | 0.990 | Leading | 7.18 | 0.998 | Leading | 3.11 | 0.989 | Leading | 7.55 |
| 49 | FLT57-3PH | 0.997 | Leading | 3.99 | 0.994 | Leading | 5.57 | 0.990 | Leading | 7.11 | 0.998 | Leading | 3.00 | 0.989 | Leading | 7.50 |
| 50 | FLT58-3PH | 0.997 | Leading | 4.03 | 0.994 | Leading | 5.61 | 0.990 | Leading | 7.18 | 0.998 | Leading | 3.11 | 0.989 | Leading | 7.54 |
| 51 | FLT59-3PH | 0.997 | Leading | 3.95 | 0.994 | Leading | 5.51 | 0.990 | Leading | 7.06 | 0.998 | Leading | 2.97 | 0.989 | Leading | 7.35 |
| 52 | FLT60-3PH | 0.996 | Leading | 4.42 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.61 |
| 53 | FLT63-3PH | 0.996 | Leading | 4.56 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.16 | 0.998 | Leading | 3.11 | 0.989 | Leading | 7.55 |
| 54 | FLT64-3PH | 0.996 | Leading | 4.29 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.58 |
| 55 | FLT65-3PH | 0.996 | Leading | 4.54 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.19 | 0.998 | Leading | 3.13 | 0.989 | Leading | 7.58 |
| 56 | FLT66-3PH | 0.997 | Leading | 4.16 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.26 | 0.998 | Leading | 3.17 | 0.989 | Leading | 7.59 |
| 57 | FLT67-3PH | 0.996 | Leading | 4.37 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 58 | FLT68-3PH | 0.996 | Leading | 4.54 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.20 | 0.998 | Leading | 3.14 | 0.989 | Leading | 7.58 |
| 59 | FLT69-3PH | 0.997 | Leading | 3.97 | 0.994 | Leading | 5.54 | 0.990 | Leading | 7.11 | 0.998 | Leading | 3.01 | 0.989 | Leading | 7.38 |
| 60 | FLT70-3PH | 0.996 | Leading | 4.44 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.24 | 0.998 | Leading | 3.18 | 0.989 | Leading | 7.64 |
| 61 | FLT71-3PH | 0.996 | Leading | 4.39 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 62 | FLT72-3PH | 0.996 | Leading | 4.57 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.20 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.59 |
| 63 | FLT73-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 64 | FLT74-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.15 | 0.989 | Leading | 7.60 |
| 65 | FLT75-3PH | 0.994 | Leading | 5.52 | 0.993 | Leading | 5.78 | 0.990 | Leading | 7.29 | 0.998 | Leading | 3.26 | 0.988 | Leading | 7.76 |
| 66 | FLT76-3PH | 0.996 | Leading | 4.53 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.20 | 0.998 | Leading | 3.14 | 0.989 | Leading | 7.59 |
| 67 | FLT77-3PH | 0.994 | Leading | 5.31 | 0.993 | Leading | 5.81 | 0.990 | Leading | 7.17 | 0.998 | Leading | 3.19 | 0.989 | Leading | 7.60 |
| 68 | FLT84-3PH | 0.996 | Leading | 4.64 | 0.994 | Leading | 5.67 | 0.990 | Leading | 7.26 | 0.998 | Leading | 3.22 | 0.989 | Leading | 7.63 |
| 69 | FLT85-3PH | 0.996 | Leading | 4.38 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.59 |
| 70 | FLT86-3PH | 0.997 | Leading | 3.89 | 0.994 | Leading | 5.48 | 0.990 | Leading | 7.05 | 0.998 | Leading | 2.86 | 0.989 | Leading | 7.42 |
| 71 | FLT87-3PH | 0.996 | Leading | 4.41 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 72 | FLT88-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.17 | 0.989 | Leading | 7.61 |
| 73 | FLT92-3PH | 0.996 | Leading | 4.59 | 0.992 | Leading | 6.17 | 0.989 | Leading | 7.64 | 0.998 | Leading | 3.36 | 0.988 | Leading | 7.91 |
| 74 | FLT93-3PH | 0.999 | Leading | 1.90 | 0.998 | Leading | 3.32 | 0.995 | Leading | 4.94 | 1.000 | Leading | 1.18 | 0.995 | Leading | 5.01 |
| 75 | FLT94-3PH | 0.996 | Leading | 4.59 | 0.992 | Leading | 6.17 | 0.989 | Leading | 7.64 | 0.998 | Leading | 3.36 | 0.988 | Leading | 7.91 |

Table 5-4 (continued)
Power Factor Analysis: GEN-2015-058

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|----------|--------|------------------|----------|--------|------------------|----------|-------|------------------|----------|-------|------------------|----------|--------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 76 | FLT95-3PH | 0.999 | Leading | 1.90 | 0.998 | Leading | 3.32 | 0.995 | Leading | 4.94 | 1.000 | Leading | 1.18 | 0.995 | Leading | 5.01 |
| 77 | FLT96-3PH | 0.971 | Leading | 12.29 | 0.979 | Leading | 10.32 | 0.993 | Leading | 5.91 | 0.997 | Leading | 3.70 | 0.990 | Leading | 7.22 |
| 78 | FLT97-3PH | 0.966 | Lagging | -13.35 | 0.954 | Lagging | -15.80 | 0.995 | Lagging | -5.08 | 0.995 | Lagging | -4.78 | 0.975 | Lagging | -11.44 |
| 79 | FLT98-3PH | 0.974 | Leading | 11.63 | 0.975 | Leading | 11.43 | 0.976 | Leading | 11.13 | 0.990 | Leading | 7.06 | 0.972 | Leading | 12.18 |
| 80 | FLT99-3PH | 0.982 | Leading | 9.67 | 0.989 | Leading | 7.58 | 0.998 | Leading | 2.74 | 1.000 | Leading | 0.58 | 0.997 | Leading | 4.00 |
| 81 | FLT100-3PH | 0.962 | Lagging | -14.09 | 0.947 | Lagging | -16.88 | 0.989 | Lagging | -7.39 | 0.993 | Lagging | -6.13 | 0.964 | Lagging | -13.72 |
| 82 | FLT101-3PH | 1.000 | Leading | 0.18 | 0.999 | Leading | 1.83 | 0.997 | Leading | 3.89 | 1.000 | Leading | 0.47 | 1.000 | Leading | 1.51 |
| 83 | FLT102-3PH | 1.000 | Leading | 1.22 | 1.000 | Lagging | -0.39 | 0.996 | Lagging | -4.31 | 0.994 | Lagging | -5.52 | 0.997 | Lagging | -4.19 |
| 84 | FLT105-3PH | 0.996 | Leading | 4.45 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.58 |
| 85 | FLT106-3PH | 0.996 | Leading | 4.42 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 86 | FLT107-3PH | 0.996 | Leading | 4.45 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.61 |
| 87 | FLT108-3PH | 0.996 | Leading | 4.44 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.61 |
| 88 | FLT109-3PH | 0.996 | Leading | 4.42 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 89 | FLT110-3PH | 0.996 | Leading | 4.42 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 90 | FLT111-3PH | 0.996 | Leading | 4.47 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.61 |
| 91 | FLT112-3PH | 0.996 | Leading | 4.58 | 0.994 | Leading | 5.67 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.61 |
| 92 | FLT113-3PH | 0.996 | Leading | 4.44 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 93 | FLT114-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 94 | FLT115-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 95 | FLT116-3PH | 0.996 | Leading | 4.35 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.59 |
| 96 | FLT117-3PH | 0.996 | Leading | 4.57 | 0.994 | Leading | 5.67 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.17 | 0.989 | Leading | 7.61 |
| 97 | FLT118-3PH | 0.996 | Leading | 4.42 | 0.994 | Leading | 5.66 | 0.990 | Leading | 7.24 | 0.998 | Leading | 3.17 | 0.989 | Leading | 7.62 |
| 98 | FLT119-3PH | 0.996 | Leading | 4.42 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 99 | FLT120-3PH | 0.997 | Leading | 4.04 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.28 | 0.998 | Leading | 3.19 | 0.989 | Leading | 7.61 |
| 100 | FLT121-3PH | 0.996 | Leading | 4.43 | 0.994 | Leading | 5.65 | 0.990 | Leading | 7.22 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 101 | FLT126-3PH | 0.997 | Leading | 3.87 | 0.994 | Leading | 5.54 | 0.990 | Leading | 7.12 | 0.998 | Leading | 2.97 | 0.989 | Leading | 7.38 |
| 102 | FLT127-3PH | 0.997 | Leading | 3.82 | 0.994 | Leading | 5.30 | 0.990 | Leading | 7.23 | 0.998 | Leading | 3.16 | 0.989 | Leading | 7.60 |
| 103 | FLT128-3PH | 0.999 | Leading | 2.47 | 0.994 | Leading | 5.54 | 0.990 | Leading | 7.19 | 0.998 | Leading | 3.15 | 0.989 | Leading | 7.56 |
| 104 | FLT129-3PH | 0.996 | Leading | 4.36 | 0.994 | Leading | 5.71 | 0.990 | Leading | 7.29 | 0.998 | Leading | 3.23 | 0.988 | Leading | 7.67 |

Study Generator GEN-2015-058

The Power Factor Analysis shows that GEN-2015-058 has a power factor range of 0.971 leading (absorbing) to 0.962 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.975 leading (absorbing) to 0.947 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.976 leading (absorbing) to 0.989 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.990 leading (absorbing) to 0.993 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.972 leading (absorbing) to 0.964 lagging (supplying) for the 2025 Summer Peak conditions.

Table 5-5
Power Factor Analysis: GEN-2015-068

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|-----------|------------------|----------|---------|------------------|----------|---------|------------------|----------|---------|------------------|----------|---------|------------------|-----------|---------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 0 | Base | 0.895 | Lagging | -149.15 | 0.934 | Lagging | -114.81 | 0.993 | Lagging | -34.64 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.09 |
| 1 | FLT01-3PH | 0.896 | Lagging | -149.04 | 0.934 | Lagging | -114.68 | 0.993 | Lagging | -34.59 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.06 |
| 2 | FLT02-3PH | 0.896 | Lagging | -149.04 | 0.934 | Lagging | -114.73 | 0.993 | Lagging | -34.62 | 0.936 | Lagging | -112.89 | 0.996 | Lagging | -27.06 |
| 3 | FLT03-3PH | 0.895 | Lagging | -149.23 | 0.934 | Lagging | -114.90 | 0.993 | Lagging | -34.83 | 0.936 | Lagging | -113.23 | 0.996 | Lagging | -27.12 |
| 4 | FLT04-3PH | 0.900 | Lagging | -145.63 | 0.936 | Lagging | -112.49 | 0.994 | Lagging | -32.39 | 0.938 | Lagging | -110.64 | 0.997 | Lagging | -24.43 |
| 5 | FLT05-3PH | 0.898 | Lagging | -146.76 | 0.935 | Lagging | -113.68 | 0.994 | Lagging | -33.65 | 0.937 | Lagging | -111.53 | 0.996 | Lagging | -26.21 |
| 6 | FLT06-3PH | 0.896 | Lagging | -149.05 | 0.934 | Lagging | -114.71 | 0.993 | Lagging | -34.60 | 0.936 | Lagging | -112.83 | 0.996 | Lagging | -27.06 |
| 7 | FLT07-3PH | 0.896 | Lagging | -149.05 | 0.934 | Lagging | -114.69 | 0.993 | Lagging | -34.59 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.06 |
| 8 | FLT11-3PH | 0.895 | Lagging | -149.21 | 0.934 | Lagging | -114.87 | 0.993 | Lagging | -34.69 | 0.936 | Lagging | -112.89 | 0.996 | Lagging | -27.10 |
| 9 | FLT12-3PH | 0.895 | Lagging | -149.21 | 0.934 | Lagging | -114.88 | 0.993 | Lagging | -34.71 | 0.936 | Lagging | -112.89 | 0.996 | Lagging | -27.11 |
| 10 | FLT13-3PH | 0.895 | Lagging | -149.16 | 0.934 | Lagging | -115.11 | 0.993 | Lagging | -34.85 | 0.936 | Lagging | -112.88 | 0.996 | Lagging | -27.29 |
| 11 | FLT14-3PH | 0.895 | Lagging | -149.25 | 0.933 | Lagging | -115.47 | 0.993 | Lagging | -34.73 | 0.936 | Lagging | -113.11 | 0.996 | Lagging | -27.18 |
| 12 | FLT15-3PH | 0.892 | Lagging | -152.00 | 0.928 | Lagging | -120.14 | 0.992 | Lagging | -39.06 | 0.932 | Lagging | -116.83 | 0.995 | Lagging | -29.54 |
| 13 | FLT16-3PH | 0.895 | Lagging | -149.23 | 0.934 | Lagging | -114.94 | 0.993 | Lagging | -34.76 | 0.936 | Lagging | -112.96 | 0.996 | Lagging | -27.16 |
| 14 | FLT17-3PH | 0.895 | Lagging | -149.22 | 0.934 | Lagging | -114.99 | 0.993 | Lagging | -34.69 | 0.936 | Lagging | -112.94 | 0.996 | Lagging | -27.13 |
| 15 | FLT18-3PH | 0.895 | Lagging | -149.22 | 0.934 | Lagging | -114.99 | 0.993 | Lagging | -34.68 | 0.936 | Lagging | -112.93 | 0.996 | Lagging | -27.12 |
| 16 | FLT19-3PH | 0.895 | Lagging | -149.15 | 0.934 | Lagging | -114.81 | 0.993 | Lagging | -34.64 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.09 |
| 17 | FLT20-3PH | 0.895 | Lagging | -149.14 | 0.934 | Lagging | -114.78 | 0.993 | Lagging | -34.62 | 0.936 | Lagging | -112.83 | 0.996 | Lagging | -27.08 |
| 18 | FLT21-3PH | 0.895 | Lagging | -149.28 | 0.934 | Lagging | -115.16 | 0.993 | Lagging | -34.94 | 0.936 | Lagging | -113.08 | 0.996 | Lagging | -27.31 |
| 19 | FLT22-3PH | 0.895 | Lagging | -149.34 | 0.934 | Lagging | -115.21 | 0.993 | Lagging | -35.00 | 0.936 | Lagging | -113.12 | 0.996 | Lagging | -27.32 |
| 20 | FLT23-3PH | 0.895 | Lagging | -149.28 | 0.934 | Lagging | -115.08 | 0.993 | Lagging | -34.88 | 0.936 | Lagging | -113.03 | 0.996 | Lagging | -27.23 |
| 21 | FLT24-3PH | 0.895 | Lagging | -149.25 | 0.934 | Lagging | -115.08 | 0.993 | Lagging | -34.86 | 0.936 | Lagging | -113.03 | 0.996 | Lagging | -27.25 |
| 22 | FLT25-3PH | 0.895 | Lagging | -149.25 | 0.934 | Lagging | -114.95 | 0.994 | Lagging | -34.29 | 0.936 | Lagging | -112.90 | 0.996 | Lagging | -27.18 |
| 23 | FLT26-3PH | 0.895 | Lagging | -149.21 | 0.934 | Lagging | -114.87 | 0.993 | Lagging | -34.61 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.13 |
| 24 | FLT27-3PH | 0.895 | Lagging | -149.20 | 0.934 | Lagging | -114.85 | 0.993 | Lagging | -34.64 | 0.936 | Lagging | -112.82 | 0.996 | Lagging | -27.10 |
| 25 | FLT28-3PH | 0.895 | Lagging | -149.38 | 0.934 | Lagging | -115.22 | 0.993 | Lagging | -34.90 | 0.936 | Lagging | -113.30 | 0.996 | Lagging | -27.36 |
| 26 | FLT29-3PH | 0.892 | Lagging | -152.01 | 0.931 | Lagging | -117.47 | 0.993 | Lagging | -36.01 | 0.934 | Lagging | -114.79 | 0.995 | Lagging | -28.59 |
| 27 | FLT30-3PH | 0.895 | Lagging | -149.36 | 0.934 | Lagging | -114.79 | 0.993 | Lagging | -34.65 | 0.936 | Lagging | -113.04 | 0.996 | Lagging | -27.09 |
| 28 | FLT31-3PH | 0.895 | Lagging | -149.27 | 0.934 | Lagging | -115.06 | 0.993 | Lagging | -34.75 | 0.936 | Lagging | -113.02 | 0.996 | Lagging | -27.23 |
| 29 | FLT34-3PH | 0.857 | Lagging | -180.67 | 0.904 | Lagging | -141.86 | 0.983 | Lagging | -55.75 | 0.896 | Lagging | -148.87 | 0.991 | Lagging | -40.23 |
| 30 | FLT35-3PH | 0.879 | Lagging | -162.96 | 0.919 | Lagging | -128.72 | 0.988 | Lagging | -46.07 | 0.917 | Lagging | -130.78 | 0.995 | Lagging | -30.24 |
| 31 | FLT36-3PH | 0.895 | Lagging | -149.39 | 0.935 | Lagging | -113.38 | 0.994 | Lagging | -32.70 | 0.936 | Lagging | -112.36 | 0.996 | Lagging | -27.93 |
| 32 | FLT37-3PH | 0.895 | Lagging | -149.15 | 0.934 | Lagging | -114.81 | 0.993 | Lagging | -34.64 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.09 |
| 33 | FLT38-3PH | 0.895 | Lagging | -149.21 | 0.938 | Lagging | -110.61 | 0.995 | Lagging | -30.51 | 0.940 | Lagging | -108.72 | 0.996 | Lagging | -27.25 |
| 34 | FLT39-3PH | 0.896 | Lagging | -149.09 | 0.934 | Lagging | -115.03 | 0.993 | Lagging | -34.85 | 0.936 | Lagging | -113.05 | 0.996 | Lagging | -27.38 |
| 35 | FLT40-3PH | 0.894 | Lagging | -150.68 | 0.933 | Lagging | -116.06 | 0.993 | Lagging | -35.68 | 0.934 | Lagging | -114.67 | 0.996 | Lagging | -27.51 |
| 36 | FLT41-3PH | 0.894 | Lagging | -150.22 | 0.933 | Lagging | -116.07 | 0.993 | Lagging | -35.74 | 0.934 | Lagging | -114.49 | 0.996 | Lagging | -27.61 |
| 37 | FLT43-3PH | 0.790 | Lagging | -233.00 | 0.857 | Lagging | -180.17 | 0.957 | Lagging | -90.46 | 0.839 | Lagging | -194.94 | 0.965 | Lagging | -81.17 |
| 38 | FLT44-3PH | 0.738 | Lagging | -274.40 | 0.838 | Lagging | -195.14 | 0.952 | Lagging | -97.00 | 0.782 | Lagging | -238.95 | 0.965 | Lagging | -82.02 |
| 39 | FLT45-3PH | 0.895 | Lagging | -149.15 | 0.934 | Lagging | -114.81 | 0.993 | Lagging | -34.64 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.09 |
| 40 | FLT46-3PH | 0.871 | Lagging | -169.41 | 0.924 | Lagging | -124.16 | 0.987 | Lagging | -48.02 | 0.917 | Lagging | -130.08 | 0.998 | Lagging | -18.29 |
| 41 | FLT47-3PH | 0.916 | Lagging | -131.83 | 0.954 | Lagging | -94.79 | 0.985 | Lagging | -52.38 | 0.915 | Lagging | -132.51 | 0.988 | Lagging | -46.19 |
| 42 | FLT48-3PH | 0.895 | Lagging | -149.15 | 0.934 | Lagging | -114.81 | 0.993 | Lagging | -34.64 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.09 |
| 43 | FLT49-3PH | 0.746 | Lagging | -267.45 | 0.709 | Lagging | -298.72 | 0.859 | Lagging | -178.61 | 0.791 | Lagging | -232.07 | 0.913 | Lagging | -133.91 |
| 44 | FLT52-3PH | 0.861 | Lagging | -176.90 | 0.897 | Lagging | -147.63 | 0.980 | Lagging | -61.65 | 0.899 | Lagging | -146.14 | 0.990 | Lagging | -42.05 |
| 46 | FLT54-3PH | 0.846 | Lagging | -188.91 | 0.900 | Lagging | -145.15 | 0.982 | Lagging | -57.31 | 0.888 | Lagging | -155.76 | 0.992 | Lagging | -38.80 |
| 47 | FLT55-3PH | 0.895 | Lagging | -149.31 | 0.933 | Lagging | -115.31 | 0.993 | Lagging | -35.06 | 0.936 | Lagging | -113.14 | 0.996 | Lagging | -27.37 |
| 48 | FLT56-3PH | 0.893 | Lagging | -151.54 | 0.929 | Lagging | -119.87 | 0.992 | Lagging | -38.84 | 0.932 | Lagging | -116.71 | 0.995 | Lagging | -28.92 |
| 49 | FLT57-3PH | 0.878 | Lagging | -163.46 | 0.912 | Lagging | -135.29 | 0.985 | Lagging | -52.66 | 0.915 | Lagging | -132.41 | 0.994 | Lagging | -33.89 |
| 50 | FLT58-3PH | 0.892 | Lagging | -151.72 | 0.928 | Lagging | -120.25 | 0.992 | Lagging | -39.15 | 0.932 | Lagging | -117.00 | 0.995 | Lagging | -29.06 |
| 51 | FLT59-3PH | 0.898 | Lagging | -147.21 | 0.933 | Lagging | -115.56 | 0.993 | Lagging | -34.74 | 0.937 | Lagging | -111.59 | 0.997 | Lagging | -24.56 |
| 52 | FLT60-3PH | 0.895 | Lagging | -149.41 | 0.934 | Lagging | -115.10 | 0.993 | Lagging | -35.70 | 0.935 | Lagging | -113.52 | 0.996 | Lagging | -27.28 |
| 53 | FLT63-3PH | 0.894 | Lagging | -150.08 | 0.932 | Lagging | -116.50 | 0.993 | Lagging | -35.48 | 0.935 | Lagging | -113.38 | 0.996 | Lagging | -28.13 |
| 54 | FLT64-3PH | 0.894 | Lagging | -150.27 | 0.933 | Lagging | -116.04 | 0.993 | Lagging | -35.31 | 0.935 | Lagging | -113.33 | 0.996 | Lagging | -27.95 |
| 55 | FLT65-3PH | 0.895 | Lagging | -149.68 | 0.933 | Lagging | -115.82 | 0.993 | Lagging | -35.09 | 0.936 | Lagging | -113.10 | 0.996 | Lagging | -27.62 |
| 56 | FLT66-3PH | 0.893 | Lagging | -151.02 | 0.932 | Lagging | -117.09 | 0.993 | Lagging | -36.53 | 0.934 | Lagging | -115.23 | 0.995 | Lagging | -28.81 |
| 57 | FLT67-3PH | 0.895 | Lagging | -149.64 | 0.933 | Lagging | -115.61 | 0.993 | Lagging | -35.25 | 0.935 | Lagging | -113.55 | 0.996 | Lagging | -27.67 |
| 58 | FLT68-3PH | 0.895 | Lagging | -149.39 | 0.933 | Lagging | -115.48 | 0.993 | Lagging | -34.82 | 0.936 | Lagging | -112.85 | 0.996 | Lagging | -27.38 |
| 59 | FLT69-3PH | 0.897 | Lagging | -147.54 | 0.935 | Lagging | -113.92 | 0.994 | Lagging | -33.77 | 0.937 | Lagging | -111.90 | 0.997 | Lagging | -24.45 |
| 60 | FLT70-3PH | 0.895 | Lagging | -149.51 | 0.933 | Lagging | -115.68 | 0.993 | Lagging | -35.20 | 0.935 | Lagging | -113.32 | 0.996 | Lagging | -27.43 |
| 61 | FLT71-3PH | 0.895 | Lagging | -149.69 | 0.934 | Lagging | -115.16 | 0.993 | Lagging | -34.95 | 0.936 | Lagging | -113.17 | 0.996 | Lagging | -27.25 |
| 62 | FLT72-3PH | 0.895 | Lagging | -149.58 | 0.932 | Lagging | -116.30 | 0.993 | Lagging | -35.51 | 0.936 | Lagging | -113.12 | 0.996 | Lagging | -27.60 |
| 63 | FLT73-3PH | 0.895 | Lagging | -149.15 | 0.934 | Lagging | -114.81 | 0.993 | Lagging | -34.64 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.09 |
| 64 | FLT74-3PH | 0.895 | Lagging | -149.15 | 0.933 | Lagging | -115.42 | 0.993 | Lagging | -35.12 | 0.936 | Lagging | -113.30 | 0.996 | Lagging | -27.35 |
| 65 | FLT75-3PH | 0.888 | Lagging | -155.74 | 0.926 | Lagging | -122.10 | 0.991 | Lagging | -40.16 | 0.930 | Lagging | -118.27 | 0.995 | Lagging | -28.90 |
| 66 | FLT76-3PH | 0.895 | Lagging | -149.33 | 0.933 | Lagging | -115.40 | 0.993 | Lagging | -34.76 | 0.936 | Lagging | -112.82 | 0.996 | Lagging | -27.33 |
| 67 | FLT77-3PH | 0.894 | Lagging | -150.12 | 0.932 | Lagging | -117.14 | 0.993 | Lagging | -36.48 | 0.935 | Lagging | -113.88 | 0.995 | Lagging | -29.63 |
| 68 | FLT84-3PH | 0.910 | Lagging | -136.61 | 0.947 | Lagging | -101.81 | 0.997 | Lagging | -22.15 | 0.949 | Lagging | -99.25 | 0.997 | Lagging | -22.43 |
| 69 | FLT85-3PH | 0.895 | Lagging | -149.59 | 0.941 | Lagging | -107.79 | 0.995 | Lagging | -29.51 | 0.943 | Lagging | -106.18 | 0.996 | Lagging | -28.07 |
| 70 | FLT86-3PH | 0.898 | Lagging | -147.10 | 0.942 | Lagging | -106.76 | 0.996 | Lagging | -25.21 | 0.944 | Lagging | -104.93 | 0.997 | Lagging | -23.98 |
| 71 | FLT87-3PH | 0.896 | Lagging | -149.09 | 0.941 | Lagging | -108.12 | 0.994 | Lagging | -32.95 | 0.939 | Lagging | -110.36 | 0.996 | Lagging | -27.22 |
| 72 | FLT88-3PH | 0.895 | Lagging | -149.47 | 0.935 | Lagging | -113.33 | 0.994 | Lagging | -33.87 | 0.937 | Lagging | -111.97 | 0.996 | Lagging | -27.96 |
| 73 | FLT92-3PH | 0.885 | Lagging | -157.50 | 0.929 | Lagging | -119.77 | 0.992 | Lagging | -38.63 | 0.931 | Lagging | -117.66 | 0.995 | Lagging | -30.66 |
| 74 | FLT93-3PH | 0.906 | Lagging | -139.88 | 0.942 | Lagging | -107.28 | 0.995 | Lagging | -29.45 | 0.942 | Lagging | -106.65 | 0.998 | Lagging</ | |

Table 5-5 (continued)
Power Factor Analysis: GEN-2015-068

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|----------|---------|------------------|----------|---------|------------------|----------|--------|------------------|----------|---------|------------------|----------|--------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 76 | FLT95-3PH | 0.906 | Lagging | -139.93 | 0.942 | Lagging | -107.36 | 0.995 | Lagging | -29.51 | 0.942 | Lagging | -106.72 | 0.998 | Lagging | -20.92 |
| 77 | FLT96-3PH | 0.896 | Lagging | -149.08 | 0.934 | Lagging | -114.73 | 0.993 | Lagging | -34.63 | 0.936 | Lagging | -112.83 | 0.996 | Lagging | -27.07 |
| 78 | FLT97-3PH | 0.896 | Lagging | -149.09 | 0.934 | Lagging | -114.89 | 0.993 | Lagging | -34.57 | 0.936 | Lagging | -112.77 | 0.996 | Lagging | -27.20 |
| 79 | FLT98-3PH | 0.895 | Lagging | -149.19 | 0.934 | Lagging | -114.85 | 0.993 | Lagging | -34.65 | 0.936 | Lagging | -112.87 | 0.996 | Lagging | -27.11 |
| 80 | FLT99-3PH | 0.896 | Lagging | -149.06 | 0.934 | Lagging | -114.73 | 0.993 | Lagging | -34.65 | 0.936 | Lagging | -112.84 | 0.996 | Lagging | -27.07 |
| 81 | FLT100-3PH | 0.895 | Lagging | -149.20 | 0.934 | Lagging | -114.95 | 0.993 | Lagging | -34.61 | 0.936 | Lagging | -112.81 | 0.996 | Lagging | -27.22 |
| 82 | FLT101-3PH | 0.895 | Lagging | -149.20 | 0.934 | Lagging | -114.91 | 0.993 | Lagging | -34.71 | 0.936 | Lagging | -112.93 | 0.996 | Lagging | -27.19 |
| 83 | FLT102-3PH | 0.896 | Lagging | -148.85 | 0.934 | Lagging | -114.51 | 0.993 | Lagging | -34.63 | 0.936 | Lagging | -112.77 | 0.996 | Lagging | -27.03 |
| 84 | FLT105-3PH | 0.894 | Lagging | -150.12 | 0.935 | Lagging | -113.88 | 0.994 | Lagging | -33.34 | 0.937 | Lagging | -111.65 | 0.996 | Lagging | -27.53 |
| 85 | FLT106-3PH | 0.894 | Lagging | -150.61 | 0.934 | Lagging | -114.52 | 0.993 | Lagging | -35.52 | 0.936 | Lagging | -113.13 | 0.996 | Lagging | -28.09 |
| 86 | FLT107-3PH | 0.895 | Lagging | -149.43 | 0.933 | Lagging | -115.64 | 0.993 | Lagging | -36.18 | 0.936 | Lagging | -112.90 | 0.996 | Lagging | -27.02 |
| 87 | FLT108-3PH | 0.894 | Lagging | -150.05 | 0.937 | Lagging | -111.57 | 0.994 | Lagging | -32.71 | 0.935 | Lagging | -113.67 | 0.996 | Lagging | -26.93 |
| 88 | FLT109-3PH | 0.895 | Lagging | -149.14 | 0.934 | Lagging | -114.84 | 0.993 | Lagging | -34.67 | 0.936 | Lagging | -112.87 | 0.996 | Lagging | -27.10 |
| 89 | FLT110-3PH | 0.895 | Lagging | -149.13 | 0.934 | Lagging | -114.83 | 0.993 | Lagging | -34.65 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.09 |
| 90 | FLT111-3PH | 0.895 | Lagging | -149.77 | 0.934 | Lagging | -115.19 | 0.993 | Lagging | -34.92 | 0.936 | Lagging | -113.06 | 0.996 | Lagging | -27.17 |
| 91 | FLT112-3PH | 0.895 | Lagging | -149.80 | 0.933 | Lagging | -115.63 | 0.993 | Lagging | -35.22 | 0.936 | Lagging | -113.18 | 0.996 | Lagging | -27.42 |
| 92 | FLT113-3PH | 0.895 | Lagging | -149.42 | 0.934 | Lagging | -114.92 | 0.993 | Lagging | -34.47 | 0.936 | Lagging | -112.90 | 0.996 | Lagging | -27.16 |
| 93 | FLT114-3PH | 0.895 | Lagging | -149.18 | 0.934 | Lagging | -115.07 | 0.993 | Lagging | -34.77 | 0.936 | Lagging | -112.84 | 0.996 | Lagging | -27.16 |
| 94 | FLT115-3PH | 0.895 | Lagging | -149.15 | 0.934 | Lagging | -114.81 | 0.993 | Lagging | -34.64 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.09 |
| 95 | FLT116-3PH | 0.896 | Lagging | -148.90 | 0.934 | Lagging | -114.90 | 0.993 | Lagging | -34.47 | 0.936 | Lagging | -112.70 | 0.996 | Lagging | -26.83 |
| 96 | FLT117-3PH | 0.895 | Lagging | -149.78 | 0.933 | Lagging | -116.10 | 0.993 | Lagging | -35.35 | 0.936 | Lagging | -113.18 | 0.996 | Lagging | -27.38 |
| 97 | FLT118-3PH | 0.895 | Lagging | -149.20 | 0.934 | Lagging | -114.83 | 0.993 | Lagging | -34.43 | 0.936 | Lagging | -112.85 | 0.996 | Lagging | -26.78 |
| 98 | FLT119-3PH | 0.895 | Lagging | -149.25 | 0.934 | Lagging | -114.85 | 0.993 | Lagging | -34.85 | 0.936 | Lagging | -113.05 | 0.996 | Lagging | -27.25 |
| 99 | FLT120-3PH | 0.896 | Lagging | -148.88 | 0.934 | Lagging | -114.31 | 0.994 | Lagging | -33.91 | 0.936 | Lagging | -112.41 | 0.996 | Lagging | -26.58 |
| 100 | FLT121-3PH | 0.895 | Lagging | -149.24 | 0.934 | Lagging | -115.00 | 0.993 | Lagging | -34.81 | 0.936 | Lagging | -112.98 | 0.996 | Lagging | -27.22 |
| 101 | FLT126-3PH | 0.891 | Lagging | -152.67 | 0.930 | Lagging | -118.42 | 0.993 | Lagging | -36.47 | 0.934 | Lagging | -114.64 | 0.995 | Lagging | -29.99 |
| 102 | FLT127-3PH | 0.895 | Lagging | -149.51 | 0.934 | Lagging | -114.75 | 0.993 | Lagging | -34.64 | 0.936 | Lagging | -112.86 | 0.996 | Lagging | -27.09 |
| 103 | FLT128-3PH | 0.892 | Lagging | -151.62 | 0.934 | Lagging | -115.19 | 0.994 | Lagging | -34.10 | 0.936 | Lagging | -112.49 | 0.996 | Lagging | -26.70 |
| 104 | FLT129-3PH | 0.895 | Lagging | -149.24 | 0.934 | Lagging | -114.98 | 0.993 | Lagging | -34.80 | 0.936 | Lagging | -113.03 | 0.996 | Lagging | -27.29 |

Study Generator GEN-2015-068

The Power Factor Analysis shows that GEN-2015-068 has a power factor range of 0.738 to 0.916 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.709 to 0.954 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.859 to 0.997 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.782 to 0.949 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.913 to 0.998 lagging (supplying) for the 2025 Summer Peak conditions.

**Table 5-6
Power Factor Analysis: GEN-2015-075**

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|-----------|------------------|----------|------|------------------|----------|------|------------------|----------|------|------------------|----------|------|------------------|----------|------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 0 | Base | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 1 | FLT01-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 2 | FLT02-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 3 | FLT03-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 4 | FLT04-3PH | 0.997 | Leading | 3.72 | 0.996 | Leading | 4.20 | 0.999 | Leading | 1.74 | 0.999 | Leading | 2.12 | 0.999 | Leading | 2.49 |
| 5 | FLT05-3PH | 0.997 | Leading | 3.71 | 0.997 | Leading | 4.19 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.11 | 0.999 | Leading | 2.50 |
| 6 | FLT06-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 7 | FLT07-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 8 | FLT11-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.11 | 0.999 | Leading | 2.51 |
| 9 | FLT12-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.11 | 0.999 | Leading | 2.51 |
| 10 | FLT13-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 11 | FLT14-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.16 | 0.999 | Leading | 1.71 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.49 |
| 12 | FLT15-3PH | 0.997 | Leading | 3.59 | 0.997 | Leading | 4.07 | 0.999 | Leading | 1.65 | 0.999 | Leading | 2.04 | 0.999 | Leading | 2.50 |
| 13 | FLT16-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 14 | FLT17-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 15 | FLT18-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 16 | FLT19-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 17 | FLT20-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 18 | FLT21-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 19 | FLT22-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 20 | FLT23-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 21 | FLT24-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 22 | FLT25-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 23 | FLT26-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 24 | FLT27-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 25 | FLT28-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 26 | FLT29-3PH | 0.997 | Leading | 3.64 | 0.997 | Leading | 4.14 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.09 | 0.999 | Leading | 2.52 |
| 27 | FLT30-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 28 | FLT31-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 29 | FLT34-3PH | 0.998 | Leading | 3.07 | 0.997 | Leading | 3.80 | 1.000 | Leading | 1.45 | 0.999 | Leading | 1.70 | 0.999 | Leading | 2.47 |
| 30 | FLT35-3PH | 0.998 | Leading | 3.32 | 0.997 | Leading | 3.88 | 1.000 | Leading | 1.51 | 0.999 | Leading | 1.87 | 0.999 | Leading | 2.47 |
| 31 | FLT36-3PH | 0.997 | Leading | 3.57 | 0.997 | Leading | 4.01 | 1.000 | Leading | 1.55 | 0.999 | Leading | 2.00 | 0.999 | Leading | 2.27 |
| 32 | FLT37-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 33 | FLT38-3PH | 0.997 | Leading | 3.75 | 0.996 | Leading | 4.26 | 0.999 | Leading | 1.80 | 0.999 | Leading | 2.13 | 0.999 | Leading | 2.49 |
| 34 | FLT39-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.11 | 0.999 | Leading | 2.51 |
| 35 | FLT40-3PH | 0.997 | Leading | 3.66 | 0.997 | Leading | 4.15 | 0.999 | Leading | 1.71 | 0.999 | Leading | 2.09 | 0.999 | Leading | 2.50 |
| 36 | FLT41-3PH | 0.997 | Leading | 3.66 | 0.997 | Leading | 4.16 | 0.999 | Leading | 1.71 | 0.999 | Leading | 2.08 | 0.999 | Leading | 2.51 |
| 37 | FLT43-3PH | 0.999 | Leading | 2.72 | 0.997 | Leading | 3.66 | 1.000 | Leading | 1.40 | 0.999 | Leading | 1.59 | 0.999 | Leading | 2.54 |
| 38 | FLT44-3PH | 0.999 | Leading | 1.94 | 0.998 | Leading | 3.40 | 1.000 | Leading | 1.37 | 1.000 | Leading | 1.19 | 0.999 | Leading | 2.55 |
| 39 | FLT45-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 40 | FLT46-3PH | 0.996 | Leading | 4.26 | 0.996 | Leading | 4.49 | 0.999 | Leading | 1.91 | 0.999 | Leading | 2.47 | 0.999 | Leading | 2.53 |
| 41 | FLT47-3PH | 0.999 | Leading | 1.98 | 0.998 | Leading | 3.11 | 1.000 | Leading | 0.88 | 1.000 | Leading | 1.03 | 0.999 | Leading | 2.38 |
| 42 | FLT48-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 43 | FLT49-3PH | 0.999 | Leading | 2.45 | 0.999 | Leading | 2.41 | 1.000 | Leading | 0.78 | 1.000 | Leading | 1.39 | 0.999 | Leading | 2.51 |
| 44 | FLT52-3PH | 0.998 | Leading | 2.94 | 0.997 | Leading | 3.63 | 1.000 | Leading | 1.28 | 0.999 | Leading | 1.61 | 0.999 | Leading | 2.45 |
| 46 | FLT54-3PH | 0.999 | Leading | 2.57 | 0.997 | Leading | 3.59 | 1.000 | Leading | 1.32 | 1.000 | Leading | 1.35 | 0.999 | Leading | 2.41 |
| 47 | FLT55-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 48 | FLT56-3PH | 0.997 | Leading | 3.57 | 0.997 | Leading | 4.01 | 0.999 | Leading | 1.62 | 0.999 | Leading | 2.03 | 0.999 | Leading | 2.48 |
| 49 | FLT57-3PH | 0.998 | Leading | 3.11 | 0.997 | Leading | 3.72 | 1.000 | Leading | 1.36 | 0.999 | Leading | 1.71 | 0.999 | Leading | 2.46 |
| 50 | FLT58-3PH | 0.997 | Leading | 3.56 | 0.997 | Leading | 4.00 | 0.999 | Leading | 1.61 | 0.999 | Leading | 2.02 | 0.999 | Leading | 2.48 |
| 51 | FLT59-3PH | 0.998 | Leading | 2.92 | 0.998 | Leading | 3.15 | 1.000 | Leading | 0.85 | 0.999 | Leading | 1.64 | 1.000 | Leading | 1.48 |
| 52 | FLT60-3PH | 0.997 | Leading | 3.70 | 0.996 | Leading | 4.29 | 0.999 | Leading | 1.77 | 0.999 | Leading | 2.11 | 0.999 | Leading | 2.54 |
| 53 | FLT63-3PH | 0.998 | Leading | 3.51 | 0.997 | Leading | 4.03 | 0.999 | Leading | 1.63 | 0.999 | Leading | 1.98 | 0.999 | Leading | 2.43 |
| 54 | FLT64-3PH | 0.997 | Leading | 3.75 | 0.996 | Leading | 4.27 | 0.999 | Leading | 1.77 | 0.999 | Leading | 2.19 | 0.999 | Leading | 2.55 |
| 55 | FLT65-3PH | 0.997 | Leading | 3.55 | 0.997 | Leading | 4.07 | 0.999 | Leading | 1.66 | 0.999 | Leading | 2.02 | 0.999 | Leading | 2.46 |
| 56 | FLT66-3PH | 0.997 | Leading | 3.61 | 0.997 | Leading | 4.02 | 0.999 | Leading | 1.60 | 0.999 | Leading | 2.00 | 0.999 | Leading | 2.33 |
| 57 | FLT67-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.15 | 0.999 | Leading | 1.70 | 0.999 | Leading | 2.08 | 0.999 | Leading | 2.48 |
| 58 | FLT68-3PH | 0.997 | Leading | 3.56 | 0.997 | Leading | 4.09 | 0.999 | Leading | 1.67 | 0.999 | Leading | 2.03 | 0.999 | Leading | 2.47 |
| 59 | FLT69-3PH | 0.997 | Leading | 3.60 | 0.997 | Leading | 4.09 | 0.999 | Leading | 1.66 | 0.999 | Leading | 2.04 | 0.999 | Leading | 2.42 |
| 60 | FLT70-3PH | 0.997 | Leading | 3.62 | 0.997 | Leading | 4.09 | 0.999 | Leading | 1.69 | 0.999 | Leading | 2.05 | 0.999 | Leading | 2.31 |
| 61 | FLT71-3PH | 0.997 | Leading | 3.62 | 0.997 | Leading | 4.14 | 0.999 | Leading | 1.69 | 0.999 | Leading | 2.07 | 0.999 | Leading | 2.47 |
| 62 | FLT72-3PH | 0.997 | Leading | 3.69 | 0.997 | Leading | 3.95 | 1.000 | Leading | 1.53 | 0.999 | Leading | 2.08 | 0.999 | Leading | 2.28 |
| 63 | FLT73-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 64 | FLT74-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.13 | 0.999 | Leading | 1.69 | 0.999 | Leading | 2.07 | 0.999 | Leading | 2.48 |
| 65 | FLT75-3PH | 0.998 | Leading | 3.08 | 0.998 | Leading | 3.21 | 1.000 | Leading | 0.89 | 1.000 | Leading | 1.50 | 0.999 | Leading | 1.64 |
| 66 | FLT76-3PH | 0.997 | Leading | 3.57 | 0.997 | Leading | 4.09 | 0.999 | Leading | 1.68 | 0.999 | Leading | 2.03 | 0.999 | Leading | 2.47 |
| 67 | FLT77-3PH | 0.997 | Leading | 3.56 | 0.997 | Leading | 4.00 | 0.999 | Leading | 1.63 | 0.999 | Leading | 2.05 | 0.999 | Leading | 2.36 |
| 68 | FLT84-3PH | 0.997 | Leading | 3.93 | 0.996 | Leading | 4.38 | 0.999 | Leading | 1.85 | 0.999 | Leading | 2.29 | 0.999 | Leading | 2.53 |
| 69 | FLT85-3PH | 1.000 | Leading | 0.93 | 0.999 | Leading | 2.48 | 1.000 | Leading | 0.71 | 1.000 | Leading | 1.40 | 1.000 | Leading | 0.69 |
| 70 | FLT86-3PH | 0.998 | Leading | 3.13 | 0.997 | Leading | 3.85 | 1.000 | Leading | 1.54 | 0.999 | Leading | 1.60 | 0.999 | Leading | 2.30 |
| 71 | FLT87-3PH | 0.997 | Leading | 3.76 | 0.996 | Leading | 4.26 | 0.999 | Leading | 1.72 | 0.999 | Leading | 1.99 | 0.999 | Leading | 2.44 |
| 72 | FLT88-3PH | 0.998 | Leading | 3.48 | 0.997 | Leading | 3.62 | 1.000 | Leading | 1.21 | 0.999 | Leading | 1.96 | 0.999 | Leading | 2.30 |
| 73 | FLT92-3PH | 0.997 | Leading | 3.55 | 0.997 | Leading | 4.08 | 0.999 | Leading | 1.69 | 0.999 | Leading | 2.03 | 0.999 | Leading | 2.54 |
| 74 | FLT93-3PH | 0.997 | Leading | 3.78 | 0.996 | Leading | 4.24 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.14 | 0.999 | Leading | 2.41 |
| 75 | FLT94-3PH | 0.997 | Leading | 3.55 | 0.997 | Leading | 4.08 | 0.999 | Leading | 1.69 | 0.999 | Leading | 2.03 | 0.999 | Leading | 2.54 |

Table 5-6 (continued)
Power Factor Analysis: GEN-2015-075

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|----------|-------|------------------|----------|------|------------------|----------|-------|------------------|----------|-------|------------------|----------|-------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 76 | FLT95-3PH | 0.997 | Leading | 3.78 | 0.996 | Leading | 4.24 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.14 | 0.999 | Leading | 2.41 |
| 77 | FLT96-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 78 | FLT97-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 79 | FLT98-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 80 | FLT99-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 81 | FLT100-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 82 | FLT101-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 83 | FLT102-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 84 | FLT105-3PH | 0.994 | Leading | 5.60 | 0.990 | Leading | 7.10 | 0.996 | Leading | 4.69 | 0.995 | Leading | 4.93 | 0.994 | Leading | 5.43 |
| 85 | FLT106-3PH | 0.998 | Lagging | -3.19 | 1.000 | Leading | 0.38 | 0.999 | Lagging | -2.10 | 1.000 | Lagging | -0.65 | 0.995 | Lagging | -4.96 |
| 86 | FLT107-3PH | 0.994 | Leading | 5.28 | 0.996 | Leading | 4.62 | 0.999 | Leading | 2.56 | 0.999 | Leading | 2.03 | 0.996 | Leading | 4.75 |
| 87 | FLT108-3PH | 0.994 | Leading | 5.43 | 0.988 | Leading | 7.90 | 0.996 | Leading | 4.63 | 1.000 | Leading | 0.50 | 0.989 | Leading | 7.42 |
| 88 | FLT109-3PH | 0.997 | Leading | 3.65 | 0.997 | Leading | 4.14 | 0.999 | Leading | 1.70 | 0.999 | Leading | 2.09 | 0.999 | Leading | 2.50 |
| 89 | FLT110-3PH | 0.997 | Leading | 3.66 | 0.997 | Leading | 4.15 | 0.999 | Leading | 1.71 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.50 |
| 90 | FLT111-3PH | 0.997 | Leading | 3.91 | 0.996 | Leading | 4.23 | 0.999 | Leading | 1.76 | 0.999 | Leading | 2.19 | 0.999 | Leading | 2.47 |
| 91 | FLT112-3PH | 0.997 | Leading | 3.93 | 0.996 | Leading | 4.20 | 0.999 | Leading | 1.78 | 0.999 | Leading | 2.20 | 0.999 | Leading | 2.54 |
| 92 | FLT113-3PH | 0.997 | Leading | 3.76 | 0.996 | Leading | 4.29 | 0.999 | Leading | 1.87 | 0.999 | Leading | 2.12 | 0.999 | Leading | 2.69 |
| 93 | FLT114-3PH | 0.997 | Leading | 3.66 | 0.997 | Leading | 4.11 | 0.999 | Leading | 1.68 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.44 |
| 94 | FLT115-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 95 | FLT116-3PH | 0.997 | Leading | 3.58 | 0.997 | Leading | 3.97 | 1.000 | Leading | 1.57 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.40 |
| 96 | FLT117-3PH | 0.997 | Leading | 3.74 | 0.997 | Leading | 3.93 | 1.000 | Leading | 1.47 | 0.999 | Leading | 2.03 | 0.999 | Leading | 2.15 |
| 97 | FLT118-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.13 | 0.999 | Leading | 1.68 | 0.999 | Leading | 2.09 | 0.999 | Leading | 2.43 |
| 98 | FLT119-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.74 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.52 |
| 99 | FLT120-3PH | 0.997 | Leading | 3.75 | 0.996 | Leading | 4.28 | 0.999 | Leading | 1.82 | 0.999 | Leading | 2.17 | 0.999 | Leading | 2.63 |
| 100 | FLT121-3PH | 0.997 | Leading | 3.67 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.72 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 101 | FLT126-3PH | 0.997 | Leading | 3.56 | 0.997 | Leading | 4.05 | 0.999 | Leading | 1.63 | 0.999 | Leading | 1.98 | 0.999 | Leading | 2.37 |
| 102 | FLT127-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.19 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.10 | 0.999 | Leading | 2.51 |
| 103 | FLT128-3PH | 0.997 | Leading | 3.68 | 0.997 | Leading | 4.17 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.11 | 0.999 | Leading | 2.51 |
| 104 | FLT129-3PH | 0.997 | Leading | 3.69 | 0.997 | Leading | 4.18 | 0.999 | Leading | 1.73 | 0.999 | Leading | 2.12 | 0.999 | Leading | 2.52 |

Study Generator GEN-2015-075

The Power Factor Analysis shows that GEN-2015-075 has a power factor range of 0.994 leading (absorbing) to 0.998 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.988 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, a power factor range of 0.996 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.995 leading (absorbing) to 1.00 (unity) for the 2020 Winter Peak conditions, and a power factor range of 0.989 leading (absorbing) to 0.995 lagging (supplying) for the 2025 Summer Peak conditions.

Table 5-7
Power Factor Analysis: GEN-2015-079

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|-----------|------------------|----------|-------|------------------|----------|-------|------------------|----------|-------|------------------|----------|-------|------------------|----------|-------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 0 | Base | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 1 | FLT01-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.75 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 2 | FLT02-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.75 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 3 | FLT03-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.87 |
| 4 | FLT04-3PH | 0.997 | Leading | 9.36 | 0.999 | Leading | 5.20 | 0.998 | Leading | 9.02 | 0.997 | Leading | 9.26 | 0.997 | Leading | 10.68 |
| 5 | FLT05-3PH | 0.997 | Leading | 9.28 | 0.999 | Leading | 4.97 | 0.998 | Leading | 8.87 | 0.997 | Leading | 9.22 | 0.997 | Leading | 10.82 |
| 6 | FLT06-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.74 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 7 | FLT07-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.75 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 8 | FLT11-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.70 | 0.998 | Leading | 8.68 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.84 |
| 9 | FLT12-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.70 | 0.998 | Leading | 8.67 | 0.998 | Leading | 9.12 | 0.997 | Leading | 10.84 |
| 10 | FLT13-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.86 |
| 11 | FLT14-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.74 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.11 | 0.997 | Leading | 10.82 |
| 12 | FLT15-3PH | 0.998 | Leading | 8.82 | 0.999 | Leading | 4.34 | 0.998 | Leading | 8.42 | 0.998 | Leading | 8.91 | 0.997 | Leading | 10.71 |
| 13 | FLT16-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.86 |
| 14 | FLT17-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 15 | FLT18-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 16 | FLT19-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 17 | FLT20-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.73 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 18 | FLT21-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.70 | 0.998 | Leading | 8.70 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.86 |
| 19 | FLT22-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.69 | 0.998 | Leading | 8.68 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.85 |
| 20 | FLT23-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.70 | 0.998 | Leading | 8.69 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.86 |
| 21 | FLT24-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.86 |
| 22 | FLT25-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.87 |
| 23 | FLT26-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 24 | FLT27-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 25 | FLT28-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.69 | 0.998 | Leading | 8.69 | 0.998 | Leading | 9.11 | 0.996 | Leading | 10.86 |
| 26 | FLT29-3PH | 0.998 | Leading | 8.67 | 1.000 | Leading | 4.01 | 0.998 | Leading | 8.21 | 0.998 | Leading | 8.85 | 0.996 | Leading | 10.89 |
| 27 | FLT30-3PH | 0.998 | Leading | 9.05 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.87 |
| 28 | FLT31-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.86 |
| 29 | FLT34-3PH | 0.998 | Leading | 8.04 | 1.000 | Leading | 4.08 | 0.998 | Leading | 8.33 | 0.998 | Leading | 8.42 | 0.997 | Leading | 10.72 |
| 30 | FLT35-3PH | 0.998 | Leading | 8.53 | 0.999 | Leading | 4.35 | 0.998 | Leading | 8.47 | 0.998 | Leading | 8.76 | 0.997 | Leading | 10.81 |
| 31 | FLT36-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.76 | 0.998 | Leading | 8.75 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.85 |
| 32 | FLT37-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 33 | FLT38-3PH | 0.998 | Leading | 8.96 | 0.999 | Leading | 4.66 | 0.998 | Leading | 8.65 | 0.998 | Leading | 8.97 | 0.997 | Leading | 10.77 |
| 34 | FLT39-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.73 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 35 | FLT40-3PH | 0.998 | Leading | 9.03 | 0.999 | Leading | 4.69 | 0.998 | Leading | 8.70 | 0.998 | Leading | 9.10 | 0.996 | Leading | 10.86 |
| 36 | FLT41-3PH | 0.998 | Leading | 9.05 | 0.999 | Leading | 4.70 | 0.998 | Leading | 8.70 | 0.998 | Leading | 9.11 | 0.996 | Leading | 10.87 |
| 37 | FLT43-3PH | 0.998 | Leading | 7.51 | 1.000 | Leading | 3.84 | 0.998 | Leading | 8.33 | 0.998 | Leading | 8.34 | 0.997 | Leading | 10.64 |
| 38 | FLT44-3PH | 0.999 | Leading | 5.96 | 1.000 | Leading | 3.33 | 0.998 | Leading | 8.37 | 0.998 | Leading | 7.53 | 0.997 | Leading | 10.76 |
| 39 | FLT45-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 40 | FLT46-3PH | 0.998 | Leading | 7.30 | 1.000 | Leading | 3.52 | 0.998 | Leading | 8.18 | 0.998 | Leading | 7.84 | 0.997 | Leading | 10.80 |
| 41 | FLT47-3PH | 0.996 | Leading | 11.68 | 0.999 | Leading | 4.64 | 0.999 | Leading | 5.75 | 0.997 | Leading | 9.25 | 0.998 | Leading | 7.62 |
| 42 | FLT48-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 43 | FLT49-3PH | 0.999 | Leading | 7.06 | 1.000 | Leading | 1.21 | 0.998 | Leading | 7.25 | 0.998 | Leading | 8.00 | 0.997 | Leading | 10.40 |
| 44 | FLT52-3PH | 0.998 | Leading | 7.35 | 1.000 | Leading | 3.08 | 0.998 | Leading | 7.45 | 0.998 | Leading | 7.74 | 0.997 | Leading | 10.12 |
| 46 | FLT54-3PH | 0.999 | Leading | 6.76 | 1.000 | Leading | 3.14 | 0.998 | Leading | 7.60 | 0.998 | Leading | 7.28 | 0.997 | Leading | 10.21 |
| 47 | FLT55-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.73 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.15 | 0.996 | Leading | 10.88 |
| 48 | FLT56-3PH | 0.998 | Leading | 8.56 | 1.000 | Leading | 3.94 | 0.998 | Leading | 8.05 | 0.998 | Leading | 8.63 | 0.997 | Leading | 10.37 |
| 49 | FLT57-3PH | 0.998 | Leading | 7.50 | 1.000 | Leading | 3.08 | 0.998 | Leading | 7.40 | 0.998 | Leading | 7.69 | 0.997 | Leading | 10.14 |
| 50 | FLT58-3PH | 0.998 | Leading | 8.52 | 1.000 | Leading | 3.88 | 0.998 | Leading | 8.00 | 0.998 | Leading | 8.59 | 0.997 | Leading | 10.34 |
| 51 | FLT59-3PH | 0.999 | Leading | 5.97 | 1.000 | Leading | 1.31 | 0.999 | Leading | 4.84 | 0.999 | Leading | 5.76 | 0.999 | Leading | 6.77 |
| 52 | FLT60-3PH | 0.998 | Leading | 9.03 | 0.999 | Leading | 4.67 | 0.998 | Leading | 8.46 | 0.998 | Leading | 8.99 | 0.997 | Leading | 10.83 |
| 53 | FLT63-3PH | 0.999 | Leading | 5.93 | 1.000 | Leading | 1.44 | 0.999 | Leading | 6.10 | 0.999 | Leading | 6.67 | 0.998 | Leading | 7.92 |
| 54 | FLT64-3PH | 0.998 | Leading | 8.08 | 1.000 | Leading | 2.72 | 0.999 | Leading | 7.05 | 0.998 | Leading | 7.52 | 0.998 | Leading | 8.06 |
| 55 | FLT65-3PH | 0.999 | Leading | 6.92 | 1.000 | Leading | 2.64 | 0.998 | Leading | 7.43 | 0.998 | Leading | 7.73 | 0.997 | Leading | 9.26 |
| 56 | FLT66-3PH | 0.998 | Leading | 8.75 | 0.999 | Leading | 6.13 | 0.998 | Leading | 8.84 | 0.997 | Leading | 9.58 | 0.996 | Leading | 11.33 |
| 57 | FLT67-3PH | 0.998 | Leading | 8.99 | 0.999 | Leading | 4.78 | 0.998 | Leading | 8.73 | 0.997 | Leading | 9.23 | 0.996 | Leading | 10.96 |
| 58 | FLT68-3PH | 0.998 | Leading | 7.29 | 1.000 | Leading | 3.07 | 0.998 | Leading | 7.98 | 0.998 | Leading | 8.21 | 0.997 | Leading | 9.80 |
| 59 | FLT69-3PH | 0.999 | Leading | 6.29 | 1.000 | Leading | 2.29 | 0.999 | Leading | 6.27 | 0.999 | Leading | 6.19 | 0.997 | Leading | 9.19 |
| 60 | FLT70-3PH | 0.997 | Leading | 9.57 | 0.999 | Leading | 5.10 | 0.998 | Leading | 8.78 | 0.997 | Leading | 9.89 | 0.995 | Leading | 12.30 |
| 61 | FLT71-3PH | 0.998 | Leading | 8.67 | 0.999 | Leading | 4.58 | 0.998 | Leading | 8.56 | 0.998 | Leading | 8.92 | 0.997 | Leading | 10.66 |
| 62 | FLT72-3PH | 0.998 | Leading | 8.58 | 1.000 | Leading | 3.44 | 0.998 | Leading | 7.32 | 0.998 | Leading | 8.59 | 0.997 | Leading | 9.63 |
| 63 | FLT73-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 64 | FLT74-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.19 | 0.998 | Leading | 8.16 | 0.998 | Leading | 8.60 | 0.997 | Leading | 10.35 |
| 65 | FLT75-3PH | 0.997 | Leading | 9.70 | 0.999 | Leading | 6.53 | 0.996 | Leading | 11.15 | 0.997 | Leading | 9.83 | 0.993 | Leading | 15.09 |
| 66 | FLT76-3PH | 0.998 | Leading | 7.47 | 1.000 | Leading | 3.22 | 0.998 | Leading | 8.14 | 0.998 | Leading | 8.38 | 0.997 | Leading | 9.94 |
| 67 | FLT77-3PH | 0.986 | Leading | 21.94 | 0.982 | Leading | 24.87 | 0.984 | Leading | 23.02 | 0.989 | Leading | 19.11 | 0.971 | Leading | 31.76 |
| 68 | FLT84-3PH | 0.997 | Leading | 9.71 | 0.999 | Leading | 5.37 | 0.998 | Leading | 9.10 | 0.997 | Leading | 9.68 | 0.996 | Leading | 11.06 |
| 69 | FLT85-3PH | 0.998 | Leading | 8.92 | 0.999 | Leading | 4.34 | 0.998 | Leading | 8.38 | 0.998 | Leading | 8.96 | 0.997 | Leading | 10.18 |
| 70 | FLT86-3PH | 0.998 | Leading | 7.10 | 1.000 | Leading | 2.64 | 0.999 | Leading | 6.90 | 0.999 | Leading | 6.88 | 0.997 | Leading | 9.57 |
| 71 | FLT87-3PH | 0.998 | Leading | 9.15 | 0.999 | Leading | 4.80 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.07 | 0.997 | Leading | 10.81 |
| 72 | FLT88-3PH | 0.998 | Leading | 9.10 | 0.999 | Leading | 4.74 | 0.998 | Leading | 8.69 | 0.998 | Leading | 9.15 | 0.997 | Leading | 10.83 |
| 73 | FLT92-3PH | 0.998 | Leading | 7.29 | 1.000 | Leading | 2.38 | 0.999 | Leading | 6.85 | 0.998 | Leading | 7.74 | 0.997 | Leading | 10.74 |
| 74 | FLT93-3PH | 0.997 | Leading | 9.34 | 0.999 | Leading | 5.74 | 0.998 | Leading | 9.10 | 0.998 | Leading | 9.03 | 0.997 | Leading | 9.29 |
| 75 | FLT94-3PH | 0.998 | Leading | 7.28 | 1.000 | Leading | 2.37 | 0.999 | Leading | 6.85 | 0.998 | Leading | 7.74 | 0.997 | Leading | 10.74 |

Table 5-7 (continued)
Power Factor Analysis: GEN-2015-079

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|----------|-------|------------------|----------|--------|------------------|----------|-------|------------------|----------|-------|------------------|----------|--------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 76 | FLT95-3PH | 0.997 | Leading | 9.34 | 0.999 | Leading | 5.73 | 0.998 | Leading | 9.10 | 0.998 | Leading | 9.03 | 0.997 | Leading | 9.29 |
| 77 | FLT96-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.73 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 78 | FLT97-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.73 | 0.998 | Leading | 8.74 | 0.998 | Leading | 9.15 | 0.996 | Leading | 10.87 |
| 79 | FLT98-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 80 | FLT99-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.74 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.86 |
| 81 | FLT100-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.74 | 0.998 | Leading | 9.15 | 0.996 | Leading | 10.87 |
| 82 | FLT101-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 83 | FLT102-3PH | 0.998 | Leading | 9.11 | 0.999 | Leading | 4.76 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.84 |
| 84 | FLT105-3PH | 0.998 | Leading | 8.66 | 0.999 | Leading | 4.31 | 0.998 | Leading | 8.34 | 0.998 | Leading | 8.93 | 0.997 | Leading | 10.14 |
| 85 | FLT106-3PH | 0.998 | Leading | 8.75 | 0.999 | Leading | 4.66 | 0.998 | Leading | 8.54 | 0.998 | Leading | 9.09 | 0.997 | Leading | 10.53 |
| 86 | FLT107-3PH | 0.997 | Leading | 9.16 | 0.999 | Leading | 4.76 | 0.998 | Leading | 8.80 | 0.998 | Leading | 9.14 | 0.996 | Leading | 11.09 |
| 87 | FLT108-3PH | 0.997 | Leading | 9.30 | 0.999 | Leading | 5.10 | 0.998 | Leading | 8.99 | 0.998 | Leading | 8.98 | 0.996 | Leading | 11.28 |
| 88 | FLT109-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.85 |
| 89 | FLT110-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.86 |
| 90 | FLT111-3PH | 0.998 | Leading | 8.53 | 0.999 | Leading | 4.53 | 0.998 | Leading | 8.60 | 0.998 | Leading | 8.87 | 0.996 | Leading | 10.87 |
| 91 | FLT112-3PH | 0.998 | Leading | 8.80 | 0.999 | Leading | 4.23 | 0.998 | Leading | 8.29 | 0.998 | Leading | 8.83 | 0.997 | Leading | 10.60 |
| 92 | FLT113-3PH | 0.998 | Leading | 8.95 | 0.999 | Leading | 4.58 | 0.998 | Leading | 8.52 | 0.998 | Leading | 9.04 | 0.997 | Leading | 10.61 |
| 93 | FLT114-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.61 | 0.998 | Leading | 8.63 | 0.998 | Leading | 9.13 | 0.997 | Leading | 10.73 |
| 94 | FLT115-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 95 | FLT116-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.74 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.11 | 0.997 | Leading | 10.81 |
| 96 | FLT117-3PH | 0.998 | Leading | 8.72 | 0.999 | Leading | 4.32 | 0.998 | Leading | 8.36 | 0.998 | Leading | 8.87 | 0.997 | Leading | 10.63 |
| 97 | FLT118-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 5.11 | 0.997 | Leading | 9.27 | 0.997 | Leading | 9.37 | 0.996 | Leading | 11.68 |
| 98 | FLT119-3PH | 0.998 | Leading | 9.00 | 0.999 | Leading | 4.68 | 0.998 | Leading | 8.57 | 0.998 | Leading | 9.01 | 0.997 | Leading | 10.73 |
| 99 | FLT120-3PH | 0.997 | Leading | 10.04 | 0.999 | Leading | 6.01 | 0.997 | Leading | 10.16 | 0.997 | Leading | 10.33 | 0.996 | Leading | 12.28 |
| 100 | FLT121-3PH | 0.998 | Leading | 9.05 | 0.999 | Leading | 4.68 | 0.998 | Leading | 8.67 | 0.998 | Leading | 9.10 | 0.997 | Leading | 10.82 |
| 101 | FLT126-3PH | 0.999 | Lagging | -5.95 | 0.996 | Lagging | -12.14 | 0.999 | Lagging | -6.56 | 1.000 | Lagging | -3.40 | 0.994 | Lagging | -14.22 |
| 102 | FLT127-3PH | 0.998 | Leading | 9.01 | 0.999 | Leading | 4.58 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 103 | FLT128-3PH | 0.998 | Leading | 8.73 | 1.000 | Leading | 3.93 | 0.998 | Leading | 8.94 | 0.997 | Leading | 9.21 | 0.996 | Leading | 10.93 |
| 104 | FLT129-3PH | 0.998 | Leading | 9.10 | 0.999 | Leading | 4.65 | 0.998 | Leading | 8.64 | 0.998 | Leading | 9.12 | 0.997 | Leading | 10.79 |

Study Generator GEN-2015-079

The Power Factor Analysis shows that GEN-2015-079 has a power factor range of 0.986 leading (absorbing) to 0.999 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.982 leading (absorbing) to 0.996 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.984 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.989 leading (absorbing) to 1.00 (unity) for the 2020 Winter Peak conditions, and a power factor range of 0.971 leading (absorbing) to 0.994 lagging (supplying) for the 2025 Summer Peak conditions.

Table 5-8
Power Factor Analysis: GEN-2015-080

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|-----------|------------------|----------|-------|------------------|----------|-------|------------------|----------|-------|------------------|----------|-------|------------------|----------|-------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 0 | Base | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 1 | FLT01-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.75 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 2 | FLT02-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.75 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 3 | FLT03-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.87 |
| 4 | FLT04-3PH | 0.997 | Leading | 9.36 | 0.999 | Leading | 5.20 | 0.998 | Leading | 9.02 | 0.997 | Leading | 9.26 | 0.997 | Leading | 10.68 |
| 5 | FLT05-3PH | 0.997 | Leading | 9.28 | 0.999 | Leading | 4.97 | 0.998 | Leading | 8.87 | 0.997 | Leading | 9.22 | 0.997 | Leading | 10.82 |
| 6 | FLT06-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.74 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 7 | FLT07-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.75 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 8 | FLT11-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.70 | 0.998 | Leading | 8.68 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.84 |
| 9 | FLT12-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.70 | 0.998 | Leading | 8.67 | 0.998 | Leading | 9.12 | 0.997 | Leading | 10.84 |
| 10 | FLT13-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.86 |
| 11 | FLT14-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.74 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.11 | 0.997 | Leading | 10.82 |
| 12 | FLT15-3PH | 0.998 | Leading | 8.82 | 0.999 | Leading | 4.34 | 0.998 | Leading | 8.42 | 0.998 | Leading | 8.91 | 0.997 | Leading | 10.71 |
| 13 | FLT16-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.86 |
| 14 | FLT17-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 15 | FLT18-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 16 | FLT19-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 17 | FLT20-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.73 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 18 | FLT21-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.70 | 0.998 | Leading | 8.70 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.86 |
| 19 | FLT22-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.69 | 0.998 | Leading | 8.68 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.85 |
| 20 | FLT23-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.70 | 0.998 | Leading | 8.69 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.86 |
| 21 | FLT24-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.86 |
| 22 | FLT25-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.87 |
| 23 | FLT26-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 24 | FLT27-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 25 | FLT28-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.69 | 0.998 | Leading | 8.69 | 0.998 | Leading | 9.11 | 0.996 | Leading | 10.86 |
| 26 | FLT29-3PH | 0.998 | Leading | 8.67 | 1.000 | Leading | 4.01 | 0.998 | Leading | 8.21 | 0.998 | Leading | 8.85 | 0.996 | Leading | 10.89 |
| 27 | FLT30-3PH | 0.998 | Leading | 9.05 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.87 |
| 28 | FLT31-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.86 |
| 29 | FLT34-3PH | 0.998 | Leading | 8.04 | 1.000 | Leading | 4.08 | 0.998 | Leading | 8.33 | 0.998 | Leading | 8.42 | 0.997 | Leading | 10.72 |
| 30 | FLT35-3PH | 0.998 | Leading | 8.53 | 0.999 | Leading | 4.35 | 0.998 | Leading | 8.47 | 0.998 | Leading | 8.76 | 0.997 | Leading | 10.81 |
| 31 | FLT36-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.76 | 0.998 | Leading | 8.75 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.85 |
| 32 | FLT37-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 33 | FLT38-3PH | 0.998 | Leading | 8.96 | 0.999 | Leading | 4.66 | 0.998 | Leading | 8.65 | 0.998 | Leading | 8.97 | 0.997 | Leading | 10.77 |
| 34 | FLT39-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.73 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 35 | FLT40-3PH | 0.998 | Leading | 9.03 | 0.999 | Leading | 4.69 | 0.998 | Leading | 8.70 | 0.998 | Leading | 9.10 | 0.996 | Leading | 10.86 |
| 36 | FLT41-3PH | 0.998 | Leading | 9.05 | 0.999 | Leading | 4.70 | 0.998 | Leading | 8.70 | 0.998 | Leading | 9.11 | 0.996 | Leading | 10.87 |
| 37 | FLT43-3PH | 0.998 | Leading | 7.51 | 1.000 | Leading | 3.84 | 0.998 | Leading | 8.33 | 0.998 | Leading | 8.34 | 0.997 | Leading | 10.64 |
| 38 | FLT44-3PH | 0.999 | Leading | 5.96 | 1.000 | Leading | 3.33 | 0.998 | Leading | 8.37 | 0.998 | Leading | 7.53 | 0.997 | Leading | 10.76 |
| 39 | FLT45-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 40 | FLT46-3PH | 0.998 | Leading | 7.30 | 1.000 | Leading | 3.52 | 0.998 | Leading | 8.18 | 0.998 | Leading | 7.84 | 0.997 | Leading | 10.80 |
| 41 | FLT47-3PH | 0.996 | Leading | 11.68 | 0.999 | Leading | 4.64 | 0.999 | Leading | 5.75 | 0.997 | Leading | 9.25 | 0.998 | Leading | 7.62 |
| 42 | FLT48-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 43 | FLT49-3PH | 0.999 | Leading | 7.06 | 1.000 | Leading | 1.21 | 0.998 | Leading | 7.25 | 0.998 | Leading | 8.00 | 0.997 | Leading | 10.40 |
| 44 | FLT52-3PH | 0.998 | Leading | 7.35 | 1.000 | Leading | 3.08 | 0.998 | Leading | 7.45 | 0.998 | Leading | 7.74 | 0.997 | Leading | 10.12 |
| 46 | FLT54-3PH | 0.999 | Leading | 6.76 | 1.000 | Leading | 3.14 | 0.998 | Leading | 7.60 | 0.998 | Leading | 7.28 | 0.997 | Leading | 10.21 |
| 47 | FLT55-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.73 | 0.998 | Leading | 8.73 | 0.998 | Leading | 9.15 | 0.996 | Leading | 10.88 |
| 48 | FLT56-3PH | 0.998 | Leading | 8.56 | 1.000 | Leading | 3.94 | 0.998 | Leading | 8.05 | 0.998 | Leading | 8.63 | 0.997 | Leading | 10.37 |
| 49 | FLT57-3PH | 0.998 | Leading | 7.50 | 1.000 | Leading | 3.08 | 0.998 | Leading | 7.40 | 0.998 | Leading | 7.69 | 0.997 | Leading | 10.14 |
| 50 | FLT58-3PH | 0.998 | Leading | 8.52 | 1.000 | Leading | 3.88 | 0.998 | Leading | 8.00 | 0.998 | Leading | 8.59 | 0.997 | Leading | 10.34 |
| 51 | FLT59-3PH | 0.999 | Leading | 5.97 | 1.000 | Leading | 1.31 | 0.999 | Leading | 4.84 | 0.999 | Leading | 5.76 | 0.999 | Leading | 6.77 |
| 52 | FLT60-3PH | 0.998 | Leading | 9.03 | 0.999 | Leading | 4.67 | 0.998 | Leading | 8.46 | 0.998 | Leading | 8.99 | 0.997 | Leading | 10.83 |
| 53 | FLT63-3PH | 0.999 | Leading | 5.93 | 1.000 | Leading | 1.44 | 0.999 | Leading | 6.10 | 0.999 | Leading | 6.67 | 0.998 | Leading | 7.92 |
| 54 | FLT64-3PH | 0.998 | Leading | 8.08 | 1.000 | Leading | 2.72 | 0.999 | Leading | 7.05 | 0.998 | Leading | 7.52 | 0.998 | Leading | 8.06 |
| 55 | FLT65-3PH | 0.999 | Leading | 6.92 | 1.000 | Leading | 2.64 | 0.998 | Leading | 7.43 | 0.998 | Leading | 7.73 | 0.997 | Leading | 9.26 |
| 56 | FLT66-3PH | 0.998 | Leading | 8.75 | 0.999 | Leading | 6.13 | 0.998 | Leading | 8.84 | 0.997 | Leading | 9.58 | 0.996 | Leading | 11.33 |
| 57 | FLT67-3PH | 0.998 | Leading | 8.99 | 0.999 | Leading | 4.78 | 0.998 | Leading | 8.73 | 0.997 | Leading | 9.23 | 0.996 | Leading | 10.96 |
| 58 | FLT68-3PH | 0.998 | Leading | 7.29 | 1.000 | Leading | 3.07 | 0.998 | Leading | 7.98 | 0.998 | Leading | 8.21 | 0.997 | Leading | 9.80 |
| 59 | FLT69-3PH | 0.999 | Leading | 6.29 | 1.000 | Leading | 2.29 | 0.999 | Leading | 6.27 | 0.999 | Leading | 6.19 | 0.997 | Leading | 9.19 |
| 60 | FLT70-3PH | 0.997 | Leading | 9.57 | 0.999 | Leading | 5.10 | 0.998 | Leading | 8.78 | 0.997 | Leading | 9.89 | 0.995 | Leading | 12.30 |
| 61 | FLT71-3PH | 0.998 | Leading | 8.67 | 0.999 | Leading | 4.58 | 0.998 | Leading | 8.56 | 0.998 | Leading | 8.92 | 0.997 | Leading | 10.66 |
| 62 | FLT72-3PH | 0.998 | Leading | 8.58 | 1.000 | Leading | 3.44 | 0.998 | Leading | 7.32 | 0.998 | Leading | 8.59 | 0.997 | Leading | 9.63 |
| 63 | FLT73-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 64 | FLT74-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.19 | 0.998 | Leading | 8.16 | 0.998 | Leading | 8.60 | 0.997 | Leading | 10.35 |
| 65 | FLT75-3PH | 0.997 | Leading | 9.70 | 0.999 | Leading | 6.53 | 0.996 | Leading | 11.15 | 0.997 | Leading | 9.83 | 0.993 | Leading | 15.09 |
| 66 | FLT76-3PH | 0.998 | Leading | 7.47 | 1.000 | Leading | 3.22 | 0.998 | Leading | 8.14 | 0.998 | Leading | 8.38 | 0.997 | Leading | 9.94 |
| 67 | FLT77-3PH | 0.986 | Leading | 21.94 | 0.982 | Leading | 24.87 | 0.984 | Leading | 23.02 | 0.989 | Leading | 19.11 | 0.971 | Leading | 31.76 |
| 68 | FLT84-3PH | 0.997 | Leading | 9.71 | 0.999 | Leading | 5.37 | 0.998 | Leading | 9.10 | 0.997 | Leading | 9.68 | 0.996 | Leading | 11.06 |
| 69 | FLT85-3PH | 0.998 | Leading | 8.92 | 0.999 | Leading | 4.34 | 0.998 | Leading | 8.38 | 0.998 | Leading | 8.96 | 0.997 | Leading | 10.18 |
| 70 | FLT86-3PH | 0.998 | Leading | 7.10 | 1.000 | Leading | 2.64 | 0.999 | Leading | 6.90 | 0.999 | Leading | 6.88 | 0.997 | Leading | 9.57 |
| 71 | FLT87-3PH | 0.998 | Leading | 9.15 | 0.999 | Leading | 4.80 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.07 | 0.997 | Leading | 10.81 |
| 72 | FLT88-3PH | 0.998 | Leading | 9.10 | 0.999 | Leading | 4.74 | 0.998 | Leading | 8.69 | 0.998 | Leading | 9.15 | 0.997 | Leading | 10.83 |
| 73 | FLT92-3PH | 0.998 | Leading | 7.29 | 1.000 | Leading | 2.38 | 0.999 | Leading | 6.85 | 0.998 | Leading | 7.74 | 0.997 | Leading | 10.74 |
| 74 | FLT93-3PH | 0.997 | Leading | 9.34 | 0.999 | Leading | 5.74 | 0.998 | Leading | 9.10 | 0.998 | Leading | 9.03 | 0.997 | Leading | 9.29 |
| 75 | FLT94-3PH | 0.998 | Leading | 7.28 | 1.000 | Leading | 2.37 | 0.999 | Leading | 6.85 | 0.998 | Leading | 7.74 | 0.997 | Leading | 10.74 |

Table 5-8 (continued)
Power Factor Analysis: GEN-2015-080

| Cont. No. | Case | 2016 Winter Peak | | | 2017 Summer Peak | | | 2020 Summer Peak | | | 2020 Winter Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|----------|-------|------------------|----------|--------|------------------|----------|-------|------------------|----------|-------|------------------|----------|--------|
| | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | | Power Factor | Q (MVAR) | |
| 76 | FLT95-3PH | 0.997 | Leading | 9.34 | 0.999 | Leading | 5.73 | 0.998 | Leading | 9.10 | 0.998 | Leading | 9.03 | 0.997 | Leading | 9.29 |
| 77 | FLT96-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.73 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 78 | FLT97-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.73 | 0.998 | Leading | 8.74 | 0.998 | Leading | 9.15 | 0.996 | Leading | 10.87 |
| 79 | FLT98-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 80 | FLT99-3PH | 0.998 | Leading | 9.09 | 0.999 | Leading | 4.74 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.86 |
| 81 | FLT100-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.74 | 0.998 | Leading | 9.15 | 0.996 | Leading | 10.87 |
| 82 | FLT101-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 83 | FLT102-3PH | 0.998 | Leading | 9.11 | 0.999 | Leading | 4.76 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.84 |
| 84 | FLT105-3PH | 0.998 | Leading | 8.66 | 0.999 | Leading | 4.31 | 0.998 | Leading | 8.34 | 0.998 | Leading | 8.93 | 0.997 | Leading | 10.14 |
| 85 | FLT106-3PH | 0.998 | Leading | 8.75 | 0.999 | Leading | 4.66 | 0.998 | Leading | 8.54 | 0.998 | Leading | 9.09 | 0.997 | Leading | 10.53 |
| 86 | FLT107-3PH | 0.997 | Leading | 9.16 | 0.999 | Leading | 4.76 | 0.998 | Leading | 8.80 | 0.998 | Leading | 9.14 | 0.996 | Leading | 11.09 |
| 87 | FLT108-3PH | 0.997 | Leading | 9.30 | 0.999 | Leading | 5.10 | 0.998 | Leading | 8.99 | 0.998 | Leading | 8.98 | 0.996 | Leading | 11.28 |
| 88 | FLT109-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.71 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.12 | 0.996 | Leading | 10.85 |
| 89 | FLT110-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.71 | 0.998 | Leading | 9.13 | 0.996 | Leading | 10.86 |
| 90 | FLT111-3PH | 0.998 | Leading | 8.53 | 0.999 | Leading | 4.53 | 0.998 | Leading | 8.60 | 0.998 | Leading | 8.87 | 0.996 | Leading | 10.87 |
| 91 | FLT112-3PH | 0.998 | Leading | 8.80 | 0.999 | Leading | 4.23 | 0.998 | Leading | 8.29 | 0.998 | Leading | 8.83 | 0.997 | Leading | 10.60 |
| 92 | FLT113-3PH | 0.998 | Leading | 8.95 | 0.999 | Leading | 4.58 | 0.998 | Leading | 8.52 | 0.998 | Leading | 9.04 | 0.997 | Leading | 10.61 |
| 93 | FLT114-3PH | 0.998 | Leading | 9.06 | 0.999 | Leading | 4.61 | 0.998 | Leading | 8.63 | 0.998 | Leading | 9.13 | 0.997 | Leading | 10.73 |
| 94 | FLT115-3PH | 0.998 | Leading | 9.08 | 0.999 | Leading | 4.72 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 95 | FLT116-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 4.74 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.11 | 0.997 | Leading | 10.81 |
| 96 | FLT117-3PH | 0.998 | Leading | 8.72 | 0.999 | Leading | 4.32 | 0.998 | Leading | 8.36 | 0.998 | Leading | 8.87 | 0.997 | Leading | 10.63 |
| 97 | FLT118-3PH | 0.998 | Leading | 9.07 | 0.999 | Leading | 5.11 | 0.997 | Leading | 9.27 | 0.997 | Leading | 9.37 | 0.996 | Leading | 11.68 |
| 98 | FLT119-3PH | 0.998 | Leading | 9.00 | 0.999 | Leading | 4.68 | 0.998 | Leading | 8.57 | 0.998 | Leading | 9.01 | 0.997 | Leading | 10.73 |
| 99 | FLT120-3PH | 0.997 | Leading | 10.04 | 0.999 | Leading | 6.01 | 0.997 | Leading | 10.16 | 0.997 | Leading | 10.33 | 0.996 | Leading | 12.28 |
| 100 | FLT121-3PH | 0.998 | Leading | 9.05 | 0.999 | Leading | 4.68 | 0.998 | Leading | 8.67 | 0.998 | Leading | 9.10 | 0.997 | Leading | 10.82 |
| 101 | FLT126-3PH | 0.999 | Lagging | -5.95 | 0.996 | Lagging | -12.14 | 0.999 | Lagging | -6.56 | 1.000 | Lagging | -3.40 | 0.994 | Lagging | -14.22 |
| 102 | FLT127-3PH | 0.998 | Leading | 9.01 | 0.999 | Leading | 4.58 | 0.998 | Leading | 8.72 | 0.998 | Leading | 9.14 | 0.996 | Leading | 10.87 |
| 103 | FLT128-3PH | 0.998 | Leading | 8.73 | 1.000 | Leading | 3.93 | 0.998 | Leading | 8.94 | 0.997 | Leading | 9.21 | 0.996 | Leading | 10.93 |
| 104 | FLT129-3PH | 0.998 | Leading | 9.10 | 0.999 | Leading | 4.65 | 0.998 | Leading | 8.64 | 0.998 | Leading | 9.12 | 0.997 | Leading | 10.79 |

Study Generator GEN-2015-080

The Power Factor Analysis shows that GEN-2015-080 has a power factor range of 0.986 leading (absorbing) to 0.999 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.982 leading (absorbing) to 0.996 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.984 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.989 leading (absorbing) to 1.00 (unity) for the 2020 Winter Peak conditions, and a power factor range of 0.971 leading (absorbing) to 0.994 lagging (supplying) for the 2025 Summer Peak conditions.

SECTION 6: LOW WIND/NO WIND ANALYSIS

The objective of this task was to determine the impact of low wind or no wind conditions/solar irradiance on wind farms and solar farms, respectively. The 2016 Winter Peak, 2017 Summer Peak, 2020 Summer Peak, 2020 Winter Peak, and 2025 Summer Peak power flows provided by SPP were examined for this analysis.

6.1 Approach

Low/no wind and low/no solar irradiance conditions were examined for all renewable interconnections. Generators were disabled (independently), but the collector systems remained in-service. In order to maintain generation and load balance in the SPP area, the generation was scaled after disabling the respective generator. The amount of reactive power injected into the transmission network was recorded at the respective point of interconnection. This reactive power comes from the capacitance of the project's transmission lines and collector cables. A shunt reactor was added at the high side bus to bring the Mvar flow into the POI down to approximately zero.

6.2 Low Wind/No Wind Analysis Results

The reactance needed to bring the Mvar flow into the point of interconnect to zero Mvar was recorded for each season for renewable interconnections. Refer to Table 6-1 for the results of this analysis. The table lists the generators examined and the amount of reactive power needed for zero Mvar flow into the POI for each season.

**Table 6-1
Low Wind/No Wind Analysis**

| Request | Size (MW) | Point of Interconnection | Reactor Size (Mvar) | | | | |
|--------------|-----------|----------------------------------|---------------------|------|------|------|------|
| | | | 16WP | 17SP | 20SP | 20WP | 25SP |
| GEN-2015-020 | 100 | Oasis 115kV | 0.6 | 0.6 | 0.6 | 0.6 | 0.6 |
| GEN-2015-031 | 300 | Swisher to Amarillo South 230 kV | 6.1 | 6.1 | 6.1 | 6.1 | 6.1 |
| GEN-2015-056 | 101 | Crossroads 345kV | 8.6 | 8.6 | 8.6 | 8.6 | 8.6 |
| GEN-2015-058 | 50 | Atoka 115kV | 0.4 | 0.4 | 0.4 | 0.4 | 0.4 |
| GEN-2015-068 | 300 | Tuco 345kV | 58.0 | 58.0 | 58.0 | 58.0 | 58.0 |
| GEN-2015-075 | 50 | Carlisle 69kV | 3.9 | 3.9 | 3.9 | 3.9 | 3.9 |
| GEN-2015-079 | 129.2 | Tap Yoakum to Hobbs 230 kV | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |
| GEN-2015-080 | 129.2 | Tap Yoakum to Hobbs 230 kV | 1.0 | 1.0 | 1.0 | 1.0 | 1.0 |

SECTION 7: CONCLUSIONS

Summary of Stability Analysis

The Stability Analysis determined that there were multiple contingencies across all seasons that resulted in system/voltage instability, generation tripping offline, and poor post-fault voltage recovery when all generation interconnection requests were at 100% output.

To mitigate the system/voltage instability, voltage violations, generation tripping offline, and poor post-fault steady-state voltages, the following upgrades were provided by SPP and implemented in each season:

- Tuco – Yoakum – Hobbs 345kV circuit #1 (**16WP and 17SP**)
- Yoakum 345/230 kV transformer and Hobbs 345/230 kV transformer (**16WP and 17SP**)
- GEN-2014-074 345/34.5 kV transformer low side tap ratio set to 0.95 p.u.
- OKU Reactive Power Support
 - +/- 100 Mvar SVC
- Border Reactive Power Support (600 Mvar total)
 - +300 Mvar SVC
 - 300 Mvar capacitor bank
- Seminole – Mustang 115 kV circuit #1

Note for GEN-2015-058, for a three-phase fault at the point of interconnection (Atoka 115 kV), the TMEIC photovoltaic inverter model (ITMEIC) tripped offline due to over frequency protection and over voltage protection. For this study, the over frequency and over voltage protection were set to 75 Hz and 1.8 p.u., respectively, to avoid instantaneous tripping. It is recommended the supplier of the TMEIC photovoltaic inverter model examine this model for three-phase faults that cause the model to trip on over frequency and over voltage protection.

After implementing the above upgrades, the contingency analysis was re-simulated for all contingencies. With the upgrades, the Stability Analysis determined that there was no wind turbine tripping or system instability observed as a result of interconnecting all study projects at 100% output.

Summary of the Short Circuit Analysis

The short circuit analysis was performed on the 2017 Summer Peak and 2025 Summer Peak power flows for all study projects. Refer to Table 7-1 and Table 7-2 for a list of maximum fault currents observed for each study project for the 17SP and 25SP cases, respectively.

Table 7-1
2017SP: List of Maximum Fault Currents Observed for Each Study Project

| Study Project | Fault Current at POI (kA) | Maximum Fault Current (kA) | Fault Location | Bus Voltage (kV) |
|----------------------|----------------------------------|-----------------------------------|-----------------------|-------------------------|
| GEN-2015-020 | 9.57 | 25.84 | Tolk East/West | 230 kV |
| GEN-2015-031 | 9.03 | 30.52 | LP - Cook | 69 kV |
| GEN-2015-056 | 5.42 | 26.24 | Cunnigham | 115 kV |
| GEN-2015-058 | 6.59 | 26.24 | Cunnigham | 115 kV |
| GEN-2015-068 | 13.36 | 30.52 | LP - Cook | 69 kV |
| GEN-2015-075 | 2.57 | 25.84 | Tolk East | 230 kV |
| GEN-2015-079 | 8.97 | 29.89 | Hobbs Int | 115 kV |
| GEN-2015-080 | 8.97 | 29.89 | Hobbs Int | 115 kV |

Table 7-2
2025SP: List of Maximum Fault Currents Observed for Each Study Project

| Study Project | Fault Current at POI (kA) | Maximum Fault Current (kA) | Fault Location | Bus Voltage (kV) |
|----------------------|----------------------------------|-----------------------------------|-----------------------|-------------------------|
| GEN-2015-020 | 9.75 | 26.48 | Tolk East/West | 230 kV |
| GEN-2015-031 | 9.05 | 34.97 | LP - Cook | 69 kV |
| GEN-2015-056 | 5.48 | 29.66 | Cunnigham | 115 kV |
| GEN-2015-058 | 6.97 | 29.66 | Cunnigham | 115 kV |
| GEN-2015-068 | 13.55 | 34.97 | LP - Cook | 69 kV |
| GEN-2015-075 | 2.58 | 26.48 | Tolk East | 230 kV |
| GEN-2015-079 | 9.26 | 32.92 | Hobbs Int | 115 kV |
| GEN-2015-080 | 9.26 | 32.92 | Hobbs Int | 115 kV |

Summary of Power Factor Analysis

The upgrades identified in the Stability Analysis were implemented in the power flow cases and utilized for the Power Factor Analysis.

Study Generator GEN-2015-020

The Power Factor Analysis shows that GEN-2015-020 has a power factor range of 0.970 leading (absorbing) to 0.990 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.973 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, a power factor range of 0.979 leading (absorbing) to 1.00 (unity) for the 2020 Summer Peak conditions, a power factor range of 0.973 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.976 leading (absorbing) to 1.00 (unity) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-031

The Power Factor Analysis shows that GEN-2015-031 has a power factor range of 0.983 leading (absorbing) to 0.784 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.991 leading (absorbing) to 0.646 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.991 leading (absorbing) to 0.744 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.979 leading (absorbing) to 0.840 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.997 leading (absorbing) to 0.782 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-056

The Power Factor Analysis shows that GEN-2015-056 has a power factor range of 0.997 leading (absorbing) to 0.965 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.998 lagging (supplying) to 1.00 (unity) for the 2017 Summer Peak conditions, a power factor range of 0.983 lagging (supplying) to 1.00 (unity) for the 2020 Summer Peak conditions, a power factor range of 0.998 leading (absorbing) to 0.974 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.979 lagging (supplying) to 1.00 (unity) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-058

The Power Factor Analysis shows that GEN-2015-058 has a power factor range of 0.971 leading (absorbing) to 0.962 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.975 leading (absorbing) to 0.947 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.976 leading (absorbing) to 0.989 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.990 leading (absorbing) to 0.993 lagging

(supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.972 leading (absorbing) to 0.964 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-068

The Power Factor Analysis shows that GEN-2015-068 has a power factor range of 0.738 to 0.916 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.709 to 0.954 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.859 to 0.997 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.782 to 0.949 lagging (supplying) for the 2020 Winter Peak conditions, and a power factor range of 0.913 to 0.998 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-075

The Power Factor Analysis shows that GEN-2015-075 has a power factor range of 0.994 leading (absorbing) to 0.998 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.988 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, a power factor range of 0.996 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.995 leading (absorbing) to 1.00 (unity) for the 2020 Winter Peak conditions, and a power factor range of 0.989 leading (absorbing) to 0.995 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-079

The Power Factor Analysis shows that GEN-2015-079 has a power factor range of 0.986 leading (absorbing) to 0.999 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.982 leading (absorbing) to 0.996 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.984 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.989 leading (absorbing) to 1.00 (unity) for the 2020 Winter Peak conditions, and a power factor range of 0.971 leading (absorbing) to 0.994 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-080

The Power Factor Analysis shows that GEN-2015-080 has a power factor range of 0.986 leading (absorbing) to 0.999 lagging (supplying) for the 2016 Winter Peak conditions, a power factor range of 0.982 leading (absorbing) to 0.996 lagging (supplying) for the 2017 Summer Peak conditions, a power factor range of 0.984 leading (absorbing) to 0.999 lagging (supplying) for the 2020 Summer Peak conditions, a power factor range of 0.989 leading (absorbing) to 1.00 (unity) for the 2020 Winter Peak conditions, and a power factor range of 0.971 leading (absorbing) to 0.994 lagging (supplying) for the 2025 Summer Peak conditions.

Summary of the Low/No Wind Analysis

The amount of reactive power injected into the transmission network was recorded at the point of interconnection for each wind and solar powered interconnection request for each season. The maximum reactance needed for zero Mvar flow was 58 Mvar for GEN-2015-068 (Tuco 345 kV). The minimum reactance needed for zero Mvar flow was 0.4 Mvar for GEN-2015-058 (Atoka 115 kV).

11.16 M: Group 9 Dynamic Stability Analysis Report

See next page

Southwest Power Pool, Inc. (SPP)

DISIS-2015-002-1 (Group 09) Definitive Impact Study

Final Report

**PXE-1304
Revision #00**

August 2016

**Submitted By:
Mitsubishi Electric Power Products, Inc. (MEPPI)
Power Systems Engineering Services Department
Warrendale, PA**

Title: DISIS-2015-002-1 (Group 09) Definitive Impact Study: Final Report PXE-1304
Date: August 2016
Author: GianMarco Alian; Engineer I, Power Systems Engineering Dept. Gianmarco Alian
Reviewed: Nicholas W. Tenza; Engineer II, Power Systems Engineering Dept. Nicholas W. Tenza
Approved: Rajat Majumder; Section Manager, Power Systems Engineering Dept. Rajat Majumder

EXECUTIVE SUMMARY

SPP requested a Definitive Interconnection System Impact Study (DISIS). The DISIS required a Stability Analysis, Short-circuit Analysis, Power Factor Analysis, and Low Wind/No Wind Analysis detailing the impacts of the interconnecting projects as shown in Table ES-1.

Table ES-1
Interconnection Projects Evaluated

| Request | Size (MW) | Generator Model | Point of Interconnection |
|--------------|-----------|--|--|
| GEN-2015-053 | 50.0 | GE 1.79 MW (584913) (wind) | Antelope 115 kV (640521) |
| GEN-2015-076 | 158.4 | Vestas 3.3-117 3.3 MW (585133, 585136) (wind) | Belden 115 kV (640080) |
| GEN-2015-087 | 66.0 | Vestas V100 2.0 MW (585233) (wind) | Tap on Fairbury (640169) to Hebron (640218) 115 kV |
| GEN-2015-088 | 300.0 | Vestas V100 2.0 MW (585243) (wind) | Tap on Moore (640277) to Pauline (640312) 345 kV |

SUMMARY OF STABILITY ANALYSIS

The Stability Analysis determined there were no contingencies that resulted in system instability or generation tripping offline for the examined seasonal peak conditions when all generation interconnection requests were at 100% output.

However, it was determined that two contingencies, FLT39-3PH, which is the loss of the Fairbry7 to Harbine7 115 kV line and FLT120-3PH, which is the loss of the McCool to Grand Island 345 kV line, resulted in post-contingency generator power swings for all seasonal peak conditions at FAIRBRYG and BROKENBG, respectively. After discussion with SPP, it was determined that this was a pre-existing issue for FLT39-3PH as it was still present in the contingency even with the GEN-2015-087 out of service. Similarly, for FLT120-3PH, it was

determined that this was a pre-existing issue as it was still present in the contingency even with all four study generators out of service.

SUMMARY OF THE SHORT-CIRCUIT ANALYSIS

The Short-Circuit Analysis was performed on the 2017 Summer Peak and 2025 Summer Peak power flows for all study projects. Refer to Table ES-2 for a list of maximum fault currents observed for each study project for the 2017 Summer Peak case. Refer to Table ES-3 for a list of maximum fault currents observed for each study project for the 2025 Summer Peak case.

Table ES-2

List of Maximum Fault Currents Observed for Each Study Project for the 2017 Summer Peak Case

| Study Project | POI Name | Fault Current at POI (kA) | Maximum Fault Current (kA) | Fault Location | Bus Voltage (kV) |
|---------------|---|---------------------------|----------------------------|----------------|------------------|
| GEN-2015-053 | Antelope 115kV (640521) | 13.13 | 29.97 | S1251 5 | 161 |
| GEN-2015-076 | Belden 115kV (640080) | 6.67 | 29.97 | S1251 5 | 161 |
| GEN-2015-087 | Tap on Fairbury (640169) to Hebron (640218) 115kV | 5.37 | 31.65 | SHELDON7 | 115 |
| GEN-2015-088 | Tap on Moore (640277) to Pauline (640312) 345kV | 10.57 | 39.11 | S1206 5 | 115 |

Table ES-3

List of Maximum Fault Currents Observed for Each Study Project for the 2025 Summer Peak Case

| Study Project | POI Name | Fault Current at POI (kA) | Maximum Fault Current (kA) | Fault Location | Bus Voltage (kV) |
|---------------|---|---------------------------|----------------------------|----------------|------------------|
| GEN-2015-053 | Antelope 115kV (640521) | 13.38 | 30.89 | S1251 5 | 161 |
| GEN-2015-076 | Belden 115kV (640080) | 6.68 | 30.88 | S1251 5 | 161 |
| GEN-2015-087 | Tap on Fairbury (640169) to Hebron (640218) 115kV | 5.37 | 32.60 | SHELDON7 | 115 |
| GEN-2015-088 | Tap on Moore (640277) to Pauline (640312) 345kV | 10.62 | 40.47 | S1206 5 | 161 |

SUMMARY OF POWER FACTOR ANALYSIS

Study Generator GEN-2015-053

The Power Factor Analysis shows that GEN-2015-053 has a power factor range of 0.613 to 0.882 leading (absorbing) for the 2016 Winter Peak conditions, a power factor range of 0.654 to 0.969 leading (absorbing) for the 2017 Summer Peak conditions, and a power factor range of 0.645 to 0.982 leading (absorbing) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-076

The Power Factor Analysis shows that GEN-2015-076 has a power factor range of 0.975 leading (absorbing) to 1.00 (unity) for the 2016 Winter Peak conditions, a power factor range of 0.985 lagging (supplying) to 0.998 leading (absorbing) for the 2017 Summer Peak conditions, and a

power factor range of 0.985 lagging (supplying) to 0.998 leading (absorbing) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-087

The Power Factor Analysis shows that GEN-2015-087 has a power factor range of 0.978 leading (absorbing) to 1.00 (unity) for the 2016 Winter Peak conditions, a power factor range of 0.955 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, and a power factor range of 0.917 leading (absorbing) to 1.00 (unity) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-088

The Power Factor Analysis shows that GEN-2015-088 has a power factor range of 0.956 leading (absorbing) to 1.00 (unity) for the 2016 Winter Peak conditions, a power factor range of 0.948 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, and a power factor range of 0.966 leading (absorbing) to 1.00 (unity) for the 2025 Summer Peak conditions.

SUMMARY OF LOW WIND/NO WIND ANALYSIS

The amount of reactive power injected into the transmission network was recorded at the high side of the transformer near the point of interconnection for all study projects for each season. The maximum reactance needed for zero Mvar flow was -22.20 Mvar for GEN-2015-088. The minimum reactance needed for zero Mvar flow was -3.20 Mvar for GEN-2015-053.

Table of Contents

| | |
|---|----|
| Section 1: Objectives | 6 |
| Section 2: Background..... | 6 |
| Section 3: Stability Analysis | 24 |
| 3.1 Approach | 24 |
| 3.2 Stability Analysis Results | 26 |
| Section 4: Short-Circuit Analysis | 31 |
| 4.1 Approach | 31 |
| 4.2 Short-circuit Analysis Results | 31 |
| Section 5: Power Factor Analysis | 39 |
| 5.1 Approach | 39 |
| 5.2 Power Factor Analysis Results | 40 |
| Section 6: Low Wind/No Wind Analysis | 49 |
| 6.1 Approach | 49 |
| 6.2 Low Wind/No Wind Analysis Results | 49 |
| Section 7: Conclusions..... | 50 |

SECTION 1: OBJECTIVES

The objective of this report is to provide Southwest Power Pool, Inc. (SPP) with the deliverables for the “DISIS-2015-002-1 (Group 09) Definitive Impact Study.” SPP requested an Interconnection System Impact Study for four (4) generation interconnections for 2016 Winter Peak, 2017 Summer Peak, and 2025 Summer Peak, which requires a Stability Analysis, Short-circuit Analysis, Power Factor Analysis, Low Wind/No Wind Analysis, and an Impact Study Report.

SECTION 2: BACKGROUND

The Siemens Power Technologies International PSS/E power system simulation program Version 32.2.0 was used for this study. SPP provided the stability database cases for 2016 Winter Peak, 2017 Summer Peak, and 2025 Summer Peak conditions and a list of contingencies to be examined. The model includes the study projects shown in Table 2-1 and the previously queued projects listed in Table 2-2. Refer to Appendix A for the steady-state and dynamic model data for the study projects. A power flow one-line diagram for each generation interconnection project is shown in Figures 2-1 through 2-4. Note that the one-line diagrams represent the 2016 Winter Peak case.

The Stability Analysis determined the impacts of the new interconnecting projects on the stability and voltage recovery of the nearby system and the ability of the interconnecting projects to meet FERC Order 661A. If problems with stability or voltage recovery are identified, the need for reactive compensation or system upgrades will be investigated. Three-phase faults and single line-to-ground faults will be examined as listed in Table 2-3. Note that all contingencies listed were examined for the Cluster Scenario.

A Short-circuit Analysis was performed on the 2017 Summer Peak and 2025 Summer Peak study years for each study generator. The study was performed five buses out from the study generator’s point of interconnection and results were documented.

The Power Factor Analysis determined the power factor at the high side of the transformer near the point of interconnection for the wind or solar interconnection projects for pre-contingency and post-contingency conditions. The N-1, three phase contingencies listed in Table 2-3 were used in the Power Factor analysis.

The Low Wind/No Wind Analysis was completed for all wind and solar farm interconnections. This analysis determined if reactive support is needed to have a Mvar flow of approximately zero at the point of interconnection (POI).

**Table 2-1
Interconnection Projects Evaluated**

| Request | Size (MW) | Generator Model | Point of Interconnection |
|----------------|------------------|--|--|
| GEN-2015-053 | 50.0 | GE 1.79 MW (584913) (wind) | Antelope 115 kV (640521) |
| GEN-2015-076 | 158.4 | Vestas 3.3-117 3.3 MW (585133, 585136) (wind) | Belden 115 kV (640080) |
| GEN-2015-087 | 66.0 | Vestas V100 2.0 MW (585233) (wind) | Tap on Fairbury (640169) to Hebron (640218) 115 kV |
| GEN-2015-088 | 300.0 | Vestas V100 2.0 MW (585243) (wind) | Tap on Moore (640277) to Pauline (640312) 345 kV |

Table 2-2
Previously Queued Nearby Interconnection Projects Included

| Request | Size (MW) | Generator Model (Gen Bus Number) | Point of Interconnection |
|--|--|--|--|
| GEN-2003-021N | 75 | Vestas 1.65 MW (640026) | Tap on the Ainsworth – Calamus 115kV line (640050) |
| GEN-2004-023N | 75 | GENROU (640028) | Columbus 115kV (640119) |
| GEN-2006-020N | 42 | Vestas V90 VCUS 1.8 & 3.0 MW (640421,640441) | Bloomfield 115kV (640084) |
| GEN-2006-037N1 | 75 | GE 1.7MW (640499) | Broken Bow 115kV (640089) |
| GEN-2006-038N005 | 79.5 | GE 1.6MW (640428) | Broken Bow 115kV (640089) |
| GEN-2006-038N019 | 79.5 | GE 1.5MW (640431) | Petersburg 115kV (640444) |
| GEN-2006-044N | 40.5 | GE 1.5MW (645062) | Petersburg 115kV (640444) |
| GEN-2007-011N08 | 81 | Vestas V90 VCRS 3.0MW (640418) | Bloomfield 115kV (640084) |
| GEN-2008-086N02/ GEN-2014-032 | 211.22 | GE 100m 1.79MW (645063 and 645064) | Meadow Grove 230kV (GEN-2008-086N02 POI) (640540) |
| GEN-2008-119O | 60 | GE 1.5MW (645061) | S1399 161kV (646399) |
| GEN-2008-123N | 89.7 | GE 100m 1.79MW, GE 103m 1.72MW (572054) | Tap on the Pauline – Guide Rock 115kV (560137) |
| GEN-2009-040 | 73.8 | Vestas V100 VCSS 2.0MW (532904) | Marshall 115kV (533303) |
| GEN-2010-041 | 10.5 | GE 1.5MW (580071) | S1399 161kV (646399) |
| GEN-2010-051 | 200 | GE 100m 1.7MW (580014, 580017, 580020) | Tap on the Twin Church – Hoskins 230kV line (560347) |
| GEN-2011-018 (replaced by GEN-2013-008) | 73.6 | GE 100m 1.7MW (640555) | Steele County 115kV (640426) |
| GEN-2011-027 | 120 | GE 1.85MW (580022, 580021, 580023) | Tap Twin Church-Hoskins 230kV (560347) |
| GEN-2011-056 | 3.6 MW increase (Pgen=21.6MW) | GENSAL (640013) | Jeffrey 115kV (640238) |
| GEN-2011-056A | 3.6 MW increase (Pgen=21.6MW) | GENSAL (640014) | Johnson 1 115kV (640240) |
| GEN-2011-056B | 4.5 MW increase (Pgen=23.5MW) | GENSAL (640015) | Johnson 2 115kV (640242) |
| GEN-2012-021 | 4.8 MW | GENROU (650010) | 84 th & Bluff 115kV (650275) |
| GEN-2013-002 | 50.6 | Siemens 108m 2.3MW (583703) | Tap Sheldon - SW7&Bennet - Folsom/Pleasant Hill 115kV (560746) |
| GEN-2013-008 | 1.2MW increase to GEN-2011-018 (Pgen=74.8MW) | GE 100m 1.7MW (640555) | Steele City (640426) 115kV |
| GEN-2013-014 | 25.5 | GE 100m 1.7MW (583643) | Tap Pauline (640313) – Guide Rock (640206) 115kV (560137) |
| GEN-2013-019 | 73.6 | Siemens 108m 2.3MW (583703) | Tap Sheldon - SW7&Bennet - Folsom/Pleasant Hill 115kV (560746) |
| GEN-2013-032 | 204 | GE 97.4m 1.7MW (583783) | Neligh 115kV (640293) |
| GEN-2014-004 | 3.96 | GE 97.4m 1.79MW (640555) | Steele City 115kV (GEN-2011-018 POI) (640426) |
| GEN-2014-013 | 73.5 | GE XLE 97.4m (583833) | Meadow Grove 230kV (GEN-2008-086N02 POI) (640540) |
| GEN-2014-031 | 35.8 | GE 1.79MW (583836) | Meadow Grove 230kV (GEN-2008-086N02 POI) (640540) |
| GEN-2014-039 | 73.39 | GE 1.79MW (584093) | Friend 115kV (640174) |
| GEN-2015-007 | 160 | GE 2.0MW | Hoskins 345kV |
| GEN-2015-023 | 300.8 | GE 1.79MW | Holt County 345kV |




Figure 2-1. Power flow one-line diagram for interconnection project at the Antelope 115kV POI (GEN-2015-053)




Figure 2-2. Power flow one-line diagram for interconnection project at the Belden 115kV POI (GEN-2015-076)




Figure 2-3. Power flow one-line diagram for interconnection project at the Tap Fairbury – Hebron 115kV POI (GEN-2015-087)

**Table 2-3
Case List with Contingency Description**

| Cont. No. | Fault Name | Description |
|-----------|------------|--|
| 8 | FLT08-3PH | 3 phase fault on the G10-051-TAP (560347) to TWIN CH4 (640386) 230 kV line circuit 1, near G10-051-TAP. |
| | | a. Apply fault at the G10-051-TAP 230 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 9 | FLT9-3PH | 3 phase fault on the G10-051-TAP (560347) to HOSKINS4 (640227) 230 kV line circuit 1, near G10-051-TAP. |
| | | a. Apply fault at the G10-051-TAP 230 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 10 | FLT10-3PH | 3 phase fault on the TWIN CH4 (640386) 230 kV / (640387) 115 kV / (643156) 13.8 kV Transformer circuit 1, near TWIN CH4 230 kV. |
| | | a. Apply fault at the TWIN CH4 230 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted transformer. |
| | | |
| 11 | FLT11-3PH | 3 phase fault on the TWIN CH4 (640386) to SIOUXCY4 (652565) 230 kV line circuit 1, near TWIN CH4. |
| | | a. Apply fault at the TWIN CH4 230 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 12 | FLT12-3PH | 3 phase fault on the HOSKINS4 (640227) 230 kV / (640228) 115 kV / (643083) 13.8 kV Transformer circuit 1, near HOSKINS4 230 kV. |
| | | a. Apply fault at the HOSKINS4 230 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted transformer. |
| | | |
| 13 | FLT13-3PH | 3 phase fault on the HOSKINS4 (640227) 230 kV / (640226) 345 kV / (643082) 13.8 kV Transformer circuit 1, near HOSKINS4 230 kV. |
| | | a. Apply fault at the HOSKINS4 230 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted transformer. |
| | | |
| 14 | FLT14-3PH | 3 phase fault on the ANTELOPE 7 (640521) to NELIGH 7 (640293) 115 kV line circuit 1, near ANTELOPE 7. |
| | | a. Apply fault at the ANTELOPE 7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 15 | FLT15-3PH | 3 phase fault on the ANTELOPE 7 (640521) to CREITON7 (640149) 115 kV line circuit 1, near ANTELOPE 7. |
| | | a. Apply fault at the ANTELOPE 7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 16 | FLT16-3PH | 3 phase fault on the ANTELOPE 7 (640521) to CO.LINE7 (640115) 115 kV line circuit 1, near ANTELOPE 7. |
| | | a. Apply fault at the ANTELOPE 7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 17 | FLT17-3PH | 3 phase fault on the ANTELOPE 7 (640521) 115 kV / (640520) 345 kV / (640524) 13.8 kV Transformer circuit 1, near ANTELOPE 7 115 kV. |
| | | a. Apply fault at the ANTELOPE 7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted transformer. |
| | | |
| 18 | FLT18-3PH | 3 phase fault on the NELIGH 7 (640293) to CLRWATR7 (640113) 115 kV line circuit 1, near NELIGH 7. |
| | | a. Apply fault at the NELIGH 7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 19 | FLT19-3PH | 3 phase fault on the NELIGH 7 (640293) to PETERSBRG.N7 (640444) 115 kV line circuit 1, near NELIGH 7. |
| | | a. Apply fault at the NELIGH 7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| | | d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

**Table 2-3 (Continued)
Case List with Contingency Description**

| Cont. No. | Fault Name | Description |
|-----------|------------|---|
| 20 | FLT20-3P | 3 phase fault on the CREITON7 (640149) to BLMFLD 7 (640084) 115 kV line circuit 1, near CREITON7. |
| | | a. Apply fault at the CREITON7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 21 | FLT21-3PH | 3 phase fault on the ANTELOPE 3 (640520) to HOSKINS3 (640226) 345 kV line circuit 1, near ANTELOPE 3. |
| | | a. Apply fault at the ANTELOPE 3 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 22 | FLT22-3PH | 3 phase fault on the CO.LINE7 (640115) to BATTLER7 (640072) 115 kV line circuit 1, near CO.LINE7. |
| | | a. Apply fault at the CO.LINE7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 23 | FLT23-3PH | 3 phase fault on the BELDEN 7 (640080) to HOSKINS7 (640228) 115 kV line circuit 1, near BELDEN 7. |
| | | a. Apply fault at the BELDEN 7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 24 | FLT24-3PH | 3 phase fault on the BELDEN 7 (640080) to HARTGTN7 (640212) 115 kV line circuit 1, near BELDEN 7. |
| | | a. Apply fault at the BELDEN 7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 25 | FLT25-3PH | 3 phase fault on the BELDEN 7 (640080) to TWIN CH7 (640387) 115 kV line circuit 1, near BELDEN 7. |
| | | a. Apply fault at the BELDEN 7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 26 | FLT26-3PH | 3 phase fault on the TWIN CH7 (640387) to EMERSON7 (640163) 115 kV line circuit 1, near TWIN CH7. |
| | | a. Apply fault at the TWIN CH7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 27 | FLT27-3PH | 3 phase fault on the TWIN CH7 (640387) to S.SIOUXCITY7 (640424) 115 kV line circuit 1, near TWIN CH7. |
| | | a. Apply fault at the TWIN CH7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 28 | FLT28-3PH | 3 phase fault on the TWIN CH7 (640387) 115 kV / (640388) 69 kV / (643157) 13.8 kV Transformer circuit 1, near TWIN CH7 115 kV. |
| | | a. Apply fault at the TWIN CH7 115 kV bus. |
| 29 | FLT29-3PH | 3 phase fault on the HARTGTN7 (640212) to GAVINS 7 (652511) 115 kV line circuit 1, near HARTGTN7. |
| | | a. Apply fault at the HARTGTN7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 30 | FLT30-3PH | 3 phase fault on the HOSKINS7 (640228) to STNTN.N7 (640363) 115 kV line circuit 1, near HOSKINS7. |
| | | a. Apply fault at the HOSKINS7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| | | d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

Table 2-3 (Continued)
Case List with Contingency Description

| Cont. No. | Fault Name | Description |
|-----------|------------|---|
| 31 | FLT31-3PH | 3 phase fault on the HOSKINS7 (640228) to NORFOLK7 (640298) 115 kV line circuit 1, near HOSKINS7. |
| | | a. Apply fault at the HOSKINS7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 32 | FLT32-3PH | 3 phase fault on the HOSKINS7 (640228) to NORFK.N7 (640296) 115 kV line circuit 1, near HOSKINS7. |
| | | a. Apply fault at the HOSKINS7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 33 | FLT33-3PH | 3 phase fault on the HOSKINS7 (640228) 115 kV / (640229) 34.5 kV / (643086) 13.8 kV Transformer circuit 1, near HOSKINS7 115 kV. |
| | | a. Apply fault at the HOSKINS7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted transformer. |
| | | |
| 34 | FLT34-3PH | 3 phase fault on the HOSKINS7 (640228) 115 kV / (640226) 345 kV / (640231) 13.8 kV Transformer circuit 1, near HOSKINS7 115 kV. |
| | | a. Apply fault at the HOSKINS7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted transformer. |
| | | |
| 35 | FLT35-3PH | 3 phase fault on the GEN15087 (G15087) to HEBRN N7 (640218) 115 kV line circuit 1, near GEN15087. |
| | | a. Apply fault at the GEN15087 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 36 | FLT36-3PH | 3 phase fault on the GEN15087 (G15087) to FAIRBRY7 (640169) 115 kV line circuit 1, near GEN15087. |
| | | a. Apply fault at the GEN15087 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 37 | FLT37-3PH | 3 phase fault on the HEBRN N7 (640218) to HEBRON 7 (640220) 115 kV line circuit 1, near HEBRN N7. |
| | | a. Apply fault at the HEBRN N7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 38 | FLT38-3PH | 3 phase fault on the HEBRN N7 (640218) to CARLJCT7 (640105) 115 kV line circuit 1, near HEBRN N7. |
| | | a. Apply fault at the HEBRN N7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 39 | FLT39-3PH | 3 phase fault on the FAIRBRY7 (640169) to HARBINE7 (640208) 115 kV line circuit 1, near FAIRBRY7. |
| | | a. Apply fault at the FAIRBRY7 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 40 | FLT40-3PH | 3 phase fault on the GEN15088 (G15088) to MOORE 3 (640277) 345 kV line circuit 1, near GEN15088. |
| | | a. Apply fault at the GEN15088 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 41 | FLT41-3P | 3 phase fault on the GEN15088 (G15088) to PAULINE3 (640312) 345 kV line circuit 1, near GEN15088. |
| | | a. Apply fault at the GEN15088 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| | | d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

**Table 2-3 (Continued)
Case List with Contingency Description**

| Cont. No. | Fault Name | Description |
|-----------|--------------|---|
| 42 | FLT42-3PH | 3 phase fault on the MOORE 3 (640277) to NW68HOLDRG3 (650114) 345 kV line circuit 1, near MOORE 3. |
| | | a. Apply fault at the MOORE 3 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 43 | FLT43-3PH | 3 phase fault on the MOORE 3 (640277) to 103&ROKEBY3 (650189) 345 kV line circuit 1, near MOORE 3. |
| | | a. Apply fault at the MOORE 3 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 44 | FLT44-3PH | 3 phase fault on the MOORE 3 (640277) to MCCOOL 3 (640271) 345 kV line circuit 1, near MOORE 3. |
| | | a. Apply fault at the MOORE 3 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 45 | FLT45-3PH | 3 phase fault on the MOORE 3 (640277) to COOPER 3 (640139) 345 kV line circuit 1, near MOORE 3. |
| | | a. Apply fault at the MOORE 3 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 46 | FLT46-3PH | 3 phase fault on the MOORE 3 (640277) 345 kV / (640278) 115 kV / (640280) 13.8 kV Transformer circuit 1, near MOORE 3 345 kV. |
| | | a. Apply fault at the MOORE 3 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted transformer. |
| | | |
| 47 | FLT47-3PH | 3 phase fault on the PAULINE3 (640312) to AXTELL 3 (640065) 345 kV line circuit 1, near PAULINE3. |
| | | a. Apply fault at the PAULINE3 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 48 | FLT48-3PH | 3 phase fault on PAULINE3 (640312) 345 kV / (640313) 115 kV / (640315) 13.8 kV Transformer circuit 1, near PAULINE3 345 kV. |
| | | a. Apply fault at the PAULINE3 115 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted transformer. |
| | | |
| 49 | FLT49-3PH | 3 phase fault on the SIDNEY2-LNX3 (659426) to LARAMIE3 (659131) 345 kV line circuit 1, near GEN15094. |
| | | a. Apply fault at the SIDNEY2-LNX3 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 50 | FLT50-3PH | 3 phase fault on the SIDNEY2-LNX3 (659426) to SIDNEY 3 (659133) 345 kV line circuit Z, near SIDNEY2-LNX3. |
| | | a. Apply fault at the SIDNEY2-LNX3 345 kV bus. |
| | | b. Clear fault after 5 cycles and trip the faulted line and remove fault. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 51 | FLT51-3PH-PO | Prior outage on the HOSKINS4 (640227) 230 kV / (640226) 345 kV / (643082) 13.8 kV transformer; 3 phase fault on the G10-051-TAP (560347) to HOSKINS4 (640227) 230 kV line circuit 1, near G14-051-TAP. |
| | | a. Apply fault at the G14-051-TAP 230 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 52 | FLT52-3PH-PO | Prior outage on the TWIN CH4 (640386) 230 kV / (640387) 115 kV / (643156) 13.8 kV transformer; 3 phase fault on the G10-051-TAP (560347) to TWIN CH4 (640386) 230 kV line circuit 1, near G14-051-TAP. |
| | | a. Apply fault at the G14-051-TAP 230 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| | | d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

Table 2-3 (Continued)
Case List with Contingency Description

| Cont. No. | Fault Name | Description |
|-----------|--------------|---|
| 53 | FLT53-3PH-PO | Prior outage on the ANTELOPE 7 (640521) – NELIGH 7 (640293) 115 kV line circuit 1; 3 phase fault on the ANTELOPE 7 (640521) to NELIGH 7 (640293) 115 kV line circuit 2, near ANTELOPE 7. |
| | | a. Apply fault at the ANTELOPE 7 115 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 54 | FLT54-3PH-PO | Prior outage on the ANTELOPE 7 (640521) – CO.LINE7 (640115) 115 kV line; 3 phase fault on the ANTELOPE 7 (640521) to CREITON7 (640149) 115 kV line, near ANTELOPE 7. |
| | | a. Apply fault at the ANTELOPE 7 115 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 55 | FLT55-3PH-PO | Prior outage on the ANTELOPE 7 (640521) 115 kV / (640520) 345 kV / (640524) 13.8 kV transformer; 3 phase fault on the ANTELOPE 7 (640521) to CO.LINE7 (640115) 115 kV line, near ANTELOPE 7. |
| | | a. Apply fault at the ANTELOPE 7 115 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 56 | FLT56-3PH-PO | Prior outage on the BELDEN 7 (640080) – HARTGTN7 (640212) 115 kV line; 3 phase fault on the BELDEN 7 (640080) to TWIN CH7 (640387) 115 kV line, near BELDEN 7. |
| | | a. Apply fault at the BELDEN 7 115 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 57 | FLT57-3PH-PO | Prior outage on the BELDEN 7 (640080) – TWIN CH7 (640387) 115 kV line; 3 phase fault on the BELDEN 7 (640080) to HOSKINS7 (640228) 115 kV line, near BELDEN 7. |
| | | a. Apply fault at the BELDEN 7 115 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 58 | FLT58-3PH-PO | Prior outage on the HEBRN N7 (640218) – CARLJCT7 (640105) 115 kV line; 3 phase fault on the GEN15087 (G15087) to HEBRN N7 (640218) 115 kV line, near GEN15087. |
| | | a. Apply fault at the GEN15087 115 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 59 | FLT59-3PH-PO | Prior outage on the HEBRN N7 (640218) – HEBRON 7 (640220) 115 kV line; 3 phase fault on the GEN15087 (G15087) to HEBRN N7 (640218) 115 kV line, near GEN15087. |
| | | a. Apply fault at the GEN15087 115 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 60 | FLT60-3PH-PO | Prior outage on the MOORE 3 (640277) – MCCOOL 3 (640271) 345 kV line; 3 phase fault on the GEN15088 (G15088) to MOORE 3 (640277) 345 kV line, near GEN15088. |
| | | a. Apply fault at the GEN15088 345 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| 61 | FLT61-3PH-PO | Prior outage on the PAULINE3 (640312) – AXTELL 3 (640065) 345 kV line; 3 phase fault on the GEN15088 (G15088) to PAULINE3 (640312) 345 kV line, near GEN15088. |
| | | a. Apply fault at the GEN15088 345 kV bus. |
| | | b. Clear fault after 5 cycles by tripping the faulted line. |
| | | c. Wait 20 cycles, and then re-close the line in (b) back into the fault. |
| | | d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

Table 2-3 (Continued)
Case List with Contingency Description

| Cont. No. | Fault Name | Description |
|-----------|--------------|---|
| 62 | FLT62-1PH_SB | Hoskins 345 kV Stuck Breaker Scenario 1 |
| | | a. Apply single phase fault at the Hoskins (640226) 345 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip Hoskins (640226) 345 kV / (640227) 230 kV / (643082) 13.8 kV transformer circuit 1. |
| 63 | FLT63-1PH_SB | Hoskins 345 kV Stuck Breaker Scenario 2 |
| | | a. Apply single phase fault at the Hoskins (640226) 345 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip Hoskins (640226) 345 kV / (640228) 115 kV / (640231) 13.8 kV transformer circuit 1. |
| 64 | FLT64-1PH_SB | Hoskins 345 kV Stuck Breaker Scenario 3 |
| | | a. Apply single phase fault at the Hoskins (640226) 345 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip Hoskins (640226) 345 kV / (640227) 230 kV / (643082) 13.8 kV transformer circuit 1. |
| 65 | FLT65-1PH_SB | Hoskins 345 kV Stuck Breaker Scenario 4 |
| | | a. Apply single phase fault at the Hoskins (640226) 345 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip Hoskins (640226) 345 kV / (640228) 115 kV / (640231) 13.8 kV transformer circuit 1. |
| 66 | FLT66-1PH_SB | Hoskins 345 kV Stuck Breaker Scenario 5 |
| | | a. Apply single phase fault at the Hoskins (640226) 345 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip Hoskins Hoskins (640226) to Shell Creek (640342) 345 kV line circuit 1. |
| 67 | FLT67-1PH_SB | Antelope 115 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the Antelope (640521) 115 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip ANTELOPE7 (640521) to CREITON7 (640149) 115 kV line circuit 1. |
| 68 | FLT68-1PH_SB | Antelope 115 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the Antelope (640521) 115 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip ANTELOPE 7 (640521) to NELIGH 7 (640293) 115 kV line circuit 1. |
| 69 | FLT69-1PH_SB | Belden 115 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the Belden (640080) 115 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip BELDEN 7 (640080) to TWIN CH7 (640387) 115 kV line circuit 1. |
| 70 | FLT70-1PH_SB | Belden 115 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the Belden (640080) 115 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip BELDEN 7 (640080) to TWIN CH7 (640387) 115 kV line circuit 1. |
| 71 | FLT71-1PH_SB | Moore 345 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the Moore (640277) 345 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip MOORE 3 (640277) to NW68HOLDRG3 (650114) 345 kV line circuit 1. |
| 72 | FLT72-1PH_SB | Moore 345 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the Moore (640277) 345 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip MOORE 3 (640277) to 103&ROKEBY3 (650189) 345 kV line circuit 1. |
| | | d. Trip MOORE 3 (640277) to COOPER 3 (640139) 345 kV line circuit 1. |

Table 2-3 (Continued)
Case List with Contingency Description

| Cont. No. | Fault Name | Description |
|-----------|--------------|---|
| 73 | FLT73-1PH_SB | Pauline 345 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the Pauline (640312) 345 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip PAULINE3 (640312) 345 kV / (640313) 115 kV / (640315) 13.8 kV Transformer. |
| 74 | FLT74-1PH_SB | d. Trip PAULINE3 (640312) to AXTELL 3 (640065) 345 kV line circuit 1. |
| | | Sidney 345 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the Sidney (659426) 345 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| 75 | FLT75-1PH_SB | c. Trip SIDNEY2-LNX3 (659426) to GEN15094 (G15094) 345 kV line circuit 1. |
| | | d. Trip SIDNEY2-LNX3 (659426) to SIDNEY 3 (659133) 345 kV line circuit Z |
| | | OGALALA4 230 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the OGALALA4 (640302) 230 kV bus. |
| 76 | FLT76-1PH_SB | b. Wait 16 cycles and remove fault. |
| | | c. Trip OGALALA4 (640302) 230 kV / (640304) 115 kV / (643115) 13.8 kV Transformer. |
| | | d. Trip OGALALA4 (640302) to GENTLMN4 (640184) 230 kV line circuit 1. |
| | | G10-051-TAP 230 kV Stuck Breaker Scenario |
| 77 | FLT77-1PH_SB | a. Apply single phase fault at the G10-051-TAP4 (560347) 230 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip G10-051-TAP (560347) to G10-051&1127 (580011) 230 kV line circuit 1. |
| | | d. Trip G10-051-TAP (560347) to TWINCH4 (640386) 230 kV line circuit 1. |
| 78 | FLT78-1PH_SB | ANTELOPE7 115 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the ANTELOPE7 (640521) 230 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip ANTELOPE7 (640521) 115 kV to CREITON7 (640149) 115 kV line circuit 1. |
| 79 | FLT79-1PH_SB | d. Trip ANTELOPE7 (640521) 115 kV to COLINE7 (640115) 115 kV line circuit 1. |
| | | BELDEN7 115 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the BELDEN7 (640080) 115 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| 80 | FLT80-1PH_SB | c. Trip BELDEN7 (640080) 115 kV / (640081) 69 kV / (643016) 13.8 kV Transformer. |
| | | d. Trip BELDEN7 (640080) to TWINCH7 (640387) 115 kV line circuit 1. |
| | | FAIRBRY7 115 kV Stuck Breaker Scenario |
| | | a. Apply single phase fault at the FAIRBRY7 (640169) 115 kV bus. |
| 81 | FLT81-3PH | b. Wait 16 cycles and remove fault. |
| | | c. Trip FAIRBRY7 (640169) 115 kV to HARBINE7 (640208) 115 kV line circuit 1. |
| | | d. Trip FAIRBRY7 (640169) 115 kV to G15-087-TAP (560061) 115 kV line circuit 1. |
| | | G15-088-TAP 345 kV Stuck Breaker Scenario |
| 82 | FLT82-3PH | a. Apply single phase fault at the G15-088-TAP (560062) 345 kV bus. |
| | | b. Wait 16 cycles and remove fault. |
| | | c. Trip G15-088-TAP (560062) 345 kV to PAULINE3 (640312) 345 kV line circuit 1. |
| | | d. Trip G15-088-TAP (560062) 345 kV to MOORE3 (640277) 345 kV line circuit 1. |
| 83 | FLT83-3PH | 3 phase fault on the Gentleman (640183) to Sweetwater (640374) 345kV line ckt 2, near Gentleman. |
| | | a. Apply fault at the Gentleman 345kV bus. |
| 84 | FLT84-3PH | b. Clear fault after 4.5 cycles by tripping the faulted line. |
| | | 3 phase fault on the Axtell (640065) to Pauline (640312) 345kV line ckt1, near Axtell. |
| 85 | FLT85-3PH | a. Apply fault at the Axtell 345kV bus. |
| | | b. Clear fault after 4.5 cycles by tripping the faulted line. |

Table 2-3 (Continued)
Case List with Contingency Description

| Cont. No. | Fault Name | Description |
|-----------|--------------|--|
| 86 | FLT86-3PH | 3 phase fault on the Gentleman (640184) to N. Platte (640286) 230kV line ckt 1, near Gentleman. |
| | | a. Apply fault at the Gentleman 230kV bus. b. Clear fault after 5.5 cycles by tripping the faulted line. |
| 87 | FLT87-3PH | 3 phase fault on the Gentleman (640184) to Ogallala(640302) 230kV line ckt 1, near Gentleman. |
| | | a. Apply fault at the Gentleman 230kV bus. b. Clear fault after 5.5 cycles by tripping the faulted line. |
| 88 | FLT88-3PH | 3 phase fault on the Axtell (640065) 345kV to Axtell (640066) 115kV/(640067) 13.8kV transformer at the Axtell 345kVbus. |
| | | a. Apply fault at the Axtell 345kV bus. b. Clear fault after 5.5 cycles by tripping the transformer |
| 89 | FLT89-3PH | 3 phase fault on the Gentleman (640183) 345kV to Gentleman (640184) 230kV/(643066) 13.8kV CKT 2 transformer at the 345kV bus. |
| | | a. Apply fault at the Gentleman 345kV bus. b. Clear fault after 5.5 cycles by tripping the transformer |
| 90 | FLT90-3PH | 3 phase fault on the Gentleman (640183) 345kV to Gentleman (640184) 230kV/(643066) 13.8kV CKT 2 transformer at the 230kV bus. |
| | | a. Apply fault at the Gentleman 230kV bus. b. Clear fault after 5.5 cycles by tripping the transformer |
| 91 | FLT91-1PH_SB | SLG fault at the Gentleman (640183) end of the Gentleman (640183) to Sweetwater (640374) ckt2 and Gentleman (640183) to Red Willow (640325) 345kV lines. Normal clearing (4.5 cycles) |
| | | a. Apply SLG fault at Gentleman (640183) 345kV |
| | | b. Run for 4.5 cycles, remove fault |
| | | c. Trip line from Gentleman (640183) to Sweetwater (640374) ckt2 345kV. d. Trip line from Gentleman (640183) to Red Willow (640325) 345kV. |
| 92 | FLT92-1PH_SB | SLG fault at the Gentleman (640184) end of the Gentleman (640184) to N. Platte (640286) ckt2 and Gentleman (640184) to N. Platte (640286) ckt3345kV lines. Normal clearing (5.5 cycles) |
| | | a. Apply SLG fault at Gentleman (640184) 345kV |
| | | b. Run for 5.5 cycles, remove fault |
| | | c. Trip line from Gentleman (640184) to N. Platte (640286) ckt2 345kV d. Trip line from Gentleman (640184) to N. Platte (640286) ckt3 345kV |
| 93 | FLT93-1PH_SB | Gentleman Stuck Breaker 3322 |
| | | a. Apply single phase fault at the Gentleman (640183) 345kV bus on the Gentleman to Sweetwater (640374) ckt2 345kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from Gentleman (640183) to Sweetwater (640374) ckt2 345kV line. d. Trip line from Gentleman (640183) to Red Willow (640325). |
| 94 | FLT94-1PH_SB | Gentleman Stuck Breaker 3316 |
| | | a. Apply single phase fault at the Gentleman (640183) 345kV bus on the Gentleman to Keystone (640252) ckt1 345kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip the Gentleman (640183) to Keystone (640252) ckt1 345kV line d. Disconnect three winding transformer at bus 640183/640184/643066. |
| 95 | FLT95-1PH_SB | Gentleman Stuck Breaker 2216 |
| | | a. Apply single phase fault at the Gentleman (640184) 230kV bus on the Gentleman to N. Platte (640286) ckt1 230kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from Gentleman (640184) to N. Platte (640286) ckt1 230kV. d. Trip line from Gentleman (640184) to N. Platte (640286) ckt3 230kV. |
| 96 | FLT96-1PH_SB | Gentleman Stuck Breaker 2222 |
| | | a. Apply single phase fault at the Gentleman (640184) 230kV bus on the Gentleman to Ogallala (640302) ckt1 230kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip the Gentleman (640183) to Ogallala (640320) ckt1 230V line d. Disconnect three winding transformer at bus 640183/640184/643066. |

Table 2-3 (Continued)
Case List with Contingency Description

| Cont. No. | Fault Name | Description |
|-----------|---------------|---|
| 97 | FLT97-1PH_SB | Sweetwater Stuck Breaker 3308 |
| | | a. Apply single phase fault at the Sweetwater (640374) 345kV bus on the Gentleman to Sweetwater (640183) ckt1 345kV line. |
| | | b. Wait 16 cycles, remove fault. |
| | | c. Trip line from Gentleman (640183) to Sweetwater (640374) 345kV. |
| 98 | FLT98-1PH_SB | Sweetwater Stuck Breaker 3310 |
| | | a. Apply single phase fault at the Sweetwater (640374) 345kV bus on the Gentleman to Sweetwater (640183) ckt1 345kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from Gentleman (640183) to Sweetwater (640374) 345kV. |
| 99 | FLT99-1PH_SB | Keystone Stuck Breaker 3310 |
| | | a. Apply single phase fault at the Keystone (640252) 345kV bus on the Keystone to Sidney (659133) ckt1 345kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from Keystone (640252) to Sidney (659133) 345kV. |
| 100 | FLT100-1PH_SB | Keystone Stuck Breaker 3312 |
| | | a. Apply single phase fault at the Keystone (640252) 345kV bus on the Keystone to Sidney (659133) ckt1 345kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from Keystone (640252) to Sidney (659133) 345kV. |
| 101 | FLT101-1PH_SB | Keystone Stuck Breaker 3312 |
| | | a. Apply single phase fault at the Keystone (640252) 345kV bus on the Keystone to Sidney (659133) ckt1 345kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from Keystone (640252) to Sidney (659133) 345kV. |
| 102 | FLT102-1PH_SB | Keystone Stuck Breaker 3304 |
| | | a. Apply single phase fault at the Keystone (640252) 345kV bus on the Keystone to Gentleman (640183) ckt1 345kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from Keystone (640252) to Gentleman (640183) 345kV. |
| 103 | FLT103-1PH_SB | Grand Island Stuck Breaker 1396 |
| | | a. Apply single phase fault at the Grand Island (652571) 345kV bus on the Grand Island to McCool (640271) ckt1 345kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from Grand Island (652571) to McCool (640271) 345kV. |
| 104 | FLT104-1PH_SB | Grand Island Stuck Breaker 2204 |
| | | a. Apply single phase fault at the Grand Island (640200) 230kV bus on the Grand Island to Riverdale (640330) ckt1 230kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from Grand Island (640200) to Riverdale (640330) 230kV. |
| 105 | FLT105-1PH_SB | N. Platte Stuck Breaker 2204 |
| | | a. Apply single phase fault at the N. Platte (640286) 230kV bus on the N. Platte to Gentleman (640184) ckt1 230kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from N. Platte (640286) to Gentleman (640184) ckt1 230kV. |
| | | d. Disconnect three winding transformer at bus 640286/640287/640291. |

Table 2-3 (Continued)
Case List with Contingency Description

| Cont. No. | Fault Name | Description |
|-----------|---------------|---|
| 106 | FLT106-1PH_SB | N. Platte Stuck Breaker 2212 |
| | | a. Apply single phase fault at the N. Platte (640286) 230kV bus on the N. Platte to Gentleman (640184) ckt2 230kV line. |
| | | b. Run 16 cycles, remove fault. |
| | | c. Trip line from N. Platte (640286) to Gentleman (640184) ckt2 230kV. |
| 107 | FLT107-1PH_SB | d. Trip line from N. Platte (640286) to C.Creek (640093) ckt1 230kV. |
| | | Axtell Stuck Breaker 3304 |
| | | a. Apply single phase fault at the Axtell (640065) 345V bus on the Axtell to Post Rock (530583) ckt1 345kV line. |
| | | b. Run 16 cycles, remove fault. |
| 108 | FLT108-3PH | c. Trip line from Axtell (640065) to Post Rock (530583) ckt1 345kV. |
| | | d. Disconnect three winding transformer at bus 640065/640066/640067. |
| | | 3 phase fault on the Gavins (652511) to HartGtn (640212) 115kV line near Gavins. |
| 109 | FLT109-3PH | a. Apply fault at the Gavins 115kV bus. |
| | | b. Clear fault after 6 cycles by tripping the faulted line. |
| 110 | FLT110-3PH | 3 phase fault on the Gavins (652511) to Bloomfield (640084) 115kV line near Gavins. |
| | | a. Apply fault at the Gavins 115kV bus. |
| 111 | FLT111-3PH | b. Clear fault after 6 cycles by tripping the faulted line. |
| | | 3 phase fault on the Gavins (652511) to Yankton Jct (660006) 115kV line near Gavins. |
| 112 | FLT112-3PH | a. Apply fault at the Gavins 115kV bus. |
| | | b. Clear fault after 6 cycles by tripping the faulted line. |
| 113 | FLT113-3PH | 3 phase fault on the Gavins (652511) to Spirit Mound (659121) 115kV line near Gavins. |
| | | a. Apply fault at the Spirit Mound 115kV bus. |
| 114 | FLT114-3PH | b. Clear fault after 6 cycles by tripping the faulted line. |
| | | 3 phase fault on the Manning (652517) to Spirit Mound (659121) 115kV line near Spirit Mound. |
| 115 | FLT115-3PH | a. Apply fault at the Spirit Mound 115kV bus. |
| | | b. Clear fault after 6 cycles by tripping the faulted line. |
| 116 | FLT116-3PH | 3 phase fault on the Yankton Jct (660006) to Napa Jct (660026) 115kV line near Yankton. |
| | | a. Apply fault at the Yankton 115kV bus. |
| 117 | FLT117-3PH | b. Clear fault after 6 cycles by tripping the faulted line. |
| | | 3 phase fault on the Yankton Jct (660006) to Tyndall (652525) 115kV line near Yankton. |
| 118 | FLT118-3PH | a. Apply fault at the Yankton 115kV bus. |
| | | b. Clear fault after 6 cycles by tripping the faulted line. |
| 119 | FLT119-3PH | 3 phase fault on the Utica Jct (652526) to Fort Randall (652509) 230kV line near Fort Randall. |
| | | a. Apply fault at the Fort Randall 230kV bus. |
| 120 | FLT120-3PH | b. Clear fault after 6 cycles by tripping the faulted line. |
| | | 3 phase fault on the Utica Jct (652526) to Rasmussen (652536) 230kV line near Rasmussen. |
| 121 | FLT121-3PH_PO | a. Apply fault at the Rasmussen 230kV bus. |
| | | b. Clear fault after 6 cycles by tripping the faulted line. |
| 122 | FLT122-3PH | 3 phase fault on the Fort Randall (652509) to Meadow Grove (640540) 230kV line near Fort Randall. |
| | | a. Apply fault at the Fort Randall 230kV bus. |
| 123 | FLT123-3PH | b. Clear fault after 6 cycles by tripping the faulted line. |
| | | 3 phase fault on the Fort Randall (652509) to FortThompson (652507) 230kV line near Fort Randall. |
| 124 | FLT124-3PH | a. Apply fault at the Fort Randall 230kV bus. |
| | | b. Clear fault after 6 cycles by tripping the faulted line. |
| 125 | FLT125-3PH | 3 phase fault on the Holt County (#640510) to Grand Island (652871) 345kV line near Grand Island. |
| | | a. Apply fault at the Grand Island 345kV bus. |
| 126 | FLT126-3PH | b. Clear fault after 6 cycles by tripping the faulted line. |
| | | 3 phase fault on the McCool (640271) to Grand Island (652871) 345kV line near Grand Island. |
| 127 | FLT127-3PH | a. Apply fault at the Grand Island 345kV bus. |
| | | b. Clear fault after 6 cycles by tripping the faulted line. |
| 128 | FLT128-3PH_PO | Prior Outage – Gavins #1 |
| | | a. Prior outage of Gavins (652511) to Yankton Jct (660006) 115kV line |
| | | b. 3 phase fault on the Gavins (652511) to HartGtn (640212) 115kV line near Gavins. |
| | | c. Apply fault at the Gavins 115kV bus. |
| 129 | FLT129-3PH | d. Clear fault after 6 cycles by tripping the faulted line. |

Table 2-3 (Continued)
Case List with Contingency Description

| Cont. No. | Fault Name | Description |
|-----------|---------------|---|
| 122 | FLT122_3PH_PO | Prior Outage – Gavins #1 |
| | | a. Prior outage of Gins (652511) to Hartgtn (660006) 115kV line |
| | | b. 3 phase fault on the Gavins (652511) to Bloomfield (640084) 115kV line near Gavins |
| | | c. Apply fault at the Gavins 115kV bus. |
| | | d. Clear fault after 6 cycles by tripping the faulted line. |
| 123 | FLT123_1PH_SB | Stuck Breaker – Gavins #1 |
| | | a. Apply SLG fault at Gavins (652511) for 16 cycles |
| | | b. Clear fault |
| | | c. Trip Gavins (652511) to Hartgtn (660006) 115kV line |
| | | d. Trip Gavins (652511) to Bloomfield (640084) 115kV line |
| 124 | FLT124_1PH_SB | Stuck Breaker – Gavins #2 |
| | | a. Apply SLG fault at Gavins (652511) for 16 cycles |
| | | b. Clear fault |
| | | c. Trip Gavins (652511) to Hartgtn (660006) 115kV line |
| | | d. Trip Gavins (652511) to Spirit Mount (659121) 115kV line |
| 125 | FLT125_1PH_SB | Stuck Breaker – Utica Jct 230kV #1 |
| | | a. Apply SLG fault at Utica Jct 230kV(652526) for 16 cycles |
| | | b. Clear fault |
| | | c. Trip Fort Randall (652509) to Utica Jct (652526) 230kV line |
| | | d. Trip Utica Jct 230/115kV auto |
| 126 | FLT126_1PH_SB | Stuck Breaker – Utica Jct 115kV #1 |
| | | a. Apply SLG fault at Utica Jct 115kV(652626) for 16 cycles |
| | | b. Clear fault |
| | | c. Trip Utica Jct (652626) to NAPA Jct (660026) 115kV line |
| | | d. Trip Utica Jct 230/115kV auto |

SECTION 3: STABILITY ANALYSIS

The objective of the Stability Analysis was to determine the impacts of the generator interconnections on the stability and voltage recovery on the SPP transmission system. If problems with stability or voltage recovery were identified, the need for reactive compensation or system upgrades were investigated.

3.1 Approach

SPP provided MEPPi with the following three power flow cases:

- 2016 Winter Peak
- 2017 Summer Peak
- 2025 Summer Peak

Each case was examined prior to the Stability Analysis to ensure the case contained the proposed study projects and any previously queued projects listed in Tables 2-1 and 2-2 respectively. There was no suspect power flow data in the study area. The dynamic datasets were also verified and stable initial system conditions (i.e., “flat lines”) were achieved. Three-phase and single phase-to-ground faults listed in Table 2-3 were examined. Single-phase fault impedances were calculated for each season to result in a voltage of approximately 60% of the pre-fault voltage. Refer to Table 3-1 for a list of the calculated single-phase fault impedances.

**Table 3-1
Calculated Single-Phase Fault Impedances**

| ¹ Ref. No. | Cont. Name | Single-Phase Fault Impedance (MVA) | | |
|-----------------------|---------------|------------------------------------|-------------|-------------|
| | | 2016 Winter | 2017 Summer | 2025 Summer |
| 1 | FLT62-1PH_SB | -4031.3 | -4031.3 | -4031.3 |
| 2 | FLT63-1PH_SB | -4031.3 | -4031.3 | -4031.3 |
| 3 | FLT64-1PH_SB | -4031.3 | -4031.3 | -4031.3 |
| 4 | FLT65-1PH_SB | -4031.3 | -4031.3 | -4031.3 |
| 5 | FLT66-1PH_SB | -4031.3 | -4031.3 | -4031.3 |
| 6 | FLT67-1PH_SB | -1750.0 | -1750.0 | -1750.0 |
| 7 | FLT68-1PH_SB | -1750.0 | -1750.0 | -1750.0 |
| 8 | FLT69-1PH_SB | -937.5 | -937.5 | -937.5 |
| 9 | FLT70-1PH_SB | -937.5 | -937.5 | -937.5 |
| 10 | FLT71-1PH_SB | -7687.5 | -8500 | -8500.0 |
| 11 | FLT72-1PH_SB | -7687.5 | -8500 | -8500.0 |
| 12 | FLT73-1PH_SB | -3015.6 | -3015.6 | -3218.8 |
| 13 | FLT74-1PH_SB | -2101.6 | -2101.6 | -2203.1 |
| 14 | FLT75-1PH_SB | -2000.0 | -2000.0 | -2000.0 |
| 15 | FLT76-1PH_SB | -1875.0 | -1750.0 | -1875.0 |
| 16 | FLT77-1PH_SB | -1750.0 | -1750.0 | -1750.0 |
| 17 | FLT78-1PH_SB | -937.5 | -937.5 | -937.5 |
| 18 | FLT79-1PH_SB | -812.5 | -812.5 | -812.5 |
| 19 | FLT80-1PH_SB | -4234.4 | -4437.5 | -4437.5 |
| 20 | FLT91-1PH_SB | -5250.0 | -5250.0 | -5656.3 |
| 21 | FLT92-1PH_SB | -4437.5 | -4437.5 | -4843.8 |
| 22 | FLT93-1PH_SB | -5250.0 | -5250.0 | -5656.3 |
| 23 | FLT94-1PH_SB | -5250.0 | -5250.0 | -5656.3 |
| 24 | FLT95-1PH_SB | -4437.5 | -4437.5 | -4843.8 |
| 25 | FLT96-1PH_SB | -4437.5 | -4437.5 | -4843.8 |
| 26 | FLT97-1PH_SB | -3625.0 | -3625.0 | -3828.1 |
| 27 | FLT98-1PH_SB | -3625.0 | -3625.0 | -3828.1 |
| 28 | FLT99-1PH_SB | -3015.6 | -3218.8 | -3218.8 |
| 29 | FLT100-1PH_SB | -3015.6 | -3218.8 | -3218.8 |
| 30 | FLT101-1PH_SB | -3015.6 | -3218.8 | -3218.8 |
| 31 | FLT102-1PH_SB | -3015.6 | -3218.8 | -3218.8 |
| 32 | FLT103-1PH_SB | -4437.5 | -4437.5 | -4437.5 |
| 33 | FLT104-1PH_SB | -4031.3 | -4031.3 | -4031.3 |
| 34 | FLT105-1PH_SB | -3218.8 | -3218.8 | -3218.8 |
| 35 | FLT106-1PH_SB | -3218.8 | -3218.8 | -3218.8 |
| 36 | FLT107-1PH_SB | -3421.9 | -3421.9 | -3421.9 |
| 37 | FLT123-1PH_SB | -1375.0 | -1375.0 | -1375.0 |
| 38 | FLT124-1PH_SB | -1375.0 | -1375.0 | -1375.0 |
| 39 | FLT125-1PH_SB | -2000.0 | -2000.0 | -2000.0 |
| 40 | FLT126-1PH_SB | -1125.0 | -1187.5 | -1187.5 |

(1) Refer to Table 2-3 for a description of the contingency scenario

Bus voltages, machine rotor angles, and previously queued generation in the study area were monitored in addition to bus voltages and machine rotor angles in the following areas:

- 534 SUNC
- 536 WERE
- 540 GMO
- 541 KCPL
- 640 NPPD
- 645 OPPD
- 650 LES
- 652 WAPA
- 635 MEC

Requested and previously queued generation outside the above study area was also monitored.

The results of the analysis determined if reactive compensation or system upgrades were required to obtain acceptable system performance. If additional reactive compensation was required, the size, type, and location were determined. The proposed reactive reinforcements would ensure the wind or solar farm meets FERC Order 661A low voltage requirements and return the wind or solar farm to its pre-disturbance operating voltage. If the results indicated the need for fast responding reactive support, dynamic support such as an SVC or STATCOM was investigated. If tripping of the prior queued projects was observed during the stability analysis (for under/over voltage or under/over frequency) the simulations were re-ran with the prior queued project's voltage and frequency tripping disabled.

3.2 Stability Analysis Results

The Stability Analysis determined there were no contingencies that resulted in system instability or generation tripping offline for the examined seasonal peak conditions when all generation interconnection requests were at 100% output.

However, it was determined that two contingencies, FLT39-3PH, which is the loss of the Fairbry7 to Harbine7 115 kV line and FLT120-3PH, which is the loss of the McCool to Grand Island 345 kV line, resulted in post-contingency generator power swings for all seasonal peak conditions at FAIRBRYG and BROKENBG, respectively. After discussion with SPP, it was determined that this was a pre-existing issue for FLT39-3PH as it was still present in the contingency even with the GEN-2015-087 out of service. Similarly, for FLT120-3PH, it was determined that this was a pre-existing issue as it was still present in the contingency even with all four study generators out of service. Plots of the generator power observed for the two cases with and without the study generators in service are shown in Figures 3-1 and 3-2.

Refer to Table 3-2 for a summary of the Stability Analysis results for the contingencies listed in Table 2-3. Table 3-2 is a summary of the stability results for the 2016 Winter Peak, 2017 Summer Peak, and 2025 Summer Peak conditions and states whether the system remained stable or generation tripped offline and if acceptable voltage recovery was observed after the fault was cleared. Voltage recovery criteria include ensuring that the transient voltage recovers to 0.7 p.u. in 2.5 seconds after the fault is cleared and ending in a steady-state voltage (for N-1 contingencies) at the pre-contingent level or at least 0.9 p.u.

Table 3-2
Stability Analysis Summary of Results for 2016 Winter,
2017 Summer, and 2025 Summer Peak Conditions

| Ref. No. | Cont. Name | 2016 Winter Peak | | | | 2017 Summer Peak | | | | 2025 Summer Peak | | | |
|----------|--------------|---------------------------|-----------------------------|---|---------------------|---------------------------|-----------------------------|---|---------------------|---------------------------|-----------------------------|---|---------------------|
| | | Voltage Recovery | | Post Fault Steady- State Voltage | System Stability | Voltage Recovery | | Post Fault Steady- State Voltage | System Stability | Voltage Recovery | | Post Fault Steady- State Voltage | System Stability |
| | | Less than 0.70 p.u. | Greater than 1.2 p.u. | | | Less than 0.70 p.u. | Greater than 1.2 p.u. | | | Less than 0.70 p.u. | Greater than 1.2 p.u. | | |
| 1 | FLT08-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 2 | FLT09-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 3 | FLT10-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 4 | FLT11-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 5 | FLT12-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 6 | FLT13-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 7 | FLT14-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 8 | FLT15-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 9 | FLT16-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 10 | FLT17-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 11 | FLT18-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 12 | FLT19-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 13 | FLT20-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 14 | FLT21-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 15 | FLT22-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 16 | FLT23-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 17 | FLT24-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 18 | FLT25-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 19 | FLT26-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 20 | FLT27-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 21 | FLT28-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 22 | FLT29-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 23 | FLT30-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 24 | FLT31-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 25 | FLT32-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 26 | FLT33-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 27 | FLT34-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 28 | FLT35-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 29 | FLT36-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 30 | FLT37-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 31 | FLT38-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 32 | FLT39-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 33 | FLT40-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 34 | FLT41-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 35 | FLT42-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 36 | FLT43-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 37 | FLT44-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 38 | FLT45-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 39 | FLT46-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 40 | FLT47-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 41 | FLT48-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 42 | FLT49-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 43 | FLT50-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 44 | FLT51-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 45 | FLT52-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 46 | FLT53-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 47 | FLT54-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 48 | FLT55-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 49 | FLT56-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 50 | FLT57-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 51 | FLT58-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 52 | FLT59-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 53 | FLT60-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 54 | FLT61-3PH-PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 55 | FLT62-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 56 | FLT63-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 57 | FLT64-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 58 | FLT65-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 59 | FLT66-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 60 | FLT67-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 61 | FLT68-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 62 | FLT69-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 63 | FLT70-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 64 | FLT71-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 65 | FLT72-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 66 | FLT73-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 67 | FLT74-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 68 | FLT75-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 69 | FLT76-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 70 | FLT77-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |

Table 3-2 (Continued)
Stability Analysis Summary of Results for 2016 Winter,
2017 Summer, and 2025 Summer Peak Conditions

| Ref. No. | Cont. Name | 2016 Winter Peak | | | | 2017 Summer Peak | | | | 2025 Summer Peak | | | |
|----------|---------------|---------------------|-----------------------|---------------------------------|------------------|---------------------|-----------------------|---------------------------------|------------------|---------------------|-----------------------|---------------------------------|------------------|
| | | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability | Voltage Recovery | | Post Fault Steady-State Voltage | System Stability |
| | | Less than 0.70 p.u. | Greater than 1.2 p.u. | | | Less than 0.70 p.u. | Greater than 1.2 p.u. | | | Less than 0.70 p.u. | Greater than 1.2 p.u. | | |
| 71 | FLT78-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 72 | FLT79-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 73 | FLT80-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 74 | FLT81-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 75 | FLT82-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 76 | FLT83-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 77 | FLT84-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 78 | FLT85-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 79 | FLT86-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 80 | FLT87-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 81 | FLT88-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 82 | FLT89-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 83 | FLT90-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 84 | FLT91-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 85 | FLT92-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 86 | FLT93-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 87 | FLT94-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 88 | FLT95-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 89 | FLT96-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 90 | FLT97-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 91 | FLT98-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 92 | FLT99-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 93 | FLT100-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 94 | FLT101-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 95 | FLT102-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 96 | FLT103-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 97 | FLT104-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 98 | FLT105-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 99 | FLT106-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 100 | FLT107-1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 101 | FLT108-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 102 | FLT109-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 103 | FLT110-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 104 | FLT111-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 105 | FLT112-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 106 | FLT113-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 107 | FLT114-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 108 | FLT115-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 109 | FLT116-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 110 | FLT117-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 111 | FLT118-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 112 | FLT119-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 113 | FLT120-3PH | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 114 | FLT121_3PH_PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 115 | FLT122_3PH_PO | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 116 | FLT123_1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 117 | FLT124_1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 118 | FLT125_1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |
| 119 | FLT126_1PH_SB | No | No | Compliant | Stable | No | No | Compliant | Stable | No | No | Compliant | Stable |

(1) Refer to Table 2-3 for a description of the contingency scenario




Figure 3-1. Plot of the generator power output at FAIRBRYG for FLT39-3PH for 2025 Summer Peak case with and without the GEN-2015-087 online.




Figure 3-2. Plot of the generator power output at BROKENBG for FLT120-3PH for 2017 Summer Peak case with and without the four study generators online.

SECTION 4: SHORT-CIRCUIT ANALYSIS

The objective of this task is to quantify the three-phase to ground fault currents for the 2017 and 2025 Summer Peak season for each interconnecting generator.

4.1 Approach

The Short-Circuit analysis will assess breaker adequacy and fault duties for the generator interconnection bus and five buses away from the point of interconnection. MEPPI will assume no outages to find maximum short-circuit currents that flow through the breaker. The Automatic Sequencing Fault Calculation (ASCC) function in PSS/E was utilized to perform this task. FLAT conditions were applied to pre-fault conditions and the following adjustments were utilized:

- All synchronous and asynchronous machine P and Q output was set to zero
- All transformer tap ratios were set to 1.0 p.u. and all phase shift angles were set to zero
- All generator reactance's were fixed to the subtransient reactance
- All line charging was set to zero
- All shunts were set to zero
- All loads were set to zero
- All pre-fault bus voltages were set to 1.0 p.u. and a phase shift angle of zero

4.2 Short-circuit Results

The maximum fault current for each bus is provided for the 2017 and 2025 Summer Peak condition. The following tables show the Short-circuit results for the 2017 Summer Peak study generators:

- Table 4-1: Short-circuit Analysis for GEN-2015-053
- Table 4-2: Short-circuit Analysis for GEN-2015-076
- Table 4-3: Short-circuit Analysis for GEN-2015-087
- Table 4-4: Short-circuit Analysis for GEN-2015-088

Table 4-1
Short-Circuit Analysis for Study Project GEN-2015-053

| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
|------------|--------------|------------------|-------------------------|------------|----------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| 560347 | G10-051-TAP | 230 | 6.9288 | 640085 | BLMFLD 8 | 69 | 2.51 | 640343 | SHELCKR4 | 230 | 10.32 |
| 579444 | G06-044N-HV1 | 115 | 5.57 | 640113 | CLRWATR7 | 115 | 5.13 | 640347 | SPALDNG7 | 115 | 3.39 |
| 580011 | G10-051&1127 | 230 | 6.18 | 640115 | CO.LINE7 | 115 | 6.74 | 640349 | SPENCER7 | 115 | 4.56 |
| 583780 | GEN-2013-032 | 115 | 10.81 | 640125 | COLMB.E3 | 345 | 9.51 | 640357 | STANTON7 | 115 | 5.07 |
| 584510 | GEN-2015-007 | 345 | 7.06 | 640127 | COLMB.E7 | 115 | 20.71 | 640363 | STNTN.N7 | 115 | 6.83 |
| 584910 | GEN-2015-053 | 115 | 12.94 | 640133 | COLMBUS4 | 230 | 10.84 | 640377 | TEKAMAHS | 161 | 8.59 |
| 585130 | GEN-2015-076 | 115 | 3.84 | 640149 | CREITON7 | 115 | 4.76 | 640386 | TWIN CH4 | 230 | 8.33 |
| 635200 | RAUN 3 | 345 | 23.27 | 640150 | CREITON8 | 69 | 3.30 | 640387 | TWIN CH7 | 115 | 10.50 |
| 635201 | RAUN 5 | 161 | 26.95 | 640165 | EMMET 7 | 115 | 2.94 | 640444 | PETERSBRG.N7 | 115 | 6.35 |
| 635202 | NEAL 4 5 | 161 | 18.61 | 640176 | FULERTN7 | 115 | 2.58 | 640520 | ANTELOPE 3 | 345 | 5.79 |
| 635203 | NEAL N 5 | 161 | 25.47 | 640181 | GENOA 7 | 115 | 4.90 | 640521 | ANTELOPE 7 | 115 | 13.13 |
| 635220 | INTCHG 5 | 161 | 14.61 | 640212 | HARTGTN7 | 115 | 5.59 | 645451 | S3451 3 | 345 | 21.57 |
| 635230 | LIBERTY5 | 161 | 24.77 | 640213 | HARTGTN8 | 69 | 3.60 | 645454 | S3454 3 | 345 | 24.24 |
| 635368 | OBRIEN 3 | 345 | 10.65 | 640226 | HOSKINS3 | 345 | 10.33 | 645459 | S3459 3 | 345 | 21.98 |
| 635400 | HIGHLND 3 | 345 | 10.55 | 640227 | HOSKINS4 | 230 | 9.10 | 646251 | S1251 5 | 161 | 29.97 |
| 635600 | GRIMES 3 | 345 | 18.90 | 640228 | HOSKINS7 | 115 | 16.80 | 650114 | NW68HOLDRG3 | 345 | 16.21 |
| 636000 | WEBSTER3 | 345 | 9.42 | 640263 | MADISON7 | 115 | 6.06 | 652510 | FTRANDL7 | 115 | 12.71 |
| 636010 | LEHIGH 3 | 345 | 10.24 | 640293 | NELIGH 7 | 115 | 10.00 | 652511 | GAVINS 7 | 115 | 9.92 |
| 640054 | ALBION 7 | 115 | 5.34 | 640294 | NELIGH 8 | 69 | 5.91 | 652517 | MANNING7 | 115 | 5.18 |
| 640058 | ATKINSN7 | 115 | 2.64 | 640296 | NORFK.N7 | 115 | 12.46 | 652525 | TYNDALL7 | 115 | 3.83 |
| 640072 | BATTLCR7 | 115 | 6.93 | 640298 | NORFOLK7 | 115 | 11.82 | 652564 | SIUXXCY3 | 345 | 14.22 |
| 640073 | BATTLCR8 | 69 | 3.83 | 640305 | ONEILL 7 | 115 | 3.87 | 652565 | SIUXXCY4 | 230 | 18.81 |
| 640080 | BELDEN 7 | 115 | 6.67 | 640306 | ONEILL 8 | 69 | 4.19 | 652864 | SIUXXCY-LNX3 | 345 | 14.22 |
| 640081 | BELDEN 8 | 69 | 3.84 | 640318 | PETRSBG7 | 115 | 6.34 | 658100 | VERMLN 7 | 115 | 4.61 |
| 640084 | BLMFLD 7 | 115 | 6.05 | 640342 | SHELCKR3 | 345 | 9.59 | 659121 | SPIRITM7 | 115 | 6.46 |
| | | | | | | | | 660006 | YKNTJCT7 | 115 | 9.02 |
| | | | | | | | | 660026 | NAPA JCT7 | 115 | 8.39 |

Table 4-2
Short-Circuit Analysis for Study Projects GEN-2015-076

| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| 560347 | G10-051-TAP | 230 | 6.93 | 640150 | CREITON8 | 69 | 3.30 | 645459 | S3459 3 | 345 | 21.98 |
| 580011 | G10-051&1127 | 230 | 6.18 | 640151 | CRESTON7 | 115 | 5.91 | 646251 | S1251 5 | 161 | 29.97 |
| 583780 | GEN-2013-032 | 115 | 10.81 | 640163 | EMERSON7 | 115 | 5.43 | 650114 | NW68HOLDRG3 | 345 | 16.21 |
| 584510 | GEN-2015-007 | 345 | 7.06 | 640164 | EMERSONG | 69 | 3.75 | 652230 | MANNING8 | 69 | 2.78 |
| 584910 | GEN-2015-053 | 115 | 12.94 | 640212 | HARTGTN7 | 115 | 5.59 | 652286 | TYNDALL8 | 69 | 2.51 |
| 585130 | GEN-2015-076 | 115 | 3.84 | 640213 | HARTGTN8 | 69 | 3.60 | 652287 | RASMUSN8 | 69 | 3.15 |
| 635200 | RAUN 3 | 345 | 23.27 | 640226 | HOSKINS3 | 345 | 10.33 | 652463 | WH SWAN7 | 115 | 12.39 |
| 635201 | RAUN 5 | 161 | 26.95 | 640227 | HOSKINS4 | 230 | 9.10 | 652502 | BERSFRD7 | 115 | 3.91 |
| 635202 | NEAL 4 5 | 161 | 18.61 | 640228 | HOSKINS7 | 115 | 16.80 | 652507 | FTTHOMP4 | 230 | 18.52 |
| 635203 | NEAL N 5 | 161 | 25.47 | 640263 | MADISON7 | 115 | 6.06 | 652509 | FTRANDL4 | 230 | 10.63 |
| 635220 | INTCHG 5 | 161 | 14.61 | 640293 | NELIGH 7 | 115 | 10.00 | 652510 | FTRANDL7 | 115 | 12.71 |
| 635223 | PLYMOTH5 | 161 | 19.46 | 640296 | NORFK.N7 | 115 | 12.46 | 652511 | GAVINS 7 | 115 | 9.92 |
| 635230 | LIBERTY5 | 161 | 24.77 | 640298 | NORFOLK7 | 115 | 11.82 | 652516 | LAKPLAT4 | 230 | 5.51 |
| 635368 | OBRIEN 3 | 345 | 10.65 | 640300 | OAKLAND7 | 115 | 7.54 | 652517 | MANNING7 | 115 | 5.18 |
| 635400 | HIGHLND 3 | 345 | 10.55 | 640342 | SHELCRK3 | 345 | 9.59 | 652525 | TYNDALL7 | 115 | 3.83 |
| 635600 | GRIMES 3 | 345 | 18.90 | 640343 | SHELCRK4 | 230 | 10.32 | 652526 | UTICAJC4 | 230 | 7.35 |
| 636000 | WEBSTER3 | 345 | 9.42 | 640357 | STANTON7 | 115 | 5.07 | 652536 | RASMUSN4 | 230 | 6.47 |
| 636010 | LEHIGH 3 | 345 | 10.24 | 640363 | STNTN.N7 | 115 | 6.83 | 652561 | DENISON5 | 161 | 5.55 |
| 640070 | BANCRFT7 | 115 | 5.15 | 640377 | TEKAMAH5 | 161 | 8.59 | 652563 | SPENCER5 | 161 | 8.46 |
| 640072 | BATTLCR7 | 115 | 6.93 | 640378 | TEKAMAH7 | 115 | 8.06 | 652564 | SIOUXCY3 | 345 | 14.22 |
| 640073 | BATTLCR8 | 69 | 3.83 | 640386 | TWIN CH4 | 230 | 8.33 | 652565 | SIOUXCY4 | 230 | 18.81 |
| 640078 | BEEMER 7 | 115 | 4.43 | 640387 | TWIN CH7 | 115 | 10.50 | 652566 | SIOUXCY5 | 161 | 19.86 |
| 640080 | BELDEN 7 | 115 | 6.67 | 640388 | TWIN CH8 | 69 | 7.69 | 652567 | DENISON4 | 230 | 4.46 |
| 640081 | BELDEN 8 | 69 | 3.84 | 640400 | W.POINT7 | 115 | 5.07 | 652574 | SIOUXCY8 | 69 | 17.51 |
| 640084 | BLMFLD 7 | 115 | 6.05 | 640409 | WINSLOW7 | 115 | 5.19 | 652578 | PAHOJA 4 | 230 | 7.16 |
| 640085 | BLMFLD 8 | 69 | 2.51 | 640424 | S.SIOUXCITY7 | 115 | 7.24 | 652583 | DENISON8 | 69 | 11.18 |
| 640115 | CO.LINE7 | 115 | 6.74 | 640425 | S.SIOUXCITY8 | 69 | 4.47 | 652626 | UTICAJC7 | 115 | 8.75 |
| 640125 | COLMB.E3 | 345 | 9.51 | 640520 | ANTELOPE 3 | 345 | 5.79 | 652864 | SIOUXCY-LNX3 | 345 | 14.22 |
| 640127 | COLMB.E7 | 115 | 20.71 | 640521 | ANTELOPE 7 | 115 | 13.13 | 658100 | VERMLN 7 | 115 | 4.61 |
| 640133 | COLMBUS4 | 230 | 10.84 | 640540 | MEADOWGROVE4 | 230 | 5.38 | 659121 | SPIRITM7 | 115 | 6.46 |
| 640136 | COLMBUS7 | 115 | 18.51 | 645451 | S3451 3 | 345 | 21.57 | 659900 | EAGLE 4 | 230 | 7.02 |
| 640149 | CREITON7 | 115 | 4.76 | 645454 | S3454 3 | 345 | 24.24 | 659901 | EAGLE 8 | 69 | 13.48 |
| | | | | | | | | 660006 | YKNTJCT7 | 115 | 9.02 |
| | | | | | | | | 660026 | NAPA JCT7 | 115 | 8.39 |

Table 4-3
Short-Circuit Analysis for Study Projects GEN-2015-087

| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
|------------|--------------|------------------|-------------------------|------------|----------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| 533303 | MARSHAL3 | 115 | 4.49 | 640153 | CRETE__7 | 115 | 8.19 | 640272 | MCCOOL 7 | 115 | 13.78 |
| 533332 | KNOB HL3 | 115 | 4.69 | 640169 | FAIRBRY7 | 115 | 5.49 | 640273 | MCCOOL 8 | 69 | 5.44 |
| 539665 | GRNLEAF3 | 115 | 4.04 | 640174 | FRIEND 7 | 115 | 5.83 | 640278 | SHELDON7 | 115 | 31.17 |
| 560061 | G15-087-TAP | 115 | 5.37 | 640178 | GENEVA 7 | 115 | 9.56 | 640361 | STEINER7 | 115 | 4.37 |
| 560137 | G08-123N-TAP | 115 | 6.36 | 640179 | GENEVA 8 | 69 | 4.12 | 640368 | SUPEROR7 | 115 | 3.35 |
| 584090 | GEN-2014-039 | 115 | 5.83 | 640206 | GUIDE R7 | 115 | 4.32 | 640372 | SUTTON 7 | 115 | 6.24 |
| 585230 | GEN-2015-087 | 115 | 4.93 | 640207 | GUIDE R8 | 69 | 2.45 | 640373 | SUTTON 8 | 69 | 3.74 |
| 640074 | BEAT. S7 | 115 | 5.19 | 640208 | HARBINE7 | 115 | 6.97 | 640413 | YORK SW7 | 115 | 7.94 |
| 640076 | BEATRCE7 | 115 | 12.92 | 640218 | HEBRN N7 | 115 | 5.51 | 640415 | CARLJCT8 | 69 | 3.54 |
| 640088 | BPS SUB7 | 115 | 15.69 | 640220 | HEBRON 7 | 115 | 5.25 | 640426 | STEELEC7 | 115 | 5.01 |
| 640105 | CARLJCT7 | 115 | 5.37 | 640235 | HUMBOLT7 | 115 | 6.38 | 640558 | S.FLATS.PLT7 | 115 | 4.41 |
| 640111 | CLATONA7 | 115 | 10.13 | 640271 | MCCOOL 3 | 345 | 10.01 | 641087 | EGYCNTR7 | 115 | 17.68 |
| | | | | | | | | 647966 | S966 8 | 69 | 0.47 |

Table 4-4
Short-Circuit Analysis for Study Project GEN-2015-088

| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| 300039 | 7FAIRPT | 345 | 11.92 | 640119 | COL.COG7 | 115 | 18.62 | 640361 | STEINER7 | 115 | 4.37 |
| 300073 | 5GENTRY | 161 | 8.97 | 640125 | COLMB.E3 | 345 | 9.51 | 640362 | STERLING7 | 115 | 4.25 |
| 300076 | 5FAIRPT | 161 | 15.81 | 640126 | E.COL. 4 | 230 | 9.27 | 640368 | SUPEROR7 | 115 | 3.35 |
| 300087 | 5HICKCK | 161 | 5.15 | 640127 | COLMB.E7 | 115 | 20.71 | 640372 | SUTTON 7 | 115 | 6.24 |
| 300107 | 5OSBORN | 161 | 7.18 | 640131 | COLMB.W4 | 230 | 9.39 | 640374 | SWEET W3 | 345 | 9.69 |
| 300249 | 2FAIRPT | 69 | 16.33 | 640136 | COLMBUS7 | 115 | 18.51 | 640383 | TOWER 7 | 115 | 8.65 |
| 301347 | 5WINSLOW | 161 | 9.09 | 640139 | COOPER 3 | 345 | 25.03 | 640411 | YORK 7 | 115 | 7.44 |
| 530558 | KNOLL 6 | 230 | 10.66 | 640140 | COOPER 5 | 161 | 17.05 | 640413 | YORK SW7 | 115 | 7.94 |
| 530582 | S HAYS6 | 230 | 8.54 | 640141 | COOPER_ESST8 | 69 | 4.45 | 640446 | COOPER 8 | 69 | 4.55 |
| 530583 | POSTROCK7 | 345 | 7.75 | 640143 | CORNFLD8 | 69 | 1.78 | 640447 | YORK.SW T2 8 | 69 | 2.40 |
| 530584 | POSTROCK6 | 230 | 10.82 | 640153 | CRETE_7 | 115 | 8.19 | 640448 | HOLDREGE 8 | 69 | 3.68 |
| 531469 | SPERVIL7 | 345 | 12.68 | 640157 | DAVIDCY7 | 115 | 5.32 | 640510 | HOLT.CO3 | 345 | 5.65 |
| 541197 | MULLNCR7 | 345 | 7.61 | 640161 | ELMCRK_7 | 115 | 5.87 | 641085 | E7THST 7 | 115 | 17.79 |
| 541199 | ST JOE 3 | 345 | 18.75 | 640171 | FIRTH 7 | 115 | 6.06 | 641087 | EGYCNR7 | 115 | 17.68 |
| 541252 | ST JOEREA 5 | 161 | 6.26 | 640174 | FRIEND 7 | 115 | 5.83 | 641088 | HASTCTY7 | 115 | 18.85 |
| 541253 | ST JOE 5 | 161 | 19.90 | 640178 | GENEVA 7 | 115 | 9.56 | 641090 | S. 281 7 | 115 | 10.98 |
| 541257 | COOK 5 | 161 | 14.20 | 640179 | GENEVA 8 | 69 | 4.12 | 645451 | S3451 3 | 345 | 21.57 |
| 541258 | WOODBIN5 | 161 | 16.75 | 640183 | GENTLMN3 | 345 | 14.14 | 645454 | S3454 3 | 345 | 24.24 |
| 541400 | EASTOWN7 | 345 | 17.39 | 640184 | GENTLMN4 | 230 | 18.14 | 645455 | S3455 3 | 345 | 27.82 |
| 541401 | EASTOWN5 | 161 | 17.28 | 640200 | GR ISLD4 | 230 | 15.79 | 645456 | S3456 3 | 345 | 30.40 |
| 542972 | HAWTH 7 | 345 | 21.05 | 640201 | GR ISLD7 | 115 | 22.21 | 645458 | S3458 3 | 345 | 27.81 |
| 542980 | NASHUA 7 | 345 | 19.70 | 640206 | GUIDE R7 | 115 | 4.32 | 645459 | S3459 3 | 345 | 21.98 |
| 542982 | IATAN 7 | 345 | 25.79 | 640207 | GUIDE R8 | 69 | 2.45 | 645740 | S3740 3 | 345 | 17.23 |
| 543028 | NASHUA-5 | 161 | 26.59 | 640208 | HARBINE7 | 115 | 6.97 | 646206 | S1206 5 | 161 | 39.11 |
| 560009 | G14-021-TAP | 345 | 8.31 | 640214 | HASTING4 | 230 | 7.16 | 646254 | S1254 5 | 161 | 26.03 |
| 560062 | G15-088-TAP | 345 | 10.57 | 640215 | HASTING7 | 115 | 18.85 | 646263 | S1263 5 | 161 | 7.60 |
| 560137 | G08-123N-TAP | 115 | 6.36 | 640222 | HILDRTH7 | 115 | 4.20 | 646280 | S1280 5 | 161 | 9.65 |
| 560746 | G13-002-TAP | 115 | 27.85 | 640224 | HOLDREG7 | 115 | 6.12 | 647974 | S974 8 | 69 | 5.35 |
| 562334 | G13-010-TAP | 345 | 7.42 | 640226 | HOSKINS3 | 345 | 10.33 | 650114 | NW68HOLDRG3 | 345 | 16.21 |
| 572051 | GEN2008-123N | 115 | 4.85 | 640234 | HUMBOLT5 | 161 | 7.44 | 650185 | WAGENER 3 | 345 | 19.47 |
| 579470 | GEN-2008-092 | 230 | 7.87 | 640242 | JOHN.2 7 | 115 | 12.40 | 650189 | 103&ROKEBY3 | 345 | 19.42 |
| 583520 | GEN-2013-002 | 115 | 27.85 | 640248 | KEAR.NE7 | 115 | 8.95 | 650210 | NW70FAIRFD7 | 115 | 20.76 |
| 583600 | GEN-2013-01 | 345 | 7.42 | 640250 | KEARNEY7 | 115 | 11.44 | 650214 | NW68HOLDRG7 | 115 | 24.78 |
| 583700 | GEN-2013-01 | 115 | 21.66 | 640252 | KEYSTON3 | 345 | 8.05 | 650216 | SW27&F 7 | 115 | 21.44 |
| 583910 | GEN-2014-021 | 345 | 6.52 | 640261 | LOWELL 7 | 115 | 7.93 | 650218 | 3&VANDORN 7 | 115 | 21.08 |
| 584090 | GEN-2014-039 | 115 | 5.83 | 640271 | MCCOOL 3 | 345 | 10.01 | 650226 | NW12&ARBOR7 | 115 | 17.87 |
| 585240 | GEN-2015-088 | 345 | 10.18 | 640272 | MCCOOL 7 | 115 | 13.78 | 650229 | 27&PLR 7 | 115 | 19.53 |
| 635000 | CBLUFFS3 | 345 | 28.28 | 640273 | MCCOOL 8 | 69 | 5.44 | 650230 | 2&N 7 | 115 | 25.27 |
| 635017 | ATCHSNT3 | 345 | 15.01 | 640275 | MINDEN 7 | 115 | 7.02 | 650238 | 20PIONEERS7 | 115 | 26.15 |
| 635018 | ATCHSN 3 | 345 | 14.89 | 640277 | MOORE 3 | 345 | 20.73 | 650242 | FOLSM&PHIL7 | 115 | 26.10 |
| 635600 | GRIMES 3 | 345 | 18.90 | 640278 | SHELDON7 | 115 | 31.17 | 650244 | SW7&BENNET7 | 115 | 21.02 |
| 635630 | BOONVIL3 | 345 | 16.08 | 640310 | ORLEANS7 | 115 | 2.49 | 650250 | 40&ROKEBY 7 | 115 | 19.99 |
| 635631 | BOONVIL5 | 161 | 20.07 | 640312 | PAULINE3 | 345 | 7.73 | 650258 | 40&GERTIE 7 | 115 | 22.29 |
| 635635 | MADISON3 | 345 | 14.87 | 640313 | PAULINE7 | 115 | 15.97 | 650267 | 84LEIGHTON7 | 115 | 27.97 |
| 640065 | AXTELL 3 | 345 | 8.77 | 640314 | PAULINE8 | 69 | 4.70 | 650270 | 70&CALVERT7 | 115 | 25.88 |
| 640066 | AXTELL 7 | 115 | 13.82 | 640316 | PAWNEEL7 | 115 | 11.22 | 650271 | 81&OCHENEY7 | 115 | 23.26 |
| 640074 | BEAT. S7 | 115 | 5.19 | 640325 | REDWILO3 | 345 | 5.97 | 650283 | WAVERLY 7 | 115 | 20.48 |
| 640076 | BEATRCE7 | 115 | 12.92 | 640330 | RIVERDL4 | 230 | 6.91 | 650285 | WAGENER 7 | 115 | 30.48 |
| 640088 | BPS SUB7 | 115 | 15.69 | 640340 | SEWARD 7 | 115 | 7.33 | 650290 | ROKEBY 7 | 115 | 24.40 |
| 640105 | CARLJCT7 | 115 | 5.37 | 640342 | SHELCKR3 | 345 | 9.59 | 652571 | GR ISLD3 | 345 | 11.49 |
| 640111 | CLATONA7 | 115 | 10.13 | 640343 | SHELCKR4 | 230 | 10.32 | 652871 | GR ISLD-LNX3 | 345 | 11.49 |

The following tables show the Short-circuit results for the 2025 Summer Peak study generators:

- Table 4-5: Short-circuit Analysis for GEN-2015-053
- Table 4-6: Short-circuit Analysis for GEN-2015-076
- Table 4-7: Short-circuit Analysis for GEN-2015-087
- Table 4-8: Short-circuit Analysis for GEN-2015-088

Table 4-5
Short-Circuit Analysis for Study Project GEN-2015-053

| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
|------------|--------------|------------------|-------------------------|------------|----------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| 560347 | G10-051-TAP | 230 | 6.95 | 640115 | CO.LINE7 | 115 | 7.61 | 640357 | STANTON7 | 115 | 5.08 |
| 579444 | G06-044N-HV1 | 115 | 5.63 | 640125 | COLMB.E3 | 345 | 9.55 | 640363 | STNTN.N7 | 115 | 6.86 |
| 580011 | G10-051&1127 | 230 | 6.19 | 640127 | COLMB.E7 | 115 | 20.80 | 640377 | TEKAMAHS | 161 | 8.63 |
| 583780 | GEN-2013-032 | 115 | 10.97 | 640133 | COLMBUS4 | 230 | 10.87 | 640386 | TWIN CH4 | 230 | 8.37 |
| 584510 | GEN-2015-007 | 345 | 7.09 | 640149 | CREITON7 | 115 | 4.77 | 640387 | TWIN CH7 | 115 | 10.52 |
| 584910 | GEN-2015-053 | 115 | 13.18 | 640150 | CREITON8 | 69 | 4.39 | 640444 | PETERSBRG.N7 | 115 | 6.43 |
| 585130 | GEN-2015-076 | 115 | 3.84 | 640165 | EMMET 7 | 115 | 3.00 | 640461 | OAKDALEP23 7 | 115 | 8.29 |
| 635200 | RAUN 3 | 345 | 23.75 | 640176 | FULERTN7 | 115 | 2.61 | 640465 | EMMETE.TAP 7 | 115 | 3.03 |
| 635201 | RAUN 5 | 161 | 27.27 | 640181 | GENOA 7 | 115 | 4.94 | 640466 | EMMETE.P22 7 | 115 | 2.84 |
| 635202 | NEAL 4 5 | 161 | 18.76 | 640212 | HARTGTN7 | 115 | 5.60 | 640520 | ANTELOPE 3 | 345 | 5.82 |
| 635203 | NEAL N 5 | 161 | 25.76 | 640213 | HARTGTN8 | 69 | 3.60 | 640521 | ANTELOPE 7 | 115 | 13.38 |
| 635220 | INTCHG 5 | 161 | 14.71 | 640226 | HOSKINS3 | 345 | 10.37 | 645451 | S3451 3 | 345 | 22.12 |
| 635230 | LIBERTY5 | 161 | 25.04 | 640227 | HOSKINS4 | 230 | 9.13 | 645454 | S3454 3 | 345 | 24.67 |
| 635368 | OBRIEN 3 | 345 | 11.30 | 640228 | HOSKINS7 | 115 | 17.00 | 645459 | S3459 3 | 345 | 23.43 |
| 635400 | HIGHLND 3 | 345 | 11.12 | 640263 | MADISON7 | 115 | 6.08 | 646251 | S1251 5 | 161 | 30.89 |
| 635600 | GRIMES 3 | 345 | 19.45 | 640293 | NELIGH 7 | 115 | 10.12 | 650114 | NW68HOLDRG3 | 345 | 16.42 |
| 636000 | WEBSTER3 | 345 | 11.03 | 640294 | NELIGH 8 | 69 | 5.94 | 652510 | FTRANDL7 | 115 | 12.89 |
| 636010 | LEHIGH 3 | 345 | 11.34 | 640296 | NORFK.N7 | 115 | 12.70 | 652511 | GAVINS 7 | 115 | 9.93 |
| 640054 | ALBION 7 | 115 | 5.48 | 640298 | NORFOLK7 | 115 | 11.97 | 652517 | MANNING7 | 115 | 5.18 |
| 640072 | BATTLCR7 | 115 | 7.44 | 640305 | ONEILL 7 | 115 | 3.92 | 652525 | TYNDALL7 | 115 | 3.83 |
| 640073 | BATTLCR8 | 69 | 3.91 | 640306 | ONEILL 8 | 69 | 4.23 | 652564 | SIouxCY3 | 345 | 14.41 |
| 640080 | BELDEN 7 | 115 | 6.68 | 640318 | PETRSBG7 | 115 | 6.42 | 652565 | SIouxCY4 | 230 | 19.06 |
| 640081 | BELDEN 8 | 69 | 3.85 | 640342 | SHELCRK3 | 345 | 9.63 | 652864 | SIouxCY-LNX3 | 345 | 14.41 |
| 640084 | BLMFLD 7 | 115 | 6.05 | 640343 | SHELCRK4 | 230 | 10.35 | 658100 | VERMLN 7 | 115 | 4.61 |
| 640085 | BLMFLD 8 | 69 | 3.70 | 640347 | SPALDNG7 | 115 | 3.65 | 659121 | SPIRITM7 | 115 | 6.46 |
| 640113 | CLRWATR7 | 115 | 5.17 | 640349 | SPENCER7 | 115 | 4.59 | 660006 | YKNTJCT7 | 115 | 9.03 |
| | | | | | | | | 660026 | NAPA ICT7 | 115 | 8.40 |

Table 4-6
Short-Circuit Analysis for Study Projects GEN-2015-076

| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| 560347 | G10-051-TAP | 230 | 6.95 | 640151 | CRESTON7 | 115 | 5.92 | 646251 | S1251 5 | 161 | 30.89 |
| 580011 | G10-051&1127 | 230 | 6.19 | 640163 | EMERSON7 | 115 | 5.44 | 650114 | NW68HOLDRG3 | 345 | 16.42 |
| 583780 | GEN-2013-032 | 115 | 10.97 | 640164 | EMERSONG | 69 | 3.75 | 652230 | MANNING8 | 69 | 2.78 |
| 584510 | GEN-2015-007 | 345 | 7.09 | 640212 | HARTGTN7 | 115 | 5.60 | 652286 | TYNDALL8 | 69 | 2.51 |
| 584910 | GEN-2015-053 | 115 | 13.18 | 640213 | HARTGTN8 | 69 | 3.60 | 652287 | RASMUSN8 | 69 | 3.15 |
| 585130 | GEN-2015-076 | 115 | 3.84 | 640226 | HOSKINS3 | 345 | 10.37 | 652463 | WH SWAN7 | 115 | 12.55 |
| 635200 | RAUN 3 | 345 | 23.75 | 640227 | HOSKINS4 | 230 | 9.13 | 652502 | BERSFRD7 | 115 | 3.91 |
| 635201 | RAUN 5 | 161 | 27.27 | 640228 | HOSKINS7 | 115 | 17.00 | 652507 | FTTHOMP4 | 230 | 19.02 |
| 635202 | NEAL 4 5 | 161 | 18.76 | 640263 | MADISON7 | 115 | 6.08 | 652509 | FTRANDL4 | 230 | 10.67 |
| 635203 | NEAL N 5 | 161 | 25.76 | 640293 | NELIGH 7 | 115 | 10.12 | 652510 | FTRANDL7 | 115 | 12.89 |
| 635220 | INTCHG 5 | 161 | 14.71 | 640296 | NORFK.N7 | 115 | 12.70 | 652511 | GAVINS 7 | 115 | 9.93 |
| 635223 | PLYMOTH5 | 161 | 19.75 | 640298 | NORFOLK7 | 115 | 11.97 | 652516 | LAKPLAT4 | 230 | 5.52 |
| 635230 | LIBERTY5 | 161 | 25.04 | 640300 | OAKLAND7 | 115 | 7.59 | 652517 | MANNING7 | 115 | 5.18 |
| 635368 | OBRIEN 3 | 345 | 11.30 | 640342 | SHELCRK3 | 345 | 9.63 | 652525 | TYNDALL7 | 115 | 3.83 |
| 635400 | HIGHLND 3 | 345 | 11.12 | 640343 | SHELCRK4 | 230 | 10.35 | 652526 | UTICAJC4 | 230 | 7.37 |
| 635600 | GRIMES 3 | 345 | 19.45 | 640357 | STANTON7 | 115 | 5.08 | 652536 | RASMUSN4 | 230 | 6.49 |
| 636000 | WEBSTER3 | 345 | 11.03 | 640363 | STNTN.N7 | 115 | 6.86 | 652561 | DENISON5 | 161 | 5.60 |
| 636010 | LEHIGH 3 | 345 | 11.34 | 640377 | TEKAMAH5 | 161 | 8.63 | 652563 | SPENCER5 | 161 | 10.14 |
| 640070 | BANCRFT7 | 115 | 5.17 | 640378 | TEKAMAH7 | 115 | 8.07 | 652564 | SIOUXCY3 | 345 | 14.41 |
| 640072 | BATTLCR7 | 115 | 7.44 | 640386 | TWIN CH4 | 230 | 8.37 | 652565 | SIOUXCY4 | 230 | 19.06 |
| 640073 | BATTLCR8 | 69 | 3.91 | 640387 | TWIN CH7 | 115 | 10.52 | 652566 | SIOUXCY5 | 161 | 20.16 |
| 640078 | BEEMER 7 | 115 | 4.44 | 640388 | TWIN CH8 | 69 | 7.70 | 652567 | DENISON4 | 230 | 4.50 |
| 640080 | BELDEN 7 | 115 | 6.68 | 640400 | W.POINT7 | 115 | 5.08 | 652574 | SIOUXCY8 | 69 | 17.62 |
| 640081 | BELDEN 8 | 69 | 3.85 | 640409 | WINSLOW7 | 115 | 5.32 | 652578 | PAHOJA 4 | 230 | 7.24 |
| 640084 | BLMFLD 7 | 115 | 6.05 | 640424 | S.SIOUXCITY7 | 115 | 7.25 | 652583 | DENISON8 | 69 | 11.34 |
| 640085 | BLMFLD 8 | 69 | 3.70 | 640425 | S.SIOUXCITY8 | 69 | 4.47 | 652626 | UTICAJC7 | 115 | 8.76 |
| 640115 | CO.LINE7 | 115 | 7.61 | 640461 | OAKDALEP23 7 | 115 | 8.29 | 652864 | SIOUXCY-LNX3 | 345 | 14.41 |
| 640125 | COLMB.E3 | 345 | 9.55 | 640520 | ANTELOPE 3 | 345 | 5.82 | 658100 | VERMLN 7 | 115 | 4.61 |
| 640127 | COLMB.E7 | 115 | 20.80 | 640521 | ANTELOPE 7 | 115 | 13.38 | 659121 | SPIRITM7 | 115 | 6.46 |
| 640133 | COLMBUS4 | 230 | 10.87 | 640540 | MEADOWGROVE4 | 230 | 5.38 | 659900 | EAGLE 4 | 230 | 7.08 |
| 640136 | COLMBUS7 | 115 | 18.61 | 645451 | S3451 3 | 345 | 22.12 | 659901 | EAGLE 8 | 69 | 13.60 |
| 640149 | CREITON7 | 115 | 4.77 | 645454 | S3454 3 | 345 | 24.67 | 660006 | YKNTJCT7 | 115 | 9.03 |
| 640150 | CREITON8 | 69 | 4.39 | 645459 | S3459 3 | 345 | 23.43 | 660026 | NAPA JCT7 | 115 | 8.40 |

Table 4-7
Short-Circuit Analysis for Study Projects GEN-2015-087

| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
|------------|--------------|------------------|-------------------------|------------|----------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| 533303 | MARSHAL3 | 115 | 4.50 | 640153 | CRETE_7 | 115 | 8.14 | 640272 | MCCOOL 7 | 115 | 13.82 |
| 533332 | KNOB HL3 | 115 | 4.70 | 640169 | FAIRBRY7 | 115 | 5.49 | 640273 | MCCOOL 8 | 69 | 5.44 |
| 539665 | GRNLEAF3 | 115 | 4.04 | 640174 | FRIEND 7 | 115 | 5.83 | 640278 | SHELDON7 | 115 | 32.60 |
| 560061 | G15-087-TAP | 115 | 5.37 | 640178 | GENEVA 7 | 115 | 9.57 | 640361 | STEINER7 | 115 | 4.37 |
| 560137 | G08-123N-TAP | 115 | 6.37 | 640179 | GENEVA 8 | 69 | 4.12 | 640368 | SUPEROR7 | 115 | 3.35 |
| 584090 | GEN-2014-039 | 115 | 5.83 | 640206 | GUIDE R7 | 115 | 4.32 | 640372 | SUTTON 7 | 115 | 6.24 |
| 585230 | GEN-2015-087 | 115 | 4.93 | 640207 | GUIDE R8 | 69 | 2.45 | 640373 | SUTTON 8 | 69 | 3.75 |
| 640074 | BEAT. S7 | 115 | 5.20 | 640208 | HARBINE7 | 115 | 6.98 | 640413 | YORK SW7 | 115 | 7.95 |
| 640076 | BEATRCE7 | 115 | 12.97 | 640218 | HEBRN N7 | 115 | 5.51 | 640415 | CARLCT8 | 69 | 3.55 |
| 640088 | BPS SUB7 | 115 | 15.78 | 640220 | HEBRON 7 | 115 | 5.25 | 640426 | STEELEC7 | 115 | 5.01 |
| 640105 | CARLJCT7 | 115 | 5.37 | 640235 | HUMBOLT7 | 115 | 6.39 | 640558 | S.FLATS.PLT7 | 115 | 4.41 |
| 640111 | CLATONA7 | 115 | 10.20 | 640271 | MCCOOL 3 | 345 | 10.10 | 641087 | EGYCNR7 | 115 | 17.70 |
| | | | | | | | | 647966 | S966 8 | 69 | 0.47 |

Table 4-8
Short-Circuit Analysis for Study Project GEN-2015-088

| Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) | Bus Number | Bus Name | Bus Voltage (kV) | Fault Current 3-LG (kA) |
|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|------------|--------------|------------------|-------------------------|
| 300039 | 7FAIRPT | 345 | 11.83 | 640119 | COL.COG7 | 115 | 18.69 | 640343 | SHELCKR4 | 230 | 10.35 |
| 300073 | 5GENTRY | 161 | 8.98 | 640125 | COLMB.E3 | 345 | 9.55 | 640361 | STEINER7 | 115 | 4.37 |
| 300076 | 5FAIRPT | 161 | 15.78 | 640126 | E.COL. 4 | 230 | 9.29 | 640362 | STERLNG7 | 115 | 4.27 |
| 300087 | 5HICKCK | 161 | 5.15 | 640127 | COLMB.E7 | 115 | 20.80 | 640368 | SUPEROR7 | 115 | 3.35 |
| 300107 | 5OSBORN | 161 | 7.17 | 640131 | COLMB.W4 | 230 | 9.41 | 640372 | SUTTON 7 | 115 | 6.24 |
| 300249 | 2FAIRPT | 69 | 16.33 | 640136 | COLMBUS7 | 115 | 18.61 | 640374 | SWEET W3 | 345 | 9.74 |
| 301347 | 5WINSLOW | 161 | 9.09 | 640139 | COOPER 3 | 345 | 25.05 | 640383 | TOWER 7 | 115 | 8.66 |
| 530558 | KNOLL 6 | 230 | 10.71 | 640140 | COOPER 5 | 161 | 17.07 | 640411 | YORK 7 | 115 | 7.46 |
| 530582 | S HAYS6 | 230 | 8.59 | 640141 | COOPER_ESST8 | 69 | 4.45 | 640413 | YORK SW7 | 115 | 7.95 |
| 530583 | POSTROCK7 | 345 | 7.78 | 640143 | CORNFLD8 | 69 | 1.78 | 640446 | COOPER 8 | 69 | 4.55 |
| 530584 | POSTROCK6 | 230 | 10.88 | 640153 | CRETE_7 | 115 | 8.14 | 640447 | YORK.SW T2 8 | 69 | 2.41 |
| 531469 | SPERVL7 | 345 | 12.75 | 640157 | DAVIDCY7 | 115 | 5.33 | 640448 | HOLDREGE 8 | 69 | 5.46 |
| 541197 | MULLNCR7 | 345 | 7.61 | 640161 | ELMCRK_7 | 115 | 5.87 | 640500 | THEDFRD3 | 345 | 5.55 |
| 541199 | ST JOE 3 | 345 | 18.30 | 640171 | FIRTH 7 | 115 | 6.10 | 640510 | HOLT.CO3 | 345 | 7.00 |
| 541252 | ST JOEREA 5 | 161 | 6.19 | 640174 | FRIEND 7 | 115 | 5.83 | 641085 | E7THST 7 | 115 | 17.82 |
| 541253 | ST JOE 5 | 161 | 18.62 | 640178 | GENEVA 7 | 115 | 9.57 | 641087 | EGYCNTR7 | 115 | 17.70 |
| 541257 | COOK 5 | 161 | 12.95 | 640179 | GENEVA 8 | 69 | 4.12 | 641088 | HASTCTY7 | 115 | 18.88 |
| 541258 | WOODBIN5 | 161 | 15.77 | 640183 | GENTLMN3 | 345 | 15.19 | 641090 | S. 281 7 | 115 | 10.99 |
| 541400 | EASTOWN7 | 345 | 17.05 | 640184 | GENTLMN4 | 230 | 18.62 | 645451 | S3451 3 | 345 | 22.12 |
| 541401 | EASTOWN5 | 161 | 16.01 | 640200 | GR ISLD4 | 230 | 15.97 | 645454 | S3454 3 | 345 | 24.67 |
| 542972 | HAWTH 7 | 345 | 21.29 | 640201 | GR ISLD7 | 115 | 22.33 | 645455 | S3455 3 | 345 | 28.37 |
| 542980 | NASHUA 7 | 345 | 19.81 | 640206 | GUIDE R7 | 115 | 4.32 | 645456 | S3456 3 | 345 | 31.16 |
| 542982 | IATAN 7 | 345 | 27.00 | 640207 | GUIDE R8 | 69 | 2.45 | 645458 | S3458 3 | 345 | 27.98 |
| 543028 | NASHUA-5 | 161 | 26.72 | 640208 | HARBINE7 | 115 | 6.98 | 645459 | S3459 3 | 345 | 23.43 |
| 560009 | G14-021-TAP | 345 | 8.32 | 640214 | HASTING4 | 230 | 7.18 | 645740 | S3740 3 | 345 | 17.35 |
| 560062 | G15-088-TAP | 345 | 10.62 | 640215 | HASTING7 | 115 | 18.88 | 646206 | S1206 5 | 161 | 40.47 |
| 560137 | G08-123N-TAP | 115 | 6.37 | 640222 | HILDRTH7 | 115 | 4.20 | 646254 | S1254 5 | 161 | 26.37 |
| 560746 | G13-002-TAP | 115 | 28.98 | 640223 | HILDRTH8 | 69 | 3.20 | 646263 | S1263 5 | 161 | 7.61 |
| 562334 | G13-010-TAP | 345 | 7.44 | 640224 | HOLDREG7 | 115 | 6.12 | 646280 | S1280 5 | 161 | 9.67 |
| 572051 | GEN2008-123N | 115 | 4.85 | 640226 | HOSKINS3 | 345 | 10.37 | 647974 | S974 8 | 69 | 5.36 |
| 579470 | GEN-2008-092 | 230 | 7.90 | 640234 | HUMBOLT5 | 161 | 7.46 | 650114 | NW68HOLDRG3 | 345 | 16.42 |
| 583520 | GEN-2013-002 | 115 | 28.98 | 640242 | JOHN.2 7 | 115 | 12.42 | 650185 | WAGENER 3 | 345 | 19.76 |
| 583600 | GEN-2013-01 | 345 | 7.44 | 640248 | KEAR.NE7 | 115 | 8.96 | 650189 | 103&ROKEBY3 | 345 | 19.66 |
| 583700 | GEN-2013-019 | 115 | 22.33 | 640250 | KEARNEY7 | 115 | 11.45 | 650210 | NW70FAIRFD7 | 115 | 21.21 |
| 583910 | GEN-2014-021 | 345 | 6.52 | 640252 | KEYSTON3 | 345 | 8.28 | 650214 | NW68HOLDRG7 | 115 | 25.43 |
| 584090 | GEN-2014-039 | 115 | 5.83 | 640261 | LOWELL 7 | 115 | 7.93 | 650216 | SW27&F 7 | 115 | 21.97 |
| 585240 | GEN-2015-088 | 345 | 10.23 | 640271 | MCCOOL 3 | 345 | 10.10 | 650218 | 3&VANDORN 7 | 115 | 21.68 |
| 635000 | CBLUFFS3 | 345 | 28.83 | 640272 | MCCOOL 7 | 115 | 13.82 | 650226 | NW12&ARBOR7 | 115 | 18.17 |
| 635017 | ATCHSNT3 | 345 | 15.03 | 640273 | MCCOOL 8 | 69 | 5.44 | 650229 | 27&PLR 7 | 115 | 20.48 |
| 635018 | ATCHSN 3 | 345 | 14.90 | 640275 | MINDEN 7 | 115 | 7.03 | 650230 | 2&N 7 | 115 | 26.04 |
| 635600 | GRIMES 3 | 345 | 19.45 | 640277 | MOORE 3 | 345 | 21.02 | 650238 | 20PIONEERS7 | 115 | 27.21 |
| 635630 | BOONVIL3 | 345 | 16.39 | 640278 | SHELDON7 | 115 | 32.60 | 650242 | FOLSM&PHIL7 | 115 | 27.69 |
| 635631 | BOONVIL5 | 161 | 20.33 | 640310 | ORLEANS7 | 115 | 2.49 | 650244 | SW7&BENNET7 | 115 | 21.85 |
| 635635 | MADISON3 | 345 | 15.13 | 640312 | PAULINE3 | 345 | 7.75 | 650250 | 40&ROKEBY 7 | 115 | 20.80 |
| 640065 | AXTELL 3 | 345 | 8.79 | 640313 | PAULINE7 | 115 | 15.98 | 650258 | 40&GERTIE 7 | 115 | 22.97 |
| 640066 | AXTELL 7 | 115 | 13.83 | 640314 | PAULINE8 | 69 | 4.70 | 650267 | 84LEIGHTON7 | 115 | 28.67 |
| 640074 | BEAT. S7 | 115 | 5.20 | 640316 | PAWNEEL7 | 115 | 11.33 | 650270 | 70&CALVERT7 | 115 | 26.69 |
| 640076 | BEATRCE7 | 115 | 12.97 | 640325 | REDWIL03 | 345 | 6.07 | 650271 | 81&OCHENEY7 | 115 | 23.93 |
| 640088 | BPS SUB7 | 115 | 15.78 | 640330 | RIVERDL4 | 230 | 6.92 | 650283 | WAVERLY 7 | 115 | 20.77 |
| 640105 | CARLUCT7 | 115 | 5.37 | 640340 | SEWARD 7 | 115 | 7.36 | 650285 | WAGENER 7 | 115 | 31.10 |
| 640111 | CLATONA7 | 115 | 10.20 | 640342 | SHELCKR3 | 345 | 9.63 | 650290 | ROKEBY 7 | 115 | 26.20 |
| | | | | | | | | 652571 | GR ISLD3 | 345 | 11.72 |
| | | | | | | | | 652871 | GR ISLD-LNX3 | 345 | 11.72 |

SECTION 5: POWER FACTOR ANALYSIS

The objective of this task is to quantify the power factor at the high side of the collector system equivalent transformer near the point of interconnection for the wind farms during base case and system contingencies. SPP transmission planning practice requires interconnecting generation projects to maintain the power factor (pf) at the high side of the transformer near the Point of Interconnection (POI) within +/- 0.95 pf for system intact conditions and for post-contingency conditions. This is analyzed by having the wind farm maintain a prescribed voltage schedule at the point of interconnection of 1.0 p.u. voltage, or if the pre-project voltage is higher than 1.0 p.u., to maintain the pre-project voltage schedule.

The 2016 Winter Peak, 2017 Summer Peak, and 2025 Summer Peak power flows provided by SPP were examined prior to the Power Factor Analysis to ensure they contained the proposed study project modeled at 100% of the nameplate rating and any previously queued projects listed in Table 2-2. There was no suspect power flow data in the study area. The proposed study project and any previously queued projects at the same point of interconnection were turned off during the power factor analysis. The wind farm(s) were then replaced by a generator modeled at the high side bus with the same real power (MW) capability as the wind farm(s) and open limits for the reactive power set points (Mvar). The generator was set to hold the POI scheduled bus voltage. All N-1, three-phase fault contingencies from Table 2-3 were then applied and the reactive power required to maintain the bus voltage was recorded.

5.1 Approach

GEN-2015-053 and GEN-2013-032 was disabled and the generator was placed at the study project's high side of the collector system equivalent transformer. The generator was modeled with PGEN = 50 MW, QMin = -9999 Mvar, and QMax = 9999 Mvar during Summer and Winter Peak conditions. All buses and transformers connected from the study project's high side of the collector system equivalent transformer to the generators were disabled. The scheduled voltage was set to 1.0323 p.u. for the 2016 Winter Peak conditions, 1.0326 p.u. for the 2017 Summer Peak conditions, and 1.0326 p.u. for the 2025 Summer Peak conditions.

GEN-2015-076 was disabled and the generator was placed at the study project's high side of the collector system equivalent transformer. The generator was modeled with PGEN = 158.4 MW, QMin = -9999 Mvar and QMax = 9999 Mvar during Summer and Winter Peak conditions. All buses and transformers connected from the study project's high side of the collector system equivalent transformer to the generators were disabled. The scheduled voltage was set to 1.0608 p.u. for the 2016 Winter Peak conditions, 1.0521 p.u. for the 2017 Summer Peak conditions, and 1.0523 p.u. for the 2025 Summer Peak conditions.

GEN-2015-087 was disabled and the generator was placed at the study project's high side of the collector system equivalent transformer. The generator was modeled with $P_{GEN} = 66$ MW, $Q_{Min} = -9999$ Mvar and $Q_{Max} = 9999$ Mvar during Summer and Winter Peak conditions. All buses and transformers connected from the study project's high side of the collector system equivalent transformer to the generators were disabled. The scheduled voltage was set to 1.0466 p.u. for the 2016 Winter Peak conditions, 1.0309 p.u. for the 2017 Summer Peak conditions, and 1.0432 p.u. for the 2025 Summer Peak conditions.

GEN-2015-088 was disabled and the generator was placed at the study project's high side of the collector system equivalent transformer. The generator was modeled with $P_{GEN} = 300$ MW, $Q_{Min} = -9999$ Mvar and $Q_{Max} = 9999$ Mvar during Summer and Winter Peak conditions. All buses and transformers connected from the study project's high side of the collector system equivalent transformer to the generators were disabled. The scheduled voltage was set to 1.0194 p.u. for the 2016 Winter Peak conditions, 1.0170 p.u. for the 2017 Summer Peak conditions, and 1.0172 p.u. for the 2025 Summer Peak conditions.

5.2 Power Factor Analysis Results

The power factor was calculated for the 2016 Winter Peak, 2017 Summer Peak, and 2025 Summer Peak conditions. The following tables show the power factor results for the study generators:

- Table 5-1: Power Factor Analysis for GEN-2015-053
- Table 5-2: Power Factor Analysis for GEN-2015-076
- Table 5-3: Power Factor Analysis for GEN-2015-087
- Table 5-4: Power Factor Analysis for GEN-2015-088

Note that a positive Q (Mvar) output illustrates that the generator is absorbing reactive power from the system, implying a leading power factor; a negative Q (Mvar) illustrates that the generator is supplying reactive power to the system, implying a lagging power factor.

**Table 5-1
Power Factor Analysis: GEN-2015-053**

| 1Ref. No. | Cont. Name | 2016 Winter Peak | | | 2017 Summer Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|---------|-----------|------------------|---------|-----------|------------------|---------|-----------|
| | | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) |
| 0 | Base | 0.644 | Leading | 59.383972 | 0.701 | Leading | 50.843864 | 0.676 | Leading | 54.504047 |
| 1 | FLT08-3PH | 0.663 | Leading | 56.43108 | 0.720 | Leading | 48.124294 | 0.693 | Leading | 51.985405 |
| 2 | FLT09-3PH | 0.669 | Leading | 55.516563 | 0.732 | Leading | 46.509369 | 0.704 | Leading | 50.382881 |
| 3 | FLT10-3PH | 0.644 | Leading | 59.388691 | 0.701 | Leading | 50.838543 | 0.676 | Leading | 54.484791 |
| 4 | FLT11-3PH | 0.658 | Leading | 57.165348 | 0.723 | Leading | 47.767635 | 0.696 | Leading | 51.562138 |
| 5 | FLT12-3PH | 0.647 | Leading | 58.89904 | 0.706 | Leading | 50.208527 | 0.681 | Leading | 53.822674 |
| 6 | FLT13-3PH | 0.638 | Leading | 60.397232 | 0.692 | Leading | 52.090084 | 0.669 | Leading | 55.485897 |
| 7 | FLT14-3PH | 0.646 | Leading | 59.154129 | 0.707 | Leading | 50.080109 | 0.685 | Leading | 53.167034 |
| 8 | FLT15-3PH | 0.645 | Leading | 59.201973 | 0.683 | Leading | 53.469574 | 0.661 | Leading | 56.835533 |
| 9 | FLT16-3PH | 0.704 | Leading | 50.369656 | 0.747 | Leading | 44.465824 | 0.688 | Leading | 52.775795 |
| 10 | FLT17-3PH | 0.876 | Leading | 27.506765 | 0.969 | Leading | 12.839367 | 0.982 | Leading | 9.6108379 |
| 11 | FLT18-3PH | 0.660 | Leading | 56.943192 | 0.654 | Leading | 57.83189 | 0.656 | Leading | 57.56459 |
| 12 | FLT19-3PH | 0.613 | Leading | 64.374931 | 0.716 | Leading | 48.709045 | 0.675 | Leading | 54.677528 |
| 13 | FLT20-3PH | 0.615 | Leading | 64.122322 | 0.664 | Leading | 56.297218 | 0.645 | Leading | 59.215027 |
| 14 | FLT21-3PH | 0.882 | Leading | 26.730412 | 0.968 | Leading | 12.958334 | 0.982 | Leading | 9.5929813 |
| 15 | FLT22-3PH | 0.702 | Leading | 50.715794 | 0.749 | Leading | 44.186878 | 0.693 | Leading | 52.03046 |
| 16 | FLT23-3PH | 0.653 | Leading | 58.043121 | 0.706 | Leading | 50.094093 | 0.683 | Leading | 53.507553 |
| 17 | FLT24-3PH | 0.629 | Leading | 61.745434 | 0.699 | Leading | 51.165527 | 0.676 | Leading | 54.510529 |
| 18 | FLT25-3PH | 0.657 | Leading | 57.317184 | 0.716 | Leading | 48.778702 | 0.689 | Leading | 52.660721 |
| 19 | FLT26-3PH | 0.646 | Leading | 59.022884 | 0.705 | Leading | 50.272224 | 0.680 | Leading | 53.963692 |
| 20 | FLT27-3PH | 0.644 | Leading | 59.334076 | 0.702 | Leading | 50.783848 | 0.676 | Leading | 54.441662 |
| 21 | FLT28-3PH | 0.644 | Leading | 59.354717 | 0.701 | Leading | 50.813423 | 0.676 | Leading | 54.472321 |
| 22 | FLT29-3PH | 0.639 | Leading | 60.234337 | 0.710 | Leading | 49.639404 | 0.680 | Leading | 53.959339 |
| 23 | FLT30-3PH | 0.647 | Leading | 58.873177 | 0.699 | Leading | 51.135136 | 0.673 | Leading | 54.94833 |
| 24 | FLT31-3PH | 0.645 | Leading | 59.166615 | 0.704 | Leading | 50.496376 | 0.679 | Leading | 54.001587 |
| 25 | FLT32-3PH | 0.653 | Leading | 57.918571 | 0.715 | Leading | 48.916904 | 0.689 | Leading | 52.642025 |
| 26 | FLT33-3PH | 0.645 | Leading | 59.186493 | 0.702 | Leading | 50.737782 | 0.677 | Leading | 54.371834 |
| 27 | FLT34-3PH | 0.644 | Leading | 59.398716 | 0.704 | Leading | 50.435459 | 0.687 | Leading | 52.952148 |
| 28 | FLT35-3PH | 0.644 | Leading | 59.469803 | 0.701 | Leading | 50.877613 | 0.675 | Leading | 54.597675 |
| 29 | FLT36-3PH | 0.645 | Leading | 59.257145 | 0.702 | Leading | 50.777763 | 0.676 | Leading | 54.521214 |
| 30 | FLT37-3PH | 0.644 | Leading | 59.387733 | 0.701 | Leading | 50.851894 | 0.676 | Leading | 54.514069 |
| 31 | FLT38-3PH | 0.644 | Leading | 59.393574 | 0.702 | Leading | 50.759739 | 0.677 | Leading | 54.351849 |
| 32 | FLT39-3PH | 0.645 | Leading | 59.290077 | 0.702 | Leading | 50.71014 | 0.676 | Leading | 54.454361 |
| 33 | FLT40-3PH | 0.665 | Leading | 56.148094 | 0.720 | Leading | 48.216183 | 0.694 | Leading | 51.799839 |
| 34 | FLT41-3PH | 0.649 | Leading | 58.608444 | 0.703 | Leading | 50.523174 | 0.678 | Leading | 54.213249 |
| 35 | FLT42-3PH | 0.648 | Leading | 58.740955 | 0.707 | Leading | 50.069225 | 0.683 | Leading | 53.481857 |
| 36 | FLT43-3PH | 0.650 | Leading | 58.502209 | 0.706 | Leading | 50.182873 | 0.680 | Leading | 53.872444 |
| 37 | FLT44-3PH | 0.661 | Leading | 56.828297 | 0.715 | Leading | 48.941143 | 0.688 | Leading | 52.74205 |
| 38 | FLT45-3PH | 0.650 | Leading | 58.412392 | 0.706 | Leading | 50.094265 | 0.682 | Leading | 53.590565 |
| 39 | FLT46-3PH | 0.641 | Leading | 59.941586 | 0.700 | Leading | 51.065971 | 0.673 | Leading | 54.881348 |
| 40 | FLT47-3PH | 0.647 | Leading | 58.91468 | 0.704 | Leading | 50.466824 | 0.679 | Leading | 54.084049 |
| 41 | FLT48-3PH | 0.644 | Leading | 59.412594 | 0.701 | Leading | 50.823818 | 0.677 | Leading | 54.422695 |
| 42 | FLT49-3PH | 0.645 | Leading | 59.304577 | 0.703 | Leading | 50.629086 | 0.677 | Leading | 54.306458 |
| 43 | FLT50-3PH | 0.644 | Leading | 59.383972 | 0.701 | Leading | 50.843864 | 0.676 | Leading | 54.504047 |

Table 5-1 (Continued)
Power Factor Analysis: GEN-2015-053

| 1Ref. No. | Cont. Name | 2016 Winter Peak | | | 2017 Summer Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|---------|-----------|------------------|---------|-----------|------------------|---------|-----------|
| | | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) |
| 44 | FLT81-3PH | 0.648 | Leading | 58.768154 | 0.706 | Leading | 50.126392 | 0.682 | Leading | 53.582169 |
| 45 | FLT82-3PH | 0.647 | Leading | 58.91468 | 0.704 | Leading | 50.466824 | 0.679 | Leading | 54.084049 |
| 46 | FLT83-3PH | 0.646 | Leading | 59.143333 | 0.703 | Leading | 50.614304 | 0.676 | Leading | 54.435402 |
| 47 | FLT84-3PH | 0.644 | Leading | 59.383972 | 0.701 | Leading | 50.843864 | 0.676 | Leading | 54.504047 |
| 48 | FLT85-3PH | 0.652 | Leading | 58.177299 | 0.705 | Leading | 50.26685 | 0.681 | Leading | 53.815033 |
| 49 | FLT86-3PH | 0.644 | Leading | 59.445526 | 0.701 | Leading | 50.906616 | 0.676 | Leading | 54.464931 |
| 50 | FLT87-3PH | 0.644 | Leading | 59.376854 | 0.701 | Leading | 50.876587 | 0.676 | Leading | 54.461319 |
| 51 | FLT88-3PH | 0.644 | Leading | 59.465363 | 0.702 | Leading | 50.727867 | 0.676 | Leading | 54.445095 |
| 52 | FLT89-3PH | 0.645 | Leading | 59.298599 | 0.702 | Leading | 50.789326 | 0.676 | Leading | 54.474705 |
| 53 | FLT90-3PH | 0.645 | Leading | 59.298599 | 0.702 | Leading | 50.789326 | 0.676 | Leading | 54.474705 |
| 54 | FLT108-3PH | 0.639 | Leading | 60.234337 | 0.710 | Leading | 49.639404 | 0.680 | Leading | 53.959339 |
| 55 | FLT109-3PH | 0.756 | Leading | 43.29015 | 0.769 | Leading | 41.531597 | 0.740 | Leading | 45.400749 |
| 56 | FLT110-3PH | 0.697 | Leading | 51.440472 | 0.744 | Leading | 44.968761 | 0.718 | Leading | 48.429607 |
| 57 | FLT111-3PH | 0.644 | Leading | 59.406586 | 0.698 | Leading | 51.277496 | 0.674 | Leading | 54.85556 |
| 58 | FLT112-3PH | 0.668 | Leading | 55.687111 | 0.734 | Leading | 46.28516 | 0.708 | Leading | 49.908005 |
| 59 | FLT113-3PH | 0.668 | Leading | 55.67786 | 0.719 | Leading | 48.304348 | 0.692 | Leading | 52.154213 |
| 60 | FLT114-3PH | 0.645 | Leading | 59.314323 | 0.701 | Leading | 50.914646 | 0.675 | Leading | 54.591637 |
| 61 | FLT115-3PH | 0.652 | Leading | 58.211811 | 0.711 | Leading | 49.448254 | 0.687 | Leading | 52.91621 |
| 62 | FLT116-3PH | 0.655 | Leading | 57.658642 | 0.717 | Leading | 48.557007 | 0.689 | Leading | 52.663456 |
| 63 | FLT117-3PH | 0.650 | Leading | 58.401375 | 0.712 | Leading | 49.28933 | 0.686 | Leading | 53.084988 |
| 64 | FLT118-3PH | 0.642 | Leading | 59.666653 | 0.695 | Leading | 51.689766 | 0.672 | Leading | 55.056446 |
| 65 | FLT119-3PH | 0.652 | Leading | 58.128502 | 0.743 | Leading | 45.032101 | 0.710 | Leading | 49.58416 |
| 66 | FLT120-3PH | 0.644 | Leading | 59.383972 | 0.701 | Leading | 50.843864 | 0.676 | Leading | 54.504047 |

(1) Refer to Table 2-3 for a description of the contingency scenario

Study Generator GEN-2015-053

The Power Factor Analysis shows that GEN-2015-053 has a power factor range of 0.613 to 0.882 leading (absorbing) for the 2016 Winter Peak conditions, a power factor range of 0.654 to 0.969 leading (absorbing) for the 2017 Summer Peak conditions, and a power factor range of 0.645 to 0.982 leading (absorbing) for the 2025 Summer Peak conditions.

Table 5-2
Power Factor Analysis: GEN-2015-076

| 1Ref. No. | Cont. Name | 2016 Winter Peak | | | 2017 Summer Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|
| | | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) |
| 0 | Base | 0.999 | Lagging | -8.55 | 0.993 | Lagging | -19.23 | 0.993 | Lagging | -19.15 |
| 1 | FLT08-3PH | 0.990 | Lagging | -22.80 | 0.986 | Lagging | -26.57 | 0.986 | Lagging | -26.77 |
| 2 | FLT09-3PH | 0.998 | Lagging | -10.40 | 0.991 | Lagging | -21.11 | 0.991 | Lagging | -20.84 |
| 3 | FLT10-3PH | 0.997 | Lagging | -11.31 | 0.991 | Lagging | -21.17 | 0.991 | Lagging | -21.13 |
| 4 | FLT11-3PH | 0.998 | Lagging | -10.30 | 0.988 | Lagging | -24.85 | 0.987 | Lagging | -26.18 |
| 5 | FLT12-3PH | 0.998 | Lagging | -10.32 | 0.992 | Lagging | -20.46 | 0.992 | Lagging | -19.69 |
| 6 | FLT13-3PH | 0.996 | Lagging | -13.41 | 0.990 | Lagging | -22.31 | 0.990 | Lagging | -22.14 |
| 7 | FLT14-3PH | 0.999 | Lagging | -8.56 | 0.993 | Lagging | -19.37 | 0.993 | Lagging | -19.29 |
| 8 | FLT15-3PH | 0.998 | Lagging | -8.94 | 0.992 | Lagging | -19.58 | 0.993 | Lagging | -19.25 |
| 9 | FLT16-3PH | 0.999 | Lagging | -6.12 | 0.993 | Lagging | -18.62 | 0.992 | Lagging | -19.97 |
| 10 | FLT17-3PH | 0.992 | Lagging | -19.55 | 0.990 | Lagging | -22.12 | 0.992 | Lagging | -20.32 |
| 11 | FLT18-3PH | 0.998 | Lagging | -8.90 | 0.993 | Lagging | -18.43 | 0.993 | Lagging | -18.79 |
| 12 | FLT19-3PH | 0.999 | Lagging | -7.69 | 0.993 | Lagging | -19.13 | 0.993 | Lagging | -19.13 |
| 13 | FLT20-3PH | 0.998 | Lagging | -9.06 | 0.989 | Lagging | -23.44 | 0.989 | Lagging | -23.99 |
| 14 | FLT21-3PH | 0.993 | Lagging | -19.50 | 0.988 | Lagging | -24.51 | 0.990 | Lagging | -22.70 |
| 15 | FLT22-3PH | 0.999 | Lagging | -6.24 | 0.994 | Lagging | -17.99 | 0.993 | Lagging | -19.32 |
| 16 | FLT23-3PH | 1.000 | Lagging | -4.89 | 0.989 | Lagging | -24.00 | 0.990 | Lagging | -23.12 |
| 17 | FLT24-3PH | 0.975 | Leading | 36.29 | 0.998 | Leading | 10.48 | 0.998 | Leading | 10.12 |
| 18 | FLT25-3PH | 0.999 | Leading | 6.59 | 0.994 | Lagging | -17.66 | 0.994 | Lagging | -17.75 |
| 19 | FLT26-3PH | 0.998 | Lagging | -8.71 | 0.993 | Lagging | -19.10 | 0.993 | Lagging | -18.96 |
| 20 | FLT27-3PH | 0.998 | Lagging | -9.05 | 0.992 | Lagging | -19.58 | 0.993 | Lagging | -19.50 |
| 21 | FLT28-3PH | 0.998 | Lagging | -8.84 | 0.993 | Lagging | -19.40 | 0.993 | Lagging | -19.33 |
| 22 | FLT29-3PH | 0.996 | Leading | 14.30 | 0.997 | Lagging | -12.39 | 0.996 | Lagging | -13.46 |
| 23 | FLT30-3PH | 0.998 | Lagging | -10.57 | 0.992 | Lagging | -20.03 | 0.992 | Lagging | -20.06 |
| 24 | FLT31-3PH | 0.999 | Lagging | -8.36 | 0.993 | Lagging | -19.26 | 0.993 | Lagging | -19.18 |
| 25 | FLT32-3PH | 0.999 | Lagging | -7.80 | 0.993 | Lagging | -18.89 | 0.993 | Lagging | -18.90 |
| 26 | FLT33-3PH | 0.998 | Lagging | -8.97 | 0.993 | Lagging | -19.37 | 0.993 | Lagging | -19.32 |
| 27 | FLT34-3PH | 0.994 | Lagging | -16.90 | 0.987 | Lagging | -25.33 | 0.988 | Lagging | -24.72 |
| 28 | FLT35-3PH | 0.999 | Lagging | -8.60 | 0.993 | Lagging | -19.20 | 0.993 | Lagging | -19.09 |
| 29 | FLT36-3PH | 0.999 | Lagging | -8.60 | 0.993 | Lagging | -19.27 | 0.993 | Lagging | -19.14 |
| 30 | FLT37-3PH | 0.999 | Lagging | -8.55 | 0.993 | Lagging | -19.22 | 0.993 | Lagging | -19.14 |
| 31 | FLT38-3PH | 0.999 | Lagging | -8.60 | 0.993 | Lagging | -19.26 | 0.993 | Lagging | -19.22 |
| 32 | FLT39-3PH | 0.999 | Lagging | -8.58 | 0.993 | Lagging | -19.30 | 0.993 | Lagging | -19.17 |
| 33 | FLT40-3PH | 0.997 | Lagging | -12.07 | 0.992 | Lagging | -20.56 | 0.992 | Lagging | -20.33 |
| 34 | FLT41-3PH | 0.998 | Lagging | -9.28 | 0.993 | Lagging | -19.37 | 0.993 | Lagging | -19.26 |
| 35 | FLT42-3PH | 0.998 | Lagging | -9.12 | 0.993 | Lagging | -19.50 | 0.992 | Lagging | -19.52 |
| 36 | FLT43-3PH | 0.998 | Lagging | -9.46 | 0.992 | Lagging | -19.66 | 0.992 | Lagging | -19.52 |
| 37 | FLT44-3PH | 0.998 | Lagging | -10.58 | 0.992 | Lagging | -20.26 | 0.992 | Lagging | -19.92 |
| 38 | FLT45-3PH | 0.998 | Lagging | -9.07 | 0.992 | Lagging | -19.79 | 0.992 | Lagging | -19.73 |
| 39 | FLT46-3PH | 0.999 | Lagging | -7.96 | 0.993 | Lagging | -19.09 | 0.993 | Lagging | -18.92 |
| 40 | FLT47-3PH | 0.998 | Lagging | -8.98 | 0.993 | Lagging | -19.42 | 0.993 | Lagging | -19.35 |
| 41 | FLT48-3PH | 0.999 | Lagging | -8.48 | 0.993 | Lagging | -19.22 | 0.993 | Lagging | -19.17 |
| 42 | FLT49-3PH | 0.999 | Lagging | -8.64 | 0.993 | Lagging | -19.34 | 0.993 | Lagging | -19.24 |
| 43 | FLT50-3PH | 0.999 | Lagging | -8.55 | 0.993 | Lagging | -19.23 | 0.993 | Lagging | -19.15 |

Table 5-2 (Continued)
Power Factor Analysis: GEN-2015-076

| 1Ref. No. | Cont. Name | 2016 Winter Peak | | | 2017 Summer Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|
| | | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) |
| 44 | FLT81-3PH | 0.998 | Lagging | -9.09 | 0.993 | Lagging | -19.50 | 0.993 | Lagging | -19.46 |
| 45 | FLT82-3PH | 0.998 | Lagging | -8.98 | 0.993 | Lagging | -19.42 | 0.993 | Lagging | -19.35 |
| 46 | FLT83-3PH | 0.999 | Lagging | -8.66 | 0.993 | Lagging | -19.34 | 0.993 | Lagging | -19.19 |
| 47 | FLT84-3PH | 0.999 | Lagging | -8.55 | 0.993 | Lagging | -19.23 | 0.993 | Lagging | -19.15 |
| 48 | FLT85-3PH | 0.999 | Lagging | -7.89 | 0.992 | Lagging | -19.72 | 0.992 | Lagging | -19.58 |
| 49 | FLT86-3PH | 0.999 | Lagging | -8.54 | 0.993 | Lagging | -19.20 | 0.993 | Lagging | -19.16 |
| 50 | FLT87-3PH | 0.999 | Lagging | -8.55 | 0.993 | Lagging | -19.21 | 0.993 | Lagging | -19.16 |
| 51 | FLT88-3PH | 0.999 | Lagging | -8.54 | 0.993 | Lagging | -19.24 | 0.993 | Lagging | -19.16 |
| 52 | FLT89-3PH | 0.999 | Lagging | -8.58 | 0.993 | Lagging | -19.25 | 0.993 | Lagging | -19.16 |
| 53 | FLT90-3PH | 0.999 | Lagging | -8.58 | 0.993 | Lagging | -19.25 | 0.993 | Lagging | -19.16 |
| 54 | FLT108-3PH | 0.996 | Leading | 14.30 | 0.997 | Lagging | -12.39 | 0.996 | Lagging | -13.46 |
| 55 | FLT109-3PH | 0.997 | Lagging | -11.96 | 0.993 | Lagging | -19.49 | 0.993 | Lagging | -19.51 |
| 56 | FLT110-3PH | 0.988 | Lagging | -24.56 | 0.985 | Lagging | -28.01 | 0.985 | Lagging | -27.54 |
| 57 | FLT111-3PH | 0.999 | Lagging | -8.56 | 0.993 | Lagging | -18.74 | 0.993 | Lagging | -18.79 |
| 58 | FLT112-3PH | 0.996 | Lagging | -14.26 | 0.987 | Lagging | -26.23 | 0.987 | Lagging | -26.25 |
| 59 | FLT113-3PH | 0.996 | Lagging | -14.40 | 0.990 | Lagging | -22.47 | 0.991 | Lagging | -21.88 |
| 60 | FLT114-3PH | 0.999 | Lagging | -8.68 | 0.993 | Lagging | -19.06 | 0.993 | Lagging | -18.98 |
| 61 | FLT115-3PH | 0.998 | Lagging | -9.46 | 0.993 | Lagging | -19.10 | 0.992 | Lagging | -19.83 |
| 62 | FLT116-3PH | 0.998 | Lagging | -10.74 | 0.991 | Lagging | -21.42 | 0.992 | Lagging | -20.73 |
| 63 | FLT117-3PH | 0.998 | Lagging | -9.63 | 0.992 | Lagging | -20.06 | 0.992 | Lagging | -19.87 |
| 64 | FLT118-3PH | 0.999 | Lagging | -8.36 | 0.993 | Lagging | -18.67 | 0.993 | Lagging | -18.76 |
| 65 | FLT119-3PH | 0.998 | Lagging | -9.73 | 0.989 | Lagging | -23.54 | 0.991 | Lagging | -21.32 |
| 66 | FLT120-3PH | 0.999 | Lagging | -8.55 | 0.993 | Lagging | -19.23 | 0.993 | Lagging | -19.15 |

(1) Refer to Table 2-3 for a description of the contingency scenario

Study Generator GEN-2015-076

The Power Factor Analysis shows that GEN-2015-076 has a power factor range of 0.975 leading (absorbing) to 1.00 (unity) for the 2016 Winter Peak conditions, a power factor range of 0.985 lagging (supplying) to 0.998 leading (absorbing) for the 2017 Summer Peak conditions, and a power factor range of 0.985 lagging (supplying) to 0.998 leading (absorbing) for the 2025 Summer Peak conditions.

**Table 5-3
Power Factor Analysis: GEN-2015-087**

| 1Ref. No. | Cont. Name | 2016 Winter Peak | | | 2017 Summer Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|
| | | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) |
| 0 | Base | 0.995 | Leading | 6.62 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |
| 1 | FLT08-3PH | 0.995 | Leading | 6.50 | 0.995 | Leading | 6.94 | 0.996 | Leading | 6.25 |
| 2 | FLT09-3PH | 0.995 | Leading | 6.54 | 0.995 | Leading | 6.87 | 0.996 | Leading | 6.21 |
| 3 | FLT10-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |
| 4 | FLT11-3PH | 0.995 | Leading | 6.57 | 0.995 | Leading | 6.93 | 0.996 | Leading | 6.24 |
| 5 | FLT12-3PH | 0.995 | Leading | 6.61 | 0.994 | Leading | 6.98 | 0.995 | Leading | 6.29 |
| 6 | FLT13-3PH | 0.995 | Leading | 6.68 | 0.994 | Leading | 7.06 | 0.995 | Leading | 6.37 |
| 7 | FLT14-3PH | 0.995 | Leading | 6.61 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.31 |
| 8 | FLT15-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 7.00 | 0.995 | Leading | 6.31 |
| 9 | FLT16-3PH | 0.995 | Leading | 6.51 | 0.995 | Leading | 6.91 | 0.996 | Leading | 6.22 |
| 10 | FLT17-3PH | 0.996 | Leading | 6.12 | 0.995 | Leading | 6.83 | 0.996 | Leading | 6.20 |
| 11 | FLT18-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 7.10 | 0.995 | Leading | 6.34 |
| 12 | FLT19-3PH | 0.995 | Leading | 6.49 | 0.994 | Leading | 7.14 | 0.996 | Leading | 6.26 |
| 13 | FLT20-3PH | 0.995 | Leading | 6.63 | 0.994 | Leading | 6.96 | 0.996 | Leading | 6.27 |
| 14 | FLT21-3PH | 0.996 | Leading | 5.96 | 0.995 | Leading | 6.69 | 0.996 | Leading | 6.06 |
| 15 | FLT22-3PH | 0.995 | Leading | 6.51 | 0.995 | Leading | 6.92 | 0.996 | Leading | 6.24 |
| 16 | FLT23-3PH | 0.995 | Leading | 6.57 | 0.995 | Leading | 6.94 | 0.996 | Leading | 6.26 |
| 17 | FLT24-3PH | 0.995 | Leading | 6.71 | 0.994 | Leading | 7.05 | 0.995 | Leading | 6.37 |
| 18 | FLT25-3PH | 0.995 | Leading | 6.56 | 0.995 | Leading | 6.93 | 0.996 | Leading | 6.26 |
| 19 | FLT26-3PH | 0.995 | Leading | 6.57 | 0.995 | Leading | 6.93 | 0.996 | Leading | 6.25 |
| 20 | FLT27-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |
| 21 | FLT28-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |
| 22 | FLT29-3PH | 0.995 | Leading | 6.64 | 0.994 | Leading | 6.96 | 0.995 | Leading | 6.29 |
| 23 | FLT30-3PH | 0.995 | Leading | 6.58 | 0.994 | Leading | 6.97 | 0.995 | Leading | 6.29 |
| 24 | FLT31-3PH | 0.995 | Leading | 6.60 | 0.994 | Leading | 6.96 | 0.996 | Leading | 6.28 |
| 25 | FLT32-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 6.98 | 0.995 | Leading | 6.30 |
| 26 | FLT33-3PH | 0.995 | Leading | 6.61 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |
| 27 | FLT34-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |
| 28 | FLT35-3PH | 0.981 | Leading | 13.22 | 0.976 | Leading | 14.74 | 0.993 | Leading | 8.10 |
| 29 | FLT36-3PH | 0.989 | Leading | 9.97 | 0.989 | Leading | 9.97 | 0.969 | Leading | 16.73 |
| 30 | FLT37-3PH | 0.994 | Leading | 7.06 | 0.999 | Leading | 2.94 | 0.997 | Leading | 5.41 |
| 31 | FLT38-3PH | 0.978 | Leading | 14.08 | 0.955 | Leading | 20.46 | 0.917 | Leading | 28.80 |
| 32 | FLT39-3PH | 0.997 | Leading | 5.53 | 0.996 | Lagging | -6.00 | 1.000 | Lagging | -0.46 |
| 33 | FLT40-3PH | 1.000 | Lagging | -2.06 | 1.000 | Leading | 0.28 | 1.000 | Leading | 0.31 |
| 34 | FLT41-3PH | 0.997 | Leading | 4.72 | 0.997 | Leading | 5.40 | 0.997 | Leading | 4.89 |
| 35 | FLT42-3PH | 0.995 | Leading | 6.33 | 0.995 | Leading | 6.78 | 0.996 | Leading | 6.20 |
| 36 | FLT43-3PH | 0.996 | Leading | 5.66 | 0.996 | Leading | 6.09 | 0.996 | Leading | 5.54 |
| 37 | FLT44-3PH | 0.996 | Leading | 5.57 | 0.996 | Leading | 5.76 | 0.996 | Leading | 5.96 |
| 38 | FLT45-3PH | 0.997 | Leading | 5.50 | 0.996 | Leading | 6.04 | 0.997 | Leading | 5.18 |
| 39 | FLT46-3PH | 0.995 | Leading | 6.85 | 0.994 | Leading | 7.04 | 0.996 | Leading | 6.23 |
| 40 | FLT47-3PH | 0.997 | Leading | 5.30 | 0.996 | Leading | 6.25 | 0.997 | Leading | 5.25 |
| 41 | FLT48-3PH | 0.999 | Leading | 2.88 | 0.998 | Leading | 3.84 | 0.999 | Leading | 2.86 |
| 42 | FLT49-3PH | 0.995 | Leading | 6.60 | 0.995 | Leading | 6.92 | 0.996 | Leading | 6.20 |
| 43 | FLT50-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |

Table 5-3 (Continued)
Power Factor Analysis: GEN-2015-087

| 1 Ref. No. | Cont. Name | 2016 Winter Peak | | | 2017 Summer Peak | | | 2025 Summer Peak | | |
|------------|------------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|
| | | Power Factor | Leading | Q (MVAR) | Power Factor | Leading | Q (MVAR) | Power Factor | Leading | Q (MVAR) |
| 44 | FLT81-3PH | 0.996 | Leading | 5.97 | 0.996 | Leading | 6.25 | 0.996 | Leading | 5.56 |
| 45 | FLT82-3PH | 0.997 | Leading | 5.30 | 0.996 | Leading | 6.25 | 0.997 | Leading | 5.25 |
| 46 | FLT83-3PH | 0.995 | Leading | 6.91 | 0.994 | Leading | 7.29 | 0.995 | Leading | 6.49 |
| 47 | FLT84-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |
| 48 | FLT85-3PH | 0.997 | Leading | 5.03 | 0.995 | Leading | 6.44 | 0.996 | Leading | 5.80 |
| 49 | FLT86-3PH | 0.995 | Leading | 6.59 | 0.994 | Leading | 7.00 | 0.996 | Leading | 6.23 |
| 50 | FLT87-3PH | 0.995 | Leading | 6.60 | 0.994 | Leading | 7.02 | 0.996 | Leading | 6.25 |
| 51 | FLT88-3PH | 0.995 | Leading | 6.66 | 0.995 | Leading | 6.81 | 0.996 | Leading | 6.03 |
| 52 | FLT89-3PH | 0.995 | Leading | 6.57 | 0.994 | Leading | 6.97 | 0.996 | Leading | 6.28 |
| 53 | FLT90-3PH | 0.995 | Leading | 6.57 | 0.994 | Leading | 6.97 | 0.996 | Leading | 6.28 |
| 54 | FLT108-3PH | 0.995 | Leading | 6.64 | 0.994 | Leading | 6.96 | 0.995 | Leading | 6.29 |
| 55 | FLT109-3PH | 0.995 | Leading | 6.50 | 0.995 | Leading | 6.93 | 0.996 | Leading | 6.25 |
| 56 | FLT110-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 7.02 | 0.995 | Leading | 6.32 |
| 57 | FLT111-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 7.00 | 0.995 | Leading | 6.31 |
| 58 | FLT112-3PH | 0.995 | Leading | 6.57 | 0.995 | Leading | 6.93 | 0.996 | Leading | 6.24 |
| 59 | FLT113-3PH | 0.995 | Leading | 6.61 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |
| 60 | FLT114-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |
| 61 | FLT115-3PH | 0.996 | Leading | 6.28 | 0.995 | Leading | 6.59 | 0.996 | Leading | 5.97 |
| 62 | FLT116-3PH | 0.995 | Leading | 6.45 | 0.995 | Leading | 6.77 | 0.996 | Leading | 6.15 |
| 63 | FLT117-3PH | 0.995 | Leading | 6.36 | 0.995 | Leading | 6.77 | 0.996 | Leading | 6.10 |
| 64 | FLT118-3PH | 0.995 | Leading | 6.57 | 0.995 | Leading | 6.83 | 0.996 | Leading | 6.21 |
| 65 | FLT119-3PH | 0.993 | Leading | 7.75 | 0.995 | Leading | 6.75 | 0.998 | Leading | 4.17 |
| 66 | FLT120-3PH | 0.995 | Leading | 6.62 | 0.994 | Leading | 6.99 | 0.995 | Leading | 6.30 |

(1) Refer to Table 2-3 for a description of the contingency scenario

Study Generator GEN-2015-087

The Power Factor Analysis shows that GEN-2015-087 has a power factor range of 0.978 leading (absorbing) to 1.00 (unity) for the 2016 Winter Peak conditions, a power factor range of 0.955 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, and a power factor range of 0.917 leading (absorbing) to 1.00 (unity) for the 2025 Summer Peak conditions.

**Table 5-4
Power Factor Analysis: GEN-2015-088**

| 1Ref. No. | Cont. Name | 2016 Winter Peak | | | 2017 Summer Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|
| | | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) |
| 0 | Base | 0.984 | Leading | 53.87 | 0.984 | Leading | 54.32 | 0.984 | Leading | 54.32 |
| 1 | FLT08-3PH | 0.986 | Leading | 51.01 | 0.985 | Leading | 52.16 | 0.985 | Leading | 52.40 |
| 2 | FLT09-3PH | 0.985 | Leading | 53.22 | 0.985 | Leading | 53.37 | 0.984 | Leading | 53.60 |
| 3 | FLT10-3PH | 0.984 | Leading | 53.83 | 0.984 | Leading | 54.26 | 0.984 | Leading | 54.25 |
| 4 | FLT11-3PH | 0.985 | Leading | 52.45 | 0.985 | Leading | 52.82 | 0.985 | Leading | 52.99 |
| 5 | FLT12-3PH | 0.984 | Leading | 53.77 | 0.984 | Leading | 54.14 | 0.984 | Leading | 54.18 |
| 6 | FLT13-3PH | 0.984 | Leading | 54.64 | 0.983 | Leading | 55.27 | 0.983 | Leading | 55.27 |
| 7 | FLT14-3PH | 0.984 | Leading | 53.81 | 0.984 | Leading | 54.27 | 0.984 | Leading | 54.35 |
| 8 | FLT15-3PH | 0.984 | Leading | 53.88 | 0.984 | Leading | 54.47 | 0.984 | Leading | 54.45 |
| 9 | FLT16-3PH | 0.985 | Leading | 52.54 | 0.985 | Leading | 53.23 | 0.985 | Leading | 53.27 |
| 10 | FLT17-3PH | 0.987 | Leading | 48.83 | 0.985 | Leading | 52.94 | 0.984 | Leading | 53.48 |
| 11 | FLT18-3PH | 0.984 | Leading | 53.83 | 0.983 | Leading | 55.46 | 0.984 | Leading | 54.78 |
| 12 | FLT19-3PH | 0.985 | Leading | 52.66 | 0.983 | Leading | 55.56 | 0.984 | Leading | 53.80 |
| 13 | FLT20-3PH | 0.984 | Leading | 54.20 | 0.984 | Leading | 54.36 | 0.984 | Leading | 54.18 |
| 14 | FLT21-3PH | 0.988 | Leading | 46.47 | 0.986 | Leading | 50.82 | 0.986 | Leading | 51.41 |
| 15 | FLT22-3PH | 0.985 | Leading | 52.54 | 0.984 | Leading | 53.46 | 0.984 | Leading | 53.52 |
| 16 | FLT23-3PH | 0.984 | Leading | 53.45 | 0.984 | Leading | 54.04 | 0.984 | Leading | 54.05 |
| 17 | FLT24-3PH | 0.984 | Leading | 55.15 | 0.983 | Leading | 55.28 | 0.983 | Leading | 55.28 |
| 18 | FLT25-3PH | 0.985 | Leading | 52.97 | 0.984 | Leading | 53.46 | 0.984 | Leading | 53.59 |
| 19 | FLT26-3PH | 0.985 | Leading | 53.20 | 0.984 | Leading | 53.53 | 0.984 | Leading | 53.59 |
| 20 | FLT27-3PH | 0.984 | Leading | 53.84 | 0.984 | Leading | 54.28 | 0.984 | Leading | 54.28 |
| 21 | FLT28-3PH | 0.984 | Leading | 53.85 | 0.984 | Leading | 54.30 | 0.984 | Leading | 54.30 |
| 22 | FLT29-3PH | 0.984 | Leading | 54.33 | 0.984 | Leading | 54.24 | 0.984 | Leading | 54.31 |
| 23 | FLT30-3PH | 0.985 | Leading | 53.19 | 0.984 | Leading | 53.80 | 0.984 | Leading | 53.87 |
| 24 | FLT31-3PH | 0.984 | Leading | 53.68 | 0.984 | Leading | 54.04 | 0.984 | Leading | 54.07 |
| 25 | FLT32-3PH | 0.984 | Leading | 53.86 | 0.984 | Leading | 54.21 | 0.984 | Leading | 54.26 |
| 26 | FLT33-3PH | 0.984 | Leading | 53.77 | 0.984 | Leading | 54.27 | 0.984 | Leading | 54.26 |
| 27 | FLT34-3PH | 0.984 | Leading | 54.00 | 0.984 | Leading | 54.32 | 0.984 | Leading | 54.31 |
| 28 | FLT35-3PH | 0.984 | Leading | 55.08 | 0.984 | Leading | 55.00 | 0.983 | Leading | 56.08 |
| 29 | FLT36-3PH | 0.986 | Leading | 51.38 | 0.985 | Leading | 52.95 | 0.984 | Leading | 55.11 |
| 30 | FLT37-3PH | 0.984 | Leading | 53.90 | 0.983 | Leading | 55.23 | 0.984 | Leading | 54.68 |
| 31 | FLT38-3PH | 0.985 | Leading | 53.31 | 0.985 | Leading | 52.92 | 0.985 | Leading | 52.12 |
| 32 | FLT39-3PH | 0.985 | Leading | 51.98 | 0.986 | Leading | 51.21 | 0.985 | Leading | 53.17 |
| 33 | FLT40-3PH | 1.000 | Leading | 7.71 | 1.000 | Lagging | -3.39 | 1.000 | Leading | 0.34 |
| 34 | FLT41-3PH | 0.982 | Leading | 58.25 | 0.977 | Leading | 65.31 | 0.980 | Leading | 60.96 |
| 35 | FLT42-3PH | 0.989 | Leading | 44.78 | 0.988 | Leading | 46.93 | 0.986 | Leading | 49.82 |
| 36 | FLT43-3PH | 0.996 | Leading | 27.35 | 0.996 | Leading | 28.30 | 0.995 | Leading | 31.46 |
| 37 | FLT44-3PH | 0.989 | Leading | 44.51 | 0.975 | Leading | 68.91 | 0.977 | Leading | 65.12 |
| 38 | FLT45-3PH | 0.996 | Leading | 26.46 | 0.995 | Leading | 28.91 | 0.996 | Leading | 25.90 |
| 39 | FLT46-3PH | 0.964 | Leading | 82.46 | 0.979 | Leading | 63.12 | 0.975 | Leading | 68.94 |
| 40 | FLT47-3PH | 0.993 | Leading | 35.40 | 0.988 | Leading | 46.27 | 0.991 | Leading | 39.92 |
| 41 | FLT48-3PH | 0.964 | Leading | 82.67 | 0.968 | Leading | 78.38 | 0.966 | Leading | 80.70 |
| 42 | FLT49-3PH | 0.984 | Leading | 54.03 | 0.984 | Leading | 54.15 | 0.984 | Leading | 53.72 |
| 43 | FLT50-3PH | 0.984 | Leading | 53.87 | 0.984 | Leading | 54.32 | 0.984 | Leading | 54.32 |

Table 5-4 (Continued)
Power Factor Analysis: GEN-2015-088

| 1Ref. No. | Cont. Name | 2016 Winter Peak | | | 2017 Summer Peak | | | 2025 Summer Peak | | |
|-----------|------------|------------------|---------|----------|------------------|---------|----------|------------------|---------|----------|
| | | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) | Power Factor | | Q (MVAR) |
| 44 | FLT81-3PH | 0.986 | Leading | 50.30 | 0.987 | Leading | 49.57 | 0.987 | Leading | 49.72 |
| 45 | FLT82-3PH | 0.993 | Leading | 35.40 | 0.988 | Leading | 46.27 | 0.991 | Leading | 39.92 |
| 46 | FLT83-3PH | 0.982 | Leading | 57.97 | 0.982 | Leading | 58.11 | 0.983 | Leading | 56.85 |
| 47 | FLT84-3PH | 0.984 | Leading | 53.87 | 0.984 | Leading | 54.32 | 0.984 | Leading | 54.32 |
| 48 | FLT85-3PH | 0.995 | Leading | 31.16 | 0.990 | Leading | 42.91 | 0.989 | Leading | 44.63 |
| 49 | FLT86-3PH | 0.985 | Leading | 53.43 | 0.984 | Leading | 54.31 | 0.984 | Leading | 53.54 |
| 50 | FLT87-3PH | 0.984 | Leading | 53.66 | 0.984 | Leading | 54.60 | 0.984 | Leading | 53.69 |
| 51 | FLT88-3PH | 0.979 | Leading | 62.73 | 0.981 | Leading | 59.81 | 0.981 | Leading | 58.92 |
| 52 | FLT89-3PH | 0.984 | Leading | 53.60 | 0.984 | Leading | 54.22 | 0.984 | Leading | 54.20 |
| 53 | FLT90-3PH | 0.984 | Leading | 53.60 | 0.984 | Leading | 54.22 | 0.984 | Leading | 54.20 |
| 54 | FLT108-3PH | 0.984 | Leading | 54.33 | 0.984 | Leading | 54.24 | 0.984 | Leading | 54.31 |
| 55 | FLT109-3PH | 0.985 | Leading | 51.90 | 0.985 | Leading | 53.25 | 0.985 | Leading | 53.33 |
| 56 | FLT110-3PH | 0.985 | Leading | 53.31 | 0.984 | Leading | 54.09 | 0.984 | Leading | 54.04 |
| 57 | FLT111-3PH | 0.984 | Leading | 53.88 | 0.984 | Leading | 54.43 | 0.984 | Leading | 54.39 |
| 58 | FLT112-3PH | 0.985 | Leading | 53.03 | 0.985 | Leading | 53.23 | 0.985 | Leading | 53.27 |
| 59 | FLT113-3PH | 0.984 | Leading | 53.48 | 0.984 | Leading | 54.11 | 0.984 | Leading | 54.13 |
| 60 | FLT114-3PH | 0.984 | Leading | 53.90 | 0.984 | Leading | 54.25 | 0.984 | Leading | 54.24 |
| 61 | FLT115-3PH | 0.986 | Leading | 49.84 | 0.987 | Leading | 49.74 | 0.986 | Leading | 50.35 |
| 62 | FLT116-3PH | 0.985 | Leading | 51.90 | 0.985 | Leading | 51.78 | 0.985 | Leading | 52.45 |
| 63 | FLT117-3PH | 0.986 | Leading | 50.86 | 0.985 | Leading | 52.26 | 0.985 | Leading | 52.30 |
| 64 | FLT118-3PH | 0.985 | Leading | 53.39 | 0.985 | Leading | 53.04 | 0.984 | Leading | 53.46 |
| 65 | FLT119-3PH | 0.956 | Leading | 92.03 | 0.948 | Leading | 100.43 | 0.987 | Leading | 49.00 |
| 66 | FLT120-3PH | 0.984 | Leading | 53.87 | 0.984 | Leading | 54.32 | 0.984 | Leading | 54.32 |

(1) Refer to Table 2-3 for a description of the contingency scenario

Study Generator GEN-2015-088

The Power Factor Analysis shows that GEN-2015-088 has a power factor range of 0.956 leading (absorbing) to 1.00 (unity) for the 2016 Winter Peak conditions, a power factor range of 0.948 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, and a power factor range of 0.966 leading (absorbing) to 1.00 (unity) for the 2025 Summer Peak conditions.

SECTION 6: LOW WIND/NO WIND ANALYSIS

The objective of this task is to determine the impact of low wind or no wind conditions on wind farms that interconnect to a 345 kV or 230 kV bus. The 2016 Winter Peak, 2017 Summer Peak, and 2025 Summer Peak power flows provided by SPP were examined for this analysis.

6.1 Approach

Low wind or no wind conditions were examined for all 345 kV or 230 kV wind farms. Generators were disabled (independently), but the collector systems remained in-service. In order to maintain generation and load balance in the SPP area, the generation was scaled after disabling the respective generator. The amount of reactive power injected into the transmission network was recorded at the respective point of interconnection. This reactive power comes from the capacitance of the project's transmission lines and collector cables. A shunt reactor was added at the high side bus to bring the Mvar flow into the POI down to approximately zero.

6.2 Low Wind/No Wind Analysis Results

The reactance needed to bring the Mvar flow into the point of interconnect to zero Mvar was recorded for each season for all wind or solar farms. Refer to Table 6-1 for the Low Wind/No Wind Analysis results. The table lists the generators examined and the amount of reactive power needed for zero Mvar flow into the POI for each season.

Table 6-1
Low Wind/No Wind Analysis

| Request | Size (MW) | Point of Interconnection | 16WP | 17SP | 25SP |
|--------------|-----------|---|-------|-------|-------|
| GEN-2015-053 | 50.0 | Antelope 115 kV (640251) | 3.30 | 3.30 | 3.30 |
| GEN-2015-076 | 158.4 | Belden 115kV (640080) | 4.20 | 4.20 | 4.20 |
| GEN-2015-087 | 66.0 | Tap on Fairbury (640169) to Hebron (640218) 115kV | 5.85 | 5.85 | 5.85 |
| GEN-2015-088 | 300.0 | Tap on Moore (640277) to Pauline (640312) 345kV | 22.20 | 22.20 | 22.20 |

SECTION 7: CONCLUSIONS

Summary of Stability Analysis

The Stability Analysis determined there were no contingencies that resulted in system instability or generation tripping offline for the examined seasonal peak conditions when all generation interconnection requests were at 100% output.

However, it was determined that two contingencies, FLT39-3PH, which is the loss of the Fairbry7 to Harbine7 115 kV line and FLT120-3PH, which is the loss of the McCool to Grand Island 345 kV line, resulted in post-contingency generator power swings for all seasonal peak conditions at Fairbryg and Brokenbg, respectively. After discussion with SPP, it was determined that this was a pre-existing issue for FLT39-3PH as it was still present in the contingency even with the GEN-2015-087 out of service. Similarly, for FLT120-3PH, it was determined that this was a pre-existing issue as it was still present in the contingency even with all four study generators out of service.

Summary of the Short-Circuit Analysis

The Short-Circuit Analysis was performed on the 2017 Summer Peak and 2025 Summer Peak power flows for all study projects. Refer to Table 7-1 for a list of maximum fault currents observed for each study project for the 2017 Summer Peak case. Refer to Table 7-2 for a list of maximum fault currents observed for each study project for the 2025 Summer Peak case.

Table 7-1
List of Maximum Fault Currents Observed for Each Study Project for the
2017 Summer Peak Case

| Study Project | POI Name | Fault Current at POI (kA) | Maximum Fault Current (kA) | Fault Location | Bus Voltage (kV) |
|---------------|---|---------------------------|----------------------------|----------------|------------------|
| GEN-2015-053 | Antelope 115kV (640521) | 13.13 | 29.97 | S1251 5 | 161 |
| GEN-2015-076 | Belden 115kV (640080) | 6.67 | 29.97 | S1251 5 | 161 |
| GEN-2015-087 | Tap on Fairbury (640169) to Hebron (640218) 115kV | 5.37 | 31.65 | SHELDON7 | 115 |
| GEN-2015-088 | Tap on Moore (640277) to Pauline (640312) 345kV | 10.57 | 39.11 | S1206 5 | 115 |

Table 7-2
List of Maximum Fault Currents Observed for Each Study Project for the
2025 Summer Peak Case

| Study Project | POI Name | Fault Current at POI (kA) | Maximum Fault Current (kA) | Fault Location | Bus Voltage (kV) |
|---------------|---|---------------------------|----------------------------|----------------|------------------|
| GEN-2015-053 | Antelope 115kV (640521) | 13.38 | 30.89 | S1251 5 | 161 |
| GEN-2015-076 | Belden 115kV (640080) | 6.68 | 30.88 | S1251 5 | 161 |
| GEN-2015-087 | Tap on Fairbury (640169) to Hebron (640218) 115kV | 5.37 | 32.60 | SHELDON7 | 115 |
| GEN-2015-088 | Tap on Moore (640277) to Pauline (640312) 345kV | 10.62 | 40.47 | S1206 5 | 161 |

Summary of Power Factor Analysis

Study Generator GEN-2015-053

The Power Factor Analysis shows that GEN-2015-053 has a power factor range of 0.358 leading (absorbing) to 0.811 leading (absorbing) for the 2016 Winter Peak conditions, a power factor range of 0.394 leading (absorbing) to 0.949 lagging (supplying) for the 2017 Summer Peak conditions, and a power factor range of 0.438 leading (absorbing) to 0.964 lagging (supplying) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-076

The Power Factor Analysis shows that GEN-2015-076 has a power factor range of 0.975 leading (absorbing) to 1.00 (unity) for the 2016 Winter Peak conditions, a power factor range of 0.985 lagging (supplying) to 0.998 leading (absorbing) for the 2017 Summer Peak conditions, and a power factor range of 0.985 lagging (supplying) to 0.998 leading (absorbing) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-087

The Power Factor Analysis shows that GEN-2015-087 has a power factor range of 0.978 leading (absorbing) to 1.00 (unity) for the 2016 Winter Peak conditions, a power factor range of 0.955 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, and a power factor range of 0.917 leading (absorbing) to 1.00 (unity) for the 2025 Summer Peak conditions.

Study Generator GEN-2015-088

The Power Factor Analysis shows that GEN-2015-088 has a power factor range of 0.956 leading (absorbing) to 1.00 (unity) for the 2016 Winter Peak conditions, a power factor range of 0.948 leading (absorbing) to 1.00 (unity) for the 2017 Summer Peak conditions, and a power factor range of 0.966 leading (absorbing) to 1.00 (unity) for the 2025 Summer Peak conditions.

Summary of Low Wind/No Wind Analysis

The amount of reactive power injected into the transmission network was recorded at the high side of the transformer near the point of interconnection for all study projects for each season. The maximum reactance needed for zero Mvar flow was -22.20 Mvar for GEN-2015-088. The minimum reactance needed for zero Mvar flow was -3.20 Mvar for GEN-2015-053.