



Report on

GEN-2015-013 Modification Request Impact Study

Revision R1 August 1, 2023

Submitted to
Southwest Power Pool



anedenconsulting.com

TABLE OF CONTENTS

Revision History.....	R-1
Executive Summary	ES-1
1.0 Scope of Study	1
1.1 Steady-State Analysis.....	1
1.2 Stability Analysis, Short Circuit Analysis	1
1.3 Reactive Power Analysis.....	1
1.4 Study Limitations.....	1
2.0 Project and Modification Request	2
3.0 Existing vs Modification Comparison.....	4
3.1 Stability Model Parameters Comparison	4
3.2 Equivalent Impedance Comparison Calculation.....	4
4.0 Reactive Power Analysis.....	5
4.1 Methodology and Criteria	5
4.2 Results.....	5
5.0 Short Circuit Analysis	7
5.1 Methodology	7
5.2 Results.....	7
6.0 Dynamic Stability Analysis.....	8
6.1 Methodology and Criteria	8
6.2 Fault Definitions	9
6.3 Results.....	12
7.0 Modified Capacity Exceeds GIA Capacity.....	13
8.0 Material Modification Determination.....	14
8.1 Results.....	14

LIST OF TABLES

Table ES-1: GEN-2015-013 Modification Request ES-1
 Table 2-1: GEN-2015-013 Modification Request 3
 Table 4-1: Shunt Reactor Size for Reactive Power Study (Modification) 5
 Table 5-1: Short Circuit Model Parameters* 7
 Table 5-2: POI Short Circuit Results 7
 Table 5-3: 25SP Short Circuit Results 7
 Table 6-1: Fault Definitions 9
 Table 6-2: GEN-2015-013 Dynamic Stability Results 12

LIST OF FIGURES

Figure 2-1: GEN-2015-013 Single Line Diagram (Existing Configuration*) 2
 Figure 2-2: GEN-2015-013 Single Line Diagram (Modification Configuration) 3
 Figure 4-1: GEN-2015-013 Single Line Diagram Shunt Sizes (Existing DISIS) 6
 Figure 4-2: GEN-2015-013 Single Line Diagram Shunt Sizes (Modification) 6

APPENDICES

- APPENDIX A: GEN-2015-013 Generator Dynamic Model
- APPENDIX B: Short Circuit Results
- APPENDIX C: Dynamic Stability Results with Existing Base Case Issues & Simulation Plots

Revision History

DATE OR VERSION NUMBER	AUTHOR	CHANGE DESCRIPTION
8/1/2023	Aneiden Consulting	Initial Report Issued

Executive Summary

Aneden Consulting (Aneden) was retained by the Southwest Power Pool (SPP) to perform a Modification Request Impact Study (Study) for GEN-2015-013, an active Generation Interconnection Request (GIR) with a Point of Interconnection (POI) at the Snyder 138 kV Substation.

The GEN-2015-013 solar project interconnects in the Western Farmers Electric Cooperative (WFEC) control area with a capacity of 120 MW. This Study has been requested to evaluate the modification of GEN-2015-013 to change the inverter configuration to 40 x Sungrow SG3600UD-MV operating at 3.066 MW for a total of 122.64 MW. This generating MW for GEN-2015-013 (122.64 MW) exceeds its Generator Interconnection Agreement (GIA) Interconnection Service amount, 120 MW, as listed in Appendix A of the GIA. As a result, the customer must ensure that the amount of power injected at the POI does not exceed the Interconnection Service amount listed in its GIA. The requested modification includes the use of a Power Plant Controller (PPC) to limit the total power injected into the POI, thus the project was dispatched at 121.64 MW.

In addition, the modification request included changes to the collection system, generator step-up transformer, generation interconnection line, and main substation transformer. The existing and modified configurations for GEN-2015-013 are shown in Table ES-1.

Table ES-1: GEN-2015-013 Modification Request

Facility	Existing Configuration	Modification Configuration
Point of Interconnection	Snyder 138 kV (521052)	Snyder 138 kV (521052)
Configuration/Capacity	72 x Eaton Power Xpert Solar 1.666 MW = 119.952 MW	40 x Sungrow SG3600UD-MV operating at 3.066 MW = 122.64 MW [121.64 MW dispatch] PPC in place to limit POI to 120 MW
Generation Interconnection Line	Length = 0.25 miles R = 0.000150 pu X = 0.000150 pu B = 0.000000 pu Rating MVA = 0.0 MVA	Length = 0.06 miles R = 0.000041 pu X = 0.000119 pu B = 0.001317 pu Rating MVA = 217 MVA
Main Substation Transformer ¹	X = 8.996%, R = 0.264%, Winding MVA = 81 MVA, Rating MVA = 135 MVA	X = 9.495%, R = 0.298%, Winding MVA = 83 MVA, Rating MVA = 138 MVA
Equivalent GSU Transformer ¹	Gen 1 Equivalent Qty: 72 X = 5.721%, R = 0.572%, Winding MVA = 132.12 MVA, Rating MVA ² = 132.1 MVA	Gen 1 Equivalent Qty: 40 X = 5.684%, R = 0.867%, Winding MVA = 144 MVA, Rating MVA = 144 MVA
Equivalent Collector Line ³	N/A (Not modeled in DISIS-2017-002-1 models)	R = 0.002527 pu X = 0.002423 pu B = 0.000105 pu
Generator Dynamic Model ⁴ & Power Factor	72 x Eaton Power Xpert Solar 1.666 MW (REGCAU1) ⁴ Leading: 0.991 Lagging: 0.991	40 x Sungrow SG3600UD-MV 3.557 MVA (REGCA1) ⁴ Leading: 0.862 Lagging: 0.862

1) X and R based on Winding MVA, 2) Rating rounded in PSS/E, 3) All pu are on 100 MVA Base, 4) DYR stability model name

SPP determined that steady-state analysis was not required because the modifications to the project were not significant enough to change the previously studied steady-state conclusions. However, SPP determined that the change from Eaton Power to Sungrow inverters required short circuit and dynamic stability analyses.

The scope of this modification request study included reactive power analysis, short circuit analysis, and dynamic stability analysis.

Aneden performed the analyses using the modification request data and the DISIS-2017-002-1 study models:

- 2025 Summer Peak (25SP),
- 2025 Winter Peak (25WP)

All analyses were performed using the Siemens PTI PSS/E¹ version 34 software and the results are summarized below.

The results of the reactive power analysis using the 25SP model showed that the GEN-2015-013 project needed a 0.14 MVAR shunt reactor on the 34.5 kV bus of the project substation with the modifications in place, an increase from the 0 MVAR found for the existing configuration using the DISIS-2017-002-1 model. This is necessary to offset the capacitive effect on the transmission network caused by the project's transmission line and collector system during reduced generation conditions. The information gathered from the reactive power analysis is provided as information to the Interconnection Customer and Transmission Owner (TO) and/or Transmission Operator (TOP). The applicable reactive power requirements will be further reviewed by the TO and/or TOP.

The short circuit analysis was performed using the 25SP stability model modified for short circuit analysis. The results from the short circuit analysis with the updated topology showed that the maximum GEN-2015-013 contribution to three-phase fault currents in the immediate transmission systems at or near the GEN-2015-013 POI was no greater than 0.5 kA. The maximum three-phase fault current level within 5 buses of the POI with the GEN-2015-013 generator online was below 37 kA.

The dynamic stability analysis was performed using Siemens PTI PSS/E version 34.8.0 software for the two modified study models: 25SP and 25WP. 28 events were simulated, which included three-phase faults and single-line-to-ground stuck breaker faults.

The results of the dynamic stability analysis showed several existing base case issues that were found in both the original DISIS-2017-002-1 model and in the model with GEN-2015-013 included. These issues were not attributed to the GEN-2015-013 modification request and are detailed in Appendix C.

There were no damping or voltage recovery violations attributed to the GEN-2015-013 modification request observed during the simulated faults. Additionally, the project was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

Based on the results of the study, SPP determined that the requested modification is not a Material Modification. The requested modification does not have a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date. As the requested modification places the generating capacity of the Interconnection Request at a higher amount than its Interconnection Service, the customer must install monitoring and control equipment as needed to ensure that the amount of power injected at the POI does not exceed the Interconnection Service amount listed in its GIA.

¹ Power System Simulator for Engineering

In accordance with FERC Order No. 827, the generating facility will be required to provide dynamic reactive power within the range of 0.95 leading to 0.95 lagging at the high-side of the generator substation.

It is likely that the customer may be required to reduce its generation output to 0 MW in real-time, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of transmission service or delivery rights. If the customer wishes to obtain deliverability to final customers, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the customer.

1.0 Scope of Study

Aneden Consulting (Aneden) was retained by the Southwest Power Pool (SPP) to perform a Modification Request Impact Study (Study) for GEN-2015-013. A Modification Request Impact Study is a generation interconnection study performed to evaluate the impacts of modifying the DISIS study assumptions. The determination of the required scope of the study is dependent upon the specific modification requested and how it may impact the results of the DISIS study. Impacting the DISIS results could potentially affect the cost or timing of any Interconnection Request with a later Queue priority date, deeming the requested modification a Material Modification. The criteria sections below include reasoning as to why an analysis was either included or excluded from the scope of study.

All analyses were performed using the Siemens PTI PSS/E version 34 software. The results of each analysis are presented in the following sections.

1.1 Steady-State Analysis

Steady-state analysis is performed if SPP deems it necessary based on the nature of the requested change. SPP determined that steady-state analysis was not required because the modifications to the project were not significant enough to change the previously studied steady-state conclusions.

1.2 Stability Analysis, Short Circuit Analysis

To determine whether stability and short circuit analyses are required, SPP evaluates the difference between the inverter parameters and, if needed, the equivalent collector system impedance between the existing configuration and the requested modification. Dynamic stability analysis and short circuit analysis would be required if the differences listed above were determined to have a significant impact on the most recently performed DISIS stability analysis.

1.3 Reactive Power Analysis

SPP requires that a reactive power analysis be performed on the requested modification configuration as it is a non-synchronous resource. The reactive power analysis determines the capacitive effect at the POI caused by the project's collector system and transmission line's capacitance. A shunt reactor size is determined in order to offset the capacitive effect and maintain zero (0) MVAR flow at the POI while the project's generators and capacitors are offline.

1.4 Study Limitations


The assessments and conclusions provided in this report are based on assumptions and information provided to Aneden by others. While the assumptions and information provided may be appropriate for the purposes of this report, Aneden does not guarantee that those conditions assumed will occur. In addition, Aneden did not independently verify the accuracy or completeness of the information provided. As such, the conclusions and results presented in this report may vary depending on the extent to which actual future conditions differ from the assumptions made or information used herein.

2.0 Project and Modification Request

The GEN-2015-013 Interconnection Customer has requested a modification to its Generation Interconnection Request (GIR) with a Point of Interconnection (POI) at the Snyder 138 kV Substation. At the time of report posting, GEN-2015-013 is an active Interconnection Request with a queue status of “IA FULLY EXECUTED/ON SCHEDULE.” GEN-2015-013 is a solar farm with a maximum summer and winter queue capacity of 120 MW with Energy Resource Interconnection Service (ERIS) and Network Resource Interconnection Service (NRIS).

The GEN-2015-013 project is currently in the DISIS-2015-001 cluster. Figure 2-1 shows the power flow model single line diagram for the existing GEN-2015-013 configuration using the DISIS-2017-002-1 stability models. The GEN-2015-013 project interconnects in the Western Farmers Electric Cooperative (WFEC) control area with a capacity of 120 MW.

Figure 2-1: GEN-2015-013 Single Line Diagram (Existing Configuration*)



*based on the DISIS-2017-002-1 25SP stability models

This Study has been requested by the Interconnection Customer to evaluate the modification of GEN-2015-013 to an inverter configuration of 40 x Sungrow SG3600UD-MV operating at 3.066 MW for a total of 122.64 MW. This generating MW for GEN-2015-013 (122.64 MW) exceeds its Generator Interconnection Agreement (GIA) Interconnection Service amount, 120 MW, as listed in Appendix A of the GIA. As a result, the customer must ensure that the amount of power injected at the POI does not exceed the Interconnection Service amount listed in its GIA. The requested modification includes the use of a Power Plant Controller (PPC) to limit the total power injected into the POI, thus the project was dispatched at 121.64 MW.

In addition, the modification request included changes to the collection system, generator step-up transformer, generation interconnection line, and main substation transformer. Figure 2-2 shows the power flow model single line diagram for the GEN-2015-013 modification. The existing and modified configurations for GEN-2015-013 are shown in Table 2-1.

Figure 2-2: GEN-2015-013 Single Line Diagram (Modification Configuration)




Table 2-1: GEN-2015-013 Modification Request

Facility	Existing Configuration	Modification Configuration
Point of Interconnection	Snyder 138 kV (521052)	Snyder 138 kV (521052)
Configuration/Capacity	72 x Eaton Power Xpert Solar 1.666 MW = 119.952 MW	40 x Sungrow SG3600UD-MV operating at 3.066 MW = 122.64 MW [121.64 MW dispatch] PPC in place to limit POI to 120 MW
Generation Interconnection Line	Length = 0.25 miles R = 0.000150 pu X = 0.000150 pu B = 0.000000 pu Rating MVA = 0.0 MVA	Length = 0.06 miles R = 0.000041 pu X = 0.000119 pu B = 0.001317 pu Rating MVA = 217 MVA
Main Substation Transformer ¹	X = 8.996%, R = 0.264%, Winding MVA = 81 MVA, Rating MVA = 135 MVA	X = 9.495%, R = 0.298%, Winding MVA = 83 MVA, Rating MVA = 138 MVA
Equivalent GSU Transformer ¹	Gen 1 Equivalent Qty: 72 X = 5.721%, R = 0.572%, Winding MVA = 132.12 MVA, Rating MVA ² = 132.1 MVA	Gen 1 Equivalent Qty: 40 X = 5.684%, R = 0.867%, Winding MVA = 144 MVA, Rating MVA = 144 MVA
Equivalent Collector Line ³	N/A (Not modeled in DISIS-2017-002-1 models)	R = 0.002527 pu X = 0.002423 pu B = 0.000105 pu
Generator Dynamic Model ⁴ & Power Factor	72 x Eaton Power Xpert Solar 1.666 MW (REGCAU1) ⁴ Leading: 0.991 Lagging: 0.991	40 x Sungrow SG3600UD-MV 3.557 MVA (REGCA1) ⁴ Leading: 0.862 Lagging: 0.862

1) X and R based on Winding MVA, 2) Rating rounded in PSS/E, 3) All pu are on 100 MVA Base, 4) DYR stability model name

3.0 Existing vs Modification Comparison

To determine which analyses are required for the Study, the differences between the existing configuration and the requested modification were evaluated. Aneden performed this comparison and the resulting analyses using a set of modified study models developed based on the modification request data and the DISIS-2017-002-1 study models. The analysis was completed using PSS/E version 34 software.

The methodology and results of the comparisons are described below.

3.1 Stability Model Parameters Comparison

SPP determined that short circuit and dynamic stability analyses were required because of the change from Eaton Power to Sungrow inverters. This is because the short circuit contribution and stability responses of the existing configuration and the requested modification's configuration may differ. The generator dynamic model for the modification can be found in Appendix A.

As short circuit and dynamic stability analyses were already deemed required, a stability model parameters comparison was not needed for the determination of the scope of the study.

3.2 Equivalent Impedance Comparison Calculation

As the inverter stability model change determined that short circuit and dynamic stability analyses were required, an equivalent impedance comparison was not needed for the determination of the scope of the study.

4.0 Reactive Power Analysis

The reactive power analysis was performed for GEN-2015-013 to determine the capacitive charging effects during reduced generation conditions (unsuitable wind speeds, unsuitable solar irradiance, insufficient state of charge, idle conditions, curtailment, etc.) at the generation site and to size shunt reactors that would reduce the project reactive power contribution to the POI to approximately zero.

4.1 Methodology and Criteria

The GEN-2015-013 generators were switched out of service while other system elements remained in-service. A shunt reactor was tested at the project's collection substation 34.5 kV bus to set the MVar flow into the POI to approximately zero. The size of the shunt reactor is equivalent to the charging current value at unity voltage and the compensation provided is proportional to the voltage effects on the charging current (i.e., for voltages above unity, reactive compensation is greater than the size of the reactor).

Aneden performed the reactive power analysis using the modification request data based on the 25SP DISIS-2017-002-1 stability study model.

4.2 Results

The results from the analysis showed that the GEN-2015-013 project needed approximately 0.14 MVar of compensation at its project substation to reduce the POI MVar to zero. This is an increase from the 0 MVar found for the existing configuration using the DISIS-2017-002-1 model. Figure 4-1 illustrates the shunt reactor size needed to reduce the POI MVar to approximately zero with the existing configuration. Figure 4-2 illustrates the shunt reactor size needed to reduce the POI MVar to approximately zero with the updated topology. The final shunt reactor requirements for GEN-2015-013 are shown in Table 4-1.

The information gathered from the reactive power analysis is provided as information to the Interconnection Customer and Transmission Owner (TO) and/or Transmission Operator (TOP). The applicable reactive power requirements will be further reviewed by the TO and/or TOP.

Table 4-1: Shunt Reactor Size for Reactive Power Study (Modification)

Machine	POI Bus Number	POI Bus Name	Reactor Size (MVar)
			25SP
GEN-2015-013	521052	SNYDER 4	0.14

Figure 4-1: GEN-2015-013 Single Line Diagram Shunt Sizes (Existing DISIS)





Figure 4-2: GEN-2015-013 Single Line Diagram Shunt Sizes (Modification)



5.0 Short Circuit Analysis

A short circuit study was performed using the 25SP model for GEN-2015-013. The detailed results of the short circuit analysis are provided in Appendix B.

5.1 Methodology

The short circuit analysis included applying a three-phase fault on buses up to 5 levels away from the 138 kV POI bus. The PSS/E “Automatic Sequence Fault Calculation (ASCC)” fault analysis module was used to calculate the fault current levels in the transmission system with and without GEN-2015-013 online.

Aneden created a short circuit model using the 25SP DISIS-2017-002-1 stability study model by adjusting the GEN-2015-013 short circuit parameters consistent with the modification data. The adjusted parameters used in the short circuit analysis are shown in Table 5-1 below. No other changes were made to the model.

Table 5-1: Short Circuit Model Parameters*

Parameter	Value by Generator Bus#
Machine MVA Base	142.28
R (pu)	0.0
X'' (pu)	0.9426

*pu values based on Machine MVA Base

5.2 Results

The results of the short circuit analysis for the 25SP model are summarized in Table 5-2 and Table 5-3. The GEN-2015-013 POI bus (Snyder 138 kV - 521052) fault current magnitudes are provided in Table 5-2 showing a fault current of 6.45 kA with the GEN-2015-013 project online. Table 5-3 shows the maximum fault current magnitudes and fault current increases with the GEN-2015-013 project online.

The maximum fault current calculated within 5 buses of the GEN-2015-013 POI (including the POI bus) was less than 37 kA for the 25SP model. The maximum GEN-2015-013 contribution to three-phase fault current was about 8.4% and 0.5 kA.

Table 5-2: POI Short Circuit Results

Case	GEN-OFF Current (kA)	GEN-ON Current (kA)	kA Change	%Change
25SP	5.95	6.45	0.50	8.4%

Table 5-3: 25SP Short Circuit Results

Voltage (kV)	Max. Current (kA)	Max kA Change	Max %Change
69	7.9	0.24	3.7%
138	36.65	0.50	8.4%
Max	36.6	0.50	8.4%

6.0 Dynamic Stability Analysis

Aneden performed a dynamic stability analysis to identify the impact of the inverter configuration change and other modifications to GEN-2015-013. The analysis was performed according to SPP's Disturbance Performance Requirements². The modification details are described in Section 2.0 above and the dynamic modeling data is provided in Appendix A. The existing base case issues and simulation plots can be found in Appendix C.

6.1 Methodology and Criteria

The dynamic stability analysis was performed using models developed with the requested GEN-2015-013 configuration of 40 x Sungrow SG3600UD-MV operating at 3.066 MW (REGCA1). This stability analysis was performed using PTI's PSS/E version 34.8.0 software.

The modifications requested for the GEN-2015-013 project were used to create modified stability models for this impact study based on the DISIS-2017-002-1 stability study models:

- 2025 Summer Peak (25SP),
- 2025 Winter Peak (25WP)

The modified dynamic model data for the GEN-2015-013 project is provided in Appendix A. The modified power flow models and associated dynamic database were initialized (no-fault test) to confirm that there were no errors in the initial conditions of the system and the dynamic data.

The following system adjustments were made to address existing base case issues that are not attributed to the modification request:

- The frequency protective relays at buses 599117, 515551, 599119, 599120, 515882, 515883, 515664, 515665, & 562685 were disabled after observing the generators tripping during initial three phase fault simulations. This frequency tripping issue is a known PSS/E limitation when calculating bus frequency as it relates to non-conventional type devices.
- The voltage protective relays at buses 515969, 515968, 515967, 515986, 515985, 515984, 587953, 587953, 539852, 539853, 539845, 539846, 539847, 539848, 515664, 515665, 588713, 588714, 588715, & 588716 were disabled to avoid generator tripping due to an instantaneous over voltage spike after fault clearing.
- The fault simulation file acceleration factor was reduced as needed to resolve stability simulation crashes.

During the fault simulations, the active power (PELEC), reactive power (QELEC), and terminal voltage (ETERM) were monitored for GEN-2015-013 and other current and prior queued projects in their cluster group³. In addition, voltages of five (5) buses away from the POI of GEN-2015-013 were monitored and plotted. The machine rotor angle for synchronous machines and speed for asynchronous machines within the study areas including 330 (AECI), 515 (SWPA), 520 (AEPW), 523 (GRDA), 524 (OKGE), 525 (WFEC), 527 (OMPA), and 534 (SUNC) were monitored. The voltages of all 100 kV and above buses within the study area were monitored as well.

² [SPP Disturbance Performance Requirements:](https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20(twg%20approved).pdf)

[https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20\(twg%20approved\).pdf](https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20(twg%20approved).pdf)

³ Based on the DISIS-2017-002 Cluster Groups

6.2 Fault Definitions

Aneden simulated the faults previously used for GEN-2015-013 and developed additional fault events as required. The new set of faults was simulated using the modified study models. The fault events included three-phase faults and single-line-to-ground stuck breaker faults. Single-line-to-ground faults are approximated by applying a fault impedance to bring the faulted bus positive sequence voltage to 0.6 pu. The simulated faults are listed and described in Table 6-1 below. These contingencies were applied to the modified 25SP and 25WP models.

Table 6-1: Fault Definitions

Fault ID	Planning Event	Fault Descriptions
FLT9001-3PH	P1	3 phase fault on the SNYDER 4 (521052) to CACHEJ4 (521190) 138 kV line CKT 1, near SNYDER 4. a. Apply fault at the SNYDER 4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9002-3PH	P1	3 phase fault on the SNYDER 4 (521052) to SNYDER-4 (511435) 138 kV line CKT 1, near SNYDER 4. a. Apply fault at the SNYDER 4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9003-3PH	P1	3 phase fault on the SNYDTER_1 138 kV (521052)/ 69 kV (521051) /13.8 kV (521176) XFMR CKT 1, near SNYDER 4 (521052) 138 kV. a. Apply fault at the SNYDER 4 138 kV bus. b. Clear fault after 7 cycles and trip the faulted transformer.
FLT9004-3PH	P1	3 phase fault on the CACHEJ4 (521190) to MDCPRK4 (520404) 138 kV line CKT 1, near CACHEJ4. a. Apply fault at the CACHEJ4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9005-3PH	P1	3 phase fault on the CACHEJ4 (521190) to CACHE4 (520410) 138 kV line CKT 1, near CACHEJ4. a. Apply fault at the CACHEJ4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9006-3PH	P1	3 phase fault on the SNYDER-4 (511435) to TAP_G17-036 (999600) 138 kV line CKT 1, near SNYDER-4. a. Apply fault at the SNYDER-4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9007-3PH	P1	3 phase fault on the SNYDER-4 (511435) to ALTUSJT4 (511440) 138 kV line CKT 1, near SNYDER-4. a. Apply fault at the SNYDER-4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9008-3PH	P1	3 phase fault on the SNYDER 138 kV (511435)/ 69 kV (511475) /13.8 kV (511419) XFMR CKT 1, near SNYDER-4 (511435) 138 kV. a. Apply fault at the SNYDER-4 138 kV bus. b. Clear fault after 7 cycles and trip the faulted transformer.

Table 6-1 Continued

Fault ID	Planning Event	Fault Descriptions
FLT9009-3PH	P1	3 phase fault on the MDCPRK4 (520404) to PARADSE4 (521024) 138 kV line CKT 1, near MDCPRK4. a. Apply fault at the MDCPRK4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9010-3PH	P1	3 phase fault on the CACHE4 (520410) to INDHOMA4 (520954) 138 kV line CKT 1, near CACHE4. a. Apply fault at the CACHE4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9011-3PH	P1	3 phase fault on the TAP_G17-036 (999600) to CACHE4 (511500) 138 kV line CKT 1, near TAP_G17-036. a. Apply fault at the TAP_G17-036 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9012-3PH	P1	3 phase fault on the TAP_G17-036 (999600) to GEN-2017-036 (588780) 138 kV line CKT 1, near TAP_G17-036. a. Apply fault at the TAP_G17-036 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. Trip generator G17-036-GEN1 (588783). c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9013-3PH	P1	3 phase fault on the SNYDER-2 (511475) to HEADRIK2 (511462) 69 kV line CKT 1, near SNYDER-2. a. Apply fault at the SSNYDER-2 69 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9014-3PH	P1	3 phase fault on the SNYDER-2 (511475) to TIPTE 1 (511472) 69 kV line CKT 1, near SNYDER-2. a. Apply fault at the SSNYDER-2 69 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9015-3PH	P1	3 phase fault on the SNYDER-2 (511475) to TOMSTEED2 (511495) 69 kV line CKT 1, near SNYDER-2. a. Apply fault at the SSNYDER-2 69 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9016-3PH	P1	3 phase fault on the ALTUSJT4 (511440) to RUSSELL4 (521043) 138 kV line CKT 1, near ALTUSJT4. a. Apply fault at the ALTUSJT4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9017-3PH	P1	3 phase fault on the ALTUSJT4 (511440) to OMPARK-4 (529345) 138 kV line CKT 1, near ALTUSJT4. a. Apply fault at the ALTUSJT4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9018-3PH	P1	3 phase fault on the ALTUSJCT 138 kV (511440)/ 69 kV (511441) /13.8 kV (511420) XFMR CKT 1, near ALTUSJT4 (511440) 138 kV. a. Apply fault at the ALTUSJT4 138 kV bus. b. Clear fault after 7 cycles and trip the faulted transformer.
FLT9019-3PH	P1	3 phase fault on the SNYDER 2 (521051) to TIPTONJ2 (521070) 69 kV line CKT 1, near SNYDER 2. a. Apply fault at the SNYDER 2 69 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.

Table 6-1 Continued

Fault ID	Planning Event	Fault Descriptions
FLT9020-3PH	P1	3 phase fault on the SNYDRSB2 (520541) to NAVJOTP2 (521009) 69 kV line CKT 1, near SNYDRSB2. a. Apply fault at the SNYDRSB2 69 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT1001-SB	P4	Stuck Breaker on SNYDER-4 (511435) 138 kV bus. a. Apply single-phase fault at SNYDER-4 (511435) on the 138 kV bus. b. Wait 16 cycles and remove fault. c. Trip the SNYDER-4 (511435) to TAP_G17-036 (999600) 138 kV line CKT 1. d. Trip the SNYDER 138 kV (511435)/ 69 kV (511475) /13.8 kV (511419) XFMR CKT 1.
FLT1002-SB	P4	Stuck Breaker on SNYDER-4 (511435) 138 kV bus. a. Apply single-phase fault at SNYDER-4 (511435) on the 138 kV bus. b. Wait 16 cycles and remove fault. c. Trip the SNYDER-4 (511435) to TAP_G17-036 (999600) 138 kV line CKT 1. d. Trip the SNYDER-4 (511435) to SNYDER 4 (521052) 138 kV line CKT 1.
FLT1003-SB	P4	Stuck Breaker on SNYDER-4 (511435) 138 kV bus. a. Apply single-phase fault at SNYDER-4 (511435) on the 138 kV bus. b. Wait 16 cycles and remove fault. c. Trip the SNYDER-4 (511435) to ALTUSJT4 (511440) 138 kV line CKT 1. d. Trip the SNYDER-4 (511435) to SNYDER 4 (521052) 138 kV line CKT 1.
FLT1004-SB	P4	Stuck Breaker on SNYDER-4 (511435) 138 kV bus. a. Apply single-phase fault at SNYDER-4 (511435) on the 138 kV bus. b. Wait 16 cycles and remove fault. c. Trip the SNYDER-4 (511435) to ALTUSJT4 (511440) 138 kV line CKT 1. d. Trip the SNYDER 138 kV (511435)/ 69 kV (511475) /13.8 kV (511419) XFMR CKT 1.
FLT1005-SB	P4	Stuck Breaker on SNYDER 4 (521052) 138 kV bus. a. Apply single-phase fault at SNYDER 4 (521052) on the 138 kV bus. b. Wait 16 cycles and remove fault. c. Trip the SNYDER 4 (521052) to CACHEJ4 (521190) 138 kV line CKT 1. d. Trip the SNYDTER_1 138 kV (521052)/ 69 kV (521051) /13.8 kV (521176) XFMR CKT 1.
FLT1006-SB	P4	Stuck Breaker on SNYDER 4 (521052) 138 kV bus. a. Apply single-phase fault at SNYDER 4 (521052) on the 138 kV bus. b. Wait 16 cycles and remove fault. c. Trip the SNYDER 4 (521052) to CACHEJ4 (521190) 138 kV line CKT 1. d. Trip the SNYDER 4 (521052) to SNYDER-4 (511435) 138 kV line CKT 1.
FLT1007-SB	P4	Stuck Breaker on SNYDER 4 (521052) 138 kV bus. a. Apply single-phase fault at SNYDER 4 (521052) on the 138 kV bus. b. Wait 16 cycles and remove fault. c. Trip the SNYDER 4 (521052) to GEN-2015-013 (562683) 138 kV line CKT 1. d. Trip the SNYDER 4 (521052) to SNYDER-4 (511435) 138 kV line CKT 1. Trip Generator G15-013-GEN1 (562685).
FLT1008-SB	P4	Stuck Breaker on SNYDER 4 (521052) 138 kV bus. a. Apply single-phase fault at SNYDER 4 (521052) on the 138 kV bus. b. Wait 16 cycles and remove fault. c. Trip the SNYDER 4 (521052) to GEN-2015-013 (562683) 138 kV line CKT 1. d. Trip the SNYDTER_1 138 kV (521052)/ 69 kV (521051) /13.8 kV (521176) XFMR CKT 1. Trip Generator G15-013-GEN1 (562685).

6.3 Results

Table 6-2 shows the relevant results of the fault events simulated for each of the modified models. Existing DISIS base case issues are documented separately in Appendix C. The associated stability plots are also provided in Appendix C.

Table 6-2: GEN-2015-013 Dynamic Stability Results

Fault ID	25SP			25WP		
	Voltage Violation	Voltage Recovery	Stable	Voltage Violation	Voltage Recovery	Stable
FLT9001-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9002-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9003-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9004-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9005-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9006-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9007-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9008-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9009-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9010-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9011-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9012-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9013-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9014-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9015-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9016-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9017-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9018-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9019-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9020-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT1001-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1002-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1003-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1004-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1005-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1006-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1007-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1008-SB	Pass	Pass	Stable	Pass	Pass	Stable

The results of the dynamic stability analysis showed several existing base case issues that were found in both the original DISIS-2017-002-1 model and the model with GEN-2015-013 included. These issues were not attributed to the GEN-2015-013 modification request and detailed in Appendix C.

There were no damping or voltage recovery violations attributed to the GEN-2015-013 modification request observed during the simulated faults. Additionally, the project was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

7.0 Modified Capacity Exceeds GIA Capacity

Under FERC Order 845, Interconnection Customers are allowed to request Interconnection Service that is lower than the full generating capacity of their planned generating facilities. The Interconnection Customers must install acceptable control and protection devices that prevent the injection above their requested Interconnection Service amount measured at the POI.

As such, Interconnection Customers are allowed to increase the generating capacity of a generating facility without increasing its Interconnection Service amount stated in its GIA. This is allowable as long as they install the proper control and protection devices, and the requested modification is not determined to be a Material Modification.

The modified generating capacity of GEN-2015-013 (122.64 MW) exceeds the GIA Interconnection Service amount, 120 MW, as listed in Appendix A of the GIA.

The customer must install monitoring and control equipment as needed to ensure that the amount of power injected at the POI does not exceed the Interconnection Service amount listed in its GIA.

8.0 Material Modification Determination

In accordance with Attachment V of SPP's Open Access Transmission Tariff, for modifications other than those specifically permitted by Attachment V, SPP shall evaluate the proposed modifications prior to making them and inform the Interconnection Customer in writing of whether the modifications would constitute a Material Modification. Material Modification shall mean (1) modification to an Interconnection Request in the queue that has a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date; or (2) planned modification to an Existing Generating Facility that is undergoing evaluation for a Generating Facility Modification or Generating Facility Replacement, and has a material adverse impact on the Transmission System with respect to: i) steady-state thermal or voltage limits, ii) dynamic system stability and response, or iii) short-circuit capability limit; compared to the impacts of the Existing Generating Facility prior to the modification or replacement.

8.1 Results

SPP determined the requested modification is not a Material Modification based on the results of this Modification Request Impact Study performed by Aneden. Aneden evaluated the impact of the requested modification on the prior study results. Aneden determined that the requested modification did not negatively impact the prior study dynamic stability and short circuit results, and the modifications to the project were not significant enough to change the previously studied steady-state conclusions.

This determination implies that any network upgrades already required by GEN-2015-013 would not be negatively impacted and that no new upgrades are required due to the requested modification, thus not resulting in a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date.