



**Aneden**  
Consulting

**Submitted to**  
**Southwest Power Pool**



Report On

**GEN-2015-023**  
**Modification Request Impact Study**

Revision R1

Date of Submittal  
September 10, 2021

[anedenconsulting.com](http://anedenconsulting.com)

**TABLE OF CONTENTS**

Revision History ..... R-1

Executive Summary ..... ES-1

1.0 Scope of Study ..... 1

    1.1 Power Flow ..... 1

    1.2 Stability Analysis, Short Circuit Analysis ..... 1

    1.3 Charging Current Compensation Analysis ..... 1

    1.4 Study Limitations ..... 1

2.0 Project and Modification Request ..... 2

3.0 Existing vs Modification Comparison ..... 4

    3.1 POI Injection Comparison ..... 4

    3.2 Turbine Parameters Comparison ..... 4

    3.3 Equivalent Impedance Comparison Calculation ..... 4

4.0 Charging Current Compensation Analysis ..... 5

    4.1 Methodology and Criteria ..... 5

    4.2 Results ..... 5

5.0 Short Circuit Analysis ..... 7

    5.1 Methodology ..... 7

    5.2 Results ..... 7

6.0 Dynamic Stability Analysis ..... 8

    6.1 Methodology and Criteria ..... 8

    6.2 Fault Definitions ..... 8

    6.3 Results ..... 13

7.0 Material Modification Determination ..... 16

    7.1 Results ..... 16

8.0 Conclusions ..... 17

## LIST OF TABLES

Table ES-1: GEN-2015-023 Existing Configuration.....	ES-1
Table ES-2: GEN-2015-023 Modification Request.....	ES-1
Table 2-1: GEN-2015-023 Existing Configuration .....	2
Table 2-2: GEN-2015-023 Modification Request .....	3
Table 3-1: GEN-2015-023 POI Injection Comparison.....	4
Table 4-1: Shunt Reactor Size for Low Wind Study (Modification).....	5
Table 5-1: POI Short Circuit Results .....	7
Table 5-2: 2021SP Short Circuit Results .....	7
Table 5-3: 2028SP Short Circuit Results .....	7
Table 6-1: Fault Definitions.....	9
Table 6-2: GEN-2015-023 Dynamic Stability Results .....	13

## LIST OF FIGURES

Figure 2-1: GEN-2015-023 Single Line Diagram (Existing Configuration).....	2
Figure 2-2: GEN-2015-023 Single Line Diagram (Modification Configuration) .....	3
Figure 4-1: GEN-2015-023 Single Line Diagram (Existing Shunt Reactor) .....	6
Figure 4-2: GEN-2015-023 Single Line Diagram (Modification Shunt Reactor).....	6
Figure 6-1: GEN-2015-023 VAR Response Regulating Remote POI Voltage.....	14
Figure 6-2: GEN-2015-023 VAR Response Regulating Local Generator Terminal Voltage .....	15

## APPENDICES

APPENDIX A: GEN-2015-023 Generator Dynamic Model
APPENDIX B: Short Circuit Results
APPENDIX C: SPP Disturbance Performance Requirements
APPENDIX D: Dynamic Stability Simulation Plots

## Revision History

DATE OR VERSION NUMBER	AUTHOR	CHANGE DESCRIPTION
09/10/2021	Ameden Consulting	Initial Report Issued.

## Executive Summary

Aneden Consulting (Aneden) was retained by the Southwest Power Pool (SPP) to perform a Modification Request Impact Study (Study) for GEN-2015-023, an active Generation Interconnection Request (GIR) with a point of interconnection (POI) at the Holt County 345 kV Substation.

The GEN-2015-023 project is proposed to interconnect in the Nebraska Public Power District (NPPD) control area with a capacity of 300.72 MW as shown in Table ES-1 below. This Study has been requested to evaluate the modification of GEN-2015-023 to change the turbine configuration to 10 x GE 116 2.3 MW + 98 x GE 127 2.82 MW for a total generating capacity of 299.36 MW.

In addition, the modification request included changes to the collection system, generator step-up transformers, generation interconnection line, and main substation transformer. The existing and modified configurations for GEN-2015-023 are shown in Table ES-2.

**Table ES-1: GEN-2015-023 Existing Configuration**

Request	Point of Interconnection	Existing Generator Configuration	GIA Capacity (MW)
GEN-2015-023	Holt County 345 kV (640510)	168 x GE 1.79 MW	300.72

**Table ES-2: GEN-2015-023 Modification Request**

Facility	Existing		Modification		
Point of Interconnection	Holt County 345 kV (640510)		Holt County 345 kV (640510)		
Configuration/Capacity	168 x GE 1.79 MW = 300.72 MW		10 x GE 116 2.3 MW + 98 x GE 127 2.82 MW = 299.36 MW		
Generation Interconnection Line	Length = 5 miles R = 0.000230 pu X = 0.002350 pu B = 0.046170 pu		Length = 0.387 miles R = 0.000031 pu X = 0.000197 pu B = 0.003254 pu		
Main Substation Transformer <sup>1</sup>	X = 8.997% R = 0.225%, Winding MVA = 100 MVA, Rating MVA = 166 MVA	X = 8.997% R = 0.225%, Winding MVA = 100 MVA, Rating MVA = 166 MVA	X12 = 8.959% R12 = 0.176%, X23 = 2.509% R23 = 0.0%, X13 = 12.366% R13 = 0.0%, Winding MVA = 100 MVA, Rating MVA = 175 MVA	X12 = 8.876% R12 = 0.179%, X23 = 2.486% R23 = 0.0%, X13 = 12.252% R13 = 0.0%, Winding MVA = 100 MVA, Rating MVA = 175 MVA	
Equivalent GSU Transformer <sup>1</sup>	Gen 1 Equivalent Qty: 84: X = 5.7%, R = 0.76%, Rating 155.4 MVA	Gen 1 Equivalent Qty: 84: X = 5.7%, R = 0.76%, Rating 155.4 MVA	Gen 1 Equivalent Qty: 53: X = 7.045%, R = 0.705%, Winding MVA = 166.42 MVA, Rating MVA <sup>2</sup> = 166.4 MVA	Gen 2 Equivalent Qty: 45: X = 7.045%, R = 0.705%, Winding MVA = 141.3 MVA, Rating MVA = 141.3 MVA	Gen 3 Equivalent Qty: 10: X = 6.289%, R = 0.629%, Winding MVA = 26 MVA, Rating MVA = 26 MVA
Equivalent Collector Line <sup>3</sup>	R = 0.006660 pu X = 0.007080 pu B = 0.062520 pu	R = 0.006080 pu X = 0.006560 pu B = 0.062820 pu	R = 0.007424 pu X = 0.013028 pu B = 0.114422 pu	R = 0.008563 pu X = 0.015074 pu B = 0.137634 pu	

1) X/R based on Winding MVA, 2) Rating rounded in PSS/E, 3) all pu are on 100 MVA Base

SPP determined that power flow should not be performed based on the POI MW injection decrease of 0.49% compared to the DISIS-2017-001 power flow models. However, SPP determined that while the modification used the same turbine manufacturer, GE, the generator model change from GEWTG2 to REGCAU1 required short circuit and dynamic stability analyses.

The scope of this modification request study included charging current compensation analysis, short circuit analysis, and dynamic stability analysis.

Aneden performed the analyses using the modification request data based on the DISIS-2017-001 Group 9 study models:

1. 2019 Winter Peak (2019WP),
2. 2021 Light Load (2021LL)
3. 2021 Summer Peak (2021SP),
4. 2028 Summer Peak (2028SP)

All analyses were performed using the PTI PSS/E version 33.10 software and the results are summarized below.

The results of the charging current compensation analysis performed using the 2019 Winter Peak, 2021 Light Load, 2021 Summer Peak, and 2028 Summer Peak models showed that the GEN-2015-023 project needed 25.81 MVAR of reactor shunts on the 34.5 kV bus of the project substation with the modifications in place, an increase from the 17.3 MVAR found for the existing GEN-2015-023 configuration calculated using the DISIS-2017-001 models. This is necessary to offset the capacitive effect on the transmission network caused by the project's transmission line and collector system during low-wind or no-wind conditions. The information gathered from the charging current compensation analysis is provided as information to the Interconnection Customer and Transmission Owner (TO) and/or Transmission Operator. The applicable reactive power requirements will be further reviewed by the Transmission Owner and/or Transmission Operator.

The results from the short circuit analysis with the updated topology showed that the maximum GEN-2015-023 contribution to three-phase fault currents in the immediate systems at or near GEN-2015-023 was not greater than 1.14 kA for the 2021SP and 2028SP models. All three-phase fault current levels within 5 buses of the POI with the GEN-2015-023 generators online were below 44 kA for the 2021SP and 2028SP models.

The dynamic stability analysis was performed using the four modified study models, 2019 Winter Peak, 2021 Light Load, 2021 Summer Peak, and 2028 Summer Peak. Up to 35 events were simulated, which included three-phase faults, three-phase faults on prior outage cases, and single-line-to-ground stuck breaker faults.

The modified GEN-2015-023 stability model was set to regulate the POI voltage (Holt County, 640510) whereas the existing stability model in the DISIS-2017-001 case was set to regulate the local generator terminal voltage. The modified GEN-2015-023 stability model was changed from

regulating the POI voltage to regulating the generator terminal voltage for this study to avoid the need for voltage control coordination with nearby generators.

The results of the dynamic stability analysis showed that there were no damping or voltage recovery violations attributed to the GEN-2015-023 project observed during the simulated faults. Additionally, the project was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

The requested modification has been determined by SPP to not be a Material Modification. The requested modification does not have a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date.

In accordance with FERC Order No. 827, the generating facility will be required to provide dynamic reactive power within the range of 0.95 leading to 0.95 lagging at the high-side of the generator substation.

It is likely that the customer may be required to reduce its generation output to 0 MW in real-time, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of transmission service or delivery rights. If the customer wishes to obtain deliverability to final customers, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the customer.



---

## 1.0 Scope of Study

Aneden Consulting (Aneden) was retained by the Southwest Power Pool (SPP) to perform a Modification Request Impact Study (Study) for GEN-2015-023. A Modification Request Impact Study is a generation interconnection study performed to evaluate the impacts of modifying the DISIS study assumptions. The determination of the required scope of the study is dependent upon the specific modification requested and how it may impact the results of the DISIS study. Impacting the DISIS results could potentially affect the cost or timing of any Interconnection Request with a later Queue priority date, deeming the requested modification a Material Modification. The criteria sections below include reasoning as to why an analysis was either included or excluded from the scope of study.

All analyses were performed using the PTI PSS/E version 33.10 software. The results of each analysis are presented in the following sections.

### 1.1 Power Flow

To determine whether power flow analysis is required, SPP evaluates the difference in the real power output at the POI between the DISIS-2017-001 power flow configuration and the requested modification. Power flow analysis is included if the difference has a significant impact on the results of the DISIS study.

### 1.2 Stability Analysis, Short Circuit Analysis

To determine whether stability and short circuit analyses are required, SPP evaluates the difference between the turbine parameters and, if needed, the collector system impedance between the existing configuration and the requested modification. Dynamic stability analysis and short circuit analysis would be required if the differences listed above were determined to have a significant impact on the most recently performed DISIS stability analysis.

### 1.3 Charging Current Compensation Analysis

SPP requires that a charging current compensation analysis be performed on the requested modification configuration as it is a non-synchronous resource. The charging current compensation analysis determines the capacitive effect at the POI caused by the project's collector system and transmission line's capacitance. A shunt reactor size is determined in order to offset the capacitive effect and maintain zero (0) MVar flow at the POI while the project's generators and capacitors are offline.

### 1.4 Study Limitations

The assessments and conclusions provided in this report are based on assumptions and information provided to Aneden by others. While the assumptions and information provided may be appropriate for the purposes of this report, Aneden does not guarantee that those conditions assumed will occur. In addition, Aneden did not independently verify the accuracy or completeness of the information provided. As such, the conclusions and results presented in this report may vary depending on the extent to which actual future conditions differ from the assumptions made or information used herein.



## 2.0 Project and Modification Request

The GEN-2015-023 Interconnection Customer has requested a modification to its Interconnection Request (IR) with a point of interconnection (POI) at the Holt County 345 kV Substation. At the time of the posting of this report, GEN-2015-023 is an active Interconnection Request with a queue status of “IA FULLY EXECUTED/ON SCHEDULE.” GEN-2015-023 is a wind farm and has a maximum summer and winter queue capacity of 300.72 MW with Energy Resource Interconnection Service (ERIS) and Network Resource Interconnection Service (NRIS).


The GEN-2015-023 project was originally studied as part of Group 9 in the DISIS-2015-001 study. Figure 2-1 shows the power flow model single line diagram for the existing GEN-2015-023 configuration.

The GEN-2015-023 project is proposed to interconnect in the Nebraska Public Power District (NPPD) control area with a capacity of 300.72 MW as shown in Table 2-1 below.

**Table 2-1: GEN-2015-023 Existing Configuration**

Request	Point of Interconnection	Existing Generator Configuration	GIA Capacity (MW)
GEN-2015-023	Holt County 345 kV (640510)	168 x GE 1.79 MW	300.72

**Figure 2-1: GEN-2015-023 Single Line Diagram (Existing Configuration)**



This Study has been requested by the Interconnection Customer to evaluate the modification of GEN-2015-023 to change the turbine configuration to 10 x GE 116 2.3 MW + 98 x GE 127 2.82 MW for a total generating capacity of 299.36 MW. In addition, the modification request included changes to the collection system, generator step-up transformers, generation interconnection line, and main substation transformer. Figure 2-2 shows the power flow model single line diagram for the GEN-2015-023 modification. The existing and modified configurations for GEN-2015-023 are shown in Table 2-2.

Figure 2-2: GEN-2015-023 Single Line Diagram (Modification Configuration)




Table 2-2: GEN-2015-023 Modification Request

Facility	Existing		Modification		
Point of Interconnection	Holt County 345 kV (640510)		Holt County 345 kV (640510)		
Configuration/Capacity	168 x GE 1.79 MW = 300.72 MW		10 x GE 116 2.3 MW + 98 x GE 127 2.82 MW = 299.36 MW		
Generation Interconnection Line	Length = 5 miles R = 0.000230 pu X = 0.002350 pu B = 0.046170 pu		Length = 0.387 miles R = 0.000031 pu X = 0.000197 pu B = 0.003254 pu		
Main Substation Transformer <sup>1</sup>	X = 8.997% R = 0.225%, Winding MVA = 100 MVA, Rating MVA = 166 MVA	X = 8.997% R = 0.225%, Winding MVA = 100 MVA, Rating MVA = 166 MVA	X12 = 8.959% R12 = 0.176%, X23 = 2.509% R23 = 0.0%, X13 = 12.366% R13 = 0.0%, Winding MVA = 100 MVA, Rating MVA = 175 MVA	X12 = 8.876% R12 = 0.179%, X23 = 2.486% R23 = 0.0%, X13 = 12.252% R13 = 0.0%, Winding MVA = 100 MVA, Rating MVA = 175 MVA	
Equivalent GSU Transformer <sup>1</sup>	Gen 1 Equivalent Qty: 84: X = 5.7%, R = 0.76%, Rating 155.4 MVA	Gen 1 Equivalent Qty: 84: X = 5.7%, R = 0.76%, Rating 155.4 MVA	Gen 1 Equivalent Qty: 53: X = 7.045%, R = 0.705%, Winding MVA = 166.42 MVA, Rating MVA <sup>2</sup> = 166.4 MVA	Gen 2 Equivalent Qty: 45: X = 7.045%, R = 0.705%, Winding MVA = 141.3 MVA, Rating MVA = 141.3 MVA	Gen 3 Equivalent Qty: 10: X = 6.289%, R = 0.629%, Winding MVA = 26 MVA, Rating MVA = 26 MVA
Equivalent Collector Line <sup>3</sup>	R = 0.006660 pu X = 0.007080 pu B = 0.062520 pu	R = 0.006080 pu X = 0.006560 pu B = 0.062820 pu	R = 0.007424 pu X = 0.013028 pu B = 0.114422 pu	R = 0.008563 pu X = 0.015074 pu B = 0.137634 pu	

1) X/R based on Winding MVA, 2) Rating rounded in PSS/E, 3) all pu are on 100 MVA Base

### 3.0 Existing vs Modification Comparison

To determine which analyses are required for the Study, the differences between the existing configuration and the requested modification were evaluated. Aneden performed this comparison and the resulting analyses using a set of modified study models developed based on the modification request data and the DISIS-2017-001 Group 9 study models.

The methodology and results of the comparisons are described below. The analysis was completed using PSS/E version 33.10 software.

#### 3.1 POI Injection Comparison

The real power injection at the POI was determined using PSS/E to compare the DISIS-2017-001 power flow configuration and the requested modifications for GEN-2015-023. The percentage change in the POI injection was then evaluated. If the MW difference was determined to be significant, power flow analysis would be performed to assess the impact of the modification request.

SPP determined that power flow analysis was not required due to the insignificant change (decrease of 0.49%) in the real power output at the POI between the studied DISIS-2017-001 power flow configuration and requested modification shown in Table 3-1.

**Table 3-1: GEN-2015-023 POI Injection Comparison**

Interconnection Request	Existing POI Injection (MW)	MRIS POI Injection (MW)	POI Injection Difference %
GEN-2015-023	294.8	293.4	-0.49%

#### 3.2 Turbine Parameters Comparison

SPP determined that while the modification used the same turbine manufacturer, GE, the generator model change from GEWTG2 to REGCAU1 required short circuit and dynamic stability analyses as the short circuit contribution and stability responses of the existing configuration and the requested modification's configuration may differ. The generator dynamic model for the modification can be found in Appendix A.

As short circuit and dynamic stability analyses were required, a turbine parameters comparison was not needed for the determination of the scope of the study.

#### 3.3 Equivalent Impedance Comparison Calculation

As the turbine stability model change determined that short circuit and dynamic stability analyses were required, an equivalent impedance comparison was not needed for the determination of the scope of the study.

## 4.0 Charging Current Compensation Analysis

The charging current compensation analysis was performed for GEN-2015-023 to determine the capacitive charging effects during reduced generation conditions (unsuitable wind speeds, unsuitable solar irradiance, insufficient state of charge, idle conditions, curtailment, etc.) at the generation site and to size shunt reactors that would reduce the project reactive power contribution to the POI to approximately zero.

### 4.1 Methodology and Criteria

The GEN-2015-023 generators were switched out of service while other collection system elements remained in-service. A shunt reactor was tested at the project's collection substation 34.5 kV bus to set the MVAR flow into the POI to approximately zero. The size of the shunt reactor is equivalent to the charging current value at unity voltage and the compensation provided is proportional to the voltage effects on the charging current (i.e. for voltages above unity, reactive compensation is greater than the size of the reactor).

### 4.2 Results

The results from the analysis showed that the GEN-2015-023 project needed approximately 25.81 MVAR of compensation at its project substation, to reduce the POI MVAR to zero. This is an increase from the 17.3 MVAR found for the existing GEN-2015-023 configuration calculated using the DISIS-2017-001 models. Figure 4-1 illustrates the shunt reactor size needed to reduce the POI MVAR to approximately zero with the existing configuration. Figure 4-2 illustrates the shunt reactor size needed to reduce the POI MVAR to approximately zero with the updated topology. The final shunt reactor requirements for GEN-2015-023 are shown in Table 4-1.

The information gathered from the charging current compensation analysis is provided as information to the Interconnection Customer and Transmission Owner (TO) and/or Transmission Operator. The applicable reactive power requirements will be further reviewed by the Transmission Owner and/or Transmission Operator.

**Table 4-1: Shunt Reactor Size for Low Wind Study (Modification)**

Machine	POI Bus Number	POI Bus Name	Reactor Size (MVAR)			
			19WP	21LL	21SP	28SP
GEN-2015-023	640510	Holt County 345 kV	25.81	25.81	25.81	25.81

Figure 4-1: GEN-2015-023 Single Line Diagram (Existing Shunt Reactor)





Figure 4-2: GEN-2015-023 Single Line Diagram (Modification Shunt Reactor)



## 5.0 Short Circuit Analysis

A short circuit study was performed using the 2021SP and 2028SP models for GEN-2015-023. The detailed results of the short circuit analysis are provided in Appendix B.

### 5.1 Methodology

The short circuit analysis included applying a 3-phase fault on buses up to 5 levels away from the 345 kV POI bus. The PSS/E “Automatic Sequence Fault Calculation (ASCC)” fault analysis module was used to calculate the fault current levels with and without GEN-2015-023 online.

### 5.2 Results

The results of the short circuit analysis for the 2021SP and 2028SP models are summarized in Table 5-1 through Table 5-3 respectively. The GEN-2015-023 POI bus fault current magnitudes are provided in Table 5-1 showing a maximum fault current of 8.08 kA with the GEN-2015-023 project online.

The maximum fault current calculated within 5 buses of the GEN-2015-023 POI was less than 44 kA for the 2021SP and 2028SP models respectively. The maximum GEN-2015-023 contribution to three-phase fault current was about 16.5% and 1.14 kA.

**Table 5-1: POI Short Circuit Results**

Case	GEN-OFF Current (kA)	GEN-ON Current (kA)	Max kA Change	Max %Change
2021SP	6.96	8.08	1.13	16.2%
2028SP	6.92	8.06	1.14	16.5%

**Table 5-2: 2021SP Short Circuit Results**

Voltage (kV)	Max. Current (kA)	Max kA Change	Max %Change
69	6.1	0.00	0.0%
115	43.9	0.09	0.7%
161	30.4	0.00	0.0%
230	20.0	0.17	1.0%
345	25.1	1.13	16.2%
<b>Max</b>	<b>43.9</b>	<b>1.13</b>	<b>16.2%</b>

**Table 5-3: 2028SP Short Circuit Results**

Voltage (kV)	Max. Current (kA)	Max kA Change	Max %Change
69	6.1	0.00	0.0%
115	43.9	0.10	0.8%
161	30.0	0.00	0.0%
230	20.3	0.18	1.1%
345	25.2	1.14	16.5%
<b>Max</b>	<b>43.9</b>	<b>1.14</b>	<b>16.5%</b>

---

## 6.0 Dynamic Stability Analysis

Aneden performed a dynamic stability analysis to identify the impact of the turbine configuration change and other modifications to the GEN-2015-023 project. The analysis was performed according to SPP's Disturbance Performance Requirements shown in Appendix C. The modification details are described in Section 2.0 above and the dynamic modeling data is provided in Appendix A. The simulation plots can be found in Appendix D.

### 6.1 Methodology and Criteria

The dynamic stability analysis was performed using models developed with the requested GEN-2015-023 configuration of 10 x GE 116 2.3 MW (REGCAU1) + 98 x GE 127 2.82 MW (REGCAU1). This stability analysis was performed using PTI's PSS/E version 33.10 software.

The stability models were developed using the DISIS-2017-001 Group 9 models. The modifications requested for the GEN-2015-023 projects were used to create modified stability models for this impact study.

The following system adjustment was made to address existing base case issues that are not attributed to the modification request:

1. The instantaneous overvoltage relays at buses 645065, 645066, 645067, and 645068 were disabled.

The modified dynamics model data for the GEN-2015-023 project is provided in Appendix A. The modified power flow models and associated dynamics database were initialized (no-fault test) to confirm that there were no errors in the initial conditions of the system and the dynamic data.

During the fault simulations, the active power (PELEC), reactive power (QELEC), and terminal voltage (ETERM) were monitored for GEN-2015-023 and other equally and prior queued projects in Group 9. In addition, voltages of five (5) buses away from the POI of GEN-2015-023 were monitored and plotted. The machine rotor angle for synchronous machines and speed for asynchronous machines within this study area including 534 (SUNC), 536 (WERE), 540 (GMO), 541 (KCPL), 635 (MEC), 640 (NPPD), 645 (OPPD), 650 (LES), 652 (WAPA) were monitored. In addition, the voltages of all 100 kV and above buses within the study area were monitored.

### 6.2 Fault Definitions

Aneden simulated the faults previously simulated for GEN-2015-023 and selected additional fault events for GEN-2015-023 as required. The new set of faults were simulated using the modified study models. The fault events included three-phase faults, three-phase faults on prior outage cases, and single-line-to-ground stuck breaker faults. The simulated faults are listed and described in Table 6-1 below. These contingencies were applied to the modified 2019 Winter Peak, 2021 Light Load, 2021 Summer Peak, and the 2028 Summer Peak models.



**Table 6-1: Fault Definitions**

Fault ID	Planning Event	Fault Descriptions
FLT16-3PH	P1	3 phase fault on the HOLT.CO3 (640510) to GPPRAR1-LNX3 (652832) 345 kV line circuit 1, near HOLT.CO3. a. Apply fault at the HOLT.CO3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT17-3PH	P1	3 phase fault on the HOLT.CO3 (640510) to GR ISLD-LNX3 (653871) 345 kV line circuit 1, near HOLT.CO3. a. Apply fault at the HOLT.CO3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT18-3PH	P1	3 phase fault on the HOLT.CO3 (640510) to THEDFRD3 (640500) 345 kV line circuit 1, near HOLT.CO3. a. Apply fault at the HOLT.CO3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT19-3PH	P1	3 phase fault on the GRPRAR2-LNX3 (652833) to FTTHOM2-LNX3 (652807) 345 kV line circuit 1, near GRPRAR2-LNX3. a. Apply fault at the GRPRAR2-LNX3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT9001-3PH	P1	3 phase fault on the GR ISLD3 (653571) to SWEET W3 (640374) 345 kV line circuit 1, near GR ISLD3. a. Apply fault at the GR ISLD3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT9002-3PH	P1	3 phase fault on the GI KU1A 345 kV (653571)/ 230 kV (640200)/ 13.8 kV (653314) XFMR CKT 1, near GR ISLD3 345 kV. a. Apply fault at the GR ISLD3 345 kV bus. b. Clear fault after 6 cycles and trip the faulted transformer.
FLT9003-3PH	P1	3 phase fault on the GI KU3A 345 kV (653571)/ 230 kV (640200)/ 13.8 kV (643071) XFMR CKT 3, near GR ISLD3 345 kV. a. Apply fault at the GR ISLD3 345 kV bus. b. Clear fault after 6 cycles and trip the faulted transformer.
FLT9004-3PH	P1	3 phase fault on the GR ISLD3 (653571) to MCCOOL 3 (640271) 345 kV line circuit 1, near GR ISLD3. a. Apply fault at the GR ISLD3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT9005-3PH	P1	3 phase fault on the FTTHOM1-LNX3 (652806) to G16-017_TAP (560074) 345 kV line circuit 1, near FTTHOM1-LNX3. a. Apply fault at the FTTHOM1-LNX3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT9006-3PH	P1	3 phase fault on the THEDFRD3 (640500) to GENTLMN3 (640183) 345 kV line circuit 1, near THEDFRD3. a. Apply fault at the THEDFRD3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT9007-3PH	P1	3 phase fault on the THEDFORD9 345 kV (640500)/ 115 kV (640381)/ 13.8 kV (640570) XFMR CKT 1, near THEDFORD9 345 kV. a. Apply fault at the THEDFORD9 345 kV bus. b. Clear fault after 6 cycles and trip the faulted transformer.

**Table 6-1 continued**

Fault ID	Planning Event	Fault Descriptions
FLT9008-3PH	P1	3 phase fault on the GENTLMN3 (640183) to REDWILO3 (640325) 345 kV line circuit 1, near GENTLMN3. a. Apply fault at the GENTLMN3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT9009-3PH	P1	3 phase fault on the GENTLMN3 (640183) to KEYSTON3 (640252) 345 kV line circuit 1, near GENTLMN3. a. Apply fault at the GENTLMN3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT9010-3PH	P1	3 phase fault on the GENTLMN4 345 kV (640183)/ 230 kV (640184)/ 13.8 kV (640185) XFMR CKT 1, near GENTLMN4 345 kV. a. Apply fault at the GENTLMN4 345 kV bus. b. Clear fault after 6 cycles and trip the faulted transformer.
FLT9011-3PH	P1	3 phase fault on the GENTLMN3 (640183) to SWEET W3 (640374) 345 kV line circuit 1, near GENTLMN3. a. Apply fault at the GENTLMN3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT9012-3PH	P1	3 phase fault on the GENTLMN4 345 kV (640183)/ 24 kV (640011) XFMR CKT 1, near GENTLMN4 345 kV. a. Apply fault at the GENTLMN4 345 kV bus. b. Clear fault after 6 cycles and trip the faulted transformer. <b>Trip the generator GENTLM2G (640011)</b>
FLT9013-3PH	P1	3 phase fault on the SWEET W3 (640374) to AXTELL 3 (640065) 345 kV line circuit 1, near SWEET W3. a. Apply fault at the SWEET W3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT9014-3PH	P1	3 phase fault on the SWEET W3 (640374) to GEN-2016-074 (587680) 345 kV line circuit 1, near SWEET W3. a. Apply fault at the SWEET W3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. <b>Trip the generator G16-074-GEN1 (587683)</b> c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT9015-3PH	P1	3 phase fault on the FTTHOMP3 345 kV (652506)/ 230 kV (652507)/ 13.8 kV (652274) XFMR CKT 1, near FTTHOMP3 345 kV. a. Apply fault at the FTTHOMP3 345 kV bus. b. Clear fault after 6 cycles and trip the faulted transformer.
FLT9016-3PH	P1	3 phase fault on the GR PRAIRIE 3 (652532) to GRPR1 3 (648513) 345 kV line circuit 1, near GR PRAIRIE 3. a. Apply fault at the GR PRAIRIE 3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line and generators radially connected. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.
FLT16-PO1	P6	<b>PRIOR OUTAGE of the HOLT.CO3 (640510) to THEDFRD3 (640500) 345 kV line circuit 1</b> 3 phase fault on the HOLT.CO3 (640510) to GPPRAR1-LNX3 (652832) 345 kV line circuit 1, near HOLT.CO3. a. Apply fault at the HOLT.CO3 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.

Table 6-1 continued

Fault ID	Planning Event	Fault Descriptions
FLT17-PO1	P6	<p><b>PRIOR OUTAGE of the HOLT.CO3 (640510) to THEDFRD3 (640500) 345 kV line circuit 1</b>                      3 phase fault on the HOLT.CO3 (640510) to GR ISLD-LNX3 (653871) 345 kV line circuit 1, near HOLT.CO3.                      a. Apply fault at the HOLT.CO3 345 kV bus.                      b. Clear fault after 6 cycles by tripping the faulted line.                      c. Wait 20 cycles, and then re-close the line in (b) back into the fault.                      d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.</p>
FLT16-PO2	P6	<p><b>PRIOR OUTAGE of the HOLT.CO3 (640510) to GR ISLD-LNX3 (653871) 345 kV line circuit 1</b>                      3 phase fault on the HOLT.CO3 (640510) to GPPRAR1-LNX3 (652832) 345 kV line circuit 1, near HOLT.CO3.                      a. Apply fault at the HOLT.CO3 345 kV bus.                      b. Clear fault after 6 cycles by tripping the faulted line.                      c. Wait 20 cycles, and then re-close the line in (b) back into the fault.                      d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.</p>
FLT18-PO2	P6	<p><b>PRIOR OUTAGE of the HOLT.CO3 (640510) to GR ISLD-LNX3 (653871) 345 kV line circuit 1</b>                      3 phase fault on the HOLT.CO3 (640510) to THEDFRD3 (640500) 345 kV line circuit 1, near HOLT.CO3.                      a. Apply fault at the HOLT.CO3 345 kV bus.                      b. Clear fault after 6 cycles by tripping the faulted line.                      c. Wait 20 cycles, and then re-close the line in (b) back into the fault.                      d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.</p>
FLT17-PO3	P6	<p><b>PRIOR OUTAGE of the HOLT.CO3 (640510) to GPPRAR1-LNX3 (652832) 345 kV line circuit 1</b>                      3 phase fault on the HOLT.CO3 (640510) to GR ISLD-LNX3 (653871) 345 kV line circuit 1, near HOLT.CO3.                      a. Apply fault at the HOLT.CO3 345 kV bus.                      b. Clear fault after 6 cycles by tripping the faulted line.                      c. Wait 20 cycles, and then re-close the line in (b) back into the fault.                      d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.</p>
FLT18-PO3	P6	<p><b>PRIOR OUTAGE of the HOLT.CO3 (640510) to GPPRAR1-LNX3 (652832) 345 kV line circuit 1</b>                      3 phase fault on the HOLT.CO3 (640510) to THEDFRD3 (640500) 345 kV line circuit 1, near HOLT.CO3.                      a. Apply fault at the HOLT.CO3 345 kV bus.                      b. Clear fault after 6 cycles by tripping the faulted line.                      c. Wait 20 cycles, and then re-close the line in (b) back into the fault.                      d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault.</p>
FLT1001-SB	P4	<p><b>Stuck Breaker on at GR PRAIRIE 3 (652532)</b>                      a. Apply single-phase fault at GR PRAIRIE 3 (652532) on the 345kV bus.                      b. Clear fault after 16 cycles and trip the following elements                      c. Trip the bus GR PRAIRIE 3 (652532) and the generators radially connected</p>
FLT1002-SB	P4	<p><b>Stuck Breaker on at HOLT. CO3 (640510)</b>                      a. Apply single-phase fault at HOLT. CO3 (640510) on the 345kV bus.                      b. Clear fault after 16 cycles and trip the following elements                      c. Trip the HOLT.CO3 (640510) to GPPRAR1-LNX3 (652832) 345 kV line circuit 1.                      d. Trip the HOLT.CO3 (640510) to GR ISLD-LNX3 (653871) 345 kV line circuit 1.</p>
FLT1003-SB	P4	<p><b>Stuck Breaker on at THEDFRD3 (640500)</b>                      a. Apply single-phase fault at THEDFRD3 (640500) on the 345kV bus.                      b. Clear fault after 16 cycles and trip the following elements                      c. Trip the bus THEDFRD3 (640500).</p>
FLT1004-SB	P4	<p><b>Stuck Breaker on at GRPRAR2-LNX3 (652833)</b>                      a. Apply single-phase fault at GRPRAR2-LNX3 (652833) on the 345kV bus.                      b. Clear fault after 16 cycles and trip the following elements                      c. Trip the bus GRPRAR2-LNX3 (652833).</p>

**Table 6-1 continued**

Fault ID	Planning Event	Fault Descriptions
FLT1005-SB	P4	<p><b>Stuck Breaker on at GRPRAR1-LNX3 (652832)</b>                      a. Apply single-phase fault at GRPRAR1-LNX3 (652832) on the 345kV bus.                      b. Clear fault after 16 cycles and trip the following elements                      c. Trip the bus GRPRAR2-LNX3 (652832).</p>
FLT1006-SB	P4	<p><b>Stuck Breaker on at GR ISLD3 (653571)</b>                      a. Apply single-phase fault at GR ISLD3 (653571) on the 345kV bus.                      b. Clear fault after 16 cycles and trip the following elements                      c. Trip the GR ISLD3 (653571) to MCCOOL 3 (640271) 345 kV line circuit 1.                      d. Trip the GI KU1A 345 kV (653571)/ 230 kV (640200)/ 13.8 kV (653314) XFMR CKT 1.</p>
FLT1007-SB	P4	<p><b>Stuck Breaker on at GR ISLD3 (653571)</b>                      a. Apply single-phase fault at GR ISLD3 (653571) on the 345kV bus.                      b. Clear fault after 16 cycles and trip the following elements                      c. Trip the GR ISLD3 (653571) to SWEET W3 (640374) 345 kV line circuit 1.                      d. Trip the GI KU1B 345 kV (653571)/ 230 kV (640200)/ 13.8 kV (653316) XFMR CKT 2.</p>
FLT1008-SB	P4	<p><b>Stuck Breaker on at GR ISLD3 (653571)</b>                      a. Apply single-phase fault at GR ISLD3 (653571) on the 345kV bus.                      b. Clear fault after 16 cycles and trip the following elements                      c. Trip the bus GR ISLD-LNX3 (653871).                      d. Trip the SHUNT at bus GR ISLD3 (653571).</p>
FLT1009-SB	P4	<p><b>Stuck Breaker on at GR ISLD-LNX3 (653871)</b>                      a. Apply single-phase fault at GR ISLD-LNX3 (653871) on the 345kV bus.                      b. Clear fault after 16 cycles and trip the following elements                      c. Trip the bus GR ISLD-LNX3 (653871).</p>

**6.3 Results**

Table 6-2 shows the results of the fault events simulated for each of the four modified cases. The associated stability plots are provided in Appendix D.

**Table 6-2: GEN-2015-023 Dynamic Stability Results**

Fault ID	19WP			21LL			21SP			26SP		
	Volt Violation	Volt Recovery	Stable	Volt Violation	Volt Recovery	Stable	Volt Violation	Volt Recovery	Stable	Volt Violation	Volt Recovery	Stable
FLT16-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT17-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT18-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT19-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9001-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9002-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9003-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9004-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9005-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9006-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9007-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9008-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9009-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9010-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9011-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9012-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9013-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9014-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9015-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT9016-3PH	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT1001-SB	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT1002-SB	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT1003-SB	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT1004-SB	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT1005-SB	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT1006-SB	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT1007-SB	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT1008-SB	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable

Table 6-2 continued

Fault ID	19WP			21LL			21SP			26SP		
	Volt Violation	Volt Recovery	Stable	Volt Violation	Volt Recovery	Stable	Volt Violation	Volt Recovery	Stable	Volt Violation	Volt Recovery	Stable
FLT1009-SB	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT16-PO1	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT17-PO1	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT16-PO2	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT18-PO2	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT17-PO3	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable
FLT18-PO3	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable	Pass	Pass	Stable

The modified GEN-2015-023 stability model was set to regulate the POI voltage (Holt County, 640510). However, nearby generators with a POI one bus away also try to control the network voltage which would require coordination as shown in Figure 6-1. The existing stability model for the GEN-2015-023 project in the DISIS-2017-001 case was set to regulate the local generator terminal voltage. The modified GEN-2015-023 stability model was changed from regulating the POI voltage to regulating the generator terminal voltage for this study and the issue was resolved as seen in Figure 6-2.

Figure 6-1: GEN-2015-023 VAR Response Regulating Remote POI Voltage





Figure 6-2: GEN-2015-023 VAR Response Regulating Local Generator Terminal Voltage



There were no damping or voltage recovery violations attributed to the GEN-2015-023 project observed during the simulated faults. Additionally, the project was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.



## 7.0 Material Modification Determination

In accordance with Attachment V of SPP's Open Access Transmission Tariff, for modifications other than those specifically permitted by Attachment V, SPP shall evaluate the proposed modifications prior to making them and inform the Interconnection Customer in writing of whether the modifications would constitute a Material Modification. Material Modification shall mean (1) modification to an Interconnection Request in the queue that has a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date; or (2) planned modification to an Existing Generating Facility that is undergoing evaluation for a Generating Facility Modification or Generating Facility Replacement, and has a material adverse impact on the Transmission System with respect to: i) steady-state thermal or voltage limits, ii) dynamic system stability and response, or iii) short-circuit capability limit; compared to the impacts of the Existing Generating Facility prior to the modification or replacement.

### 7.1 Results

SPP determined the requested modification is not a Material Modification based on the results of this Modification Request Impact Study performed by Aneden. Aneden evaluated the impact of the requested modification on the prior study results. Aneden determined that the requested modification resulted in similar dynamic stability and short circuit analyses and that the prior study power flow results are not negatively impacted.

This determination implies that any network upgrades already required by GEN-2015-023 would not be negatively impacted and that no new upgrades are required due to the requested modification, thus not resulting in a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date.

---

## 8.0 Conclusions

The Interconnection Customer for GEN-2015-023 requested a Modification Request Impact Study to assess the impact of the turbine and facility change to a configuration of 10 x GE 116 2.3 MW + 98 x GE 127 2.82 MW for a total generating capacity of 299.36 MW.

In addition, the modification request included changes to the collection system, generator step-up transformers, generation interconnection line, main substation transformer, and reactive power devices.

SPP determined that power flow should not be performed based on the POI MW injection decrease of 0.49% compared to the recently studied DISIS-2017-001 power flow models. However, SPP determined that while the modification used the same turbine manufacturer, GE, the generator model change from GEWTG2 to REGCAU1 required short circuit and dynamic stability analyses. The scope of this modification request study included charging current compensation analysis, short circuit analysis, and dynamic stability analysis.

The results of the charging current compensation analysis performed using the 2019 Winter Peak, 2021 Light Load, 2021 Summer Peak, and 2028 Summer Peak models showed that the GEN-2015-023 project needed 25.81 MVAR of reactor shunts on the 34.5 kV bus of the project substation with the modifications in place, an increase from the 17.3 MVAR found for the existing GEN-2015-023 configuration calculated using the DISIS-2017-001 models. This is necessary to offset the capacitive effect on the transmission network caused by the project's transmission line and collector system during low-wind or no-wind conditions. The information gathered from the charging current compensation analysis is provided as information to the Interconnection Customer and Transmission Owner (TO) and/or Transmission Operator. The applicable reactive power requirements will be further reviewed by the Transmission Owner and/or Transmission Operator.

The results from the short circuit analysis with the updated topology showed that the maximum GEN-2015-023 contribution to three-phase fault currents in the immediate systems at or near GEN-2015-023 was not greater than 1.14 kA for the 2021SP and 2028SP models. All three-phase fault current levels within 5 buses of the POI with the GEN-2015-023 generators online were below 44 kA for the 2021SP and 2028SP models.

The dynamic stability analysis was performed using the four modified study models, 2019 Winter Peak, 2021 Light Load, 2021 Summer Peak, and 2028 Summer Peak. Up to 35 events were simulated, which included three-phase faults, three-phase faults on prior outage cases, and single-line-to-ground stuck breaker faults.

The modified GEN-2015-023 stability model was set to regulate the POI voltage (Holt County, 640510) whereas the existing stability model in the DISIS-2017-001 case was set to regulate the local generator terminal voltage. The modified GEN-2015-023 stability model was changed from regulating the POI voltage to regulating the generator terminal voltage for this study to avoid the need for voltage control coordination with nearby generators.

The results of the dynamic stability analysis showed that there were no damping or voltage recovery violations attributed to the GEN-2015-023 project observed during the simulated faults. Additionally, the project was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

The requested modification has been determined by SPP to not be a Material Modification. The requested modification does not have a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date.

In accordance with FERC Order No. 827, the generating facility will be required to provide dynamic reactive power within the range of 0.95 leading to 0.95 lagging at the high-side of the generator substation.

It is likely that the customer may be required to reduce its generation output to 0 MW in real-time, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of transmission service or delivery rights. If the customer wishes to obtain deliverability to final customers, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the customer.