


GEN-2015-047
Impact Restudy for
Generator Modification
(Turbine Change)

May 2017
Generator Interconnection



Revision History

Date	Author	Change Description
5/25/2017	SPP	GEN-2015-047 Impact Restudy for Generator Modification Report Issued

Executive Summary

The GEN-2015-047 Interconnection Customer has requested a modification to its Generator Interconnection Request to change wind turbine generators for its project. Originally, it consisted of one hundred fifty (150) Vestas V110 VCSS 2.0 MW wind turbine generators for a total nameplate capacity of 300.0 MW. The requested change is for one hundred nine (109) GE 2.5 MW wind turbines and eleven (11) GE 2.3 MW for a total nameplate capacity of 297.8 MW. The point of interconnection (POI) is the Oklahoma Gas & Electric (OKGE) Sooner 345kV substation.

The study models used were the 2016 winter, 2017 summer, and 2025 summer models that included Interconnection Requests and assigned network upgrades through DISIS-2015-002-2.

Stability analysis has determined with all assigned Network Upgrades in service, generators in the monitored areas remained stable and within the pre-contingency, voltage recovery, and post fault voltage recovery criterion of 0.7pu to 1.2pu for the entire modeled disturbances. Additionally, the project wind farm was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

Power factor analysis for each generation project was performed on the current study 2016 winter peak, 2017 summer peak, and 2025 summer peak cases with identified system upgrades. As reactive power is required for GEN-2015-047, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.

An analysis was conducted to determine the capacitive effects on the transmission system caused by the generator lead and collector system during periods of reduced generation. The generating facility is required to provide reactive compensation that can inject approximately 37 MVAR of inductive reactance during periods of reduced generation. Such compensation can be provided either by discrete reactive devices or by the generator itself if it possesses that capability.

Short Circuit analysis was conducted using the current study upgrade 2017 summer peak and 2025 summer peak cases.

With the assumptions outlined in this report and with all the required network upgrades from the DISIS-2015-002-2 in place, GEN-2015-047 with the GE 2.5 MW and GE 2.3 MW wind turbine generators should be able to interconnect reliably to the SPP transmission grid. The proposed change in wind turbine generators is not a Material Modification.

It should be noted that this study analyzed the requested modification to change inverter technology, manufacturer, and layout. Power flow analysis was not performed. This study analyzed many of the most probable contingencies, but it is not an all-inclusive list and cannot account for every operational situation. It is likely that the customer may be required to reduce its generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of delivery or transmission service. If the customer wishes to sell power from the facility, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the Customer.

Table of Contents

Revision History	1
Executive Summary	i
Table of Contents	iii
1. Introduction	1
2. Facilities	4
3. Stability Analysis	5
Model Preparation	5
Disturbances	5
Results	9
FERC LVRT Compliance	9
4. Power Factor Analysis	11
Model Preparation	11
Disturbances	11
Results	11
5. Reduced Generation Analysis	12
6. Short Circuit Analysis	13
Results	13
7. Conclusion	14
Appendix A – 2016 Winter Peak Stability Plots	15
Appendix B – 2017 Summer Peak Stability Plots	16
Appendix C – 2025 Summer Peak Stability Plots	17
Appendix D – Power Factor Analysis Results	18
Appendix E – Short Circuit Analysis Results	19

1. Introduction

The GEN-2015-047 Interconnection Customer has requested a modification to its Generator Interconnection Request to change wind turbine generators from Vestas V110 VCSS 2.0 MW wind turbines to GE 2.5 MW and GE 2.3 MW wind turbines. Originally, it consisted of one hundred fifty (150) Vestas V110 VCSS 2.0MW wind turbines for a total 300.0 MW. The requested change is shown in **Table 1-1**.

Table 1-1: Interconnection Request

Request	Capacity (MW)	Generator Model	Point of Interconnection
GEN-2015-047	297.8	109 x GE 2.5 MW wind turbines, and 11 x GE 2.3 MW wind turbines	Sooner 345kV (514803)

The POI is the OKGE Sooner 345kV substation. Other queued generation projects in the model are listed in **Table 1-2**.

Table 1-2: Other Queued Interconnection Requests in the Model

Request	Capacity (MW)	Generator Model	Point of Interconnection
ASGI-2010-006	150	GE 1.5MW	Remington 138kV (301369)
ASGI-2014-014	54.3 Summer 56.4 Winter	GENSAL	Ferguson 69kV (512664)
ASGI-2015-004	54.3 Summer 56.364 Winter	GENSAL	Coffeyville Municipal Light & Power Northern Industrial Park Substation 69kV (512735)
GEN-2002-004	199.5	GE 1.5MW	Lathams 345kV (532800)
GEN-2005-013	199.8	Vestas V90 1.8MW	Caney River 345kV (532780)
GEN-2007-025	299.2	GE 1.6MW	Viola 345kV (532798)
GEN-2008-013	300	GE 1.68MW	Hunter 345kV (515476)
GEN-2008-021	1261 Summer 1283 Winter	GENROU	Wolf Creek 345kV (532797)
GEN-2008-098	100.8	Gamesa 2.0MW, and Gamesa 2.1MW	Tap Wolf Creek to LaCygne 345kV line (560004)
GEN-2009-025	59.8	Siemens 2.3MW	Tap Deer Creek to Sinclair Blackwell 69kV (Nardins 515528)
GEN-2010-003 (Phase II to GEN- 2008-098)	100.8	Gamesa 2.0MW, and Gamesa 2.1MW	Tap Wolf Creek to LaCygne 345kV line (560004)
GEN-2010-005	299.2	GE 1.6MW	Viola 345kV (532798)
GEN-2010-055	4.8	GENROU	Wekiwa 138kV (509757)
GEN-2011-057	150	Vestas V110 2.0MW	Creswell 138kV (532981)
GEN-2012-032	299	Siemens 2.3MW	Tap Rose Hill-Sooner 345kV (Open Sky 515621)
GEN-2012-033	98.055	GE 1.715MW, and GE 1.79MW	Breckenridge 138kV (514815)
GEN-2012-041	85 Summer 121.5 Winter	GENROU	Tap Rose Hill-Sooner 345kV (Ranch Road 515576)
GEN-2013-012	4 x 168MW Summer 4 x 215MW Winter	GENROU (514910) (514911) (514912) (514942)	Redbud 345kV (514909)

Table 1-2: Other Queued Interconnection Requests in the Model

Request	Capacity (MW)	Generator Model	Point of Interconnection
GEN-2013-028	516.4 Summer 559.5 Winter	GENROU (583743, 583746)	Tap on Tulsa N to GRDA1 345kV (512865)
GEN-2013-029	299	Siemens 2.3MW	Renfrow 345kV (515543)
GEN-2014-001	199.5	Gamesa 2.1MW	Tap Wichita to Emporia Energy Center 345kV (562476)
GEN-2014-028 (Uprate to GEN-2004-017)	35 (uprate) (256 summer 259 winter)	GENROU	Riverton 161kV (547469)
GEN-2014-064	248.4	GE 2.3MW	Otter 138kV (514708)
GEN-2015-001	199.8	Vestas V126 3.3MW, and Vestas V126 3.3MW de-rated to 3.0MW	Ranch Road 345kV (515576)
GEN-2015-015	154.56	Siemens 2.3MW with Power Boost (115kW => 2.415MW)	Tap Medford Tap to Coyote 138kV (560031)
GEN-2015-016	200.0	Vestas V110 2.0MW	Tap Centerville to Marmaton 161kV (560029)
GEN-2015-024	217.8	GE 1.8MW	Tap Thistle to Wichita 345kV, ckt1&2 (560033)
GEN-2015-025	215.95	GE 1.8MW, and GE 1.79MW	Tap Thistle to Wichita 345kV, ckt1&2 (560033)
GEN-2015-030	200.1	GE 2.3MW	Sooner 345kV (514803)
GEN-2015-034	200	Vestas V110 2.0MW	Ranch Road 345kV (515576)
GEN-2015-052	300	Vestas V110 2.0MW	Tap Opensky to Rose Hill 345 kV (560053)
GEN-2015-062 (Uprate to GEN-2012-033)	4.505	GE 1.8MW (uprated 53 GE 1.715MW)	Breckenridge 138kV (514815)
GEN-2015-063	300	Vestas V110 2.0MW	Tap Woodring to Mathewson 345 kV (560055)
GEN-2015-066	248.4	GE 2.3MW	Tap Cleveland to Sooner 345 kV (560056)
GEN-2015-069	300	Vestas V110 2.0MW	Union Ridge 230kV (532874)
GEN-2015-073	200.1	Siemens 2.3MW	Emporia 345kV (532768)
GEN-2015-083	124.2	GE 2.3MW	Belle Plain 138kV (533063)
GEN-2015-090	220	GE 2.0MW	Tap Wichita to Thistle 345kV at GEN-2015-024 (584660) 345kV

A stability analysis was performed for the change in wind turbines. The analysis was performed on three (3) seasonal models including 2016 winter peak (16WP), the 2017 summer peak (17SP), and the 2025 summer peak (25SP) cases. These cases are modified versions of the 2015 model series of Model Development Working Group (MDWG) dynamic study models that included upgrades and Interconnection Requests through DISIS-2015-002-2.

Stability Analysis determines the impacts of the new interconnecting project on the stability and voltage recovery of the nearby systems and the ability of the interconnecting project to meet FERC Order 661A. If problems with stability or voltage recovery are identified, the need for reactive compensation or system upgrades is investigated. The contingencies listed in **Table 3-1** were used in the stability analysis.

Power Factor Analysis determines the power factor at the point of interconnection (POI) for the interconnection projects for pre-contingency and post-contingency conditions. The contingencies used in the power factor analysis are a subset of the stability analysis contingencies shown in **Table 3-1**.

Reduced Generation Analysis was performed to determine reactor inductive amounts to compensate for the capacitive effects on the transmission system caused by the interconnecting project's generator lead transmission line and collector systems during low or reduced generation conditions. The results of the analysis are illustrated in **Figure 5-2**.


Short Circuit Analysis was conducted using the current study upgrade 2017 summer peak and 2025 summer peak cases. The results from the Short circuit analysis are shown in **Appendix E**.

Nothing in this System Impact Study constitutes a request for transmission service or grants the Interconnection Customer any rights to transmission service. If the customer wishes to sell power from the facility, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the Customer.

2. Facilities

A one-line PSS/E slider drawing from the 16WP case is shown in **Figure 2-1** for GEN-2015-047. The POI is the OKGE Sooner 345kV substation.

Figure 2-1: GEN-2015-047 One-line Diagram



3. Stability Analysis

Transient stability analysis is used to determine if the transmission system can maintain angular stability and ensure bus voltages stay within planning criteria bandwidth during and after a disturbance while considering the addition of a generator interconnection request.

Model Preparation

Transient stability analysis was performed using modified versions of the 2015 series of Model Development Working Group (MDWG) dynamic study models including the 2016 winter peak, 2017 summer peak, and the 2025 summer peak seasonal models. The cases are then loaded with prior queued interconnection requests and network upgrades assigned to those interconnection requests through DISIS-2015-002-2. Finally the prior queued and study generation are dispatched into the SPP footprint. Initial simulations are then carried out for a no-disturbance run of twenty (20) seconds to verify the numerical stability of the model.

Disturbances

Twenty-five (25) contingencies were identified for use in this study and are listed in **Table 3-1**. These contingencies are faults at locations defined by SPP Generation Interconnection Staff. These contingencies include three-phase and single-phase N-1. Single-phase line faults were simulated by applying fault impedance to the positive sequence network at the fault location to represent the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the specified fault location of approximately 60% of pre-fault voltage. This method is in agreement with SPP current practice.

Except for transformer faults, the typical sequence of events for a three-phase and single-phase fault is as follows:

1. apply fault at particular location
2. continue fault for five (5) cycles, clear the fault by tripping the faulted facility
3. after an additional twenty (20) cycles, re-close the previous facility back into the fault
4. continue fault for five (5) additional cycles
5. trip the faulted facility and remove the fault

Transformer faults are typically modeled as three-phase faults, unless otherwise noted. The sequence of events for a transformer fault is as follows:

1. apply fault for five (5) cycles
2. clear the fault by tripping the affected transformer facility (unless otherwise noted there will be no re-closing into a transformer fault)

The SPP areas monitored during the stability analysis were:

- 330: Associated Electric Cooperative Inc. (AECI)
- 520: American Electric Power (AEPW)
- 523: Grand River Dam Authority (GRDA)
- 524: Oklahoma Gas and Electric Company (OKGE)
- 525: Western Farmers Electric Cooperative (WFEC)

- 527: Oklahoma Municipal Power Authority (OMPA)
- 536: Westar Energy, Inc. (WERE)

Table 3-1: Contingencies Evaluated

Cont. No.	Contingency Name	Description
0	FLT_00_NOFAULT	No Fault Conditions
1	FLT_01_SOONER7_RANCHR7_345KV_3PH	3 phase fault on the Sooner (514803) to Ranch Road (515576) 345kV line, near Sooner. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
2	FLT_02_SOONER7_RANCHR7_345KV_1PH	Single phase fault on the Sooner (514803) to Ranch Road (515576) 345kV line, near Sooner. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
3	FLT_03_SOONER7_G16061TAP_345KV_3PH	3 phase fault on the Sooner (514803) to G16-061 Tap (560084) 345kV line, near Sooner. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
4	FLT_04_SOONER7_SPRNGCK7_345KV_3PH	3 phase fault on the Sooner (514803) to Spring Creek (514881) 345kV line, near Sooner. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
5	FLT_05_SOONER7_G15066T_345KV_3PH	3 phase fault on the Sooner (514803) to G15-066 Tap (560056) 345kV line, near Sooner. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
6	FLT_06_G16061TAP_WOODRNG7_345KV_3PH	3 phase fault on the G16-061 Tap (560084) to Woodring (514715) 345kV line, near G16-061 Tap. a. Apply fault at the G16-061 Tap 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
7	FLT_07_WOODRNG7_G15063T_345KV_3PH	3 phase fault on the Woodring (514715) to G15-063 Tap (560055) 345kV line, near Woodring. a. Apply fault at the Woodring 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
8	FLT_08_WOODRNG7_HUNTERS7_345KV_3PH	3 phase fault on the Woodring (514715) to Hunters (515476) 345kV line, near Woodring. a. Apply fault at the Woodring 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.

Table 3-1: Contingencies Evaluated

Cont. No.	Contingency Name	Description
9	FLT_09_G15066T_CLEVLND7_345kV_3PH	3 phase fault on the G15-066 Tap (560056) to Cleveland (512694) 345kV line, near G15-066 Tap. a. Apply fault at the G15-066 Tap 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
10	FLT_10_SPRNGCK7_NORTWST7_345kV_3PH	3 phase fault on the Spring Creek (514881) to Northwest (514880) 345kV line, near Spring Creek. a. Apply fault at the Spring Creek 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
11	FLT_11_RANCHR7_OPENSKY7_345kV_3PH	3 phase fault on the Ranch Road (515576) to Open Sky (515621) 345kV line, near Ranch Road. a. Apply fault at the Ranch Road 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
12	FLT_12_SOONER4_SNRPMPT4_138kV_3PH	3 phase fault on the Sooner (514802) to Sooner Pump Tap (514798) 138kV line, near Sooner. a. Apply fault at the Sooner 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
13	FLT_13_SOONER4_PERRY4_138kV_3PH	3 phase fault on the Sooner (514802) to Perry (514707) 138kV line, near Sooner. a. Apply fault at the Sooner 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
14	FLT_14_SOONER4_MILLERT4_138kV_3PH	3 phase fault on the Sooner (514802) to Miller Tap (514704) 138kV line, near Sooner. a. Apply fault at the Sooner 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
15	FLT_15_SOONER4_MORISNT4_138kV_3PH	3 phase fault on the Sooner (514802) to Morrison Tap (515447) 138kV line, near Sooner. a. Apply fault at the Sooner 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
16	FLT_16_SOONER7_RANCHR7SB_345kV_1PH	Single phase fault with stuck breaker on the Sooner (514803) to Ranch Road (515576) 345kV line, near Sooner. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 16 cycles by tripping the faulted line.
17	FLT_17_RANCHR7_OPENSKY7SB_345kV_1PH	Single phase fault with stuck breaker on the Ranch Road (515576) to Open Sky (515621) 345kV line, near Ranch Road. a. Apply fault at the Ranch Road 345kV bus. b. Clear fault after 16 cycles by tripping the faulted line.
18	FLT_18_SOONER4_SNRPMPT4SB_138kV_1PH	Single phase fault with stuck breaker on the Sooner (514802) to Sooner Pump Tap (514798) 138kV line, near Sooner. a. Apply fault at the Sooner 138kV bus. b. Clear fault after 16 cycles by tripping the faulted line.

Table 3-1: Contingencies Evaluated

Cont. No.	Contingency Name	Description
19	FLT_19_SOONER7_SPRNGCK7PO_345kV_3PH	<p>Prior outage on the Sooner (514803) to Ranch Road (515576) 345kV line: 3 phase fault on the Sooner (514803) to Spring Creek (514881) 345kV line, near Sooner 345kV. a. Prior Outage Sooner to Ranch Road 345kV. b. Apply fault at the Sooner 345kV bus. c. Clear fault after 5 cycles by tripping the faulted line. d. Wait 20 cycles, and then re-close the line in (b) back into the fault. e. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p>
20	FLT_20_SOONER7_RANCHR7PO_345kV_3PH	<p>Prior outage on the Sooner (514803) to Spring Creek (514881) 345kV line: 3 phase fault on the Sooner (514803) to Ranch Road (515576) 345kV line, near Sooner 345kV. a. Prior Outage Sooner to Spring Creek 345kV. b. Apply fault at the Sooner 345kV bus. c. Clear fault after 5 cycles by tripping the faulted line. d. Wait 20 cycles, and then re-close the line in (b) back into the fault. e. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p>
21	FLT_21_SOONER7_G16061TAPPO_345kV_3PH	<p>Prior outage on the Sooner (514803) to Spring Creek (514881) 345kV line: 3 phase fault on the Sooner (514803) to G16-061 Tap (560084) 345kV line, near Sooner 345kV. a. Prior Outage Sooner to Spring Creek 345kV. b. Apply fault at the Sooner 345kV bus. c. Clear fault after 5 cycles by tripping the faulted line. d. Wait 20 cycles, and then re-close the line in (b) back into the fault. e. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p>
22	FLT_22_SOONER7_SPRNGCK7PO_345kV_3PH	<p>Prior outage on the Sooner 345kV (514803) to Sooner 138kV (514802) to Sooner 13.8kV (515760) transformer: 3 phase fault on the Sooner (514803) to Spring Creek (514881) 345kV line, near Sooner 345kV. a. Prior Outage Sooner 345kV to Sooner 138kV transformer. b. Apply fault at the Sooner 345kV bus. c. Clear fault after 5 cycles by tripping the faulted line. d. Wait 20 cycles, and then re-close the line in (b) back into the fault. e. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p>
23	FLT_23_SOONER4_SOONER7SB_138_345kV_1PH	<p>Single phase fault with stuck breaker on the Sooner 138kV (514802) to Sooner 345kV (514803) to Sooner 13.8kV (515760) transformer, near Sooner. a. Apply fault at the Sooner 138kV bus. b. Clear fault after 16 cycles by tripping the faulted line.</p>
24	FLT_24_SOONER7_SOONER4_345_138kV_3PH	<p>3 phase fault on the Sooner 345kV (514803) to Sooner 138kV (514802) to Sooner 13.8kV (515760) transformer, near Sooner 345kV. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer.</p>
25	FLT_25_WOODRNG7_WOODRNG4_345_138kV_3PH	<p>3 phase fault on the Woodring 345kV (514715) to Woodring 138kV (514715) to Woodring 13.8kV (515770) transformer, near Woodring 345kV. a. Apply fault at the Woodring 345kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer.</p>

Results

The stability analysis was performed and the results are summarized in **Table 3-2**. The stability plots will be available upon customer request.

Table 3-2: Contingency Results

Contingency Number and Name		Three Phase		
		2016WP	2017SP	2025SP
0	FLT_00_NOFAULT	STABLE	STABLE	STABLE
1	FLT_01_SOONER7_RANCHR7_345kV_3PH	STABLE	STABLE	STABLE
2	FLT_02_SOONER7_RANCHR7_345kV_1PH	STABLE	STABLE	STABLE
3	FLT_03_SOONER7_G16061TAP_345kV_3PH	STABLE	STABLE	STABLE
4	FLT_04_SOONER7_SPRNGCK7_345kV_3PH	STABLE	STABLE	STABLE
5	FLT_05_SOONER7_G15066T_345kV_3PH	STABLE	STABLE	STABLE
6	FLT_06_G16061TAP_WOODRNG7_345kV_3PH	STABLE	STABLE	STABLE
7	FLT_07_WOODRNG7_G15063T_345kV_3PH	STABLE	STABLE	STABLE
8	FLT_08_WOODRNG7_HUNTERS7_345kV_3PH	STABLE	STABLE	STABLE
9	FLT_09_G15066T_CLEVLND7_345kV_3PH	STABLE	STABLE	STABLE
10	FLT_10_SPRNGCK7_NORTWST7_345kV_3PH	STABLE	STABLE	STABLE
11	FLT_11_RANCHR7_OPENSKY7_345kV_3PH	STABLE	STABLE	STABLE
12	FLT_12_SOONER4_SNRPMPT4_138kV_3PH	STABLE	STABLE	STABLE
13	FLT_13_SOONER4_PERRY4_138kV_3PH	STABLE	STABLE	STABLE
14	FLT_14_SOONER4_MILLERT4_138kV_3PH	STABLE	STABLE	STABLE
15	FLT_15_SOONER4_MORISNT4_138kV_3PH	STABLE	STABLE	STABLE
16	FLT_16_SOONER7_RANCHR7SB_345kV_1PH	STABLE	STABLE	STABLE
17	FLT_17_RANCHR7_OPENSKY7SB_345kV_1PH	STABLE	STABLE	STABLE
18	FLT_18_SOONER4_SNRPMPT4SB_138kV_1PH	STABLE	STABLE	STABLE
19	FLT_19_SOONER7_SPRNGCK7PO_345kV_3PH	STABLE	STABLE	STABLE
20	FLT_20_SOONER7_RANCHR7PO_345kV_3PH	STABLE	STABLE	STABLE
21	FLT_21_SOONER7_G16061TAPPO_345kV_3PH	STABLE	STABLE	STABLE
22	FLT_22_SOONER7_SPRNGCK7PO_345kV_3PH	STABLE	STABLE	STABLE
23	FLT_23_SOONER4_SOONER7SB_138_345kV_1PH	STABLE	STABLE	STABLE
24	FLT_24_SOONER7_SOONER4_345_138kV_3PH	STABLE	STABLE	STABLE
25	FLT_25_WOODRNG7_WOODRNG4_345_138kV_3PH	STABLE	STABLE	STABLE

FERC LVRT Compliance

FERC Order 661A places specific requirements on wind farms through its Low Voltage Ride Through (LVRT) provisions. For Interconnection Agreements signed after December 31, 2006, wind farms shall stay on line for faults at the POI that draw the voltage down at the POI to 0.0 pu. The faults listed below in **Table 3-3** were tested to meet Order 661A LVRT provisions. GEN-2015-047 was found to be in compliance with FERC Order 661A.

Table 3-3 LVRT Contingencies

Contingency Name	Description
FLT_01_SOONER7_RANCHR7_345kV_3PH	3 phase fault on the Sooner (514803) to Ranch Road (515576) 345kV line, near Sooner. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
FLT_03_SOONER7_G16061TAP_345kV_3PH	3 phase fault on the Sooner (514803) to G16-061 Tap (560084) 345kV line, near Sooner. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.

Table 3-3 LVRT Contingencies

Contingency Name	Description
FLT_04_SOONER7_SPRNGCK7_345kV_3PH	3 phase fault on the Sooner (514803) to Spring Creek (514881) 345kV line, near Sooner. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
FLT_05_SOONER7_G15066T_345kV_3PH	3 phase fault on the Sooner (514803) to G15-066 Tap (560056) 345kV line, near Sooner. a. Apply fault at the Sooner 345kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.

4. Power Factor Analysis

The power factor analysis was performed for each project included in this study and is designed to demonstrate the reactive power requirements at the point of interconnection (POI) using the current study upgrade cases. For all projects that require reactive power, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the POI.

Model Preparation

For each project included in this study, as well as previous queued projects modeled at the same POI, the projects were turned off for the power factor analysis. The projects were replaced by an equivalent generator located at the POI producing the total MW of the projects at that POI and 0.0 Mvar capability.

A Mvar generator without limits was modeled at the interconnection project POI to hold a voltage schedule at the POI consistent with the greater of the voltage schedule in the base case or unity (1.0 pu) voltage.

Disturbances

Each N-1 contingency evaluated in the Stability Analysis found in **Table 3-1** was also included in the determination of the power factor requirements.

Results

The power factor ranges are summarized in **Table 4-1** and the resultant ranges are shown **Table D-1**. The analysis showed that reactive power is required for the study project, the final requirement in the Generation Interconnection Agreement (GIA) for each project will be the pro-forma 95% lagging to 95% leading at the POI.

For analyzing power factor results a positive Q (Mvar) output indicates that the equivalent generator is supplying reactive power to the system, implying a lagging power factor. A negative Q (Mvar) output indicates that the equivalent generator is absorbing reactive power from the system, implying a leading power factor.

Table 4-1: Summary of Power Factor Analysis at the POI

Request	Capacity (MW)	Point of Interconnection (POI)	Fuel	Generator	Lagging (providing Mvars)	Leading (absorbing Mvars)
GEN-2015-047	297.8	Sooner 345kV (514803)	Wind	109 x GE 2.5MW = 272.5MW, and 11 x GE 2.3MW = 25.3MW	0.95	0.95

NOTE: As reactive power is required for the project, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.

5. Reduced Generation Analysis

A low generation analysis was performed for GEN-2015-047 to determine the capacitive charging current injected at the POI from the generation facility.

The project inverters and capacitors (if any) were turned off in the study case. **Figure 5-1** shows the resulting reactive power injection (approximately 37 Mvar) at the POI that is due to the capacitance of the project's 34.5 kV collector system transmission lines and of the transmission lead that connects the 345/34.5 kV transformer to the POI.

A shunt reactor was added at the GEN-2015-047 project substation 34.5 kV bus to bring the Mvar flow into the POI down to approximately zero as shown in **Figure 5-2**. A reactor of approximately 37 Mvar installed on the low side of the 345/34.5 kV transformer will negate the capacitive effect of the project at the POI.

Figure 5-1: GEN-2015-047 with inverters turned off





Figure 5-2: GEN-2015-047 with inverters turned off and 37 Mvar reactor at 34.5kV bus



6. Short Circuit Analysis

The short circuit analysis was performed on the 2017 & 2025 Summer Peak power flow cases using the PSS/E ASCC program. Since the power flow model does not contain negative and zero sequence data, only three-phase symmetrical fault current levels were calculated at the point of interconnection up to and including five levels away.

Short Circuit Analysis was conducting using flat conditions with the following PSS/E ASCCC program settings:

- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-/0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-/0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

Results

The results of the short circuit analysis are shown in **Appendix E**; 2017 summer peak results in **Table E-1** and 2025 summer peak results in **Table E-2**.

7. Conclusion

The GEN-2015-047 Interconnection Customer has requested a modification to its Generator Interconnection Request to change from Vestas V110 2.0 MW wind turbines to GE 2.5 MW and GE 2.3 MW wind turbines. Originally, it consisted of one hundred fifty (150) Vestas V110 VCSS 2.0MW wind turbines for a total 300.0 MW. The requested change is one hundred nine (109) GE 2.5 MW wind turbines and eleven (11) GE 2.3 MW for a total nameplate capacity of 297.8 MW. The point of interconnection (POI) is the Oklahoma Gas & Electric (OKGE) Sooner 345kV substation.

Stability analysis has determined that with all previously assigned Network Upgrades in service, generators in the monitored areas remained stable and within the pre-contingency, voltage recovery, and post fault voltage recovery criterion of 0.7pu to 1.2pu for the entire modeled disturbances. Additionally, the project was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

A power factor analysis was performed for the modification request. As reactive power is required for GEN-2015-047, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the POI.

An analysis was conducted to determine the capacitive effects on the transmission system caused by the generator lead and collector system during periods of reduced generation. The generating facility is required to provide reactive compensation that can inject approximately 37 MVAR of inductive reactance during periods of reduced generation. Such compensation can be provided either by discrete reactive devices or by the generator itself if it possesses that capability.

Short Circuit analysis was conducted using the current study upgrade 2017 summer peak and 2025 summer peak cases.

With the assumptions outlined in this report and with all the required network upgrades from the DISIS 2015-002-2 in place, GEN-2015-047 with the GE 2.5 MW and GE 2.3 MW wind turbine generators should be able to interconnect reliably to the SPP transmission grid. The proposed change in wind turbine generators is not a Material Modification.

It should be noted that this study analyzed the requested modification to change generator technology, manufacturer, and layout. Power flow analysis was not performed. This study analyzed many of the most probable contingencies, but it is not an all-inclusive list and cannot account for every operational situation. It is likely that the customer may be required to reduce its generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of delivery or transmission service. If the customer wishes to sell power from the facility, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the Customer.

Appendix A – 2016 Winter Peak Stability Plots

(Available on request)

Appendix B – 2017 Summer Peak Stability Plots

(Available on request)

Appendix C – 2025 Summer Peak Stability Plots

(Available on request)

Appendix D – Power Factor Analysis Results

Table D-1: GEN-2015-047 Power Factor Analysis Results

Leading power factor is absorbing vars; Lagging power factor is providing vars												
GEN-2015-047 POI: Sooner 345 kV (514803) Power at POI (MW): 297.8				2016 Winter Peak POI Voltage = 1.006 pu			2017 Summer Peak POI Voltage = 1.010 pu			2025 Summer Peak POI Voltage = 1.010 pu		
Contingency Name		Mvars at POI	Power Factor	LAG	Mvars at POI	Power Factor	LAG	Mvars at POI	Power Factor	LAG		
0	FLT_00_NOFAULT	120.5741	0.92691	LAG	116.8946	0.93085	LAG	117.4945	0.93022	LAG		
1	FLT_01_SOONER7_RANCHR7_345kV_3PH	75.02146	0.96970	LAG	80.09245	0.96568	LAG	79.32642	0.96631	LAG		
2	FLT_02_SOONER7_RANCHR7_345kV_1PH	75.02146	0.96970	LAG	80.09245	0.96568	LAG	79.32642	0.96631	LAG		
3	FLT_03_SOONER7_G16061TAP_345kV_3PH	143.7941	0.90052	LAG	139.2509	0.90586	LAG	142.3507	0.90222	LAG		
4	FLT_04_SOONER7_SPRNGCK7_345kV_3PH	149.2601	0.89399	LAG	150.2515	0.89280	LAG	149.1773	0.89409	LAG		
5	FLT_05_SOONER7_G15066T_345kV_3PH	81.29441	0.96470	LAG	64.51218	0.97733	LAG	63.69373	0.97788	LAG		
6	FLT_06_G16061TAP_WOODRNG7_345kV_3PH	133.7865	0.91218	LAG	129.0923	0.91750	LAG	132.1771	0.91402	LAG		
7	FLT_07_WOODRNG7_G15063T_345kV_3PH	155.456	0.88649	LAG	145.1789	0.89888	LAG	142.147	0.90246	LAG		
8	FLT_08_WOODRNG7_HUNTERS7_345kV_3PH	125.6757	0.92132	LAG	117.2663	0.93046	LAG	118.9421	0.92867	LAG		
9	FLT_09_G15066T_CLEVLND7_345kV_3PH	109.0616	0.93901	LAG	91.87397	0.95556	LAG	90.6787	0.95664	LAG		
10	FLT_10_SPRNGCK7_NORTWST7_345kV_3PH	121.8746	0.9255	LAG	163.1816	0.87697	LAG	165.8819	0.87361	LAG		
11	FLT_11_RANCHR7_OPENSKY7_345kV_3PH	115.6959	0.93213	LAG	116.4239	0.93136	LAG	116.261	0.93153	LAG		
12	FLT_12_SOONER4_SNRPMPT4_138kV_3PH	122.9784	0.92429	LAG	118.9708	0.92864	LAG	119.6059	0.92795	LAG		
13	FLT_13_SOONER4_PERRY4_138kV_3PH	122.8982	0.92438	LAG	119.2488	0.92834	LAG	120.0462	0.92748	LAG		
14	FLT_14_SOONER4_MILLERT4_138kV_3PH	122.5473	0.92476	LAG	118.5246	0.92912	LAG	119.2483	0.92834	LAG		
15	FLT_15_SOONER4_MORISNT4_138kV_3PH	130.3849	0.91605	LAG	125.5912	0.92141	LAG	126.1918	0.92075	LAG		
16	FLT_16_SOONER7_RANCHR7SB_345kV_1PH	75.02146	0.96970	LAG	80.09245	0.96568	LAG	79.32642	0.96631	LAG		
17	FLT_17_RANCHR7_OPENSKY7SB_345kV_1PH	115.6959	0.93213	LAG	116.4239	0.93135	LAG	116.261	0.93153	LAG		
18	FLT_18_SOONER4_SNRPMPT4SB_138kV_1PH	122.9784	0.92429	LAG	118.9708	0.92864	LAG	119.6059	0.92795	LAG		
19	FLT_19_SOONER7_SPRNGCK7PO_345kV_3PH	149.2601	0.89399	LAG	150.2515	0.89280	LAG	149.1773	0.89409	LAG		
20	FLT_20_SOONER7_RANCHR7PO_345kV_3PH	75.02146	0.96970	LAG	80.09245	0.96568	LAG	79.32642	0.96631	LAG		
21	FLT_21_SOONER7_G16061TAPPO_345kV_3PH	143.7941	0.90052	LAG	139.2509	0.90586	LAG	142.3507	0.90222	LAG		
22	FLT_22_SOONER7_SPRNGCK7PO_345kV_3PH	149.2601	0.89399	LAG	150.2515	0.89280	LAG	149.1773	0.89409	LAG		
23	FLT_23_SOONER4_SOONER7SB_138_345kV_1PH	117.9939	0.92968	LAG	109.0629	0.93901	LAG	109.8501	0.93821	LAG		
24	FLT_24_SOONER7_SOONER4_345_138kV_3PH	117.9939	0.92968	LAG	109.0629	0.93901	LAG	109.8501	0.93821	LAG		
25	FLT_25_WOODRNG7_WOODRNG4_345_138kV_3PH	125.9128	0.92106	LAG	119.6444	0.92791	LAG	118.2651	0.92939	LAG		

Appendix E – Short Circuit Analysis Results

Table E-1: GEN-2015-047 Short Circuit Analysis Results (2017SP)

PSS®E-32.2.0 ASCC SHORT CIRCUIT CURRENTS THU, MAY 25 2017 7:47
 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO
 MDWG 17S WITH MMWG 15S, MRO 16W TOPO/16S PROF, SERC 16S

OPTIONS USED:

- FLAT CONDITIONS
- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

X----- BUS -----X	THREE PHASE FAULT
	/I+/ AN(I+)
514803 [SOONER 7 345.00] AMP	24534.4 -86.49
514802 [SOONER 4 138.00] AMP	31297.0 -86.78
514881 [SPRNGCK7 345.00] AMP	21409.2 -85.53
515576 [RANCHRD7 345.00] AMP	13729.5 -86.67
560056 [G15-066T 345.00] AMP	17948.8 -86.54
560084 [G16-061-TAP 345.00] AMP	14700.4 -84.90
584690 [GEN-2015-030345.00] AMP	18698.3 -85.92
584880 [GEN-2015-047345.00] AMP	10996.2 -83.66
512694 [CLEVLND7 345.00] AMP	14816.8 -86.33
514704 [MILLERT4 138.00] AMP	20113.8 -85.57
514707 [PERRY 4 138.00] AMP	10934.9 -83.28
514715 [WOODRNG7 345.00] AMP	16932.2 -84.82
514798 [SNRPMP4 138.00] AMP	20130.2 -85.54
514880 [NORTWST7 345.00] AMP	29358.0 -86.05
515447 [MORISNT4 138.00] AMP	13644.9 -82.93
515621 [OPENSKY7 345.00] AMP	12743.4 -86.64
529200 [OMCDLEC7 345.00] AMP	13704.2 -86.67
584450 [G1501-G1631 345.00] AMP	11047.1 -85.63
584770 [GEN-2015-034345.00] AMP	11035.0 -85.68
585040 [GEN-2015-066345.00] AMP	17784.4 -86.52
509852 [T.NO.--7 345.00] AMP	23393.4 -86.30
512729 [CLEVLND 4 138.00] AMP	16665.4 -85.45
514706 [COWCRK 4 138.00] AMP	11232.5 -82.99
514714 [WOODRNG4 138.00] AMP	18616.4 -83.30
514737 [OTOE 4 138.00] AMP	16080.7 -83.28
514743 [OSAGE 4 138.00] AMP	15537.9 -81.75
514799 [SNRPMP 4 138.00] AMP	11172.4 -80.57
514825 [KAYWIND7 345.00] AMP	12710.4 -86.63
514879 [NORTWST4 138.00] AMP	42443.1 -85.92
514901 [CIMARON7 345.00] AMP	29721.7 -85.77
514908 [ARCADIA7 345.00] AMP	24878.1 -86.46
515006 [MORRISN4 138.00] AMP	13614.8 -82.92
515011 [STILWTR4 138.00] AMP	13289.3 -80.15
515412 [DMNCRKT4 138.00] AMP	13448.6 -84.33
515476 [HUNTERS7 345.00] AMP	12038.8 -84.70
515497 [MATHWSN7 345.00] AMP	27538.0 -85.77
560053 [G15-052T 345.00] AMP	13112.9 -86.46
560055 [G15-063T 345.00] AMP	16812.0 -84.90
300138 [4CLEVLND 138.00] AMP	16667.4 -85.42

509755	[WEKIWA-7	345.00]	AMP	18588.2	-86.20
509895	[T.NO.2-4	138.00]	AMP	34189.2	-84.98
510376	[WEBBTAP4	138.00]	AMP	7472.0	-78.68
510406	[N.E.S.-7	345.00]	AMP	18715.1	-86.41
512865	[GREC TAP5	345.00]	AMP	25558.3	-87.32
514705	[COWCRK 2	69.000]	AMP	4043.2	-86.74
514708	[OTTER 4	138.00]	AMP	9516.2	-82.41
514709	[FRMNTAP4	138.00]	AMP	17442.3	-82.88
514711	[WAUKOTPA	138.00]	AMP	14921.6	-81.72
514713	[WRVALLY4	138.00]	AMP	8652.3	-82.15
514733	[MARSHL 4	138.00]	AMP	7782.0	-80.53
514742	[OSGE 2	69.000]	AMP	14627.2	-84.40
514758	[STDBEAR4	138.00]	AMP	13170.8	-81.68
514761	[WHEAGLE4	138.00]	AMP	14865.3	-81.80
514770	[MARLNDT4	138.00]	AMP	10521.7	-76.97
514801	[MINCO 7	345.00]	AMP	16168.3	-85.16
514828	[KETCHTP4	138.00]	AMP	26011.1	-84.56
514854	[BRADEN 4	138.00]	AMP	30756.0	-85.14
514873	[LNEOAK 4	138.00]	AMP	26423.9	-84.57
514898	[CIMARON4	138.00]	AMP	42068.0	-85.00
514907	[ARCADIA4	138.00]	AMP	40833.3	-85.64
514909	[REDBUD 7	345.00]	AMP	23849.0	-86.78
514934	[DRAPER 7	345.00]	AMP	20374.3	-85.15
515045	[SEMINOL7	345.00]	AMP	25903.4	-86.18
515181	[UNVRSTY4	138.00]	AMP	13411.5	-79.89
515400	[DMANCRK4	138.00]	AMP	7954.9	-80.21
515407	[TATONGA7	345.00]	AMP	10482.6	-86.78
515471	[NW164TH4	138.00]	AMP	34845.8	-85.66
515477	[CHSHLMV7	345.00]	AMP	12022.9	-84.70
515512	[SPVALLY4	138.00]	AMP	8666.7	-77.82
515610	[FSHRTAP7	345.00]	AMP	15920.3	-85.09
532794	[ROSEHIL7	345.00]	AMP	18818.1	-85.81
560086	[G16-072-TAP	345.00]	AMP	11100.0	-84.64
584900	[GEN-2015-052345.00]	AMP	13062.8	-86.43	
585010	[GEN-2015-063345.00]	AMP	16753.6	-84.87	
300140	[4SILVCTY	138.00]	AMP	15768.5	-82.23
300996	[4JAVINE	138.00]	AMP	6523.9	-82.69
301429	[4CLEVLNDXFMR	138.00]	AMP	16667.4	-85.42
509757	[WEKIWA-4	138.00]	AMP	31241.6	-84.89
509782	[R.S.S.-7	345.00]	AMP	30803.7	-86.91
509807	[ONETA--7	345.00]	AMP	29567.7	-86.67
509817	[T.NO.--4	138.00]	AMP	34247.5	-84.89
509870	[SAPLPD7	345.00]	AMP	21070.7	-86.50
510377	[FAIRFXT4	138.00]	AMP	7502.6	-78.75
510380	[DELWARE7	345.00]	AMP	11395.6	-84.84
510432	[SHIDWFC4	138.00]	AMP	5327.6	-75.96
510907	[PITTSB-7	345.00]	AMP	13045.9	-84.54
511425	[TUTCONT4	138.00]	AMP	10601.6	-80.92
512650	[GRDA1 7	345.00]	AMP	25990.4	-87.32
512749	[PAWNSW4	138.00]	AMP	9911.0	-83.58
514710	[WAUKOMI4	138.00]	AMP	9512.8	-80.46
514712	[FAIRMON4	138.00]	AMP	13624.6	-82.24
514731	[SO4TH 4	138.00]	AMP	14797.2	-81.23
514748	[CONTEMP4	138.00]	AMP	12831.1	-81.68
514753	[CONORTH4	138.00]	AMP	12870.8	-81.68
514760	[KILDARE4	138.00]	AMP	10139.5	-79.53
514768	[WF KAY 2	69.000]	AMP	2949.1	-81.29
514819	[EL-RENO4	138.00]	AMP	15222.9	-80.01
514820	[JENSENT4	138.00]	AMP	14999.8	-79.44
514827	[CTNWOOD4	138.00]	AMP	16549.7	-80.44
514834	[KETCH 4	138.00]	AMP	26476.6	-84.56
514851	[QUAILCK4	138.00]	AMP	28916.5	-83.27
514852	[SLVRLAK4	138.00]	AMP	32142.8	-83.89
514863	[HAYMAKR4	138.00]	AMP	26014.5	-82.45

514864	[PIEDMNT4	138.00]	AMP	22046.2	-84.44
514894	[CZECHAL4	138.00]	AMP	28021.0	-82.98
514895	[SARA 4	138.00]	AMP	18585.5	-84.10
514906	[JNSKAMO4	138.00]	AMP	20532.9	-81.91
514933	[DRAPER 4	138.00]	AMP	38552.0	-85.17
515009	[MCELROY4	138.00]	AMP	13527.4	-79.75
515039	[PAYNESB4	138.00]	AMP	7618.3	-77.28
515044	[SEMINOL4	138.00]	AMP	39082.3	-85.70
515224	[MUSKOGEE7	345.00]	AMP	28777.4	-86.76
515402	[CONBLKT2	69.000]	AMP	13283.8	-82.81
515444	[MCNOWND7	345.00]	AMP	16123.3	-85.15
515448	[CRSRDSW7	345.00]	AMP	8151.6	-85.99
515461	[RNDBARN4	138.00]	AMP	38843.2	-85.56
515465	[LGARBER4	138.00]	AMP	21021.6	-82.40
515466	[MITCHSB4	138.00]	AMP	21064.9	-83.35
515514	[KNIPE 4	138.00]	AMP	5016.4	-78.92
515542	[CWBOYHT4	138.00]	AMP	7841.1	-74.45
515543	[RENFROW7	345.00]	AMP	11135.5	-84.66
515549	[MNCWND37	345.00]	AMP	11274.4	-84.89
515582	[SLNGWND7	345.00]	AMP	7041.9	-85.75
515585	[MAMTHPW7	345.00]	AMP	9281.9	-86.61
515600	[KNGFSHR7	345.00]	AMP	11008.2	-84.89
515800	[GRACMNT7	345.00]	AMP	14770.3	-85.24
521006	[MARSHAL4	138.00]	AMP	7745.8	-80.48
521007	[MARLAND_138	138.00]	AMP	7239.7	-74.55
521100	[WARREN 4	138.00]	AMP	8652.3	-82.15
529241	[OMMORANT	69.000]	AMP	9136.5	-83.31
529249	[OMWW	69.000]	AMP	11261.5	-83.58
532791	[BENTON 7	345.00]	AMP	19012.8	-85.72
532797	[WOLFCRK7	345.00]	AMP	15970.0	-86.82
532800	[LATHAMS7	345.00]	AMP	10459.0	-85.56
533062	[ROSEHIL4	138.00]	AMP	30985.5	-86.17
560077	[G16-032-TAP	345.00]	AMP	3366.3	-79.62
562075	[G15-081-TAP	345.00]	AMP	11375.4	-86.55
562790	[G15-038T	345.00]	AMP	13236.4	-84.93
584170	[GEN-2014-064138.00]		AMP	9444.1	-82.38
584700	[GEN-2015-029345.00]		AMP	7355.4	-85.26

Table E-2: GEN-2015-047 Short Circuit Analysis Results (2025SP)

PSS®E-32.2.0 ASCC SHORT CIRCUIT CURRENTS

THU, MAY 25 2017 7:50

2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO
 MDWG 2025S WITH MMWG 2024S, MRO & SERC 2025 SUMMER

OPTIONS USED:

- FLAT CONDITIONS
- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

X----- BUS -----X			THREE PHASE FAULT	
			/I+/ AMP	AN(I+) -
514803	[SOONER 7	345.00]	24732.1	-86.49
514802	[SOONER 4	138.00]	31800.8	-86.81
514881	[SPRNGCK7	345.00]	21905.0	-85.53
515576	[RANCHRD7	345.00]	13768.6	-86.67
560056	[G15-066T	345.00]	18042.8	-86.54
560084	[G16-061-TAP	345.00]	14855.5	-84.89
584690	[GEN-2015-030345.00]	AMP	18811.9	-85.91
584880	[GEN-2015-047345.00]	AMP	11030.4	-83.65
512694	[CLEVLND7	345.00]	14881.0	-86.33
514704	[MILLERT4	138.00]	20413.9	-85.61
514707	[PERRY 4	138.00]	11005.9	-83.26
514715	[WOODRNG7	345.00]	17285.2	-84.84
514798	[SNRPMP4	138.00]	20461.2	-85.59
514880	[NORTWST7	345.00]	30528.4	-86.09
515447	[MORISNT4	138.00]	13863.3	-82.89
515621	[OPENSKY7	345.00]	12781.1	-86.64
529200	[OMCDLEC7	345.00]	13743.2	-86.67
584450	[G1501-G1631	345.00]	11071.7	-85.63
584770	[GEN-2015-034345.00]	AMP	11059.7	-85.67
585040	[GEN-2015-066345.00]	AMP	17876.7	-86.51
509852	[T.NO.--7	345.00]	23592.9	-86.30
512729	[CLEVLND 4	138.00]	16716.6	-85.45
514706	[COWCRK 4	138.00]	11309.7	-82.96
514714	[WOODRNG4	138.00]	18744.0	-83.29
514737	[OTOE 4	138.00]	16272.1	-83.28
514743	[OSAGE 4	138.00]	16531.6	-82.03
514799	[SNRPMP 4	138.00]	11273.8	-80.55
514825	[KAYWIND7	345.00]	12747.9	-86.63
514879	[NORTWST4	138.00]	42927.3	-85.97
514901	[CIMARON7	345.00]	31124.9	-85.95
514908	[ARCADIA7	345.00]	26065.0	-86.55
515006	[MORRISN4	138.00]	13831.9	-82.89
515011	[STILWTR4	138.00]	13870.8	-80.01
515412	[DMNCRKT4	138.00]	13715.2	-84.39
515476	[HUNTERS7	345.00]	12408.1	-84.74
515497	[MATHWSN7	345.00]	29678.5	-86.07
560053	[G15-052T	345.00]	13184.2	-86.46
560055	[G15-063T	345.00]	17246.6	-84.94
300138	[4CLEVLND	138.00]	16718.6	-85.43
509755	[WEKIWA-7	345.00]	18777.1	-86.22
509895	[T.NO.2-4	138.00]	34376.8	-84.98
510376	[WEBBTAP4	138.00]	7572.9	-78.68
510406	[N.E.S.-7	345.00]	18841.4	-86.42
512865	[GREC TAP5	345.00]	25882.3	-87.33

514705	[COWCRK 2	69.000]	AMP	4048.2	-86.74
514708	[OTTER 4	138.00]	AMP	9546.1	-82.40
514709	[FRMNTAP4	138.00]	AMP	17555.7	-82.87
514711	[WUKOTP4	138.00]	AMP	15009.6	-81.72
514713	[WRVALLY4	138.00]	AMP	8688.9	-82.12
514733	[MARSHL 4	138.00]	AMP	7799.4	-80.53
514742	[OSGE 2	69.000]	AMP	17519.5	-84.60
514758	[STDBEAR4	138.00]	AMP	13834.0	-81.86
514761	[WHEAGLE4	138.00]	AMP	15608.1	-81.90
514770	[MARLNDT4	138.00]	AMP	10903.7	-76.94
514801	[MINCO 7	345.00]	AMP	16530.7	-85.20
514828	[KETCHTP4	138.00]	AMP	26061.9	-84.56
514854	[BRADEN 4	138.00]	AMP	30929.8	-85.16
514873	[LNEOAK 4	138.00]	AMP	26554.6	-84.59
514898	[CIMARON4	138.00]	AMP	42425.1	-85.06
514907	[ARCADIA4	138.00]	AMP	41263.7	-85.71
514909	[REDBUD 7	345.00]	AMP	25385.1	-86.83
514934	[DRAPER 7	345.00]	AMP	20530.5	-85.12
515045	[SEMINOL7	345.00]	AMP	26075.2	-86.15
515181	[UNVRSTY4	138.00]	AMP	13707.3	-79.81
515400	[DMANCRK4	138.00]	AMP	8047.6	-80.20
515407	[TATONGA7	345.00]	AMP	15930.3	-86.55
515471	[NW164TH4	138.00]	AMP	35155.3	-85.70
515477	[CHSHLMV7	345.00]	AMP	12391.2	-84.74
515512	[SPVALLY4	138.00]	AMP	8859.9	-77.69
515610	[FSHRTAP7	345.00]	AMP	16269.5	-85.15
515644	[STLWTR2	69.000]	AMP	16268.2	-78.22
532794	[ROSEHIL7	345.00]	AMP	19116.6	-85.82
560086	[G16-072-TAP	345.00]	AMP	11621.5	-84.72
584900	[GEN-2015-052345.00]		AMP	13133.4	-86.44
585010	[GEN-2015-063345.00]		AMP	17184.8	-84.91
300140	[4SILVCTY	138.00]	AMP	15852.5	-82.25
300996	[4JAVINE	138.00]	AMP	6531.1	-82.68
301429	[4CLEVLNDXFMR	138.00]	AMP	16718.6	-85.43
509757	[WEKIWA-4	138.00]	AMP	31499.0	-84.89
509782	[R.S.S.-7	345.00]	AMP	31489.1	-86.98
509807	[ONETA--7	345.00]	AMP	29964.9	-86.69
509817	[T.NO.--4	138.00]	AMP	34436.2	-84.89
509870	[SAPLPRD7	345.00]	AMP	21376.2	-86.54
510377	[FAIRFXT4	138.00]	AMP	7603.9	-78.75
510380	[DELWARE7	345.00]	AMP	11493.8	-84.87
510432	[SHIDWFC4	138.00]	AMP	5378.7	-75.94
510907	[PITTSB-7	345.00]	AMP	13084.5	-84.54
511425	[TUTCONT4	138.00]	AMP	10672.3	-80.90
512650	[GRDA1 7	345.00]	AMP	26331.1	-87.34
512662	[STILWTP2	69.000]	AMP	16283.3	-78.22
512749	[PAWNSW4	138.00]	AMP	9946.4	-83.60
514710	[WUKOMI4	138.00]	AMP	9562.1	-80.48
514712	[FAIRMON4	138.00]	AMP	13698.2	-82.22
514731	[SO4TH 4	138.00]	AMP	14880.2	-81.21
514748	[CONTEMP4	138.00]	AMP	13437.3	-81.82
514753	[CONORTH4	138.00]	AMP	13487.3	-81.83
514760	[KILDARE4	138.00]	AMP	10512.8	-79.43
514768	[WF KAY 2	69.000]	AMP	2951.8	-81.29
514819	[EL-RENO4	138.00]	AMP	15287.2	-80.04
514820	[JENSENT4	138.00]	AMP	15063.7	-79.45
514827	[CTNWOOD4	138.00]	AMP	16602.4	-80.44
514834	[KETCH 4	138.00]	AMP	26520.7	-84.56
514851	[QUAILCK4	138.00]	AMP	28978.1	-83.27
514852	[SLVRLAK4	138.00]	AMP	32245.7	-83.91
514863	[HAYMAKR4	138.00]	AMP	26070.9	-82.47
514864	[PIEDMNT4	138.00]	AMP	22138.3	-84.46
514894	[CZECHAL4	138.00]	AMP	27697.8	-83.00
514895	[SARA 4	138.00]	AMP	18618.6	-84.10

514906	[JNSKAMO4	138.00]	AMP	20324.9	-81.88
514933	[DRAPER 4	138.00]	AMP	38603.9	-85.15
515009	[MCELROY4	138.00]	AMP	13731.5	-79.69
515039	[PAYNESB4	138.00]	AMP	7749.7	-77.17
515044	[SEMINOL4	138.00]	AMP	39221.2	-85.67
515224	[MUSKOG7	345.00]	AMP	28887.4	-86.76
515402	[CONBLKT2	69.000]	AMP	15527.8	-82.74
515444	[MCNOWND7	345.00]	AMP	16483.6	-85.19
515448	[CRSRDSW7	345.00]	AMP	11103.5	-85.54
515461	[RNDBARN4	138.00]	AMP	39224.0	-85.63
515465	[LGARBER4	138.00]	AMP	20997.7	-82.39
515466	[MITCHSB4	138.00]	AMP	21101.9	-83.35
515514	[KNIPE 4	138.00]	AMP	5080.6	-78.86
515542	[CWBOYHT4	138.00]	AMP	8006.3	-74.36
515543	[RENFROW7	345.00]	AMP	11784.7	-84.77
515549	[MNCWND37	345.00]	AMP	11440.9	-84.91
515582	[SLNGWND7	345.00]	AMP	8983.9	-85.26
515585	[MAMTHPW7	345.00]	AMP	13254.8	-86.34
515600	[KNGFSHR7	345.00]	AMP	11159.7	-84.92
515800	[GRACMNT7	345.00]	AMP	15205.9	-85.32
521006	[MARSHAL4	138.00]	AMP	7763.0	-80.47
521007	[MARLAND_138	138.00]	AMP	7418.2	-74.47
521100	[WARREN 4	138.00]	AMP	8688.9	-82.12
529241	[OMMORANT	69.000]	AMP	12304.5	-84.33
529249	[OMWW	69.000]	AMP	13318.5	-83.72
532791	[BENTON 7	345.00]	AMP	19372.9	-85.75
532797	[WOLFCKR7	345.00]	AMP	16038.0	-86.82
532800	[LATHAMS7	345.00]	AMP	10514.5	-85.56
533062	[ROSEHIL4	138.00]	AMP	31764.9	-86.13
560077	[G16-032-TAP	345.00]	AMP	3372.7	-79.62
562075	[G15-081-TAP	345.00]	AMP	16230.3	-86.40
562790	[G15-038T	345.00]	AMP	13473.6	-84.97
584170	[GEN-2014-064	138.00]	AMP	9473.5	-82.37
584700	[GEN-2015-029	345.00]	AMP	9603.6	-84.60