

**GEN-2015-073**  
**Impact Restudy for**  
**Generator Modification**  
**(Turbine Change)**

**March 2017**  
**Generator Interconnection**



## Revision History

| Date      | Author | Change Description   |
|-----------|--------|--|
| 3/30/2017 | SPP    | GEN-2015-073 Impact Restudy for Generator Modification Report Issued |

---

## Executive Summary

---

The GEN-2015-073 Interconnection Customer has requested a modification to its Generator Interconnection Request (GIR) to change wind turbine generators. Originally, the GIR consisted of eight-seven (87) Siemens 2.3MW wind turbines for a total 200.1 MW. The requested change is fifty-eight (58) Vestas V126 GS 3.45MW wind turbines totaling 200.1MW. The point of interconnection (POI) is the Westar Energy (WERE) Emporia Substation 345kV.

The study models used were the 2016 winter, 2017 summer, and 2025 summer models that included Interconnection Requests through DISIS-2015-002.

Stability analysis has determined with all previously assigned Network Upgrades in service, generators in the monitored areas remained stable and within the pre-contingency, voltage recovery, and post fault voltage recovery criterion of 0.7pu to 1.2pu for the entire modeled disturbances. Additionally, the project wind farm was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

A power factor analysis was performed for the project on the current study 2016 winter peak, 2017 summer peak, and 2025 summer peak cases with identified system upgrades. As reactive power is required for GEN-2015-073, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.

A reduced generation analysis was conducted to determine reactor inductive amounts to compensate the capacitive effects on the transmission system during low or reduced wind conditions caused by the interconnecting project's generator lead transmission line and collector systems. The interconnection customer's facility is required to install a reactor or an equivalent means of compensation that can inject approximately 14.8Mvar. Reactive compensation devices are typically installed on the low side of the project's substation 345/34.5kV transformer.

Short Circuit analysis was conducted using the current study upgrade 2017 summer peak and 2025 summer peak cases.

With the assumptions outlined in this report and with all the required network upgrades from the DISIS 2015-002 in place, GEN-2015-073 with fifty-eight (58) Vestas V126 GS 3.45MW wind turbines should be able to interconnect reliably to the SPP transmission grid. The change in wind turbine generator is not a Material Modification.

It should be noted that this study analyzed the requested modification to change generator technology, manufacturer, and layout. Powerflow analysis was not performed. This study analyzed many of the most probable contingencies, but it is not an all-inclusive list and cannot

account for every operational situation. It is likely that the customer may be required to reduce its generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of delivery or transmission service. If the customer wishes to sell power from the facility, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the Customer.

---

## Table of Contents

---

|  |            |
|--|------------|
| <b>Revision History .....</b>                              | <b>1</b>   |
| <b>Executive Summary .....</b>                             | <b>i</b>   |
| <b>Table of Contents .....</b>                             | <b>iii</b> |
| <b>1. Introduction .....</b>                               | <b>1</b>   |
| <b>2. Facilities .....</b>                                 | <b>4</b>   |
| <b>3. Stability Analysis .....</b>                         | <b>5</b>   |
| Model Preparation.....                                     | 5          |
| Disturbances .....   | 5          |
| Results.....   | 17         |
| FERC LVRT Compliance .....                                 | 18         |
| <b>4. Power Factor Analysis .....</b>                      | <b>20</b>  |
| Model Preparation.....                                     | 20         |
| Disturbances .....   | 20         |
| Results.....   | 20         |
| <b>5. Reduced Wind Generation Analysis .....</b>           | <b>21</b>  |
| <b>6. Short Circuit Analysis.....</b>                      | <b>23</b>  |
| Results.....   | 23         |
| <b>7. Conclusion .....</b>                                 | <b>24</b>  |
| <b>Appendix A – 2016 Winter Peak Stability Plots.....</b>  | <b>26</b>  |
| <b>Appendix B – 2017 Summer Peak Stability Plots .....</b> | <b>27</b>  |
| <b>Appendix C – 2025 Summer Peak Stability Plots .....</b> | <b>28</b>  |
| <b>Appendix D – Power Factor Analysis Results .....</b>    | <b>29</b>  |
| <b>Appendix E – Short Circuit Analysis Results .....</b>   | <b>31</b>  |

## 1. Introduction

The GEN-2015-073 Interconnection Customer has requested a modification to its Generator Interconnection Request to change its wind turbine generators from eight-seven (87) Siemens 2.3MW wind turbines to fifty-eight (58) Vestas V126 GS 3.45MW wind turbines for a total 200.1 MW. The requested change is shown in **Table 1-1**.

**Table 1-1: Interconnection Request**

| Request      | Capacity (MW) | Generator Model            | Point of Interconnection |
|--------------|---------------|----------------------------|--------------------------|
| GEN-2015-073 | 200.1         | 58 x Vestas V126 GS 3.45MW | Emporia 345kV (532768)   |

The POI is the WERE Emporia Substation 345kV. Other queued generation projects in the model are listed in **Table 1-2**.

**Table 1-2: Other Queued Interconnection Requests in the Model**

| Request                      | Capacity (MW)                          | Generator Model                                     | Point of Interconnection                            |
|------------------------------|--|---|---|
| GEN-2002-004                 | 199.5                                  | GE.1.5MW  | Latham 345kV (532800)                               |
| GEN-2005-013                 | 199.8                                  | Vestas V90 1.8MW                                    | Caney River 345kV (532780)                          |
| GEN-2007-025                 | 299.2                                  | GE 1.6MW  | Viola 345kV (532798)                                |
| GEN-2008-013                 | 300                                    | G.E. 1.68MW   | Hunter 345kV (515476)                               |
| GEN-2008-021                 | 1261 Summer<br>1283 Winter             | GENROU  | Wolf Creek 345kV (532797)                           |
| GEN-2008-098                 | 100.8                                  | Vestas V100 1.8MW                                   | Tap on the Wolf Creek – LaCygne 345kV line (560004) |
| GEN-2009-025                 | 59.8                                   | Siemens 2.3MW                                       | Tap on the Deerck – Sinck 69kV line (515528)        |
| GEN-2010-003                 | 100.8                                  | Vestas V100 1.8MW                                   | Tap on the Wolf Creek – LaCygne 345kV line (560004) |
| GEN-2010-005                 | 299.2                                  | GE 1.6MW & Vestas V110 2.0MW                        | Viola 345kV (532798)                                |
| ASGI-2010-006                | 150                                    | GE1.5MW   | Remington 138kV (301369)                            |
| GEN-2010-055                 | 4.8                                    | GENROU  | Wekiwa 138kV (509757)                               |
| GEN-2011-057                 | 150.4                                  | GE 1.6MW  | Creswell 138kV (532981)                             |
| GEN-2012-027                 | 150.7                                  | GE 1.62MW   | Shidler 138kV (510403)                              |
| KCPL Distributed: Osawatomie | 76.0                                   | GENROU (543078)                                     | Paola 161kV   |
| GEN-2012-032                 | 300                                    | Vestas V112 3.0MW                                   | Tap Rose Hill-Sooner 345kV (562318)                 |
| GEN-2012-033                 | 98.8                                   | GE 1.62MW   | Tap Bunch Creek-South 4th 138kV(562303)             |
| GEN-2012-040                 | 76.5                                   | GE 1.7MW  | Chilocco 138kV (521198)                             |
| GEN-2012-041                 | 85 Summer<br>121.5 Winter              | GENROU  | Tap Rose Hill-Sooner 345kV (562318)                 |
| GEN-2013-012                 | 4 x 168.0MW Summer<br>4 x 215MW Winter | GENROU (514910)<br>(514911)<br>(514912)<br>(514942) | Redbud 345kV (514909)                               |

**Table 1-2: Other Queued Interconnection Requests in the Model**

| Request       | Capacity (MW)                                     | Generator Model   | Point of Interconnection   |
|---------------|---|---|--|
| GEN-2013-028  | 516.4 Summer<br>559.5 Winter                      | GENROU (583743,<br>583746)                              | Tap on Tulsa N to GRDA1 345kV (562423)   |
| GEN-2013-029  | 300   | Vestas V100 VCSS<br>2MW (583753,<br>583756)             | Renfrow 345kV(515543)  |
| GEN-2014-001  | 200.6   | GE 1.7MW 100m<br>(583853,583856)                        | Tap Wichita to Emporia Energy Center 345kV<br>(562476)                                   |
| GEN-2014-028  | 35 (Uprate)<br>(Pgen=259W/256<br>S)               | GENROU  | Riverton 161kV (547469)  |
| GEN-2014-064  | 248.4   | GE 2.3MW  | Otter 138kV (514708)   |
| ASGI-2014-014 | 56.4W/54.3S                                       | GENROU  | Ferguson 69kV (512664)   |
| GEN-2015-001  | 200.0   | Vestas V110 2.0MW                                       | Ranch Road 345kV   |
| GEN-2015-015  | 154.6   | Siemens 2.3MW with<br>Power Boost (115kW<br>=> 2.415MW) | Tap Medford Tap – Coyote 138kV   |
| GEN-2015-016  | 200.0   | Vestas V110 2.0MW                                       | Tap Centerville – Marmaton 161kV   |
| GEN-2015-024  | 220.0   | GE 2.0MW  | Tap on Thistle to Wichita 345kV, ckt1&2 (560033)   |
| GEN-2015-025  | 220.0   | GE 2.0MW  | Tap on Thistle to Wichita 345kV, ckt1&2 (560033)   |
| GEN-2015-028  | 3.0 uprate to<br>GEN-2009-025<br>for total 62.8MW | Siemens 2.3MW with<br>Power Boost (115kW<br>=> 2.415MW) | Nardins 69kV   |
| GEN-2015-030  | 200.1   | GE 2.3MW  | Sooner 345kV   |
| ASGI-2015-004 | 54.300 Summer<br>56.364 Winter                    | GENSAL  | Coffeyville Municipal Light & Power Northern<br>Industrial Park Substation 69kV (512735) |
| GEN-2015-034  | 199.95  | Vestas V126 GS<br>3.3MW & 3.45MW                        | Ranch Road 345kV (515576)  |
| GEN-2015-047  | 300   | Vestas V110-2MW<br>(wind)                               | Sooner 345kV Tap (514803)  |
| GEN-2015-052  | 300   | Vestas V110-2MW<br>(wind)                               | Tap on Opensky (515621) to RoseHill (532794)<br>345 kV (560053)                          |
| GEN-2015-062  | 4.5   | G.E. 1.79MW (wind)                                      | Breckenridge 138kV (514815)  |
| GEN-2015-063  | 300   | Vestas V110-2MW<br>(wind)                               | Tap on Woodring (514715) to Matthewson<br>(515497) 345 kV (560055)                       |
| GEN-2015-066  | 248   | G.E. 2.3MW (wind)                                       | Tap on Cleveland (512694) to Sooner (514803)<br>345 kV (560056)                          |
| GEN-2015-067  | 150   | PV inverter user<br>model (solar)                       | Sooner 138kV (514802)  |
| GEN-2015-069  | 300   | Vestas V110-2MW<br>(wind)                               | Union Ridge 230kV (532874)   |
| GEN-02015-083 | 125   | G.E. 2.3MW (wind)                                       | Belle Plain 138kV (533063)   |
| GEN-2015-090  | 220   | G.E. 2MW (wind)   | Wichita (532796)-Thistle (539801) 345kV Tap<br>(GEN-2015-024 (560033) 345kV)             |

A stability analysis was performed for the change in wind turbines. The analysis was performed on three (3) seasonal models including 2016 winter peak (16WP), the 2017 summer peak (17SP), and the 2025 summer peak (25SP) cases. These cases are modified versions of the 2015 model series of Model Development Working Group (MDWG) dynamic study models that included upgrades and Interconnection Requests through DISIS-2015-002.

The stability analysis determines the impacts of the new interconnecting project on the stability and voltage recovery of the nearby systems and the ability of the interconnecting project to meet FERC Order 661A. If problems with stability or voltage recovery are identified, the need for reactive compensation or system upgrades is investigated. The contingencies listed in **Table 3-1** were used in the stability analysis.

The power factor analysis determines the power factor at the point of interconnection (POI) for the wind interconnection projects for pre-contingency and post-contingency conditions. The contingencies used in the power factor analysis are a subset of the stability analysis contingencies shown in **Table 3-1**.

A reduced (low wind/no wind) generation analysis was performed to determine reactor inductive amounts to compensate for the capacitive effects on the transmission system caused by the interconnecting project's generator lead transmission line and collector systems during low or reduced wind conditions.

Short Circuit analysis was conducted using the current study upgrade 2017 summer peak and 2025 summer peak cases. The results from the Short circuit analysis are shown in Appendix F.


Nothing in this System Impact Study constitutes a request for transmission service or grants the Interconnection Customer any rights to transmission service. If the customer wishes to sell power from the facility, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the Customer.



## 2. Facilities

A one-line PSS/E slider drawing from the 16WP case is shown in **Figure 2-1** for GEN-2015-073.

**Figure 2-1: GEN-2015-073 One-line Diagram**



---

## 3. Stability Analysis

---

Transient stability analysis is used to determine if the transmission system can maintain angular stability and ensure bus voltages stay within planning criteria bandwidth during and after a disturbance while considering the addition of a generator interconnection request.

### Model Preparation

Transient stability analysis was performed using modified versions of the 2015 series of Model Development Working Group (MDWG) dynamic study models including the 2016 winter peak, 2017 summer peak, and the 2025 summer peak seasonal models. The cases are then loaded with prior queued interconnection requests and network upgrades assigned to those interconnection requests. Finally other queued projects as shown in **Table 1-2** and the study generation are dispatched into the SPP footprint. Initial simulations are then carried out for a no-disturbance run of twenty (20) seconds to verify the numerical stability of the model.

### Disturbances

Ninety (90) contingencies were identified for use in this study and are listed in **Table 3-1**. These contingencies are faults at locations defined by SPP Generation Interconnection Staff. These contingencies include three-phase and single-phase N-1. Single-phase line faults were simulated by applying fault impedance to the positive sequence network at the fault location to represent the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the specified fault location of approximately 60% of pre-fault voltage. This method is in agreement with SPP current practice.

Except for transformer faults, the typical sequence of events for a three-phase and single-phase fault is as follows:

1. apply fault at particular location
2. continue fault for five (5) cycles, clear the fault by tripping the faulted facility
3. after an additional twenty (20) cycles, re-close the previous facility back into the fault
4. continue fault for five (5) additional cycles
5. trip the faulted facility and remove the fault

Transformer faults are typically modeled as three-phase faults, unless otherwise noted. The sequence of events for a transformer fault is as follows:

1. apply fault for five (5) cycles
2. clear the fault by tripping the affected transformer facility (unless otherwise noted there will be no re-closing into a transformer fault)

The SPP areas monitored during the stability analysis were:

- 520: American Electric Power (AEPW)

- 524: Oklahoma Gas and Electric Company (OKGE)
- 525: Western Farmers Electric Cooperative (WFEC)
- 526: Southwestern Public Service (SPS)
- 531: Midwest Energy, Inc. (MIDW)
- 534: Sunflower Electric Power Corp. (SUNC)
- 536: Westar Energy, Inc. (WERE)
- 541: Kansas City Power and Light (KCPL)

**Table 3-1: Contingencies Evaluated**

| Cont. No. | Contingency Name                       | Description  |
|-----------|--|--|
| 0         | FLT_000_NOFAULT                        | No Fault Conditions  |
| 1         | FLT_01_Viola_Renfrow_345kV_3PH         | 3 phase fault on the Viola (532798) to Renfrow (515543) 345kV line, near Viola.<br>a. Apply fault at the Viola 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.               |
| 2         | FLT_02_Viola_Wichita_345kV_3PH         | 3 phase fault on the Viola (532798) to Wichita (532796) 345kV line, near Viola.<br>a. Apply fault at the Viola 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.               |
| 3         | FLT_03_Renfrow_Hunter_345kV_3PH        | 3 phase fault on the Renfrow (515543) to Hunter (515476) 345kV line, near Renfrow.<br>a. Apply fault at the Renfrow 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.          |
| 4         | FLT_04_Renfrow_Renfrow_345_138kV_3PH   | 3 phase fault on the Renfrow 345kV (515543) to Renfrow 138kV (515544) to Renfrow 13.8kV (515545) transformer, near Renfrow 345kV.<br>a. Apply fault at the Renfrow 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.  |
| 5         | FLT_05_Hunter_Woodring_345kV_3PH       | 3 phase fault on the Hunter (515476) to Woodring (514715) 345kV line, near Hunter.<br>a. Apply fault at the Hunter 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.           |
| 6         | FLT_06_Woodring_Sooner_345kV_3PH       | 3 phase fault on Woodring (514715) to Sooner (514803) 345kV line, near Woodring.<br>a. Apply fault at the Woodring 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.           |
| 7         | FLT_07_Woodring_G15063Tap_345kV_3PH    | 3 phase fault on Woodring (514715) to G1506Tap (560055) 345kV line, near Woodring.<br>a. Apply fault at the Woodring 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.         |
| 8         | FLT_08_Woodring_Woodring_345_138kV_3PH | 3 phase fault on the Woodring 345kV (514715) to Woodring 138kV (514714) to Woodring 13.8kV (515770) transformer, near Woodring 345kV.<br>a. Apply fault at the Woodring 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.   |
| 9         | FLT_09_Mathewson_Northwest_345kV_3PH   | 3 phase fault on the Mathewson (515497) to Northwest (514880) 345kV line, near Mathewson.<br>a. Apply fault at the Mathewson 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

**Table 3-1: Contingencies Evaluated**

| Cont. No. | Contingency Name                    | Description  |
|-----------|-------------------------------------|--|
| 10        | FLT_10_Mathewson_Cimarron_345kV_3PH | 3 phase fault on the Mathewson (515497) to Cimarron (514901) 345kV line, near Mathewson.<br>a. Apply fault at the Mathewson 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.    |
| 11        | FLT_11_Mathewson_Tatonga_345kV_3PH  | 3 phase fault on the Mathewson (515497) to Tatonga (515407) 345kV line, near Mathewson.<br>a. Apply fault at the Mathewson 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.     |
| 12        | FLT_12_Sooner_SpringCreek_345kV_3PH | 3 phase fault on the Sooner (514803) to Spring Creek (514881) 345kV line, near Sooner.<br>a. Apply fault at the Sooner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.         |
| 13        | FLT_13_Sooner_G15066T_345kV_3PH     | 3 phase fault on the Sooner (514803) to G15066T (560056) 345kV line, near Sooner.<br>a. Apply fault at the Sooner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.              |
| 14        | FLT_14_Sooner_Sooner_345_138kV_3PH  | 3 phase fault on the Sooner 345kV (514803) to Sooner 138kV (514802) to Sooner 13.8kV (515760) transformer, near Sooner 345kV.<br>a. Apply fault at the Sooner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.   |
| 15        | FLT_15_RanchRoad_Sooner_345kV_3PH   | 3 phase fault on the Ranch Road (515576) to Sooner (514803) 345kV line, near Ranch Road.<br>a. Apply fault at the Ranch Road 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.   |
| 16        | FLT_16_RanchRoad_OpenSky_345kV_3PH  | 3 phase fault on the Ranch Road (515576) to Open Sky (515621) 345kV line, near Ranch Road.<br>a. Apply fault at the Ranch Road 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 17        | FLT_17_Rosehill_Benton_345kV_3PH    | 3 phase fault on the Rosehill (532794) to Benton (532791) 345kV line, near Rosehill.<br>a. Apply fault at the Rosehill 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.         |
| 18        | FLT_18_Rosehill_WolfCreek_345kV_3PH | 3 phase fault on the Rosehill (532794) to Wolf Creek (532797) 345kV line, near Rosehill.<br>a. Apply fault at the Rosehill 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.     |

**Table 3-1: Contingencies Evaluated**

| <b>Cont. No.</b> | <b>Contingency Name</b>                  | <b>Description</b>  |
|------------------|--|---|
| 19               | FLT_19_Rosehill_Latham_345kV_3PH         | 3 phase fault on the Rosehill (532794) to Latham (532800) 345kV line, near Rosehill.<br>a. Apply fault at the Rosehill 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.          |
| 20               | FLT_20_Rosehill_G15052T_345kV_3PH        | 3 phase fault on the Rosehill (532794) to G15052T (560053) 345kV line, near Rosehill.<br>a. Apply fault at the Rosehill 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.         |
| 21               | FLT_21_Rosehill_Rosehill_345_138kV_3PH   | 3 phase fault on the Rosehill 345kV (532794) to Rosehill 138kV (533062) to Rosehill 13.8kV (532831) transformer, near Rosehill 345kV.<br>a. Apply fault at the Rosehill 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.  |
| 22               | FLT_22_Northwest_SpringCreek_345kV_3PH   | 3 phase fault on the Northwest (514880) to Spring Creek (514881) 345kV line, near Northwest.<br>a. Apply fault at the Northwest 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 23               | FLT_23_Northwest_Cimarron_345kV_3PH      | 3 phase fault on the Northwest (514880) to Cimarron (514901) 345kV line, near Northwest.<br>a. Apply fault at the Northwest 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.     |
| 24               | FLT_24_Northwest_Arcadia_345kV_3PH       | 3 phase fault on the Northwest (514880) to Arcadia (514908) 345kV line, near Northwest.<br>a. Apply fault at the Northwest 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.      |
| 25               | FLT_25_Northwest_Northwest_345_138kV_3PH | 3 phase fault on the Northwest 345kV (514880) to Northwest 138kV (514879) to Northwest 13.8kV (515742) transformer, near Northwest 345kV.<br>a. Apply fault at the Northwest 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.   |
| 26               | FLT_26_Benton_WolfCreek_345kV_3PH        | 3 phase fault on the Benton (532791) to Wolf Creek (532796) 345kV line, near Benton.<br>a. Apply fault at the Benton 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.            |
| 27               | FLT_27_Benton_Benton_345_138kV_3PH       | 3 phase fault on the Benton 345kV (532791) to Benton 138kV (532986) to Benton 13.8kV (532821) transformer, near Benton 345kV.<br>a. Apply fault at the Benton 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.  |

**Table 3-1: Contingencies Evaluated**

| Cont. No. | Contingency Name                     | Description   |
|-----------|--------------------------------------|---|
| 28        | FLT_28_Wichita_Reno_345kV_3PH        | 3 phase fault on the Wichita (532796) to Reno (532771) 345kV line, near Wichita.<br>a. Apply fault at the Wichita 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.         |
| 29        | FLT_29_Wichita_Benton_345kV_3PH      | 3 phase fault on the Wichita (532796) to Benton (532791) 345kV line, near Wichita.<br>a. Apply fault at the Wichita 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.       |
| 30        | FLT_30_Wichita_G1524&1525T_345kV_3PH | 3 phase fault on the Wichita (532796) to G1525&G1525T (560033) 345kV line, near Wichita.<br>a. Apply fault at the Wichita 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 31        | FLT_31_Wichita_Evans_345_138kV_3PH   | 3 phase fault on the Wichita 345kV (532796) to Evans 138kV (533040) to Evans 13.8kV (532830) transformer, near Wichita 345kV.<br>a. Apply fault at the Wichita 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.   |
| 32        | FLT_32_Thistle_G1524&1525T_345kV_3PH | 3 phase fault on the Thistle (539801) to G1524&G1525T (560033) 345kV line, near Thistle.<br>a. Apply fault at the Thistle 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 33        | FLT_33_Thistle_Woodward_345kV_3PH    | 3 phase fault on the Thistle (539801) to Woodward (515375) 345kV line, near Thistle.<br>a. Apply fault at the Thistle 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.     |
| 34        | FLT_34_Thistle_ClarkCounty_345kV_3PH | 3 phase fault on the Thistle (539801) to Clark County (539800) 345kV line, near Thistle.<br>a. Apply fault at the Thistle 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 35        | FLT_35_Thistle_Thistle_345_138kV_3PH | 3 phase fault on the Thistle 345kV (539801) to Thistle 138kV (539804) to Thistle 13.8kV (539802) transformer, near Thistle 345kV.<br>a. Apply fault at the Thistle 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.   |
| 36        | FLT_36_Reno_Summit_345kV_3PH         | 3 phase fault on the Reno (532771) to Summit (532773) 345kV line, near Reno.<br>a. Apply fault at the Reno 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.                |
| 37        | FLT_37_Reno_Reno_345_115kV_3PH       | 3 phase fault on the Reno 345kV (532771) to Reno 138kV (533416) to Reno 14.4kV (532807) transformer, near Reno 345kV.<br>a. Apply fault at the Reno 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.  |

**Table 3-1: Contingencies Evaluated**

| <b>Cont. No.</b> | <b>Contingency Name</b>            | <b>Description</b>  |
|------------------|------------------------------------|---|
| 38               | FLT_38_Summit_Blustem_345kV_3PH    | 3 phase fault on the Summit (532773) to Blustem (532767) 345kV line, near Summit.<br>a. Apply fault at the Summit 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.   |
| 39               | FLT_39_Summit_ElmCreek_345kV_3PH   | 3 phase fault on the Summit (532773) to Elm Creek (539805) 345kV line, near Summit.<br>a. Apply fault at the Summit 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 40               | FLT_40_Summit_Summit_345_230kV_3PH | 3 phase fault on the Summit 345kV (532773) to Summit 230kV (532873) to Summit 14.4kV (432813) transformer, near Summit 345kV.<br>a. Apply fault at the Summit 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.  |
| 41               | FLT_41_EMPEC_Lang_345kV_3PH        | 3 phase fault on the EMPEC (532768) to Lang (532769) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.         |
| 42               | FLT_42_EMPEC_Morris_345kV_3PH      | 3 phase fault on the EMPEC (532768) to Morris (532770) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.       |
| 43               | FLT_43_EMPEC_Swissvale_345kV_3PH   | 3 phase fault on the EMPEC (532768) to Swissvale (532774) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.    |
| 44               | FLT_44_EMPEC_G14001Tap_345kV_3PH   | 3 phase fault on the EMPEC (532768) to G14001Tap (562476) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.    |
| 45               | FLT_45_Morris_JECN_345kV_3PH       | 3 phase fault on the Morris (532770) to JECN (532766) 345kV line, near Morris.<br>a. Apply fault at the Morris 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.      |
| 46               | FLT_46_Morris_Morris_345_230kV_3PH | 3 phase fault on the Morris 345kV (532770) to Morris 230kV (532863) to Morris 14.4kV (532809) transformer, near Morris 345kV.<br>a. Apply fault at the Morris 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.  |



**Table 3-1: Contingencies Evaluated**

| Cont. No. | Contingency Name                                      | Description   |
|-----------|---|---|
| 47        | FLT_47_Swissvale_Wgardner_345kV_3PH (2016WP & 2017SP) | 3 phase fault on the Swissvale (532774) to WGardner (542965) 345kV line, near Swissvale.<br>a. Apply fault at the Swissvale 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 48        | FLT_47_Swissvale_Douglas_345kV_3PH (2025SP)           | 3 phase fault on the Swissvale (532774) to Douglas (532776) 345kV line, near Swissvale.<br>a. Apply fault at the Swissvale 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.  |
| 49        | FLT_48_Swissvale_Swissvale_345_230kV_3PH              | 3 phase fault on the Swissvale 345kV (532774) to Swissvale 230kV (532856) to Swissvale 14.4kV (532815) transformer, near Swissvale 345kV.<br>a. Apply fault at the Swissvale 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.   |
| 50        | FLT_49_Wgardner_Stillwell_345kV_3PH                   | 3 phase fault on the WGardner (542965) to Stillwell (542968) 345kV line, near WGardner.<br>a. Apply fault at the WGardner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.   |
| 51        | FLT_50_Wgardner_Craig_345kV_3PH                       | 3 phase fault on the WGardner (542965) to Craig (542977) 345kV line, near WGardner.<br>a. Apply fault at the WGardner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.       |
| 52        | FLT_51_Wgardner_Lacygne_345kV_3PH                     | 3 phase fault on the WGardner (542965) to LaCygne (542981) 345kV line, near WGardner.<br>a. Apply fault at the WGardner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.     |
| 53        | FLT_52_Wgardner_Wgardner_345_161kV_3PH                | 3 phase fault on the WGardner 345kV (532774) to WGardner 161kV (542966) to WGardner 14.4kV (543649) transformer, near WGardner 345kV.<br>a. Apply fault at the WGardner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.  |
| 54        | FLT_53_Stillwell_Peculiar_345kV_3PH                   | 3 phase fault on the Stillwell (542968) to Peculiar (541198) 345kV line, near Stillwell.<br>a. Apply fault at the Stillwell 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 55        | FLT_54_Stillwell_Lacygne_345kV_3PH                    | 3 phase fault on the Stillwell (542968) to LaCygne (542981) 345kV line, near Stillwell.<br>a. Apply fault at the Stillwell 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.  |

**Table 3-1: Contingencies Evaluated**

| Cont. No. | Contingency Name                         | Description   |
|-----------|--|---|
| 56        | FLT_55_Stillwell_Stillwell_345_161kV_3PH | 3 phase fault on the Stillwell 345kV (542968) to Stillwell 161kV (542969) to Stillwell 14.4kV (543648) transformer, near Stillwell 345kV.<br>a. Apply fault at the Stillwell 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.   |
| 57        | FLT_56_Craig_87th_345kV_3PH              | 3 phase fault on the Craig (542977) to 87th (532775) 345kV line, near Craig.<br>a. Apply fault at the Craig 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.           |
| 58        | FLT_57_Craig_Craig_345_161kV_3PH         | 3 phase fault on the Craig 345kV (542977) to Craig 161kV (542978) to Craig 14.4kV (543641) transformer, near Craig 345kV.<br>a. Apply fault at the Craig 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted transformer.   |
| 59        | FLT_58_Lacygne_Neosho_345kV_3PH          | 3 phase fault on the Lacygne (542981) to Neosho (532793) 345kV line, near Lacygne.<br>a. Apply fault at the Lacygne 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.   |
| 60        | FLT_59_Lacygne_Waverly_345kV_3PH         | 3 phase fault on the Lacygne (542981) to Waverly (532799) 345kV line, near Lacygne.<br>a. Apply fault at the Lacygne 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.  |
| 61        | FLT_60_Neosho_Blackberry_345kV_3PH       | 3 phase fault on the Neosho (532793) to Blackberry (300739) 345kV line, near Neosho.<br>a. Apply fault at the Neosho 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.  |
| 62        | FLT_61_Neosho_Delaware_345kV_3PH         | 3 phase fault on the Neosho (532793) to Delaware (510380) 345kV line, near Neosho.<br>a. Apply fault at the Neosho 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.    |
| 63        | FLT_62_Neosho_CaneyCreek_345kV_3PH       | 3 phase fault on the Neosho (532793) to Caney Creek (532780) 345kV line, near Neosho.<br>a. Apply fault at the Neosho 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 64        | FLT_63_Viola_Renfrow_345kV_1PH           | Single phase fault on the Viola (532798) to Renfrow (515543) 345kV line, near Viola.<br>a. Apply fault at the Viola 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.   |

**Table 3-1: Contingencies Evaluated**

| Cont. No. | Contingency Name                    | Description   |
|-----------|-------------------------------------|---|
| 65        | FLT_64_Viola_Wichita_345kV_1PH      | Single phase fault on the Viola (532798) to Wichita (532796) 345kV line, near Viola.<br>a. Apply fault at the Viola 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.                 |
| 66        | FLT_65_Renfrow_Hunter_345kV_1PH     | Single phase fault on the Renfrow (515543) to Hunter (515476) 345kV line, near Renfrow.<br>a. Apply fault at the Renfrow 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.            |
| 67        | FLT_66_Hunter_Woodring_345kV_1PH    | Single phase fault on the Hunter (515476) to Woodring (514715) 345kV line, near Hunter.<br>a. Apply fault at the Hunter 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.             |
| 68        | FLT_67_Woodring_Sooner_345kV_1PH    | Single phase fault on Woodring (514715) to Sooner (514803) 345kV line, near Woodring.<br>a. Apply fault at the Woodring 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.             |
| 69        | FLT_68_Woodring_G15063Tap_345kV_1PH | Single phase fault on Woodring (514715) to G1506Tap (560055) 345kV line, near Woodring.<br>a. Apply fault at the Woodring 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.           |
| 70        | FLT_69_Sooner_SpringCreek_345kV_1PH | Single phase fault on the Sooner (514803) to Spring Creek (514881) 345kV line, near Sooner.<br>a. Apply fault at the Sooner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.         |
| 71        | FLT_70_Sooner_G15066T_345kV_1PH     | Single phase fault on the Sooner (514803) to G15066T (560056) 345kV line, near Sooner.<br>a. Apply fault at the Sooner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.              |
| 72        | FLT_71_RanchRoad_Sooner_345kV_1PH   | Single phase fault on the Ranch Road (515576) to Sooner (514803) 345kV line, near Ranch Road.<br>a. Apply fault at the Ranch Road 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.   |
| 73        | FLT_72_RanchRoad_OpenSky_345kV_1PH  | Single phase fault on the Ranch Road (515576) to Open Sky (515621) 345kV line, near Ranch Road.<br>a. Apply fault at the Ranch Road 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |

**Table 3-1: Contingencies Evaluated**

| <b>Cont. No.</b> | <b>Contingency Name</b>              | <b>Description</b>  |
|------------------|--------------------------------------|---|
| 74               | FLT_73_Rosehill_Benton_345kV_1PH     | Single phase fault on the Rosehill (532794) to Benton (532791) 345kV line, near Rosehill.<br>a. Apply fault at the Rosehill 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.     |
| 75               | FLT_74_Rosehill_WolfCreek_345kV_1PH  | Single phase fault on the Rosehill (532794) to Wolf Creek (532797) 345kV line, near Rosehill.<br>a. Apply fault at the Rosehill 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 76               | FLT_75_Rosehill_Latham_345kV_1PH     | Single phase fault on the Rosehill (532794) to Latham (532800) 345kV line, near Rosehill.<br>a. Apply fault at the Rosehill 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.     |
| 77               | FLT_76_Rosehill_G15052T_345kV_1PH    | Single phase fault on the Rosehill (532794) to G15052T (560053) 345kV line, near Rosehill.<br>a. Apply fault at the Rosehill 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.    |
| 78               | FLT_77_Wichita_Reno_345kV_1PH        | Single phase fault on the Wichita (532796) to Reno (532771) 345kV line, near Wichita.<br>a. Apply fault at the Wichita 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.          |
| 79               | FLT_78_Wichita_Benton_345kV_1PH      | Single phase fault on the Wichita (532796) to Benton (532791) 345kV line, near Wichita.<br>a. Apply fault at the Wichita 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.        |
| 80               | FLT_79_Wichita_G1524_1525T_345kV_1PH | Single phase fault on the Wichita (532796) to G1525&G1525T (560033) 345kV line, near Wichita.<br>a. Apply fault at the Wichita 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.  |
| 81               | FLT_80_EMPEC_Lang_345kV_1PH          | Single phase fault on the EMPEC (532768) to Lang (532769) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.                |
| 82               | FLT_81_EMPEC_Morris_345kV_1PH        | Single phase fault on the EMPEC (532768) to Morris (532770) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.              |

**Table 3-1: Contingencies Evaluated**

| <b>Cont. No.</b> | <b>Contingency Name</b>                               | <b>Description</b>   |
|------------------|---|--|
| 83               | FLT_82_EMPEC_Swissvale_345kV_1PH                      | Single phase fault on the EMPEC (532768) to Swissvale (532774) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.          |
| 84               | FLT_83_EMPEC_G14001Tap_345kV_1PH                      | Single phase fault on the EMPEC (532768) to G14001Tap (562476) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.          |
| 85               | FLT_84_Morris_JECN_345kV_1PH                          | Single phase fault on the Morris (532770) to JECN (532766) 345kV line, near Morris.<br>a. Apply fault at the Morris 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.            |
| 86               | FLT_85_Wgardner_Stillwell_345kV_1PH                   | Single phase fault on the WGardner (542965) to Stillwell (542968) 345kV line, near WGardner.<br>a. Apply fault at the WGardner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| 87               | FLT_86_Wgardner_Craig_345kV_1PH                       | Single phase fault on the WGardner (542965) to Craig (542977) 345kV line, near WGardner.<br>a. Apply fault at the WGardner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.     |
| 88               | FLT_87_Wgardner_Lacygne_345kV_1PH                     | Single phase fault on the WGardner (542965) to LaCygne (542981) 345kV line, near WGardner.<br>a. Apply fault at the WGardner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.   |
| 89               | FLT_88A_Wgardner_Swissvale_345kV_1PH (2016WP& 2017SP) | 3 phase fault on the WGardner (542965) to Swissvale (532774) 345kV line, near WGardner.<br>a. Apply fault at the WGardner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.      |
| 90               | FLT_88_Wgardner_Douglas_345kV_1PH (2025SP)            | 3 phase fault on the WGardner (542965) to Douglas (532776) 345kV line, near WGardner.<br>a. Apply fault at the WGardner 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.        |

## Results

The stability analysis was performed and the results are summarized in **Table 3-2**. The stability plots will be available upon customer request.

**Table 3-2: Summary of Results**

| Contingency Number and Name |   | 2016WP | 2017SP | 2025SP |
|-----------------------------|---|--------|--------|--------|
| 0                           | FLT_000_NOFAULT                                       | STABLE | STABLE | STABLE |
| 1                           | FLT_01_Viola_Renfrow_345kV_3PH                        | STABLE | STABLE | STABLE |
| 2                           | FLT_02_Viola_Wichita_345kV_3PH                        | STABLE | STABLE | STABLE |
| 3                           | FLT_03_Renfrow_Hunter_345kV_3PH                       | STABLE | STABLE | STABLE |
| 4                           | FLT_04_Renfrow_Renfrow_345_138kV_3PH                  | STABLE | STABLE | STABLE |
| 5                           | FLT_05_Hunter_Woodring_345kV_3PH                      | STABLE | STABLE | STABLE |
| 6                           | FLT_06_Woodring_Sooner_345kV_3PH                      | STABLE | STABLE | STABLE |
| 7                           | FLT_07_Woodring_G15063Tap_345kV_3PH                   | STABLE | STABLE | STABLE |
| 8                           | FLT_08_Woodring_Woodring_345_138kV_3PH                | STABLE | STABLE | STABLE |
| 9                           | FLT_09_Mathewson_Northwest_345kV_3PH                  | STABLE | STABLE | STABLE |
| 10                          | FLT_10_Mathewson_Cimarron_345kV_3PH                   | STABLE | STABLE | STABLE |
| 11                          | FLT_11_Mathewson_Tatonga_345kV_3PH                    | STABLE | STABLE | STABLE |
| 12                          | FLT_12_Sooner_SpringCreek_345kV_3PH                   | STABLE | STABLE | STABLE |
| 13                          | FLT_13_Sooner_G15066T_345kV_3PH                       | STABLE | STABLE | STABLE |
| 14                          | FLT_14_Sooner_Sooner_345_138kV_3PH                    | STABLE | STABLE | STABLE |
| 15                          | FLT_15_RanchRoad_Sooner_345kV_3PH                     | STABLE | STABLE | STABLE |
| 16                          | FLT_16_RanchRoad_OpenSky_345kV_3PH                    | STABLE | STABLE | STABLE |
| 17                          | FLT_17_Rosehill_Benton_345kV_3PH                      | STABLE | STABLE | STABLE |
| 18                          | FLT_18_Rosehill_WolfCreek_345kV_3PH                   | STABLE | STABLE | STABLE |
| 19                          | FLT_19_Rosehill_Latham_345kV_3PH                      | STABLE | STABLE | STABLE |
| 20                          | FLT_20_Rosehill_G15052T_345kV_3PH                     | STABLE | STABLE | STABLE |
| 21                          | FLT_21_Rosehill_Rosehill_345_138kV_3PH                | STABLE | STABLE | STABLE |
| 22                          | FLT_22_Northwest_SpringCreek_345kV_3PH                | STABLE | STABLE | STABLE |
| 23                          | FLT_23_Northwest_Cimarron_345kV_3PH                   | STABLE | STABLE | STABLE |
| 24                          | FLT_24_Northwest_Arcadia_345kV_3PH                    | STABLE | STABLE | STABLE |
| 25                          | FLT_25_Northwest_Northwest_345_138kV_3PH              | STABLE | STABLE | STABLE |
| 26                          | FLT_26_Benton_WolfCreek_345kV_3PH                     | STABLE | STABLE | STABLE |
| 27                          | FLT_27_Benton_Benton_345_138kV_3PH                    | STABLE | STABLE | STABLE |
| 28                          | FLT_28_Wichita_Reno_345kV_3PH                         | STABLE | STABLE | STABLE |
| 29                          | FLT_29_Wichita_Benton_345kV_3PH                       | STABLE | STABLE | STABLE |
| 30                          | FLT_30_Wichita_G1524&1525T_345kV_3PH                  | STABLE | STABLE | STABLE |
| 31                          | FLT_31_Wichita_Evans_345_138kV_3PH                    | STABLE | STABLE | STABLE |
| 32                          | FLT_32_Thistle_G1524&1525T_345kV_3PH                  | STABLE | STABLE | STABLE |
| 33                          | FLT_33_Thistle_Woodward_345kV_3PH                     | STABLE | STABLE | STABLE |
| 34                          | FLT_34_Thistle_ClarkCounty_345kV_3PH                  | STABLE | STABLE | STABLE |
| 35                          | FLT_35_Thistle_Thistle_345_138kV_3PH                  | STABLE | STABLE | STABLE |
| 36                          | FLT_36_Reno_Summit_345kV_3PH                          | STABLE | STABLE | STABLE |
| 37                          | FLT_37_Reno_Reno_345_115kV_3PH                        | STABLE | STABLE | STABLE |
| 38                          | FLT_38_Summit_Blustem_345kV_3PH                       | STABLE | STABLE | STABLE |
| 39                          | FLT_39_Summit_ElmCreek_345kV_3PH                      | STABLE | STABLE | STABLE |
| 40                          | FLT_40_Summit_Summit_345_230kV_3PH                    | STABLE | STABLE | STABLE |
| 41                          | FLT_41_EMPEC_Lang_345kV_3PH                           | STABLE | STABLE | STABLE |
| 42                          | FLT_42_EMPEC_Morris_345kV_3PH                         | STABLE | STABLE | STABLE |
| 43                          | FLT_43_EMPEC_Swissvale_345kV_3PH                      | STABLE | STABLE | STABLE |
| 44                          | FLT_44_EMPEC_G14001Tap_345kV_3PH                      | STABLE | STABLE | STABLE |
| 45                          | FLT_45_Morris_JECN_345kV_3PH                          | STABLE | STABLE | STABLE |
| 46                          | FLT_46_Morris_Morris_345_230kV_3PH                    | STABLE | STABLE | STABLE |
| 47                          | FLT_47_Swissvale_Wgardner_345kV_3PH (2016WP & 2017SP) | STABLE | STABLE | STABLE |
| 48                          | FLT_47_Swissvale_Douglas_345kV_3PH (2025SP)           | STABLE | STABLE | STABLE |
| 49                          | FLT_48_Swissvale_Swissvale_345_230kV_3PH              | STABLE | STABLE | STABLE |

**Table 3-2: Summary of Results**

| Contingency Number and Name |  | 2016WP | 2017SP | 2025SP |
|-----------------------------|--|--------|--------|--------|
| 50                          | FLT_49_Wgardner_Stillwell_345kV_3PH                      | STABLE | STABLE | STABLE |
| 51                          | FLT_50_Wgardner_Craig_345kV_3PH                          | STABLE | STABLE | STABLE |
| 52                          | FLT_51_Wgardner_Lacygne_345kV_3PH                        | STABLE | STABLE | STABLE |
| 53                          | FLT_52_Wgardner_Wgardner_345_161kV_3PH                   | STABLE | STABLE | STABLE |
| 54                          | FLT_53_Stillwell_Peculiar_345kV_3PH                      | STABLE | STABLE | STABLE |
| 55                          | FLT_54_Stillwell_Lacygne_345kV_3PH                       | STABLE | STABLE | STABLE |
| 56                          | FLT_55_Stillwell_Stillwell_345_161kV_3PH                 | STABLE | STABLE | STABLE |
| 57                          | FLT_56_Craig_87th_345kV_3PH                              | STABLE | STABLE | STABLE |
| 58                          | FLT_57_Craig_Craig_345_161kV_3PH                         | STABLE | STABLE | STABLE |
| 59                          | FLT_58_Lacygne_Neosho_345kV_3PH                          | STABLE | STABLE | STABLE |
| 60                          | FLT_59_Lacygne_Waverly_345kV_3PH                         | STABLE | STABLE | STABLE |
| 61                          | FLT_60_Neosho_Blackberry_345kV_3PH                       | STABLE | STABLE | STABLE |
| 62                          | FLT_61_Neosho_Delaware_345kV_3PH                         | STABLE | STABLE | STABLE |
| 63                          | FLT_62_Neosho_CaneyCreek_345kV_3PH                       | STABLE | STABLE | STABLE |
| 64                          | FLT_63_Viola_Renfrow_345kV_1PH                           | STABLE | STABLE | STABLE |
| 65                          | FLT_64_Viola_Wichita_345kV_1PH                           | STABLE | STABLE | STABLE |
| 66                          | FLT_65_Renfrow_Hunter_345kV_1PH                          | STABLE | STABLE | STABLE |
| 67                          | FLT_66_Hunter_Woodring_345kV_1PH                         | STABLE | STABLE | STABLE |
| 68                          | FLT_67_Woodring_Sooner_345kV_1PH                         | STABLE | STABLE | STABLE |
| 69                          | FLT_68_Woodring_G15063Tap_345kV_1PH                      | STABLE | STABLE | STABLE |
| 70                          | FLT_69_Sooner_SpringCreek_345kV_1PH                      | STABLE | STABLE | STABLE |
| 71                          | FLT_70_Sooner_G15066T_345kV_1PH                          | STABLE | STABLE | STABLE |
| 72                          | FLT_71_RanchRoad_Sooner_345kV_1PH                        | STABLE | STABLE | STABLE |
| 73                          | FLT_72_RanchRoad_OpenSky_345kV_1PH                       | STABLE | STABLE | STABLE |
| 74                          | FLT_73_Rosehill_Benton_345kV_1PH                         | STABLE | STABLE | STABLE |
| 75                          | FLT_74_Rosehill_WolfCreek_345kV_1PH                      | STABLE | STABLE | STABLE |
| 76                          | FLT_75_Rosehill_Latham_345kV_1PH                         | STABLE | STABLE | STABLE |
| 77                          | FLT_76_Rosehill_G15052T_345kV_1PH                        | STABLE | STABLE | STABLE |
| 78                          | FLT_77_Wichita_Reno_345kV_1PH                            | STABLE | STABLE | STABLE |
| 79                          | FLT_78_Wichita_Benton_345kV_1PH                          | STABLE | STABLE | STABLE |
| 80                          | FLT_79_Wichita_G1524_1525T_345kV_1PH                     | STABLE | STABLE | STABLE |
| 81                          | FLT_80_EMPEC_Lang_345kV_1PH                              | STABLE | STABLE | STABLE |
| 82                          | FLT_81_EMPEC_Morris_345kV_1PH                            | STABLE | STABLE | STABLE |
| 83                          | FLT_82_EMPEC_Swissvale_345kV_1PH                         | STABLE | STABLE | STABLE |
| 84                          | FLT_83_EMPEC_G14001Tap_345kV_1PH                         | STABLE | STABLE | STABLE |
| 85                          | FLT_84_Morris_JECN_345kV_1PH                             | STABLE | STABLE | STABLE |
| 86                          | FLT_85_Wgardner_Stillwell_345kV_1PH                      | STABLE | STABLE | STABLE |
| 87                          | FLT_86_Wgardner_Craig_345kV_1PH                          | STABLE | STABLE | STABLE |
| 88                          | FLT_87_Wgardner_Lacygne_345kV_1PH                        | STABLE | STABLE | STABLE |
| 89                          | FLT_88A_Wgardner_Swissvale_345kV_1PH<br>(2016WP& 2017SP) | STABLE | STABLE | STABLE |
| 90                          | FLT_88_Wgardner_Douglas_345kV_1PH (2025SP)               | STABLE | STABLE | STABLE |

## FERC LVRT Compliance

FERC Order 661A places specific requirements on wind farms through its Low Voltage Ride Through (LVRT) provisions. For Interconnection Agreements signed after December 31, 2006, wind farms shall stay on line for faults at the POI that draw the voltage down at the POI to 0.0

pu. The faults listed below in **Table 3-3** were tested to meet Order 661A LVRT provisions. GEN-2015-073 was found to be in compliance with FERC Order 661A.

**Table 3-3 LVRT Contingencies**

| Contingency Number and Name      | Description  |
|----------------------------------|--|
| FLT_41_EMPEC_Lang_345kV_3PH      | 3 phase fault on the EMPEC (532768) to Lang (532769) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.      |
| FLT_42_EMPEC_Morris_345kV_3PH    | 3 phase fault on the EMPEC (532768) to Morris (532770) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.    |
| FLT_43_EMPEC_Swissvale_345kV_3PH | 3 phase fault on the EMPEC (532768) to Swissvale (532774) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |
| FLT_44_EMPEC_G14001Tap_345kV_3PH | 3 phase fault on the EMPEC (532768) to G14001Tap (562476) 345kV line, near EMPEC.<br>a. Apply fault at the EMPEC 345kV bus.<br>b. Clear fault after 5 cycles by tripping the faulted line.<br>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.<br>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. |



## 4. Power Factor Analysis

The power factor analysis was performed for each project included in this study and is designed to demonstrate the reactive power requirements at the point of interconnection (POI) using the current study upgrade cases. For all projects that require reactive power, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the POI.

### Model Preparation

The study project as well as other projects modeled at the same POI was turned off for the power factor analysis. The projects were replaced by an equivalent generator located at the POI producing the total MW of the project at that POI and 0.0 Mvar capability.

A Mvar generator without limits was modeled at the interconnection project POI to hold a voltage schedule at the POI consistent with the greater of the voltage schedule in the base case or unity (1.0 pu) voltage.

### Disturbances

Each N-1 contingency evaluated in the Stability Analysis found in **Table 3-1** was also included in the determination of the power factor requirements.

### Results

The power factor ranges are summarized in **Table 4-1** and the resultant ranges are shown **Table D-1** located in Appendix D. The analysis showed that reactive power is required for the study project, the final requirement in the Generation Interconnection Agreement (GIA) for each project will be the pro-forma 95% lagging to 95% leading at the POI.

For analyzing power factor results a positive Q (Mvar) output indicates that the equivalent generator is supplying reactive power to the system, implying a lagging power factor. A negative Q (Mvar) output indicates that the equivalent generator is absorbing reactive power from the system, implying a leading power factor.

**Table 4-1: Summary of Power Factor Analysis at the POI**

| Request      | Capacity (MW) | Point of Interconnection (POI) | Fuel | Generator                | Lagging (providing Mvars) | Leading (absorbing Mvars) |
|--------------|---------------|--------------------------------|------|--------------------------|---------------------------|---------------------------|
| GEN-2015-073 | 200.1         | Emporia 345kV (532768)         | Wind | Vestas V126 GS<br>3.45MW | 0.95                      | 0.95                      |

NOTE: As reactive power is required for the project, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the point of interconnection.

---

## 5. Reduced Wind Generation Analysis

---

A low wind analysis was performed for GEN-2015-073. SPP performed this low wind analysis to determine the capacitive reactive power injected at the POI.

The study generator and capacitors (if any) were turned off in the base case. **Figure 5-1** shows the resulting reactive power injection (approximately 14.9Mvar) at the POI that is due to the capacitance of the project's transmission line and collector cables. **Figure 5-2** shows two reactors totaling 14.8Mvar on the low side buses of the project's 345/34.5kV transformers to offset the capacitive injection at the POI. The interconnection customer's facility is required to install a reactor or an equivalent means of compensation that can inject approximately 14.8Mvar. Reactive compensation devices are typically installed on the low side of the project's substation 345/34.5kV transformer.

Figure 5-1: GEN-2015-073 with generators turned off





Figure 5-2: GEN-2015-073 with shunt reactors at low side of project 345/34.5kV transformer and with generators turned off



---

## 6. Short Circuit Analysis

---

The short circuit analysis was performed on the 2017 and 2025 Summer Peak power flow cases using the PSS/E ASCC program. Since the power flow model does not contain negative and zero sequence data, only three-phase symmetrical fault current levels were calculated at the point of interconnection other buses up to and including five levels away from the POI.

Short Circuit Analysis was conducting using flat conditions with the following PSS/E ASCCC program settings:

- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-/0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-/0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

### Results

The results of the short circuit analysis are shown in **Appendix E, Table E-1 GEN-2015-073 Short Circuit Analysis Results (2017SP)** and **Table E-2 GEN-2015-073 Short Circuit Analysis Results (2025SP)**.

---

## 7. Conclusion

---

The GEN-2015-073 Interconnection Customer has requested a modification to its Generator Interconnection Request (GIR) to change wind turbine generators. Originally, the GIR consisted of eight-seven (87) Siemens 2.3MW wind turbines for a total 200.1 MW. The requested change is fifty-eight (58) Vestas V126 GS 3.45MW wind turbines totaling 200.1MW. The point of interconnection (POI) is the Westar Energy (WERE) Emporia Substation 345kV.

Stability analysis has determined that with all previously assigned Network Upgrades in service, generators in the monitored areas remained stable and within the pre-contingency, voltage recovery, and post fault voltage recovery criterion of 0.7pu to 1.2pu for the entire modeled disturbances. Additionally, the project wind farm was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

A power factor analysis was performed for the wind turbine modification request. As reactive power is required for GEN-2015-073, the final requirement in the GIA will be the pro-forma 95% lagging to 95% leading at the POI.

A reduced generation analysis was conducted to determine reactor inductive amounts to compensate the capacitive effects on the transmission system during low or reduced wind conditions caused by the interconnecting project's generator lead transmission line and collector systems. The interconnection customer's facility is required to install a reactor or equivalent compensation that can inject approximately 14.8Mvar of inductive reactance. Reactive compensation devices are typically installed on the low side of the project's substation 345/34.5kV transformer.

Short Circuit analysis was conducted using the current study upgrade 2017 summer peak and 2025 summer peak cases.

With the assumptions outlined in this report and with all the required network upgrades from the DISIS 2015-002 in place, GEN-2015-073 with fifty-eight (58) Vestas V126 GS 3.45MW wind turbines should be able to interconnect reliably to the SPP transmission grid. The change in wind turbine generator is not a Material Modification.

It should be noted that this study analyzed the requested modification to change generator technology, manufacturer, and layout. Powerflow analysis was not performed. This study analyzed many of the most probable contingencies, but it is not an all-inclusive list and cannot account for every operational situation. It is likely that the customer may be required to reduce its generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of delivery or transmission service. If the customer wishes to sell power from the facility, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the Customer.

---

## **Appendix A – 2016 Winter Peak Stability Plots**

---

(Available on request)

---

## **Appendix B – 2017 Summer Peak Stability Plots**

---

(Available on request)



---

## **Appendix C – 2025 Summer Peak Stability Plots**

---

(Available on request)

## Appendix D – Power Factor Analysis Results

**Table D-1: GEN-2015-073 Power Factor Analysis Results**

| Leading power factor is absorbing vars; Lagging power factor is providing vars          |                                      |              |  |              |              |  |              |              |  |      |  |
|---|--------------------------------------|--------------|--|--------------|--------------|--|--------------|--------------|--|------|--|
| GEN-2015-073 Turbine Restudy<br>POI - EMPEC 345.00 (532768)<br>Power at POI (MW): 200.1 |                                      |              | 2016 Winter Peak<br>POI Voltage = 1.005 pu |              |              | 2017 Summer Peak<br>POI Voltage = 1.010 pu |              |              | 2025 Summer Peak<br>POI Voltage = 1.010 pu |      |  |
| Contingency Name  | Mvars at POI                         | Power Factor |  | Mvars at POI | Power Factor |  | Mvars at POI | Power Factor |  |      |  |
| 0   | FLT_00_NoFault                       | -4.379       | 1.000                                      | LEAD         | -4.837       | 1.000                                      | LEAD         | -4.841       | 1.000                                      | LEAD |  |
| 1   | FLT_01_Viola_Renfrow_345kV           | -3.868       | 1.000                                      | LEAD         | -4.791       | 1.000                                      | LEAD         | -5.875       | 1.000                                      | LEAD |  |
| 2   | FLT_02_Viola_Wichita_345kV           | -6.703       | 0.999                                      | LEAD         | -8.552       | 0.999                                      | LEAD         | -6.029       | 1.000                                      | LEAD |  |
| 3   | FLT_03_Renfrow_Hunter_345kV          | -1.184       | 1.000                                      | LEAD         | -2.708       | 1.000                                      | LEAD         | -3.998       | 1.000                                      | LEAD |  |
| 4   | FLT_04_Renfrow_Renfrow_345_138kV     | -3.941       | 1.000                                      | LEAD         | -4.306       | 1.000                                      | LEAD         | -4.487       | 1.000                                      | LEAD |  |
| 5   | FLT_05_Hunter_Woodring_345kV         | 4.211        | 1.000                                      | LAG          | 1.382        | 1.000                                      | LAG          | -0.884       | 1.000                                      | LEAD |  |
| 6   | FLT_06_Woodring_Sooner_345kV         | -4.612       | 1.000                                      | LEAD         | -5.151       | 1.000                                      | LEAD         | -5.171       | 1.000                                      | LEAD |  |
| 7   | FLT_07_Woodring_G15063Tap_345kV      | -0.952       | 1.000                                      | LEAD         | -2.502       | 1.000                                      | LEAD         | -2.798       | 1.000                                      | LEAD |  |
| 8   | FLT_08_Woodring_Woodring_345_138kV   | -4.142       | 1.000                                      | LEAD         | -4.589       | 1.000                                      | LEAD         | -4.622       | 1.000                                      | LEAD |  |
| 9   | FLT_09_Mathewson_Northwest_345kV     | -4.209       | 1.000                                      | LEAD         | -4.709       | 1.000                                      | LEAD         | -4.805       | 1.000                                      | LEAD |  |
| 10  | FLT_10_Mathewson_Cimarron_345kV      | -4.124       | 1.000                                      | LEAD         | -4.639       | 1.000                                      | LEAD         | -4.674       | 1.000                                      | LEAD |  |
| 11  | FLT_11_Mathewson_Tatonga_345kV       | -3.030       | 1.000                                      | LEAD         | -3.995       | 1.000                                      | LEAD         | -4.719       | 1.000                                      | LEAD |  |
| 12  | FLT_12_Sooner_SpringCreek_345kV      | -2.341       | 1.000                                      | LEAD         | -3.614       | 1.000                                      | LEAD         | -3.528       | 1.000                                      | LEAD |  |
| 13  | FLT_13_Sooner_G15066T_345kV          | 1.175        | 1.000                                      | LAG          | -0.458       | 1.000                                      | LEAD         | -1.133       | 1.000                                      | LEAD |  |
| 14  | FLT_14_Sooner_Sooner_345_138kV       | -4.420       | 1.000                                      | LEAD         | -4.914       | 1.000                                      | LEAD         | -4.912       | 1.000                                      | LEAD |  |
| 15  | FLT_15_RanchRoad_Sooner_345kV        | 2.614        | 1.000                                      | LAG          | -0.610       | 1.000                                      | LEAD         | -0.503       | 1.000                                      | LEAD |  |
| 16  | FLT_16_RanchRoad_OpenSky_345kV       | -4.264       | 1.000                                      | LEAD         | -5.262       | 1.000                                      | LEAD         | -5.317       | 1.000                                      | LEAD |  |
| 17  | FLT_17_Rosehill_Benton_345kV         | -5.325       | 1.000                                      | LEAD         | -5.814       | 1.000                                      | LEAD         | -6.208       | 1.000                                      | LEAD |  |
| 18  | FLT_18_Rosehill_WolfCreek_345kV      | -2.625       | 1.000                                      | LEAD         | -4.340       | 1.000                                      | LEAD         | -4.193       | 1.000                                      | LEAD |  |
| 19  | FLT_19_Rosehill_Latham_345kV         | -2.608       | 1.000                                      | LEAD         | -3.312       | 1.000                                      | LEAD         | -3.621       | 1.000                                      | LEAD |  |
| 20  | FLT_20_Rosehill_G15052T_345kV        | -4.769       | 1.000                                      | LEAD         | -6.689       | 0.999                                      | LEAD         | -6.959       | 0.999                                      | LEAD |  |
| 21  | FLT_21_Rosehill_Rosehill_345_138kV   | -4.060       | 1.000                                      | LEAD         | -4.798       | 1.000                                      | LEAD         | -4.815       | 1.000                                      | LEAD |  |
| 22  | FLT_22_Northwest_SpringCreek_345kV   | -2.610       | 1.000                                      | LEAD         | -3.191       | 1.000                                      | LEAD         | -3.025       | 1.000                                      | LEAD |  |
| 23  | FLT_23_Northwest_Cimarron_345kV      | -4.345       | 1.000                                      | LEAD         | -4.807       | 1.000                                      | LEAD         | -4.798       | 1.000                                      | LEAD |  |
| 24  | FLT_24_Northwest_Arcadia_345kV       | -3.838       | 1.000                                      | LEAD         | -4.787       | 1.000                                      | LEAD         | -5.042       | 1.000                                      | LEAD |  |
| 25  | FLT_25_Northwest_Northwest_345_138kV | -4.369       | 1.000                                      | LEAD         | -4.765       | 1.000                                      | LEAD         | -4.800       | 1.000                                      | LEAD |  |
| 26  | FLT_26_Benton_WolfCreek_345kV        | -2.543       | 1.000                                      | LEAD         | -4.449       | 1.000                                      | LEAD         | -4.370       | 1.000                                      | LEAD |  |
| 27  | FLT_27_Benton_Benton_345_138kV       | -4.619       | 1.000                                      | LEAD         | -5.106       | 1.000                                      | LEAD         | -5.134       | 1.000                                      | LEAD |  |
| 28  | FLT_28_Wichita_Reno_345kV            | 2.255        | 1.000                                      | LAG          | 4.919        | 1.000                                      | LAG          | 3.585        | 1.000                                      | LAG  |  |
| 29  | FLT_29_Wichita_Benton_345kV          | -6.627       | 0.999                                      | LEAD         | -6.301       | 1.000                                      | LEAD         | -7.588       | 0.999                                      | LEAD |  |
| 30  | FLT_30_Wichita_G1524&1525T_345kV     | -3.398       | 1.000                                      | LEAD         | -4.236       | 1.000                                      | LEAD         | -4.291       | 1.000                                      | LEAD |  |
| 31  | FLT_31_Wichita_Evans_345_138kV       | -3.964       | 1.000                                      | LEAD         | -6.199       | 1.000                                      | LEAD         | -6.515       | 0.999                                      | LEAD |  |
| 32  | FLT_32_Thistle_G1524&1525T_345kV     | -2.173       | 1.000                                      | LEAD         | -3.141       | 1.000                                      | LEAD         | -2.951       | 1.000                                      | LEAD |  |
| 33  | FLT_33_Thistle_Woodward_345kV        | -4.382       | 1.000                                      | LEAD         | -4.827       | 1.000                                      | LEAD         | -4.660       | 1.000                                      | LEAD |  |
| 34  | FLT_34_Thistle_ClarkCounty_345kV     | -3.510       | 1.000                                      | LEAD         | -4.249       | 1.000                                      | LEAD         | -4.261       | 1.000                                      | LEAD |  |
| 35  | FLT_35_Thistle_Thistle_345_138kV     | -4.308       | 1.000                                      | LEAD         | -4.537       | 1.000                                      | LEAD         | -4.697       | 1.000                                      | LEAD |  |
| 36  | FLT_36_Reno_Summit_345kV             | -1.524       | 1.000                                      | LEAD         | -1.683       | 1.000                                      | LEAD         | -2.001       | 1.000                                      | LEAD |  |
| 37  | FLT_37_Reno_Reno_345_115kV           | -4.155       | 1.000                                      | LEAD         | -4.349       | 1.000                                      | LEAD         | -4.607       | 1.000                                      | LEAD |  |

| Leading power factor is absorbing vars; Lagging power factor is providing vars          |                                      |              |  |              |              |  |              |              |  |      |  |
|---|--------------------------------------|--------------|--|--------------|--------------|--|--------------|--------------|--|------|--|
| GEN-2015-073 Turbine Restudy<br>POI - EMPEC 345.00 (532768)<br>Power at POI (MW): 200.1 |                                      |              | 2016 Winter Peak<br>POI Voltage = 1.005 pu |              |              | 2017 Summer Peak<br>POI Voltage = 1.010 pu |              |              | 2025 Summer Peak<br>POI Voltage = 1.010 pu |      |  |
| Contingency Name  | Mvars at POI                         | Power Factor |  | Mvars at POI | Power Factor |  | Mvars at POI | Power Factor |  |      |  |
| 38  | FLT_38_Summit_JECN_345kV             | -3.817       | 1.000                                      | LEAD         | -4.042       | 1.000                                      | LEAD         | -4.304       | 1.000                                      | LEAD |  |
| 39  | FLT_39_Summit_ElmCreek_345kV         | -2.598       | 1.000                                      | LEAD         | -3.136       | 1.000                                      | LEAD         | -3.355       | 1.000                                      | LEAD |  |
| 40  | FLT_40_Summit_Summit_345_230kV       | -4.528       | 1.000                                      | LEAD         | -3.920       | 1.000                                      | LEAD         | -3.951       | 1.000                                      | LEAD |  |
| 41  | FLT_41_EMPEC_Lang_345kV              | -10.385      | 0.999                                      | LEAD         | -8.952       | 0.999                                      | LEAD         | -9.541       | 0.999                                      | LEAD |  |
| 42  | FLT_42_EMPEC_Morris_345kV            | 6.749        | 0.999                                      | LAG          | 6.044        | 1.000                                      | LAG          | 5.584        | 1.000                                      | LAG  |  |
| 43  | FLT_43_EMPEC_Swissvale_345kV         | -13.286      | 0.998                                      | LEAD         | -15.774      | 0.997                                      | LEAD         | -16.044      | 0.997                                      | LEAD |  |
| 44  | FLT_44_EMPEC_G14001Tap_345kV         | -5.870       | 1.000                                      | LEAD         | -8.940       | 0.999                                      | LEAD         | -7.177       | 0.999                                      | LEAD |  |
| 45  | FLT_45_Morris_JECN_345kV             | 2.956        | 1.000                                      | LAG          | -0.893       | 1.000                                      | LEAD         | -1.159       | 1.000                                      | LEAD |  |
| 46  | FLT_46_Morris_Morris_345_230kV       | -7.029       | 0.999                                      | LEAD         | -4.780       | 1.000                                      | LEAD         | -4.822       | 1.000                                      | LEAD |  |
| 47  | FLT_47_Swissvale_Wgardner_345kV      | -14.337      | 0.997                                      | LEAD         | -16.485      | 0.997 <sup>1</sup>                         | LEAD         | -13.985      | 0.998                                      | LEAD |  |
| 48  | FLT_48_Swissvale_Swissvale_345_230kV | -6.678       | 0.999                                      | LEAD         | -4.894       | 1.000                                      | LEAD         | -5.026       | 1.000                                      | LEAD |  |
| 49  | FLT_49_Wgardner_Stillwell_345kV      | -4.927       | 1.000                                      | LEAD         | -5.922       | 1.000                                      | LEAD         | -6.014       | 1.000                                      | LEAD |  |
| 50  | FLT_50_Wgardner_Craig_345kV          | -3.242       | 1.000                                      | LEAD         | -4.424       | 1.000                                      | LEAD         | -3.828       | 1.000                                      | LEAD |  |
| 51  | FLT_51_Wgardner_Lacygne_345kV        | 5.444        | 1.000                                      | LAG          | 5.721        | 1.000                                      | LAG          | 5.363        | 1.000                                      | LAG  |  |
| 52  | FLT_52_Wgardner_Wgardner_345_161kV   | -5.435       | 1.000                                      | LEAD         | -5.343       | 1.000                                      | LEAD         | -5.360       | 1.000                                      | LEAD |  |
| 53  | FLT_53_Stillwell_Peculiar_345kV      | -1.916       | 1.000                                      | LEAD         | -2.855       | 1.000                                      | LEAD         | -2.878       | 1.000                                      | LEAD |  |
| 54  | FLT_54_Stillwell_Lacygne_345kV       | 9.599        | 0.999                                      | LAG          | 9.749        | 0.999                                      | LAG          | 9.564        | 0.999                                      | LAG  |  |
| 55  | FLT_55_Stillwell_Stillwell_345_161kV | -4.075       | 1.000                                      | LEAD         | -4.602       | 1.000                                      | LEAD         | -4.607       | 1.000                                      | LEAD |  |
| 56  | FLT_56_Craig_87 <sup>th</sup> _345kV | -2.229       | 1.000                                      | LEAD         | -1.433       | 1.000                                      | LEAD         | -1.737       | 1.000                                      | LEAD |  |
| 57  | FLT_57_Craig_Craig_345_161kV         | -3.998       | 1.000                                      | LEAD         | -4.577       | 1.000                                      | LEAD         | -4.593       | 1.000                                      | LEAD |  |
| 58  | FLT_58_Lacygne_Neosho_345kV          | -4.324       | 1.000                                      | LEAD         | -4.954       | 1.000                                      | LEAD         | -4.978       | 1.000                                      | LEAD |  |
| 59  | FLT_59_Lacygne_Waverly_345kV         | 22.914       | 0.994 <sup>2</sup>                         | LAG          | 15.240       | 0.997                                      | LAG          | 13.566       | 0.998                                      | LAG  |  |
| 60  | FLT_60_Neosho_Blackberry_345kV       | -2.867       | 1.000                                      | LEAD         | -3.806       | 1.000                                      | LEAD         | -3.741       | 1.000                                      | LEAD |  |
| 61  | FLT_61_Neosho_Delaware_345kV         | -3.162       | 1.000                                      | LEAD         | -3.984       | 1.000                                      | LEAD         | -3.984       | 1.000                                      | LEAD |  |
| 62  | FLT_62_Neosho_CaneyCreek_345kV       | 3.183        | 1.000                                      | LAG          | 1.924        | 1.000                                      | LAG          | 1.300        | 1.000                                      | LAG  |  |

1. Most leading power factor
2. Most lagging power factor

# Appendix E – Short Circuit Analysis Results

**Table E-1: GEN-2015-073 Short Circuit Analysis Results (2017SP)**

PSS(R)E-32.2.2 ASCC SHORT CIRCUIT CURRENTS TUE, FEB

14 2017 17:11  
 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO  
 MDWG 17S WITH MMWG 15S, MRO 16W TOPO/16S PROF, SERC 16S

OPTIONS USED:

- FLAT CONDITIONS
  - BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
  - GENERATOR P=0, Q=0
  - TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
  - LINE CHARGING=0.0 IN +/-0 SEQUENCE
  - LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
  - LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCE
  - DC LINES AND FACTS DEVICES BLOCKED
  - TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

| X----- BUS -----X |               |         | THREE PHASE FAULT |                  |
|-------------------|---------------|---------|-------------------|------------------|
|                   |               |         | /I+/<br>AMP       | AN(I+)<br>-86.19 |
| 532768            | [EMPEC 7      | 345.00] | AMP               | 17283.1          |
| 532769            | [LANG 7       | 345.00] | AMP               | 17072.2          |
| 532770            | [MORRIS 7     | 345.00] | AMP               | 12731.0          |
| 532774            | [SWISVAL7     | 345.00] | AMP               | 16423.8          |
| 562476            | [G14-001-TAP  | 345.00] | AMP               | 10942.5          |
| 585100            | [GEN-2015-073 | 345.00] | AMP               | 14171.8          |
| 532766            | [JEC N 7      | 345.00] | AMP               | 23298.6          |
| 532796            | [WICHITA7     | 345.00] | AMP               | 23718.1          |
| 532856            | [SWISVAL6     | 230.00] | AMP               | 21813.3          |
| 532863            | [MORRIS 6     | 230.00] | AMP               | 13782.0          |
| 533304            | [LANG 3       | 115.00] | AMP               | 14440.2          |
| 542965            | [W.GRDNR7     | 345.00] | AMP               | 25251.9          |
| 583850            | [GEN-2014-001 | 345.00] | AMP               | 7502.8           |
| 532765            | [HOYT 7       | 345.00] | AMP               | 15354.2          |
| 532767            | [BLUSTEM7     | 345.00] | AMP               | 9609.0           |
| 532771            | [RENO 7       | 345.00] | AMP               | 10671.1          |
| 532791            | [BENTON 7     | 345.00] | AMP               | 19033.4          |
| 532798            | [VIOLA 7      | 345.00] | AMP               | 11409.3          |
| 532851            | [AUBURN 6     | 230.00] | AMP               | 13446.6          |
| 532852            | [JEC 6        | 230.00] | AMP               | 24522.2          |
| 532857            | [TECHILL6     | 230.00] | AMP               | 11266.9          |
| 532858            | [BALDWIN6     | 230.00] | AMP               | 13734.8          |
| 532862            | [MCDOWEL6     | 230.00] | AMP               | 6892.7           |
| 532874            | [UNIONRG6     | 230.00] | AMP               | 8763.7           |
| 533040            | [EVANS N4     | 138.00] | AMP               | 37053.0          |
| 533301            | [EAST ST3     | 115.00] | AMP               | 9202.6           |
| 533305            | [MORRIS 3     | 115.00] | AMP               | 12407.5          |
| 533306            | [READING3     | 115.00] | AMP               | 6390.9           |
| 533307            | [PRAIRIE3     | 115.00] | AMP               | 9248.7           |
| 542966            | [WGARDNR5     | 161.00] | AMP               | 27244.1          |
| 542968            | [STILWEL7     | 345.00] | AMP               | 24264.6          |
| 542977            | [CRAIG 7      | 345.00] | AMP               | 21510.9          |
| 542981            | [LACYGNE7     | 345.00] | AMP               | 24950.3          |
| 560033            | [G1524&G1525T | 345.00] | AMP               | 19150.8          |
| 515543            | [RENFROW7     | 345.00] | AMP               | 11221.6          |
| 532772            | [STRANGR7     | 345.00] | AMP               | 22142.2          |

|        |                      |         |        |         |        |
|--------|----------------------|---------|--------|---------|--------|
| 532773 | [SUMMIT 7            | 345.00] | AMP    | 10231.9 | -85.73 |
| 532775 | [87TH 7              | 345.00] | AMP    | 19924.0 | -85.69 |
| 532792 | [FR2EAST7            | 345.00] | AMP    | 6214.1  | -85.59 |
| 532793 | [NEOSHO 7            | 345.00] | AMP    | 16198.2 | -84.49 |
| 532794 | [ROSEHIL7            | 345.00] | AMP    | 18824.7 | -85.80 |
| 532797 | [WOLFCRK7            | 345.00] | AMP    | 15971.2 | -86.81 |
| 532799 | [WAVERLY7            | 345.00] | AMP    | 14712.8 | -86.51 |
| 532853 | [LAWHILL6            | 230.00] | AMP    | 13751.9 | -85.20 |
| 532861 | [EMANHAT6            | 230.00] | AMP    | 9565.6  | -85.60 |
| 532873 | [SUMMIT 6            | 230.00] | AMP    | 12906.7 | -85.19 |
| 532986 | [BENTON 4            | 138.00] | AMP    | 27908.2 | -85.85 |
| 533041 | [EVANS S4            | 138.00] | AMP    | 37053.0 | -87.18 |
| 533065 | [SG12COL4            | 138.00] | AMP    | 20146.8 | -85.76 |
| 533151 | [AUBURN 3            | 115.00] | AMP    | 21702.4 | -84.05 |
| 533163 | [HOYT 3              | 115.00] | AMP    | 22824.7 | -85.67 |
| 533171 | [OSAGE J3            | 115.00] | AMP    | 5151.5  | -72.86 |
| 533182 | [TECHILE3            | 115.00] | AMP    | 30018.6 | -82.91 |
| 533232 | [BALDCRK3            | 115.00] | AMP    | 19909.9 | -84.58 |
| 533309 | [WEMPORI3            | 115.00] | AMP    | 9770.3  | -81.62 |
| 533335 | [MCDOWEL3            | 115.00] | AMP    | 17702.0 | -85.31 |
| 533336 | [BLUSTEM3            | 115.00] | AMP    | 16964.4 | -86.43 |
| 533359 | [UNIONRG3            | 115.00] | AMP    | 3784.2  | -87.74 |
| 533390 | [MAIZEW 4            | 138.00] | AMP    | 25939.2 | -85.53 |
| 533416 | [RENO 3              | 115.00] | AMP    | 21539.8 | -85.57 |
| 539801 | [THISTLE7            | 345.00] | AMP    | 15378.5 | -85.86 |
| 541198 | [PECULR 7            | 345.00] | AMP    | 20114.0 | -85.62 |
| 542969 | [STILWEL5            | 161.00] | AMP    | 38986.5 | -85.84 |
| 542978 | [CRAIG 5             | 161.00] | AMP    | 39235.8 | -85.69 |
| 543049 | [CEDRCRK5            | 161.00] | AMP    | 27477.8 | -84.94 |
| 543054 | [CEDARNL5            | 161.00] | AMP    | 13621.2 | -84.61 |
| 543077 | [PLSTVAL5            | 161.00] | AMP    | 9737.8  | -83.35 |
| 543105 | [BULLCRK5            | 161.00] | AMP    | 24968.2 | -87.10 |
| 543132 | [BNSF 5              | 161.00] | AMP    | 19921.4 | -85.74 |
| 584659 | [G15024G15025345.00] | AMP     | 6650.0 | -86.46  |        |
| 585070 | [GEN-2015-069230.00] | AMP     | 6570.4 | -84.48  |        |
| 300739 | [7BLACKBERRY         | 345.00] | AMP    | 12247.8 | -84.37 |
| 510380 | [DELWARE7            | 345.00] | AMP    | 11393.8 | -84.84 |
| 515375 | [WWRDEHV7            | 345.00] | AMP    | 18092.5 | -85.93 |
| 515476 | [HUNTERS7            | 345.00] | AMP    | 12085.2 | -84.69 |
| 515544 | [RENFROW4            | 138.00] | AMP    | 13395.7 | -84.83 |
| 530592 | [SMOKYHL6            | 230.00] | AMP    | 6884.6  | -84.32 |
| 532780 | [CANEYRV7            | 345.00] | AMP    | 9887.0  | -85.50 |
| 532795 | [FR2WEST7            | 345.00] | AMP    | 5204.9  | -85.65 |
| 532800 | [LATHAMS7            | 345.00] | AMP    | 10459.6 | -85.56 |
| 532802 | [WAVERTX7            | 345.00] | AMP    | 12556.3 | -86.05 |
| 532854 | [LEC U5 6            | 230.00] | AMP    | 13616.5 | -85.09 |
| 532855 | [MIDLAND6            | 230.00] | AMP    | 12175.6 | -84.82 |
| 532865 | [NMANHT6             | 230.00] | AMP    | 8770.7  | -85.16 |
| 532872 | [EMCPHER6            | 230.00] | AMP    | 7716.0  | -83.42 |
| 532920 | [TECHILL5            | 161.00] | AMP    | 5771.5  | -84.75 |
| 532937 | [NEOSHO 5            | 161.00] | AMP    | 21992.2 | -84.26 |
| 532988 | [BELAIRE4            | 138.00] | AMP    | 18637.6 | -84.79 |
| 532990 | [MIDIAN 4            | 138.00] | AMP    | 10061.0 | -80.49 |
| 533015 | [BENTLEY4            | 138.00] | AMP    | 9827.5  | -85.10 |
| 533021 | [NEOSHO 4            | 138.00] | AMP    | 23036.3 | -84.46 |
| 533024 | [29TH 4              | 138.00] | AMP    | 19399.9 | -85.12 |
| 533035 | [CHISHLM4            | 138.00] | AMP    | 21786.1 | -84.81 |
| 533053 | [LAKERDG4            | 138.00] | AMP    | 17996.8 | -85.60 |
| 533054 | [MAIZE 4             | 138.00] | AMP    | 22202.1 | -85.18 |
| 533062 | [ROSEHIL4            | 138.00] | AMP    | 30970.3 | -86.16 |
| 533074 | [45TH ST4            | 138.00] | AMP    | 25950.4 | -85.68 |

|        |                      |         |     |         |        |
|--------|----------------------|---------|-----|---------|--------|
| 533153 | [COLINE 3            | 115.00] | AMP | 23235.0 | -81.04 |
| 533155 | [CROOKED3            | 115.00] | AMP | 20489.6 | -84.01 |
| 533166 | [INDIANH3            | 115.00] | AMP | 17630.7 | -82.26 |
| 533167 | [KEENE 3             | 115.00] | AMP | 10051.0 | -84.37 |
| 533169 | [NTHLAND3            | 115.00] | AMP | 15021.4 | -82.70 |
| 533170 | [OSAGE 3             | 115.00] | AMP | 4384.3  | -71.72 |
| 533176 | [SHAWNEE3            | 115.00] | AMP | 12205.2 | -82.20 |
| 533177 | [6 GOLDN3            | 115.00] | AMP | 16256.1 | -81.89 |
| 533180 | [TEC E 3             | 115.00] | AMP | 29606.0 | -82.94 |
| 533187 | [27CROC03            | 115.00] | AMP | 20243.5 | -83.01 |
| 533194 | [SHERWOD3            | 115.00] | AMP | 19824.1 | -83.74 |
| 533197 | [HARTLND3            | 115.00] | AMP | 4720.2  | -74.94 |
| 533198 | [HOYTJS 3            | 115.00] | AMP | 19905.8 | -84.88 |
| 533199 | [HOYTJN 3            | 115.00] | AMP | 18913.7 | -84.62 |
| 533250 | [LWRNCHL3            | 115.00] | AMP | 27782.9 | -83.95 |
| 533268 | [STRANGR3            | 115.00] | AMP | 31925.0 | -86.81 |
| 533270 | [STULL T3            | 115.00] | AMP | 12144.4 | -72.49 |
| 533271 | [SWLWRNC3            | 115.00] | AMP | 18543.3 | -80.95 |
| 533283 | [87TH 3              | 115.00] | AMP | 26058.7 | -85.95 |
| 533308 | [VAUGHN 3            | 115.00] | AMP | 2811.4  | -71.29 |
| 533311 | [WMBROSJ3            | 115.00] | AMP | 6761.4  | -76.34 |
| 533326 | [EMANHAT3            | 115.00] | AMP | 13088.0 | -85.59 |
| 533328 | [FT JCT 3            | 115.00] | AMP | 14504.6 | -85.84 |
| 533341 | [STAGGHL3            | 115.00] | AMP | 9504.6  | -83.82 |
| 533350 | [SMAN_W_3            | 115.00] | AMP | 12505.2 | -79.35 |
| 533360 | [TCHOPE 3            | 115.00] | AMP | 3364.3  | -87.26 |
| 533362 | [CHAPMAN3            | 115.00] | AMP | 10324.2 | -85.53 |
| 533381 | [SUMMIT 3            | 115.00] | AMP | 16809.6 | -86.26 |
| 533392 | [SCRNTJS3            | 115.00] | AMP | 5082.8  | -74.25 |
| 533413 | [CIRCLE 3            | 115.00] | AMP | 18064.1 | -85.03 |
| 533415 | [DAVIS 3             | 115.00] | AMP | 8102.7  | -82.40 |
| 533429 | [MOUNDRG3            | 115.00] | AMP | 7010.5  | -83.06 |
| 533438 | [WMPHER3             | 115.00] | AMP | 10832.7 | -84.14 |
| 539800 | [CLARKCOUNTY7        | 345.00] | AMP | 12611.4 | -84.73 |
| 539804 | [THISTLE4            | 138.00] | AMP | 16296.2 | -86.47 |
| 539805 | [ELMCREEK7           | 345.00] | AMP | 5251.7  | -85.37 |
| 541200 | [PHILL 7             | 345.00] | AMP | 18156.0 | -85.65 |
| 541231 | [STRANGR5            | 161.00] | AMP | 15155.9 | -87.58 |
| 541341 | [S.HARP 5            | 161.00] | AMP | 25055.9 | -85.17 |
| 541342 | [PECULR 5            | 161.00] | AMP | 24419.7 | -85.47 |
| 542979 | [PFLUMM 5            | 161.00] | AMP | 26860.2 | -85.04 |
| 542982 | [IATAN 7             | 345.00] | AMP | 25786.0 | -86.70 |
| 542994 | [HICKMAN5            | 161.00] | AMP | 18422.9 | -83.90 |
| 542995 | [MONTROS5            | 161.00] | AMP | 17462.5 | -84.08 |
| 543031 | [SHWNMSN5            | 161.00] | AMP | 31001.3 | -84.73 |
| 543038 | [LENEXAS5            | 161.00] | AMP | 26147.1 | -85.03 |
| 543039 | [LENEXAN5            | 161.00] | AMP | 27167.3 | -84.72 |
| 543044 | [MOONLT 5            | 161.00] | AMP | 16510.9 | -85.05 |
| 543048 | [COLLEGE5            | 161.00] | AMP | 27872.2 | -84.69 |
| 543050 | [ANTIOCH5            | 161.00] | AMP | 21947.3 | -84.42 |
| 543053 | [REDEL 5             | 161.00] | AMP | 23838.3 | -84.19 |
| 543055 | [SEOTTWA5            | 161.00] | AMP | 6692.0  | -81.12 |
| 543057 | [BUCYRUS5            | 161.00] | AMP | 19128.2 | -84.31 |
| 543126 | [LACKMAN5            | 161.00] | AMP | 13045.0 | -83.85 |
| 543131 | [CLARE 5             | 161.00] | AMP | 13981.8 | -84.49 |
| 560053 | [G15-052T            | 345.00] | AMP | 13120.0 | -86.45 |
| 583750 | [GEN-2013-029345.00] |         | AMP | 10000.2 | -84.61 |
| 584660 | [GEN-2015-024345.00] |         | AMP | 5405.6  | -86.43 |
| 584670 | [GEN-2015-025345.00] |         | AMP | 6534.5  | -86.43 |
| 585250 | [GEN-2015-090345.00] |         | AMP | 3101.8  | -85.71 |

**Table E-2: GEN-2015-073 Short Circuit Analysis Results (2025SP)**

PSS(R)E-32.2.2 ASCC SHORT CIRCUIT CURRENTS

TUE, FEB 14

2017 17:14

2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO

MDWG 2025S WITH MMWG 2024S, MRO & SERC 2025 SUMMER

OPTIONS USED:

- FLAT CONDITIONS
  - BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
  - GENERATOR P=0, Q=0
  - TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
  - LINE CHARGING=0.0 IN +/-0 SEQUENCE
  - LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
  - LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCE
  - DC LINES AND FACTS DEVICES BLOCKED
  - TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

| X----- BUS -----X |               |         | THREE PHASE FAULT |             |
|-------------------|---------------|---------|-------------------|-------------|
|                   |               |         | /I+/<br>AMP       | AN(I+)<br>- |
| 532768            | [EMPEC 7      | 345.00] | 17389.2           | -86.18      |
| 532769            | [LANG 7       | 345.00] | 17175.8           | -86.17      |
| 532770            | [MORRIS 7     | 345.00] | 12794.9           | -85.53      |
| 532774            | [SWISVAL7     | 345.00] | 16681.3           | -85.36      |
| 562476            | [G14-001-TAP  | 345.00] | 11042.5           | -85.05      |
| 585100            | [GEN-2015-073 | 345.00] | 14242.4           | -85.64      |
| 532766            | [JEC N 7      | 345.00] | 23513.3           | -87.51      |
| 532776            | [DOUGLAS7     | 345.00] | 18181.1           | -85.14      |
| 532796            | [WICHITA7     | 345.00] | 24680.8           | -86.24      |
| 532856            | [SWISVAL6     | 230.00] | 21903.8           | -85.41      |
| 532863            | [MORRIS 6     | 230.00] | 13858.1           | -85.32      |
| 533304            | [LANG 3       | 115.00] | 14470.0           | -85.15      |
| 583850            | [GEN-2014-001 | 345.00] | 7545.9            | -84.77      |
| 532765            | [HOYT 7       | 345.00] | 15628.7           | -85.78      |
| 532767            | [BLUSTEM7     | 345.00] | 9737.1            | -86.29      |
| 532771            | [RENO 7       | 345.00] | 11457.1           | -85.98      |
| 532791            | [BENTON 7     | 345.00] | 19393.9           | -85.74      |
| 532798            | [VIOLA 7      | 345.00] | 13506.5           | -85.45      |
| 532851            | [AUBURN 6     | 230.00] | 13515.0           | -83.80      |
| 532852            | [JEC 6        | 230.00] | 24643.2           | -87.76      |
| 532857            | [TECHILL6     | 230.00] | 11312.4           | -84.30      |
| 532858            | [BALDWIN6     | 230.00] | 14316.5           | -84.69      |
| 532862            | [MCDOWEL6     | 230.00] | 6912.1            | -84.93      |
| 532874            | [UNIONRG6     | 230.00] | 8856.4            | -83.66      |
| 533040            | [EVANS N4     | 138.00] | 42055.9           | -87.26      |
| 533285            | [DOUGLAS3     | 115.00] | 23976.7           | -85.78      |
| 533301            | [EAST ST3     | 115.00] | 9217.3            | -82.07      |
| 533305            | [MORRIS 3     | 115.00] | 12438.3           | -86.31      |
| 533306            | [READING3     | 115.00] | 6396.0            | -73.69      |
| 533307            | [PRAIRIE3     | 115.00] | 9264.2            | -82.45      |
| 542965            | [W.GRDNR7     | 345.00] | 25938.2           | -85.83      |
| 560033            | [G1524&G1525T | 345.00] | 19678.1           | -86.39      |
| 515543            | [RENFROW7     | 345.00] | 11853.9           | -84.75      |
| 532772            | [STRANGR7     | 345.00] | 24242.2           | -86.19      |
| 532773            | [SUMMIT 7     | 345.00] | 10600.8           | -85.90      |
| 532792            | [FR2EAST7     | 345.00] | 6648.9            | -85.72      |
| 532794            | [ROSEHIL7     | 345.00] | 19128.0           | -85.82      |
| 532797            | [WOLFCRK7     | 345.00] | 16039.4           | -86.82      |
| 532853            | [LAWHILL6     | 230.00] | 14469.7           | -85.39      |
| 532861            | [EMANHAT6     | 230.00] | 9599.6            | -85.62      |

|        |                      |         |     |         |        |
|--------|----------------------|---------|-----|---------|--------|
| 532873 | [SUMMIT 6            | 230.00] | AMP | 13478.4 | -85.34 |
| 532986 | [BENTON 4            | 138.00] | AMP | 28458.3 | -85.85 |
| 533041 | [EVANS S4            | 138.00] | AMP | 42055.9 | -87.26 |
| 533065 | [SG12COL4            | 138.00] | AMP | 21501.9 | -85.71 |
| 533075 | [VIOLA 4             | 138.00] | AMP | 22036.2 | -86.03 |
| 533151 | [AUBURN 3            | 115.00] | AMP | 21977.4 | -84.09 |
| 533163 | [HOYT 3              | 115.00] | AMP | 23018.6 | -85.75 |
| 533171 | [OSAGE J3            | 115.00] | AMP | 5155.5  | -72.85 |
| 533182 | [TECHILE3            | 115.00] | AMP | 30488.4 | -82.76 |
| 533232 | [BALDCRK3            | 115.00] | AMP | 21675.0 | -84.85 |
| 533236 | [FAIRGDS3            | 115.00] | AMP | 22153.2 | -81.51 |
| 533271 | [SWLWRNC3            | 115.00] | AMP | 22816.0 | -81.96 |
| 533309 | [WEMPORI3            | 115.00] | AMP | 9790.0  | -81.60 |
| 533335 | [MCDOWEL3            | 115.00] | AMP | 17763.0 | -85.57 |
| 533336 | [BLUSTEM3            | 115.00] | AMP | 17078.9 | -86.54 |
| 533359 | [UNIONRG3            | 115.00] | AMP | 3792.8  | -87.75 |
| 533390 | [MAIZEW 4            | 138.00] | AMP | 27864.2 | -85.44 |
| 533416 | [RENO 3              | 115.00] | AMP | 25059.6 | -86.11 |
| 539801 | [THISTLE7            | 345.00] | AMP | 15716.4 | -85.88 |
| 542966 | [WGARDNR5            | 161.00] | AMP | 27436.8 | -86.93 |
| 542968 | [STILWEL7            | 345.00] | AMP | 24401.2 | -85.86 |
| 542977 | [CRAIG 7             | 345.00] | AMP | 21942.5 | -85.75 |
| 542981 | [LACYGNE7            | 345.00] | AMP | 25069.4 | -86.87 |
| 584659 | [G15024G15025345.00] |         | AMP | 6698.0  | -86.48 |
| 585070 | [GEN-2015-069230.00] |         | AMP | 6610.8  | -84.48 |
| 515375 | [WWRDEHV7            | 345.00] | AMP | 20414.7 | -86.01 |
| 515476 | [HUNTERS7            | 345.00] | AMP | 12445.0 | -84.73 |
| 515544 | [RENFROW4            | 138.00] | AMP | 13620.7 | -84.89 |
| 530592 | [SMOKYHL6            | 230.00] | AMP | 6941.3  | -84.30 |
| 532775 | [87TH 7              | 345.00] | AMP | 20389.3 | -85.75 |
| 532793 | [NEOSHO 7            | 345.00] | AMP | 16293.0 | -84.49 |
| 532795 | [FR2WEST7            | 345.00] | AMP | 5481.1  | -85.75 |
| 532799 | [WAVERLY7            | 345.00] | AMP | 14764.2 | -86.51 |
| 532800 | [LATHAMS7            | 345.00] | AMP | 10515.9 | -85.56 |
| 532854 | [LEC U5 6            | 230.00] | AMP | 14314.9 | -85.27 |
| 532855 | [MIDLAND6            | 230.00] | AMP | 12771.6 | -84.98 |
| 532865 | [NMANHT6             | 230.00] | AMP | 8802.0  | -85.19 |
| 532872 | [EMCPHER6            | 230.00] | AMP | 8520.3  | -83.90 |
| 532920 | [TECHILL5            | 161.00] | AMP | 5790.7  | -84.76 |
| 532984 | [SUMNER 4            | 138.00] | AMP | 10180.1 | -82.91 |
| 532988 | [BELAIRE4            | 138.00] | AMP | 18906.2 | -84.76 |
| 532990 | [MIDIAN 4            | 138.00] | AMP | 10208.1 | -81.79 |
| 533015 | [BENTLEY4            | 138.00] | AMP | 10120.2 | -85.06 |
| 533024 | [29TH 4              | 138.00] | AMP | 19689.4 | -85.09 |
| 533035 | [CHISHLM4            | 138.00] | AMP | 22456.6 | -84.77 |
| 533036 | [CLEARWT4            | 138.00] | AMP | 21755.7 | -85.40 |
| 533046 | [GILL S 4            | 138.00] | AMP | 28357.0 | -85.43 |
| 533053 | [LAKERDG4            | 138.00] | AMP | 18961.9 | -85.56 |
| 533054 | [MAIZE 4             | 138.00] | AMP | 23381.2 | -85.11 |
| 533062 | [ROSEHIL4            | 138.00] | AMP | 31772.9 | -86.17 |
| 533074 | [45TH ST4            | 138.00] | AMP | 29217.4 | -86.42 |
| 533153 | [COLINE 3            | 115.00] | AMP | 23427.4 | -80.93 |
| 533155 | [CROOKED3            | 115.00] | AMP | 20734.5 | -84.04 |
| 533166 | [INDIANH3            | 115.00] | AMP | 17814.9 | -82.22 |
| 533167 | [KEENE 3             | 115.00] | AMP | 10031.8 | -85.12 |
| 533169 | [NTHLAND3            | 115.00] | AMP | 15094.3 | -82.68 |
| 533170 | [OSAGE 3             | 115.00] | AMP | 4387.2  | -71.70 |
| 533176 | [SHAWNEE3            | 115.00] | AMP | 12271.5 | -82.16 |
| 533177 | [6 GOLDN3            | 115.00] | AMP | 16334.2 | -81.83 |
| 533180 | [TEC E 3             | 115.00] | AMP | 30049.2 | -82.79 |
| 533187 | [27CROCO3            | 115.00] | AMP | 20481.8 | -82.89 |



|        |                      |         |     |         |        |
|--------|----------------------|---------|-----|---------|--------|
| 533194 | [SHERWOD3            | 115.00] | AMP | 20135.9 | -83.72 |
| 533197 | [HARTLND3            | 115.00] | AMP | 13015.2 | -81.23 |
| 533198 | [HOYTJS 3            | 115.00] | AMP | 20048.8 | -84.93 |
| 533199 | [HOYTJN 3            | 115.00] | AMP | 19061.0 | -84.73 |
| 533234 | [BISMAR3             | 115.00] | AMP | 22060.4 | -80.86 |
| 533240 | [EUDORA 3            | 115.00] | AMP | 12123.5 | -81.77 |
| 533250 | [LWRNCHL3            | 115.00] | AMP | 30883.2 | -83.97 |
| 533253 | [MOCKBRD3            | 115.00] | AMP | 20606.4 | -79.49 |
| 533256 | [19THST 3            | 115.00] | AMP | 19242.5 | -80.73 |
| 533257 | [19THSTJ3            | 115.00] | AMP | 19836.4 | -80.95 |
| 533268 | [STRANGR3            | 115.00] | AMP | 33054.2 | -86.94 |
| 533270 | [STULL T3            | 115.00] | AMP | 12659.0 | -72.25 |
| 533308 | [VAUGHN 3            | 115.00] | AMP | 2812.9  | -71.28 |
| 533311 | [WMBROSJ3            | 115.00] | AMP | 6774.1  | -76.31 |
| 533326 | [EMANHAT3            | 115.00] | AMP | 13123.0 | -85.63 |
| 533328 | [FT JCT 3            | 115.00] | AMP | 14585.1 | -85.96 |
| 533340 | [SMANHAT3            | 115.00] | AMP | 11996.4 | -85.49 |
| 533341 | [STAGGHL3            | 115.00] | AMP | 9524.1  | -83.88 |
| 533360 | [TCHOPE 3            | 115.00] | AMP | 3371.1  | -87.27 |
| 533362 | [CHAPMAN3            | 115.00] | AMP | 10381.9 | -85.59 |
| 533381 | [SUMMIT 3            | 115.00] | AMP | 17359.3 | -86.39 |
| 533392 | [SCRNTJS3            | 115.00] | AMP | 5088.0  | -74.23 |
| 533413 | [CIRCLE 3            | 115.00] | AMP | 22714.6 | -85.87 |
| 533415 | [DAVIS 3             | 115.00] | AMP | 8741.9  | -82.40 |
| 533429 | [MOUNDRG3            | 115.00] | AMP | 7183.7  | -83.13 |
| 533438 | [WMCIPHER3           | 115.00] | AMP | 12426.2 | -84.78 |
| 533880 | [GODDARD2            | 138.00] | AMP | 18933.2 | -85.91 |
| 539800 | [CLARKCOUNTY7        | 345.00] | AMP | 12693.8 | -84.73 |
| 539804 | [THISTLE4            | 138.00] | AMP | 16515.4 | -86.38 |
| 539805 | [ELMCREEK7           | 345.00] | AMP | 5313.6  | -85.43 |
| 541198 | [PECULR 7            | 345.00] | AMP | 20152.7 | -85.60 |
| 542969 | [STILWEL5            | 161.00] | AMP | 38867.9 | -85.83 |
| 542978 | [CRAIG 5             | 161.00] | AMP | 39829.9 | -85.73 |
| 542982 | [IATAN 7             | 345.00] | AMP | 27000.3 | -86.67 |
| 543049 | [CEDRCRK5            | 161.00] | AMP | 27769.4 | -84.96 |
| 543054 | [CEDARNL5            | 161.00] | AMP | 13668.6 | -84.61 |
| 543077 | [PLSTVAL5            | 161.00] | AMP | 9761.0  | -83.35 |
| 543105 | [BULLCRK5            | 161.00] | AMP | 25120.8 | -87.11 |
| 543132 | [BNSF 5              | 161.00] | AMP | 20023.6 | -85.74 |
| 560053 | [G15-052T            | 345.00] | AMP | 13192.5 | -86.46 |
| 583750 | [GEN-2013-029345.00] |         | AMP | 10492.1 | -84.69 |
| 584660 | [GEN-2015-024345.00] |         | AMP | 5436.3  | -86.45 |
| 584670 | [GEN-2015-025345.00] |         | AMP | 6580.7  | -86.45 |
| 585250 | [GEN-2015-090345.00] |         | AMP | 3110.7  | -85.71 |