



GEN-2015-083

Impact Restudy for Generator Modification (Turbine Change)

Published on August 2018

By Generator Interconnection

REVISION HISTORY

| DATE OR VERSION NUMBER | AUTHOR | CHANGE DESCRIPTION | COMMENTS |
|---------------------------|------------------------------|-----------------------|----------|
| 8/7/2018 | Generator Interconnection | | |
| | | | |
| | | | |

EXECUTIVE SUMMARY

The GEN-2015-083 Interconnection Customer has requested a modification to its Interconnection Request. SPP has performed this system impact restudy to determine the effects of changing wind turbine generators from the previously studied fifty-four (54) GE 2.3MW wind turbine generators to fifty (50) GE 2.5MW as well as a POI change from Belle Plain to Sumner (one bus away). The total nameplate remains the same at 125 MW.

In this restudy the project uses fifty (50) GE 2.5MW wind turbine generators for an aggregate power of 125 MW. The point of interconnection (POI) for GEN-2015-083 is at Westar (WERE) Sumner 138kV substation. The Interconnection Customer has provided documentation that shows the GE 2.3MW wind turbine generators have a reactive capability of 0.95 lagging (providing VARS) and 0.95 leading (absorbing VARS) power factor.

This study was performed to determine whether the request for modification is considered Material. To determine this, study models that included Interconnection Requests through DISIS-2015-002 were used that analyzed the timeframes of 2016 winter, 2017 summer, and 2025 summer models.

Power flow analysis was performed. Cost Allocation remains the same. Interconnection costs decreased. No additional upgrades were identified.

The restudy showed that the stability analysis has determined with all previously assigned Network Upgrades in service, generators in the monitored areas remained stable and within the pre-contingency, voltage recovery, and post fault voltage recovery criterion of 0.7pu to 1.2pu for the entire modeled disturbances. Additionally, the project wind farm was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A. The requested modification is not considered Material.

A power factor analysis and a low-wind/no-wind condition analysis were performed for this modification request. The facility will be required to maintain a 95% lagging (providing VARS) and 95% leading (absorbing VARS) power factor at the POI. Additionally, the project will be required to install approximately 6.5 Mvar of reactor shunts on its substation 138 kV bus(es). This is necessary to offset the capacitive effect on the transmission network caused by the project's transmission line and collector system during low-wind/no-wind conditions.

With the assumptions outlined in this report and with all the required network upgrades from the DISIS 2015-002 in place, GEN-2015-083 with the GE 2.5MW wind turbine generators should be able to interconnect reliably to the SPP transmission grid.

It should be noted that this study analyzed the requested modification to change generator technology, manufacturer, and layout. This study analyzed many of the most probable contingencies, but it is not an all-inclusive list and cannot account for every operational situation. It is likely that the customer may be required to reduce its generation output to 0 MW, also known as

curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of transmission service or delivery rights. If the customer wishes to obtain deliverability to final customers, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the customer.

CONTENTS

| | |
|--|----|
| Revision History | i |
| Executive Summary | ii |
| Section 1: Introduction..... | 5 |
| Table 2-1: Interconnection Request | 5 |
| Table 2-2: Group 8 Prior and Later Queued Interconnection Requests | 5 |
| Section 2: Facilities | 8 |
| Figure 2-1: GEN-2015-083 One-line Diagram | 8 |
| Section 3: Stability Analysis | 10 |
| Model Preparation..... | 10 |
| Disturbances | 10 |
| Table 3-1: Contingencies Evaluated | 11 |
| Results..... | 19 |
| Table 3-2: Stability Analysis Results | 19 |
| FERC LVRT Compliance..... | 21 |
| Section 4: Power Factor Analysis..... | 22 |
| Table 4-1: Stability Analysis Results | 22 |
| Section 5: Reduced Generation Analysis..... | 23 |
| Model Preparation..... | 23 |
| Results..... | 23 |
| Table 5-1: Summary of Shunt Reactor Requirements | 23 |
| Section 6: Short Circuit Analysis | 24 |
| Section 7: Conclusion..... | 25 |
| Table 6-1: Interconnection Request | 25 |
| Appendix A: Plots | 26 |
| Appendix B: Power Factor Analysis..... | 27 |
| Appendix C: Short Circuit Analysis..... | 30 |
| Appendix D: Low Wind Analysis | 33 |
| Figure D-1: GEN-2015-083 with Generation Off and no Shunt Reactor | 33 |
| Figure D-1: GEN-2015-083 with Generation Off and Shunt Reactor | 33 |

SECTION 1: INTRODUCTION

GEN-2015-083 Impact Restudy is a generation interconnection study performed to study the impacts of interconnecting the project shown in Table I-1. This restudy evaluates the requested modification to change from fifty-four (54) GE 2.3MW wind turbine generators to fifty (50) GE 2.5MW, as well as a POI change from Belle Plain to Sumner (one bus away).

TABLE 2-1: INTERCONNECTION REQUEST

| Request | Capacity (MW) | Generator Model | Point of Interconnection |
|--------------|---------------|-----------------|--------------------------|
| GEN-2015-083 | 125 | GE 2.5MW (wind) | Sumner (532984) |

The prior-queued, equally-queued and lower queued requests shown in Table I-2 were included in this study and the wind farms were dispatched to 100% of rated capacity.

TABLE 2-2: GROUP 8 PRIOR AND LATER QUEUED INTERCONNECTION REQUESTS

| Request | Capacity (MW) | Generator Model | Point of Interconnection |
|---------------------------------|----------------------------|----------------------|--|
| GEN-2002-004 | 199.5 | GE.1.5MW | Latham 345kV (532800) |
| GEN-2005-013 | 199.8 | Vestas V90 1.8MW | Caney River 345kV (532780) |
| GEN-2007-025 | 299.2 | GE 1.6MW | Viola 345kV (532798) |
| GEN-2008-013 | 300 | G.E. 1.68MW | Hunter 345kV (515476) |
| GEN-2008-021 | 1261 Summer 1283 Winter | GENROU | Wolf Creek 345kV (532797) |
| GEN-2008-098 | 100.8 | Vestas V100 1.8MW | Tap on the Wolf Creek – LaCygne 345kV line (560004) |
| GEN-2009-025 | 59.8 | Siemens 2.3MW | Tap on the Deerck – Sinck 69KV line (515528) |
| GEN-2010-003 | 100.8 | Vestas V100 1.8MW | Tap on the Wolf Creek – LaCygne 345kV line (560004) |
| GEN-2010-005 | 299.2 | GE 1.6MW | Viola 345kV (532798) |
| ASGI-2010-006 | 150 | GE1.5MW | Remington 138kV (301369) |
| GEN-2010-055 | 4.8 | GENROU | Wekiwa 138kV (509757) |
| GEN-2011-057 | 150.4 | GE 1.6MW | Creswell 138kV (532981) |
| KCPL Distributed: Osawatomie | 76.0 | GENROU (543078) | Paola 161kV |
| GEN-2012-032 | 300 | Vestas V112 3.0MW | Tap Rose Hill-Sooner 345kV (562318) |
| GEN-2012-033 | 98.8 | GE 1.62MW | Tap Bunch Creek-South 4th 138kV(562303) |
| GEN-2012-041 | 85 Summer 121.5 Winter | GENROU | Tap Rose Hill-Sooner 345kV (562318) |

| Request | Capacity (MW) | Generator Model | Point of Interconnection |
|---------------|--|--|---|
| GEN-2013-012 | 4 x 168.0MW Summer 4 x 215MW Winter | GENROU (514910) (514911) (514912) (514942) | Redbud 345kV (514909) |
| GEN-2013-029 | 300 | Vestas V100 VCSS 2MW (583753, 583756) | Renfrow 345kV(515543) |
| GEN-2014-001 | 200.6 | GE 1.7MW 100m (583853,583856) | Tap Wichita to Emporia Energy Center 345kV (562476) |
| GEN-2014-028 | 35 (Uprate) (Pgen=259W/2 56S) | GENROU | Riverton 161kV (547469) |
| GEN-2014-064 | 248.4 | GE 2.3MW | Otter 138kV (514708) |
| ASGI-2014-014 | 56.4W/54.3S | GENROU | Ferguson 69kV (512664) |
| GEN-2015-001 | 200.0 | Vestas V110 2.0MW | Ranch Road 345kV |
| GEN-2015-016 | 200.0 | Vestas V110 2.0MW | Tap Centerville – Marmaton 161kV |
| GEN-2015-024 | 220.0 | GE 2.0MW | Tap on Thistle to Wichita 345kV, ckt1&2 (560033) |
| GEN-2015-025 | 220.0 | GE 2.0MW | Tap on Thistle to Wichita 345kV, ckt1&2 (560033) |
| GEN-2015-028 | 3.0 uprate to GEN-2009-025 for total 62.8MW | Siemens 2.3MW with Power Boost (115kW => 2.415MW) | Nardins 69kV |
| GEN-2015-030 | 200.1 | GE 2.3MW | Sooner 345kV |
| ASGI-2015-004 | 54.300 Summer 56.364 Winter | GENSAL | Coffeyville Municipal Light & Power Northern Industrial Park Substation 69kV (512735) |

The study included a stability analysis of the interconnection request. Contingencies that resulted in a prior-queued project tripping off-line, if any, were re-run with the prior-queued project's voltage and frequency tripping relays disabled. Also a low-wind/no-wind analysis was performed on this project since it is a non-synchronous resource. The analyses were performed on three seasonal models, the modified versions of the 2016 winter peak, the 2017 summer peak, and the 2025 summer peak cases. The stability analysis determines the impacts of the new interconnecting project on the stability and voltage recovery of the nearby systems and the ability of the interconnecting project to meet FERC Order 661A. If problems with stability or voltage recovery are identified, the need for reactive compensation or system upgrades is investigated. The three-phase faults and the single line-to-ground faults listed in Table III-1 were used in the stability analysis.


Power factor analysis results are in Appendix B

The low-wind/no-wind analysis determines the capacitive effect at the POI caused by the project's collector system and transmission line capacitance. A shunt reactor size was determined to offset the capacitive effect and to maintain zero Mvar flow at the POI when the plant generators and capacitors are off-line such as might be seen in low-wind or no-wind conditions.

SECTION 2: FACILITIES

A one-line drawing for the GEN-2015-083 generation interconnection request is shown in Figure 2-1. The POI is a new tap on the WERE Sumner 138kV substation.

FIGURE 2-1: GEN-2015-083 ONE-LINE DIAGRAM



SECTION 3: POWER FLOW ANALYSIS

Power flow analysis was performed with DISIS-2016-001-1 models. The interconnection costs for GEN-2015-083 decreased from \$6,713,963 to \$4,453,966. The current study upgrade identified in DISIS-2016-001-1 (Rebuild Farber – Belle Plains 138 kV CKT 1) was necessary for voltage and thermal mitigations. Additionally, the previously allocated upgrade of GEN-2015-063 Tap – Matthewson 345 kV CKT 1 was also required. No additional upgrades were identified. The Cost Allocation for GEN-2016-060 remains the same.

TABLE 3-1: GEN-2016-060 NETWORK UPGRADES

| Network Upgrade | POI at Belle Plains | POI at Sumner 138kV |
|---|----------------------------|----------------------------|
| Rebuild Farber – Belle Plains 138 kV CKT 1 (Current Study) | ✓ | ✓ |
| GEN-2015-063 Tap_Matthewson 345 kV CKT 1 (Previously Allocated) | ✓ | ✓ |
| Viola – Sumner County CKT 1 (Previously Allocated) | ✓ | |

SECTION 3: STABILITY ANALYSIS

Transient stability analysis is used to determine if the transmission system can maintain angular stability and ensure bus voltages stay within planning criteria bandwidth during and after a disturbance while considering the addition of a generator interconnection request.

MODEL PREPARATION

Transient stability analysis was performed using modified versions of the 2015 series of Model Development Working Group (MDWG) dynamic study models including the 2016 winter peak, the 2017 summer peak, and the 2025 summer peak seasonal models. The cases are then loaded with prior queued interconnection requests and network upgrades assigned to those interconnection requests. Finally the prior queued and study generation are dispatched into the SPP footprint. Initial simulations are then carried out for a no-disturbance run of twenty (20) seconds to verify the numerical stability of the model.

DISTURBANCES

Forty-seven (47) contingencies were identified for use in this study and are listed in Table 3-1. These contingencies included three-phase faults and single-phase line faults at locations defined by SPP. Single-phase line faults were simulated by applying fault impedance to the positive sequence network at the fault location to represent the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the specified fault location of approximately 60% of pre-fault voltage. This method is in agreement with SPP current practice.

Except for transformer faults, the typical sequence of events for a three-phase and a single-phase fault is as follows:

1. apply fault at particular location
2. continue fault for five (5) cycles, clear the fault by tripping the faulted facility
3. after an additional twenty (20) cycles, re-close the previous facility back into the fault
4. continue fault for five (5) additional cycles
5. trip the faulted facility and remove the fault

Transformer faults are typically modeled as three-phase faults, unless otherwise noted. The sequence of events for a transformer fault is as follows:

1. apply fault for five (5) cycles
2. clear the fault by tripping the affected transformer facility (unless otherwise noted there will be no re-closing into a transformer fault)

TABLE 3-1: CONTINGENCIES EVALUATED

| Contingency Number and Name | | Description |
|-----------------------------|-----------|---|
| 1 | FLT15-3PH | <p>3 phase fault on the WICHITA7 (532796) to VIOLA 7 (532798) 345 kV line circuit 1, near WICHITA7.</p> <p>a. Apply fault at the WICHITA7 345 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 2 | FLT69-3PH | <p>3 phase fault on the SC10BEL4 (533063) to FARBER 4 (533042) 138 kV line circuit 1, near SC10BEL4.</p> <p>a. Apply fault at the SC10BEL4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 3 | FLT70-3PH | <p>3 phase fault on the SC10BEL4 (533063) to SUMNER 4 (532984) 138 kV line circuit 1, near SC10BEL4.</p> <p>a. Apply fault at the SC10BEL4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 4 | FLT71-3PH | <p>3 phase fault on the FARBER 4 (533042) to ELPASO 4 (533039) 138 kV line circuit 1, near FARBER 4.</p> <p>a. Apply fault at the FARBER 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 5 | FLT72-3PH | <p>3 phase fault on the SUMNER 4 (532984) to OXFORD 4 (532982) 138 kV line circuit 1, near SUMNER 4.</p> <p>a. Apply fault at the SUMNER 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |

| Contingency Number and Name | | Description |
|-----------------------------|-------------|---|
| 6 | FLT73-3PH | <p>3 phase fault on the SUMNER 4 (532984) to TIMBJCT4 (532992) 138 kV line circuit 1, near SUMNER 4.</p> <p>a. Apply fault at the SUMNER 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 7 | FLT114-SB | <p>Stuck Breaker on FARBER 4 – SC10BEL 4 138 kV line</p> <p>a. Apply single-phase fault at FARBER 4 (533042) 138 kV</p> <p>b. After 16 cycles, trip the FARBER 4 (533042) to ELPASO 4 (533039) 138 kV line</p> <p>c. Trip the FARBER 4 (533042) to SC10BEL 4 (533063) 138 kV line, and remove the fault</p> |
| 8 | FLT9001-3PH | <p>3 phase fault on the OXFORD 4 (532982) to CRESWLN4 (532981) 138 kV line circuit 1, near OXFORD 4.</p> <p>a. Apply fault at the OXFORD 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 9 | FLT9002-3PH | <p>3 phase fault on the SUMNER 4 (532984) to VIOLA 4 (533075) 138 kV line circuit 1, near SUMNER 4.</p> <p>a. Apply fault at the SUMNER 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 10 | FLT9003-3PH | <p>3 phase fault on the SUMNER 4 (532984) to SC10BEL4 (533063) 138 kV line circuit 1, near SUMNER 4</p> <p>a. Apply fault at the SUMNER 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 11 | FLT9004-3PH | <p>3 phase fault on the VIOLA 4 (533075) 138 kV / VIOLA 7 (532798) 345 kV /(532832) 13.8 kV transformer, near VIOLA 4 138 kV.</p> <p>a. Apply fault at the VIOLA 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |

| Contingency Number and Name | | Description |
|-----------------------------|-------------|--|
| 12 | FLT9005-3PH | <p>3 phase fault on the VIOLA 4 (533075) to CLEARWT4 (533036) 138 kV line circuit 1, near VIOLA 4</p> <p>a. Apply fault at the VIOLA 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 13 | FLT9006-3PH | <p>3 phase fault on the VIOLA 4 (533075) to GILL S 4 (533046) 138 kV line circuit 1, near VIOLA 4</p> <p>a. Apply fault at the VIOLA 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 14 | FLT9007-3PH | <p>3 phase fault on the TIMBJCT4 (532992) 138 kV / TIMBJCT2 (533558) 69 kV / (533120) 13.8 kV transformer, near TIMBJCT4 138 kV.</p> <p>a. Apply fault at the TIMBJCT4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |
| 15 | FLT9008-3PH | <p>3 phase fault on the VIOLA 7 (532798) to WICHITA7 (532796) 345 kV line circuit 1, near VIOLA 7.</p> <p>a. Apply fault at the VIOLA 7 345 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 16 | FLT9009-3PH | <p>3 phase fault on the VIOLA 7 (532798) to RENFROW7 (515543) 345 kV line circuit 1, near VIOLA 7.</p> <p>a. Apply fault at the VIOLA 7 345 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 17 | FLT9010-3PH | <p>3 phase fault on the VIOLA 7 (532798) to FR2EAST7 (532792) 345 kV line circuit 1, near VIOLA 7.</p> <p>a. Apply fault at the VIOLA 7 345 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |

| Contingency Number and Name | | Description |
|-----------------------------|-------------|--|
| 18 | FLT9011-3PH | <p>3 phase fault on the GILL S 4 (533046) to GILL W 4 (533045) 138 kV line circuit Z1, near GILL S 4.</p> <p>a. Apply fault at the GILL S 4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 19 | FLT9012-3PH | <p>3 phase fault on the CLEARWT4 (533036) to GODDARD2 (533880) 138 kV line circuit 1, near CLEARWT4.</p> <p>a. Apply fault at the CLEARWT4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 20 | FLT9013-3PH | <p>3 phase fault on the CLEARWT4 (533036) to MILANTP4 (539675) 138 kV line circuit 1, near CLEARWT4.</p> <p>a. Apply fault at the CLEARWT4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 21 | FLT9014-3PH | <p>3 phase fault on the CLEARWT4 (533036) to GILL W 4 (533045) 138 kV line circuit 1, near CLEARWT4.</p> <p>a. Apply fault at the CLEARWT4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 22 | FLT9015-3PH | <p>3 phase fault on the CRESWLN4 (532981) 138 kV / CRESWLN2 (533543) 69 kV /(533081) 13.2 kV transformer, near CRESWLN4 138 kV.</p> <p>a. Apply fault at the CRESWLN4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |
| 23 | FLT9016-3PH | <p>3 phase fault on the CRESWLN4 (532981) to MIDLTNT4 (514804) 138 kV line circuit 1, near CRESWLN4.</p> <p>a. Apply fault at the CRESWLN4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |

| Contingency Number and Name | | Description |
|-----------------------------|-------------|---|
| 24 | FLT9017-3PH | <p>3 phase fault on the CRESWLN4 (532981) to SLATECRK4 (533070) 138 kV line circuit 1, near CRESWLN4.</p> <p>a. Apply fault at the CRESWLN4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 25 | FLT9001-PO1 | <p>Prior Outage of SUMNER 4 to SC10BEL4 138 kV line;</p> <p>3 phase fault on the OXFORD 4 (532982) to CRESWLN4 (532981) 138 kV line circuit 1, near OXFORD 4.</p> <p>a. Apply fault at the VIOLA 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 26 | FLT9007-PO1 | <p>Prior Outage of SUMNER 4 to SC10BEL4 138 kV line;</p> <p>3 phase fault on TIMBJCT (532992) 138 kV/TIMBJCT2 (533558) 69 kV/TIMBJCT1 (533120) 13.2 kV transformer near TIMBJCT 138 kV</p> <p>a. Apply fault at the TIMBJCT 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |
| 27 | FLT9004-PO1 | <p>Prior Outage of SUMNER 4 to SC10BEL4 138 kV line;</p> <p>3 phase fault on the VIOLA 4 (533075) 138 kV / VIOLA 7 (532798) 345 kV /(532832) 13.8 kV transformer, near VIOLA 4 138 kV</p> <p>a. Apply fault at the VIOLA 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |
| 28 | FLT9005-PO1 | <p>Prior Outage of SUMNER 4 to SC10BEL4 138 kV line;</p> <p>3 phase fault on the VIOLA 4 (533075) to CLEARWT4 (533036) 138 kV line circuit 1, near VIOLA 4</p> <p>a. Apply fault at the VIOLA 4 138 kV bus.</p> <p>b. Clear fault after 5 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |

| Contingency Number and Name | | Description |
|-----------------------------|-------------|--|
| 29 | FLT9006-PO1 | <p>Prior Outage of SUMNER 4 to SC10BEL4 138 kV line; 3 phase fault on the VIOLA 4 (533075) to GILL S 4 (533046) 138 kV line circuit 1, near VIOLA 4</p> <p>a. Apply fault at the VIOLA 4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 30 | FLT9007-PO2 | <p>Prior Outage of SUMNER 4 to OXFORD 4 138 kV line; 3 phase fault on TIMBJCT (532992) 138 kV/TIMBJCT2 (533558) 69 kV/TIMBJCT1 (533120) 13.2 kV transformer near TIMBJCT 138 kV</p> <p>a. Apply fault at the TIMBJCT 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |
| 31 | FLT9004-PO2 | <p>Prior Outage of SUMNER 4 to OXFORD 4 138 kV line; 3 phase fault on the VIOLA 4 (533075) 138 kV / VIOLA 7 (532798) 345 kV / (532832) 13.8 kV transformer, near VIOLA 4 138 kV</p> <p>a. Apply fault at the VIOLA 4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |
| 32 | FLT9005-PO2 | <p>Prior Outage of SUMNER 4 to OXFORD 4 138 kV line; 3 phase fault on the VIOLA 4 (533075) to CLEARWT4 (533036) 138 kV line circuit 1, near VIOLA 4</p> <p>a. Apply fault at the VIOLA 4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 33 | FLT9006-PO2 | <p>Prior Outage of SUMNER 4 to OXFORD 4 138 kV line; 3 phase fault on the VIOLA 4 (533075) to GILL S 4 (533046) 138 kV line circuit 1, near VIOLA 4</p> <p>a. Apply fault at the VIOLA 4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |

| Contingency Number and Name | | Description |
|-----------------------------|-------------|---|
| 34 | FLT69-PO2 | <p>Prior Outage of SUMNER 4 to OXFORD 4 138 kV line; 3 phase fault on the SC10BEL4 (533063) to FARBER 4 (533042) 138 kV line circuit 1, near SC10BEL4.</p> <p>a. Apply fault at the SC10BEL4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 35 | FLT9001-PO3 | <p>Prior Outage of SUMNER 4 to TIMBMJCT4 138 kV line; 3 phase fault on the OXFORD 4 (532982) to CRESWLN4 (532981) 138 kV line circuit 1, near OXFORD 4.</p> <p>a. Apply fault at the VIOLA 4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |
| 36 | FLT9004-PO3 | <p>Prior Outage of SUMNER 4 to TIMBMJCT4 138 kV line; 3 phase fault on the VIOLA 4 (533075) 138 kV / VIOLA 7 (532798) 345 kV / (532832) 13.8 kV transformer, near VIOLA 4 138 kV</p> <p>a. Apply fault at the VIOLA 4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |
| 37 | FLT9005-PO3 | <p>Prior Outage of SUMNER 4 to TIMBMJCT4 138 kV line; 3 phase fault on the VIOLA 4 (533075) to CLEARWT4 (533036) 138 kV line circuit 1, near VIOLA 4</p> <p>a. Apply fault at the VIOLA 4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. 3 phase fault on the VIOLA 4 (533075) to CLEARWT4 (533036) 138 kV line circuit 1, near VIOLA 4</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 38 | FLT9006-PO3 | <p>Prior Outage of SUMNER 4 to TIMBMJCT4 138 kV line; 3 phase fault on the VIOLA 4 (533075) to GILL S 4 (533046) 138 kV line circuit 1, near VIOLA 4</p> <p>a. Apply fault at the VIOLA 4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. 3 phase fault on the VIOLA 4 (533075) to GILL S 4 (533046) 138 kV line circuit 1, near VIOLA 4</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |

| Contingency Number and Name | | Description |
|-----------------------------|-------------|--|
| 39 | FLT69-PO3 | <p>Prior Outage of SUMNER 4 to TIMBMJCT4 138 kV line; 3 phase fault on the SC10BEL4 (533063) to FARBER 4 (533042) 138 kV line circuit 1, near SC10BEL4.</p> <p>a. Apply fault at the SC10BEL4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. 3 phase fault on the SC10BEL4 (533063) to FARBER 4 (533042) 138 kV line circuit 1, near SC10BEL4. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 40 | FLT9001-PO4 | <p>Prior Outage of SUMNER 4 to VIOLA 4 138 kV line; 3 phase fault on the OXFORD 4 (532982) to CRESWLN4 (532981) 138 kV line circuit 1, near OXFORD 4.</p> <p>a. Apply fault at the TIMBJCT 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |
| 41 | FLT9007-PO4 | <p>Prior Outage of SUMNER 4 to VIOLA 4 138 kV line; 3 phase fault on TIMBJCT (532992) 138 kV/TIMBJCT2 (533558) 69 kV/TIMBJCT1 (533120) 13.2 kV transformer near TIMBJCT 138 kV</p> <p>a. Apply fault at the TIMBJCT 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted transformer.</p> |
| 42 | FLT69-PO4 | <p>Prior Outage of SUMNER 4 to VIOLA 4 138 kV line; 3 phase fault on the SC10BEL4 (533063) to FARBER 4 (533042) 138 kV line circuit 1, near SC10BEL4.</p> <p>a. Apply fault at the SC10BEL4 138 kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p> |
| 43 | FLT9100-SB | <p>Stuck Breaker on OXFORD 4 – SUMNER 4 138 kV line</p> <p>a. Apply single-phase fault at OXFORD 4 (532982) 138 kV b. After 16 cycles, trip the OXFORD 4 (532982) 138 kV Bus and remove the fault</p> |
| 44 | FLT9200-SB | <p>Stuck Breaker on SC10BEL4 - SUMNER 4 138 kV line</p> <p>a. Apply single-phase fault at SC10BEL4 (533063) 138 kV b. After 16 cycles, trip the SC10BEL4 (533063) 138 kV Bus and remove the fault</p> |
| 45 | FLT9300-SB | <p>Stuck Breaker on TIMBJCT4 - SUMNER 4 138 kV line</p> <p>a. Apply single-phase fault at TIMBJCT4 (532992) 138 kV b. After 16 cycles, trip the TIMBJCT4 (532992) 138 kV Bus and remove the fault</p> |

| Contingency Number and Name | | Description |
|-----------------------------|------------|---|
| 46 | FLT9400-SB | Stuck Breaker on CRESWLN4 (532981) 138 kV/CRESWLN2 (533543) 69 kV/CRESW2 1 (533081) 13.2 kV transformer near 138kV a. Apply single-phase fault at CRESWLN4 (532981) 138kV b. After 16 cycles, trip the CRESWLN4 (532981) 138 kV/CRESWLN2 (533543) 69 kV/CRESW2 1 (533081) 13.2 kV transformer c. Trip the CRESWLN4 (532981) 138 kV/CRESWLN2 (533543) 69 kV/CRESW1 1 (533080) 13.2 kV transformer, and remove the fault |
| 47 | FLT9500-SB | Stuck Breaker on VIOLA 4 - SUMNER 4 138kV line a. Apply single-phase fault at VIOLA 4 (533075) 138kV b. After 16 cycles, trip the VIOLA 4 (533075) to SUMNER 4 (532984) 138 kV line b. Trip the VIOLA 4 (533075) 138 kV / VIOLA 7 (532798) 345 kV / (532832) 13.8 kV transformer, and remove the fault |

RESULTS

The stability analysis was performed and the results are summarized in Table 3-2. Based on the stability results and with all network upgrades in service, GEN-2015-083 did not cause any stability problems and remained stable for all faults studied. No generators tripped or went unstable, and voltages recovered to acceptable levels.

Complete sets of plots for the stability analysis are available on request.

TABLE 3-2: STABILITY ANALYSIS RESULTS

| Contingency Number and Name | | 2015SP | 2015WP | 2025SP |
|-----------------------------|-----------|--------|--------|--------|
| 1 | FLT15-3PH | Stable | Stable | Stable |
| 2 | FLT69-3PH | Stable | Stable | Stable |
| 3 | FLT70-3PH | Stable | Stable | Stable |
| 4 | FLT71-3PH | Stable | Stable | Stable |
| 5 | FLT72-3PH | Stable | Stable | Stable |
| 6 | FLT73-3PH | Stable | Stable | Stable |
| 7 | FLT114-SB | Stable | Stable | Stable |

| Contingency Number and Name | | 2015SP | 2015WP | 2025SP |
|-----------------------------|-------------|--------|--------|--------|
| 8 | FLT9001-3PH | Stable | Stable | Stable |
| 9 | FLT9002-3PH | N/A | N/A | Stable |
| 10 | FLT9003-3PH | Stable | Stable | Stable |
| 11 | FLT9004-3PH | N/A | N/A | Stable |
| 12 | FLT9005-3PH | N/A | N/A | Stable |
| 13 | FLT9006-3PH | N/A | N/A | Stable |
| 14 | FLT9007-3PH | Stable | Stable | Stable |
| 15 | FLT9008-3PH | Stable | Stable | Stable |
| 16 | FLT9009-3PH | Stable | Stable | Stable |
| 17 | FLT9010-3PH | Stable | Stable | Stable |
| 18 | FLT9011-3PH | Stable | Stable | Stable |
| 19 | FLT9012-3PH | N/A | N/A | Stable |
| 20 | FLT9013-3PH | Stable | Stable | Stable |
| 21 | FLT9014-3PH | Stable | Stable | Stable |
| 22 | FLT9015-3PH | Stable | Stable | Stable |
| 23 | FLT9016-3PH | Stable | Stable | Stable |
| 24 | FLT9017-3PH | Stable | Stable | Stable |
| 25 | FLT9001-PO1 | Stable | Stable | Stable |
| 26 | FLT9007-PO1 | Stable | Stable | Stable |
| 27 | FLT9004-PO1 | N/A | N/A | Stable |
| 28 | FLT9005-PO1 | N/A | N/A | Stable |
| 29 | FLT9006-PO1 | N/A | N/A | Stable |
| 30 | FLT9007-PO2 | Stable | Stable | Stable |
| 31 | FLT9004-PO2 | Stable | Stable | Stable |
| 32 | FLT9005-PO2 | Stable | Stable | Stable |

| Contingency Number and Name | | 2015SP | 2015WP | 2025SP |
|-----------------------------|-------------|--------|--------|--------|
| 33 | FLT9006-PO2 | Stable | Stable | Stable |
| 34 | FLT69-PO2 | Stable | Stable | Stable |
| 35 | FLT9001-PO3 | Stable | Stable | Stable |
| 36 | FLT9004-PO3 | N/A | N/A | Stable |
| 37 | FLT9005-PO3 | N/A | N/A | Stable |
| 38 | FLT9006-PO3 | N/A | N/A | Stable |
| 39 | FLT69-PO3 | Stable | Stable | Stable |
| 40 | FLT9001-PO4 | N/A | N/A | Stable |
| 41 | FLT9007-PO4 | N/A | N/A | Stable |
| 42 | FLT69-PO4 | N/A | N/A | Stable |
| 43 | FLT9100-SB | Stable | Stable | Stable |
| 44 | FLT9200-SB | Stable | Stable | Stable |
| 45 | FLT9300-SB | Stable | Stable | Stable |
| 46 | FLT9400-SB | Stable | Stable | Stable |
| 47 | FLT9500-SB | Stable | Stable | Stable |

FERC LVRT COMPLIANCE

FERC Order #661A places specific requirements on wind farms through its Low Voltage Ride Through (LVRT) provisions. For Interconnection Agreements signed after December 31, 2006, wind farms shall stay on line for faults at the POI that draw the voltage down at the POI to 0.0 pu.

Contingencies 9 and 10 in Table 3-1 simulated the LVRT contingencies. GEN-2015-083 met the LVRT requirements by staying on line and the transmission system remaining stable.

SECTION 4: POWER FACTOR ANALYSIS

A subset of the stability faults was used as power flow contingencies to determine the power factor requirements for the wind farm to maintain scheduled voltage at the POI. The voltage schedule was set equal to the voltages at the POI before the project is added, with a minimum of 1.0 per unit. A fictitious reactive power source replaced the study project to maintain scheduled voltage during all studied contingencies. The MW and Mvar injections from the study project at the POI were recorded and the resulting power factors were calculated for all contingencies for summer peak and winter peak cases. The most leading and most lagging power factors determine the minimum power factor range capability that the study project must install before commercial operation.

Per FERC and SPP Tariff requirements, if the power factor needed to maintain scheduled voltage is less than 0.95 lagging, then the requirement is limited to 0.95 lagging. The lower limit for leading power factor requirement is also 0.95. If a project never operated leading under any contingency, then the leading requirement is set to 1.0. The same applies on the lagging side.

The power factor analysis showed a need for reactive capability by the study project at the POI. The final power factor requirement in the Generator Interconnection Agreement (GIA) will be the proforma 0.95 lagging to 0.95 leading at the POI, and this requirement is shown in Table 4-1. The detailed power factor analysis tables are in Appendix B. Since the GE 2.5 MW wind turbines as studied have a reactive capability (of 0.95 lagging and 0.95 leading), the generation facility may require external capacitor banks or other reactive equipment to meet the power factor requirement at the POI.

TABLE 4-1: STABILITY ANALYSIS RESULTS

| Request | Size (MW) | Generator Model | Point of Interconnection | Final PF | |
|--------------|--------------|-------------------------|-----------------------------|----------------------|----------------------|
| | | | | Requirement at POI | |
| | | | | Lagging ^b | Leading ^c |
| GEN-2015-083 | 125 | 50 GE 2.5 MW generators | Sumner (532984) | 0.95 ^d | 0.95 ^e |

Notes:

- The table shows the minimum required power factor capability at the point of interconnection that must be designed and installed with the plant. The power factor capability at the POI includes the net effect of the generators, transformers, line impedances, and any reactive compensation devices installed on the plant side of the meter. Installing more capability than the minimum requirement is acceptable.
- Lagging is when the generating plant is supplying reactive power to the transmission grid, like a shunt capacitor. In this situation, the alternating current sinusoid “lags” behind the alternating voltage sinusoid, meaning that the current peaks shortly after the voltage.
- Leading is when the generating plant is taking reactive power from the transmission grid, like a shunt reactor. In this situation, the alternating current sinusoid “leads” the alternating voltage sinusoid, meaning that the current peaks shortly before the voltage.
- Electrical need is lower, but PF requirement limited to 0.95 by FERC order.
- The most leading power factor determined through analysis was 1.00.

SECTION 5: REDUCED GENERATION ANALYSIS

Interconnection requests for wind generation projects that interconnect on the SPP system are analyzed for the capacitive charging effects during reduced generation conditions (unsuitable wind speeds, curtailment, etc.) at the generation site.

MODEL PREPARATION

The project generators and capacitors (if any), and all other wind projects that share the same POI, were turned off in the base case. The resulting reactive power injection into the transmission network comes from the capacitance of the project's transmission lines and collector cables. This reactive power injection is measured at the POI. Shunt reactors were added at the study project substation low voltage bus to bring the Mvar flow into the POI down to approximately zero.

RESULTS

A final shunt reactor requirement for each of the studied interconnection requests is shown in Table 5-1. One line drawings used in the analysis are shown in Appendix D: Low Wind Analysis.

TABLE 5-1: SUMMARY OF SHUNT REACTOR REQUIREMENTS

| Request | Capacity | POI | Approximate Shunt Reactor Required |
|--------------|----------|-----------------|------------------------------------|
| GEN-2015-083 | 125MW | Sumner (532984) | 6.5 Mvar |

The results shown are for the 2025 summer case. The other two cases (2016 winter and 2017 summer) were almost identical since the generation plant design is the same in all cases.

SECTION 6: SHORT CIRCUIT ANALYSIS

The short circuit analysis was performed on the 2017 & 2025 Summer Peak power flow cases using the PSS/E ASCC program. Since the power flow model does not contain negative and zero sequence data, only three-phase symmetrical fault current levels were calculated at the point of interconnection up to and including five levels away.

Short Circuit Analysis was conducting using flat conditions with the following PSS/E ASCCC program settings:

- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-/0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-/0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

Results

The results of the short circuit analysis are shown in [Appendix C](#).

SECTION 7: CONCLUSION

The SPP GEN-2015-083 Impact Restudy evaluated the impact of interconnecting the project shown below in Table 6-1.

TABLE 6-1: INTERCONNECTION REQUEST

| Request | Capacity (MW) | Generator Model | Point of Interconnection |
|--------------|---------------|------------------------|--------------------------|
| GEN-2015-083 | 125MW | 50 GE 2.5MW generators | Sumner (532984) |

With all Base Case Network Upgrades in service, previously assigned Network Upgrades in service, and required capacitor banks in service, the GEN-2015-083 project was found to remain on line, and the transmission system was found to remain stable for all conditions studied. The requested modification is not considered Material.

A low-wind/no-wind condition analysis was performed for this modification request. The project will be required to install a total of approximately 6.5 Mvar of reactor shunts on its substation 138kV bus. This is necessary to offset the capacitive effect on the transmission network cause by the project's transmission line and collector system during low-wind or no-wind conditions.

Low Voltage Ride Through (LVRT) analysis showed the study generators did not trip offline due to low voltage when all Network Upgrades are in service.

Any changes to the assumptions made in this study, for example, one or more of the previously queued requests withdraw, may require a re-study at the expense of the Customer.

Nothing in this System Impact Study constitutes a request for transmission service or confers upon the Interconnection Customer any right to receive transmission service.

APPENDIX A: PLOTS

Available on request.

APPENDIX B: POWER FACTOR ANALYSIS

| Case | Outage Label | Pgen (MW) | QGEN (MVar) | PF | Leading Lagging |
|------|--------------|-----------|-------------|-------|-----------------|
| 16WP | FLT15 | 125 | 21.68627 | 0.985 | Lagging |
| 16WP | FLT69 | 125 | 24.10172 | 0.982 | Lagging |
| 16WP | FLT70 | 125 | 24.17275 | 0.982 | Lagging |
| 16WP | FLT71 | 125 | 26.06281 | 0.979 | Lagging |
| 16WP | FLT72 | 125 | -5.804245 | 0.999 | Leading |
| 16WP | FLT73 | 125 | -1.597905 | 1.000 | Leading |
| 16WP | FLT9001 | 125 | -5.099016 | 0.999 | Leading |
| 16WP | FLT9003 | 125 | 24.17275 | 0.982 | Lagging |
| 16WP | FLT9007 | 125 | -8.480408 | 0.998 | Leading |
| 16WP | FLT9008 | 125 | 21.68627 | 0.985 | Lagging |
| 16WP | FLT9009 | 125 | 1.851644 | 1.000 | Lagging |
| 16WP | FLT9010 | 125 | -0.0931992 | 1.000 | Leading |
| 16WP | FLT9011 | 125 | 1.692081 | 1.000 | Lagging |
| 16WP | FLT9013 | 125 | 3.93846 | 1.000 | Lagging |
| 16WP | FLT9014 | 125 | 6.004606 | 0.999 | Lagging |
| 16WP | FLT9015 | 125 | 3.65591 | 1.000 | Lagging |
| 16WP | FLT9016 | 125 | 25.95339 | 0.979 | Lagging |
| 16WP | FLT9017 | 125 | -7.467247 | 0.998 | Leading |
| 16WP | UNFAULTED | 125 | 1.7552 | 1.000 | Lagging |
| 17SP | FLT15 | 125 | 7.035601 | 0.998 | Lagging |
| 17SP | FLT69 | 125 | 0.818457 | 1.000 | Lagging |
| 17SP | FLT70 | 125 | -0.0383099 | 1.000 | Leading |
| 17SP | FLT71 | 125 | 6.534454 | 0.999 | Lagging |
| 17SP | FLT72 | 125 | -10.90503 | 0.996 | Leading |
| 17SP | FLT73 | 125 | 1.133902 | 1.000 | Lagging |

| Case | Outage Label | Pgen (MW) | QGEN (MVar) | PF | Leading Lagging |
|------|--------------|-----------|-------------|-------|-----------------|
| 17SP | FLT9001 | 125 | -9.441909 | 0.997 | Leading |
| 17SP | FLT9003 | 125 | -0.0383099 | 1.000 | Leading |
| 17SP | FLT9007 | 125 | -6.345002 | 0.999 | Leading |
| 17SP | FLT9008 | 125 | 7.035601 | 0.998 | Lagging |
| 17SP | FLT9009 | 125 | -5.483699 | 0.999 | Leading |
| 17SP | FLT9010 | 125 | -6.161466 | 0.999 | Leading |
| 17SP | FLT9011 | 125 | -3.017931 | 1.000 | Leading |
| 17SP | FLT9013 | 125 | -5.090569 | 0.999 | Leading |
| 17SP | FLT9014 | 125 | -4.470612 | 0.999 | Leading |
| 17SP | FLT9015 | 125 | -6.407546 | 0.999 | Leading |
| 17SP | FLT9016 | 125 | -2.841096 | 1.000 | Leading |
| 17SP | FLT9017 | 125 | -9.526103 | 0.997 | Leading |
| 17SP | UNFAULTED | 125 | -5.579602 | 0.999 | Leading |
| 25SP | FLT15 | 125 | 0.648969 | 1.000 | Lagging |
| 25SP | FLT69 | 125 | -7.745823 | 0.998 | Leading |
| 25SP | FLT70 | 125 | -8.768277 | 0.998 | Leading |
| 25SP | FLT71 | 125 | -1.409599 | 1.000 | Leading |
| 25SP | FLT72 | 125 | -13.1085 | 0.995 | Leading |
| 25SP | FLT73 | 125 | 2.136209 | 1.000 | Lagging |
| 25SP | FLT9001 | 125 | -14.84279 | 0.993 | Leading |
| 25SP | FLT9002 | 125 | 1.89629 | 1.000 | Lagging |
| 25SP | FLT9003 | 125 | -8.768277 | 0.998 | Leading |
| 25SP | FLT9004 | 125 | -0.809785 | 1.000 | Leading |
| 25SP | FLT9005 | 125 | -4.412814 | 0.999 | Leading |
| 25SP | FLT9006 | 125 | -5.386446 | 0.999 | Leading |
| 25SP | FLT9007 | 125 | -5.109126 | 0.999 | Leading |
| 25SP | FLT9008 | 125 | 0.648969 | 1.000 | Lagging |

| Case | Outage Label | Pgen (MW) | QGEN (MVar) | PF | Leading Lagging |
|------|--------------|-----------|-------------|-------|-----------------|
| 25SP | FLT9009 | 125 | -6.931538 | 0.998 | Leading |
| 25SP | FLT9010 | 125 | -2.863758 | 1.000 | Leading |
| 25SP | FLT9011 | 125 | -3.967323 | 0.999 | Leading |
| 25SP | FLT9012 | 125 | -4.264443 | 0.999 | Leading |
| 25SP | FLT9013 | 125 | -5.504511 | 0.999 | Leading |
| 25SP | FLT9014 | 125 | -5.692423 | 0.999 | Leading |
| 25SP | FLT9015 | 125 | -4.872952 | 0.999 | Leading |
| 25SP | FLT9016 | 125 | -5.921418 | 0.999 | Leading |
| 25SP | FLT9017 | 125 | -11.19366 | 0.996 | Leading |
| 25SP | UNFAULTED | 125 | -6.516462 | 0.999 | Leading |

APPENDIX C: SHORT CIRCUIT ANALYSIS

17SP

| Bus Distance From POI | BUS NUMBER | BUS NAME | KV | AREA | ZONE | 3 Phase Fault Current (kA) | | Difference (ON - OFF) | |
|-----------------------|------------|--------------|-----|------|------|----------------------------|--------|-----------------------|------------|
| | | | | | | GenON | GenOFF | From POI | BUS NUMBER |
| 0 | 532984 | SUMNER 4 | 138 | 536 | 1537 | 7.659 | 7.168 | 0.491 | 6.85% |
| 1 | 532982 | OXFORD 4 | 138 | 536 | 1537 | 7.268 | 6.863 | 0.405 | 5.90% |
| 1 | 532992 | TIMBJCT4 | 138 | 536 | 1537 | 4.972 | 4.802 | 0.170 | 3.55% |
| 1 | 533063 | SC10BEL4 | 138 | 536 | 1537 | 8.475 | 8.158 | 0.317 | 3.88% |
| 1 | 585200 | GEN-2015-083 | 138 | 536 | 1537 | 3.561 | N/A | N/A | N/A |
| 2 | 532981 | CRESWLN4 | 138 | 536 | 1537 | 7.321 | 7.148 | 0.173 | 2.41% |
| 2 | 532985 | TCROCK 4 | 138 | 536 | 1537 | 4.692 | 4.540 | 0.152 | 3.34% |
| 2 | 533042 | FARBER 4 | 138 | 536 | 1537 | 15.484 | 15.297 | 0.188 | 1.23% |
| 3 | 514804 | MIDLTNT4 | 138 | 524 | 566 | 7.482 | 7.381 | 0.101 | 1.37% |
| 3 | 533070 | SLATECRK | 138 | 536 | 1537 | 4.298 | 4.240 | 0.057 | 1.35% |
| 3 | 533039 | ELPASO 4 | 138 | 536 | 1537 | 24.403 | 24.212 | 0.191 | 0.79% |
| 4 | 515381 | PECKHMT4 | 138 | 524 | 566 | 8.050 | 7.966 | 0.084 | 1.05% |
| 4 | 521198 | CHILOCCO | 138 | 525 | 575 | 5.871 | 5.806 | 0.066 | 1.13% |
| 4 | 533029 | 59TH ST4 | 138 | 536 | 1537 | 17.459 | 17.406 | 0.053 | 0.31% |
| 4 | 533032 | BU11PON4 | 138 | 536 | 1537 | 14.867 | 14.819 | 0.048 | 0.33% |
| 4 | 533062 | ROSEHIL4 | 138 | 536 | 1537 | 30.758 | 30.636 | 0.123 | 0.40% |
| 4 | 533066 | 64TH 4 | 138 | 536 | 1537 | 14.215 | 14.171 | 0.044 | 0.31% |
| 4 | 533068 | STEARMN4 | 138 | 536 | 1537 | 19.480 | 19.411 | 0.070 | 0.36% |
| 5 | 514759 | NEWKIRK4 | 138 | 524 | 566 | 8.409 | 8.331 | 0.078 | 0.94% |
| 5 | 533046 | GILL S 4 | 138 | 536 | 1537 | 22.309 | 22.262 | 0.047 | 0.21% |
| 5 | 532991 | WEAVER 4 | 138 | 536 | 1537 | 21.875 | 21.792 | 0.083 | 0.38% |
| 5 | 532794 | ROSEHIL7 | 345 | 536 | 1537 | 18.858 | 18.814 | 0.044 | 0.23% |
| 5 | 533048 | HARRY 4 | 138 | 536 | 1537 | 13.483 | 13.446 | 0.037 | 0.28% |
| 5 | 533030 | BOEING 4 | 138 | 536 | 1537 | 16.958 | 16.913 | 0.045 | 0.26% |

25SP

| Bus Distance From POI | BUS NUMBER | BUS NAME | kV | AREA | ZONE | 3 Phase Fault Current (kA) | | Difference (ON - OFF) | |
|-----------------------|------------|--------------|-----|------|------|----------------------------|--------|-----------------------|--------|
| | | | | | | GenON | GenOFF | Change | % |
| 0 | 532984 | SUMNER 4 | 138 | 536 | 1537 | 10.500 | 10.011 | 0.489 | 4.88% |
| 1 | 532982 | OXFORD 4 | 138 | 536 | 1537 | 9.470 | 9.107 | 0.363 | 3.99% |
| 1 | 532992 | TIMBJCT4 | 138 | 536 | 1537 | 5.795 | 5.674 | 0.122 | 2.14% |
| 1 | 533063 | SC10BEL4 | 138 | 536 | 1537 | 9.900 | 9.667 | 0.233 | 2.41% |
| 1 | 533075 | VIOLA 4 | 138 | 536 | 1537 | 22.332 | 22.236 | 0.096 | 0.43% |
| 1 | 585200 | GEN-2015-083 | 138 | 536 | 1537 | 3.967 | N/A | N/A | N/A |
| 2 | 532981 | CRESWLN4 | 138 | 536 | 1537 | 8.031 | 7.920 | 0.111 | 1.40% |
| 2 | 532985 | TCROCK 4 | 138 | 536 | 1537 | 5.418 | 5.312 | 0.106 | 2.00% |
| 2 | 533042 | FARBER 4 | 138 | 536 | 1537 | 16.338 | 16.217 | 0.121 | 0.75% |
| 2 | 533036 | CLEARWT4 | 138 | 536 | 1537 | 22.099 | 22.048 | 0.051 | 0.23% |
| 2 | 533046 | GILL S 4 | 138 | 536 | 1537 | 28.848 | 28.765 | 0.083 | 0.29% |
| 2 | 532798 | VIOLA | 345 | 536 | 1537 | 13.470 | 13.449 | 0.021 | 0.16% |
| 3 | 514804 | MIDLTNT4 | 138 | 524 | 566 | 7.861 | 7.800 | 0.061 | 0.78% |
| 3 | 533070 | SLATECRK | 138 | 536 | 1537 | 4.496 | 4.462 | 0.034 | 0.76% |
| 3 | 533039 | ELPASO 4 | 138 | 536 | 1537 | 25.680 | 25.545 | 0.136 | 0.53% |
| 3 | 533045 | GILL W 4 | 138 | 536 | 1537 | 28.848 | 28.765 | 0.083 | 0.29% |
| 3 | 533880 | GODDARD2 | 138 | 536 | 1537 | 19.237 | 19.214 | 0.023 | 0.12% |
| 3 | 539675 | MILANTP4 | 138 | 534 | 1541 | 7.148 | 7.148 | 0.000 | 0.00% |
| 3 | 533029 | 59TH ST4 | 138 | 536 | 1537 | 19.131 | 19.080 | 0.051 | 0.27% |
| 3 | 515543 | RENFROW7 | 345 | 524 | 566 | 11.828 | 11.821 | 0.007 | 0.06% |
| 3 | 532792 | FR2EAST7 | 345 | 536 | 1537 | 6.635 | 6.631 | 0.004 | 0.06% |
| 3 | 532796 | WICHITA7 | 345 | 536 | 1537 | 24.745 | 24.714 | 0.031 | 0.12% |
| 3 | 533044 | GILL E 4 | 138 | 536 | 1537 | 28.848 | 28.765 | 0.083 | 0.29% |
| 4 | 515381 | PECKHMT4 | 138 | 524 | 566 | 8.384 | 8.334 | 0.050 | 0.60% |
| 4 | 521198 | CHILOCCO | 138 | 525 | 575 | 6.098 | 6.059 | 0.039 | 0.64% |
| 4 | 533032 | BU11PON4 | 138 | 536 | 1537 | 15.161 | 15.130 | 0.032 | 0.21% |
| 4 | 533062 | ROSEHIL4 | 138 | 536 | 1537 | 31.619 | 31.532 | 0.087 | 0.28% |
| 4 | 533066 | 64TH 4 | 138 | 536 | 1537 | 14.509 | 14.480 | 0.029 | 0.20% |
| 4 | 533068 | STEARMN4 | 138 | 536 | 1537 | 20.020 | 19.971 | 0.049 | 0.25% |
| 4 | 533072 | WACO 4 | 138 | 536 | 1537 | 23.837 | 23.784 | 0.053 | 0.22% |
| 4 | 533041 | EVANS S4 | 138 | 536 | 1537 | 42.437 | 42.370 | 0.067 | 0.16% |
| 4 | 539668 | HARPER 4 | 138 | 534 | 1541 | 6.003 | 6.007 | -0.004 | -0.07% |
| 4 | 539676 | MILAN 4 | 138 | 534 | 1541 | 4.251 | 4.253 | -0.002 | -0.04% |
| 4 | 515476 | HUNTERS7 | 345 | 524 | 566 | 12.408 | 12.406 | 0.001 | 0.01% |
| 4 | 583750 | GEN-2013 | 345 | 524 | 566 | 10.477 | 10.472 | 0.005 | 0.05% |
| 4 | 515544 | RENFROW4 | 138 | 524 | 566 | 13.624 | 13.622 | 0.002 | 0.01% |
| 4 | 532795 | FR2WEST7 | 345 | 536 | 1537 | 5.490 | 5.488 | 0.002 | 0.05% |
| 4 | 532771 | RENO 7 | 345 | 536 | 1535 | 11.554 | 11.555 | -0.001 | -0.01% |
| 4 | 532791 | BENTON 7 | 345 | 536 | 1537 | 19.502 | 19.471 | 0.031 | 0.16% |
| 4 | 560033 | G1524&G1 | 345 | 536 | 1537 | 19.633 | 19.620 | 0.014 | 0.07% |
| 4 | 562476 | G14-001- | 345 | 536 | 1537 | 11.033 | 11.033 | -0.001 | -0.01% |
| 4 | 533040 | EVANS N4 | 138 | 536 | 1537 | 42.437 | 42.370 | 0.067 | 0.16% |
| 4 | 533051 | INTERST4 | 138 | 536 | 1537 | 17.689 | 17.667 | 0.022 | 0.13% |
| 4 | 515477 | CHSHLMV7 | 345 | 524 | 566 | 12.391 | 12.389 | 0.001 | 0.01% |
| 5 | 514759 | NEWKIRK4 | 138 | 524 | 566 | 8.734 | 8.688 | 0.046 | 0.53% |
| 5 | 532991 | WEAVER 4 | 138 | 536 | 1537 | 22.405 | 22.349 | 0.057 | 0.25% |

| | | | | | | | | | |
|---|--------|----------|-----|-----|------|--------|--------|--------|--------|
| 5 | 532794 | ROSEHIL7 | 345 | 536 | 1537 | 19.152 | 19.118 | 0.034 | 0.18% |
| 5 | 533048 | HARRY 4 | 138 | 536 | 1537 | 13.722 | 13.698 | 0.024 | 0.18% |
| 5 | 533030 | BOEING 4 | 138 | 536 | 1537 | 17.358 | 17.326 | 0.032 | 0.18% |
| 5 | 533034 | CENTENN4 | 138 | 536 | 1537 | 16.870 | 16.853 | 0.017 | 0.10% |
| 5 | 533053 | LAKERDG4 | 138 | 536 | 1537 | 19.270 | 19.251 | 0.019 | 0.10% |
| 5 | 533074 | 45TH ST4 | 138 | 536 | 1537 | 29.635 | 29.599 | 0.036 | 0.12% |
| 5 | 539000 | RAGO 4 | 138 | 534 | 1541 | 3.655 | 3.657 | -0.003 | -0.07% |
| 5 | 539001 | ANTHONY4 | 138 | 534 | 1541 | 3.666 | 3.669 | -0.003 | -0.07% |
| 5 | 539638 | FLATRDG4 | 138 | 534 | 1541 | 14.973 | 14.978 | -0.005 | -0.03% |
| 5 | 539004 | MAYFLD 4 | 138 | 534 | 1541 | 3.787 | 3.789 | -0.002 | -0.05% |
| 5 | 514715 | WOODRNG7 | 345 | 524 | 566 | 17.238 | 17.240 | -0.003 | -0.02% |
| 5 | 515546 | GRANTCO4 | 138 | 524 | 566 | 6.278 | 6.279 | -0.001 | -0.01% |
| 5 | 515569 | MDFRDTP4 | 138 | 524 | 566 | 11.006 | 11.004 | 0.002 | 0.02% |
| 5 | 520409 | RENFROW4 | 138 | 525 | 587 | 9.998 | 9.999 | -0.001 | -0.01% |
| 5 | 578530 | FR3 | 345 | 536 | 1537 | 5.092 | 5.090 | 0.002 | 0.04% |
| 5 | 532773 | SUMMIT 7 | 345 | 536 | 1535 | 10.678 | 10.679 | -0.001 | -0.01% |
| 5 | 533416 | RENO 3 | 115 | 536 | 1535 | 25.673 | 25.676 | -0.003 | -0.01% |
| 5 | 532797 | WOLFCRK7 | 345 | 536 | 1536 | 15.728 | 15.724 | 0.003 | 0.02% |
| 5 | 532986 | BENTON 4 | 138 | 536 | 1537 | 28.321 | 28.278 | 0.043 | 0.15% |
| 5 | 539801 | THISTLE7 | 345 | 534 | 1529 | 15.627 | 15.628 | -0.001 | -0.01% |
| 5 | 584659 | G15024G1 | 345 | 536 | 1537 | 6.721 | 6.720 | 0.001 | 0.01% |
| 5 | 532768 | EMPEC 7 | 345 | 536 | 1534 | 17.278 | 17.284 | -0.005 | -0.03% |
| 5 | 583850 | GEN-2014 | 345 | 536 | 1537 | 7.551 | 7.552 | -0.001 | -0.01% |
| 5 | 533065 | SG12COL4 | 138 | 536 | 1537 | 21.794 | 21.777 | 0.017 | 0.08% |
| 5 | 533390 | MAIZEW 4 | 138 | 536 | 1537 | 28.204 | 28.171 | 0.033 | 0.12% |
| 5 | 533050 | HOOVERS4 | 138 | 536 | 1537 | 19.138 | 19.115 | 0.023 | 0.12% |

APPENDIX D: LOW WIND ANALYSIS

FIGURE D-1: GEN-2015-083 WITH GENERATION OFF AND NO SHUNT REACTOR




FIGURE D-1: GEN-2015-083 WITH GENERATION OFF AND SHUNT REACTOR

