
Southwest Power Pool (SPP)

Affected System Limited Operation Impact Study for DPP-2015-AUG-West

Final Report

**REP-0851:
Revision #02**

May 2020

**Submitted By:
Mitsubishi Electric Power Products, Inc. (MEPPI)
Power Systems Engineering Division
Warrendale, PA**

Report Revision Table

| Date | Revision | Description |
|-----------|----------|----------------------|
| 5/19/2020 | 0 | Issued Draft Report |
| 5/20/2020 | 1 | Address SPP comments |
| 5/22/2020 | 2 | Issued Final Report |
| | | |
| | | |

Title: Affected System Limited Operation Impact Study for DPP-2015-AUG-West: Final Report REP-0851
Date: May 2020
Author: Nicholas Tenza; Senior Engineer, Power Systems Engineering Division Nicholas Tenza
Approved: Donald Shoup; General Manager, Power Systems Engineering Division Donald Shoup

EXECUTIVE SUMMARY

Southwest Power Pool (“SPP”) has requested an Affected System Limited Operation Impact Study for the Midcontinent Independent System Operator (“MISO”) current study Generator Interconnection Requests (GIRs) in the DPP-2015-AUG-West cluster. The DPP-2015-AUG-West cluster consists of five (5) GIRs totaling approximately 1,000 MW of generation that were studied in geographical groups (clusters). Steady-state thermal and voltage analyses as well as Transfer Distribution Factor analyses were performed to determine the impact the MISO GIRs have on the SPP system. This report documents the impacts of five (5) projects in the MISO generator queue on the SPP transmission system and the Limited Operation amount calculation for each request. The MISO current study projects are listed in Table ES-1.

Table ES-1: Current Study Interconnection Projects Evaluated in DPP-2015-AUG-West

| GIR | Group # | Capacity | Service | Fuel Type | Area | Proposed Point of Interconnection |
|------|---------|----------|---------|-----------|----------------------|-----------------------------------|
| J412 | 09 | 200 | ER/NR | Wind | Nebraska | Raun 345 kV Substation |
| J455 | 09 | 300 | ER | Wind | Nebraska | Clay County 345 kV Substation |
| J436 | 15 | 150 | ER | Wind | Eastern South Dakota | Big Stone South 345 kV Substation |
| J437 | 15 | 150 | ER | Wind | Eastern South Dakota | Big Stone South 345 kV Substation |
| J442 | 15 | 200 | ER/NR | Wind | Eastern South Dakota | Big Stone South 230 kV Substation |

For the Affected System LOIS, power flow analysis was conducted. Certain constraints identified can be mitigated with updates to facility ratings per transmission owner feedback. Power flow analysis from this Affected System LOIS has determined the following amounts can interconnect on an interim basis prior to the completion of the R-Plan Network Upgrade:

- J412 request can interconnect 200 MW of generation with Network Resource Interconnection Service and,
- J455 request can interconnect 300 MW of generation with Energy Resource Interconnection Service and,
- J436 request can interconnect 150 MW of generation with Energy Resource Interconnection Service and,
- J437 request can interconnect 150 MW of generation with Energy Resource Interconnection Service and,
- J442 request can interconnect 200 MW of generation with Network Resource Interconnection Service

This study does not guarantee operation for all periods of time. This interconnection study identifies impacts for Energy Resource Interconnection Service (ERIS) interconnection injection constraints (defined as a 20% distribution factor impact for observed contingency constraints and 3% distribution factor impact for system intact constraints) and Network Resource Interconnection Service (NRIS) constraints (defined as 3% distribution factor impact) on the MISO Transmission System. This affected system study does not identify impacts for all potential situations. Although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every real-time operational situation. Because of this, it is likely that the MISO Interconnection Requests may be required to reduce generation output to zero (0) MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

The study results presented in this report are contingent upon completion of all SPP planned projects identified in the 17ITP base cases. In compliance with current SPP practices, an Affected System Restudy may be performed at SPP's discretion due to changes in assumptions of this study.

TABLE OF CONTENTS

| | |
|------------------------------------------------------------|-----|
| Executive Summary | i |
| 1. Background and Objectives | 4 |
| 2. Model Development..... | 5 |
| 2.1 Before Transfer Case Development | 5 |
| 2.1.1 SPP and MISO Higher Queued Generation Dispatch | 6 |
| 2.2 Transfer Case Development | 7 |
| 2.3 SPP Model Request | 7 |
| 3. Contingencies and Metrics..... | 8 |
| 3.1 Contingencies Examined for the Study | 8 |
| 3.2 Monitored Facilities | 8 |
| 3.3 Software Solution Parameters | 8 |
| 3.4 System Performance Criteria..... | 9 |
| 3.4.1 ERIS Thermal Constraints..... | 9 |
| 3.4.2 NRIS Thermal Constraints | 9 |
| 3.4.3 Voltage Constraints | 10 |
| 4. Steady-State Thermal and Voltage Analysis results..... | 11 |
| 4.1 Thermal Analysis Results..... | 11 |
| 4.2 Voltage Analysis Results..... | 12 |
| 5. Conclusion | 12 |
| Appendix A: Interconnection Tables | A-1 |
| Appendix B: Dispatch Tables | B-1 |
| Appendix C: NRIS Thermal Results..... | C-1 |

LIST OF TABLES

| | |
|--------------------------------------------------------------------------|------|
| Table 2-1: Summary of Study Cases | 5 |
| Table 2-2: Network Upgrades Applied to the BC Cases | 6 |
| Table 3-1: Buses with Additional Voltage Criteria | 10 |
| Table 3-2: First Tier External Areas – Facilities 115kV and Greater..... | 10 |
| Table 4-1: Thermal Constraints for NRIS Requests | 11 |
| Table A-1: SPP Higher-Queued Interconnection Projects..... | A-1 |
| Table A-2: MISO West Higher Queued-Interconnection Projects..... | A-3 |
| Table A-3: SPP Transmission Upgrades Removed | A-5 |
| Table B-1: Higher Queued and Current Study Dispatch | B-1 |
| Table B-2: MISO ER Sink Generators for TDF Analysis | B-2 |
| Table B-3: MISO NR Sink Generators for TDF Analysis – J412 (MEC)..... | B-11 |
| Table B-4: MISO NR Sink Generators for TDF Analysis – J442 (OTP)..... | B-11 |

1. Background and Objectives

SPP requested an Affected System Limited Operation Impact Study for five (5) generation interconnection requests (“GIRs”) in the MISO footprint for multiple study years and multiple seasonal power flow cases. These GIR’s are in MISO’s Definitive Planning Process August 2015 West region (DPP-2015-AUG West). The objective of this report is to determine the impact the MISO GIRs have on the SPP transmission system and the amount of Interconnection Service available without resulting in constraints meeting the thresholds for mitigation, if any, prior to the completion of all required Network Upgrades. Each GIR is to be studied in and evaluated on a group basis with a steady-state voltage and thermal analysis. The MISO GIRs have been placed in to the following geographical areas (clusters) for this study:

- Nebraska Area (Group 09 – 2 GIRs)
- Eastern South Dakota Area (Group 15 – 3 GIRs)

The Siemens Power Technologies International PSS/E Version 33.10.0 and PowerGEM’s TARA 1802 were used for this study. SPP started the model development with the following seven (7) DISIS-2016-001 model seasonal power flow cases in PSS/E format:

- Year 1 (2017) Winter Peak (17WP)
- Year 2 (2018) Spring (18G)
- Year 2 (2018) Summer Peak (18SP)
- Year 5 (2021) Light (21L)
- Year 5 (2021) Summer (21SP)
- Year 5 (2021) Winter (21WP) peak
- Year 10 (2026) Summer (26SP) peak

The power flow cases above were provided by SPP and included all SPP higher-queued generators and MISO higher queued generators. The power flow cases were updated by SPP to reflect the groups under study to create forty-six (46) cases (refer to Section 2 for detail model development). The cases were dispatched according to the criterion in Table B-1 and a selection of Network Upgrades were confirmed to be removed from the models (refer to Table A-3 for a list of upgrades that were removed from the models).

This impact study required a steady-state voltage and thermal analysis for each of the cases. The thermal analysis was completed to determine if any thermal constraints existed. If any thermal loadings greater than 100% were identified, a Transfer Distribution Factor (TDF) analysis was completed to determine if any MISO GIRs have a significant impact on the SPP transmission system element. A limited operation amount was required to be determined for constraints in the SPP transmission area that were determined to be caused by a MISO GIR. Once all thermal

constraints were mitigated, a voltage analysis was completed and the same process was followed to determine if any MISO GIRs cause the voltage constraints. If voltage constraints were observed, mitigation was recommended.

2. Model Development

SPP provided the seven (7) dispatched seasonal power flow cases for groups 09 and 15, i.e. the two geographical study areas (clusters) that include the MISO current study generation. The two groups then had three types of dispatch for their local generation: High-Variable Energy Resource (HVER) Energy Resource Interconnection Service (ERIS), Low-Variable Energy Resource (LVER) ERIS, and Network Resource Interconnection Service (NRIS). The groups and the dispatch resulted in 46 cases with unique dispatches as shown in Table 2-1. SPP higher-queued generation and MISO existing and higher-queued generation in the MISO West region were also included in the cases.

Table 2-1: Summary of Study Cases

| Seasonal Case | ERIS (GroupALL) | NRIS (Group00NR) | NRIS (GroupNR) |
|-----------------------------|------------------------|---------------------|-------------------|
| +1 Winter Peak (i.e. 17WP) | 1 per group | 1 per study | |
| +1 Spring (i.e. 18G) | 1 per group | | 1 per group |
| +1 Summer Peak (i.e. 18SP) | 1 per group | 1 per study | |
| +5 Light Load (i.e. 21L) | 1 per group | | 1 per group |
| +5 Summer Peak (i.e. 21SP) | 1 per group | 1 per study | |
| +5 Winter Peak (i.e. 21WP) | 1 per group | 1 per study | |
| +10 Summer Peak (i.e. 26SP) | 1 per group | 1 per study | |
| Total cases: | 14 cases | 5 cases | 4 cases |
| SPP DPP-2015-AUG-West | 46 cases (23 BC/23 TC) | | |

2.1 Before Transfer Case Development

This section describes the steps taken to develop the seven (7) seasonal power flow cases into the twenty-three (23) pre-project (“Before Transfer”) cases as required for this study. First, all higher-queued SPP generators were added and dispatched. Next, topology upgrades that existed in the SPP and MISO West area were added and MISO existing and higher-queued generation in the MISO West area were added and dispatched per SPP criteria. Refer to Table 2-2 for a list of Network Upgrades applied to the BC cases. Finally, the MISO West current study generators were added to the power flow cases, including all available collector system data, and were kept out-of-

service. Note for the 00NR-18SP case, a fictitious 250 Mvar SVC was required to be added to the MISO Dorsey bus (667035) in order to achieve an acceptable solution.

Table 2-2: Network Upgrades Applied to the BC Cases

| Ref No. | Network Upgrade Added |
|---------|---------------------------------------------------------------------------------------|
| 1 | Terminal equipment upgrade for Cleo Corner to Cleo Tap 138kV circuit |
| 2 | Bismark to Hilken 230kV uprate |
| 3 | Rerate Renfrow to Renfrow 138kV circuit, NRIS only |
| 4 | NIW to Colby 161kV rebuild |
| 5 | MISO Big Stone and Ellendale Projects advanced to 17WP-18WP |
| 6 | Rebuild Beatrice to Harbine 115kV circuit |
| 7 | Rebuild Gavins to Yankton 115kV circuit |
| 8 | M Ave to New Sharon 69kV reconductor |
| 9 | Powershiek transformer upgrade |
| 10 | Cleveland to Silvery City 138 kV Ckt 1 rerate |
| 11 | Matthewson – G15063 Tap 345 kV rerate |
| 12 | Dickinson transformer 230/115 kV Ckt 2 |
| 13 | Advance Colby 631198 - Ledyard 631197 - Kossuth 635369 to early seasons [17WP - 18SP] |

2.1.1 SPP and MISO Higher Queued Generation Dispatch

The included SPP higher-queued generators near the MISO West region were in the following groups:

- Nebraska (Group 9)
- Eastern South Dakota (Group 15)

A list of the SPP higher-queued generators added to the cases are in Table A-1. All generators were added with a 0.95 power factor capability and included in all cases regardless of their in-service date. For SPP generators with NRIS service in NR cases the increase in generation was offset by generators in the same control area. For all other cases and service types the increase in

generation was offset by generation in the SPP footprint. The MISO West higher-queued generation was included in the power flow cases, dispatched per SPP methodology, and are given in Table A-2.

2.2 Transfer Case Development

The Transfer Cases (“TC”) were created from the Before Transfer Cases (“BC”) by incrementally dispatching all of the current study generation in Table A-4. The current study requests were dispatched according to SPP methodology (Table B-1). The increase in generation was offset by generation in the MISO Classic region, excluding high-variable generation, for the ERIS cases and offset by generation in the MISO local area for NRIS cases. Note for the 00NR-18SP case, a fictitious 250 Mvar SVC was required to be added to the Dorsey bus (667035) and a fictitious 25 Mvar SVC was required to be added to the Patrick bus (152436) in order to achieve an acceptable solution.

2.3 SPP Model Request

MISO interconnection customers involved in this affected system analysis may obtain SPP models by submitting a request through the SPP Request Management System (RMS) (<https://spprms.issuetrak.com/login.asp>) and selecting the Quick Pick “Order Transmission Map/Model”. Information about setting up an RMS account is available on the SPP website (<http://www.spp.org/stakeholder-center/customer-relations/request-management-system/>).

SPP models contain Critical Energy Infrastructure Information and resource-specific data and are only available to entities that execute a Non-Competitive Duty Non-Disclosure Agreement. A customer may designate a consultant or other non-competitive agent to obtain models on their behalf.

3. Contingencies and Metrics

A total of forty-six (46) power flow cases were created for this study. Twenty-three (23) Before Transfer Cases (BC) were created by incorporating SPP higher-queued GIRs, MISO existing higher-queued GIRs, identified previously assigned MISO upgrades, and the current study generators out-of-service for DPP-2015-AUG-West. Twenty-three (23) Transfer Cases (TC) were created by dispatching all of the current study GIRs for DPP-2015-AUG-West- from the BC cases according to SPP's dispatch methodology. A comprehensive set of contingencies were analyzed for each case and the SPP transmission system was monitored. The contingencies and areas monitored in this study are identified in the following sections.

3.1 Contingencies Examined for the Study

The following contingencies were examined for this study:

- All branches, ties, shunts, and generators within the following areas:
 - SPP Internal Areas for 60kV – 999kV facilities:
 - 515 – 546, 640, 641, 642, 645, 650, 652, 659, 998, 999
 - SPP External Areas for 100kV – 999kV facilities:
 - 327, 330, 351, 356, 502-504, 600, 615, 620, 627, 635, 672, 680
- NERC, SPP, and Tier 1 Permanent Contingent Flowgates
- SPP T.O. Specific P1, P2, P4, and P5 TPL-004-1 Contingencies
- SPP T.O. Specific Op Guide Implementation

Note only P1 contingencies in the above contingency list were considered for mitigation.

3.2 Monitored Facilities

The following facilities were monitored for this study:

- All branches (thermal)/ buses(voltage) and ties within the following areas:
 - SPP Internal Areas for 60kV – 999kV facilities:
 - 515 – 546, 640 – 659, 998, 999
- NERC, SPP, and Tier 1 Permanent Monitor Flowgates (thermal)

3.3 Software Solution Parameters

The following PSS/E and TARA power flow solution settings were used for this study:

- Fixed Slope Decoupled Newton-Raphson Power Flow Solution (FDNS)
- Area Interchange Enabled
- Phase Shift Adjustment Enabled
- Transformer Tap Stepping Enabled

- DC Tap Adjustment Enabled
- Switch Shunt Adjustment Enabled
- Non-Divergent Solution Flag Disabled

3.4 System Performance Criteria

The following sections describe the criteria used to evaluate the performance of the system.

3.4.1 ERIS Thermal Constraints

For Energy Resource Interconnection Service (ERIS), thermal overloads were determined for system intact (N-0) greater than 100% of Rate A - normal and for contingency (N-1) greater than 100% of Rate B – emergency conditions. The overloads were then screened to determine which interconnection requests have at least

- 3% Distribution Factor (DF) for system intact conditions (N-0),
- 20% DF upon outage-based conditions (N-n),
- or 3% DF on contingent elements that resulted in a non-converged solution that are associated with voltage issues

The ERIS requests were sunk to the entire MISO Classic footprint. Refer to Table B-2 for a list of sink generators for the ERIS analysis. If a facility is overloaded under no contingency (P0) with distribution factor equal to or greater than 3% or under contingency (P1, P2, and Extreme Events) by a request with a distribution factor of greater than or equal to 20%, that request will be labeled as affecting, and a limited operation amount was determined for the impacting request. Non-converged contingencies shall also be considered for limited operation service.

3.4.2 NRIS Thermal Constraints

For Network Resource Interconnection Service (NRIS), thermal overloads were determined for system intact (N-0) greater than 100% of Rate A - normal and for contingency (N-1) greater than 100% of Rate B – emergency conditions. The overloads were then screened to determine which interconnection requests have at least

- 3% Distribution Factor (DF) for system intact conditions (N-0),
- 3% DF upon outage-based conditions (N-n),
- or 3% DF on contingent elements that resulted in a non-converged solution that are associated with voltage issues

The NR requests were sunk to their local transmission area (J412 – MEC, J442 – OTP). Refer to Table B-3 for a list of MEC sink generators for J412 and Table B-4 for a list of OTP sink generators for J442. If a facility is overloaded under no contingency (P0) or under contingency (P1, P2, and

Extreme Events) with distribution factor equal to or greater than 3%, that request will be labeled as affecting, and a limited operation amount was determined for the impacting request. Non-converged contingencies shall also be considered for limited operation service.

3.4.3 Voltage Constraints

For non-converged power flow solutions that are determined to be caused by lack of voltage support, appropriate transmission support were identified to mitigate the constraint. After all thermal overload and voltage support mitigations were determined; a full ACCC analysis was performed to determine voltage constraints. The following voltage performance guidelines were used in accordance with the Transmission Owner local planning criteria. SPP voltage criteria are applicable to all SPP facilities 69 kV and greater in the absence of more stringent criteria:

- P0 (system intact): 0.95 to 1.05 per unit
- P1 – P7 (contingency): 0.90 to 1.05 per unit

Table 3-1 and Table 3-2 list buses that have more stringent criteria than listed above.

Table 3-1: Buses with Additional Voltage Criteria

| Areas/Buses | Area/Bus # | Voltage | System Intact (per unit) | Contingency (per unit) |
|--------------|------------|-------------------------------|--------------------------|------------------------|
| AEPW EMDE | 520 544 | 60kV – 999kV 159kV – 999kV | 0.95 – 1.05 | 0.92 – 1.05 |
| WERE | 536 | 60kV – 200kV | 0.95 – 1.05 | 0.93 – 1.05 |
| WERE | 536 | 200kV – 999kV | 0.95 – 1.05 | 0.95 – 1.05 |
| TUCO | 525830 | 230kV | 0.925 – 1.05 | 0.925 – 1.05 |
| Wolf Creek | 532797 | 345kV | 0.985 – 1.03 | 0.985 – 1.03 |
| S1251 | 646251 | 161kV | 1.001 – 1.047 | 1.001 – 1.047 |

Table 3-2: First Tier External Areas – Facilities 115kV and Greater

| Areas/Buses | System Intact (per unit) | Contingency (per unit) |
|-------------------------------------------------------------------------------------|--------------------------|------------------------|
| EES-EAI LAGN EES AMMO CLEC LAFA LEPA XEL MP SMMPA GRE | 0.95 – 1.05 | 0.90 – 1.05 |

| | | |
|------------------------------------------|-------------|-------------|
| OTP ALTW MEC MDU DPC ALTE | | |
| OTP-H (115kV+) | 0.97 – 1.05 | 0.92 – 1.10 |
| SPC | 0.95 – 1.05 | 0.95 – 1.05 |

The constraints identified through the voltage scan were screened for the following for each interconnection request (note in certain conditions, engineering judgement may be required to determine whether or not a generator had impacts to voltage constraints):

- $\geq 3\%$ PTFD on any circuit at the constraint for system intact or on the contingent element
- Violation in the TC case beyond BC
- $\geq 2\%$ change in pu voltage between BC and TC cases

4. Steady-State Thermal and Voltage Analysis results

This section lists the thermal and voltage constraints identified from the steady-state analysis and the associated limited operation amounts of the impacting requests (if applicable).

4.1 Thermal Analysis Results

There were no thermal constraints that met the SPP criteria for Groups 09 or 15 ERIS study cases. Refer to Table 4-1 for a list of thermal constraints identified in this analysis that met the NRIS TDF criteria. Due to transmission owner feedback and updates to the models, there were no constraints identified requiring additional mitigation. Refer to Appendix C for a complete list of NRIS thermal results.

Table 4-1: Thermal Constraints for NRIS Requests

| Ref. No. | Monitored Facility | Rating | Areas Name | Seasons | Worst Percentage Loading (Season) | Contingency for Worst Loading | OTDF (%) |
|----------|--------------------------------------------------|--------|------------|-------------------------------------|-----------------------------------|-----------------------------------------------------|-------------|
| 1 | 602008 MINVALT4 230 652550 GRANITF4 230 1 | 259 | XEL/WAPA | 00NR-18SP 00NR-21SP 00NR-26SP | 128.07 (21SP) | 602009 MNVLTAP4 230 652550 GRANITF4 230 1 | J442: 3.77 |
| 2 | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 00NR-18SP 00NR-21SP 00NR-26SP | 125.71 (26SP) | 601048 LYON CO 3 345 601077 HAWKSNEST 3 345 1 | J442: 12.37 |
| 3 | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 00NR-18SP 00NR-21SP 00NR-26SP | 120.86 (26SP) | 601031 BRKNGCO3 345 620417 BSSOUTH3 345 1 | J442: 6.32 |

After discussion with the transmission owners, the following updates to the transmission elements identified in Table 4-1 were implemented and confirmed to cover the maximum loading observed in the thermal analysis.

- Minnesota Valley to Granite Falls 230kV line
 - Upgrade CT jumpers to achieve a minimum rating of 407 MVA (332 MVA required)
- Split Rock to White 345kV line
 - Upgrade jumpers to achieve a minimum rating of 1057 MVA (901.5 MVA required)
- Johnson Junction Tap to Morris 115kV line section
 - Upgrade GRE portion of line conductor to achieve minimum line rating of 122 MVA (111.4 MVA required)

After applying the above updates, there were no additional thermal constraints identified for the NRIS analysis. It was determined all ER and NR requests can interconnect at the following amounts:

- J412 request can interconnect 200 MW of generation with Network Resource Interconnection Service and,
- J455 request can interconnect 300 MW of generation with Energy Resource Interconnection Service and,
- J436 request can interconnect 150 MW of generation with Energy Resource Interconnection Service and,
- J437 request can interconnect 150 MW of generation with Energy Resource Interconnection Service and,
- J442 request can interconnect 200 MW of generation with Network Resource Interconnection Service

4.2 Voltage Analysis Results

There were no voltage constraints identified for Groups 09 or 15 ERIS and NRIS study cases.

5. Conclusion

SPP had requested an Affected System Limited Operation Impact Study for five (5) MISO GIRs, totaling 1,000 MW, in the DPP-2015-AUG-West group. A steady-state thermal and voltage analysis as well as Transfer Distribution Factor analysis was performed to determine the impact the MISO GIRs have on the SPP system. It was observed that the MISO GIRs resulted in no thermal constraints and no voltage constraints that would require limited operation amounts for the MISO requests. The 5 MISO GIRs were thus determined to be able to connect at full output without resulting in a negative impact on the SPP transmission system.

The study results presented in this report are contingent upon completion of all SPP planned projects identified in the 17ITP base cases. In compliance with current SPP practices, an Affected System Restudy may be performed at SPP's discretion due to changes in assumptions of this study.

Appendix A: Interconnection Tables

Table A-1: SPP Higher-Queued Interconnection Projects

| GIR | Proposed Point of Interconnection | Max MW Output | Fuel Type | Group # | Service | Area |
|------------------|-----------------------------------------|---------------|-----------|---------------|---------|------|
| GEN-2003-021N | Ainsworth Wind Tap 115kV | 75 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2004-023N | Columbus Co 115kV | 75 | Coal | 09 - Nebraska | ER | NPPD |
| GEN-2006-020N | Bloomfield 115kV | 42 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2006-037N1 | Broken Bow 115kV | 75 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2006-038N005 | Broken Bow 115kV | 80 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2006-038N019 | Petersburg North 115kV | 80 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2006-044N | North Petersburg 115kV | 40.5 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2007-011N08 | Bloomfield 115kV | 81 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2008-086N02 | Meadow Grove 230kV | 201 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2008-1190 | S1399 161kV | 60 | Wind | 09 - Nebraska | ER | OPPD |
| GEN-2008-123N | Tap Pauline - Hildreth (Rosemont) 115kV | 89.66 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2009-040 | Tap Smittyville - Knob Hill 115KV | 72 | Wind | 09 - Nebraska | ER | WERE |
| GEN-2010-051 | Hoskins-Twin Church 230kV | 200 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2011-018 | Steele City 115kV | 73.6 | Wind | 09 - Nebraska | ER/NR | NPPD |
| GEN-2011-027 | Hoskins-Twin Church 230kV | 120 | Wind | 09 - Nebraska | ER/NR | NPPD |
| GEN-2011-056 | Jeffrey 115kV | 3.6 | Hydro | 09 - Nebraska | ER | NPPD |
| GEN-2011-056A | John 1 115kV | 3.6 | Hydro | 09 - Nebraska | ER | NPPD |
| GEN-2011-056B | John 2 115kV | 4.5 | Hydro | 09 - Nebraska | ER | NPPD |
| GEN-2012-021 | Terry Bundy Generating Station 115kV | 4.8 | Gas | 09 - Nebraska | ER | LES |
| GEN-2013-002 | Monolith 115kV | 50.6 | Wind | 09 - Nebraska | ER/NR | LES |
| GEN-2013-008 | Steele City 115kV | 1.2 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2013-019 | Monolith 115kV | 73.6 | Wind | 09 - Nebraska | ER/NR | LES |

| | | | | | | |
|----------------|---------------------------------------------------|--------|------|---------------------------|-------|------|
| GEN-2013-032 | Antelope 115kV | 202.5 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2014-0011S | Sulphur 115kV | 103.24 | Wind | 15 - Eastern South Dakota | ER | WAPA |
| GEN-2014-004 | Steele City 115kV | 4 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2014-013 | Meadow Grove 230kV | 73.5 | Wind | 09 - Nebraska | ER/NR | NPPD |
| GEN-2014-031 | Meadow Grove 230kV | 35.8 | Wind | 09 - Nebraska | ER/NR | NPPD |
| GEN-2014-032 | Meadow Grove 230kV | 10.2 | Wind | 09 - Nebraska | ER/NR | NPPD |
| GEN-2014-039 | Friend 115kV | 73.4 | Wind | 09 - Nebraska | ER/NR | NPPD |
| GEN-2015-007 | Hoskins 345kV | 160 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2015-023 | Grand Prairie-Grand Island (Holt County NE) 345kV | 300.7 | Wind | 09 - Nebraska | ER/NR | NPPD |
| GEN-2015-076 | Belden 115kv Substation | 158.4 | Wind | 09 - Nebraska | ER | NPPD |
| GEN-2015-088 | Moore-Pauline 345kV | 300 | Wind | 09 - Nebraska | ER/NR | NPPD |

*ERIS/NRIS MW output was the same for all generators unless otherwise noted.

Table A-2: MISO West Higher Queued-Interconnection Projects

| MISO Project | Point of Interconnection | Max MW Output | Service | Fuel Type | Area |
|--------------|----------------------------------------------------------------|---------------|---------|-----------|------|
| G058 | Valley Queen 12.5kV | 3 | ERIS | Diesel | SD |
| G059 | Solway CT substation | 50 | ERIS | Gas | MN |
| G067 | Unknown | 2 | ERIS | Diesel | ND |
| G073 | Unknown | 1 | ERIS | Wind | MN |
| G146 | PRRF Substation | 4 | ERIS | Biomass | MN |
| G291 | Jamestown - Oakes 41.6kV | 19 | ERIS | Wind | ND |
| G340 | Toronto 41.6kV | 1 | ERIS | Wind | MN |
| G380 | Rugby 115kV Substation | 150 | ERIS | Wind | ND |
| G396 | Milbank 41.6kV | 2 | ERIS | Diesel | SD |
| G474 | OTP Cyrus - Hoffman 41.6kV | 20 | ERIS | Wind | MN |
| G481 | Belcourt 69kV Substation | 1 | ERIS | Wind | ND |
| G619 | GRE Tamarac 41 kV Substation | 50 | NRIS | Wind | MN |
| G645 | Ladish 115 kV Substation | 50 | NRIS | Coal | ND |
| G736 | Big Stone South 230kV Substation | 200 | NRIS | Wind | SD |
| G788 | Ladish 115 kV substation | 49 | NRIS | Coal | ND |
| J191 | Rolling Hills 345 kV Substation | 101.2 | NRIS | Wind | IA |
| J262 | OTP Jamestown 345/115 kV substation | 100 | NRIS | Wind | ND |
| J263 | OTP Jamestown 345/115 kV Substation | 100 | NRIS | Wind | ND |
| J274 | Winterset. - Creston 161 kV | 100 | NRIS | Wind | IA |
| J279 | Raun 345 kV Substation | 30 | NRIS | Coal | IA |
| J285 | Proposed O'Brien County 345kV substation | 250 | NRIS | Wind | IA |
| J289 | 161 kV sybstation on Winterset Junction to Creston 161 kV Line | 20 | NRIS | Wind | IA |
| J343 | 161 kv substation on Creston-Clarinda line | 150 | NRIS | Wind | IA |
| J411 | LeHigh - Raun 345 kV Line | 300 | NRIS | Wind | IA |

| | | | | | |
|------|-----------------------------------------------|-----|------|------|----|
| J412 | LeHigh - Raun 345 kV line | 200 | NRIS | Wind | IA |
| J436 | Big Stone South - Ellendale 345 kV line | 150 | ERIS | Wind | SD |
| J437 | Big Stone South - Ellendale 345 kV line | 150 | ERIS | Wind | SD |
| J438 | Poweshiek-Parnell 161 kV line | 170 | NRIS | Wind | IA |
| J442 | Big Stone substation via a radial 230 kV line | 200 | NRIS | Wind | SD |
| J455 | Kossuth - O'Brien 345 kV line | 300 | ERIS | Wind | IA |
| R101 | 1.5 miles SW of Red Lake Falls, MN | 4.6 | NRIS | Wind | MN |
| R15 | Pomeroy 161 kV substation | 80 | NRIS | Wind | IA |
| R23 | Monona - Carroll 161 kV | 100 | NRIS | Wind | IA |
| R26 | MEC Cooper - Booneville 345 kV | 400 | ERIS | Wind | MO |
| R34 | Council Bluffs - Madison County 345 kV | 250 | NRIS | Wind | IA |
| R35 | Pomeroy Wind Farm site | 80 | | Wind | IA |
| R38 | MEC Council Bluffs - Grimes 345 kV | 200 | NRIS | Wind | IA |
| R39 | Raun - Lakefield Junction | 500 | NRIS | Wind | IA |
| R41 | MEC Council Bluffs - Grimes 345 kV | 100 | NRIS | Wind | IA |
| R42 | Lehigh 345 kV Substation | 250 | NRIS | Wind | IA |
| R49 | Pomeroy Generating station | 12 | NRIS | Wind | IA |
| R65 | R34 Expansion | 92 | NRIS | Wind | IA |

Table A-3: SPP Transmission Upgrades Removed

| Ref No. | Network Upgrade Removed |
|----------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1 | SPP R Plan <ul style="list-style-type: none">• Thedford 345/115/13.8 kV transformer• Gerald Gentleman Station to Thedford 345 kV circuit #1• Holt County to Thedford 345 kV circuit #1 |
| 2 | Grand Island to Holt 345kV CT uprate (rating change, using 19ITP rating) |

Table A-4: MISO West Current Study Interconnection Projects

| GIR | Group # | Capacity | Service | Fuel Type | Area | Proposed Point of Interconnection |
|------------|----------------|-----------------|----------------|------------------|----------------------|------------------------------------------|
| J412 | 09 | 200 | ER/NR | Wind | Nebraska | Raun 345 kV Substation |
| J455 | 09 | 300 | ER | Wind | Nebraska | Clay County 345 kV Substation |
| J436 | 15 | 150 | ER | Wind | Eastern South Dakota | Big Stone South 345 kV Substation |
| J437 | 15 | 150 | ER | Wind | Eastern South Dakota | Big Stone South 345 kV Substation |
| J442 | 15 | 200 | ER/NR | Wind | Eastern South Dakota | Big Stone South 230 kV Substation |

Appendix B: Dispatch Tables

Table B-1: Higher Queued and Current Study Dispatch

| Dispatch Type | Season | Service Type | Renewable in group | Renewable out of group | Conventional in group | Conventional out of group |
|---------------|-----------------------|--------------|------------------------|------------------------|-----------------------|---------------------------|
| HVER | All | All | 100% | 20% | N/A | N/A |
| LVER | Peak | All | 20% | 20% | 100% | 100% |
| NR | Spring and Light Load | ERIS | 80% | 20% | Off | Off |
| | | NRIS | 100% | 20% | 100% | 20% |
| | Peak | ERIS | 20% (solar: 80% in SP) | 20% (solar: 80% in SP) | 80% | 80% |
| | | NRIS | 100% | 100% | 100% | 100% |

HVER – High Variable Energy Resource Dispatch

LVER – Low Variable Energy Resource Dispatch

N/A – units are not dispatched up from base case amounts

Renewable – Includes wind, solar, and storage

Conventional – Includes nuclear, hydro, coal, cc, CT, oil, waste heat

Table B-2: MISO ER Sink Generators for TDF Analysis

| Bus # | Bus Name | ID | Bus # | Bus Name | ID | Bus # | Bus Name | ID |
|--------|------------------|----|--------|--------------------|----|--------|--------------------|----|
| 248893 | 07LCPGD1 13.800 | 1 | 350233 | 1MRNGEN3 13.800 | 3 | 608715 | INLAND G 13.800 | 1 |
| 248894 | 07LCPGD2 13.800 | 1 | 350234 | 1MRNGEN4 20.000 | 4 | 600026 | INV 71G 13.800 | 1 |
| 248895 | 07LCPGD3 13.800 | 1 | 350235 | 1MRNGEN5 13.800 | 5 | 600027 | INV 72G 13.800 | 2 |
| 248773 | 07MEROM5 345.00 | 1 | 350236 | 1MRNGEN6 13.800 | 6 | 600028 | INV 73G 13.800 | 3 |
| 248903 | 07RAT_1G 13.500 | 1 | 347832 | 1NEWTON 1 24.000 | 1 | 600029 | INV 74G 13.800 | 4 |
| 248904 | 07RAT_2G 13.500 | 1 | 347833 | 1NEWTON 2 24.000 | 2 | 600030 | INV 75G 13.800 | 5 |
| 248889 | 07WORTH1 13.800 | 1 | 345396 | 1OSAGE 1&2 13.800 | 1 | 600031 | INV 76G 13.800 | 6 |
| 248890 | 07WORTH2 13.800 | 1 | 345397 | 1OSAGE 3&4 13.800 | 3 | 256479 | IRVING C2.5000 | 1 |
| 251849 | 08CAY1 18.000 | 1 | 345398 | 1OSAGE 5&6 13.800 | 5 | 693787 | ISLAND ST PP13.800 | G2 |
| 251850 | 08CAY2 18.000 | 2 | 345399 | 1OSAGE 7&8 13.800 | 7 | 600051 | JANESVL9 23.900 | 1 |
| 251851 | 08CAYCT4 13.800 | 4 | 349966 | 1PEARL GT 13.800 | 2 | 603156 | JIMFLS 7 115.00 | 1 |
| 251852 | 08CONRSV 13.800 | 1 | 345441 | 1PENOGEN1 13.800 | 1 | 698617 | JOF G 2.4000 | 1 |
| 251853 | 08DESTEC 18.000 | 1 | 345442 | 1PENOGEN2 13.800 | 2 | 681542 | JPM 24.000 | 6 |
| 251901 | 08EDWCT1 18.000 | G1 | 345443 | 1PENOGEN3 13.800 | 3 | 693783 | JUNEAU J31 13.800 | 1 |
| 251902 | 08EDWCT2 18.000 | G2 | 345444 | 1PENOGEN4 13.800 | 4 | 693793 | KAU CLP HY 4.1600 | H2 |
| 251903 | 08EDWST1 18.000 | ST | 345501 | 1PICKVL 1 13.800 | 1 | 693792 | KAU LCP HY 2.4000 | H1 |
| 251858 | 08GALL2 18.000 | 2 | 345502 | 1PICKVL 2 13.800 | 2 | 693790 | KAU_CITY HY12.4000 | H1 |
| 251860 | 08GALL4 18.000 | 4 | 345503 | 1PICKVL 3 13.800 | 3 | 693791 | KAU_CITY HY22.4000 | H2 |
| 251861 | 08GIB1 24.000 | 1 | 345504 | 1PICKVL 4 13.800 | 4 | 693789 | KAU_RCP HY 2.4000 | H1 |
| 251862 | 08GIB2 24.000 | 2 | 345505 | 1PICKVL 5 13.800 | 5 | 698963 | KBADGRHY 4.1600 | H1 |
| 251863 | 08GIB3 24.000 | 3 | 345506 | 1PICKVL 6 13.800 | 7 | 256422 | KENT CO C13.800 | 1 |
| 251864 | 08GIB4 24.000 | 4 | 349129 | 1PR STATE G124.500 | 1 | 698301 | KIL G1 4.0000 | 1 |
| 251865 | 08GIB5 24.000 | 5 | 349130 | 1PR STATE G224.500 | 2 | 699109 | KIN HG 13.800 | 1 |
| 251866 | 08HENRY1 13.800 | 1 | 345994 | 1RCEC G1 13.800 | 1 | 600006 | KING 31G 20.000 | 1 |
| 251867 | 08HENRY2 13.800 | 2 | 345995 | 1RCEC G2 13.800 | 2 | 635853 | KNOXIND8 69.000 | 4 |
| 251868 | 08HENRY3 13.800 | 3 | 345996 | 1RCEC G3 13.800 | 3 | 693823 | KRAFT K1 13.800 | 1 |
| 251952 | 08MADSN1 13.800 | 1 | 345997 | 1RCEC G4 13.800 | 4 | 693824 | KRAFT K2 13.800 | 2 |
| 251953 | 08MADSN2 13.800 | 2 | 340574 | 1REID 1 13.800 | 5 | 680099 | LAFARG_8 69.000 | 1 |
| 251954 | 08MADSN3 13.800 | 3 | 340575 | 1REID CT 13.800 | C | 699653 | LAKF G9 13.800 | 9 |
| 251955 | 08MADSN4 13.800 | 4 | 347819 | 1SHELBYCO_U113.800 | 1 | 630076 | LAKFLDM8 69.000 | 1 |
| 251956 | 08MADSN5 13.800 | 5 | 347823 | 1SHELBYCO_U213.800 | 2 | 699651 | LAKFNT1 13.800 | 6 |
| 251957 | 08MADSN6 13.800 | 6 | 347824 | 1SHELBYCO_U313.800 | 3 | 699652 | LAKFNT2 13.800 | 5 |
| 251958 | 08MADSN7 13.800 | 7 | 347825 | 1SHELBYCO_U413.800 | 4 | 629072 | LANS5 4G 22.000 | 4 |
| 251959 | 08MADSN8 13.800 | 8 | 347826 | 1SHELBYCO_U513.800 | 5 | 259446 | LARCH C4.1600 | 1 |
| 251869 | 08MRKLN D 11.500 | 1 | 347827 | 1SHELBYCO_U613.800 | 6 | 608702 | LASKIN 7 115.00 | 1 |
| 251870 | 08NBL SV3 13.800 | 3 | 347828 | 1SHELBYCO_U713.800 | 7 | 661055 | LEWIS71G 13.800 | 1 |

| | | | | | | | | | | | |
|--------|----------|--------|----|--------|--------------|--------|---|--------|-------------|--------|----|
| 251871 | 08NBLSV4 | 13.800 | 4 | 347829 | 1SHELBYCO_U8 | 13.800 | 8 | 613110 | LITCHFLD | 69.000 | 10 |
| 251872 | 08NBLSV5 | 13.800 | 5 | 343554 | 1REYNOLD CT | 13.200 | 1 | 699625 | LITTLE Q H1 | 0.4800 | 1 |
| 251873 | 08NOBS1 | 13.800 | 1 | 345670 | 1RUSH G1 | 18.000 | 1 | 699626 | LITTLE Q H2 | 4.1600 | 2 |
| 251874 | 08NOBS2 | 13.800 | 2 | 345671 | 1RUSH G2 | 18.000 | 2 | 699627 | LITTLE Q H3 | 4.1600 | 3 |
| 251878 | 08VERML1 | 13.800 | 1 | 345756 | 1SIOUX 1 | 18.000 | H | 699628 | LITTLE Q H5 | 0.4800 | 5 |
| 251879 | 08VERML2 | 13.800 | 2 | 345765 | 1SIOUX 2 | 18.000 | H | 699629 | LITTLE Q H6 | 0.4800 | 6 |
| 251880 | 08VERML3 | 13.800 | 3 | 349122 | 1TILTON G1 | 13.800 | 1 | 608850 | LITTLEF9 | 34.500 | 1 |
| 251881 | 08VERML4 | 13.800 | 4 | 349123 | 1TILTON G2 | 13.800 | 2 | 605062 | LKCRYST8 | 69.000 | 1 |
| 251882 | 08VERML5 | 13.800 | 5 | 349124 | 1TILTON G3 | 13.800 | 3 | 630198 | LMCK E 8 | 69.000 | 2 |
| 251883 | 08VERML6 | 13.800 | 6 | 349125 | 1TILTON G4 | 13.800 | 4 | 630197 | LMCK W 8 | 69.000 | 1 |
| 251884 | 08VERML7 | 13.800 | 7 | 345826 | 1TRIGENMO | 13.800 | 1 | 256477 | LOUD H2 | 5.000 | 1 |
| 251885 | 08VERML8 | 13.800 | 8 | 345832 | 1TS G1 | 13.800 | 1 | 636641 | LOUIS31G | 24.000 | 1 |
| 251886 | 08WABR D | 2.4000 | 7A | 345841 | 1TS G2 | 13.800 | 2 | 600017 | LSP CT G | 13.200 | C |
| 251887 | 08WABR1 | 13.800 | 1 | 345886 | 1VENCTG | 13.800 | 8 | 608682 | LSPI 9 | 14.300 | 1 |
| 251888 | 08WABR2 | 13.800 | 2 | 345882 | 1VENICE3 | 15.000 | 3 | 600018 | LSSTEAMG | 13.200 | S |
| 251889 | 08WABR3 | 13.800 | 3 | 345883 | 1VENICE4 | 15.000 | 4 | 636203 | LUNDQST5 | 161.00 | 2 |
| 251890 | 08WABR4 | 13.800 | 4 | 345884 | 1VENICE5 | 13.800 | 5 | 258583 | MACKINAW C | 24.900 | 1 |
| 251892 | 08WABR5 | 13.800 | 5 | 340576 | 1WILSON | 24.000 | 1 | 605063 | MADLV8 | 69.000 | 1 |
| 251893 | 08WABR6 | 24.000 | 6 | 349114 | 1WOOD RIV G4 | 13.800 | 4 | 603088 | MAIN ST7 | 115.00 | 1 |
| 251894 | 08WBSHC1 | 13.800 | 1 | 349115 | 1WOOD RIV G5 | 20.000 | H | 699773 | MANSTQ | 4.1600 | 1 |
| 251895 | 08WBSHC3 | 13.800 | 3 | 635822 | 29 HUBB8 | 69.000 | 1 | 698746 | MCCLURE | 2.4000 | 1 |
| 251896 | 08WBSHC5 | 13.800 | 5 | 346573 | 2AVENA | 69.000 | 1 | 699105 | MCH HG1 | 4.1600 | 1 |
| 251897 | 08WHTLD1 | 13.800 | 1 | 343008 | 2FULTON69 | 69.000 | 4 | 699106 | MCH HG2 | 4.1600 | 2 |
| 251898 | 08WHTLD2 | 13.800 | 2 | 344805 | 2JC FAIR | 69.000 | 1 | 698552 | MELISSA | 13.800 | 3 |
| 251899 | 08WHTLD3 | 13.800 | 3 | 345193 | 2MEXICO UE | 69.000 | 1 | 605113 | MELRSMU8 | 69.000 | 1 |
| 251900 | 08WHTLD4 | 13.800 | 4 | 345222 | 2MOBERLY | 69.000 | 1 | 605379 | MENOMONG | 69.000 | 1 |
| 253508 | 10AB_GT1 | 13.800 | 3 | 345240 | 2MOREAU | 69.000 | 1 | 680157 | MERRIL_8 | 69.000 | 1 |
| 253509 | 10AB_GT2 | 13.800 | 4 | 343003 | 2PLANT | 69.000 | 5 | 693616 | MERRILL HY | 2.3000 | 1 |
| 253506 | 10ABB_G1 | 22.000 | 1 | 343051 | 2PLANT2 | 69.000 | 7 | 693527 | MEWD CT | 13.800 | 1 |
| 253507 | 10ABB_G2 | 22.000 | 2 | 343040 | 2UMC | 69.000 | 1 | 256478 | MIO H2 | 5.000 | 1 |
| 253513 | 10BG_GT1 | 13.800 | 1 | 680014 | 7MILECRK | 69.000 | 1 | 600019 | MNRIVRG1 | 13.800 | 1 |
| 253514 | 10BG_GT2 | 13.800 | 2 | 256421 | ADA C | 13.800 | 1 | 608714 | MNTC A G | 13.800 | 2 |
| 253625 | 10CAN_G1 | 6.9000 | 1 | 630680 | ADM69KV8 | 69.000 | 6 | 608713 | MNTC C G | 13.800 | 1 |
| 253626 | 10CAN_G2 | 6.9000 | 2 | 259342 | ADRIAN EN C | 2.4000 | 1 | 636761 | MOLIN12G | 13.800 | 1 |
| 253627 | 10CAN_G3 | 6.9000 | 3 | 630057 | ADRIANM8 | 69.000 | 1 | 636762 | MOLIN34G | 13.800 | 3 |
| 253502 | 10CUL_G2 | 14.400 | 2 | 256462 | ALCONA H | 4.8000 | 1 | 638090 | MONTEZU8 | 69.000 | 9 |
| 253503 | 10CUL_G3 | 22.000 | 3 | 693577 | ALEXANDR HY | 2.3000 | 1 | 613160 | MORA | 69.000 | 2 |
| 253512 | 10NE_GT | 12.500 | 1 | 658054 | ALEXPLDM | 115.00 | 1 | 633008 | MPW 8G | 13.800 | 8 |
| 253591 | 10WAR_G1 | 15.000 | 1 | 256463 | ALLEGAN H | 4.8000 | 1 | 633009 | MPW 9G | 20.000 | 9 |

| | | | | | | | | |
|--------|--------------------|----|--------|--------------------|----|--------|--------------------|---|
| 253592 | 10WAR_G2 15.000 | 2 | 630653 | AMANA 69.000 | 1 | 629091 | MQOKETA9 34.500 | 1 |
| 253593 | 10WAR_G3 15.000 | 3 | 629108 | AMES 9 34.500 | 7 | 698767 | MUNISNG GEN 2.4000 | 1 |
| 253594 | 10WAR_G4 20.000 | 4 | 638001 | AMES 8 69.000 | 7 | 613170 | N BRANCH 69.000 | 3 |
| 255246 | 17BAILLY-10 13.800 | 10 | 629149 | ANITA 34.500 | 3 | 630373 | N CENT8 69.000 | 1 |
| 255234 | 17BAILLY-7 22.000 | 7 | 600020 | ANS 72G 13.800 | 2 | 630614 | N LONDON 69.000 | 1 |
| 255235 | 17BAILLY-8 22.000 | 8 | 600021 | ANS 73G 13.800 | 3 | 608732 | NATIONLG 13.800 | 1 |
| 255236 | 17MI_CITY-1222.000 | 12 | 698925 | AP_PPRGT 12.500 | GT | 693730 | NB VIL G 2.4000 | 1 |
| 255238 | 17SCHAFER-1418.000 | 14 | 698914 | APP HYD GEN 4.0000 | H1 | 605469 | NCENTRL8 69.000 | 1 |
| 255237 | 17SCHAFER-1522.000 | 15 | 698927 | APP_PAPR 12.500 | S | 699552 | NEEVIN 18.000 | 1 |
| 255232 | 17SCHAFER-1724.000 | 17 | 680431 | ARCAD MU 69.000 | 1 | 699071 | NEQ HG1 6.9000 | 1 |
| 255233 | 17SCHAFER-1824.000 | 18 | 680064 | ARGYLE_8 69.000 | 1 | 699072 | NEQ HG2 6.9000 | 2 |
| 255249 | 17SCHAFER-A 13.800 | A | 629074 | ARNOLD1G 22.000 | 1 | 630722 | NEVADA R 69.000 | W |
| 255250 | 17SCHAFER-B 13.800 | B | 638051 | ATLNTIC8 69.000 | 1 | 613190 | NEW PRAG 69.000 | 2 |
| 255441 | 17SGR_CK-CTA18.000 | G1 | 613010 | AUSTIN NE G 69.000 | 1 | 680132 | NEWLIS_8 69.000 | 1 |
| 255442 | 17SGR_CK-CTB18.000 | G2 | 698655 | AUTRAIN 2.4000 | 1 | 605079 | NEWULMS8 69.000 | 3 |
| 255443 | 17SGR_CK-STG18.000 | S1 | 658098 | BENSONM7 115.00 | 1 | 608767 | NSM 2ABG 13.800 | 2 |
| 255240 | 17WCE-GT1 18.000 | 1 | 600041 | BFT 85G 13.800 | 5 | 608762 | NSM 3A G 13.800 | 3 |
| 255241 | 17WCE-GT2 18.000 | 2 | 600042 | BFT 86G 13.800 | 6 | 608765 | NSM 3B G 13.800 | 3 |
| 255239 | 17WCE-ST 18.000 | 3 | 600016 | BFTG4DSG 13.800 | 4 | 608764 | NSM B1 G 13.800 | 2 |
| 263758 | 18BURNIPS U613.800 | 6 | 605024 | BIGFALL8 69.000 | 1 | 699852 | NSP 14-1 13.800 | 1 |
| 263757 | 18BURNIPS U813.800 | 8 | 620315 | BIGSTN1G 24.000 | 1 | 699385 | OK C G5 18.000 | H |
| 256360 | 18CMPBL1 16.000 | A | 693932 | BIRON HY G3 0.4800 | H3 | 699386 | OK C G6 18.000 | H |
| 256339 | 18CMPBL2 20.000 | 2 | 693822 | BIRON PM G5 13.200 | 5 | 699387 | OK C G7 18.000 | H |
| 256343 | 18CMPBL3 18.000 | 3 | 693933 | BIRON ST 2.4000 | H1 | 699388 | OK C G8 18.000 | 8 |
| 256376 | 18CMPBLP 13.800 | A | 693819 | BIRON ST G1 13.200 | 1 | 699111 | OLQ HG1 2.3000 | 1 |
| 256370 | 18COBB1 14.400 | 1 | 693820 | BIRON ST G3 2.4000 | 3 | 699112 | OLQ HG2 2.3000 | 2 |
| 256369 | 18COBB2 14.400 | 2 | 693821 | BIRON ST G4 4.1600 | 4 | 256468 | OTTAWA1G C4.1600 | 1 |
| 256371 | 18COBB3 14.400 | 3 | 605013 | BLEARTH8 69.000 | 1 | 256469 | OTTAWA2G C4.1600 | 2 |
| 256344 | 18COBB4 18.000 | 4 | 600012 | BLK D72G 13.800 | 2 | 629075 | OTTUMW1G 24.000 | 1 |
| 256345 | 18COBB5 18.000 | 5 | 600013 | BLK D73G 13.800 | 3 | 613230 | OWATNA 12.500 | 7 |
| 256365 | 18COVRT1 16.000 | G | 600014 | BLK D74G 18.000 | 4 | 698176 | PDS G1-4 4.1600 | 1 |
| 256366 | 18COVRT2 16.000 | G | 600011 | BLK D75G 18.000 | 5 | 698177 | PDS G5-8 4.1600 | 2 |
| 256367 | 18COVRT3 16.000 | G | 600022 | BLL 71G 13.800 | 1 | 638061 | PELLA W8 69.000 | 1 |
| 256357 | 18COVRT4 16.500 | S | 600023 | BLL 72G 13.800 | 2 | 259485 | PEOPLES 1C4.1600 | 1 |
| 256358 | 18COVRT5 16.500 | S | 600024 | BLL 73G 13.800 | 3 | 259486 | PEOPLES 2C4.1600 | 1 |
| 256359 | 18COVRT6 16.500 | S | 600025 | BLL 74G 13.800 | 4 | 693786 | PETENWEL HG 6.9000 | 1 |
| 256377 | 18FILRCT 13.800 | 1 | 600043 | BLL C75G 18.000 | 7 | 254811 | 16PETE 1 20.000 | 1 |
| 256379 | 18GAYL12 13.800 | 1 | 600044 | BLL C76G 18.000 | 8 | 254812 | 16PETE 2 22.000 | 2 |
| 256380 | 18GAYL34 13.800 | 3 | 608849 | BLNCHRD9 34.500 | 1 | 254813 | 16PETE 3 22.000 | 3 |

| | | | | | | | | |
|--------|--------------------|----|--------|--------------------|---|--------|-------------------|----|
| 263754 | 18GAYLORD U113.800 | 1 | 613050 | BLOOM PR 69.000 | 2 | 254814 | 16PETE 4 22.000 | 4 |
| 263755 | 18GAYLORD U213.800 | 2 | 613051 | BLOOM PR NE 69.000 | 6 | 693610 | PHB 14 13.800 | X |
| 263756 | 18GAYLORD U313.800 | 3 | 699969 | BLT G6 13.800 | 6 | 635801 | PHILL 1G 13.800 | 1 |
| 263760 | 18GD.HAVENG 13.800 | 2 | 699968 | BLT G7 13.800 | 7 | 635802 | PHILL 2G 13.800 | 2 |
| 263751 | 18HERSEY U1013.800 | 10 | 608774 | BOSWE43G 20.900 | 3 | 635803 | PHILL 3G 13.800 | 3 |
| 263750 | 18HERSEY U9 13.800 | 9 | 608776 | BOSWE71G 14.400 | 1 | 699108 | PIN HG 2.3000 | 1 |
| 256381 | 18HILMAN 13.800 | 1 | 608777 | BOSWE72G 14.400 | 2 | 699430 | PL PRG1 24.000 | 1 |
| 257522 | 18INDST7 13.800 | 7 | 608852 | BRAINRD9 34.500 | 1 | 699431 | PL PRG2 24.000 | 2 |
| 257523 | 18INDST8 13.800 | 8 | 259517 | BRENT RUN 1C4.1600 | 1 | 698497 | POB GT5 13.800 | 5 |
| 257524 | 18INDST9 13.800 | 9 | 259518 | BRENT RUN 2C0.4800 | 3 | 698763 | PORTAGE CT 12.500 | 1 |
| 257532 | 18JDYNG3 12.470 | 3 | 600080 | WPP93-MN 0.4800 | W | 608667 | POTLTCH7 115.00 | 4 |
| 257531 | 18JDYNG4 12.470 | 4 | 630038 | BRLGTN28 69.000 | 1 | 699453 | POWCTG11 18.000 | 1 |
| 257530 | 18JDYNG5 12.470 | 5 | 629071 | BURLIN1G 20.000 | 1 | 699455 | POWCTG12 18.000 | 1 |
| 257533 | 18JDYNG6 12.470 | 6 | 680300 | BVR DAM 69.000 | 1 | 699457 | POWCTG21 18.000 | 1 |
| 263761 | 18KALK GEN 13.800 | 1 | 629070 | BVRCH52G 20.000 | 2 | 699459 | POWCTG22 18.000 | 1 |
| 256382 | 18KALRIV 13.800 | 1 | 600053 | BYLSBY9G 12.500 | 1 | 699454 | POWSTG10 18.000 | 1 |
| 256361 | 18KARN1A 16.000 | A | 256466 | C&C GEN 1C4.1600 | 1 | 699458 | POWSTG20 18.000 | 1 |
| 256362 | 18KARN1B 16.000 | B | 259339 | C&C GEN 2C4.1600 | 2 | 629085 | PR CRK1G 34.500 | 1A |
| 256363 | 18KARN2A 16.000 | A | 256424 | CADCGEN C13.800 | 1 | 629066 | PR CRK4G 18.000 | 4 |
| 256364 | 18KARN2B 16.000 | B | 698611 | CAF G 2.3000 | 1 | 600003 | PR IS31G 20.000 | 1 |
| 256329 | 18KARN3 26.000 | 3 | 698330 | CAR G1 4.1600 | 1 | 600004 | PR IS32G 20.000 | 2 |
| 256330 | 18KARN4 26.000 | 4 | 625430 | CASCADE 161.00 | 1 | 657904 | PRAIRIE8 69.000 | 1 |
| 263765 | 18KLEBER HYD2.4000 | 1 | 680114 | CASHTO_8 69.000 | 1 | 631017 | PRAR CK7 115.00 | 3 |
| 256384 | 18LIVPK1 13.800 | 1 | 698708 | CATARACT 2.4000 | 1 | 613250 | PRESTON 69.000 | 4 |
| 256385 | 18LIVPK2 13.800 | 2 | 635023 | CBLUF33G 24.000 | 3 | 698776 | PRICKET 2.4000 | 1 |
| 256386 | 18LIVPK3 13.800 | 3 | 635024 | CBLUF4G 26.000 | 4 | 613290 | PRINPLNT 69.000 | 3 |
| 256387 | 18LIVPK4 13.800 | 4 | 699277 | CCD GT1 13.800 | 1 | 699403 | PRS GT1 13.800 | 1 |
| 257514 | 18LOWELL 138.00 | 1 | 699278 | CCD GT2 13.800 | 2 | 699404 | PRS GT2 13.800 | 2 |
| 256341 | 18LUDN34 20.000 | 3 | 699279 | CCD GT3 13.800 | 3 | 699405 | PRS GT3 13.800 | 3 |
| 256342 | 18LUDN56 20.000 | 5 | 699280 | CCD GT4 13.800 | 4 | 699406 | PRS GT4 13.800 | 4 |
| 256395 | 18MCVG10 13.800 | 0 | 636302 | CCITY S8 69.000 | 1 | 698770 | PSQI G5 13.800 | 5 |
| 256396 | 18MCVG11 13.800 | 1 | 605378 | CEDARFA8 69.000 | 1 | 698771 | PSQI G6 13.800 | 6 |
| 256397 | 18MCVG12 13.800 | 2 | 657749 | CENTER1G 22.000 | 1 | 698772 | PSQI G7 13.800 | 7 |
| 256398 | 18MCVG13 13.800 | 3 | 657748 | CENTER2G 20.000 | 1 | 698773 | PSQI G8 13.800 | 8 |
| 256399 | 18MCVG14 13.800 | 4 | 680328 | CENTRAL_G 69.000 | 1 | 698774 | PSQI G9 13.800 | 9 |
| 256388 | 18MCVG3 13.800 | 3 | 629083 | CGORDO1G 24.900 | 1 | 699434 | PT BHG1 19.000 | 1 |
| 256389 | 18MCVG4 13.800 | 4 | 699137 | CHA1 18 18.000 | 1 | 699435 | PT BHG2 19.000 | 2 |
| 256390 | 18MCVG5 13.800 | 5 | 699138 | CHA2 18 18.000 | 2 | 699597 | PUL G31 13.800 | 1 |
| 256391 | 18MCVG6 13.800 | 6 | 699139 | CHA3 18 18.000 | 3 | 699591 | PUL G5 14.000 | 5 |

| | | | | | | | | | | | | |
|--------|--------------|--------|---|--------|-----------------|----------|--------|--------|------------|---------|--------|---|
| 256392 | 18MCVG7 | 13.800 | 7 | 600091 | CHB341_2W | 0.4800 | W | 699595 | PUL G6 | 14.000 | 6 | |
| 256393 | 18MCVG8 | 13.800 | 8 | 605348 | CHPFALL1G | 8 | 69.000 | 1 | 699590 | PUL G7 | 13.800 | 7 |
| 256394 | 18MCVG9 | 13.800 | 9 | 605407 | CHPFALL2G | 8 | 69.000 | 1 | 699594 | PUL G8 | 16.000 | 8 |
| 256337 | 18MCVST1 | 22.000 | 1 | 699124 | CKH HG | 2.3000 | 1 | 699099 | PVY HG1 | 6.9000 | 1 | |
| 256578 | 18MCVST2 | 22.000 | 2 | 605565 | CLAMDAM9 | 34.500 | 1 | 699101 | PVY HG2 | 6.9000 | 2 | |
| 256400 | 18MICHP1 | 13.800 | 1 | 608668 | CLOQUET7 | 115.00 | 3 | 613300 | R.FALLS7 | 115.00 | 2 | |
| 256401 | 18MICHP2 | 13.800 | 2 | 259383 | CLYDE GEN | C4.1600 | 1 | 605172 | RAPIDAN8 | 69.000 | 1 | |
| 256338 | 18PALISD | 22.000 | 1 | 699152 | COL G1 | 22.000 | 1 | 613320 | REDWD FL | 69.000 | 1 | |
| 256403 | 18PLYMO1 | 13.800 | 1 | 699153 | COL G2 | 22.000 | 2 | 605181 | REDWING8 | 69.000 | 1 | |
| 256404 | 18PLYMO2 | 13.800 | 2 | 600064 | COLVILL G | 18.000 | 2 | 263836 | REO BUS A | 13.800 | 1C | |
| 256405 | 18PLYMO3 | 13.800 | 3 | 600063 | COLVILL1 G | 18.000 | 1 | 263837 | REO BUS B | 13.800 | 2C | |
| 256406 | 18PLYMO4 | 13.800 | 4 | 256476 | COOKE | 1H2.5000 | 1 | 603129 | RICH_VA7 | 115.00 | 1 | |
| 256407 | 18PLYMO5 | 13.800 | 5 | 603154 | CORNELL HYD7 | 115.00 | 1 | 699131 | RIV NG1 | 16.000 | ST | |
| 256408 | 18PLYMO6 | 13.800 | 6 | 636412 | CORVL12G | 13.800 | 1 | 699132 | RIV NG2 | 18.000 | C1 | |
| 256409 | 18PLYMO7 | 13.800 | 7 | 636413 | CORVL34G | 13.800 | 3 | 699133 | RIV NG3 | 18.000 | C2 | |
| 256411 | 18PLYMO8 | 13.800 | 8 | 661015 | COYOTE1G | 24.000 | 1 | 631189 | RIVER RUN5 | 161.00 | A | |
| 256410 | 18PLYMO9 | 13.800 | 9 | 629134 | CRESTN_9 | 34.500 | 3 | 600007 | RIVRS77G | 16.000 | 7 | |
| 257525 | 18PROJ1G | 13.800 | 1 | 256458 | CROTON | H7.5000 | 1 | 600070 | RIVRSIDEG9 | 718.000 | 9 | |
| 256351 | 18RENAS1 | 18.000 | 1 | 699624 | CUSTER CT1 | 13.800 | 1 | 600071 | RIVRSIDG10 | 718.000 | 10 | |
| 256352 | 18RENAS2 | 18.000 | 2 | 693679 | CYPRES DVAR | 34.500 | A | 636655 | RIVSID5G | 15.000 | 5 | |
| 256353 | 18RENAS3 | 18.000 | 3 | 605506 | DANBURY8 | 69.000 | 1 | 256457 | ROGERS | H7.2000 | 1 | |
| 256354 | 18RENAS4 | 18.000 | 4 | 638002 | DAYTON8 | 69.000 | G1 | 629017 | ROQ 13.2 | 13.200 | 2 | |
| 256412 | 18THTFD1 | 13.800 | 1 | 630290 | DBQ 8TH8 | 69.000 | 3 | 629055 | ROQ GT 9 | 13.800 | 1 | |
| 256413 | 18THTFD2 | 13.800 | 2 | 699993 | DE PERE | 18.000 | 1 | 699042 | ROR G3 | 13.800 | 3 | |
| 256414 | 18THTFD3 | 13.800 | 3 | 605527 | DELLS 8 | 69.000 | 1 | 699043 | ROR G5 | 13.800 | 5 | |
| 256415 | 18THTFD4 | 13.800 | 4 | 630337 | DERCREK8 | 69.000 | 1 | 699044 | ROR G6 | 13.800 | 6 | |
| 263764 | 18TOWER HYD | 2.4000 | 1 | 699718 | DETRDB | 4.1600 | 1 | 693771 | ROTHCH GEN | 13.800 | 1 | |
| 263752 | 18TOWER U4 | 13.200 | 4 | 699714 | DFTR13 | 2.4000 | 1 | 635791 | RVHLS12G | 13.200 | 1 | |
| 263753 | 18VESTABURGG | 13.800 | 1 | 699715 | DFTR45 | 4.1600 | 1 | 635792 | RVHLS34G | 13.200 | 3 | |
| 256383 | 18VIKLNC | 13.800 | 1 | 693775 | DIESEL 4 CT | 12.470 | 4 | 635793 | RVHLS56G | 13.200 | 5 | |
| 256355 | 18WEDCK7 | 18.000 | 7 | 658064 | DLFRONTST7 | 115.00 | 1 | 635794 | RVHLS78G | 13.200 | 7 | |
| 256356 | 18WEDCK8 | 18.000 | 8 | 608844 | DOGLAKE9 | 34.500 | 1 | 629141 | SANDSPR9 | 34.500 | 4 | |
| 256418 | 18WEDCKP | 13.800 | A | 605534 | DOUGHTY8 | 69.000 | 1 | 693649 | SANDSTON | 6.9000 | 1 | |
| 256372 | 18WHITN1 | 14.400 | 1 | 693815 | DU BAY HG | 4.1600 | H1 | 256481 | SANFORD | H2.4000 | 1 | |
| 256373 | 18WHITN2 | 14.400 | 2 | 256484 | EDENVIL | H2.3000 | 1 | 658074 | SARATOG7 | 115.00 | 1 | |
| 256368 | 18WHITN3 | 15.500 | 3 | 699207 | EDG G4 | 22.000 | 4 | 605551 | SAXONFL9 | 34.500 | 1 | |
| 263305 | 18ZEELANDG | 69.000 | 1 | 699208 | EDG G5 | 22.000 | 5 | 636760 | SB P 8 | 69.000 | 4 | |
| 256346 | 18ZELND1 | 18.000 | A | 636222 | ELFARMG1 | 13.200 | 1 | 608763 | SBAYP 1G | 13.800 | 1 | |

| | | | | | | | | | | | |
|--------|------------|--------|----|--------|---------------|----------|----|--------|-------------|---------|----|
| 256347 | 18ZELND2 | 18.000 | B | 636223 | ELFARMG2 | 13.200 | 2 | 608766 | SBAYP 2G | 13.800 | 2 |
| 256348 | 18ZELND3 | 18.000 | A | 636224 | ELFARMG3 | 13.200 | 3 | 259381 | SCENIC VW | C4.1600 | 1 |
| 256349 | 18ZELND4 | 18.000 | B | 680516 | ELKMDGEN | 13.800 | 1 | 635839 | SE124THG | 13.200 | 1 |
| 256350 | 18ZELND5 | 18.000 | C | 699389 | ELM ROAD G1 | 25.000 | 1 | 699866 | SEC CT1 | 18.000 | 1 |
| 264853 | 19ANITA | 41.570 | 1 | 699390 | ELM ROAD G2 | 25.000 | 2 | 699867 | SEC CT2 | 18.000 | 2 |
| 264856 | 19BLRP2 | 26.000 | 2 | 693788 | ELM STRET PP1 | 2.000 | GT | 256482 | SECORD | H2.4000 | 1 |
| 264513 | 19BYRON | 41.570 | 1 | 680120 | ELROY MN | 69.000 | 1 | 699190 | SFL G1 | 13.800 | 1 |
| 264875 | 19CC15 | 15.500 | 5 | 629067 | EMERYGT1 | 18.000 | 1 | 699191 | SFL G2 | 13.800 | 2 |
| 264876 | 19CC16 | 15.500 | 6 | 629068 | EMERYGT2 | 18.000 | 1 | 699192 | SFL G3 | 13.800 | 3 |
| 264500 | 19COLFX | 41.570 | 11 | 629069 | EMERYST1 | 18.000 | 1 | 699193 | SFL G4 | 13.800 | 4 |
| 264501 | 19DIGIA | 41.570 | 1 | 263834 | ERIC GEN | 18.000 | 1 | 605250 | SHAKOPE8 | 69.000 | 1 |
| 264854 | 19ENFPP | 22.000 | 1 | 698721 | ESC STM | 12.500 | 1 | 635050 | SHENAND8 | 69.000 | 3 |
| 265145 | 19ENFPP2 | 120.00 | 11 | 699737 | ESHDR1 | 4.1600 | 1 | 693772 | SHIRAS PT5A | 12.470 | 1 |
| 264504 | 19ESSEX | 24.000 | 11 | 699738 | ESHDR2 | 4.1600 | 1 | 693773 | SHIRAS PT5B | 13.800 | 3 |
| 264758 | 19GRNECP | 345.00 | P1 | 699739 | ESHDR3 | 4.1600 | 1 | 256420 | SHOCKLEY | C13.800 | 1 |
| 264505 | 19HANCK | 41.570 | 11 | 699740 | ESHDR4 | 4.1600 | 1 | 630674 | SIBLEY | 69.000 | 3 |
| 264570 | 19HANCK1 | 120.00 | 12 | 608723 | ETCO G | 13.800 | 1 | 625440 | SILVER L | 161.00 | 1 |
| 264506 | 19HURHY | 41.570 | 1 | 613080 | FAIRMONT | 69.000 | 1 | 605081 | SLPY MU8 | 69.000 | 1 |
| 265073 | 19J025 | 120.00 | 1 | 605086 | FARFXNU8 | 69.000 | 1 | 256485 | SMALLWOOD | H2.3000 | 1 |
| 264878 | 19JUDD1 | 13.800 | 1 | 699822 | FCH 14-1 | 13.800 | 1 | 620285 | SOLWAY 7 | 115.00 | 1 |
| 264879 | 19JUDD2 | 13.800 | 1 | 699823 | FCH 14-2 | 13.800 | 2 | 613390 | SPRING V | 69.000 | 2 |
| 264880 | 19JUDD3 | 13.800 | 1 | 693600 | FEM14-3 | 13.800 | X | 698109 | SPU G1 | 13.800 | 1 |
| 264881 | 19JUDD4 | 13.800 | 1 | 600038 | FEN 83G | 13.800 | 3 | 605394 | ST CROIG | 161.00 | 1 |
| 264871 | 19MON1 | 26.000 | 1 | 600039 | FEN 84G | 13.800 | 4 | 613401 | ST PETERBWY | 13.800 | 1 |
| 264759 | 19MON12P | 345.00 | 11 | 680408 | FENNIM_8 | 69.000 | 1 | 693817 | ST POINT G1 | 4.1600 | 1 |
| 264872 | 19MON2 | 26.000 | 2 | 600050 | FEP CT G | 18.000 | 1 | 693816 | ST POINT HG | 2.4000 | HY |
| 264873 | 19MON3 | 26.000 | 3 | 600125 | FEP ST G | 13.800 | 2 | 603035 | STCLOUD7 | 115.00 | 1 |
| 264874 | 19MON4 | 26.000 | 4 | 256483 | FIVE CHAN | H2.4000 | 1 | 605075 | STJ EAS8 | 69.000 | 1 |
| 264625 | 19NEAST | 120.00 | 12 | 680334 | FLAMBEAU | 69.000 | 1 | 680001 | STONE | 69.000 | 1 |
| 264507 | 19NEAST | 24.000 | 11 | 605465 | FLAMSTN9 | 34.500 | 1 | 254845 | 16STOUT5 | 13.800 | 5 |
| 264508 | 19OLIVR | 41.570 | 11 | 608666 | FONDULAC | 115.00 | 1 | 254846 | 16STOUT6 | 13.800 | 6 |
| 264509 | 19PLACD | 41.570 | 12 | 256461 | FOOTE | 3H4.8000 | 1 | 254847 | 16STOUT7 | 22.000 | 7 |
| 264510 | 19PUTNM | 41.570 | 11 | 680303 | FOREST C | 69.000 | 1 | 254851 | 16STOCT | 13.800 | 1G |
| 264640 | 19REMER1 | 120.00 | 11 | 699557 | FOXENCT1 | 18.000 | 1 | 254854 | 16STOCT4 | 13.800 | 4G |
| 264702 | 19RESOURCE | 120.00 | 1 | 699558 | FOXENCT2 | 18.000 | 1 | 254855 | 16STOCT5 | 13.800 | 5G |
| 264986 | 19RR11 | 120.00 | 11 | 699559 | FOXENST1 | 18.000 | 1 | 254856 | 16STOCT6 | 18.000 | 6G |
| 264866 | 19RRG2 | 18.000 | 2 | 629046 | FOXLK53G | 13.800 | 3 | 600040 | STP COIG | 13.800 | 1 |
| 264867 | 19RRG3 | 18.000 | 3 | 629051 | FOXLKG19 | 13.800 | 1 | 256426 | STRAITS | P13.800 | 1 |
| 264862 | 19SC1 | 15.500 | 1 | 605500 | FREDRICG | 34.500 | 1 | 638036 | STRTR P8 | 69.000 | 6 |

| | | | | | | | | |
|--------|--------------------|----|--------|------------------------|----|--------|--------------------|----|
| 264756 | 19SC123P 120.00 | 11 | 259463 | FREMONTGEN C0.4800 | 1 | 605552 | SUPERFL9 34.500 | 1 |
| 264861 | 19SC2 15.500 | 2 | 605317 | FRENCH G 69.000 | 1 | 699835 | SYC 14-1 13.800 | 1 |
| 264860 | 19SC3 15.500 | 3 | 635691 | GDMECGT1 18.000 | 1 | 699836 | SYC 14-2 13.800 | 2 |
| 264859 | 19SC4 15.500 | 4 | 635692 | GDMECGT2 18.000 | 2 | 635708 | SYCAMRG1 13.800 | 1 |
| 264857 | 19SC7 18.000 | 7 | 635693 | GDMECST3 18.000 | 3 | 635709 | SYCAMRG2 13.800 | 2 |
| 265165 | 19SIGEL 34.500 | W1 | 638091 | GENESE08 69.000 | 8 | 699844 | SYN14-1 13.800 | X |
| 264511 | 19SLOCM 24.000 | 11 | 681522 | GENOA53G 24.000 | 3 | 605391 | T BEARTG 69.000 | 1 |
| 264512 | 19SUPER 41.570 | 11 | 254801 | 16GEORG1 13.800 | 1G | 608693 | TAC HBRG1 13.200 | 1 |
| 264868 | 19TC8 15.500 | 8 | 254802 | 16GEORG2 13.800 | 2G | 608901 | TAC HBRG2 13.200 | 2 |
| 264870 | 19TC9 22.000 | 9 | 254803 | 16GEORG3 13.800 | 3G | 608902 | TAC HBRG3 13.200 | 3 |
| 264796 | 19WALTZ 41.570 | 1 | 254804 | 16GEORG4 13.800 | 4G | 608800 | TACRIDG9 34.500 | 1 |
| 264846 | 19WAYER 41.570 | 1 | 699323 | GER GT1 13.800 | 1 | 698961 | THILMANY 12.500 | 1 |
| 264514 | 19WILMT 41.570 | 11 | 699324 | GER GT2 13.800 | 2 | 608665 | THOMSON7 115.00 | 6 |
| 264985 | 19WTRMN5 120.00 | P | 699325 | GER GT3 13.800 | 3 | 680545 | TIMBERLINE_G69.000 | 1 |
| 349993 | 1ALSEY G1-2 13.800 | 1 | 699326 | GER GT4 13.800 | 4 | 256456 | TIPPY H7.5000 | 1 |
| 349994 | 1ALSEY G3-G413.800 | 3 | 699322 | GER GT5 13.800 | 5 | 630813 | TIPTONM8 69.000 | 1 |
| 349995 | 1ALSEY G5 13.800 | 5 | 698724 | GLADSTN 12.500 | 1 | 693628 | TKY14-2 13.800 | X |
| 344061 | 1AUDRN G1 13.800 | 1 | 661100 | GLNDCT1G 13.800 | 1 | 693557 | TOMAHAWK HG 2.3000 | 1 |
| 344062 | 1AUDRN G2 13.800 | 2 | 661101 | GLNDCT2G 13.800 | 2 | 629132 | TRAER 9 34.500 | 6 |
| 344063 | 1AUDRN G3 13.800 | 3 | 629110 | GR JCT 9 34.500 | 2 | 698070 | TUR G4 13.800 | 4 |
| 344064 | 1AUDRN G4 13.800 | 4 | 693896 | GR RAPD1 2.4000 | 1 | 638033 | UNI GEN8 69.000 | 9 |
| 344065 | 1AUDRN G5 13.800 | 5 | 693899 | GR RAPD2 2.4000 | 4 | 263819 | UNIT1 13.200 | 1 |
| 344066 | 1AUDRN G6 13.800 | 6 | 613090 | GRAND MA 69.000 | 1 | 263820 | UNIT2 13.200 | 1 |
| 344067 | 1AUDRN G7 13.800 | 7 | 256467 | GRANDBL G C4.1600 | 1 | 263821 | UNIT3 13.200 | 1 |
| 344068 | 1AUDRN G8 13.800 | 8 | 259442 | GRANDBL N C4.1600 | 1 | 263822 | UNIT4 13.200 | 1 |
| 349126 | 1BALDWIN G1 20.000 | 1 | 259340 | GRANGER 2C14.400 | 1 | 263823 | UNIT5 13.200 | 1 |
| 349127 | 1BALDWIN G2 18.000 | 2 | 256423 | GRAYLING C13.800 | 1 | 263824 | UNIT6 13.200 | 1 |
| 349128 | 1BALDWIN G3 24.000 | 3 | 615091 | GRE- ARROWHDG13.800 | 1 | 699514 | UNIV GT 13.800 | 1 |
| 344225 | 1CAL G1 25.000 | 1 | 615051 | GRE- CAMBRDG869.000 | 1 | 699515 | UNIV ST 13.800 | 2 |
| 343018 | 1CEC 1 13.800 | 1 | 615052 | GRE-CGS 82G16.000 | 1 | 699747 | USHDRO 4.1600 | 3A |
| 343019 | 1CEC 2 13.800 | 3 | 615001 | GRE-COAL 41G22.000 | 1 | 699745 | USHYDO 13.800 | 1 |
| 349101 | 1CLINTON G1 22.000 | 1 | 615002 | GRE-COAL 42G22.000 | 2 | 699748 | USHYDO 4.1600 | 10 |
| 346896 | 1COFFEN 1 22.000 | 1 | 615020 | GRE-ELK RIV869.000 | 1 | 699506 | VALLYG1 13.800 | 1 |
| 346897 | 1COFFEN 2 24.000 | 2 | 619903 | GRE-ELKRNT869.000 | 1 | 699507 | VALLYG2 13.800 | 2 |
| 340579 | 1COLEMAN1 18.000 | 1 | 619900 | GRE-ELKRWS1869.000 | 1 | 256473 | VENICE C4.1600 | 2 |
| 340580 | 1COLEMAN2 18.000 | 2 | 259341 | GREENMDW C0.4800 | 1 | 256474 | VENICE W 1C4.1600 | 1 |
| 340581 | 1COLEMAN3 18.000 | 3 | 615065 | GRE- HASTNGSG69.000 | 1 | 256470 | VENICE W 2C4.1600 | 0 |

| | | | | | | | | |
|--------|--------------------|----|--------|--------------------|---|--------|--------------------|---|
| 343549 | 1DALMAN 31 13.200 | 1 | 615066 | GRE-LAKEMARG69.000 | 1 | 698807 | VIC 1 11 11.500 | 1 |
| 343550 | 1DALMAN 32 13.200 | 2 | 615041 | GRE-LGS 31G13.800 | 1 | 698808 | VIC A 11 11.500 | 1 |
| 343551 | 1DALMAN 33 19.000 | 3 | 615042 | GRE-LGS 32G13.800 | 2 | 259423 | VIENNA C4.1600 | 1 |
| 343552 | 1DALMAN 41 18.000 | 4 | 615043 | GRE-LGS 33G13.800 | 3 | 256425 | VIKNG MCB C13.800 | 1 |
| 349633 | 1DCK GEN1 22.000 | 1 | 615044 | GRE-LGS 34G13.800 | 4 | 630895 | VINTON MUNI869.000 | 1 |
| 349630 | 1EDE GEN1 16.500 | 1 | 615045 | GRE-LGS 35G13.800 | 5 | 680102 | VIOLA_8 69.000 | 1 |
| 349631 | 1EDE GEN2 20.000 | 1 | 615046 | GRE-LGS 36G13.800 | 6 | 698790 | WARDEN 1 13.800 | 1 |
| 349632 | 1EDE GEN3 22.000 | 1 | 615070 | GRE-MAPLE 1G69.000 | 1 | 693594 | WAUSAU HG 4.1600 | 1 |
| 343555 | 1FACTORY CT 13.200 | 1 | 619925 | GRE-MOOSELK869.000 | 1 | 638082 | WAVRLYS8 69.000 | 2 |
| 347112 | 1GIBSN G1 13.800 | 1 | 619926 | GRE-MOSEMN869.000 | 1 | 699022 | WAY HG1 4.1600 | 1 |
| 347113 | 1GIBSN G2 13.800 | 2 | 615031 | GRE-PVS 51G16.000 | 1 | 699180 | WCCF CT1 13.800 | 1 |
| 345998 | 1GOSCK 1 13.800 | 1 | 615032 | GRE-PVS 52G16.000 | 2 | 699181 | WCCF CT2 13.800 | 1 |
| 345999 | 1GOSCK 2 13.800 | 2 | 615033 | GRE-PVS 53G13.800 | 3 | 699182 | WCCF STM 13.800 | 1 |
| 346000 | 1GOSCK 3 13.800 | 3 | 615080 | GRE-ROCKLK1G69.000 | 1 | 256459 | WEBBER 1H7.2000 | 1 |
| 346001 | 1GOSCK 4 13.800 | 4 | 615060 | GRE-ST BONI869.000 | 1 | 256480 | WEBBER 2H2.5000 | 2 |
| 346002 | 1GOSCK 5 13.800 | 5 | 615010 | GRE-STANT41G18.000 | 1 | 613410 | WELLS 69.000 | 1 |
| 346003 | 1GOSCK 6 13.800 | 6 | 693784 | GRFTHR F G1 6.9000 | 1 | 699824 | WEM 34 13.800 | 1 |
| 340572 | 1GREEN 1 21.000 | 1 | 693785 | GRFTHR F G2 6.9000 | 2 | 699655 | WEM G31 13.800 | 1 |
| 340573 | 1GREEN 2 21.000 | 2 | 605053 | GRNFLCY8 69.000 | 1 | 699660 | WEM G32 13.800 | 2 |
| 347170 | 1GRTW 1 18.000 | 1 | 630399 | GRNL CT8 69.000 | 1 | 699661 | WEM G33 13.800 | 3 |
| 347171 | 1GRTW 2 18.000 | 2 | 600126 | GRNT CTY 1G 13.800 | 1 | 699679 | WES G1 13.800 | 1 |
| 347168 | 1GRTW 3 13.800 | 3 | 600127 | GRNT CTY 2G 13.800 | 3 | 699680 | WES G2 13.800 | 2 |
| 347169 | 1GRTW 4 13.800 | 4 | 605514 | GRNTS NG 69.000 | 1 | 699678 | WES G3 22.000 | 3 |
| 349121 | 1HAVANA G6 20.000 | 6 | 638032 | GT SUB 8 69.000 | 1 | 699682 | WES G31 13.800 | Y |
| 349106 | 1HENNEPIN G113.800 | 1 | 630266 | HAHN 8 69.000 | 1 | 699681 | WES G32 13.800 | X |
| 349107 | 1HENNEPIN G215.500 | H | 629084 | HANCWIND 25.000 | 1 | 699662 | WES G4 19.000 | 4 |
| 340577 | 1HMP&L 1 18.000 | 3 | 256455 | HARDY H7.5000 | 1 | 630506 | WEST LIB 69.000 | 1 |
| 340578 | 1HMP&L 2 18.000 | 4 | 605264 | HASTING8 69.000 | 1 | 630063 | WESTBKM8 69.000 | 1 |
| 347229 | 1HOLLANDU1 18.000 | 1 | 605308 | HATFLD 8 69.000 | 1 | 693625 | WGA14-1 13.800 | X |
| 347230 | 1HOLLANDU2 18.000 | 2 | 605435 | HAYWAR G 69.000 | 1 | 605431 | WHITE G 69.000 | 1 |
| 347231 | 1HOLLANDU3 18.000 | 3 | 699024 | HEM HG1 4.1600 | 1 | 258546 | WHITEFTHR C4.1600 | 1 |
| 343553 | 1INTSTA CT 13.800 | 1 | 600128 | HERC G 13.800 | 1 | 256419 | WHITING P13.800 | A |
| 344860 | 1KEOK 7 13.800 | 7 | 661044 | HESKET1G 13.800 | 1 | 698556 | WHR HG 2.3000 | 1 |
| 344863 | 1KEOK 10 13.800 | 10 | 661045 | HESKET2G 13.800 | 2 | 600032 | WHT 51G 13.800 | 1 |
| 344864 | 1KEOK 12 13.800 | 12 | 608676 | HIBBARD7 115.00 | 3 | 600033 | WHT 52G 13.800 | 2 |
| 344861 | 1KEOK 1-4 13.800 | 1 | 608729 | HIBBTACG 13.800 | 1 | 600034 | WHT 53G 13.800 | 3 |
| 344862 | 1KEOK 5-6 13.800 | 5 | 693593 | HIGH FLS HG 2.3000 | 1 | 600035 | WHT 54G 13.800 | 4 |

| | | | | | | | | |
|--------|------------------|---|--------|------------------------|----|--------|------------------------|----|
| 344876 | 1KNMDY G1 13.800 | 1 | 693606 | HKP 14-2 13.800 | X | 600036 | WHT 55G 13.800 | 5 |
| 344877 | 1KNMDY G2 13.800 | 2 | 256460 | HODENPYL H7.2000 | 1 | 600037 | WHT 56G 13.800 | 6 |
| 344894 | 1LAB G1 20.000 | 1 | 698733 | HOIST 2.4000 | H2 | 605012 | WILMART8 69.000 | 1 |
| 344895 | 1LAB G2 20.000 | 2 | 600129 | HOLCOMB G 6.9000 | 1 | 608861 | WINTON 9 46.000 | 1 |
| 344896 | 1LAB G3 20.000 | 3 | 620223 | HOOT LK7 115.00 | 4 | 693936 | WIS RVR 2.4000 | 1 |
| 344897 | 1LAB G4 20.000 | 4 | 620323 | HOOTLK2G 13.800 | 2 | 605349 | WISSOTAG 69.000 | 1 |
| 349751 | 1MEDINA1 13.800 | 1 | 620324 | HOOTLK3G 13.800 | 3 | 699830 | WMD14-9 13.800 | X |
| 349752 | 1MEDINA2 13.800 | 3 | 693818 | HOT POND G2 13.800 | 1 | 619990 | WMU-WILMR E869.000 | 5 |
| 345132 | 1MER 1 16.500 | 1 | 619954 | HUC- HUTCHK869.000 | 1 | 619985 | WMU- WILMRMN869.000 | 1 |
| 345140 | 1MER 2 16.500 | 2 | 619953 | HUC- HUTCHPT869.000 | 2 | 619986 | WMU- WILMRSW869.000 | 4 |
| 345148 | 1MER 3 16.000 | H | 603139 | HURLEY 7 115.00 | 1 | 698798 | WPINE M 13.800 | 1 |
| 345156 | 1MER 4 18.000 | H | 693779 | HYDRO MBLP 7.8000 | H1 | 693935 | WR HYDRO 2.4000 | H1 |
| 345164 | 1MER 5 13.800 | 5 | 629144 | IA JCT 2 34.500 | 1 | 693623 | WTN14-1 13.800 | X |
| 345172 | 1MER 6 13.800 | 6 | 625420 | IBM 161.00 | 1 | 259447 | ZACHARY C4.1600 | 1 |
| 350231 | 1MRNGEN1 13.800 | 1 | 608757 | IMTRA-2G 2.3000 | 1 | 259374 | ZEELNDFRM C4.1600 | 1 |
| 350232 | 1MRNGEN2 13.800 | 2 | 638076 | INDMUNI8 69.000 | 1 | 625425 | ZUMBRO R 161.00 | 1 |

Table B-3: MISO NR Sink Generators for TDF Analysis – J412 (MEC)

| Bus # | Bus Name | ID | Bus # | Bus Name | ID | Bus # | Bus Name | ID |
|--------|-------------------|----|--------|-----------------|----|--------|-----------------|----|
| 635020 | ATCHSNW1 0.6900 | W | 635792 | RVHLS34G 13.200 | 3 | 636412 | CORVL12G 13.800 | 1 |
| 635023 | CBLUF33G 24.000 | 3 | 635792 | RVHLS34G 13.200 | 3 | 636413 | CORVL34G 13.800 | 3 |
| 635024 | CBLUF4G 26.000 | 4 | 635793 | RVHLS56G 13.200 | 5 | 636413 | CORVL34G 13.800 | 3 |
| 635050 | SHENAND8 69.000 | 3 | 635793 | RVHLS56G 13.200 | 5 | 636641 | LOUIS31G 24.000 | 1 |
| 635059 | ADAMS W1 0.6000 | W | 635794 | RVHLS78G 13.200 | 7 | 636655 | RIVSID5G 15.000 | 5 |
| 635102 | RLHILLSW0 0.6900 | W | 635794 | RVHLS78G 13.200 | 7 | 636760 | SB P 8 69.000 | 4 |
| 635213 | NEAL 3G 22.000 | 3 | 635801 | PHILL 1G 13.800 | 1 | 636761 | MOLIN12G 13.800 | 1 |
| 635214 | NEAL 4G 24.000 | 4 | 635802 | PHILL 2G 13.800 | 2 | 636761 | MOLIN12G 13.800 | 1 |
| 635215 | IDA GRV W1 0.6900 | W | 635803 | PHILL 3G 13.800 | 3 | 636762 | MOLIN34G 13.800 | 3 |
| 635216 | IDA GRV W2 0.6900 | W | 635822 | 29 HUBB8 69.000 | 1 | 636762 | MOLIN34G 13.800 | 3 |
| 635216 | IDA GRV W2 0.6900 | W | 635839 | SE124THG 13.200 | 1 | 638001 | AMES 8 69.000 | 7 |
| 635414 | OBRIEN W1 0.6900 | W | 635839 | SE124THG 13.200 | 1 | 638001 | AMES 8 69.000 | 7 |
| 635415 | OBRIEN W2 0.6900 | W | 635853 | KNOXIND8 69.000 | 4 | 638002 | DAYTON8 69.000 | G1 |
| 635648 | DEY415 W 0.6000 | W | 636035 | POCHNTG3 0.5750 | W | 638002 | DAYTON8 69.000 | G1 |
| 635691 | GDMECGT1 18.000 | 1 | 636203 | LUNDQST5 161.00 | 2 | 638032 | GT SUB 8 69.000 | 1 |
| 635692 | GDMECGT2 18.000 | 2 | 636222 | ELFARMG1 13.200 | 1 | 638032 | GT SUB 8 69.000 | 1 |
| 635693 | GDMECST3 18.000 | 3 | 636223 | ELFARMG2 13.200 | 2 | 638033 | UNI GEN8 69.000 | 9 |
| 635708 | SYCAMRG1 13.800 | 1 | 636224 | ELFARMG3 13.200 | 3 | 638036 | STRTR P8 69.000 | 6 |
| 635709 | SYCAMRG2 13.800 | 2 | 636302 | CCITY S8 69.000 | 1 | 638036 | STRTR P8 69.000 | 6 |
| 635791 | RVHLS12G 13.200 | 1 | 636302 | CCITY S8 69.000 | 1 | 638061 | PELLA W8 69.000 | 1 |
| 635791 | RVHLS12G 13.200 | 1 | 636412 | CORVL12G 13.800 | 1 | 638091 | GENESE08 69.000 | 8 |

Table B-4: MISO NR Sink Generators for TDF Analysis – J442 (OTP)

| Bus # | Bus Name | ID | Bus # | Bus Name | ID | Bus # | Bus Name | ID |
|--------|--------------------|----|--------|--------------------|----|--------|-------------------|----|
| 615132 | G619TAMW 0.6000 | W | 620223 | HOOT LK7 115.00 | 4 | 657748 | CENTER2G 20.000 | 1 |
| 620101 | G736 CRN RD10.6000 | W | 620285 | SOLWAY 7 115.00 | 1 | 657749 | CENTER1G 22.000 | 1 |
| 620115 | HRDLKGEN 0.6000 | 1 | 620315 | BIGSTN1G 24.000 | 1 | 657904 | PRAIRIE8 69.000 | 1 |
| 620115 | HRDLKGEN 0.6000 | 1 | 620857 | LKPRSTN9 41.600 | 1 | 657964 | ASH2GEN9 0.5750 | 1 |
| 620115 | HRDLKGEN 0.6000 | 1 | 657601 | L2GEN 9 0.5750 | 1 | 657985 | ASH1GEN9 0.5750 | 1 |
| 620115 | HRDLKGEN 0.6000 | 1 | 657705 | DRAYTON7 115.00 | X | 658064 | DLFRONTST7 115.00 | 1 |
| 620115 | HRDLKGEN 0.6000 | 1 | 657737 | ASH3GEN9 0.6900 | 1 | 658098 | BENSONM7 115.00 | 1 |
| 620172 | JAMESPK9 41.600 | 1 | 657745 | MPC02100GEN90.6900 | 1 | 661015 | COYOTE1G 24.000 | 1 |
| 620172 | JAMESPK9 41.600 | 1 | | | | | | |

Appendix C: NRIS Thermal Results

Table C-1: NRIS Thermal Constraints

| Case | Monitored Facility | Rating | Areas Name | Bench Case Final %Loading | Study Case Final %Loading | Cont Event Facility | J442 |
|-----------|------------------------------------------|--------|------------|---------------------------|---------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | | 200 MW |
| 00NR-18SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 99.9 | 108.76 | [XEL] 601031 BRKNGCO3 345 601077 HAWKSNEST 3 345 1 | 12.48% |
| 00NR-18SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 101.71 | 110.65 | [XEL] 601048 LYON CO 3 345 601077 HAWKSNEST 3 345 1 | 12.48% |
| 00NR-21SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 92.69 | 100.48 | [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z | 10.11% |
| 00NR-21SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 92.95 | 100.56 | [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z [WAPA/NPPD] 640510 HOLT.CO3 345 653871 GR ISLD-LNX3 345 1 | 10.11% |
| 00NR-21SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 92.96 | 100.57 | [WAPA/NPPD] 640510 HOLT.CO3 345 653871 GR ISLD-LNX3 345 1 | 10.11% |
| 00NR-21SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 93.47 | 101.05 | [NPPD] 640200 GR ISLD4 230 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 643071 GR ISLD T6 9 13.8 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 [NPPD] 640200 GR ISLD4 230 997427 GI KU1B 230 2 [NPPD] 653316 GR ISL29 13.8 997427 GI KU1B 230 2 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 640200 GR ISLD4 230 997428 GI KU1A 230 1 | 10.11% |

| | | | | | | | |
|-----------|---------------------------------------------|-------|----------|-------|--------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | [NPPD] 653314 GR ISL19 13.8 997428 GI KU1A 230 1 [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD- LNX3 345 Z | |
| 00NR-21SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 93.47 | 101.05 | [NPPD]653571 GR ISLD3 345 [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD- LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | 10.11% |
| 00NR-21SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 93.47 | 101.05 | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD- LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 | 10.11% |

| | | | | | | | | |
|-----------|-----------------------|----------------|-------|----------|-------|--------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | | [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| 00NR-21SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.47 | 101.05 | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD- LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | 10.11% |
| 00NR-21SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.47 | 101.05 | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD- LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | 10.11% |
| 00NR-21SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.47 | 101.05 | [NPPD]653571 GR ISLD3 345 [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD- LNX3 345 Z | 10.11% |

| | | | | | | | | |
|-----------|-----------------------------------------|-------|----------|-------|--------|--|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | | [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| 00NR-21SP | 601006 SPLT RK3 345 1 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.47 | 101.05 | | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | 10.11% |
| 00NR-21SP | 601006 SPLT RK3 345 1 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.47 | 101.05 | | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | 10.11% |
| 00NR-21SP | 601006 SPLT RK3 345 1 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.47 | 101.05 | | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 | 10.11% |

| | | | | | | | | | |
|-----------|-----------------------|----------------|-------|----------|-------|--------|--|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | | | <p>[NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z</p> <p>[NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3</p> <p>[NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1</p> <p>[NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2</p> | |
| 00NR-21SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.47 | 101.05 | | <p>[NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z</p> <p>[NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3</p> <p>[NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1</p> <p>[NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2</p> | 10.11% |
| 00NR-21SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.47 | 101.05 | | <p>[NPPD]653571 GR ISLD3 345</p> <p>[NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z</p> <p>[NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3</p> <p>[NPPD] 653571 GR ISLD3 345 997428 GI KU1A</p> | 10.11% |

| | | | | | | | | | |
|-----------|--------------------------|--------------------|-------|----------|--------|--|--------|-------------------------------------------------------------|--------|
| | | | | | | | | 230 1 | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| 00NR-21SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 103.43 | | 112.13 | [XEL] 601031 BRKNGCO3 345 601077 HAWKSNEST 3 345 1 | 12.37% |
| 00NR-21SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 105.23 | | 114.03 | [XEL] 601048 LYON CO 3 345 601077 HAWKSNEST 3 345 1 | 12.37% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 92.13 | | 100 | [XEL] 601001 FORBES 2 500 601017 CHIS-N 2 500 1 | 10.07% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 92.63 | | 100.05 | [WAPA] 652530 WATERTN4 230 652582 APPLEDORN 4 230 1 | 10.30% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 92.7 | | 100.09 | [XEL/MGE] 601044 BRIGGS RD 3 345 694098 NMA B5 345 345 1 | 10.24% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 92.84 | | 100.15 | [WAPA] 652509 FTRANDL4 230 652526 UTICAJC4 230 1 | 10.15% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 92.6 | | 100.15 | [XEL] 615529 GRE-PANTHER4 230 619940 HUC- MCLEOD 4 230 1 | 10.48% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 92.41 | | 100.28 | [OTP] 620314 BIGSTON4 230 620325 BROWNSV4 230 1 | 11.84% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 92.88 | | 100.28 | [WAPA] 652509 FTRANDL4 230 652516 LAKPLAT4 230 1 | 10.17% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.69 | | 100.4 | [XEL] 601002 ADAMS 3 345 615306 GRE-PL VLLY3 345 1 | 10.22% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.08 | | 100.47 | [WAPA] 652507 FTTHOMP4 230 652516 LAKPLAT4 230 1 | 10.17% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.19 | | 100.48 | [NPPD] 640139 COOPER 3 345 640009 COOPER1G 22.0 1 | 10.25% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.19 | | 100.48 | [NPPD] 640139 COOPER 3 345 640009 COOPER1G 22.0 1 | 10.25% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.1 | | 100.49 | [WAPA] 652507 FTTHOMP4 230 652509 FTRANDL4 230 1 | 10.16% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.05 | | 100.52 | [OTP] 620329 WAHPETN4 230 658109 FERGSFL4 230 1 | 10.46% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.21 | | 100.56 | [XEL] 601039 NROC 3 345 601044 BRIGGS RD 3 345 1 | 10.25% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.31 | | 100.61 | [WAPA] 659105 LELANDO3 345 659424 LELAND2- LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.31 | | 100.61 | [WAPA] 659105 LELANDO3 345 659424 LELAND2- LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.09 | | 100.63 | [XEL] 602009 MNVLTAP4 230 615529 GRE- PANTHER4 230 1 | 10.49% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 92.73 | | 100.63 | [OTP/WAPA] 620314 BIGSTON4 230 652503 BLAIR 4 230 1 | 11.58% |

| | | | | | | | | |
|-----------|--------------------------|--------------------|-------|----------|-------|--------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.11 | 100.68 | [XEL] 602008 MINVALT4 230 602009 MNVLTAP4 230 1 [XEL] 602009 MNVLTAP4 230 615529 GRE- PANTHER4 230 1 [XEL/WAPA] 602009 MNVLTAP4 230 652550 GRANITF4 230 1 | 10.50% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.17 | 100.71 | [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2- LNX3 345 Z | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.17 | 100.71 | [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2- LNX3 345 Z | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.17 | 100.72 | [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2- LNX3 345 Z [WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1 | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.17 | 100.72 | [WAPA] 652273 FTTHMP19 13.8 997456 FT2 KU1A 230 1 [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2- LNX3 345 Z [WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1 | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.17 | 100.72 | [WAPA] 652274 FTTHMP29 13.8 997455 FT2 KU1B 230 1 [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2- LNX3 345 Z [WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1 | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.73 | [WAPA] 652273 FTTHMP19 13.8 997456 FT2 KU1A 230 1 [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1- LNX3 345 Z [WAPA] 652806 FTTHOM1-LNX3 345 659424 LELAND2-LNX3 345 1 [WAPA] 659105 LELANDO3 345 659424 LELAND2- LNX3 345 Z | 9.63% |

| | | | | | | | | |
|-----------|--------------------------|--------------------|-------|----------|-------|--------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------|
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.73 | [WAPA] 652273 FTTHMP19 13.8 997456 FT2 KU1A 230 1 [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1- LNX3 345 Z [WAPA] 652806 FTTHOM1-LNX3 345 659424 LELAND2-LNX3 345 1 [WAPA] 659105 LELANDO3 345 659424 LELAND2- LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.73 | [WAPA] 652274 FTTHMP29 13.8 997455 FT2 KU1B 230 1 [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1- LNX3 345 Z [WAPA] 652806 FTTHOM1-LNX3 345 659424 LELAND2-LNX3 345 1 [WAPA] 659105 LELANDO3 345 659424 LELAND2- LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.73 | [WAPA] 652273 FTTHMP19 13.8 997456 FT2 KU1A 230 1 [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1- LNX3 345 Z [WAPA] 652806 FTTHOM1-LNX3 345 659424 LELAND2-LNX3 345 1 [WAPA] 659105 LELANDO3 345 659424 LELAND2- LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.73 | [WAPA] 652274 FTTHMP29 13.8 997455 FT2 KU1B 230 1 [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1- LNX3 345 Z [WAPA] 652806 FTTHOM1-LNX3 345 659424 LELAND2-LNX3 345 1 [WAPA] 659105 LELANDO3 345 659424 LELAND2- LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.73 | [WAPA] 652274 FTTHMP29 13.8 997455 FT2 KU1B 230 1 | 9.63% |

| | | | | | | | | | |
|-----------|-----------------------|------------------------------------|-------|----------|-------|--------|--|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | | | [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1-LNX3 345 Z [WAPA] 652806 FTTHOM1-LNX3 345 659424 LELAND2-LNX3 345 1 [WAPA] 659105 LELANDO3 345 659424 LELAND2-LNX3 345 Z | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 601006 SPLT RK3 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.73 | | [WAPA] 652806 FTTHOM1-LNX3 345 659424 LELAND2-LNX3 345 1 [WAPA] 659105 LELANDO3 345 659424 LELAND2-LNX3 345 Z [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1-LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 601006 SPLT RK3 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.73 | | [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1-LNX3 345 Z [WAPA] 652806 FTTHOM1-LNX3 345 659424 LELAND2-LNX3 345 1 [WAPA] 659105 LELANDO3 345 659424 LELAND2-LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 601006 SPLT RK3 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.16 | 100.73 | | [WAPA] 652532 GR PRAIRIE 3 345 652833 GRPRAR2-LNX3 345 Z [WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1 [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2-LNX3 345 Z | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 601006 SPLT RK3 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.38 | 100.73 | | [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1-LNX3 345 Z [WAPA] 652806 FTTHOM1-LNX3 345 659424 LELAND2-LNX3 345 1 | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 601006 SPLT RK3 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.74 | | [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1-LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 601006 SPLT RK3 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.74 | | [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1-LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 601006 SPLT RK3 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.74 | | [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1-LNX3 345 Z | 9.63% |

| | | | | | | | | |
|-----------|--------------------------|--------------------|-------|----------|-------|--------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.74 | [WAPA] 652506 FTTHOMP3 345 652806 FTTHOM1-LNX3 345 Z | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.17 | 100.75 | [WAPA] 652532 GR PRAIRIE 3 345 652833 GRPRAR2-LNX3 345 Z | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.52 | 100.77 | [MEC] 635000 CBLUFFS3 345 635023 CBLUF33G 24.0 1 | 10.25% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.5 | 100.86 | [WAPA] 652806 FTTHOM1-LNX3 345 659424 LELAND2-LNX3 345 1 | 9.63% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.29 | 100.89 | [WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1 | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.52 | 100.92 | [XEL] 603013 PIPESTN7 115 603016 SPLT RK7 115 1 | 10.37% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.39 | 100.94 | [WAPA] 652474 AURORA 7 115 652505 FLANDRU7 115 1 | 10.56% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.62 | 101.01 | [MP/WPS] 608615 ARROWHD4 230 699448 AWHDPST 230 1 | 10.19% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.83 | 101.08 | [MEC] 635000 CBLUFFS3 345 635024 CBLUF4G 26.0 1 | 10.25% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.6 | 101.11 | [XEL/ALTW] 601002 ADAMS 3 345 631144 MITCHLCO3 345 1 | 10.23% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.85 | 101.26 | [WAPA] 652504 BROOKNG7 115 652538 WHITE 7 115 1 | 10.47% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.75 | 101.29 | [XEL/ALTE] 601028 EAU CL 3 345 694003 ARPIN B4 345 1 | 10.23% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.96 | 101.37 | [XEL/WAPA] 601031 BRKNGCO3 345 652537 WHITE 3 345 2 [WAPA] 652537 WHITE 3 345 997443 WHT KU1A 115 1 [WAPA] 652538 WHITE 7 115 997443 WHT KU1A 115 1 [WAPA] 652293 WHITE 9 13.8 997443 WHT KU1A 115 1 | 10.46% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.96 | 101.37 | [XEL/WAPA] 601031 BRKNGCO3 345 652537 WHITE 3 345 1 [WAPA] 652537 WHITE 3 345 997443 WHT KU1A 115 1 [WAPA] 652538 WHITE 7 115 997443 WHT KU1A 115 1 | 10.46% |

| | | | | | | | | | |
|-----------|-----------------------|----------------|-------|----------|-------|--------|--|-----------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | | | [WAPA] 652293 WHITE 9 13.8 997443 WHT KU1A 115 1 | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.99 | 101.4 | | [WAPA] 652537 WHITE 3 345 997443 WHT KU1A 115 1 [WAPA] 652538 WHITE 7 115 997443 WHT KU1A 115 1 [WAPA] 652293 WHITE 9 13.8 997443 WHT KU1A 115 1 | 10.47% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.05 | 101.41 | | [WAPA] 652523 SIOUXFL4 230 652606 LETCHER4 230 1 | 10.05% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.22 | 101.51 | | [XEL] 600020 ANS 72G 13.8 997966 ANS 1 13.8 2 [XEL] 603200 ANSON 7 115 997966 ANS 1 13.8 2 [XEL] 600021 ANS 73G 13.8 997966 ANS 1 13.8 2 | 10.25% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.22 | 101.51 | | [XEL] 603016 SPLT RK7 115 603200 ANSON 7 115 1 | 10.25% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.94 | 101.69 | | [OTP] 620314 BIGSTON4 230 997788 230/115_8 115 1 [OTP] 620214 BIGSTON7 115 997788 230/115_8 115 1 [OTP] 620316 BIGSTON9 13.8 997788 230/115_8 115 1 | 11.10% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 93.93 | 101.7 | | [XEL] 603134 BUFFRID7 115 603191 YANKEE 7 115 1 | 10.84% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.29 | 101.75 | | [XEL] 603180 CHANRMB7 115 603195 FENTON 7 115 1 | 10.42% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.07 | 101.78 | | [WAPA] 652503 BLAIR 4 230 652550 GRANITF4 230 1 | 10.96% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.31 | 101.89 | | [XEL] 601048 LYON CO 3 345 615643 GRE-CEDARMT3 345 1 | 10.54% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.33 | 101.92 | | [XEL] 601048 LYON CO 3 345 615643 GRE-CEDARMT3 345 2 | 10.54% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.47 | 102.03 | | [WAPA] 652474 AURORA 7 115 652504 BROOKNG7 115 1 | 10.56% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.75 | 102.03 | | [XEL] 603264 PROSE WIND7 115 603265 PROSE CAP7 115 1 | 10.25% |

| | | | | | | | | | |
|-----------|--------------------------|--------------------|-------|----------|-------|--------|-------------------------------------------|-----------------------|--------|
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.75 | 102.03 | [XEL] 603016 SPLT RK7 115 1 | 115 603265 PROSE CAP7 | 10.25% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.09 | 102.25 | [MEC] 635200 RAUN 3 22.0 1 | 345 635213 NEAL 3G | 10.25% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.08 | 102.45 | [XEL] 601014 AS KING3 345 1 | 345 601028 EAU CL 3 | 10.23% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.21 | 102.51 | [WAPA] 652529 WATERTN3 KU1A 230 1 | 345 997446 WT2 | 9.99% |
| | | | | | | | [WAPA] 652530 WATERTN4 KU1A 230 1 | 230 997446 WT2 | |
| | | | | | | | [WAPA] 652237 WATERT19 230 1 | 13.8 997446 WT2 KU1A | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.13 | 102.54 | [WAPA] 652607 WESSINGTON 4 4 230 1 | 230 659122 STORLA | 10.10% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.93 | 102.6 | [XEL] 601050 HELENA 3 CEDARMT3 345 1 | 345 615643 GRE- | 10.64% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.95 | 102.63 | [XEL] 601050 HELENA 3 CEDARMT3 345 2 | 345 615643 GRE- | 10.64% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.26 | 102.64 | [WAPA] 652507 FTTHOMP4 LETCHER4 230 1 | 230 652606 | 10.02% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.24 | 102.66 | [WAPA] 652513 HANLON 4 230 1 | 230 652523 SIOUXFL4 | 10.00% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 94.92 | 102.77 | [ALTW] 631139 HAZLTON3 MITCHLCO3 345 1 | 345 631144 | 10.23% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.45 | 103.05 | [WAPA] 652506 FTTHOMP3 230 1 | 345 997456 FT2 KU1A | 9.59% |
| | | | | | | | [WAPA] 652507 FTTHOMP4 230 1 | 230 997456 FT2 KU1A | |
| | | | | | | | [WAPA] 652273 FTTHMP19 230 1 | 13.8 997456 FT2 KU1A | |
| | | | | | | | [WAPA] 652506 FTTHOMP3 230 1 | 345 997455 FT2 KU1B | |
| | | | | | | | [WAPA] 652507 FTTHOMP4 230 1 | 230 997455 FT2 KU1B | |
| | | | | | | | [WAPA] 652274 FTTHMP29 230 1 | 13.8 997455 FT2 KU1B | |
| | | | | | | | [WAPA] 652506 FTTHOMP3 345 1 | 345 652806 FTTHOM1- | |

| | | | | | | | | |
|-----------|-----------------------|----------------|-------|----------|-------|-------|----------------------------------------------------------|--------|
| | | | | | | | LNX3 345 Z | |
| | | | | | | | [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2-LNX3 345 Z | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.92 | 103.1 | [MEC] 635200 RAUN 3 345 635214 NEAL 4G 24.0 1 | 10.25% |
| | | | | | | | [WAPA] 652273 FTTHMP19 13.8 997456 FT2 KU1A 230 1 | |
| | | | | | | | [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2-LNX3 345 Z | |
| | | | | | | | [WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1 | |
| | | | | | | | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.9 | 103.5 | [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 | 10.11% |
| | | | | | | | [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z | |
| | | | | | | | [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 | |
| | | | | | | | [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 | |
| | | | | | | | [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| | | | | | | | [WAPA] 652274 FTTHMP29 13.8 997455 FT2 KU1B 230 1 | |
| | | | | | | | [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2-LNX3 345 Z | |
| | | | | | | | [WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1 | |
| | | | | | | | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.9 | 103.5 | [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 | 10.11% |

| | | | | | | | | | |
|-----------|-----------------------|----------------|-------|----------|------|-------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.9 | 103.5 | [WAPA] 652273 FTTHMP19 13.8 997456 FT2 KU1A 230 1 [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2-LNX3 345 Z [WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1 [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | 10.11% | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.9 | 103.5 | [WAPA] 652273 FTTHMP19 13.8 997456 FT2 KU1A 230 1 [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2-LNX3 345 Z [WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1 | 10.11% | |

| | | | | | | | | | |
|-----------|-----------------------|--------------------|-------|----------|------|-------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| | | | | | | | | <p>[NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z</p> <p>[NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3</p> <p>[NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1</p> <p>[NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2</p> | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.9 | 103.5 | <p>[WAPA] 652274 FTTHMP29 13.8 997455 FT2 KU1B 230 1</p> <p>[WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2-LNX3 345 Z</p> <p>[WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1</p> <p>[NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z</p> <p>[NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3</p> <p>[NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1</p> <p>[NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2</p> | 10.11% | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 95.9 | 103.5 | [WAPA] 652274 FTTHMP29 13.8 997455 FT2 KU1B 230 1 | 10.11% | |

| | | | | | | | | | |
|-----------|------------------------------------------|-------|----------|-------|--------|------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| | | | | | | | | [WAPA] 652506 FTTHOMP3 345 652807 FTTHOM2-LNX3 345 Z [WAPA] 652807 FTTHOM2-LNX3 345 652833 GRPRAR2-LNX3 345 1 [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| 00NR-26SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 96.07 | 104.14 | [OTP] 620327 HANKSON4 230 620329 WAHPETN4 230 1 | 12.08% | | |
| 00NR-26SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 97.01 | 104.44 | [WAPA] 652513 HANLON 4 230 659122 STORLA 4 230 1 [WAPA] 652607 WESSINGTON 4 230 659122 STORLA 4 230 1 [WAPA] 659122 STORLA 4 230 997389 KV1A_2 115 1 | 10.01% | | |
| 00NR-26SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 97.23 | 104.61 | [WAPA] 652513 HANLON 4 230 659122 STORLA 4 230 1 | 10.00% | | |
| 00NR-26SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 98.3 | 106.71 | [WAPA] 652532 GR PRAIRIE 3 345 652832 GRPRAR1-LNX3 345 Z | 10.11% | | |
| 00NR-26SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 98.3 | 106.71 | [WAPA] 652532 GR PRAIRIE 3 345 652832 GRPRAR1-LNX3 345 Z [WAPA] 640510 HOLT.CO3 345 652832 GRPRAR1-LNX3 345 1 | 10.11% | | |
| 00NR-26SP | 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 717.1 | XEL/WAPA | 98.3 | 106.71 | [WAPA] 652532 GR PRAIRIE 3 345 652832 GRPRAR1-LNX3 345 Z | 10.11% | | |

| | | | | | | | | | |
|-----------|-----------------------|--------------------|-------|----------|--------|--------|--|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | | | [WAPA] 640510 HOLT.CO3 345 652832 GRPRAR1-LNX3 345 1 | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 98.16 | 106.77 | | [WAPA] 640510 HOLT.CO3 345 652832 GRPRAR1-LNX3 345 1 | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 101.66 | 110.15 | | [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 101.77 | 110.15 | | [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 101.79 | 110.16 | | [WAPA/NPPD] 640510 HOLT.CO3 345 653871 GR ISLD-LNX3 345 1 | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | | [NPPD]653571 GR ISLD3 345 [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | | [NPPD]653571 GR ISLD3 345 [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A | 10.11% |

| | | | | | | | | |
|-----------|-----------------------|----------------|-------|----------|--------|--------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | | 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD- LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | [NPPD]653571 GR ISLD3 345 [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD- LNX3 345 Z [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 | 10.11% |

| | | | | | | | | | |
|-----------|-----------------------|----------------|-------|----------|--------|--------|--|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | | | <p>[NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z</p> <p>[NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3</p> <p>[NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1</p> <p>[NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2</p> | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | | <p>[NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z</p> <p>[NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3</p> <p>[NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1</p> <p>[NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2</p> | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | | <p>[NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1</p> <p>[NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z</p> <p>[NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3</p> <p>[NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1</p> | 10.11% |

| | | | | | | | | |
|-----------|-----------------------|--------------------|-------|----------|--------|--------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--------|
| | | | | | | | [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | [NPPD] 640200 GR ISLD4 230 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 [NPPD] 643071 GR ISLD T6 9 13.8 997692 GI KU3A 230 3 [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 [NPPD] 640200 GR ISLD4 230 997427 GI KU1B 230 2 [NPPD] 653316 GR ISL29 13.8 997427 GI KU1B 230 2 [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 [NPPD] 640200 GR ISLD4 230 997428 GI KU1A 230 1 [NPPD] 653314 GR ISL19 13.8 997428 GI KU1A 230 1 [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD- LNX3 345 Z | 10.11% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 345 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 [NPPD] 653571 GR ISLD3 345 653871 GR ISLD- LNX3 345 Z | 10.11% |

| | | | | | | | | | |
|-----------|-----------------------|----------------|-------|----------|--------|--------|--|------------------------------------------------------|--------|
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 | 10.11% |
| | | | | | | | | [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 102.34 | 110.76 | | [NPPD] 640271 MCCOOL 3 345 653571 GR ISLD3 345 1 | 10.11% |
| | | | | | | | | [NPPD] 640374 SWEET W3 345 653571 GR ISLD3 345 1 | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 653871 GR ISLD-LNX3 345 Z | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 997692 GI KU3A 230 3 | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 997428 GI KU1A 230 1 | |
| | | | | | | | | [NPPD] 653571 GR ISLD3 345 997427 GI KU1B 230 2 | |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 113.93 | 123.68 | | [XEL] 601031 BRKNGCO3 HAWKSNEST 3 345 1 | 12.37% |
| 00NR-26SP | 601006 SPLT RK3 345 1 | 652537 WHITE 3 | 717.1 | XEL/WAPA | 115.6 | 125.71 | | [XEL] 601048 LYON CO 3 345 1 | 12.37% |

| | | | | | | | |
|-----------|-----------------------------------------------|------|----------|--------|--------|------------------------------------------------------------------------------------------------------------|-------|
| 00NR-18SP | 602008 MINVALT4 230 652550 GRANITF4 230 1 | 259 | XEL/WAPA | 107.57 | 117.94 | [XEL/WAPA] 602009 MNVLTAP4 230 652550 GRANITF4 230 1 | 4.01% |
| 00NR-21SP | 602008 MINVALT4 230 652550 GRANITF4 230 1 | 259 | XEL/WAPA | 117.12 | 128.07 | [XEL/WAPA] 602009 MNVLTAP4 230 652550 GRANITF4 230 1 | 3.77% |
| 00NR-26SP | 602008 MINVALT4 230 652550 GRANITF4 230 1 | 259 | XEL/WAPA | 110.67 | 119.56 | [XEL/WAPA] 602009 MNVLTAP4 230 652550 GRANITF4 230 1 | 3.77% |
| 00NR-18SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 83.26 | 106.72 | [XEL/OTP] 601031 BRKNGCO3 345 620417 BSSOUTH3 345 1 | 6.36% |
| 00NR-21SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 87.22 | 105.52 | [OTP] 620327 HANKSON4 230 620329 WAHPETN4 230 1 | 5.56% |
| 00NR-21SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 87.35 | 108.37 | [OTP/WAPA] 620314 BIGSTON4 230 652503 BLAIR 4 230 1 | 5.96% |
| 00NR-21SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 96.75 | 120.4 | [XEL/OTP] 601031 BRKNGCO3 345 620417 BSSOUTH3 345 1 | 6.32% |
| 00NR-26SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 84.65 | 101.24 | [OTP] 620329 WAHPETN4 230 658109 FERGSFL4 230 1 | 4.70% |
| 00NR-26SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 84.94 | 101.63 | [XEL/WAPA] 601006 SPLT RK3 345 652537 WHITE 3 345 1 | 4.74% |
| 00NR-26SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 84.94 | 101.63 | [XEL/WAPA] 601006 SPLT RK3 345 652537 WHITE 3 345 1 [XEL/WAPA] 601031 BRKNGCO3 345 652537 WHITE 3 345 1 | 4.74% |
| 00NR-26SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 85.26 | 101.85 | [XEL] 601031 BRKNGCO3 345 601077 HAWKSNEST 3 345 1 | 4.70% |
| 00NR-26SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 86.4 | 102.78 | [XEL] 601048 LYON CO 3 345 601077 HAWKSNEST 3 345 1 | 4.70% |
| 00NR-26SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 87.21 | 105.2 | [WAPA] 652503 BLAIR 4 230 652550 GRANITF4 230 1 | 4.95% |
| 00NR-26SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 94 | 112.56 | [OTP] 620327 HANKSON4 230 620329 WAHPETN4 230 1 | 5.56% |
| 00NR-26SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 91.76 | 113.68 | [OTP/WAPA] 620314 BIGSTON4 230 652503 BLAIR 4 230 1 | 5.96% |
| 00NR-26SP | 616002 GRE-JOHNJCT7 115 652555 MORRIS 7 115 1 | 92.2 | OTP/WAPA | 96.57 | 120.86 | [XEL/OTP] 601031 BRKNGCO3 345 620417 BSSOUTH3 345 1 | 6.32% |