

GENERATOR INTERCONNECTION AFFECTED SYSTEM IMPACT STUDY REPORT

ASGI-2016-011 ASGI-2016-012 ASGI-2016-013

Published June 2017

By SPP Generator Interconnections Dept.

REVISION HISTORY

Date	Author	Change Description				
06/30/2017	SPP	Affected System Impact Study for ASGI-2016-011, ASGI-2016-012, & ASGI-2016-013 Report Revision 0 Issued				

EXECUTIVE SUMMARY

An Affected System Interconnection Customer has requested an Affected System Impact Study (ASIS) consistent with Southwest Power Pool (SPP) Open Access Transmission Tariff (OATT) for interconnection requests into the system of Peoples Electric Cooperative (PEC). The PEC facilities connect with the facilities of Southwestern Power Administration (SWPA) and Western Farmers Electric Cooperative (WFEC). This report will detail the results from the three Group 14 requests in this study: ASGI-2016-011, ASGI-2016-012, & ASGI-2016-013. All three requests are thermal units totaling 7.4, 61.7, and 4.9 MW, respectively.

This ASIS addresses the effects of the proposed generators on the SPP transmission system based on the system topology and requests included in the SPP DISIS-2016-001 study:

- ASGI-2016-011 requested the interconnection of three (3) Caterpillar G3520H Gas Engines and associated facilities interconnecting to the PEC distribution system served from the PEC Gerty substation, which connects to SWPA facilities at the Allen 138 kV tap.
- ASGI-2016-012 requested the interconnection of twenty-five (25) Caterpillar G3520H Gas Engines and associated facilities interconnecting to the PEC distribution system served from the PEC Centrahoma substation, which connects to SWPA facilities at the Tupelo 138 kV substation.
- ASGI-2016-013 requested the interconnection of two (2) Caterpillar G3520H Gas Engines and associated facilities interconnecting to the PEC distribution system served from the PEC Ashland 138 kV substation on the WFEC 138 kV line between Coalgate and Pittsburgh.

Power flow and stability analysis from this ASIS has determined that ASGI-2016-011, ASGI-2016-012, & ASGI-2016-013 can interconnect all of their respective generation (mentioned above) with Energy Resource Interconnection Service (ERIS) prior to the completion of the required Network Upgrades listed within **Table 2** of this report. It should be noted that although this ASIS analyzed many of the more-probable contingencies, it is not an all-inclusive list that can account for every operational situation. Additionally, the generator may not be able to inject any power onto the Transmission System due to constraints that fall below the threshold of mitigation for a Generator Interconnection request. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to **0 MW** under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Transient stability analysis for this ASIS has determined that no issues were observed for the transmission system for the forty-nine (49) selected faults for the interconnection of ASGI-2016-011, ASGI-2016-012, & ASGI-2016-013. As discussed above, this amount may be reduced further dependent upon system conditions.

Nothing in this study should be construed as a guarantee of delivery or transmission service. If the customer(s) wishes to move power across the facilities of SPP, a separate request for transmission service must be made on Southwest Power Pool's OASIS by the Customer(s).

TABLE OF CONTENTS

Revision Historyi
Executive Summary i
Table of Contentsii
Purpose1
Facilities
Generating Facilities
Power Flow Analysis
Model Preparation
Voltage7
Results
Curtailment and System Reliability8
Stability Analysis
Model Preparation
Short Circuit Analysis
Conclusion

PURPOSE

An Affected System Interconnection Customer has requested an Affected System Impact Study (ASIS) consistent with the SPP OATT for interconnection requests into the system of PEC. The PEC facilities connect with the facilities of SWPA and WFEC.

The purpose of this study is to evaluate the impacts of interconnecting the following generators on the SPP transmission system based on the system topology and requests included in the SPP DISIS-2016-001 study:

- ASGI-2016-011 requested the interconnection of three (3) Caterpillar G3520H Gas Engines and associated facilities interconnecting to the PEC distribution system served from the PEC Gerty substation, which connects to SWPA facilities at the Allen 138 kV tap.
- ASGI-2016-012 requested the interconnection of twenty-five (25) Caterpillar G3520H Gas Engines and associated facilities interconnecting to the PEC distribution system served from the PEC Centrahoma substation, which connects to SWPA facilities at the Tupelo 138 kV substation.
- ASGI-2016-013 requested the interconnection of two (2) Caterpillar G3520H Gas Engines and associated facilities interconnecting to the PEC distribution system served from the PEC Ashland 138 kV substation on the WFEC 138 kV line between Coalgate and Pittsburgh.

The Affected System Interconnection Customer(s) have requested these amounts to be studied with ERIS to commence on or around June 1, 2017.

The ASIS considers the Base Case as well as all Generating Facilities (and with respect to (b) below, any identified Network Upgrades associated with such higher queued interconnection) that, on the date the ASIS is commenced:

- a) are directly interconnected to the Transmission System;
- b) are interconnected to Affected Systems and may have an impact on the Interconnection Request;
- c) have a pending higher queued Interconnection Request to interconnect to the Transmission System listed in **Table 1**; or
- d) have no Queue Position but have executed an LGIA or requested that an unexecuted LGIA be filed with FERC.

Any changes to these assumptions, for example, one or more of the previously queued requests not included within this study execute an interconnection agreement and commencing commercial operation, may require a re-study of this ASIS at the expense of the Customer(s).

Nothing within this System Impact Study constitutes a request for transmission service or confers upon the Interconnection Customer(s) any right to receive transmission service rights. Should the Customer(s) require transmission service, those rights should be requested through SPP's Open Access Same-Time Information System (OASIS) or that of the applicable transmission provider.

This ASIS included prior queued generation interconnection requests. Those listed within **Table 1** are the generation interconnection requests that are assumed to have rights to either full or partial interconnection service prior to the requested in-service for this ASIS. Also listed in Table 1 are both the amount of MW of interconnection service expected at the effective time of this study and the total

Southwest Power Pool, Inc.

Project	MW	Total MW	Fuel Source	POI	Status
GEN-2015-036	303.6	303.6	Wind	Johnston County 345kV Substation	FACILITY STUDY STAGE
GEN-2016-028	100	100	Wind	Clayton 138 kV Sub	FACILITY STUDY STAGE
GEN-2016-030	100	100	Solar	Brown 138 kV	FACILITY STUDY STAGE
GEN-2016-063	200	200	Wind	Hugo-Sunnyside 345 kV	FACILITY STUDY STAGE
ASGI-2016-011	7.4	7.4	Thermal	Allen Tap 138 kV	Current Study
ASGI-2016-012	61.7	61.7	Thermal	Tupelo 138 kV	Current Study
ASGI-2016-013	4.9	4.9	Thermal	Ashland 138 kV	Current Study

Table 1: Generation Requests Included within ASIS

This ASIS was required because the Affected System Interconnection Customer(s) are requesting interconnection at a location electrically close to the SPP system.

Table 2 below lists the higher queued required upgrade projects for which these requests have cost responsibility. DISIS-2016-001 Group 14 Impact Study was posted February 28, 2017.

DISIS-2016-001 reports can be located at the following Generation Interconnection Study URL: <u>http://sppoasis.spp.org/documents/swpp/transmission/GenStudies.cfm?YearType=2016 Impact Studies</u>

ASGI-2016-011, ASGI-2016-012, & ASGI-2016-013 are included as prior queued to DISIS-2016-002 cluster and will be evaluated for impacts prior to the DISIS-2016-002 study.

Table 2: Upgrade Projects Required for Interconnection Service

Upgrade Project	Туре	Description	Status	Study Assignment
Currently, None				

Any changes to these assumptions may require a re-study of this ASIS at the expense of the Customer(s).

Nothing in this System Impact Study constitutes a request for transmission service or grants the Interconnection Customer(s) any rights to transmission service.

FACILITIES

GENERATING FACILITIES

ASGI-2016-011 requested the interconnection of three (3) Caterpillar G3520H Gas Engines and associated facilities interconnecting to the PEC distribution system served from the PEC Gerty substation, which connects to SWPA facilities at the Allen 138 kV tap in Hughes County, Oklahoma.

ASGI-2016-012 requested the interconnection of twenty-five (25) Caterpillar G3520H Gas Engines and associated facilities interconnecting to the PEC distribution system served from the PEC Centrahoma substation, which connects to SWPA facilities at the Tupelo 138 kV substation in Coal County, Oklahoma.

ASGI-2016-013 requested the interconnection of two (2) Caterpillar G3520H Gas Engines and associated facilities interconnecting to the PEC distribution system served from the PEC Ashland 138 kV substation on the 138 kV WFEC line between Coalgate and Pittsburgh, in Coal County, Oklahoma. Figures 1-3 depict the one-line diagram for the POI and the Interconnection Request(s).





Figure 2: Proposed ASGI-2016-012 Configuration and Request Power Flow Model





Figure 3: Proposed ASGI-2016-013 Configuration and Request Power Flow Model

BASE CASE NETWORK UPGRADES

The Network Upgrades included within the cases used for this Affected System Impact Study are those facilities that are a part of the SPP Transmission Expansion Plan or the Balanced Portfolio projects. These facilities have an approved Notification to Construct (NTC), or are in construction stages and expected to be in-service at the effective time of this study. No other upgrades were included for this ASIS. If for some reason, construction on these projects is delayed or discontinued, a restudy may be needed to determine the interconnection service availability of the Customer(s).

POWER FLOW ANALYSIS

Power flow analysis is used to determine if the transmission system can accommodate the injection from the request without violating thermal or voltage transmission planning criteria.

MODEL PREPARATION

Power flow analysis was performed using modified versions of the 2015 series of 2016 ITP Near-Term study models including these seasonal models:

- Year 1 (2016) Winter Peak (16WP)
- Year 2 (2017) Spring (17G)
- Year 2 (2017) Summer Peak (17SP)
- Year 5 (2020) Light (20L)
- Year 5 (2020) Summer (20SP)
- Year 5 (2020) Winter (20WP) peak
- Year 10 (2025) Summer (25SP) peak

To incorporate the Interconnection Customers' request, a re-dispatch of existing generation within SPP was performed with respect to the amount of the Customers' injection.

For Variable Energy Resources (VER) (solar/wind) in each power flow case, ERIS, is evaluated for the generating plants within a geographical area of the interconnection request(s) for the VERs dispatched at 100% nameplate of maximum generation. The VERs in the remote areas is dispatched at 20% nameplate of maximum generation. SPP projects are dispatched across the SPP footprint using load factor ratios. MISO projects are dispatched across the SPP footprint using load factor ratios.

Peaking units are not dispatched in the Year 2 spring and Year 5 light, or in the "High VER" summer and winter peaks. To study peaking units' impacts, the Year 1 winter peak, Year 2 summer peak, and Year 5 summer and winter peaks, and Year 10 summer peak models are developed with peaking units dispatched at 100% of the nameplate rating and VERs dispatched at 20% of the nameplate rating. Each interconnection request is also modeled separately at 100% nameplate for certain analyses.

All generators (VER and peaking) that requested Network Resource Interconnection Service (NRIS) are dispatched in an additional analysis into the interconnecting Transmission Owner's (T.O.) area at 100% nameplate with Energy Resource Interconnection Service (ERIS) only requests at 80% nameplate. This method allows for identification of network constraints that are common between regional groupings to have affecting requests share the mitigating upgrade costs throughout the cluster.

For this ASIS, only the previous queued requests listed in **Table 1** were assumed to be in-service at 100% dispatch.

STUDY METHODOLOGY AND CRITERIA

THERMAL OVERLOADS

Network constraints are found by using PSS/E AC Contingency Calculation (ACCC) analysis with PSS/E MUST First Contingency Incremental Transfer Capability (FCITC) analysis on the entire cluster grouping dispatched at the various levels previously mentioned.

For Energy Resource Interconnection Service (ERIS), thermal overloads are determined for system intact (n-0) (greater than or equal to 100% of Rate A - normal) and for contingency (n-1) (greater than or equal to 100% of Rate B – emergency) conditions.

The overloads are then screened to determine which of generator interconnection requests have at least

- 3% Distribution Factor (DF) for system intact conditions (n-0),
- 20% DF upon outage based conditions (n-1),
- or 3% DF on contingent elements that resulted in a non-converged solution.

Interconnection Requests that requested Network Resource Interconnection Service (NRIS) are also studied in a separate NRIS analysis to determine if any constraint measured greater than or equal to a 3% DF. If so, these constraints are also considered for transmission reinforcement under NRIS.

The contingency set includes all SPP control area branches and ties 69kV and above, first tier Non-SPP control area branches and ties 115 kV and above, any defined contingencies for these control areas, and generation unit outages for the SPP control areas with SPP reserve share program redispatch.

The monitored elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier Non-SPP control area branches and ties 69 kV and above. NERC Power Transfer Distribution Flowgates for SPP and first tier Non-SPP control area are monitored. Additional NERC Flowgates are monitored in second tier or greater Non-SPP control areas. Voltage monitoring was performed for SPP control area buses 69 kV and above.

VOLTAGE

For non-converged power flow solutions that are determined to be caused by lack of voltage support, appropriate transmission support will be determined to mitigate the constraint.

After all thermal overload and voltage support mitigations are determined; a full ACCC analysis is then performed to determine voltage constraints. The following voltage performance guidelines are used in accordance with the Transmission Owner local planning criteria.

Transmission Owner	Voltage Criteria	Voltage Criteria
	(System Intact)	(Contingency)
AEPW	0.95 – 1.05 pu	0.92 – 1.05 pu
GRDA	0.95 – 1.05 pu	0.90 – 1.05 pu
SWPA	0.95 – 1.05 pu	0.90 – 1.05 pu
OKGE	0.95 – 1.05 pu	0.90 – 1.05 pu
OMPA	0.95 – 1.05 pu	0.90 – 1.05 pu
WFEC	0.95 – 1.05 pu	0.90 – 1.05 pu
SWPS	0.95 – 1.05 pu	0.90 – 1.05 pu
MIDW	0.95 – 1.05 pu	0.90 – 1.05 pu
SUNC	0.95 – 1.05 pu	0.90 – 1.05 pu
KCPL	0.95 – 1.05 pu	0.90 – 1.05 pu
INDN	0.95 – 1.05 pu	0.90 – 1.05 pu
SPRM	0.95 – 1.05 pu	0.90 – 1.05 pu
NPPD	0.95 – 1.05 pu	0.90 – 1.05 pu
WAPA	0.95 – 1.05 pu	0.90 – 1.05 pu
WERE L-V	0.95 – 1.05 pu	0.93 – 1.05 pu
WERE H-V	0.95 – 1.05 pu	0.95 – 1.05 pu
EMDE L-V	0.95 – 1.05 pu	0.90 – 1.05 pu
EMDE H-V	0.95 – 1.05 pu	0.92 – 1.05 pu
LES	0.95 – 1.05 pu	0.90 – 1.05 pu
OPPD	0.95 – 1.05 pu	0.90 – 1.05 pu

<u>SPP Areas (69kV+):</u>

SPP Buses with more stringent voltage criteria:

Bus Name/Number	Voltage Criteria (System Intact)	Voltage Criteria (Contingency)
TUCO 230kV 525830	0.925 – 1.05 pu	0.925 – 1.05 pu
Wolf Creek 345kV 532797	0.985 – 1.03 pu	0.985 – 1.03 pu
FCS 646251	1.001 – 1.047 pu	1.001 – 1.047 pu

Affected System Areas (115kV+):

Transmission Owner	Voltage Criteria (System Intact)	Voltage Criteria (Contingency)
AECI	0.95 – 1.05 pu	0.90 – 1.05 pu

Transmission Owner	Voltage Criteria (System Intact)	Voltage Criteria (Contingency)
EES-EAI	0.95 – 1.05 pu	0.90 – 1.05 pu
LAGN	0.95 – 1.05 pu	0.90 – 1.05 pu
EES	0.95 – 1.05 pu	0.90 – 1.05 pu
AMMO	0.95 – 1.05 pu	0.90 – 1.05 pu
CLEC	0.95 – 1.05 pu	0.90 – 1.05 pu
LAFA	0.95 – 1.05 pu	0.90 – 1.05 pu
LEPA	0.95 – 1.05 pu	0.90 – 1.05 pu
XEL	0.95 – 1.05 pu	0.90 – 1.05 pu
MP	0.95 – 1.05 pu	0.90 – 1.05 pu
SMMPA	0.95 – 1.05 pu	0.90 – 1.05 pu
GRE	0.95 – 1.05 pu	0.90 – 1.10 pu
OTP	0.95 – 1.05 pu	0.90 – 1.05 pu
OTP-H (115kV+)	0.97 – 1.05 pu	0.92 – 1.10 pu
ALTW	0.95 – 1.05 pu	0.90 – 1.05 pu
MEC	0.95 – 1.05 pu	0.90 – 1.05 pu
MDU	0.95 – 1.05 pu	0.90 – 1.05 pu
SPC	0.95 – 1.05 pu	0.95 – 1.05 pu
DPC	0.95 – 1.05 pu	0.90 – 1.05 pu
ALTE	0.95 – 1.05 pu	0.90 – 1.05 pu

The constraints identified through the voltage scan are then screened for the following for each interconnection request. 1) 3% DF on the contingent element and 2) 2% change in pu voltage. In certain conditions, engineering judgement was used to determine whether or not a generator had impacts to voltage constraints.

RESULTS

The ASIS ACCC analysis indicates that the Affected System Interconnection Customer(s) can interconnect their generation at the available MW amount listed in the results tables before all required upgrades listed within the DISIS-2016-001 studies or latest iteration can be placed into service. ACCC results for the ASIS can be found in **Table 3**, **Table 4** and **Table 5**.

Table 3 and **Table 4** results are based on the study assumption of system conditions prior to the DISIS-2016-002 identified and assigned Network Upgrades.

Constraints listed in **Table 5** do not require additional transmission reinforcement for Interconnection Service, but could require Interconnection Customer to reduce generation in operational conditions. These transmission constraints occur when this study's generation is dispatched into the SPP footprint for Energy Resource Interconnection Service (ERIS).

CURTAILMENT AND SYSTEM RELIABILITY

In no way does this study guarantee operation for all periods of time. It should be noted that although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to **0 MW** under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Table 3: Thermal Constraints Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Max MW Available	Contingency
				Currently, None						

Table 4: Voltage Constraints Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Max MW Available	Contingency
				Currently, None						

Table 5: Constraints that do not require additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
				Currently, None					

STABILITY ANALYSIS

Transient stability analysis is used to determine if the transmission system can maintain angular stability and ensure bus voltages stay within planning criteria bandwidth during and after a disturbance while considering the addition of a generator interconnection request.

MODEL PREPARATION

Transient stability analysis was performed using modified versions of the 2015 series of Model Development Working Group (MDWG) dynamic study models including the 2016 winter, 2017 and 2025 summer peak dynamic cases. The cases were adapted to resemble the power flow study cases with regards to prior queued generation requests and topology. Finally the prior queued and study generation was dispatched into the SPP footprint. Initial simulations are then carried out for a nodisturbance run of twenty (20) seconds to verify the numerical stability of the model.

DISTURBANCES

Forty-nine (49) contingencies were identified for use in this ASIS. These faults are listed within **Table 6**. These contingencies included three-phase faults and single-phase line faults at locations defined by SPP. Single-phase line faults were simulated by applying fault impedance to the positive sequence network at the fault location to represent the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the specified fault location of approximately 60% of pre-fault voltage. This method is in agreement with SPP current practice.

With the exception of transformers, the typical sequence of events for a three-phase and single-phase fault is as follows:

- 1. apply fault at particular location
- 2. continue fault for five (5) cycles, clear the fault by tripping the faulted facility
- 3. run for an additional twenty (20) cycles, reclose into fault
- 4. continue fault for five (5) cycles, clear the fault by tripping the faulted facility

Transformer faults are typically modeled as three-phase faults, unless otherwise noted. The sequence of events for a transformer fault is as follows:

- 1. apply fault for five (5) cycles
- 2. clear the fault by tripping the affected transformer facility (unless otherwise noted there will be no re-closing into a transformer fault)

Сс	ontingency Number and Name	Description				
1	FLT_01_TUPELO4_ALLEN4_138kV_3PH	 3PH Fault on the Tupelo (505600) to Allen (505598) 138kV line, near Tupelo. a. Apply fault at the Tupelo 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. 				

Contingency Number and Name Description				
		3PH Fault on the Tupelo (505600) to South Brown (505602)		
		138kV line, near Tupelo.		
		a. Apply fault at the Tupelo 138kV bus.		
2	FIT 02 TUDELOA CROOWNA 129W 2DH	b. Clear fault after 5 cycles by tripping the faulted line.		
2	FE1_02_10FEE04_3DR0WN4_130RV_3FII	c. Wait 20 cycles, and then re-close the line in (b) back into the		
		fault.		
		d. Leave fault on for 5 cycles, then trip the line in (b) and		
		remove fault.		
		3PH Fault on the Tupelo (505600) to Atoka West (521188)		
		138kV line, near Tupelo.		
		a. Apply fault at the Tupelo 138kV bus.		
3	FLT 03 TUPELO4 ATKWEST4 138kV 3PH	b. Clear fault after 5 cycles by tripping the faulted line.		
		c. Wait 20 cycles, and then re-close the line in (b) back into the		
		fault.		
		d. Leave fault on for 5 cycles, then trip the line in (b) and		
		remove fault.		
		(F10991) 129 Vine neer Tunele		
		(510001) 130KV IIIIe, liear Tupelo.		
		a. Apply fault at the Tupelo ISOKV bus.		
4	FLT_04_TUPELO4_ALLENGT4_138kV_3PH	c Wait 20 cycles and then re-close the line in (h) back into the		
		fault		
		d Leave fault on for 5 cycles then trip the line in (b) and		
		remove fault.		
		3PH Fault on the Tupelo (505600) to Tupelo Tap (521071)		
		138kV line, near Tupelo.		
		a. Apply fault at the Tupelo 138kV bus.		
5		b. Clear fault after 5 cycles by tripping the faulted line.		
5	rL1_05_10rEL04_10rL01r4_136Kv_5rH	c. Wait 20 cycles, and then re-close the line in (b) back into the		
		fault.		
		d. Leave fault on for 5 cycles, then trip the line in (b) and		
		remove fault.		
		3PH Fault on the Tupelo (505600) to WFEC Tupelo(520406)		
		138kV line, near Tupelo.		
		a. Apply fault at the Tupelo 138kV bus.		
6	FLT_06_TUPELO4_TUPELO4_138kV_3PH	b. Clear fault after 5 cycles by tripping the faulted line.		
		c. wait 20 cycles, and then re-close the line in (b) back into the		
		Iduit.		
		u. Leave fault off for 5 cycles, then trip the fine in (b) and		
		3PH Fault on the South Brown (505602) to Kiersey Junction		
		South (521109) 138kV line near South Brown		
7		a Apply fault at the South Brown 138kV hus		
		h. Clear fault after 5 cycles by tripping the faulted line		
	FLT_07_SBROWN4_KRSYJCTS4_138kV_3PH	c. Wait 20 cycles, and then re-close the line in (b) back into the		
		fault.		
		d. Leave fault on for 5 cycles, then trip the line in (b) and		
		remove fault.		

Со	ntingency Number and Name	Description
		3PH Fault on the South Brown (505602) to Denison (505604)
		138kV line, near South Brown.
		a. Apply fault at the South Brown 138kV bus.
0	ELT OG CODOWNIA DENICONA 1201-U 2011	b. Clear fault after 5 cycles by tripping the faulted line.
ð	FL1_08_SBROWN4_DENISON4_138KV_3PH	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the South Brown (505602) to Kiersey Junction
		North (521108) 138kV line, near South Brown.
		a. Apply fault at the South Brown 138kV bus.
0	ΕΙ Τ ΛΩ ΟΡΟΛΙΜΝΙΑ ΚΡΟΥΙΟΤΝΑ 129ΗΟ 200	b. Clear fault after 5 cycles by tripping the faulted line.
9	FL1_09_3DK0WN4_KK31JC1N4_130KV_3FH	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the South Brown (505602) to Brown (515157)
		138kV line, near South Brown.
		a. Apply fault at the South Brown 138kV bus.
10	FIT 10 CRDOWNA RDOWNA 129-W 2DH	b. Clear fault after 5 cycles by tripping the faulted line.
	FLI_I0_3DROWIN4_DROWIN4_I30RV_3FR	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the South Brown (505602) to Russett (521044)
		138kV line, near South Brown.
		a. Apply fault at the South Brown 138kV bus.
11	FLT 11 SBROWN4 RUSSETT4 138kV 3PH	b. Clear fault after 5 cycles by tripping the faulted line.
		c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the South Brown (505602) to Colbert Tap
		(515159) 138kV line, near South Brown.
		a. Apply fault at the South Brown 138kV bus.
12	FLT 12 SBROWN4 COLBRTP4 138kV 3PH	b. Clear fault after 5 cycles by tripping the faulted line.
		c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		3PH Fault on the colbert Tap (515159) to Butterfield
13		(515176) 138KV line, near Colbert Tap.
		a. Appry fault at the Coldert Tap 138KV bus.
	FLT_13_COLBRTP4_BUTRFLD4_138kV_3PH	b. Clear fault after 5 cycles by tripping the faulted line.
	_	c. wait 20 cycles, and then re-close the line in (b) back into the
		Idult. d Leave fault on for 5 cycles then trip the line in (b) and
		u. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.

Со	ntingency Number and Name	Description
		3PH Fault on the Colbert Tap (515159) to Bodle (515155)
		138kV line, near Colbert Tap.
		a. Apply fault at the Colbert Tap 138kV bus.
1/	FLT 14 COLBRTDA BODI FA 1386V 3DH	b. Clear fault after 5 cycles by tripping the faulted line.
14	TET_14_COLDRIF4_DODLE4_130KV_5FII	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Colbert (520860) to OKGE Colbert (515193)
		138kV line, near Colbert.
		a. Apply fault at the Colbert 138kV bus.
15	FLT_15_COLBERT4_COLBRT4_138kV_3PH	b. Clear fault after 5 cycles by tripping the faulted line.
		c. wait 20 cycles, and then re-close the line in (b) back into the
		Iduit.
		u. Leave fault of 101 5 cycles, then trip the fille fill (b) and
		3PH Fault on the Colbert (520860) to Kiersey (520963) 138kV
		line near Colhert
		a. Apply fault at the Colbert 138kV bus.
16		b. Clear fault after 5 cycles by tripping the faulted line.
	FLT_16_COLBERT4_KIERSEY4_138kV_3PH	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Colbert (520860) to Seaway (520426) 138kV
		line, near Colbert.
		a. Apply fault at the Colbert 138kV bus.
17	FLT_17_COLBERT4_SEAWAY4_138kV_3PH	b. Clear fault after 5 cycles by tripping the faulted line.
		c. wait 20 cycles, and then re-close the line in (b) back into the
		d Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Durant (520884) to Bennington (520826)
		138kV line, near Durant.
		a. Apply fault at the Durant 138kV bus.
10	ΕΙ Τ 18 ΠΗΡΑΝΤΆ ΒΕΝΝΟΤΝΑ 139-Ν 20Η	b. Clear fault after 5 cycles by tripping the faulted line.
10	TEI_IO_DORANT4_DENNGIN4_ISOKV_SFII	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Durant (520884) to South Coleman (521049)
		130KV IIIIe, near Durant 128kV bus
		a. Apply fault at the Durant ISOKY DUS.
19	FLT_19_DURANT4_SCOLEMN4_138kV_3PH	whit 20 cycles and then re-close the line in (b) back into the
		fault
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.

Со	ntingency Number and Name	Description
		3PH Fault on the OKGE Russett (515120) to Russett (521044)
		138kV line, near OKGE Russett.
		a. Apply fault at the OKGE Russett 138kV bus.
20	ELT 20 DUCCETA DUCCETTA 138by 3DH	b. Clear fault after 5 cycles by tripping the faulted line.
20	FL1_20_K035E14_K035E114_150KV_5FI1	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the OKGE Russett (515120) to Johnson County
		(514808) 138kV line, near OKGE Russett.
		a. Apply fault at the OKGE Russett 138kV bus.
21	FLT_21_RUSSET4_JOHNCO4_138kV_3PH	b. Clear fault after 5 cycles by tripping the faulted line.
		c. Wait 20 cycles, and then re-close the line in (b) back into the
		tault.
		a. Leave fault on for 5 cycles, then trip the line in (b) and
		2DH Fault on the OKCE Duggett (E1E120) to Classes Madill
		(515147) 138kV line near OKCE Russett
		a Apply fault at the OKGF Russett 138kV hus
22	a. Apply fault at the Ol	h Clear fault after 5 cycles by tripping the faulted line
	FLT_22_RUSSET4_GLASSES4_138kV_3PH	c Wait 20 cycles and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the OKGE Russett (515120) to Springdale
		(515172) 138kV line, near OKGE Russett.
		a. Apply fault at the OKGE Russett 138kV bus.
23	FLT_23_RUSSET4_SPRNDAL4_138kV_3PH	b. Clear fault after 5 cycles by tripping the faulted line.
		c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		line near Allen
		a Apply fault at the Allen 138kV bus
		h Clear fault after 5 cycles by tripping the faulted line
24	FLT_24_ALLEN4_EXPLOR4_138kV_3PH	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Explorer (505596) to Greasy Creek (505595)
		138kV line, near Explorer.
		a. Apply fault at the Explorer 138kV bus.
25	FLT 25 FXPLOR4 CRFASVC4 138-W 20H	b. Clear fault after 5 cycles by tripping the faulted line.
		c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.

Со	ntingency Number and Name	Description
		3PH Fault on the Greasy Creek (505595) to Weleetka (505592)
		138kV line, near Greasy Creek.
		a. Apply fault at the Greasy Creek 138kV bus.
26	FLT_26_GREASYC4_WELEETKA4_138kV_3P	b. Clear fault after 5 cycles by tripping the faulted line.
20	Н	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Weleetka (505592) to Checota (505594)
		138kV line, near Weleetka.
		a. Apply fault at the Weleetka 138kV bus.
27	FL1_27_WELEE1KA4_CHEC01A4_138KV_3P	b. Clear fault after 5 cycles by tripping the faulted line.
	п	c. wait 20 cycles, and then re-close the line in (b) back into the
		Iduit.
		u. Leave fault off for 5 cycles, then trip the fine in (b) and
		3PH Foult on the Weleetka (505502) to AFP Weleetka
		(510902) 138kV line near Weleetka
		a Apply fault at the Weleetka 138kV hus
	FLT 28 WELEETKA4 WELETK4 138kV 3P	b. Clear fault after 5 cycles by tripping the faulted line.
28	Н	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
	FLT_29_WELEETKA4_WELEETK5_138_161k	3PH Fault on the Weleetka (505592) 138kV to (505590) 69kV
		to (505591) 13.8kV transformer circuit 1, near Weleetka
29		138kV.
	V_11 11	a. Apply fault at the Weleetka 138kV bus.
		b. Clear fault after 5 cycles by tripping the faulted line.
		3PH Fault on the Weleetka (505592) to Fixico Tap (510877)
		138kV line, near Weleetka.
		a. Apply fault at the weleetka 138kv bus.
30	FLT_30_WELETK4_FIXCT4_138kV_3PH	b. Clear fault after 5 cycles by thipping the faulted line.
		foult
		d Leave fault on for 5 cycles then trin the line in (h) and
		remove fault.
		3PH Fault on the Weleetka (505592) to Dustin (510921)
		138kV line, near Weleetka.
		a. Apply fault at the Weleetka 138kV bus.
21	ELT 21 WELETVA DISTINA 120 V 201	b. Clear fault after 5 cycles by tripping the faulted line.
31	FLI_31_WELEIK4_DUSIIN4_138KV_3PH	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Weleetka (505592) to Henryetta (510892)
		138kV line, near Weleetka.
32		a. Apply fault at the Weleetka 138kV bus.
	FLT_32_WELETK4_HENRYET4_138kV_3PH	b. Clear fault after 5 cycles by tripping the faulted line.
	·	c. wait 20 cycles, and then re-close the line in (b) back into the
		Iduit.
		u. Leave fault on for 5 cycles, then trip the line in (b) and remove fault
		i chiove iduit.

Со	ntingency Number and Name	Description
		3PH Fault on the Weleetka (505592) to EC.Hen (510923)
		138kV line, near Weleetka.
		a. Apply fault at the Weleetka 138kV bus.
33	FLT 33 WELETK4 ECHEN4 138kV 3PH	b. Clear fault after 5 cycles by tripping the faulted line.
		c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		to (510041) 12 9kW transformer girguit 2 near Welestka
21	FLT_34_WELETK4_WELEETK2_138_69kV_1	1201-W
54	PH	a Apply fault at the Weleetka 138kV bus
		h Clear fault after 5 cycles by tripping the faulted transformer
		3PH Fault on the Ashland (520818) to Colgate (520862)
		138kV line, near Ashland.
		a. Apply fault at the Ashland 138kV bus.
25		b. Clear fault after 5 cycles by tripping the faulted line.
35	FL1_35_A5HLAND4_COLGATE4_138KV_3PH	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Ashland (520818) to Pittsburg (521030)
		138kV line, near Ashland.
		a. Apply fault at the Ashland 138kV bus.
36	FLT_36_ASHLAND4_PITTSBG4_138kV_3PH	b. Clear fault after 5 cycles by tripping the faulted line.
		c. wait 20 cycles, and then re-close the line in (b) back into the
		d Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault
		3PH Fault on the Colgate (520862) to Tupelo (505600) 138kV
		line, near Colgate.
		a. Apply fault at the Colgate 138kV bus.
27		b. Clear fault after 5 cycles by tripping the faulted line.
57	FLI_5/_COLGATE4_TOPELO4_TSOKV_SPH	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Savanna (521047) to Pittsburg (521030)
		150KV line, near Ashland.
		a. Apply fault at the Ashianu 150KV bus.
38	FLT_38_SAVANNA4_PITTSBG4_138kV_3PH	b. Clear fault after 5 cycles by thipping the faulted line. c. Wait 20 cycles and then re-close the line in (b) back into the
		fault
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Savanna (521047) to Hartshorne (520934)
		138kV line, near Ashland.
		a. Apply fault at the Ashland 138kV bus.
39	ΕΙ Τ. 20 ς Δυλννάλ ηλοτείνα 120 μ σου	b. Clear fault after 5 cycles by tripping the faulted line.
		c. Wait 20 cycles, and then re-close the line in (b) back into the
		tault.
		a. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.

Co	ntingency Number and Name	Description
		3PH Fault on the Hartshorne (520934) to Lone Oak (510897)
		138kV line, near Hartshorne.
		a. Apply fault at the Hartshorne 138kV bus.
40	FLT 40 HARTSHN4 LONFOAK4 138kV 3PH	b. Clear fault after 5 cycles by tripping the faulted line.
10		c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Hartshorne (520934) to Manning (520896)
		138kV line, near Hartshorne.
		a. Apply fault at the Hartshorne 138kV bus.
41	FLT_41_HARTSHN4_MANNING4_138kV_3P	b. Clear fault after 5 cycles by tripping the faulted line.
	Н	c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Lone Oak (510897) to South McAlester Tap
		(510906) 138KV line, near Lone Oak.
		8kV_3PH (510906) 138kV line, near Lone Oak. a. Apply fault at the Lone Oak 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault. 3PH Fault on the Lone Oak (510897) to McAlester (510908 138kV line, near Lone Oak.
42	FLT_42_LONEOAK4_SMCALTP4_138kV_3PH	b. Clear fault after 5 cycles by tripping the faulted line.
		c. wait 20 cycles, and then re-close the line in (b) back into the
		Iduit. d. Leave fault on for E-cycles, then trip the line in (b) and
		a Leave fault on for 5 cycles, then trip the fine in (b) and
		3PH Foult on the Long Oak (510897) to McAlester (510908)
	FLT_43_LONEOAK4_MCALEST4_138kV_3PH	138kV line near Lone Oak
		a Apply fault at the Lone Oak 138kV hus
		h Clear fault after 5 cycles by tripping the faulted line
43		c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Lone Oak (510897) to Enogex Wilburton Tap
		(510944) 138kV line, near Lone Oak.
		a. Apply fault at the Lone Oak 138kV bus.
лл	ΕΙ Τ. ΛΛ. Ι ΟΝΕΟΛΚΑ. ΕΝΟΨΙΙ ΤΛ. 138৮Ν. 3ΡΗ	b. Clear fault after 5 cycles by tripping the faulted line.
		c. Wait 20 cycles, and then re-close the line in (b) back into the
		fault.
		d. Leave fault on for 5 cycles, then trip the line in (b) and
		remove fault.
		3PH Fault on the Lone Oak (510897) to Carbon (520844)
		138KV line, near Lone Oak.
		a. Apply fault at the Lone Oak 138KV bus.
45	FLT_45_LONEOAK4_CARBON4_138kV_3PH	b. Clear fault after 5 cycles by tripping the faulted line.
		c. Wait 20 cycles, and then re-close the line in (b) back into the
		d Leave fault on for 5 cycles then trin the line in (b) and
		remove fault
		3PH Fault on the Lone Oak (510897) 138kV to (510896) 69kV
		to (510940) 13 8kV transformer circuit 1 near Lone Oak
46	FLT_46_LONEOAK4_LONEOAK2_138_69kV_	138kV.
	1РН	a. Apply fault at the Lone Oak 138kV bus.
		b. Clear fault after 5 cycles by tripping the faulted transformer.

Contingency Number and Name		Description			
		3PH Fault on the Weleetka (505592) to Pharoah SW (510026)			
		138kV line, near Weleetka.			
		a. Apply fault at the Weleetka 138kV bus.			
17		b. Clear fault after 5 cycles by tripping the faulted line.			
47	FEI_47_WEEETR4_FIIAROAII4_150KV_5FII	c. Wait 20 cycles, and then re-close the line in (b) back into the			
		fault.			
		d. Leave fault on for 5 cycles, then trip the line in (b) and			
		remove fault.			
		SLG Fault with stuck breaker on the Greasy Creek (505595)			
	FLT_48_GREASYC4_EXPLOR4SB_138kV_1PH	to Explorer (505596) 138kV line, near Greasy Creek.			
48		a. Apply single line to ground at the Greasy Creek 138kV bus.			
		b. Clear fault after 16 cycles by tripping the faulted line and th			
		Greasy Creek (505595) bus as well as Explorer bus (505596).			
		SLG Fault with stuck breaker on the South Brown (505602)			
		to Denison (505604) 138kV line, near South Brown.			
19	FLT_49_SBROWN4_DENISON4SB_138kV_1P	a. Apply single line to ground fault at the South Brown 138kV			
49	Н	bus.			
		b. Clear fault after 16 cycles by tripping the faulted line and the			
		South Brown bus (505602).			

RESULTS

Initial stability simulations showed angle instabilities for ASGI-2016-011, ASGI-2016-012, and ASGI-2016-013 for contingencies at the Tupelo substation and nearby. It was determined that the generator documentation for these projects provided saturated reactances, rather than unsaturated reactances, which are required for the PSSE generator model. After correcting the reactances in the PSSE generator model, the simulation was repeated. The project generators as well as all the monitored synchronous generators exhibited no angular instabilities for the contingencies simulated.

Results of the stability analysis are summarized in **Table 7**. These results are valid for ASGI-2016-011, ASGI-2016-012, and ASGI-2016-013, with generation amounts up to 7.4, 61.7, and 4.9 MW, respectively.

	Contingency Number and Name	2016WP	2017SP	2025SP
1	FLT_01_TUPELO4_ALLEN4_138kV_3PH	Stable	Stable	Stable
2	FLT_02_TUPELO4_SBROWN4_138kV_3PH	Stable	Stable	Stable
3	FLT_03_TUPELO4_ATKWEST4_138kV_3PH	Stable	Stable	Stable
4	FLT_04_TUPELO4_ALLENGT4_138kV_3PH	Stable	Stable	Stable
5	FLT_05_TUPELO4_TUPLOTP4_138kV_3PH	Stable	Stable	Stable
6	FLT_06_TUPELO4_TUPELO4_138kV_3PH	Stable	Stable	Stable
7	FLT_07_SBROWN4_KRSYJCTS4_138kV_3PH	Stable	Stable	Stable
8	FLT_08_SBROWN4_DENISON4_138kV_3PH	Stable	Stable	Stable
9	FLT_09_SBROWN4_KRSYJCTN4_138kV_3PH	Stable	Stable	Stable
10	FLT_10_SBROWN4_BROWN4_138kV_3PH	Stable	Stable	Stable
11	FLT_11_SBROWN4_RUSSETT4_138kV_3PH	Stable	Stable	Stable
12	FLT_12_SBROWN4_COLBRTP4_138kV_3PH	Stable	Stable	Stable
13	FLT_13_COLBRTP4_BUTRFLD4_138kV_3PH	Stable	Stable	Stable

Table 7: Fault Analysis Results

	Contingency Number and Name	2016WP	2017SP	2025SP
14	FLT_14_COLBRTP4_BODLE4_138kV_3PH	Stable	Stable	Stable
15	FLT_15_COLBERT4_COLBRT4_138kV_3PH	Stable	Stable	Stable
16	FLT_16_COLBERT4_KIERSEY4_138kV_3PH	Stable	Stable	Stable
17	FLT_17_COLBERT4_SEAWAY4_138kV_3PH	Stable	Stable	Stable
18	FLT_18_DURANT4_BENNGTN4_138kV_3PH	Stable	Stable	Stable
19	FLT_19_DURANT4_SCOLEMN4_138kV_3PH	Stable	Stable	Stable
20	FLT_20_RUSSET4_RUSSETT4_138kV_3PH	Stable	Stable	Stable
21	FLT_21_RUSSET4_JOHNCO4_138kV_3PH	Stable	Stable	Stable
22	FLT_22_RUSSET4_GLASSES4_138kV_3PH	Stable	Stable	Stable
23	FLT_23_RUSSET4_SPRNDAL4_138kV_3PH	Stable	Stable	Stable
24	FLT_24_ALLEN4_EXPLOR4_138kV_3PH	Stable	Stable	Stable
25	FLT_25_EXPLOR4_GREASYC4_138kV_3PH	Stable	Stable	Stable
26	FLT_26_GREASYC4_WELEETKA4_138kV_3PH	Stable	Stable	Stable
27	FLT_27_WELEETKA4_CHECOTA4_138kV_3PH	Stable	Stable	Stable
28	FLT_28_WELEETKA4_WELETK4_138kV_3PH	Stable	Stable	Stable
29	FLT_29_WELEETKA4_WELEETK5_138_161kV_1PH	Stable	Stable	Stable
30	FLT_30_WELETK4_FIXCT4_138kV_3PH	Stable	Stable	Stable
31	FLT_31_WELETK4_DUSTIN4_138kV_3PH	Stable	Stable	Stable
32	FLT_32_WELETK4_HENRYET4_138kV_3PH	Stable	Stable	Stable
33	FLT_33_WELETK4_ECHEN4_138kV_3PH	Stable	Stable	Stable
34	FLT_34_WELETK4_WELEETK2_138_69kV_1PH	Stable	Stable	Stable
35	FLT_35_ASHLAND4_COLGATE4_138kV_3PH	Stable	Stable	Stable
36	FLT_36_ASHLAND4_PITTSBG4_138kV_3PH	Stable	Stable	Stable
37	FLT_37_COLGATE4_TUPELO4_138kV_3PH	Stable	Stable	Stable
38	FLT_38_SAVANNA4_PITTSBG4_138kV_3PH	Stable	Stable	Stable
39	FLT_39_SAVANNA4_HARTSHN4_138kV_3PH	Stable	Stable	Stable
40	FLT_40_HARTSHN4_LONEOAK4_138kV_3PH	Stable	Stable	Stable
41	FLT_41_HARTSHN4_MANNING4_138kV_3PH	Stable	Stable	Stable
42	FLT_42_LONEOAK4_SMCALTP4_138kV_3PH	Stable	Stable	Stable
43	FLT_43_LONEOAK4_MCALEST4_138kV_3PH	Stable	Stable	Stable
44	FLT_44_LONEOAK4_ENOWILT4_138kV_3PH	Stable	Stable	Stable
45	FLT_45_LONEOAK4_CARBON4_138kV_3PH	Stable	Stable	Stable
46	FLT_46_LONEOAK4_LONEOAK2_138_69kV_1PH	Stable	Stable	Stable
47	FLT_47_WELETK4_PHAROAH4_138kV_3PH	Stable	Stable	Stable
48	FLT_48_GREASYC4_EXPLOR4SB_138kV_1PH	Stable	Stable	Stable
49	FLT_49_SBROWN4_DENISON4SB_138kV_1PH	Stable	Stable	Stable

Table 7: Fault Analysis Results

SHORT CIRCUIT ANALYSIS

A short circuit analysis was performed on the 2017 Summer Peak and 2025 Summer Peak power flow case using the PSS/E ASCC program. Since the power flow model does not contain negative and zero sequence data, only three-phase symmetrical fault current levels were calculated at the point of interconnection up to and including five levels away. The results of the short circuit analysis are shown below.

ASGI-2016-011 17SP

PSS[®]E-32.2.0 ASCC SHORT CIRCUIT CURRENTS

THU, JUN 15 2017

10:32 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO MDWG 175 WITH MMWG 155, MRO 16W TOPO/165 PROF, SERC 165

OPTIONS USED:

- FLAT CONDITIONS
 - BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE

- GENERATOR P=0, Q=0

- TRANSFOMRER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-/0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-/0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED

- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

				THREE PHAS	SE FAULT
Х	BUS	X		/I+/	AN(I+)
505598	[ALLEN 4	138.00]	AMP	5477.7	-76.43
505596	[EXPLOR 4	138.00]	AMP	5414.0	-76.12
505600	[TUPELO 4	138.00]	AMP	10654.9	-79.04
510916	[ALLEN4	138.00]	AMP	5470.3	-76.43
588270	[ASGI1611	138.00]	AMP	4158.6	-77.16
505595	[GREASYC4	138.00]	AMP	6880.1	-76.47
505602	[S BROWN4	138.00]	AMP	8061.5	-77.45
510881	[ALLENGT4	138.00]	AMP	10312.2	-78.88
510884	[HOLDEXP4	138.00]	AMP	5287.4	-76.01
520406	[TUPELO4	138.00]	AMP	9719.7	-79.20
521071	[TUPLOTP4	138.00]	AMP	10367.6	-78.88
521188	[ATKWEST4	138.00]	AMP	5189.0	-80.78
585330	[ASGI-2015-	00138.00]	AMP	4686.3	-80.23
588280	[ASGI1612	138.00]	AMP	5869.8	-79.98
505592	[WELEETK4	138.00]	AMP	14161.1	-78.74
505604	[DENISON4	138.00]	AMP	3068.7	-75.83
510880	[COALGTP4	138.00]	AMP	6081.8	-77.55
510887	[ATOKA4	138.00]	AMP	5796.6	-79.47
510935	[EXPCOLT4	138.00]	AMP	7515.2	-77.69
515157	[BROWN 4	138.00]	AMP	8021.4	-77.39
515159	[COLBRTP4	138.00]	AMP	6141.1	-76.06
515192	[LULA 4	138.00]	AMP	9192.9	-79.26
520862	[COLGATE4	138.00]	AMP	5998.2	-79.87
521044	[RUSSETT4	138.00]	AMP	10861.7	-77.84
521075	[STONEWAL	LH138.00]	AMP	8615.8	-77.90
521108	[KRSYJCTN4	138.00]	AMP	7709.4	-77.95
521109	[KRSYJCTS4	138.00]	AMP	7494.8	-77.63
505590	[WELEETK5	161.00]	AMP	6173.2	-82.13
505594	[CHECOTA4	138.00]	AMP	6256.4	-77.07
510862	[COALGAT4	138.00]	AMP	5860.2	-77.44

Southwest Power Pool, Inc.

510863	[ALLENNG4	138.00]	AMP	5568.7	-76.85
510882	TATOKA2	69.000	AMP	3997.4	-77.93
510895	LEHIGH-4	138.00	AMP	5689.6	-77.93
510902	- WELETK4	138.00	AMP	13900.1	-78.63
510936	EXPCOLG4	138.00	AMP	7412.9	-77.64
510949	WAPANUCKA	4138.00	AMP	5806.1	-79.67
515120	RUSSET-4	138.00	AMP	10928.6	-77.86
515153	COLEMNT4	138.00	AMP	7998.5	-77.39
515155	BODLE 4	138.00	AMP	6036.1	-75.61
515176	BUTRFLD4	138.00	AMP	5567.2	-75.87
515191	LULA 2	69.000	AMP	5939.7	-81.20
515500	FRISCC04	138.00	AMP	7968.9	-79.97
520818	ASHLAND4	138.00	AMP	4664.9	-80.22
520963	- [KIERSEY4	138.00]	AMP	5404.2	-75.29
520969	LASALLE4	138.00	AMP	6472.8	-76.69
521026	PHAROAH4	138.00	AMP	13918.0	-78.81
521049	SCOLEMN4	138.00	AMP	6975.9	-78.99
521187	ATKEAST4	138.00]	AMP	5098.5	-80.94
587200		030138.00]	AMP	5846.9	-78.11
300686	4WOODY	138.00	AMP	7307.0	-79.20
300895	2CHECOTA	69.000]	AMP	5392.2	-77.57
505552	GORE 5	161.00]	AMP	11262.9	-79.93
505574	EUFAULA4	138.00]	AMP	8682.8	-80.40
510877	[FIXCT4	138.00]	AMP	7030.6	-71.70
510879	ΑΤΟΚΑ Ρ2	69.000]	AMP	3426.3	-74.37
510891	[LANE 2	69.000]	AMP	2765.2	-68.59
510892	[HENRYET4	138.00]	AMP	8315.1	-81.39
510903	[WELEETK2	69.000]	AMP	10180.2	-83.25
510921	[DUSTIN-4	138.00]	AMP	8497.1	-81.31
510923	[EC.HEN-4	138.00]	AMP	8386.5	-77.18
514808	[JOHNCO 4	138.00]	AMP	14513.4	-82.93
515147	[GLASSES4	138.00]	AMP	7917.3	-75.47
515152	[BROWNTP4	138.00]	AMP	7951.5	-77.33
515154	[EXPLRPL4	138.00]	AMP	4403.6	-76.30
515172	[SPRNDAL4	138.00]	AMP	11030.4	-78.06
515190	[AOCPT 2	69.000]	AMP	5640.5	-74.87
515193	[COLBRT-4	138.00]	AMP	4728.7	-75.16
515362	[HARDEN 4	138.00]	AMP	8101.9	-80.15
515511	[SOCPMPT2	69.000]	AMP	5600.3	-80.79
520860	[COLBERT4	138.00]	AMP	4722.8	-75.08
520884	[DURANT 4	138.00]	AMP	5385.8	-81.43
520886	[DUSTIN 4	138.00]	AMP	7075.6	-79.65
520968	[LANE 4	138.00]	AMP	4828.6	-81.59
520971	[LATTAJT4	138.00]	AMP	5517.0	-76.13
521030	[PITTSBG4	138.00]	AMP	4406.6	-80.33
521084	[WETUMKA4	138.00]	AMP	8383.8	-80.72
588290	[ASGI1613	138.00]	AMP	4664.9	-80.22

PSS®E-32.2.0 ASCC SHORT CIRCUIT CURRENTS THU, 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO MDWG 2025S WITH MMWG 2024S, MRO & SERC 2025 SUMMER

OPTIONS USED:

- FLAT CONDITIONS
 - BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
 - GENERATOR P=0, Q=0
 - TRANSFOMRER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
 - LINE CHARGING=0.0 IN +/-/0 SEQUENCE
 - LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
 - LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-/0 SEQUENCE
 - DC LINES AND FACTS DEVICES BLOCKED
 - TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

				THREE PHAS	E FAULT
Х	BUS	· X		/I+/	AN(I+)
505598	[ALLEN 4	138.00]	AMP	5543.0	-76.48
505596	[EXPLOR 4	138.00]	AMP	5538.7	-76.24
505600	[TUPELO 4	138.00]	AMP	10721.6	-79.04
510916	[ALLEN4	138.00]	AMP	5535.4	-76.48
588270	[ASGI1611	138.00]	AMP	4195.6	-77.20
505595	[GREASYC4	138.00]	AMP	7183.0	-76.76
505602	[S BROWN4	138.00]	AMP	8074.3	-77.43
510881	[ALLENGT4	138.00]	AMP	10374.4	-78.88
510884	[HOLDEXP4	138.00]	AMP	5406.3	-76.13
520406	[TUPELO4	138.00]	AMP	9776.4	-79.20
521071	[TUPLOTP4	138.00]	AMP	10427.0	-78.87
521188	[ATKWEST4	138.00]	AMP	5200.9	-80.78
585330	[ASGI-2015-	00138.00]	AMP	4699.2	-80.23
588280	[ASGI1612	138.00]	AMP	5887.2	-79.97
505592	[WELEETK4	138.00]	AMP	16081.9	-80.03
505604	[DENISON4	138.00]	AMP	3070.6	-75.83
510880	[COALGTP4	138.00]	AMP	6100.4	-77.54
510887	[ATOKA4	138.00]	AMP	5810.7	-79.47
510935	[EXPCOLT4	138.00]	AMP	7548.2	-77.68
515157	[BROWN 4	138.00]	AMP	8034.1	-77.38
515159	[COLBRTP4	138.00]	AMP	6148.5	-76.04
515192	[LULA 4	138.00]	AMP	9233.0	-79.26
520862	[COLGATE4	138.00]	AMP	6023.9	-79.89
521044	[RUSSETT4	138.00]	AMP	10881.1	-77.82
521075	[STONEWAL	LH138.00]	AMP	8656.0	-77.89
521108	[KRSYJCTN4	138.00]	AMP	7720.9	-77.94
521109	[KRSYJCTS4	138.00]	AMP	7505.9	-77.62
505590	[WELEETK5	161.00]	AMP	6448.0	-82.87
505594	[CHECOTA4	138.00]	AMP	6180.2	-77.04
510862	[COALGAT4	138.00]	AMP	5877.4	-77.43
510863	[ALLENNG4	138.00]	AMP	5586.7	-76.84
510882	[ATOKA2	69.000]	AMP	4001.0	-77.93
510895	[LEHIGH-4	138.00]	AMP	5704.8	-77.92
510902	[WELETK4	138.00]	AMP	16758.3	-80.45
510936	[EXPCOLG4	138.00]	AMP	7445.0	-77.63
510949	[WAPANUCKA	4138.00]	AMP	5824.3	-79.67
515120	[RUSSET-4	138.00]	AMP	10948.2	-77.85
515153	[COLEMNT4	138.00]	AMP	8011.1	-77.37
515155	[BODLE 4	138.00]	AMP	6043.3	-75.60
515176	[BUTRFLD4	138.00]	AMP	5573.2	-75.86
515191	[LULA 2	69.000]	AMP	5945.9	-81.20
515500	[FRISCC04	138.00]	AMP	7990.5	-79.96
520818	[ASHLAND4	138.00]	AMP	4684.1	-80.25
520963	[KIERSEY4	138.00]	AMP	5409.9	-75.28
520969	[LASALLE4	138.00]	AMP	6494.9	-76.67

THU, JUN 15 2017 10:32

Southwest Power Pool, Inc.

521026	[PHAROAH4	138.00]	AMP	15721.9	-80.05
521049	SCOLEMN4	138.00]	AMP	6984.9	-78.98
521187	ATKEAST4	138.00]	AMP	5107.8	-80.94
587200	[GEN-2016-030	0138.00]	AMP	5853.6	-78.10
300686	4WOODY	138.00]	AMP	7568.6	-79.58
300895	2CHECOTA	69.000]	AMP	5367.3	-77.55
505552	GORE 5	161.00]	AMP	11096.1	-79.97
505574	EUFAULA4	138.00]	AMP	8288.5	-80.07
510877	[FIXCT4	138.00]	AMP	7132.7	-71.59
510879	[ΑΤΟΚΑ Ρ2	69.000]	AMP	3429.2	-74.37
510891	[LANE 2	69.000]	AMP	2766.5	-68.58
510892	[HENRYET4	138.00]	AMP	8885.2	-82.11
510903	[WELEETK2	69.000]	AMP	10768.1	-84.19
510921	[DUSTIN-4	138.00]	AMP	9221.8	-82.30
510923	[EC.HEN-4	138.00]	AMP	8997.7	-77.62
514808	[JOHNCO 4	138.00]	AMP	14543.9	-82.92
515147	[GLASSES4	138.00]	AMP	7929.2	-75.46
515152	[BROWNTP4	138.00]	AMP	7963.9	-77.31
515154	[EXPLRPL4	138.00]	AMP	4407.4	-76.29
515172	[SPRNDAL4	138.00]	AMP	11047.1	-78.04
515190	[AOCPT 2	69.000]	AMP	5644.5	-74.86
515193	[COLBRT-4	138.00]	AMP	4733.0	-75.15
515362	[HARDEN 4	138.00]	AMP	8121.3	-80.14
515511	[SOCPMPT2	69.000]	AMP	5605.8	-80.79
520860	[COLBERT4	138.00]	AMP	4727.1	-75.07
520884	[DURANT 4	138.00]	AMP	5390.1	-81.42
520886	[DUSTIN 4	138.00]	AMP	7439.4	-80.19
520968	[LANE 4	138.00]	AMP	4836.0	-81.59
520971	[LATTAJT4	138.00]	AMP	5533.2	-76.11
521030	[PITTSBG4	138.00]	AMP	4428.0	-80.37
521084	[WETUMKA4	138.00]	AMP	8911.7	-81.44
588290	[ASGI1613	138.00]	AMP	4684.1	-80.25

ASGI-2016-012 17SP

PSS®E-32.2.0 ASCC SHORT CIRCUIT CURRENTS

WED, JUN 14 2017

15:55 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO MDWG 17S WITH MMWG 15S, MRO 16W TOPO/16S PROF, SERC 16S

OPTIONS USED:

- FLAT CONDITIONS

- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFOMRER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-/0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-/0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

				THREE PHAS	E FAULT
Х	BUS	· X		/I+/	AN(I+)
505600	[TUPELO 4	138.00]	AMP	10654.9	-79.04
505598	[ALLEN 4	138.00]	AMP	5477.7	-76.43
505602	[S BROWN4	138.00]	AMP	8061.5	-77.45
510881	[ALLENGT4	138.00]	AMP	10312.2	-78.88
520406	[TUPELO4	138.00]	AMP	9719.7	-79.20
521071	[TUPLOTP4	138.00]	AMP	10367.6	-78.88
521188	[ATKWEST4	138.00]	AMP	5189.0	-80.78
585330	[ASGI-2015-	00138.00]	AMP	4686.3	-80.23
588280	[ASGI1612	138.00]	AMP	5869.8	-79.98
505596	[EXPLOR 4	138.00]	AMP	5414.0	-76.12
505604	[DENISON4	138.00]	AMP	3068.7	-75.83
510880	[COALGTP4	138.00]	AMP	6081.8	-77.55
510887	[ATOKA4	138.00]	AMP	5796.6	-79.47
510916	[ALLEN4	138.00]	AMP	5470.3	-76.43
510935	[EXPCOLT4	138.00]	AMP	7515.2	-77.69
515157	[BROWN 4	138.00]	AMP	8021.4	-77.39
515159	[COLBRTP4	138.00]	AMP	6141.1	-76.06
515192	[LULA 4	138.00]	AMP	9192.9	-79.26
520862	[COLGATE4	138.00]	AMP	5998.2	-79.87
521044	[RUSSETT4	138.00]	AMP	10861.7	-77.84
521075	[STONEWAL	LH138.00]	AMP	8615.8	-77.90
521108	[KRSYJCTN4	138.00]	AMP	7709.4	-77.95
521109	[KRSYJCTS4	138.00]	AMP	7494.8	-77.63
588270	[ASGI1611	138.00]	AMP	4158.6	-77.16
505595	[GREASYC4	138.00]	AMP	6880.1	-76.47
510862	[COALGAT4	138.00]	AMP	5860.2	-77.44
510863	[ALLENNG4	138.00]	AMP	5568.7	-76.85
510882	[ATOKA2	69.000]	AMP	3997.4	-77.93
510884	[HOLDEXP4	138.00]	AMP	5287.4	-76.01
510895	[LEHIGH-4	138.00]	AMP	5689.6	-77.93
510936	[EXPCOLG4	138.00]	AMP	7412.9	-77.64
510949	[WAPANUCKA	4138.00]	AMP	5806.1	-79.67
515120	[RUSSET-4	138.00]	AMP	10928.6	-77.86
515153	[COLEMNT4	138.00]	AMP	7998.5	-77.39
515155	[BODLE 4	138.00]	AMP	6036.1	-75.61
515176	[BUTRFLD4	138.00]	AMP	5567.2	-75.87
515191	[LULA 2	69.000]	AMP	5939.7	-81.20
515500	[FRISCC04	138.00]	AMP	7968.9	-79.97
520818	[ASHLAND4	138.00]	AMP	4664.9	-80.22
520963	[KIERSEY4	138.00]	AMP	5404.2	-75.29
520969	[LASALLE4	138.00]	AMP	6472.8	-76.69
521049	[SCOLEMN4	138.00]	AMP	6975.9	-78.99
521187	[ATKEAST4	138.00]	AMP	5098.5	-80.94

Southwest Power Pool, Inc.

587200	[GEN-2016-036	0138.00]	AMP	5846.9	-78.11
505592	[WELEETK4	138.00]	AMP	14161.1	-78.74
510879	[ΑΤΟΚΑ Ρ2	69.000]	AMP	3426.3	-74.37
510891	[LANE 2	69.000]	AMP	2765.2	-68.59
514808	[JOHNCO 4	138.00]	AMP	14513.4	-82.93
515147	[GLASSES4	138.00]	AMP	7917.3	-75.47
515152	[BROWNTP4	138.00]	AMP	7951.5	-77.33
515154	[EXPLRPL4	138.00]	AMP	4403.6	-76.30
515172	[SPRNDAL4	138.00]	AMP	11030.4	-78.06
515190	AOCPT 2	69.000]	AMP	5640.5	-74.87
515193	COLBRT-4	138.00]	AMP	4728.7	-75.16
515362	HARDEN 4	138.00	AMP	8101.9	-80.15
515511	SOCPMPT2	69.000	AMP	5600.3	-80.79
520860	COLBERT4	138.00]	AMP	4722.8	-75.08
520884	DURANT 4	138.00]	AMP	5385.8	-81.43
520968	LANE 4	138.00]	AMP	4828.6	-81.59
520971	LATTAJT4	138.00	AMP	5517.0	-76.13
521030	_ [PITTSBG4	138.00]	AMP	4406.6	-80.33
588290	ASGI1613	138.00	AMP	4664.9	-80.22
505590	WELEETK5	161.00]	AMP	6173.2	-82.13
505594	CHECOTA4	138.00	AMP	6256.4	-77.07
510874	_ [MCGEETP2	69.000]	AMP	2241.0	-64.61
510885	_ [PITTSB-2	69.000]	AMP	2300.6	-63.22
510902	WELETK4	138.00]	AMP	13900.1	-78.63
514809	JOHNCO 7	345.00]	AMP	9294.9	-84.51
515122	SXMLCKT4	138.00]	AMP	10674.3	-79.91
515149	MADINDT4	138.00]	AMP	7908.0	-75.52
515150	CANEYCK4	138.00]	AMP	8350.6	-77.54
515151	LTLCITY4	138.00]	AMP	6972.7	-77.22
515162	FNDTION4	138.00]	AMP	11195.5	-78.34
515164	ROCKYPT4	138.00]	AMP	10023.1	-80.55
515183	SOCPUMP2	69.000]	AMP	5558.4	-80.74
515189	AOCPA 2	69.000]	AMP	6732.1	-77.63
515197	- [HOMERTP2	69.000]	AMP	5494.4	-74.30
515318	SOTHADA4	138.00]	AMP	11066.3	-80.81
520426	- SEAWAY4	138.00]	AMP	3967.0	-75.01
520826	BENNGTN4	138.00	AMP	4719.7	-83.15
520874	DARWIN 4	138.00]	AMP	4691.3	-83.64
520970	LATTA 4	138.00]	AMP	4564.4	-74.97
521014	OILCNTR4	138.00]	AMP	4994.8	-75.77
521026	PHAROAH4	138.00]	AMP	13918.0	-78.81
521047	[SAVANNA4	138.00]	AMP	5062.2	-80.43

ASGI-2016-012 25SP

PSS®E-32.2.0 ASCC SHORT CIRCUIT CURRENTS

WED, JUN 14 2017

16:08 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO MDWG 2025S WITH MMWG 2024S, MRO & SERC 2025 SUMMER

OPTIONS USED:

- FLAT CONDITIONS

- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFOMRER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-/0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-/0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

				THREE PHAS	E FAULT
Х	BUS	X		/I+/	AN(I+)
505600	[TUPELO 4	138.00]	AMP	10721.6	-79.04
505598	[ALLEN 4	138.00]	AMP	5543.0	-76.48
505602	[S BROWN4	138.00]	AMP	8074.3	-77.43
510881	[ALLENGT4	138.00]	AMP	10374.4	-78.88
520406	[TUPELO4	138.00]	AMP	9776.4	-79.20
521071	[TUPLOTP4	138.00]	AMP	10427.0	-78.87
521188	[ATKWEST4	138.00]	AMP	5200.9	-80.78
585330	[ASGI-2015	-00138.00]	AMP	4699.2	-80.23
588280	[ASGI1612	138.00]	AMP	5887.2	-79.97
505596	[EXPLOR 4	138.00]	AMP	5538.7	-76.24
505604	[DENISON4	138.00]	AMP	3070.6	-75.83
510880	[COALGTP4	138.00]	AMP	6100.4	-77.54
510887	[АТОКА4	138.00]	AMP	5810.7	-79.47
510916	[ALLEN4	138.00]	AMP	5535.4	-76.48
510935	[EXPCOLT4	138.00]	AMP	7548.2	-77.68
515157	[BROWN 4	138.00]	AMP	8034.1	-77.38
515159	[COLBRTP4	138.00]	AMP	6148.5	-76.04
515192	[LULA 4	138.00]	AMP	9233.0	-79.26
520862	[COLGATE4	138.00]	AMP	6023.9	-79.89
521044	[RUSSETT4	138.00]	AMP	10881.1	-77.82
521075	[STONEWAL	LH138.00]	AMP	8656.0	-77.89
521108	[KRSYJCTN4	138.00]	AMP	7720.9	-77.94
521109	[KRSYJCTS4	138.00]	AMP	7505.9	-77.62
588270	[ASGI1611	138.00]	AMP	4195.6	-77.20
505595	[GREASYC4	138.00]	AMP	7183.0	-76.76
510862	[COALGAT4	138.00]	AMP	5877.4	-77.43
510863	[ALLENNG4	138.00]	AMP	5586.7	-76.84
510882	[ATOKA2	69.000]	AMP	4001.0	-77.93
510884	[HOLDEXP4	138.00]	AMP	5406.3	-76.13
510895	[LEHIGH-4	138.00]	AMP	5704.8	-77.92
510936	[EXPCOLG4	138.00]	AMP	7445.0	-77.63
510949	[WAPANUCKA	4138.00]	AMP	5824.3	-79.67
515120	[RUSSET-4	138.00]	AMP	10948.2	-77.85
515153	[COLEMNT4	138.00]	AMP	8011.1	-77.37
515155	[BODLE 4	138.00]	AMP	6043.3	-75.60
515176	[BUTRFLD4	138.00]	AMP	5573.2	-75.86
515191	[LULA 2	69.000]	AMP	5945.9	-81.20
515500	[FRISCC04	138.00]	AMP	7990.5	-79.96
520818	[ASHLAND4	138.00]	AMP	4684.1	-80.25
520963	[KIERSEY4	138.00]	AMP	5409.9	-75.28
520969	[LASALLE4	138.00]	AMP	6494.9	-76.67
521049	[SCOLEMN4	138.00]	AMP	6984.9	-78.98
521187	[ATKEAST4	138.00]	AMP	5107.8	-80.94

Southwest Power Pool, Inc.

587200	[GEN-2016-	030138.00]	AMP	5853.6	-78.10
505592	- [WELEETK4	138.00]	AMP	16081.9	-80.03
510879	ATOKA P2	69.000]	AMP	3429.2	-74.37
510891	LANE 2	69.000	AMP	2766.5	-68.58
514808	JOHNCO 4	138.00]	AMP	14543.9	-82.92
515147	GLASSES4	138.00]	AMP	7929.2	-75.46
515152	BROWNTP4	138.00]	AMP	7963.9	-77.31
515154	EXPLRPL4	138.00]	AMP	4407.4	-76.29
515172	[SPRNDAL4	138.00]	AMP	11047.1	-78.04
515190	[AOCPT 2	69.000]	AMP	5644.5	-74.86
515193	[COLBRT-4	138.00]	AMP	4733.0	-75.15
515362	[HARDEN 4	138.00]	AMP	8121.3	-80.14
515511	[SOCPMPT2	69.000]	AMP	5605.8	-80.79
520860	[COLBERT4	138.00]	AMP	4727.1	-75.07
520884	[DURANT 4	138.00]	AMP	5390.1	-81.42
520968	[LANE 4	138.00]	AMP	4836.0	-81.59
520971	[LATTAJT4	138.00]	AMP	5533.2	-76.11
521030	[PITTSBG4	138.00]	AMP	4428.0	-80.37
588290	[ASGI1613	138.00]	AMP	4684.1	-80.25
505590	[WELEETK5	161.00]	AMP	6448.0	-82.87
505594	[CHECOTA4	138.00]	AMP	6180.2	-77.04
510874	[MCGEETP2	69.000]	AMP	2241.6	-64.61
510885	[PITTSB-2	69.000]	AMP	2303.3	-63.21
510902	[WELETK4	138.00]	AMP	16758.3	-80.45
514809	[JOHNCO 7	345.00]	AMP	9321.6	-84.50
515122	[SXMLCKT4	138.00]	AMP	10689.8	-79.89
515149	[MADINDT4	138.00]	AMP	7920.0	-75.51
515150	[CANEYCK4	138.00]	AMP	8365.3	-77.53
515151	[LTLCITY4	138.00]	AMP	6982.4	-77.21
515162	[FNDTION4	138.00]	AMP	11212.2	-78.32
515164	[ROCKYPT4	138.00]	AMP	10037.1	-80.54
515183	[SOCPUMP2	69.000]	AMP	5563.8	-80.74
515189	[AOCPA 2	69.000]	AMP	6737.0	-77.62
515197	[HOMERTP2	69.000]	AMP	5498.2	-74.30
515318	[SOTHADA4	138.00]	AMP	11088.5	-80.80
520426	[SEAWAY4	138.00]	AMP	3970.1	-75.00
520826	[BENNGTN4	138.00]	AMP	4721.8	-83.15
520874	[DARWIN 4	138.00]	AMP	4694.5	-83.64
520970	[LATTA 4	138.00]	AMP	4575.5	-74.95
521014	[OILCNTR4	138.00]	AMP	5008.6	-75.75
521026	[PHAROAH4	138.00]	AMP	15721.9	-80.05
521047	[SAVANNA4	138.00]	AMP	5096.9	-80.50

ASGI-2016-013 17SP

PSS®E-32.2.0 ASCC SHORT CIRCUIT CURRENTS

THU, JUN 15 2017

10:33 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO MDWG 17S WITH MMWG 15S, MRO 16W TOPO/16S PROF, SERC 16S

OPTIONS USED:

- FLAT CONDITIONS

- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFOMRER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-/0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-/0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

				THREE PHAS	E FAULT
Х	BUS	X		/I+/	AN(I+)
520818	[ASHLAND4	138.00]	AMP	4664.9	-80.22
520862	[COLGATE4	138.00]	AMP	5998.2	-79.87
521030	[PITTSBG4	138.00]	AMP	4406.6	-80.33
588290	[ASGI1613	138.00]	AMP	4664.9	-80.22
520406	[TUPELO4	138.00]	AMP	9719.7	-79.20
521047	[SAVANNA4	138.00]	AMP	5062.2	-80.43
505600	[TUPELO 4	138.00]	AMP	10654.9	-79.04
520934	[HARTSHN4	138.00]	AMP	8361.4	-80.25
505598	[ALLEN 4	138.00]	AMP	5477.7	-76.43
505602	[S BROWN4	138.00]	AMP	8061.5	-77.45
510881	[ALLENGT4	138.00]	AMP	10312.2	-78.88
510897	[LONEOAK4	138.00]	AMP	8571.0	-80.25
520986	[MANNING4	138.00]	AMP	4258.5	-80.24
521071	[TUPLOTP4	138.00]	AMP	10367.6	-78.88
521188	[ATKWEST4	138.00]	AMP	5189.0	-80.78
585330	[ASGI-2015-0	0138.00]	AMP	4686.3	-80.23
588280	[ASGI1612	138.00]	AMP	5869.8	-79.98
505596	[EXPLOR 4	138.00]	AMP	5414.0	-76.12
505604	DENISON4	138.00]	AMP	3068.7	-75.83
510880	COALGTP4	138.00]	AMP	6081.8	-77.55
510887	[АТОКА4	138.00]	AMP	5796.6	-79.47
510896	[LONEOAK2	69.000]	AMP	7025.7	-83.13
510906	[SMCALTP4	138.00]	AMP	8273.8	-80.57
510908	[MCALEST4	138.00]	AMP	9551.0	-81.93
510916	ALLEN4	138.00]	AMP	5470.3	-76.43
510935	[EXPCOLT4	138.00]	AMP	7515.2	-77.69
510944	[ENOWILT4	138.00]	AMP	8400.2	-79.87
515157	[BROWN 4	138.00]	AMP	8021.4	-77.39
515159	[COLBRTP4	138.00]	AMP	6141.1	-76.06
515192	[LULA 4	138.00]	AMP	9192.9	-79.26
520418	LIMESTONEJ4	138.00]	AMP	3540.7	-80.24
520844	CARBON 4	138.00]	AMP	6628.0	-80.21
521044	RUSSETT4	138.00]	AMP	10861.7	-77.84
521075	STONEWAL L	H138.00]	AMP	8615.8	-77.90
521108	KRSYJCTN4	138.00]	AMP	7709.4	-77.95
521109	KRSYJCTS4	138.00]	AMP	7494.8	-77.63
588270	[ASGI1611	138.00]	AMP	4158.6	-77.16

ASGI-2016-013 25SP

PSS®E-32.2.0 ASCC SHORT CIRCUIT CURRENTS

THU, JUN 15 2017

10:33 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO MDWG 20255 WITH MMWG 20245, MRO & SERC 2025 SUMMER

OPTIONS USED:

- FLAT CONDITIONS

- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFOMRER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-/0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-/0 SEQUENCE
- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

				THREE PHAS	E FAULT
Х	BUS	X		/I+/	AN(I+)
520818	[ASHLAND4	138.00]	AMP	4684.1	-80.25
520862	[COLGATE4	138.00]	AMP	6023.9	-79.89
521030	[PITTSBG4	138.00]	AMP	4428.0	-80.37
588290	[ASGI1613	138.00]	AMP	4684.1	-80.25
520406	[TUPELO4	138.00]	AMP	9776.4	-79.20
521047	[SAVANNA4	138.00]	AMP	5096.9	-80.50
505600	[TUPELO 4	138.00]	AMP	10721.6	-79.04
520934	[HARTSHN4	138.00]	AMP	8477.6	-80.40
505598	[ALLEN 4	138.00]	AMP	5543.0	-76.48
505602	[S BROWN4	138.00]	AMP	8074.3	-77.43
510881	[ALLENGT4	138.00]	AMP	10374.4	-78.88
510897	[LONEOAK4	138.00]	AMP	8693.8	-80.41
520986	[MANNING4	138.00]	AMP	4288.4	-80.32
521071	[TUPLOTP4	138.00]	AMP	10427.0	-78.87
521188	[ATKWEST4	138.00]	AMP	5200.9	-80.78
585330	[ASGI-2015-00	0138.00]	AMP	4699.2	-80.23
588280	[ASGI1612	138.00]	AMP	5887.2	-79.97
505596	[EXPLOR 4	138.00]	AMP	5538.7	-76.24
505604	[DENISON4	138.00]	AMP	3070.6	-75.83
510880	[COALGTP4	138.00]	AMP	6100.4	-77.54
510887	[ATOKA4	138.00]	AMP	5810.7	-79.47
510896	[LONEOAK2	69.000]	AMP	7052.0	-83.21
510906	[SMCALTP4	138.00]	AMP	8396.3	-80.73
510908	[MCALEST4	138.00]	AMP	9717.4	-82.14
510916	[ALLEN4	138.00]	AMP	5535.4	-76.48
510935	[EXPCOLT4	138.00]	AMP	7548.2	-77.68
510944	[ENOWILT4	138.00]	AMP	8517.2	-80.02
515157	[BROWN 4	138.00]	AMP	8034.1	-77.38
515159	[COLBRTP4	138.00]	AMP	6148.5	-76.04
515192	[LULA 4	138.00]	AMP	9233.0	-79.26
520418	[LIMESTONEJ4	138.00]	AMP	3561.4	-80.30
520844	[CARBON 4	138.00]	AMP	6717.9	-80.36
521044	[RUSSETT4	138.00]	AMP	10881.1	-77.82
521075	[STONEWAL LH	138.00]	AMP	8656.0	-77.89
521108	[KRSYJCTN4	138.00]	AMP	7720.9	-77.94
521109	[KRSYJCTS4	138.00]	AMP	7505.9	-77.62
588270	[ASGI1611	138.00]	AMP	4195.6	-77.20

CONCLUSION

An Affected System Interconnection Customer has requested an Affected System Impact Study (ASIS) consistent with Southwest Power Pool (SPP) Open Access Transmission Tariff (OATT) for interconnection requests into the system of PEC. The PEC facilities connect with the facilities of SWPA and WFEC. The three Group 14 requests in this study are: ASGI-2016-011, ASGI-2016-012, & ASGI-2016-013. All three requests are thermal units totaling 7.4, 61.7, and 4.9 MW, respectively.

Power flow and stability analysis has determined that ASGI-2016-011, ASGI-2016-012, & ASGI-2016-013 can interconnect all of their respective generation (mentioned above) with ERIS prior to the completion of the required Network Upgrades, listed within **Table 2** of this report. It should be noted that although this ASIS analyzed many of the most probable contingencies, it is not an all-inclusive list that can account for every operational situation. Additionally, the generator may not be able to inject any power onto the Transmission System due to constraints that fall below the threshold of mitigation for a Generator Interconnection request. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to **0 MW** under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Transient stability analysis for this ASIS has determined that no violations were observed for the transmission system for the forty-nine (49) selected faults for the interconnection of ASGI-2016-011, ASGI-2016-012, and ASGI-2016-013.

Any changes to these assumptions may require a re-study of this ASIS at the expense of the Customer. Changed assumptions may include, but are not limited to: one or more previously-queued requests not included within this study executing an interconnection agreement and commencing commercial operation.

Nothing in this System Impact Study constitutes a request for transmission service or confers upon the Interconnection Customer any right to receive transmission service.