



SCREENING STUDY

SPP-DPT-2016-001

Published on 03/18/2016

By SPP Engineering, SPP Transmission Service Studies

REVISION HISTORY

DATE OR VERSION NUMBER	AUTHOR	CHANGE DESCRIPTION	COMMENTS
3/18/2016	SPP	Original	

CONTENTS

Revision History i

Executive Summary 1

Introduction 2

Study Methodology 3

Study Results 5

Conclusion 6

Appendix A 7

EXECUTIVE SUMMARY

Oklahoma Municipal Power Authority has requested a screening study to determine the impacts on SPP and first-tier third party facilities due to a Delivery Point Transfer of 8 MW. Third party includes both first-tier neighboring facilities outside SPP and Transmission Owner facilities within SPP that are not under the SPP OATT. The service type requested for this screening study is Delivery Point Transfer (DPT). The period of the service requested is from 6/1/2016 to 6/1/2026.

The principal objective of this study is to identify system problems and potential system modifications necessary to facilitate the DPT request while maintaining system reliability. The DPT request was studied using two system scenarios. The service was modeled by a transfer from OMPA to WFEC. The two scenarios were studied to capture system limitations caused or impacted by the requested service. An analysis was conducted on the planning horizon.

The requested service does not significantly impact facilities on the SPP system. Tables 1 and 2 summarize the results of the screening study analysis for the new source location for the scenarios listed in the table. Table 1 lists SPP and first-tier third party thermal transfer limitations identified. Table 2 lists SPP and first-tier third party voltage transfer limitations identified. Table 3 lists the network upgrades required to mitigate the limitations impacted by this request. Table 4 lists the potential redispatch relief pairs to prevent deferral of service, if applicable.

INTRODUCTION

Oklahoma Municipal Power Authority has requested a screening study to determine the impacts on SPP and first-tier third party facilities for a Delivery Point Transfer of 8 MW. The principal objective of this study is to identify the constraints on the SPP and first-tier third party transmission systems that may limit the requested service and to determine the potential least cost solutions required to alleviate the limiting facilities.

This study includes steady-state contingency analysis (PSS/E function ACCC). The steady-state analysis considers the impact of the request on transmission line and transformer loadings, and bus voltages for outages of single transmission lines, transformers, and generating units, and selected multiple transmission lines and transformers on the SPP and first-tier third party systems.

The DPT request was studied using two system scenarios. The service was modeled by a transfer from OMPA to WFEC. Two scenarios were studied to capture the system limitations caused or impacted by the requested service. Scenario 0 includes projected usage of transmission service included in the SPP 2015 Series Cases. Scenario 5 includes transmission service not already included in the SPP 2015 Series Cases.

STUDY METHODOLOGY

DESCRIPTION

The facility study analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier non-SPP control area systems. The steady-state analysis was performed consistent with current SPP Criteria and NERC Reliability Standards requirements. SPP conforms to NERC Reliability Standards, which provide strict requirements related to voltage violations and thermal overloads during normal conditions and during a contingency. NERC Standards require all facilities to be within normal operating ratings for normal system conditions and within emergency ratings after a contingency.

Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP Model Development Working Group (MDWG) models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 105% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 103.5% and 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69 kV and above; first tier non-SPP control area branches and ties 115 kV and above; any defined contingencies for these control areas; and generation unit outages for the control areas with SPP reserve share program redispatch. The monitored elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier non-SPP control area branches and ties 115 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3% transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier non-SPP control area facilities, a 3% TDF cutoff was applied to AECL, AMRN (Ameren), and ENTR (Entergy) control areas. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

MODEL DEVELOPMENT

SPP used five seasonal models to study the 8 MW DPT request for the requested service period. The following SPP Transmission Expansion Plan 2015 Series (2016 ITP Near Term) Cases were used to study the impact of the requested service on the transmission system:

- 2016 Summer Peak (16SP)
- 2016/17 Winter Peak (16WP)
- 2017 Summer Peak (17SP)
- 2017/18 Winter Peak (17WP)
- 2020 Summer Peak (20SP)
- 2020/21 Winter Peak (20WP)
- 2025 Summer Peak (25SP)
- 2025/26 Winter Peak (25WP)

The Summer Peak models apply to June through September and the Winter Peak models apply to December through March.

The chosen base case models were modified to reflect the current modeling information. One group of requests was developed from the aggregate to model the requested service. From the seasonal models, two system scenarios were developed. Scenario 0 includes projected usage of transmission included in the SPP 2015 Series Cases. Scenario 5 includes transmission service not already included in the SPP 2015 Series Cases.

TRANSMISSION REQUEST MODELING

NITS requests are modeled as Generation to Load transfers in addition to Generation to Generation transfers. NITS requests are modeled as Generation to Load transfers in addition to Generation to Generation because the requested NITS is a request to serve network load with the new designated network resource, and the impacts on Transmission System are determined accordingly. PTP Transmission Service requests are modeled as Generation to Generation transfers. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the request source and redispatching the request sink.

TRANSFER ANALYSIS

Using the selected cases both with and without the requested transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. TDF cutoffs (SPP and 1st-Tier) and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

STUDY RESULTS

STUDY ANALYSIS RESULTS

Tables 1 and 2 contain the initial steady-state analysis results of the DPT. The tables are attached to the end of this report, if applicable. The tables identify the scenario and season in which the event occurred, the transfer amount studied, the facility control area location, applicable ratings of the thermal transfer limitations and voltage transfer limitations, and the loading percentage and voltage per unit (pu).

TABLE 1

Table 1 lists the SPP and first-tier third party thermal transfer limitations caused or impacted by the 8 MW transfer for applicable scenarios. Solutions are identified for the limitations in this table.

TABLE 2

Table 2 lists the SPP and first-tier third party voltage transfer limitations caused or impacted by the 8 MW transfer for applicable scenarios. Solutions are identified for the violations in this table.

TABLE 3

Table 3 lists the network upgrades required to mitigate the limitations caused or impacted by this request. Engineering and construction costs are provided for assigned upgrades in this table.

TABLE 4

Table 4 lists the potential redispatch relief pairs to prevent deferral of service.

CONCLUSION

The results of the screening study show that limiting constraints do not exist on the SPP system for the 8 MW DPT. No new Network Upgrades are required to support the requested transfer. Redispatch is required to mitigate impacts for which Network Upgrades have been previously approved. Potential redispatch pairs are identified in Table 4. Since no additional limitations were identified, the request will be accepted. Once the request has been confirmed, SPP will issue a service agreement.

APPENDIX A

PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

BASE CASE SETTINGS:

- Solutions: Fixed slope decoupled Newton-Raphson solution (FDNS)
- Tap adjustment: Stepping
- Area Interchange Control: Tie lines and loads
- Var limits: Apply immediately
- Solution Options:
 - Phase shift adjustment
 - Flat start
 - Lock DC taps
 - Lock switched shunts

ACCC CASE SETTINGS:

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- System intact rating: Rate A
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3mw
- Excl'd cases w/ no overloads from report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. Case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution:
- Tap adjustment: Stepping
- Area interchange control: Tie lines and loads (Disabled for generator outages)
- Var limits: Apply immediately
- Solution options:
 - Phase shift adjustment
 - Flat start
 - Lock DC taps
 - Lock switched shunts

Table 1 - SPP Facility Thermal Transfer Limitations

Scenario	Season	From Area	To Area	Monitored Branch Over 100% Rate B	Base Case Loading (%)	Transfer Case Loading (%)	TDF (%)	Outaged Branch Causing Overload	Upgrade Name	Solution
5	17SP	OKGE	OKGE	FPL SWITCH - WOODWARD 138KV CKT 1	101.5	103.5	35.7%	MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1	Multi - Woodward District EHV - Tatonga - Mathewson - Cimarron 345 kV	Build new 126 mile Woodward - Tatonga 345 kV circuit 2 and Tatonga - Mathewson - Cimarron 345 kV line.
5	20SP	OKGE	WFEC	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	100.9	101.4	4.2%	ANADARKO - POCASSETT 138KV CKT 1	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	Reconductor 1.27 mile Franklin SW - Midwest Tap to 1590AS52 conductor
5	20SP	OKGE	WFEC	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	99.9	100.8	12.8%	CANADIAN - CEDAR LANE 138KV CKT 1	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	Reconductor 1.27 mile Franklin SW - Midwest Tap to 1590AS52 conductor
5	25SP	OKGE	WFEC	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	99.6	100.7	4.2%	ANADARKO - POCASSETT 138KV CKT 1	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	Reconductor 1.27 mile Franklin SW - Midwest Tap to 1590AS52 conductor

Table 2 - SPP Facility Voltage Transfer Limitations

Scenario	Season	Area	Monitored Bus with Violation	Post-transfer Voltage (PU)	Outaged Branch Causing Overload	Upgrade Name	Solution
			None				

Table 3 - Upgrade Requirements and Solutions Needed

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost	NTC
	None					

Construction Pending Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost	NTC
	None					

Expansion Plan Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
	None			

Reliability Projects - The requested service is contingent upon completion of the following upgrades. Cost is not assignable to the transmission customer.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)
OKGE	Multi - Woodward District EHV - Tatonga - Matthewson - Cimarron 345 kV	Build new 126 mile Woodward - Tatonga 345 kV circuit 2 and Tatonga - Matthewson - Cimarron 345 kV line.	6/1/2017	3/1/2021
OKGE	FRANKLIN SW - MIDWEST TAP 138KV CKT 1	Reconductor 1.27 mile Franklin SW - Midwest Tap to 1590A552 conductor	6/1/2018	6/1/2021

Table 4 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

Upgrade: Multi - Woodward District EHV - Tatonga - Mathewson - Cimarron 345 KV
Limiting Facility: FPL SWITCH - WOODWARD 138KV CKT 1
Direction: TO->FROM
Line Outage: MATHWSN7 345.0V - TATONGA7 345.0V 345KV CKT 1
Flowgate: 2015AGZAFS1171955175P
Date Redispatch Needed: Starting 2017 6/1 - 10/1 Until EOC of Upgrade
Season Flowgate Identified: 2017 Summer Peak

Table with columns: Reservation, Relief Amount, Aggregate Relief Amount, Source Control Area, Source, Maximum Increment (MW), GSF, Sink Control Area, Sink, Maximum Decrement (MW), GSF, Factor, and Aggregate Redispatch Amount (MW).

Table 4 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

OKGE	MUSTANG 69KV	53	-0.02522	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.04133	64
OKGE	MUSTANG 69KV	53	-0.02522	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.04142	64
OKGE	MUSTANG 69KV	53	-0.02522	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.04133	64
AEPW	SOUTHWESTERN STATION 138KV	302	-0.0248	WERE	GILL ENERGY CENTER 138KV	26	0.01649	-0.04129	64
AEPW	SOUTHWESTERN STATION 138KV	302	-0.0248	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.041	64
GRDA	BOOMER 69KV	24	-0.0226	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.04073	65
OKGE	MUSTANG 138KV	149.5	-0.0239	WERE	GILL ENERGY CENTER 138KV	26	0.01649	-0.04039	65
OMPA	OMPA-PONCA CITY 69KV	128.8107	-0.02591	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.04005	65
AEPW	SOUTHWESTERN STATION 138KV	302	-0.0248	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.04091	65
AEPW	SOUTHWESTERN STATION 138KV	302	-0.0248	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.04091	65
GRDA	BOOMER 69KV	24	-0.0226	WERE	MARSHGEN1 0.6900 34KV	30	0.01721	-0.03981	66
OKGE	HORSESHOE LAKE 138KV	294	-0.02221	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.04034	66
OKGE	MCCLAIN 138KV	38.4023	-0.02295	WERE	MARSHGEN1 0.6900 34KV	30	0.01721	-0.04016	66
OKGE	MUSTANG 138KV	149.5	-0.0239	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.04001	66
OKGE	MUSTANG 138KV	149.5	-0.0239	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.0401	66
OKGE	MUSTANG 138KV	149.5	-0.0239	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.04001	66
OKGE	MUSTANG 69KV	53	-0.02522	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.03981	66
OKGE	HORSESHOE LAKE 138KV	294	-0.02221	WERE	MARSHGEN1 0.6900 34KV	30	0.01721	-0.03942	67
OKGE	MCCLAIN 138KV	38.4023	-0.02295	WERE	GILL ENERGY CENTER 138KV	26	0.01649	-0.03944	67
OMPA	OMPA-PONCA CITY 69KV	128.8107	-0.02591	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.03944	67
OMPA	OMPA-PONCA CITY 69KV	128.8107	-0.02591	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.03971	67
OKGE	REDBUD 345KV	166	-0.02124	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.03937	67
AEPW	SOUTHWESTERN STATION 138KV	302	-0.0248	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.03939	67
OKGE	SPRING CREEK UNIT 3 AND 4 345KV	36	-0.02142	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.03955	67
OKGE	TINKER 5G 138KV	62	-0.02157	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.0397	67
GRDA	BOOMER 69KV	24	-0.0226	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.03871	68
GRDA	BOOMER 69KV	24	-0.0226	WERE	GILL ENERGY CENTER 138KV	26	0.01649	-0.03909	68
GRDA	BOOMER 69KV	24	-0.0226	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.0388	68
GRDA	BOOMER 69KV	24	-0.0226	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.03871	68
OKGE	HORSESHOE LAKE 138KV	294	-0.02221	WERE	GILL ENERGY CENTER 138KV	26	0.01649	-0.0387	68
OKGE	MCCLAIN 138KV	38.4023	-0.02295	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.03906	68
OKGE	MCCLAIN 138KV	38.4023	-0.02295	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.03915	68
OKGE	MCCLAIN 138KV	38.4023	-0.02295	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.03906	68
OKGE	MUSTANG 69KV	53	-0.02522	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.03875	68
OKGE	MUSTANG 69KV	53	-0.02522	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.03902	68
AEPW	SOUTHWESTERN STATION 138KV	302	-0.0248	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.0386	68
OKGE	SPRING CREEK UNIT 3 AND 4 345KV	36	-0.02142	WERE	MARSHGEN1 0.6900 34KV	30	0.01721	-0.03863	68
OKGE	TINKER 5G 138KV	62	-0.02157	WERE	MARSHGEN1 0.6900 34KV	30	0.01721	-0.03878	68
OKGE	HORSESHOE LAKE 138KV	294	-0.02221	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.03832	69
OKGE	HORSESHOE LAKE 138KV	294	-0.02221	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.03841	69
OKGE	HORSESHOE LAKE 138KV	294	-0.02221	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.03832	69
OKGE	MUSTANG 138KV	149.5	-0.0239	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.03849	69
OKGE	REDBUD 345KV	166	-0.02124	WERE	MARSHGEN1 0.6900 34KV	30	0.01721	-0.03845	69
AEPW	SOUTHWESTERN STATION 138KV	302	-0.0248	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.03833	69
OKGE	TINKER 5G 138KV	62	-0.02157	WERE	GILL ENERGY CENTER 138KV	26	0.01649	-0.03806	69
WFEC	ANADARKO 69KV	70	-0.02783	WERE	COFFEY CO SUB 34KV	401	0.01014	-0.03797	70
OKGE	MCCLAIN 138KV	38.4023	-0.02295	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.03754	70
OKGE	MUSTANG 138KV	149.5	-0.0239	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.0377	70
OKGE	REDBUD 345KV	166	-0.02124	WERE	GILL ENERGY CENTER 138KV	26	0.01649	-0.03773	70
OKGE	SPRING CREEK UNIT 3 AND 4 345KV	36	-0.02142	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.03753	70
OKGE	SPRING CREEK UNIT 3 AND 4 345KV	36	-0.02142	WERE	GILL ENERGY CENTER 138KV	26	0.01649	-0.03791	70
OKGE	SPRING CREEK UNIT 3 AND 4 345KV	36	-0.02142	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.03762	70
OKGE	SPRING CREEK UNIT 3 AND 4 345KV	36	-0.02142	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.03753	70
OKGE	TINKER 5G 138KV	62	-0.02157	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.03768	70
OKGE	TINKER 5G 138KV	62	-0.02157	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.03777	70
OKGE	TINKER 5G 138KV	62	-0.02157	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.03768	70
GRDA	BOOMER 69KV	24	-0.0226	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.03719	71
OKGE	MUSTANG 138KV	149.5	-0.0239	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.03743	71
OKGE	REDBUD 345KV	166	-0.02124	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.03735	71
OKGE	REDBUD 345KV	166	-0.02124	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.03744	71
OKGE	REDBUD 345KV	166	-0.02124	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.03735	71
OKGE	SEMINOLE 345KV	559.6	-0.01884	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.03697	71
OKGE	HORSESHOE LAKE 138KV	294	-0.02221	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.0368	72
OKGE	MCCLAIN 138KV	38.4023	-0.02295	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.03648	72
OKGE	MCCLAIN 138KV	38.4023	-0.02295	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.03675	72
OKGE	SEMINOLE 138KV	302.5742	-0.0187	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.03683	72
OKGE	HORSESHOE LAKE 138KV	294	-0.02221	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.03601	73
OMPA	OMPA-PONCA CITY 69KV	128.8107	-0.02591	WERE	COFFEY CO SUB 34KV	401	0.01014	-0.03605	73
OKGE	SEMINOLE 345KV	559.6	-0.01884	WERE	MARSHGEN1 0.6900 34KV	30	0.01721	-0.03605	73
OKGE	SPRING CREEK UNIT 3 AND 4 345KV	36	-0.02142	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.03601	73
OKGE	TINKER 5G 138KV	62	-0.02157	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.03616	73
OKGE	HORSESHOE LAKE 138KV	294	-0.02221	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.03574	74
OKGE	REDBUD 345KV	166	-0.02124	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.03583	74
OKGE	SEMINOLE 138KV	302.5742	-0.0187	WERE	MARSHGEN1 0.6900 34KV	30	0.01721	-0.03591	74
OKGE	MUSTANG 69KV	53	-0.02522	WERE	COFFEY CO SUB 34KV	401	0.01014	-0.03536	75
OKGE	REDBUD 345KV	166	-0.02124	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.03504	75
OKGE	SEMINOLE 138KV	302.5742	-0.0187	WERE	GILL ENERGY CENTER 138KV	26	0.01649	-0.03519	75
OKGE	SEMINOLE 345KV	559.6	-0.01884	WERE	GILL ENERGY CENTER 138KV	26	0.01649	-0.03533	75
OKGE	SEMINOLE 345KV	559.6	-0.01884	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.03504	75
OKGE	SPRING CREEK UNIT 3 AND 4 345KV	36	-0.02142	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.03522	75
OKGE	TINKER 5G 138KV	62	-0.02157	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.0351	75
OKGE	TINKER 5G 138KV	62	-0.02157	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.03537	75
WFEC	ANADARKO 69KV	70	-0.02783	WERE	ELK RIVER 345KV	150	0.0068	-0.03463	76
OKGE	REDBUD 345KV	166	-0.02124	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.03477	76
OKGE	SEMINOLE 138KV	302.5742	-0.0187	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.03481	76
OKGE	SEMINOLE 138KV	302.5742	-0.0187	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.0349	76
OKGE	SEMINOLE 138KV	302.5742	-0.0187	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.03481	76
OKGE	SEMINOLE 345KV	559.6	-0.01884	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.03495	76
OKGE	SEMINOLE 345KV	559.6	-0.01884	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.03495	76
AEPW	SOUTHWESTERN STATION 138KV	302	-0.0248	WERE	COFFEY CO SUB 34KV	401	0.01014	-0.03494	76
OKGE	SPRING CREEK UNIT 3 AND 4 345KV	36	-0.02142	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.03495	76
WFEC	ANADARKO 69KV	70	-0.02783	WERE	CANEYWF1 0.6900 34KV	199.8	0.00616	-0.03399	78
OKGE	MUSTANG 138KV	149.5	-0.0239	WERE	COFFEY CO SUB 34KV	401	0.01014	-0.03404	78
OKGE	SEMINOLE 138KV	302.5742	-0.0187	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.03329	79
OKGE	SEMINOLE 345KV	559.6	-0.01884	WERE	TECUMSEH ENERGY CENTER 115KV	70	0.01459	-0.03343	79
OKGE	MCCLAIN 138KV	38.4023	-0.02295	WERE	COFFEY CO SUB 34KV	401	0.01014	-0.03309	80

Table 4 - Potential Redispatch Relief Pairs to Prevent Deferral of Service

AEPW	WELLETTKA 138KV	157	-0.01484	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.03297	80
OMPA	OMPA-PONCA CITY 69KV	128.8107	-0.02591	WERE	ELK RIVER 345KV	150	0.00668	-0.03271	81
OKGE	SEMINOLE 138KV	302.5742	-0.0187	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.0325	81
OKGE	SEMINOLE 345KV	559.6	-0.01884	WERE	LAWRENCE ENERGY CENTER 230KV	369.9012	0.0138	-0.03264	81
OKGE	HORSESHOE LAKE 138KV	294	-0.02221	WERE	COFFEY CO SUB 34KV	401	0.01014	-0.03235	82
OMPA	OMPA-PONCA CITY 69KV	128.8107	-0.02591	WERE	CANEYWF1 0.6900 34KV	199.8	0.00616	-0.03207	82
OKGE	SEMINOLE 138KV	302.5742	-0.0187	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.03223	82
OKGE	SEMINOLE 345KV	559.6	-0.01884	WERE	LAWRENCE ENERGY CENTER 115KV	105	0.01353	-0.03237	82
AEPW	WELLETTKA 138KV	157	-0.01484	WERE	MARSHGEN1 0.6900 34KV	30	0.01721	-0.03205	82
OKGE	MUSTANG 69KV	53	-0.02522	WERE	ELK RIVER 345KV	150	0.0068	-0.03202	83
OKGE	TINKER 5G 138KV	62	-0.02157	WERE	COFFEY CO SUB 34KV	401	0.01014	-0.03171	83
OKGE	MUSTANG 69KV	53	-0.02522	WERE	CANEYWF1 0.6900 34KV	199.8	0.00616	-0.03138	84
OKGE	PALDRW21 34.500 345KV	300	0.08398	OKGE	CRSRDW21 34.500 345KV	197.8	0.11547	-0.03149	84
OKGE	PALDRW21 34.500 345KV	300	0.08398	OKGE	SILNGW21 34.500 345KV	100	0.11547	-0.03149	84
OKGE	PALDRW21 34.500 345KV	300	0.08398	OKGE	SLINGW11 34.500 345KV	199	0.11547	-0.03149	84
OKGE	REDBUD 345KV	166	-0.02124	WERE	COFFEY CO SUB 34KV	401	0.01014	-0.03138	84
AEPW	SOUTHWESTERN STATION 138KV	302	-0.0248	WERE	ELK RIVER 345KV	150	0.0068	-0.0316	84
OKGE	SPRING CREEK UNIT 3 AND 4 345KV	36	-0.02142	WERE	COFFEY CO SUB 34KV	401	0.01014	-0.03156	84
AEPW	SOUTHWESTERN STATION 138KV	302	-0.0248	WERE	CANEYWF1 0.6900 34KV	199.8	0.00616	-0.03096	85
AEPW	WELLETTKA 138KV	157	-0.01484	WERE	EMPORIA ENERGY CENTER 345KV	180	0.01611	-0.03095	85
AEPW	WELLETTKA 138KV	157	-0.01484	WERE	JEFFREY ENERGY CENTER 230KV	730	0.0162	-0.03104	85
AEPW	WELLETTKA 138KV	157	-0.01484	WERE	JEFFREY ENERGY CENTER 345KV	1460	0.01611	-0.03095	85
AEPW	COGENTRIX 345KV	381.723	-0.01255	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.03068	86
OKGE	MUSTANG 138KV	149.5	-0.0239	WERE	ELK RIVER 345KV	150	0.0068	-0.0307	86
AEPW	RIVERSIDE STATION 138KV	141.6538	-0.0125	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.03063	86
OKGE	MUSKOGEE 345KV	37.5	-0.01213	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.03026	87
AEPW	TULSA POWER STATION 138KV	318	-0.01232	WERE	EVANS ENERGY CENTER 138KV	514.7959	0.01813	-0.03045	87
OKGE	MUSTANG 138KV	149.5	-0.0239	WERE	CANEYWF1 0.6900 34KV	199.8	0.00616	-0.03006	88

Maximum Decrement and Maximum Increment were determined from the Source and Sink Operating Points in the study models where limiting facility was identified.

Factor = Source GSF - Sink GSF

Redispatch Amount = Relief Amount / Factor