



# **GENERATOR INTERCONNECTION AFFECTED SYSTEM IMPACT STUDY REPORT**

ASGI-2017-009

Published October 2017

By SPP Generator Interconnections Dept.

# REVISION HISTORY

---

Date	Author	Change Description
10/11/2017	SPP	Affected System Impact Study for ASGI-2017-009 Report Revision 0 Issued

## EXECUTIVE SUMMARY

---

An Affected System Interconnection Customer has requested an Affected System Impact Study (ASIS) consistent with Southwest Power Pool (SPP) Open Access Transmission Tariff (OATT) for interconnection requests into the system of Associated Electric Cooperative Inc. (AECI). AECI request GI-57/SIS-28, 200 MW wind generating facility, has been assigned the SPP queue identifier ASGI-2017-009.

This ASIS addresses the effects to the SPP system of interconnecting the generators to the AECI transmission system for the system topology and requests included in SPP DISIS-2016-001. ASGI-2017-009 is requesting the interconnection of one-hundred-three (103) Vestas V110 2.0 MW wind turbines for a total of 200MW injection at the Point of Interconnection (POI) and associated facilities interconnecting to AECI at the Fairfax 138 kV substation in Osage County, OK.

The ASIS analysis has determined that the ASGI-2017-009 request can interconnect 200.0 MW of generation with Energy Resource Interconnection Service (ERIS) with the study dispatch assumption listed in **Table 1** after the completion of the required Network Upgrades, listed within **Table 2A or Table 2B** of this report depending on the which higher queued AECI upgrade set is assigned to ASGI-2017-005 (AECI GIA-052). AECI upgrade sets are listed in **Table 6 and Table 7**.

It should be noted that although this ASIS analyzed many of the most probable contingencies, it is not an all-inclusive list that can account for every operational situation. Additionally, the generator may not be able to inject any power onto the Transmission System due to constraints that fall below the threshold of mitigation for a Generator Interconnection request. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to **0 MW** under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Transient stability analysis for this ASIS has determined that issues were observed as listed in **Table 4** for the transmission system for the thirty-five (35) selected faults for the interconnection of ASGI-2017-009 and the analysis shows that the generators will meet Low Voltage Ride-Through (LVRT) requirements of FERC Order #661A. As discussed above, this amount may be reduced further dependent upon system conditions.

Nothing in this study should be construed as a guarantee of delivery or transmission service. If the customer(s) wishes to move power across the facilities of SPP, a separate request for transmission service must be made on Southwest Power Pool's OASIS by the Customer(s).

# TABLE OF CONTENTS

---

<b>Revision History</b> .....	<b>i</b>
<b>Executive Summary</b> .....	<b>i</b>
<b>Table of Contents</b> .....	<b>ii</b>
<b>Purpose</b> .....	<b>3</b>
<b>Facilities</b> .....	<b>8</b>
Generating Facility .....	8
Interconnection Facilities.....	8
Base Case Network Upgrades.....	8
<b>Power Flow Analysis</b> .....	<b>9</b>
Model Preparation .....	9
Study Methodology and Criteria.....	10
Thermal Overloads .....	10
Voltage .....	11
Results.....	12
Curtailment and System Reliability .....	12
<b>Stability Analysis</b> .....	<b>13</b>
Model Preparation .....	13
Disturbances.....	13
Results.....	19
FERC LVRT Compliance .....	20
<b>Short Circuit Analysis</b> .....	<b>21</b>
<b>Conclusion</b> .....	<b>26</b>
<b>AECI Upgrade Sets</b> .....	<b>27</b>
<b>Thermal and Steady State Voltage Constraints Tables Base On AECI Upgrade Set #1</b> .....	<b>28</b>
<b>Thermal and Steady State Voltage Constraints Tables Base On AECI Upgrade Set #2</b> .....	<b>47</b>

## PURPOSE

---

An Affected System Interconnection Customer has requested an Affected System Impact Study (ASIS) consistent with the Southwest Power Pool (SPP) Open Access Transmission Tariff (OATT) for interconnection requests into the system of Associated Electric Cooperative Inc. (AECI).

The purpose of this study is to evaluate the impacts of interconnecting the AECI GI-52/SIS-28 request assigned the SPP queue identifier ASGI-2017-009. ASGI-2017-009 is requesting the interconnection of one-hundred-three (103) Vestas V110 2.0 MW wind turbines for a total of 200MW injection at the Point of Interconnection (POI) and associated facilities interconnecting to AECI at the Remington 138 kV substation in Osage County, OK.

The ASIS considers the Base Case as well as all Generating Facilities (and with respect to (b) below, any identified Network Upgrades associated with such higher queued interconnection) that, on the date the ASIS is commenced:

- a) are directly interconnected to the Transmission System;
- b) are interconnected to Affected Systems and may have an impact on the Interconnection Request;
- c) have a pending higher queued Interconnection Request to interconnect to the Transmission System listed in **Table 1**; or
- d) have no Queue Position but have executed an LGIA or requested that an unexecuted LGIA be filed with FERC.

Any changes to these assumptions, for example, one or more of the previously queued requests not included within this study execute an interconnection agreement and commencing commercial operation, may require a re-study of this ASIS at the expense of the Customer(s).

Nothing within this System Impact Study constitutes a request for transmission service or confers upon the Interconnection Customer(s) any right to receive transmission service rights. Should the Customer(s) require transmission service, those rights should be requested through SPP's Open Access Same-Time Information System (OASIS) or that of the applicable transmission provider.

This ASIS included prior queued generation interconnection requests. Those listed within **Table 1** are the generation interconnection requests that are assumed to have rights to either full or partial interconnection service prior to the requested in-service for this ASIS. Also listed in **Table 1** are both the amount of MW of interconnection service expected at the effective time of this study and the total MW requested of interconnection service, the fuel type, the Point of Interconnection (POI), and the current status of each particular prior queued request.

Table 1: Generation Requests Included within ASIS

Project	MW	Fuel Source	POI	Status
ASGI-2010-006	150	Wind	Remington 138kV	Commercial Operation
ASGI-2014-014	56.4	Thermal	Ferguson 69kV	Commercial Operation
ASGI-2015-004	56.36	Thermal	Coffeyville City 69kV	Commercial Operation
GEN-2002-004	200	Wind	Latham 345kV	Commercial Operation
GEN-2005-013	201	Wind	Caney River 345kV	Commercial Operation
GEN-2007-025	300	Wind	Viola 345kV	Commercial Operation
GEN-2008-013	300	Wind	Hunter 345kV	Commercial Operation
GEN-2008-021	42	Nuclear	Wolf Creek 345kV	Commercial Operation
GEN-2008-098	100.8	Wind	Waverly 345kV	Commercial Operation
GEN-2009-025	59.8	Wind	Nardins 69kV	Commercial Operation
GEN-2010-003	100.8	Wind	Waverly 345kV	Commercial Operation
GEN-2010-005	299.2	Wind	Viola 345kV	Commercial Operation
GEN-2010-055	4.5	Gas	Wekiwa 138kV	Commercial Operation
GEN-2011-057	150.4	Wind	Creswell 138kV	Commercial Operation
GEN-2012-032	300	Wind	Open Sky 345kV	Commercial Operation
GEN-2012-033	98.1	Wind	Tap and Tie South 4th - Bunch Creek & Enid Tap - Fairmont (GEN-2012-033T) 138kV	Commercial Operation
GEN-2012-041	121.5	CT	Ranch Road 345kV	Commercial Operation
GEN-2013-012	147	Gas	Redbud 345kV	Commercial Operation
GEN-2013-028	559.5	Gas	Tap N Tulsa - GRDA 1 345kV	IA Executed/On schedule for 2017 COD
GEN-2013-029	300	Wind	Renfrow 345kV	Commercial Operation
GEN-2014-001	200.6	Wind	Tap Wichita - Emporia Energy Center (GEN-2014-001 Tap) 345kV	IA Executed/On Suspension
GEN-2014-028	35	CC	Riverton 161kV	Commercial Operation
GEN-2014-064	248.4	Wind	Otter 138kV	IA Executed/On Suspension
GEN-2015-001	200	Wind	Ranch Road 345kV	Commercial Operation
GEN-2015-015	154.6	Wind	Tap Medford Tap - Coyote 138kV	IA Executed/On schedule for 2017 COD
GEN-2015-016	200	Wind	Tap Marmaton - Centerville 161kV	IA Executed/On schedule for 2018 COD
GEN-2015-024	220	Wind	Tap Thistle - Wichita 345kV Dbl CKT	Commercial Operation
GEN-2015-025	220	Wind	Tap Thistle - Wichita 345kV Dbl CKT	Commercial Operation
GEN-2015-030	200.1	Wind	Sooner 345kV	IA Executed/On Suspension
GEN-2015-034	200	Wind	Ranch Road 345kV	Facility Study Stage
GEN-2015-047	300	Wind	Sooner 345kV	Facility Study Stage
GEN-2015-052	300	Wind	Tap Open Sky - Rose Hill 345kV	Facility Study Stage
GEN-2015-062	4.5	Wind	Tap and Tie South 4th - Bunch Creek & Enid Tap - Fairmont (GEN-2012-033T) 138kV	Facility Study Stage
GEN-2015-063	300	Wind	Tap Woodring - Mathewson 345kV	Facility Study Stage
GEN-2015-066	248.4	Wind	Tap Cleveland - Sooner 345kV	Facility Study Stage

Table 1: Generation Requests Included within ASIS

Project	MW	Fuel Source	POI	Status
GEN-2015-069	300	Wind	Union Ridge 230kV	Facility Study Stage
GEN-2015-073	200.1	Wind	Emporia Energy Center 345kV	Facility Study Stage
GEN-2015-083	125	Wind	Belle Plain 138kV	Facility Study Stage
GEN-2015-090	220	Wind	Tap Thistle - Wichita 345kV Dbl CKT	Facility Study Stage
GEN-2016-009	29	Thermal	Osage 69kV (514742)	Facility Study Stage
GEN-2016-022	151.8	Wind	Ranch Road 345kV (515576)	Facility Study Stage
GEN -2016-024	55.86	Wind	Midian 138kV (532990)	Facility Study Stage
GEN-2016-031	1.5MW uprate of GEN-2015- 001 (total = 201.3MW)	Wind	Ranch Road 345kV (515576)	Facility Study Stage
GEN-2016-032	200	Wind	Tap Marshall (514733)- Cottonwood Creek (514827) 138kV, (G16-032-TAP, 560077)	Facility Study Stage
GEN -2016-048	82.32	Solar	Sooner 138kV (514802)	Facility Study Stage
GEN-2016-060	25.3	Wind	Belle Plain 138kV (533063)	Facility Study Stage
GEN-2016-061	250.7	Wind	Tap Woodring (514715) – Sooner (514803) 345kV (G16- 061-TAP, 560084)	Facility Study Stage
GEN-2016-068	250	Wind	Woodring 345kV (514715)	Facility Study Stage
GEN-2016-071	200.1	Wind	Chilocco 138kV (521198)	Facility Study Stage
ASGI-2017-009	200	Wind	Fairfax (AECI) 138 kV	Current Study

This ASIS was required because the Affected System Interconnection Customer(s) are requesting interconnection at a location electrically close to the SPP system.

**Table 2A and Table 2B** below lists the higher queued required upgrade projects for which these requests have cost responsibility. DISIS-2016-001 Group 08 Impact Study was posted February 28, 2017.

DISIS-2016-001 reports can be located at the following Generation Interconnection Study URL:  
[http://sppoasis.spp.org/documents/swpp/transmission/GenStudies.cfm?YearType=2016\\_Impact\\_Studies](http://sppoasis.spp.org/documents/swpp/transmission/GenStudies.cfm?YearType=2016_Impact_Studies)

Table 2A: Upgrade Projects Required for Interconnection Service under AECI Upgrade Set #1

Upgrade Project	Type	Description	Status	Study Assignment
GEN-2015-063 Tap – Mathewson 345 kV CKT 1	Structure Replacements	Replace terminal equipment and structures to achieve conductor limit	IA Pending	DISIS-2015-002
Farber – Belle Plains 138kV CKT 1	Rebuild	Rebuild approximately 10 miles of 138kV from Farber – Belle Plains	Facility Study	DISIS-2016-001
Collinsville (GRDA)* – Skiatook Tap (AECI/KAMO)** 138kV CKT 1	Terminal Equipment	Replace terminal equipment to achieve at least 158MVA Summer Peak Emergency (Rate B)	Assigned to AECI Higher Queued Impact Study Assignment	Assigned to ASGI-2017-005 (AECI GIA-052) cost allocation of \$250,000
Remington (AECI/KAMO) – Shidler (AEP)* 138kV CKT 1	Rebuild	Rebuild approximately 8.6 miles of 138kV	Assigned to AECI Higher Queued Impact Study Assignment	Assigned to ASGI-2017-005 (AECI-052) per AECI Impact Study
Shidler – West Pawhuska – Pawhuska Tap – Domes – Mound Road – Bartlesville 138kV CKT 1*	Rebuild	Rebuild approximately 45 miles of 138kV from Shidler – Bartlesville 138kV to achieve at least 161MVA Summer Peak Normal (Rate A) and 234 Summer Peak Emergency (Rate B)	Assigned to AECI Higher Queued Impact Study Assignment	Assigned to ASGI-2017-005 (AECI GIA-052) cost allocation of \$37,000,000
Remington (AECI/KAMO) – Barnsdall (AEP)* 138kV CKT 1	Build	Build approximately 35 miles of 138kV to mitigate power flow Fairfax Pawnee 138kV constraints and unstable results from the transient stability analysis	Current Study	Current Study Affected System, AEP-PSO, Barnsdall Upgrade cost allocation of \$5,000,000. Cost assumes new line is built and owned by AECI.

Table 2B: Upgrade Projects Required for Interconnection Service under AECI Upgrade Set #2

Upgrade Project	Type	Description	Status	Study Assignment
Remington (AECI/KAMO) – Barnsdall (AEP)* 138kV CKT 1	Build	Build approximately 35 miles of 138kV	Assigned to AECI Higher Queued Impact Study Assignment	Assigned to ASGI-2017-005 (AECI-052) per AECI Impact Study.  Current Study Affect System, AEP-PSO, Barnsdall Upgrade cost allocation of \$5,000,000
GEN-2015-063 Tap – Mathewson 345 kV CKT 1	Structure Replacements	Replace terminal equipment and structures to achieve conductor limit	IA Pending	DISIS-2015-002
Farber – Belle Plains 138kV CKT 1	Rebuild	Rebuild approximately 10 miles of 138kV from Farber – Belle Plains	Facility Study	DISIS-2016-001
Collinsville (GRDA)* – Skiatook Tap (AECI/KAMO)** 138kV CKT 1	Terminal Equipment	Replace terminal equipment to achieve at least 158MVA Summer Peak Emergency (Rate B)	Assigned to AECI Higher Queued Impact Study Assignment	ASGI-2017-005 (AECI GIA-052) cost allocation of \$250,000
Shidler – West Pawhuska – Pawhuska Tap 138kV CKT 1*	Rebuild	Rebuild approximately 21 miles of 138kV from Shidler – Pawhuska Tap 138kV to achieve at least 155 Summer Peak Emergency (Rate B)	Assigned to AECI Higher Queued Impact Study Assignment	ASGI-2017-005 (AECI GIA-052) cost allocation of \$25,200,000
Mound Road – Bartlesville 138kV CKT 1*	Rebuild	Rebuild approximately 3 miles of 138kV from Mound Road – Bartlesville 138kV to achieve at least 155 Summer Peak Normal (Rate A) and 200 Summer Peak Emergency (Rate B)	Assigned to AECI Higher Queued Impact Study Assignment	ASGI-2017-005 (AECI GIA-052) cost allocation of \$2,500,000
Bartlesville Comanche – Bartlesville Southeast 138kV CKT 1*	Rebuild	Rebuild approximately 5 miles of 138kV from Mound Road – Bartlesville 138kV to achieve at least 157 Summer Peak Emergency (Rate B)	Current Study	ASGI-2017-009 (AECI GIA-057) cost allocation of \$5,000,000

\* Upgrades denoted will require an SPP Affected System Facilities Study agreement and deposit. These upgrades could require the need for a Construction Agreement (CA) as a result of the Affected System Facilities Study.

\*\* Upgrades denoted also require AECI review for AECI facility mitigations.

Any changes to these assumptions may require a re-study of this ASIS at the expense of the Customer(s).

Nothing in this System Impact Study constitutes a request for transmission service or grants the Interconnection Customer(s) any rights to transmission service.

# FACILITIES


## GENERATING FACILITY

The Affected System Interconnection Customers' request is the interconnection of one-hundred-three (103) Vestas V110 2.0 MW wind turbines for a total of 200MW injection at the Point of Interconnection (POI) and associated facilities interconnecting to AECl at the Remington 138 kV substation in Osage County, OK.

## INTERCONNECTION FACILITIES

The POI for ASGI-2017-009 Interconnection Customer connects to the Affected System Fairfax 138 kV substation in Osage County, OK. **Figure 1** depicts the one-line diagram for the POI and the Interconnection Request(s).

Figure 1: Proposed ASGI-2017-009 Configuration and Request Power Flow Model



## BASE CASE NETWORK UPGRADES

The Network Upgrades included within the cases used for this Affected System Impact Study are those facilities that are a part of the SPP Transmission Expansion Plan or the Balanced Portfolio projects. These facilities have an approved Notification to Construct (NTC), or are in construction stages and expected to be in-service at the effective time of this study. No other upgrades were included for this ASIS. If for some reason, construction on these projects is delayed or discontinued, a restudy may be needed to determine the interconnection service availability of the Customer(s).

# POWER FLOW ANALYSIS

---

Power flow analysis is used to determine if the transmission system can accommodate the injection from the request without violating thermal or voltage transmission planning criteria.

## *MODEL PREPARATION*

Power flow analysis was performed using modified versions of the 2015 series of 2016 ITP Near-Term study models including these seasonal models:

- Year 1 (2016) Winter Peak (16WP)
- Year 2 (2017) Spring (17G)
- Year 2 (2017) Summer Peak (17SP)
- Year 5 (2020) Light (20L)
- Year 5 (2020) Summer (20SP)
- Year 5 (2020) Winter (20WP) peak
- Year 10 (2025) Summer (25SP) peak

To incorporate the Interconnection Customers' request, a re-dispatch of existing generation within SPP and AECl was performed with respect to the amount of the Customers' injection.

For Variable Energy Resources (VER) (solar/wind) in each power flow case, ERIS, is evaluated for the generating plants within a geographical area of the interconnection request(s) for the VERs dispatched at 100% nameplate of maximum generation. The VERs in the remote areas is dispatched at 20% nameplate of maximum generation. SPP projects are dispatched across the SPP footprint using load factor ratios. AECl projects are dispatched across the AECl footprint using load factor ratios.

Peaking units are not dispatched in the Year 2 spring and Year 5 light, or in the "High VER" summer and winter peaks. To study peaking units' impacts, the Year 1 winter peak, Year 2 summer peak, and Year 5 summer and winter peaks, and Year 10 summer peak models are developed with peaking units dispatched at 100% of the nameplate rating and VERs dispatched at 20% of the nameplate rating. Each interconnection request is also modeled separately at 100% nameplate for certain analyses.

All generators (VER and peaking) that requested Network Resource Interconnection Service (NRIS) are dispatched in an additional analysis into the interconnecting Transmission Owner's (T.O.) area at 100% nameplate with Energy Resource Interconnection Service (ERIS) only requests at 80% nameplate. This method allows for identification of network constraints that are common between regional groupings to have affecting requests share the mitigating upgrade costs throughout the cluster.

For this ASIS, only the previous queued requests listed in **Table 1** were assumed to be in-service at 100% dispatch.

## ***STUDY METHODOLOGY AND CRITERIA***

### **THERMAL OVERLOADS**

Network constraints are found by using PSS/E AC Contingency Calculation (ACCC) analysis with PSS/E MUST First Contingency Incremental Transfer Capability (FCITC) analysis on the entire cluster grouping dispatched at the various levels previously mentioned.

For ERIS, thermal overloads are determined for system intact (n-0) (greater than or equal to 100% of Rate A - normal) and for contingency (n-1) (greater than or equal to 100% of Rate B - emergency) conditions.

The overloads are then screened to determine which of generator interconnection requests have at least

- 3% Distribution Factor (DF) for system intact conditions (n-0),
- 20% DF upon outage based conditions (n-1),
- or 3% DF on contingent elements that resulted in a non-converged solution.

Interconnection Requests that requested NRIS are also studied in a separate NRIS analysis to determine if any constraint measured greater than or equal to a 3% DF. If so, these constraints are also considered for transmission reinforcement under NRIS.

The contingency set includes all SPP control area branches and ties 69kV and above, first tier Non-SPP control area branches and ties 115 kV and above, any defined contingencies for these control areas, and generation unit outages for the SPP control areas with SPP reserve share program redispatch.

The monitored elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier Non-SPP control area branches and ties 69 kV and above. NERC Power Transfer Distribution Flowgates for SPP and first tier Non-SPP control area are monitored. Additional NERC Flowgates are monitored in second tier or greater Non-SPP control areas. Voltage monitoring was performed for SPP control area buses 69 kV and above.

**VOLTAGE**

For non-converged power flow solutions that are determined to be caused by lack of voltage support, appropriate transmission support will be determined to mitigate the constraint.

After all thermal overload and voltage support mitigations are determined; a full ACCC analysis is then performed to determine voltage constraints. The following voltage performance guidelines are used in accordance with the Transmission Owner local planning criteria.

**SPP Areas (69kV+):**

<b>Transmission Owner</b>	<b>Voltage Criteria (System Intact)</b>	<b>Voltage Criteria (Contingency)</b>
AEPW	0.95 – 1.05 pu	0.92 – 1.05 pu
GRDA	0.95 – 1.05 pu	0.90 – 1.05 pu
SWPA	0.95 – 1.05 pu	0.90 – 1.05 pu
OKGE	0.95 – 1.05 pu	0.90 – 1.05 pu
OMPA	0.95 – 1.05 pu	0.90 – 1.05 pu
WFEC	0.95 – 1.05 pu	0.90 – 1.05 pu
SWPS	0.95 – 1.05 pu	0.90 – 1.05 pu
MIDW	0.95 – 1.05 pu	0.90 – 1.05 pu
SUNC	0.95 – 1.05 pu	0.90 – 1.05 pu
KCPL	0.95 – 1.05 pu	0.90 – 1.05 pu
INDN	0.95 – 1.05 pu	0.90 – 1.05 pu
SPRM	0.95 – 1.05 pu	0.90 – 1.05 pu
NPPD	0.95 – 1.05 pu	0.90 – 1.05 pu
WAPA	0.95 – 1.05 pu	0.90 – 1.05 pu
WERE L-V	0.95 – 1.05 pu	0.93 – 1.05 pu
WERE H-V	0.95 – 1.05 pu	0.95 – 1.05 pu
EMDE L-V	0.95 – 1.05 pu	0.90 – 1.05 pu
EMDE H-V	0.95 – 1.05 pu	0.92 – 1.05 pu
LES	0.95 – 1.05 pu	0.90 – 1.05 pu
OPPD	0.95 – 1.05 pu	0.90 – 1.05 pu

**SPP Buses with more stringent voltage criteria:**

<b>Bus Name/Number</b>	<b>Voltage Criteria (System Intact)</b>	<b>Voltage Criteria (Contingency)</b>
TUCO 230kV 525830	0.925 – 1.05 pu	0.925 – 1.05 pu
Wolf Creek 345kV 532797	0.985 – 1.03 pu	0.985 – 1.03 pu
FCS 646251	1.001 – 1.047 pu	1.001 – 1.047 pu

**Affected System Areas (115kV+):**

<b>Transmission Owner</b>	<b>Voltage Criteria (System Intact)</b>	<b>Voltage Criteria (Contingency)</b>
AECI	0.95 – 1.05 pu	0.90 – 1.05 pu

EES-EAI	0.95 – 1.05 pu	0.90 – 1.05 pu
LAGN	0.95 – 1.05 pu	0.90 – 1.05 pu
EES	0.95 – 1.05 pu	0.90 – 1.05 pu
AMMO	0.95 – 1.05 pu	0.90 – 1.05 pu
CLEC	0.95 – 1.05 pu	0.90 – 1.05 pu
LAFA	0.95 – 1.05 pu	0.90 – 1.05 pu
LEPA	0.95 – 1.05 pu	0.90 – 1.05 pu
XEL	0.95 – 1.05 pu	0.90 – 1.05 pu
MP	0.95 – 1.05 pu	0.90 – 1.05 pu
SMMPA	0.95 – 1.05 pu	0.90 – 1.05 pu
GRE	0.95 – 1.05 pu	0.90 – 1.10 pu
OTP	0.95 – 1.05 pu	0.90 – 1.05 pu
OTP-H (115kV+)	0.97 – 1.05 pu	0.92 – 1.10 pu
ALTW	0.95 – 1.05 pu	0.90 – 1.05 pu
MEC	0.95 – 1.05 pu	0.90 – 1.05 pu
MDU	0.95 – 1.05 pu	0.90 – 1.05 pu
SPC	0.95 – 1.05 pu	0.95 – 1.05 pu
DPC	0.95 – 1.05 pu	0.90 – 1.05 pu
ALTE	0.95 – 1.05 pu	0.90 – 1.05 pu

The constraints identified through the voltage scan are then screened for the following for each interconnection request. 1) 3% DF on the contingent element and 2) 2% change in pu voltage. In certain conditions, engineering judgement was used to determine whether or not a generator had impacts to voltage constraints.

## RESULTS

The ASIS ACCC analysis indicates that the Affected System Interconnection Customer(s) can interconnect their generation into the AECI transmission system at the available MW listed in the results tables after all required upgrades listed within the DISIS-2016-001 studies or latest iteration can be placed into service. ACCC results in **Table 8**, **Table 9**, and **Table 10** are dependent on AECI Upgrade Set #1 and incremental SPP upgrades assigned to ASGI-2017-005. ACCC results **Table 11**, **Table 12**, and **Table 13** are dependent on AECI Upgrade Set #2 and incremental SPP upgrades assigned to ASGI-2017-005. Incremental SPP upgrades assigned to ASGI-2017-005 for each AECI upgrade set can be identified within **Table 2A** and **Table 2B**.

Constraints listed in **Table 9** and **Table 12** do not require additional transmission reinforcement for Interconnection Service, but could require Interconnection Customer to reduce generation in operational conditions. These transmission constraints occur when this study's generation is dispatched into the AECI footprint for ERIS and NRIS.

## CURTAILMENT AND SYSTEM RELIABILITY

In no way does this study guarantee operation for all periods of time. It should be noted that although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to **0 MW** under certain system conditions to allow system operators to maintain the reliability of the transmission network.

# STABILITY ANALYSIS

---

Transient stability analysis is used to determine if the transmission system can maintain angular stability and ensure bus voltages stay within planning criteria bandwidth during and after a disturbance while considering the addition of a generator interconnection request.

## *MODEL PREPARATION*

Transient stability analysis was performed using modified versions of the 2015 series of Model Development Working Group (MDWG) dynamic study models including the 2016 winter, 2017 and 2025 summer peak dynamic cases. The cases were adapted to resemble the power flow study cases with regards to prior queued generation requests and topology. Finally the prior queued and study generation was dispatched into the SPP footprint. Initial simulations are then carried out for a no-disturbance run of twenty (20) seconds to verify the numerical stability of the model.

## *DISTURBANCES*

The thirty-five (35) contingencies were identified for use in this ASIS. These faults are listed within **Table 3**. These contingencies included three-phase faults and single-phase line faults at locations defined by SPP. Single-phase line faults were simulated by applying fault impedance to the positive sequence network at the fault location to represent the effect of the negative and zero sequence networks on the positive sequence network. The fault impedance was computed to give a positive sequence voltage at the specified fault location of approximately 60% of pre-fault voltage. This method is in agreement with SPP current practice.

With the exception of transformers, the typical sequence of events for a three-phase and single-phase fault is as follows:

1. apply fault at particular location
2. continue fault for five (5) cycles, clear the fault by tripping the faulted facility
3. run for an additional twenty (20) cycles, reclose into fault
4. continue fault for five (5) cycles, clear the fault by tripping the faulted facility

Transformer faults are typically modeled as three-phase faults, unless otherwise noted. The sequence of events for a transformer fault is as follows:

1. apply fault for five (5) cycles
2. clear the fault by tripping the affected transformer facility (unless otherwise noted there will be no re-closing into a transformer fault)

Table 3: Contingencies Evaluated

Contingency Number and Name		Description
1	FLT_01_4FAIRFAX_4REMINGTON_138kV_3PH	Fault on the Fairfax (300139) to Remington (301369) 138kV line, near Fairfax. a. Apply fault at the Fairfax 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
2	FLT_02_4FAIRFAX_2FAIRFAX_138_69kV_3PH	Fault on the Fairfax (300139) 138V to (300929) 69kV transformer circuit 1, near Fairfax 138kV. a. Apply fault at the Fairfax 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line.
3	FLT_03_4FAIRFAX_PAWNSW4_138kV_3PH	Fault on the Fairfax (300139) to Pawnee SW (512749) 138kV line, near Fairfax. a. Apply fault at the Fairfax 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
4	FLT_04_4REMINGTON_SHILDER4_138kV_3PH	Fault on the Remington (301369) to Shidler (510403) 138kV line, near Remington. a. Apply fault at the Remington 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
5	FLT_05_SHILDER4_FAIRFXT4_138kV_3PH	Fault on the Shidler (510403) to Fairfax Tap (510377) 138kV line, near Shidler. a. Apply fault at the Shidler 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
6	FLT_06_SHILDER4_WPAWTHSK4_138kV_3PH	Fault on the Shidler (510403) to West Pawhuska (510382) 138kV line, near Shidler. a. Apply fault at the Shidler 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
7	FLT_07_WEBBTAP4_OSAGE4_138kV_3PH	Fault on the Webber Tap (510376) to Osage (514743) 138kV line, near Webber Tap. a. Apply fault at the Webber Tap 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
8	FLT_08_PAWHTP4_DOMES4_138kV_3PH	Fault on the Pawhuska Tap (510412) to Dome (510383) 138kV line, near Pawhuska Tap. a. Apply fault at the Pawhuska Tap 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.

Table 3: Contingencies Evaluated

Contingency Number and Name		Description
9	FLT_09_2FAIRFAX_2GETTYTAP_69kV_3PH	Fault on the Fairfax (300929) to Getty Tap (512758) 69kV line, near Fairfax. a. Apply fault at the Fairfax 69kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
10	FLT_10_2FAIRFAX_2NAVLRES_69kV_3PH	Fault on the Fairfax (300929) to Naval Reserve (300937) 69kV line, near Fairfax. a. Apply fault at the Fairfax 69kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
11	FLT_11_PAWNSW4_4CLEVLND_138kV_3PH	Fault on the Pawnee SW (512749) to Cleveland (300138) 138kV line, near Pawnee SW. a. Apply fault at the Pawnee SW 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
12	FLT_12_PAWNSW4_4GLENCOE_138kV_3PH	Fault on the Pawnee SW (512749) to Glencoe (301425) 138kV line, near Pawnee SW. a. Apply fault at the Pawnee SW 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
13	FLT_13_4CLEVLND_4JAVINE_138kV_3PH	Fault on the Cleveland (300138) to Javine (300996) 138kV line, near Cleveland. a. Apply fault at the Cleveland 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
14	FLT_14_4CLEVLND_4CLEVLNDXFMR_138kV_3PH	Fault on the Cleveland (300138) to Cleveland XFMR (301429) 138kV line, near Cleveland. a. Apply fault at the Cleveland 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
15	FLT_15_4CLEVLND_CLEVLND4_138kV_3PH	Fault on the Cleveland (300138) to GRDA Cleveland (512729) 138kV line, near Cleveland. a. Apply fault at the Cleveland 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.

Table 3: Contingencies Evaluated

Contingency Number and Name		Description
16	FLT_16_4CLEVLND_4SILVCTY_138kV_3PH	Fault on the Cleveland (300138) to Silver City (300140) 138kV line, near Cleveland. a. Apply fault at the Cleveland 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
17	FLT_17_4SFORKKTP_4SFORKK_138kV_3PH	Fault on the South Fork Tap (301339) to South Fork (300165) 138kV line, near South Fork Tap. a. Apply fault at the Fork Tap 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
18	FLT_18_MOUNDRD4_BVCOM4_138kV_3PH	Fault on the Mound Road (510395) to Bartlesville Comanche (510390) 138kV line, near Mound Road. a. Apply fault at the Mound Road 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
19	FLT_19_OSAGE4_SNRPMPT4_138kV_3PH	Fault on the Osage (514743) to Sooner Pump Tap (514798) 138kV line, near Osage. a. Apply fault at the Osage 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
20	FLT_20_OSAGE4_MARLNDT4_138kV_3PH	Fault on the Osage (514743) to Marland Tap (514770) 138kV line, near Osage. a. Apply fault at the Osage 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
21	FLT_21_OSAGE4_STDBEAR4_138kV_3PH	Fault on the Osage (514743) to Standing Bear (514758) 138kV line, near Osage. a. Apply fault at the Osage 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
22	FLT_22_OSAGE4_WHEAGLE4_138kV_3PH	Fault on the Osage (514743) to White Eagle (514761) 138kV line, near Osage. a. Apply fault at the Osage 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.

Table 3: Contingencies Evaluated

Contingency Number and Name		Description
23	FLT_23_4STILWTR_4RAMSEY_138kV_3PH	Fault on the Stillwater (300141) to Ramsey (300844) 138kV line, near Stillwater. a. Apply fault at the Stillwater 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
24	FLT_24_4STILWTR_NORTHTP4_138kV_3PH	Fault on the Stillwater (300141) to North Tap (512731) 138kV line, near Stillwater. a. Apply fault at the Stillwater 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
25	FLT_25_OSAGE4_OSAGE2_138_69kV_3PH	Fault on the Osage (514743) 138kV to (514742) 69kV transformer circuit 1, near Osage 138kV. a. Apply fault at the Osage 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line.
26	FLT_26_4STILWTR_2WILLIAMS_138_69kV_3PH	Fault on the Stillwater (300141) 138kV to Williams (301413) 69kV transformer circuit 1, near Stillwater 138kV. a. Apply fault at the Stillwater 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line.
27	FLT_27_TNO4_SKIATOK4_138kV_3PH	Fault on the Tulsa North (509817) to Skiatook Tap (509884) 138kV line, near Tulsa North. a. Apply fault at the Tulsa North 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
28	FLT_28_TNO4_NES4_138kV_3PH	Fault on the Tulsa North (509817) to Northeastern (510396) 138kV line, near Tulsa North. a. Apply fault at the Tulsa North 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
29	FLT_29_4FAIRFAX_4REMINGTONPO_138kV_3PH	<b>Prior outage</b> on the Fairfax Tap (300139) to Pawnee Switch (512749) 138kV line: Fault on the Fairfax (300139) to Remington (301369) 138kV line, near Fairfax. a. Apply fault at the Fairfax 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
30	FLT_30_PAWNSW4_4FAIRFAXSB_138kV_1PH	<b>Single phase fault with stuck breaker</b> on the Pawnee SW (512749) to Fairfax (300139) 138kV line, near Pawnee SW. a. Apply fault at the Pawnee SW 138kV bus. b. At 16 cycles, clear the fault, open the faulted line, and open the Pawnee SW (512749) to Cleveland (300138) 138kV line.

Table 3: Contingencies Evaluated

Contingency Number and Name		Description
31	FLT_31_SHILDER4_4REMINGTONSB_138kV_1PH	<p><b>Single phase fault with stuck breaker</b> on the Shidler (510403) to Remington (301369) 138kV line, near Shidler.</p> <p>a. Apply fault at the Shidler 138kV bus.                      b. At 16 cycles, clear the fault, open the faulted line, and open the Shidler (510403) to Fairfax (300139) 138kV line.</p>
32	FLT_32_4REMINGTON_SHILDER4PO_138kV_3PH	<p><b>Prior outage</b> on the Pawnee SW (512749) to Glencoe (301425) 138kV line:                      Fault on the Remington (301369) to Shidler (510403) 138kV line, near Remington.</p> <p>a. Apply fault at the Remington 138kV bus.                      b. Clear fault after 5 cycles by tripping the faulted line.                      c. Wait 20 cycles, and then re-close the line in (b) back into the fault.                      d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p>
33	FLT_33_SHILDER4_4REMINGTONPO_138kV_3PH	<p><b>Prior outage</b> on the Pawnee SW (512749) to Cleveland (300138) 138kV line:                      Fault on the Shidler (510403) to Remington (301369) 138kV line, near Shidler.</p> <p>a. Apply fault at the Shidler 138kV bus.                      b. Clear fault after 5 cycles by tripping the faulted line.                      c. Wait 20 cycles, and then re-close the line in (b) back into the fault.                      d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p>
34	FLT_34_4FAIRFAX_PAWNSW4PO_138kV_3PH	<p><b>Prior outage</b> on the Shidler (510403) to Fairfax Tap (510377) 138kV line:                      Fault on the Fairfax (300139) to Pawnee SW (512749) 138kV line, near Fairfax.</p> <p>a. Apply fault at the Fairfax 138kV bus.                      b. Clear fault after 5 cycles by tripping the faulted line.                      c. Wait 20 cycles, and then re-close the line in (b) back into the fault.                      d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p>
35	FLT_35_4FAIRFAX_PAWNSW4PO_138kV_3PH	<p><b>Prior outage</b> on the Shidler (510403) to West Pawhuska (510382) 138kV line:                      Fault on the Fairfax (300139) to Pawnee SW (512749) 138kV line, near Fairfax.</p> <p>a. Apply fault at the Fairfax 138kV bus.                      b. Clear fault after 5 cycles by tripping the faulted line.                      c. Wait 20 cycles, and then re-close the line in (b) back into the fault.                      d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.</p>

**RESULTS**

Results of the stability analysis are summarized in **Table 4**. These results are valid for ASGI-2017-009 interconnecting with a generation amount up to 200 MW. Unstable responses can be mitigated with upgrades mentioned in **Table 2A or Table 2B** are in-service.

*Table 4: Fault Results*

Contingency Number and Name		2016WP	2017SP	2025SP
1	FLT_01_4FAIRFAX_4REMINGTON_138kV_3PH	Stable	Stable	Stable
2	FLT_02_4FAIRFAX_2FAIRFAX_138_69kV_3PH	Stable	Stable	Stable
3	FLT_03_4FAIRFAX_PAWNSW4_138kV_3PH	Stable	Stable	Stable
4	FLT_04_4REMINGTON_SHILDER4_138kV_3PH	Unstable	Unstable	Unstable
5	FLT_05_SHILDER4_FAIRFXT4_138kV_3PH	Stable	Stable	Stable
6	FLT_06_SHILDER4_WPAWTHSK4_138kV_3PH	Stable	Stable	Stable
7	FLT_07_WEBBTAP4_OSAGE4_138kV_3PH	Stable	Stable	Stable
8	FLT_08_PAWHTP4_DOMES4_138kV_3PH	Stable	Stable	Stable
9	FLT_09_2FAIRFAX_2GETTYTAP_69kV_3PH	Stable	Stable	Stable
10	FLT_10_2FAIRFAX_2NAVLRES_69kV_3PH	Stable	Stable	Stable
11	FLT_11_PAWNSW4_4CLEVLND_138kV_3PH	Stable	Stable	Stable
12	FLT_12_PAWNSW4_4GLENCOE_138kV_3PH	Stable	Stable	Stable
13	FLT_13_4CLEVLND_4JAVINE_138kV_3PH	Stable	Stable	Stable
14	FLT_14_4CLEVLND_4CLEVLNDXFMR_138kV_3PH	Stable	Stable	Stable
15	FLT_15_4CLEVLND_CLEVLND4_138kV_3PH	Stable	Stable	Stable
16	FLT_16_4CLEVLND_4SILVCTY_138kV_3PH	Stable	Stable	Stable
17	FLT_17_4SFORKKTP_4SFORKK_138kV_3PH	Stable	Stable	Stable
18	FLT_18_MOUNDRD4_BVCOM4_138kV_3PH	Stable	Stable	Stable
19	FLT_19_OSAGE4_SNRPMPT4_138kV_3PH	Stable	Stable	Stable
20	FLT_20_OSAGE4_MARLNDT4_138kV_3PH	Stable	Stable	Stable
21	FLT_21_OSAGE4_STDBEAR4_138kV_3PH	Stable	Stable	Stable
22	FLT_22_OSAGE4_WHEAGLE4_138kV_3PH	Stable	Stable	Stable
23	FLT_23_4STILWTR_4RAMSEY_138kV_3PH	Stable	Stable	Stable
24	FLT_24_4STILWTR_NORTHTP4_138kV_3PH	Stable	Stable	Stable
25	FLT_25_OSAGE4_OSGE2_138_69kV_3PH	Stable	Stable	Stable
26	FLT_26_4STILWTR_2WILLIAMS_138_69kV_3PH	Stable	Stable	Stable
27	FLT_27_TNO4_SKIATOK4_138kV_3PH	Stable	Stable	Stable
28	FLT_28_TNO4_NES4_138kV_3PH	Stable	Stable	Stable
29	FLT_29_4FAIRFAX_4REMINGTONPO_138kV_3PH	Stable	Stable	Stable
30	FLT_30_PAWNSW4_4FAIRFAXSB_138kV_1PH	Unstable	Unstable	Unstable
31	FLT_31_SHILDER4_4REMINGTONSB_138kV_1PH	Unstable	Unstable	Unstable
32	FLT_32_4REMINGTON_SHILDER4PO_138kV_3PH	Unstable	Unstable	Unstable
33	FLT_33_SHILDER4_4REMINGTONPO_138kV_3PH	Unstable	Unstable	Unstable
34	FLT_34_4FAIRFAX_PAWNSW4PO_138kV_3PH	Unstable	Unstable	Unstable
35	FLT_35_4FAIRFAX_PAWNSW4PO_138kV_3PH	Unstable	Unstable	Unstable

**FERC LVRT COMPLIANCE**

FERC Order #661A places specific requirements on wind farms through its Low Voltage Ride Through (LVRT) provisions. For Interconnection Agreements signed after December 31, 2006, wind farms shall stay on line for faults at the POI that draw the voltage down at the POI to 0.0 pu.

Fault contingencies were developed to verify that wind farms remain on line when the POI voltage is drawn down to 0.0 pu. These contingencies are shown in **Table 5**.

*Table 5: LVRT Contingencies*

Contingency Number and Name		Description
1	FLT_01_4FAIRFAX_4REMINGTON_138kV_3PH	Fault on the Fairfax (300139) to Remington (301369) 138kV line, near Fairfax. a. Apply fault at the Fairfax 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.
2	FLT_02_4FAIRFAX_2FAIRFAX_138_69kV_3PH	Fault on the Fairfax (300139) 138V to (300929) 69kV transformer circuit 1, near Fairfax 138kV. a. Apply fault at the Fairfax 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line.
3	FLT_03_4FAIRFAX_PAWNSW4_138kV_3PH	Fault on the Fairfax (300139) to Pawnee SW (512749) 138kV line, near Fairfax. a. Apply fault at the Fairfax 138kV bus. b. Clear fault after 5 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 5 cycles, then trip the line in (b) and remove fault.

The required prior queued project wind farms remained online for the fault contingencies described in this section as well as the fault contingencies described in the Disturbances section of this report. ASGI-2017-009 is found to be in compliance with FERC Order #661A.

# SHORT CIRCUIT ANALYSIS

A short circuit analysis was performed on the 2017 & 2025 Summer Peak power flow cases using the PSS/E ASCC program. Since the power flow model does not contain negative and zero sequence data, only three-phase symmetrical fault current levels were calculated at the point of interconnection up to and including five levels away. The results of the short circuit analysis are shown on the next page.

## ASGI-2017-009 Short Circuit Analysis Results (2017SP)

PSS@E ASCC SHORT CIRCUIT CURRENTS WED, SEP 20 2017 8:55  
 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO  
 MDWG 17S WITH MMWG 15S, MRO 16W TOPO/16S PROF, SERC 16S

### OPTIONS USED:

- FLAT CONDITIONS
- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/-/0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/-/0

### SEQUENCE

- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

### THREE PHASE FAULT

X-----	BUS -----X	/I+/	AN(I+)
300139	[4FAIRFAX 138.00]	AMP	10491.0 -82.67
300929	[2FAIRFAX 69.000]	AMP	10345.1 -83.51
301369	[4REMNGTON 138.00]	AMP	11161.0 -81.98
512749	[PAWNSW4 138.00]	AMP	10959.2 -84.02
588320	[ASGI1709 138.00]	AMP	7144.6 -82.91
300138	[4CLEVLND 138.00]	AMP	17108.2 -85.48
300919	[4RALSTNBND 138.00]	AMP	3535.7 -80.75
300922	[2BURBANK 138.00]	AMP	5856.1 -81.14
300937	[2NAVLRES 69.000]	AMP	4442.7 -70.20
301379	[4OSAGEWIND 138.00]	AMP	9641.6 -81.68
301425	[4GLENCOE 138.00]	AMP	10362.1 -83.01
510388	[BARNSAL4 138.00]	AMP	8284.3 -81.35
510403	[SHIDLER4 138.00]	AMP	9866.0 -80.14
512758	[2GETTYTAP 69.000]	AMP	5103.8 -81.94
588300	[ASGI1705 138.00]	AMP	6956.9 -82.59
300140	[4SILVCTY 138.00]	AMP	15881.7 -82.22
300141	[4STILWTR 138.00]	AMP	13842.2 -81.42
300644	[2GETTY 69.000]	AMP	4976.3 -81.59
300939	[2PAWNEE 69.000]	AMP	4235.3 -79.73
300940	[2PAWYA 69.000]	AMP	3245.5 -68.00
300996	[4JAVINE 138.00]	AMP	6577.8 -82.60
301429	[4CLEVLNDXFMR138.00]	AMP	17108.2 -85.48
509884	[SKIATOK4 138.00]	AMP	11068.4 -81.52

510377 [FAIRFXT4 138.00] AMP 9111.4 -79.22  
 510382 [WPAWHSK4 138.00] AMP 6072.4 -77.59  
 510433 [BARNPMP4 138.00] AMP 7728.3 -81.02  
 512729 [CLEVLND 4 138.00] AMP 17104.6 -85.50  
 300131 [4FISHERTP 138.00] AMP 14544.6 -80.86  
 300137 [4BRISTOW 138.00] AMP 7128.9 -79.76  
 300844 [4RAMSEY 138.00] AMP 10643.0 -79.82  
 300934 [2HALETP 69.000] AMP 4969.2 -80.08  
 300943 [2SILVCTY 69.000] AMP 10120.6 -79.21  
 301337 [2PRSHNGTP 69.000] AMP 3174.2 -68.06  
 301339 [4SFORKKTP 138.00] AMP 6871.9 -82.64  
 301413 [2WILLIAMS 69.000] AMP 20828.9 -76.64  
 301430 [2CLEVLNDXFMR69.000] AMP 10548.8 -83.52  
 509817 [T.NO.--4 138.00] AMP 34817.7 -84.86  
 510376 [WEBBTAP4 138.00] AMP 9027.7 -79.11  
 510395 [MOUNDRD4 138.00] AMP 9550.4 -79.25  
 510412 [PAWH-TP4 138.00] AMP 6023.0 -77.85  
 512675 [PAWNEGR2 69.000] AMP 3901.9 -77.80  
 512694 [CLEVLND7 345.00] AMP 15035.5 -86.35  
 512726 [SILVCTYGR4 138.00] AMP 15723.6 -82.31  
 512731 [NORTHTP4 138.00] AMP 11061.2 -82.80  
 300143 [4VALLEY 138.00] AMP 7357.7 -79.65  
 300145 [4FISHER 138.00] AMP 12298.7 -80.58  
 300146 [4SKIAETP 138.00] AMP 6948.1 -82.87  
 300165 [4SFORKK 138.00] AMP 4388.2 -80.64  
 300686 [4WOODY 138.00] AMP 7308.8 -79.20  
 300843 [2PERRYKM 69.000] AMP 4118.6 -77.85  
 300889 [2BRIISTOW 69.000] AMP 9380.9 -78.14  
 300927 [2CLEVLND 69.000] AMP 10548.8 -83.52  
 300928 [2DIXIE 69.000] AMP 5065.3 -71.87  
 300936 [2MANFORD 69.000] AMP 6220.2 -72.25  
 300945 [2YALE 69.000] AMP 5208.6 -70.47  
 301005 [2TALLANT 69.000] AMP 3462.6 -69.60  
 301331 [2PERSHING 69.000] AMP 3145.9 -68.17  
 505610 [KEYSTON4 138.00] AMP 21414.2 -81.36  
 509757 [WEKIWA-4 138.00] AMP 31369.0 -84.87  
 509837 [46ST--E4 138.00] AMP 14101.9 -78.36  
 509839 [CDC-ET 4 138.00] AMP 18628.9 -79.86  
 509842 [CDC-WT 4 138.00] AMP 19380.4 -84.17  
 509844 [OWASOTP4 138.00] AMP 14975.1 -79.79  
 509851 [P&P WTP4 138.00] AMP 14960.3 -82.08  
 509852 [T.NO.--7 345.00] AMP 23586.7 -86.29  
 509863 [PPTAP 4 138.00] AMP 10315.2 -83.75  
 509895 [T.NO.2-4 138.00] AMP 34745.9 -84.96  
 510383 [DOMES 4 138.00] AMP 6408.7 -78.59  
 510390 [BV-COM-4 138.00] AMP 10385.3 -80.48  
 510396 [N.E.S.-4 138.00] AMP 35638.8 -84.97  
 510432 [SHIDWFC4 138.00] AMP 6074.6 -75.87  
 510434 [HERITAGETRL4138.00] AMP 4360.0 -76.93  
 512710 [KINZEGR4 138.00] AMP 14398.8 -79.76  
 512712 [19TH ST4 138.00] AMP 12619.1 -79.78  
 512732 [NORTHTP2 69.000] AMP 6016.4 -88.36

512809 [STILLWTR2 69.000] AMP 20941.3 -76.39  
514743 [OSAGE 4 138.00] AMP 16657.7 -81.47  
560056 [G15-066T 345.00] AMP 18465.4 -86.52

**Short Circuit Analysis Results (2025SP)**

PSS@E ASCC SHORT CIRCUIT CURRENTS WED, SEP 20 2017 8:55  
 2015 MDWG FINAL WITH 2013 MMWG, UPDATED WITH 2014 SERC & MRO  
 MDWG 2025S WITH MMWG 2024S, MRO & SERC 2025 SUMMER

OPTIONS USED:

- FLAT CONDITIONS
- BUS VOLTAGES SET TO 1 PU AT 0 PHASE ANGLE
- GENERATOR P=0, Q=0
- TRANSFORMER TAP RATIOS=1.0 PU and PHASE ANGLES=0.0
- LINE CHARGING=0.0 IN +/- /0 SEQUENCE
- LOAD=0.0 IN +/- SEQUENCE, CONSIDERED IN ZERO SEQUENCE
- LINE/FIXED/SWITCHED SHUNTS=0.0 AND MAGNETIZING ADMITTANCE=0.0 IN +/- /0

SEQUENCE

- DC LINES AND FACTS DEVICES BLOCKED
- TRANSFORMER ZERO SEQUENCE IMPEDANCE CORRECTIONS IGNORED

THREE PHASE FAULT

X-----	BUS -----	X	/I+ /	AN(I+)
300139	[4FAIRFAX	138.00]	AMP	10527.0 -82.67
300929	[2FAIRFAX	69.000]	AMP	10360.5 -83.51
301369	[4REMNGTON	138.00]	AMP	11237.3 -82.00
512749	[PAWNSW4	138.00]	AMP	10984.5 -84.04
588320	[ASGI1709	138.00]	AMP	7156.9 -82.91
300138	[4CLEVLND	138.00]	AMP	17149.7 -85.48
300919	[4RALSTNBND	138.00]	AMP	3543.3 -80.75
300922	[2BURBANK	138.00]	AMP	5877.0 -81.14
300937	[2NAVLRES	69.000]	AMP	4445.0 -70.19
301379	[4OSAGEWIND	138.00]	AMP	9697.3 -81.69
301425	[4GLENCOE	138.00]	AMP	10392.7 -83.06
510388	[BARNSAL4	138.00]	AMP	8322.2 -81.37
510403	[SHIDLER4	138.00]	AMP	9970.8 -80.15
512758	[2GETTYTAP	69.000]	AMP	5107.0 -81.95
588300	[ASGI1705	138.00]	AMP	6980.1 -82.59
300140	[4SILVCTY	138.00]	AMP	15960.3 -82.23
300141	[4STILWTR	138.00]	AMP	13908.9 -81.50
300644	[2GETTY	69.000]	AMP	4979.3 -81.59
300939	[2PAWNEE	69.000]	AMP	4237.2 -79.73
300940	[2PAWYA	69.000]	AMP	3246.5 -67.99
300996	[4JAVINE	138.00]	AMP	6584.0 -82.60
301429	[4CLEVLNDXFM	138.00]	AMP	17149.7 -85.48
509884	[SKIATOK4	138.00]	AMP	11096.2 -81.52
510377	[FAIRFXT4	138.00]	AMP	9204.5 -79.22
510382	[WPAWHSK4	138.00]	AMP	6196.2 -77.77
510433	[BARNPMP4	138.00]	AMP	7768.5 -81.05
512729	[CLEVLND 4	138.00]	AMP	17146.1 -85.50
300131	[4FISHERTP	138.00]	AMP	14599.9 -80.85
300137	[4BRISTOW	138.00]	AMP	7205.5 -79.85
300844	[4RAMSEY	138.00]	AMP	10656.2 -79.83

300934 [2HALETPP 69.000] AMP 4971.3 -80.07  
 300943 [2SILVCTY 69.000] AMP 10136.6 -79.21  
 301337 [2PRSHNGTP 69.000] AMP 3175.1 -68.05  
 301339 [4SFORKKTP 138.00] AMP 6878.7 -82.64  
 301413 [2WILLIAMS 69.000] AMP 21611.6 -76.65  
 301430 [2CLEVLNDXFMR69.000] AMP 10557.5 -83.52  
 509817 [T.NO.--4 138.00] AMP 34997.8 -84.86  
 510376 [WEBBTAP4 138.00] AMP 9119.9 -79.12  
 510395 [MOUNDRD4 138.00] AMP 9667.7 -79.34  
 510412 [PAWH-TP4 138.00] AMP 6194.0 -78.15  
 512675 [PAWNEGR2 69.000] AMP 3903.6 -77.80  
 512694 [CLEVLND7 345.00] AMP 15089.2 -86.35  
 512726 [SILVCTYGR4 138.00] AMP 15800.3 -82.33  
 512731 [NORTHTP4 138.00] AMP 11080.1 -82.82  
 300143 [4VALLEY 138.00] AMP 7364.3 -79.66  
 300145 [4FISHER 138.00] AMP 12338.6 -80.58  
 300146 [4SKIAETP 138.00] AMP 6955.1 -82.87  
 300165 [4SFORKK 138.00] AMP 4391.0 -80.64  
 300686 [4WOODY 138.00] AMP 7570.4 -79.57  
 300843 [2PERRYKM 69.000] AMP 4136.3 -77.88  
 300889 [2BRIISTOW 69.000] AMP 9427.7 -78.19  
 300927 [2CLEVLND 69.000] AMP 10557.5 -83.52  
 300928 [2DIXIE 69.000] AMP 5068.2 -71.86  
 300936 [2MANFORD 69.000] AMP 6226.4 -72.24  
 300945 [2YALE 69.000] AMP 5214.6 -70.46  
 301005 [2TALLANT 69.000] AMP 3463.5 -69.59  
 301331 [2PERSHING 69.000] AMP 3146.8 -68.16  
 505610 [KEYSTON4 138.00] AMP 21528.6 -81.34  
 509757 [WEKIWA-4 138.00] AMP 31617.4 -84.87  
 509837 [46ST--E4 138.00] AMP 14131.5 -78.34  
 509839 [CDC-ET 4 138.00] AMP 18681.7 -79.84  
 509842 [CDC-WT 4 138.00] AMP 19437.1 -84.17  
 509844 [OWASOTP4 138.00] AMP 15003.1 -79.78  
 509851 [P&P WTP4 138.00] AMP 15003.7 -82.07  
 509852 [T.NO.--7 345.00] AMP 23776.2 -86.30  
 509863 [PPTAP 4 138.00] AMP 10331.7 -83.75  
 509895 [T.NO.2-4 138.00] AMP 34925.0 -84.95  
 510383 [DOMES 4 138.00] AMP 6541.2 -78.78  
 510390 [BV-COM-4 138.00] AMP 10501.4 -80.54  
 510396 [N.E.S.-4 138.00] AMP 35765.5 -84.96  
 510432 [SHIDWFC4 138.00] AMP 6116.1 -75.85  
 510434 [HERITAGETRL4138.00] AMP 4525.5 -77.39  
 512710 [KINZEGR4 138.00] AMP 14424.7 -79.72  
 512712 [19TH ST4 138.00] AMP 12636.8 -79.75  
 512732 [NORTHTP2 69.000] AMP 6018.0 -88.37  
 512809 [STILLWTR2 69.000] AMP 21757.2 -76.39  
 514743 [OSAGE 4 138.00] AMP 17549.3 -81.74  
 560056 [G15-066T 345.00] AMP 18537.8 -86.52

## CONCLUSION

---

An Affected System Interconnection Customer has requested an Affected System Impact Study (ASIS) under the Southwest Power Pool Open Access Transmission Tariff (OATT) for ASGI-2017-009. ASGI-2017-009 (200 MW) wind generating facilities is to be interconnected into the system of AECL. ASGI-2017-009 has requested this ASIS to determine the impacts of interconnecting to the transmission system with all required Network Upgrades identified in the DISIS-2016-001 Impact Study placed into service.

The ASIS analysis has determined that the ASGI-2017-009 request can interconnect 200 MW of generation with ERIS and NRIS with the study dispatch assumption listed in **Table 1** provided the Network Upgrades listed in **Table 2A or Table 2B** are able to be placed in service.

It should be noted that although this ASIS analyzed many of the most probable contingencies, it is not an all-inclusive list that can account for every operational situation. Additionally, the generator may not be able to inject any power onto the Transmission System due to constraints that fall below the threshold of mitigation for a Generator Interconnection request. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to **0 MW** under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Transient stability analysis for this ASIS has determined that issues were observed as listed in **Table 4** for the transmission system for the thirty-five (35) selected faults for the interconnection of ASGI-2017-009 and the analysis shows that the generators will meet Low Voltage Ride-Through (LVRT) requirements of FERC Order #661A. As discussed above, this amount may be reduced further dependent upon system conditions.

Any changes to these assumptions, for example, one or more of the previously queued requests not included within this study execute an interconnection agreement and commencing commercial operation, may require a re-study of this ASIS at the expense of the Customer.

Nothing in this System Impact Study constitutes a request for transmission service or confers upon the Interconnection Customer any right to receive transmission service.

# AECI UPGRADE SETS

---

Table 6: AECI Upgrade Set #1

<b>Upgrades</b>
Fairfax 138/69kV Transformers CKT 1 & 2 (84 MVA)
Remington - Shidler 138kV rebuild
Remington - Fairfax 138kV rebuild
Fairfax - Nava Reserve - Pawya - Pershing Tap 69kV

Table 7: AECI Upgrade Set #2

<b>Upgrades</b>
Fairfax 138/69kV Transformers CKT 1 & 2 (84 MVA)
Remington - Barnsdal 138kV build
Fairfax - Nava Reserve - Pawya - Pershing Tap 69kV

# THERMAL AND STEADY STATE VOLTAGE CONSTRAINTS TABLES BASE ON AECI UPGRADE SET #1

---

*Table 8: Thermal Constraints Requiring Additional Transmission Reinforcements*

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX - PAWNSW4 138.00 138KV CKT 1	304	357	0.80382	101.0768	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX - PAWNSW4 138.00 138KV CKT 1	304	357	0.80382	101.0768	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX - PAWNSW4 138.00 138KV CKT 1	304	357	0.80388	102.3235	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX - PAWNSW4 138.00 138KV CKT 1	304	357	0.80388	102.3235	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX - PAWNSW4 138.00 138KV CKT 1	304	357	0.8051	104.3618	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX - PAWNSW4 138.00 138KV CKT 1	304	357	0.8051	104.3618	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX - PAWNSW4 138.00 138KV CKT 1	304	357	0.80453	101.1255	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX - PAWNSW4 138.00 138KV CKT 1	304	357	0.80453	101.1255	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX - PAWNSW4 138.00 138KV CKT 1	304	357	0.80452	100.2643	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX - PAWNSW4 138.00 138KV CKT 1	304	357	0.80452	100.2643	4REMNGTON 138.00 - SHIDLER 138KV CKT 1

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20L	ASGI_17_09	FROM->TO	2GETTYTAP 69.000 - PAWNEE 69KV CKT 1	72	72	0.14239	103.5922	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	2GETTYTAP 69.000 - PAWNEE 69KV CKT 1	72	72	0.14239	103.5922	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03647	109.7146	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03647	109.6676	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03647	104.8487	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.04179	99.1	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.04179	99.1	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03774	106.503	ARCADIA - SEMINOLE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03502	101.1543	GRACEMONT - MINCO 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.034	105.1259	G14-057T 345.00 - SUNNYSIDE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.034	101.8331	G14-057T 345.00 - LAWTON EASTSIDE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.04086	100.3257	ARCADIA - SEMINOLE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.16361	105.48	G15052_T 345.00 - ROSE HILL 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.15237	104.3561	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.15237	104.2533	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.147	102.4866	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.147	102.461	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.147	100.6653	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.14565	103.5252	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.14565	100.5172	G15063_T 345.00 - WOODRING 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.14433	104.3436	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.14433	101.1623	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1	143	143	0.06555	128.5979	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1	143	143	0.06555	128.5979	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0509	105.8955	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0509	105.8875	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0509	101.3323	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04978	109.5004	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04859	101.502	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04859	101.4925	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04749	106.0883	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05281	119.1936	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05281	119.18	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05281	114.5915	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05154	129.8019	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04932	109.1463	EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04921	117.2413	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04613	101.4386	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04613	101.4386	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04507	105.413	MORRIS COUNTY - SWISSVALE 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04498	106.4121	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04469	105.3256	LACYGNE - STILWELL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04461	102.7598	AXTELL - G16-050-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04461	102.1294	G16-050-TAP 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0436	99.1	DELAWARE - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0436	99.1	DELAWARE - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04354	105.2937	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04354	103.123	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04354	100.8812	LATHAMS7 345.00 - ROSE HILL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04351	100	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04344	99.6	MINGO - RED WILLOW 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04344	99.6	MINGO - RED WILLOW 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04321	100.2561	7JASPER 345.00 - BLACKBERRY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04318	99.3	FT SMITH - MUSKOGEE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04311	99.4	DELAWARE - NORTHEAST STATION 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04311	99.4	DELAWARE - NORTHEAST STATION 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	102.2474	P12:115:WERE:LANG-TECH_115P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	102.1705	P12:115:WERE:FOUR-LANG_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	102.0697	LANG - READING LAKE 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	101.781	OSAGE CITY JUNCTION SWITCHING STATION - READING LAKE 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	101.233	OSAGE CITY JUNCTION SWITCHING STATION - SCRNTJS3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	101.2319	SCRANTON - SCRNTJS3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	100.923	FOUR CORNERS - SCRNTJN3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	100.9229	SCRANTON - SCRNTJN3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	100.5777	P12:115:WERE:FOUR-TECH_115F::

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	100.5228	CARB-KW 3 - FOUR CORNERS 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	100.297	CARB-KW 3 - SHAWNEE HEIGHTS 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04274	99.8	SHAWNEE HEIGHTS - TECUMSEH HILL 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04273	100.7449	DBL-SPRVL-IR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0427	100.3276	RENO COUNTY - WICHITA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04262	99.6	MINGO - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04262	99.6	MINGO - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04253	99.7	P12:161:WERE:MARM-KCPL_161::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04253	99.7	CENTERVILLE - G15-016T 161.00 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04253	99.4	CENTERVILLE - PAOLA 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0425	99.2	BROOKLINE - FLINT CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0425	99.2	BROOKLINE - FLINT CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04247	99.2	RENO COUNTY - SUMMIT 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04237	106.4856	AUBURN ROAD - JEFFREY ENERGY CENTER 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04224	99.9	G13-010T 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04224	99.8	G13-010T 345.00 - G16-049-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04224	99.6	G16-049-TAP 345.00 - SPEARVILLE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04218	99.5	HOLCOMB - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04218	99.5	HOLCOMB - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04214	99.8	AXTELL - PAULINE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04214	99.1	DELL 500 - INDEPENDENCE 500KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0421	100.6217	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0421	100	G15063_T 345.00 - WOODRING 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04208	99.6	G15088_T 345.00 - MOORE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04208	99.3	G15088_T 345.00 - PAULINE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04208	99.1	7JASPER 345.00 - MORGAN 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04207	99.4	7MCCREDIE 345.00 - 7MONTGMRY 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04205	100	P12:115:WERE:AUBN-SMAN_115F2::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04205	100	P12:115:WERE:AUBN-SMAN_115F3::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04205	100	P12:115:WERE:AUBN-SMAN_115F1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04205	99.9	SMAN_W_3 115.00 - SOUTH MANHATTAN 115KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04205	99.813	SOUTH ALMA - SOUTH MANHATTAN 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04205	99.7	CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04205	99.25755	KEENE - SOUTH ALMA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04205	99.1	AUBURN ROAD - OLDAUBU3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.042	99.4	KEO EHV - WEST MEMPHIS 500 500KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04198	99.9	GRAND ISLAND - SWEETWATER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04188	99.1	7SPORTSMAN - BLACKBERRY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04186	99.3	CLIFTON - CONCORDIA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04186	99.3	CLIFTON - CONCORDIA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04186	99.1	P12:115:WERE-MKEC:CLIFTON-KNOBHILL::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04186	99.1	P12:115:WERE:KNOB-MKEC_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04186	99.1	GREENLEAF - KNOB HILL 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04186	99.1	CLIFTON - GREENLEAF 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04184	99.3	G14-057T 345.00 - SUNNYSIDE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04184	99.1	G14-057T 345.00 - LAWTON EASTSIDE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04177	99.2	5JASPER 161.00 - LAMAR 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04177	99.2	7JASPER 345.00 345/161KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04174	107.2666	P13:115-345:WERE:LANG_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04174	107.2666	LANG (LANG TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04174	107.265	EMPORIA ENERGY CENTER - LANG 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04172	99.3	AUBURN ROAD - SWISSVALE 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04166	99.2	CIMARRON - DRAPER LAKE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04165	99.8	P13:069-138:WERE:ALTO_TX-1OR3P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04163	99.1	GRAND ISLAND - MCCOOL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04162	99.1	HAWTHORN - NASHUA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04161	99.40984	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04161	99.40984	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04161	99.4	DBL-HTCH-OTA
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0416	99.2	IATAN - NASHUA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0416	99.10702	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0416	99.10702	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04155	99.5	CONCORDIA - ELM CREEK 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04155	99.5	CONCORDIA (CONCORD6) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04155	99.5	CONCORDIA (CONCORD6) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04155	99.5	CONCORDIA - ELM CREEK 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04143	101.4107	DBL-THIS-G15

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04143	99.2	P12:069:WERE:ALLE-TIOG_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04142	99.8	P13:115-230:WERE:MCDO_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04142	99.8	MCDOWELL CREEK (MCDO TX-1) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04142	99.8	MCDOWELL CREEK - MORRIS COUNTY 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04142	99.2	ALTOONA - BUTLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04141	99.2	P13:069-138:WERE:BUTL_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0414	99.1	P12:115:WERE:MCDO-WILD_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	105.6674	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	104.279	GEN542955 1-LACYGNE UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	104.1932	GEN542962 2-IATAN UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	103.586	GEN542956 2-LACYGNE UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	103.4575	GEN542951 5-HAWTHORN UNIT #5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	103.1893	GEN542957 1-IATAN UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	102.5657	GEN300003 1-THOMAS HILL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	101.7339	GEN640009 1-COOPER NUCLEAR STATION
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	101.6635	GEN645012 2-NEBRASKA CITY 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	101.4784	GEN645011 1-NEBRASKA CITY 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	101.2077	GEN541151 3-SIBLEY GENERATING UNIT #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	100.4134	GEN546702 1-NM GEN N1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	100.359	GEN344225 1-1CAL G1 25.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	100.1928	GEN300007 1-NEW MADRID UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	100.1818	GEN300006 1-NEW MADRID UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	100.1754	P12:115:WERE:EMAN-KSU_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	100.1014	GEN635024 4-WALTER SCOTT UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	100	GEN659107 2-ANTELOPE VALLEY UNIT2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	100	GEN659103 1-ANTELOPE VALLEY UNIT1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	100	GEN300002 1-THOMAS HILL UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	100	EASTDC - ERCOT EQUIVALENCE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.9	GEN659111 2-LELAND OLDS UNIT2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.9	GEN635023 3-WALTER SCOTT UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.9	P12:115:WERE:PHLP-SALM_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.8	GEN542954 3-MONTROSE UNIT #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.8	GEN541162 1-ARIES STEAM TURBINE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.7	GEN629075 1-OTTUMWA GENERATOR FOR OTTUMWA UNIT NO 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.7	GEN542953 2-MONTROSE UNIT #2

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.7	GEN590011 2-ERCOT EQUIVALENCE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.7	GEN562694 1-G15_016_3 0.6900
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.7	P12:115:WERE:EUR-WEMP_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.7	P12:115:WERE:3VAN-HEC_115P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.7	P12:138:WERE:HARR-WEAV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.6	GEN590010 1-ERCOT EQUIVALENCE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.6	GEN532662 1-LAWRENCE ENERGY CENTER UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.5	GEN532672 1-TECUMSEH ENERGY CENTER UNIT 8
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.5	P12:069:WERE:HOOVN-RIPL_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.4	GEN542967 9-HAWTHORN UNIT #9
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.4	GEN546698 1-QN GEN2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.4	GEN300001 1-THOMAS HILL UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.4	GEN635214 4-NEAL UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.4	GEN636641 1-LOUISA UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.4	GEN541166 2-SHARPR#2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.4	GEN541165 1-SHARPR#1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	GEN542961 6-HAWTHORN COMBUSTION TURBINE #6
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	GEN541163 1-ARIES COMBUSTION TURBINE #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	GEN600002 3-SHERBURNE CNTY G3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	GEN543106 1-BULL CREEK COMBUSTION TURBINE #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	GEN505432 1-SIKESTON
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	GEN645025 5-NORTH OMAHA 5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	GEN629074 1-ARNOLD LOWSIDE OF GSU XFMR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	GEN543107 2-BULL CREEK COMBUSTION TURBINE #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	GEN543109 4-BULL CREEK COMBUSTION TURBINE #4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	GEN543108 3-BULL CREEK COMBUSTION TURBINE #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	P12:069:WERE:MEAD-PLAZ_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.3	SHERBURNE CO 345/24.0KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN344894 1-1LAB G1 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN344896 3-1LAB G3 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN300011 1-ST FRANCIS UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN344897 4-1LAB G4 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN600000 1-SHERBURNECNTY G1

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN549893 2-SOUTHWEST 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN645042 2-CASS COUNTY 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN659110 1-LELAND OLDS UNIT1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN645041 1-CASS COUNTY 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	GEN300010 1-ST FRANCIS UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	P12:115:WERE:ANZI-FTJU_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.2	ABILENE ENERGY CENTER 115/34.5KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	GEN344895 2-1LAB G2 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	GEN300012 1-HOLDEN UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	GEN300015 1-1SGPDEL 18.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	GEN300013 1-HOLDEN UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	GEN635213 3-NEAL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	GEN543078 1-PAOLA COMBUSTION TURBINES
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	GEN541170 4-LAKERD#4 13.800
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	GEN532661 1-LAWRENCE ENERGY CENTER UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	GEN600001 2-SHERBURNE CNTY G2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	GEN541154 3-RALPH GREEN GENERATING UNIT #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04139	99.1	4SIOUX 1 138.00 138/18.0KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04138	100.5381	P12:138:WERE:BENT-NORT_138P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04138	100.1787	P12:069:WERE:64TH-NORT_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04138	100.1589	P12:069:WERE:COWS-HOOVS_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04138	99.7	P12:069:WERE:MACA-PLAZ_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04138	99.2	P12:069:WERE:COWS-SUNS_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04138	99.1	P12:115:WERE:WMCP-MWE_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04138	99.1	P12:115:MIDW::RICE-WHEATLANDS
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04136	101.1459	HOYT (HOYT TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04136	99.6	P12:069:WERE:MOUN-NEWT_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04135	99.8	P12:138:WERE:HOOV-MURR_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04134	99.2	P12:138:WERE:NORT-WEAV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04133	99.5	P12:138:WERE:COWS-WACO_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04133	99.2	P12:138:WERE:17TH-CANA_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04131	99.9	P12:138:WERE:GECT-HOOV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04131	99.7	P12:115:WERE:LANG-WEMP_115::

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04131	99.3	P13:069-138:WERE:HOOV_TX-3::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0413	99.3	P13:069-138:WERE:COWS_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04129	99.1	P12:138:WERE:GORD-MAIZ_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04129	99.1	MAIZE - MAIZEW 4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04129	99.1	EVANS ENERGY CENTER NORTH - MAIZEW 4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04127	99.1	P12:115:WERE:INDA-HOYT_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04108	104.6393	MORRIS COUNTY (MORR TX-1) 345/230/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04101	99.6	OVEXFRMCCOVE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04092	99.1	MORISNT4 138.00 - STILLWATER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04091	99.1	P12:138:OKGE:3TERM2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04069	100.3634	SUMMIT - UNIONRG6 230.00 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04067	99.7	P12:115:WERE:MOUN-WEMP_115P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04067	99.2	P12:115:WERE:SPCKJ-WEMP_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04041	99.2	MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	100.6431	87th STREET - CRAIG 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04014	102.0337	87th STREET - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03992	99.3	7MCCREDIE 345.00 - 7OVERTON 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03969	101.1145	BENTON - WICHITA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03969	99.4	DBL-THIS-WWR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03959	103.0432	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03959	101.9211	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03929	99.7	RANCHRD7 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0392	101.2535	HUNTERS7 345.00 - WOODRING 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0392	99.3	G16-072-TAP 345.00 - RENFROW7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0392	99.3	G16-072-TAP 345.00 - HUNTERS7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05705	107.6854	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05705	107.6725	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05705	103.2493	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05657	105.1912	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05419	113.0594	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05419	113.0576	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05419	108.5159	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05315	122.8779	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05084	103.8922	EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05074	110.6492	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04636	99.9	MORRIS COUNTY - SWISSVALE 230KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04627	101.1966	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04594	100	LACYGNE - STILWELL 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0447	100	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04356	101.2321	AUBURN ROAD - JEFFREY ENERGY CENTER 230KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04292	102.353	P13:115-345:WERE:LANG_TX-1::
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04292	102.3529	LANG (LANG TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04292	102.3516	EMPORIA ENERGY CENTER - LANG 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04256	100.3794	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04256	99.2	GEN542955 1-LACYGNE UNIT #1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04256	99.1	GEN542962 2-IATAN UNIT #2
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04221	99.7	MORRIS COUNTY (MORR TX-1) 345/230/14.4KV TRANSFORMER CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05316	102.7406	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05316	102.7373	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05215	105.6699	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05208	102.3432	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05208	102.3412	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0511	112.251	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04874	100.0991	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX - PAWNWSW4 138.00 138KV CKT 1	304	357	0.80387	99.2	4REMINGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX - PAWNWSW4 138.00 138KV CKT 1	304	357	0.80387	99.2	4REMINGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03956	126.2315	FAIRFAX - PAWNWSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03956	126.2315	FAIRFAX - PAWNWSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03638	126.3782	SOONER (SOONER5) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03441	127.7398	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03441	127.6889	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03441	127.4849	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03441	127.4129	P12:138:AEPW:MOUNDRD4:SHIDLER4

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03441	127.3335	DOMES - MOUND ROAD 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03237	134.1208	G15-015T 138.00 - MDFRDTP4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03237	132.0974	MDFRDTP4 138.00 - RENFROW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03237	118.4934	CHIKASKIA - COYOTE 4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03237	118.4864	COYOTE 4 138.00 - G15-015T 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03176	147.4578	G15052_T 345.00 - ROSE HILL 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03176	136.776	G15052_T 345.00 - OPENSKY7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03176	126.2144	OPENSKY7 345.00 - RANCHR7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03176	106.5467	RANCHR7 345.00 - SOONER 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03146	146.5379	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03146	124.9236	RENFROW7 345.00 - VIOLA 7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03141	120.0361	CHIKASKIA - KILDARE4 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03132	116.9483	RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03042	135.1707	TIMBER JUNCTION - UDALL 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03042	134.9396	P12:069:WERE:TIMJ-WEAV_69::
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03042	134.1814	RICHLAND - UDALL 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03042	132.8775	RICHLAND - ROSE HILL JUNCTION 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03042	131.3028	ROSE HILL JUNCTION - WEAVER 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02965	135.9778	CRESWELL - SUMNER COUNTY NO. 4 ROME 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02965	135.6473	CITY OF WELLINGTON - SUMNER COUNTY NO. 4 ROME 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02965	135.4616	P12:069:WERE:BELL-CRSW_69::
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02965	132.6658	CITY OF WELLINGTON - SUMNER COUNTY NO. 3 MILLER 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02965	130.1881	BELL - SUMNER COUNTY NO. 3 MILLER 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02965	128.8096	BELL - PECK 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02965	128.683	P12:069:WERE:BELL-MURR_69::
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02965	127.2489	GILL ENERGY CENTER WEST - PECK 69KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03931	124.4607	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03931	124.4607	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03612	125.1142	SOONER (SOONERS) 345/138/13.8KV TRANSFORMER CKT 1

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03415	126.2008	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03415	126.164	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03415	125.8994	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03415	125.787	DOMES - MOUND ROAD 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03415	125.7599	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03212	131.7973	G15-015T 138.00 - MDFRDTP4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03212	129.9177	MDFRDTP4 138.00 - RENFROW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03212	116.2612	CHIKASKIA - COYOTE 4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03212	116.2537	COYOTE 4 138.00 - G15-015T 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03139	146.1529	G15052_T 345.00 - ROSE HILL 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03139	136.3186	G15052_T 345.00 - OPENSKY7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03139	125.9855	OPENSKY7 345.00 - RANCHR7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03139	106.7313	RANCHR7 345.00 - SOONER 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03116	118.3471	CHIKASKIA - KILDARE4 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03107	144.5825	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03107	123.9875	RENFROW7 345.00 - VIOLA 7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03104	114.6635	RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.0304	119.1817	OSAGE - SOONER PUMP TAP 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.0304	119.1114	SOONER - SOONER PUMP TAP 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03013	133.0941	TIMBER JUNCTION - UDALL 69KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03013	132.8463	P12:069:WERE:TIMJ-WEAV_69::
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03013	131.8416	RICHLAND - UDALL 69KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03013	130.4903	RICHLAND - ROSE HILL JUNCTION 69KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03013	128.6767	ROSE HILL JUNCTION - WEAVER 69KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02995	119.3633	DMNCRKT4 - MILLER 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02995	119.2511	MILLER - SOONER 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03976	118.1307	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03976	118.1307	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.0346	120.021	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.0346	119.9661	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.0346	119.6316	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.0346	119.4562	P12:138:AEPW:MOUNDRD4:SHIDLER4

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.0346	119.4523	DOMES - MOUND ROAD 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03259	124.5916	G15-015T 138.00 - MDFRDTP4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03259	122.1643	MDFRDTP4 138.00 - RENFROW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03259	109.0392	CHIKASKIA - COYOTE 4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03259	109.0318	COYOTE 4 138.00 - G15-015T 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03205	140.8797	G15052_T 345.00 - ROSE HILL 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03205	131.0764	G15052_T 345.00 - OPENSKY7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03205	120.8266	OPENSKY7 345.00 - RANCRD7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03205	99.5	RANCRD7 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03173	137.1373	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03162	112.2645	CHIKASKIA - KILDARE4 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03153	105.7366	RENFROW7 345.00 (BANK 1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03085	112.5528	OSAGE - SOONER PUMP TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03085	112.4433	SOONER - SOONER PUMP TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03064	128.2887	TIMBER JUNCTION - UDALL 69KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03064	127.9325	P12:069:WERE:TIMJ-WEAV_69::
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03064	126.3311	RICHLAND - UDALL 69KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03064	124.3431	RICHLAND - ROSE HILL JUNCTION 69KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03064	121.7648	ROSE HILL JUNCTION - WEAVER 69KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03039	112.9417	DMNCRKT4 - WHITE EAGLE 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03039	112.6901	DMNCRKT4 - MILLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03039	112.5276	MILLER - SOONER 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02987	127.8392	CITY OF WELLINGTON - SUMNER COUNTY NO. 3 MILLER 69KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02987	125.3849	CRESWELL - SUMNER COUNTY NO. 4 ROME 69KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02987	125.2621	P12:069:WERE:BELL-CRSW_69::
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02987	124.9588	CITY OF WELLINGTON - SUMNER COUNTY NO. 4 ROME 69KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02987	123.6494	BELL - SUMNER COUNTY NO. 3 MILLER 69KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02987	121.4908	BELL - PECK 69KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02987	121.3126	P12:069:WERE:BELL-MURR_69::
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.02987	118.9868	GILL ENERGY CENTER WEST - PECK 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06911	108.7174	VIOLA 7 345.00 - WICHITA 345KV CKT 1

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06198	114.68	SOONER - SPRING CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06198	114.549	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.03398	102.5097	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.07094	106.1972	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06547	110.4589	SOONER - SPRING CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06547	110.3201	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.03641	99.9	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06159	109.0838	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06159	101.9533	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06522	106.2627	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06522	106.0297	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.03253	102.4121	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.0602	104.2732	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.0602	104.1369	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06077	119.6496	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06077	112.4489	SOONER - SPRING CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07398	99.6	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06968	104.0639	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06968	100	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06311	99.1	GEN542955 1-LACYGNE UNIT #1
08ALL	17G	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06713	101.2265	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.08288	99.7	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07534	106.4701	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07534	102.2043	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07174	102.3545	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07398	99.6	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06968	104.0636	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06968	100	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06311	99.1	GEN542955 1-LACYGNE UNIT #1
08ALL	17G	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06713	101.2264	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.08288	99.7	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07534	106.4702	CANEYRV7 345.00 - NEOSHO 345KV CKT 1

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07534	102.2043	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07174	102.354	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	1076	1076	0.05333	102.4653	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	1076	1076	0.05312	103.0023	SWISSVALE - WEST GARDNER 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	NORTHWEST - SPRING CREEK 345KV CKT 1	1039	1195	0.0619	102.2847	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	SPVALLY4 138.00 - STILLWATER 138KV CKT 1	194	222	0.0605	107.3893	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	SPVALLY4 138.00 - STILLWATER 138KV CKT 1	194	222	0.0605	107.3893	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	SPVALLY4 138.00 - STILLWATER 138KV CKT 1	194	222	0.0556	100.4768	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	SPVALLY4 138.00 - STILLWATER 138KV CKT 1	194	222	0.05248	99.2	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05124	115.8143	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04983	116.9474	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04983	116.9293	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04983	109.4665	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04682	112.4368	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04842	121.9317	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04716	120.1998	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04716	120.1923	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04716	113.0082	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04425	117.4529	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05388	134.9029	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.0524	125.6875	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.0524	125.6617	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.0524	118.5532	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04927	131.7881	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04315	108.0353	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04288	99.6	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04288	99.6	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04094	100.1259	AXTELL - G16-050-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04094	99.4	G16-050-TAP 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04071	102.0899	LACYGNE - STILWELL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03996	103.3169	CANEYRV7 345.00 - NEOSHO 345KV CKT 1

Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03996	100.4793	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03865	99.1	IATAN - NASHUA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03839	99.2	SWISSVALE - TECUMSEH HILL 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03839	99.2	TECUMSEH HILL (TECH TX-3) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03818	100	LAWRENCE HILL (LAWH TX-3) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	104.8179	GEN542955 1-LACYGNE UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	103.6259	GEN542956 2-LACYGNE UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	100.65	GEN542951 5-HAWTHORN UNIT #5
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	99.9	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	99.8	GEN300003 1-THOMAS HILL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03604	99.1	SUMMIT - UNIONRG6 230.00 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03542	101.8082	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03542	100.1441	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03403	104.6477	87th STREET - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03351	103.0512	87th STREET - CRAIG 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05637	117.1878	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05324	120.9893	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05324	120.9377	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05324	113.9419	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05097	110.8305	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05547	123.5074	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05338	115.6484	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05338	115.6344	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05338	108.6681	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05056	121.4464	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04407	99.4	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05418	113.8874	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05214	115.5155	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05214	115.5054	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05214	108.1685	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04937	110.8694	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05283	107.7654	HOYT - STRANGER CREEK 345KV CKT 1

*Table 9: Thermal Constraints Not Requiring Additional Transmission Reinforcements*

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05083	100.7288	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05083	100.7093	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04813	107.3599	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	VIOLA 7 345.00 (VIOLA 1X) 345/138/13.8KV TRANSFORMER CKT 1	448	492.8	0.03906	99.7	VIOLA 7 345.00 - WICHITA 345KV CKT 1

*Table 10: Voltage Constraints Requiring Additional Transmission Reinforcements*

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Max MW Available	Contingency
				Currently, None						

# THERMAL AND STEADY STATE VOLTAGE CONSTRAINTS TABLES BASE ON AECI UPGRADE SET #2

---

*Table 11: Thermal Constraints Requiring Additional Transmission Reinforcements*

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20L	ASGI_17_09	'FROM->TO'	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.19513	102.0882	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	'FROM->TO'	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.19513	102.0882	FAIRFAX - PAWNSW4 138.00 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	16WP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03303	109.503	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	17G	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03243	118.8066	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	17G	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	101.8052	GREC TAP5 345.00 - TULSA NORTH 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	100.9615	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03242	130.5685	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03242	116.7445	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03173	124.3499	GRDA1 - GREC TAP5 345.00 345KV CKT 1
0	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03173	103.4456	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03173	103.2941	GREC TAP5 345.00 - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03157	102.6698	P12:138:AEPW-WERE:NBVILLE4:DEARING4
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03153	102.4446	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03153	101.8617	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03027	100.1821	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03027	99.6	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02961	101.7491	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.0321	131.0749	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.0321	118.1286	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03134	122.9706	GRDA1 - GREC TAP5 345.00 345KV CKT 1
0	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03134	103.2621	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03134	102.2094	GREC TAP5 345.00 - TULSA NORTH 345KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03129	102.6064	P12:138:AEPW-WERE:NBVILLE4:DEARING4
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03125	102.3668	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03125	101.7595	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02994	100.2754	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02994	99.7	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02994	99.7	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03228	111.9168	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	20WP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03228	100.2982	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	20WP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03155	104.5612	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03247	128.73	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03247	114.2254	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03178	116.6651	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03155	99.9	P12:138:AEPW-WERE:NBVILLE4:DEARING4

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	99.6	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	99.1	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.1663	110.1744	BARNSDALL - SKIATOOK PUMP 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.1663	110.1708	P12:138:AEPW:BARNSAL4:T.NO.--4
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.1663	110.0014	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.14583	104.1276	BARTLESVILLE COMANCHE - BLUESTEM 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.14583	102.0697	BARTLESVILLE SOUTHEAST - BLUESTEM 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03046	108.9876	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03046	108.8412	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03046	104.1173	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03395	105.9919	ARCADIA - SEMINOLE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03145	100.6692	GRACEMONT - MINCO 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03038	104.6222	G14-057T 345.00 - SUNNYSIDE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03038	101.3296	G14-057T 345.00 - LAWTON EASTSIDE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03707	99.8	ARCADIA - SEMINOLE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06577	99.5	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06577	99.5	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06602	122.4773	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06602	122.4773	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06549	119.8965	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06549	119.8965	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06371	142.5648	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06371	142.5648	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06513	117.9396	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06513	117.9396	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06527	101.654	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06527	101.654	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06541	102.4312	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06541	102.4312	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.13056	102.4879	G15052_T 345.00 - ROSE HILL 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11974	101.402	SOONER - SPRING CREEK 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11974	101.3412	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11487	99.5	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11487	99.4	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11323	100.5183	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11152	101.2891	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1	143	143	0.05357	118.8064	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1	143	143	0.05357	118.8064	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	DOMES - MOUND ROAD 138KV CKT 1	189	189	0.16471	105.3708	4REMINGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	DOMES - PAWHUSKA TAP 138KV CKT 1	189	189	0.16471	106.3667	4REMINGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04873	105.6947	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04873	105.5807	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04873	101.202	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04779	109.3352	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04642	101.3107	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04642	101.3028	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0455	105.9135	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05064	118.9769	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05064	118.9756	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05064	114.3991	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04955	129.6283	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04746	108.9917	EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04729	117.0711	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0434	101.1519	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0434	101.1519	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04335	106.2871	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04324	105.265	MORRIS COUNTY - SWISSVALE 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04302	105.194	LACYGNE - STILWELL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04284	102.6132	AXTELL - G16-050-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04284	101.9835	G16-050-TAP 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04204	99	DELAWARE - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04204	99	DELAWARE - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04186	99.9	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0417	99.5	MINGO - RED WILLOW 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0417	99.5	MINGO - RED WILLOW 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04155	100.1244	7JASPER 345.00 - BLACKBERRY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04151	99.2	FT SMITH - MUSKOGEE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04143	99.3	DELAWARE - NORTHEAST STATION 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04143	99.3	DELAWARE - NORTHEAST STATION 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04141	105.0932	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04141	102.9267	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04141	100.6904	LATHAMS7 345.00 - ROSE HILL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	102.1063	P12:115:WERE:LANG-TECH_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	102.0292	P12:115:WERE:FOUR-LANG_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.9284	LANG - READING LAKE 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.6395	OSAGE CITY JUNCTION SWITCHING STATION - READING LAKE 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.0916	OSAGE CITY JUNCTION SWITCHING STATION - SCRNTJS3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.0905	SCRANTON - SCRNTJS3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.7816	FOUR CORNERS - SCRNTJN3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.7815	SCRANTON - SCRNTJN3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.4367	P12:115:WERE:FOUR-TECH_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.3819	CARB-KW 3 - FOUR CORNERS 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.1561	CARB-KW 3 - SHAWNEE HEIGHTS 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	99.6	SHAWNEE HEIGHTS - TECUMSEH HILL 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.041	100.6044	DBL-SPRVL-IR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04097	100.1854	RENO COUNTY - WICHITA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04091	99.6	P12:161:WERE:MARM-KCPL_161::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04091	99.6	CENTERVILLE - G15-016T 161.00 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04091	99.3	CENTERVILLE - PAOLA 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0409	99.5	MINGO - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0409	99.5	MINGO - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04084	99	BROOKLINE - FLINT CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04084	99	BROOKLINE - FLINT CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04075	99	RENO COUNTY - SUMMIT 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04063	106.3436	AUBURN ROAD - JEFFREY ENERGY CENTER 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04053	99.8	G13-010T 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04053	99.7	G13-010T 345.00 - G16-049-TAP 345.00 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04053	99.4	G16-049-TAP 345.00 - SPEARVILLE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04047	99.3	HOLCOMB - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04047	99.3	HOLCOMB - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04045	99	DELL 500 - INDEPENDENCE 500KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04044	99.7	AXTELL - PAULINE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0404	99.3	7MCCREDIE 345.00 - 7MONTGMRY 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04037	99.5	G15088_T 345.00 - MOORE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04037	99.2	G15088_T 345.00 - PAULINE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04035	99.5	CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.9	P12:115:WERE:AUBN-SMAN_115F3::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.9	P12:115:WERE:AUBN-SMAN_115F1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.9	P12:115:WERE:AUBN-SMAN_115F2::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.8	SMAN_W_3 115.00 - SOUTH MANHATTAN 115KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.67502	SOUTH ALMA - SOUTH MANHATTAN 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.11964	KEENE - SOUTH ALMA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04032	100.4624	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04032	99.8	G15063_T 345.00 - WOODRING 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04031	99.2	KEO EHV - WEST MEMPHIS 500 500KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04028	99.8	GRAND ISLAND - SWEETWATER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04023	99	7SPORTSMAN - BLACKBERRY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99.1	CLIFTON - CONCORDIA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99.1	CLIFTON - CONCORDIA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99	P12:115:WERE:KNOB-MKEC_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99	P12:115:WERE-MKEC:CLIFTON-KNOBHILL::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99	CLIFTON - GREENLEAF 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04012	99.2	G14-057T 345.00 - SUNNYSIDE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0401	99.1	5JASPER 161.00 - LAMAR 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0401	99.1	7JASPER 345.00 345/161KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04005	107.1274	P13:115-345:WERE:LANG_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04005	107.1274	LANG (LANG TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04005	107.1257	EMPORIA ENERGY CENTER - LANG 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04	99.1	AUBURN ROAD - SWISSVALE 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99.27483	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99.27483	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99	CIMARRON - DRAPER LAKE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99	GRAND ISLAND - MCCOOL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03993	99	HAWTHORN - NASHUA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03993	98.97136	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03993	98.97136	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03991	99.6	P13:069-138:WERE:ALTO_TX-10R3P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03991	99.3	DBL-HTCH-OTA
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03991	99.1	IATAN - NASHUA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA (CONCORD6) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA - ELM CREEK 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA (CONCORD6) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA - ELM CREEK 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03975	101.2688	DBL-THIS-G15
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03975	99.1	P12:069:WERE:ALLE-TIOG_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03974	99.7	P13:115-230:WERE:MCDO_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03974	99.7	MCDOWELL CREEK - MORRIS COUNTY 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03974	99.7	MCDOWELL CREEK (MCDO TX-1) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	105.5185	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	104.141	GEN542955 1-LACYGNE UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	104.0564	GEN542962 2-IATAN UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	103.4483	GEN542956 2-LACYGNE UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	103.3168	GEN542951 5-HAWTHORN UNIT #5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	103.0529	GEN542957 1-IATAN UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	102.427	GEN300003 1-THOMAS HILL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.5974	GEN640009 1-COOPER NUCLEAR STATION
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.5263	GEN645012 2-NEBRASKA CITY 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.3423	GEN645011 1-NEBRASKA CITY 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.0707	GEN541151 3-SIBLEY GENERATING UNIT #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.3996	P12:138:WERE:BENT-NORT_138P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.2772	GEN546702 1-NM GEN N1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.2207	GEN344225 1-1CAL G1 25.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.0523	GEN300007 1-NEW MADRID UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	GEN635024 4-WALTER SCOTT UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	GEN300006 1-NEW MADRID UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	P12:115:WERE:EMAN-KSU_115::

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	P12:069:WERE:COWS-HOOVS_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.9	GEN659103 1-ANTELOPE VALLEY UNIT1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.9	GEN659107 2-ANTELOPE VALLEY UNIT2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.9	EASTDC - ERCOT EQUIVALENCE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.8	GEN659111 2-LELAND OLDS UNIT2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.8	GEN300002 1-THOMAS HILL UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.7	GEN635023 3-WALTER SCOTT UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.7	GEN541162 1-ARIES STEAM TURBINE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.7	P12:115:WERE:PHLP-SALM_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	GEN542954 3-MONTROSE UNIT #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	GEN629075 1-OTTUMWA GENERATOR FOR OTTUMWA UNIT NO 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	GEN542953 2-MONTROSE UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	P12:138:WERE:HARR-WEAV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN590010 1-ERCOT EQUIVALENCE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN590011 2-ERCOT EQUIVALENCE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN532662 1-LAWRENCE ENERGY CENTER UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN562694 1-G15_016_3 0.6900
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	P12:115:WERE:3VAN-HEC_115P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	P12:115:WERE:EEUR-WEMPL_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	P12:069:WERE:MACA-PLAZ_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.4	GEN532672 1-TECUMSEH ENERGY CENTER UNIT 8
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN542967 9-HAWTHORN UNIT #9
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN300001 1-THOMAS HILL UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN636641 1-LOUISA UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN546698 1-QN GEN2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	P12:069:WERE:HOOVN-RIPL_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN629074 1-ARNOLD LOWSIDE OF GSU XFMR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN635214 4-NEAL UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN600002 3-SHERBURNE CNTY G3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN541166 2-SHARPR#2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543108 3-BULL CREEK COMBUSTION TURBINE #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543106 1-BULL CREEK COMBUSTION TURBINE #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543107 2-BULL CREEK COMBUSTION TURBINE #2

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543109 4-BULL CREEK COMBUSTION TURBINE #4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN505432 1-SIKESTON
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN541165 1-SHARPR#1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN542961 6-HAWTHORN COMBUSTION TURBINE #6
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN300011 1-ST FRANCIS UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN541163 1-ARIES COMBUSTION TURBINE #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN549893 2-SOUTHWEST 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN645025 5-NORTH OMAHA 5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	P12:069:WERE:MEAD-PLAZ_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	P12:069:WERE:COWS-SUNS_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	SHERBURNE CO 345/24.0KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344896 3-1LAB G3 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300012 1-HOLDEN UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN659110 1-LELAND OLDS UNIT1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN635213 3-NEAL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344894 1-1LAB G1 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300010 1-ST FRANCIS UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN543078 1-PAOLA COMBUSTION TURBINES
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN600000 1-SHERBURNECNTY G1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300013 1-HOLDEN UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344895 2-1LAB G2 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN645042 2-CASS COUNTY 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN600001 2-SHERBURNE CNTY G2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN645041 1-CASS COUNTY 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300015 1-1SGPDEL 18.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344897 4-1LAB G4 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	P12:115:WERE:ANZI-FITU_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	ABILENE ENERGY CENTER 115/34.5KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	4SIOUX 1 138.00 138/18.0KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03969	100	P12:069:WERE:64TH-NORT_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03968	101.0077	HOYT (HOYT TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03968	99.5	P12:069:WERE:MOUN-NEWT_69::

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03967	99.7	P12:138:WERE:HOOV-MURR_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03965	99	P12:138:WERE:17TH-CANA_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03965	99	P12:138:WERE:NORT-WEAV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03964	99.3	P12:138:WERE:COWS-WACO_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99.8	P12:138:WERE:GECT-HOOV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99.5	P12:115:WERE:LANG-WEMP_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99.1	P13:069-138:WERE:HOOV_TX-3::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99	ALTOONA - BUTLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03962	99.2	P13:069-138:WERE:COWS_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03962	99	P13:069-138:WERE:BUTL_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03958	99	P12:115:WERE:INDA-HOYT_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03941	104.5045	MORRIS COUNTY (MORR TX-1) 345/230/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03935	99.5	OVEXFRMCCOVE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03903	100.2276	SUMMIT - UNIONRG6 230.00 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03901	99.6	P12:115:WERE:MOUN-WEMP_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03901	99.1	P12:115:WERE:SPCKJ-WEMP_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03874	99	MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0386	100.4994	87th STREET - CRAIG 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0384	101.8884	87th STREET - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03825	99.1	7MCCREDIE 345.00 - 7OVERTON 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03805	99.3	DBL-THIS-WWR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03784	100.9513	BENTON - WICHITA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0377	99.5	RANCHR7 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03759	102.8606	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03759	101.7465	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03752	101.124	HUNTERS7 345.00 - WOODRING 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03752	99.2	G16-072-TAP 345.00 - HUNTERS7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03752	99.1	G16-072-TAP 345.00 - RENFROW7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05489	107.3806	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05489	107.2914	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05489	102.9466	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05459	104.9541	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05201	112.8729	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05201	112.8701	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05201	108.3238	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05115	122.7053	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04896	103.7365	EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04881	110.4837	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04464	101.0683	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04452	99.7	MORRIS COUNTY - SWISSVALE 230KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04425	99.8	LACYGNE - STILWELL 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04256	99.8	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04181	101.0892	AUBURN ROAD - JEFFREY ENERGY CENTER 230KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04123	102.2126	P13:115-345:WERE:LANG_TX-1::
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04123	102.2126	LANG (LANG TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04123	102.211	EMPORIA ENERGY CENTER - LANG 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04087	100.2299	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04087	99	GEN542955 1-LACYGNE UNIT #1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04087	99	GEN542962 2-IATAN UNIT #2
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04054	99.5	MORRIS COUNTY (MORR TX-1) 345/230/14.4KV TRANSFORMER CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05099	102.5505	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05099	102.5404	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05015	105.5003	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0499	102.1669	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0499	102.1649	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0491	112.0934	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04681	99.9	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06988	99.2	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06988	99.2	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06982	99.3	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06982	99.3	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17238	174.5054	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17238	174.5054	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17089	106.9083	4REMINGTON 138.00 - FAIRFAX 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11947	135.2455	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11947	135.2455	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11507	132.6854	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11507	132.6854	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10509	114.3917	OSAGE - WEBB CITY TAP 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10223	136.7851	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10043	130.181	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10043	129.7489	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09756	131.6556	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09756	131.6556	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09756	128.8151	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0962	131.5664	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0962	131.5296	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0962	131.3874	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0962	130.7505	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0962	130.2724	DOMES - MOUND ROAD 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09605	126.5992	BARNSDALL - SKIATOOK PUMP 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09605	126.5967	P12:138:AEPW:BARNSAL4:T.NO.--4
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09605	126.529	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09188	127.9325	CLEVELAND - JAVINE 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09188	127.0573	4SFORKKTP 138.00 - JAVINE 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09046	114.431	BURBANK - FAIRFAX 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09046	107.4722	GEN588303 1-ASGI1705-GEN0.6900
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09046	107.3964	4REMNGTON 138.00 - ASGI1705 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09046	106.7052	GEN301382 1-10SAGEWINDG10.6900
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09046	106.6263	40SAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08982	137.614	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08982	133.0169	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08768	116.5349	RAMONA - WALMART2 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08768	115.378	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08763	116.4423	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08763	116.1289	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08632	129.106	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08632	129.106	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08632	129.1013	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08599	115.3708	CLEVELAND DIST - HALLETT TAP 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08519	127.7707	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08493	142.377	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08493	142.3751	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	126.8709	4SFORKK 138.00 - 4SFORKKTP 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	126.866	4SFORKK 138.00 138/69KV TRANSFORMER CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06183	110.0706	SOUTH FORK - TALLANT 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06183	104.4088	2PRSHNGTP 69.000 - TALLANT 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06183	99.8	2PRSHNGTP 69.000 - PAWYA 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04939	107.3428	HALLETT TAP - PAWNEE 69KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17239	161.1549	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17239	161.1549	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17084	99	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11944	125.0771	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11944	125.0771	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11503	122.1855	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11503	122.1855	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10507	102.886	OSAGE - WEBB CITY TAP 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10219	126.0779	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10041	117.4907	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10041	117.2013	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09752	120.7157	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09752	120.7157	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09752	117.7336	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09616	120.6865	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09616	120.6568	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09616	120.576	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09616	119.7264	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09616	119.3686	DOMES - MOUND ROAD 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09602	115.3132	BARNSDALL - SKIATOOK PUMP 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09602	115.31	P12:138:AEPW:BARNSAL4:T.NO.--4

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09602	115.2312	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08978	127.3064	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08978	122.4333	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08766	104.6337	RAMONA - WALMART2 69KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08766	103.4238	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08762	104.8065	COLLINSVILLE (COLAUTO3) 161/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08762	104.8065	COLLINSVILLE (COLAUTO3) 161/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08762	103.7526	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0863	116.9276	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0863	116.9276	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0863	116.9275	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17232	181.7239	FAIRFAX - PAWNWSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17232	181.7239	FAIRFAX - PAWNWSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17085	120.5174	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11943	148.2471	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11943	148.2471	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.115	140.8777	CLEVELAND - PAWNWSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.115	140.8777	CLEVELAND - PAWNWSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10506	128.692	FAIRFAX TAP - SHIDLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10506	126.0548	OSAGE - WEBB CITY TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10216	148.79	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10038	142.0835	4GLENCOE 138.00 - PAWNWSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10038	141.5912	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0975	143.8599	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0975	143.8599	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0975	139.4966	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09613	144.1441	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09613	144.1406	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09613	143.9912	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09613	142.9332	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09613	142.3632	DOMES - MOUND ROAD 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09181	141.4308	CLEVELAND - JAVINE 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09181	140.324	4SFORKKTP 138.00 - JAVINE 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	126.1995	BURBANK - FAIRFAX 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	119.6069	GEN588303 1-ASGI1705-GEN0.6900
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	119.5073	4REMNGTON 138.00 - ASGI1705 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	118.8161	GEN301382 1-10SAGEWINDG10.6900
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	118.7122	40SAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	105.4422	GEN588323 1-ASGI1709-GEN0.6900
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	105.3103	ASGI1709 138.00 - FAIRFAX 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08974	149.854	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08974	145.3059	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08927	138.5622	4CLEVLNDXFMR138.00 138/69KV TRANSFORMER CKT 2
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08763	128.6105	RAMONA - WALMART TAP2 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08763	126.6087	RAMONA - WALMART2 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08763	124.9005	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08759	128.1036	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08759	127.6181	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08626	143.7095	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08626	143.7095	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08626	143.7095	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08593	127.2877	CLEVELAND DIST - HALLETT TAP 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08548	139.2777	CLEVELAND - HALLETT TAP 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08513	143.1714	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	161.522	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	161.5202	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
0	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	104.5005	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
0	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	104.4948	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08481	142.1469	4SFORKK 138.00 - 4SFORKKTP 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08481	142.1281	4SFORKK 138.00 138/69KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0618	123.9105	SOUTH FORK - TALLANT 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0618	117.6453	2PRSHNGTP 69.000 - TALLANT 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0618	108.6938	2PRSHNGTP 69.000 - PAWYA 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0618	104.3098	NAVAL RESERVE - PAWYA 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04934	126.402	HALLETT TAP - PAWNEE 69KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04934	101.4286	2GETTYTAP 69.000 - PAWNEE 69KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17185	153.702	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17185	153.702	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.1188	112.8775	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.1188	112.8775	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11379	117.1189	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11379	117.1189	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10129	119.2457	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09993	106.3681	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09993	106.2312	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0967	113.8824	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0967	113.8824	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0967	112.593	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09533	112.8201	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09533	112.7848	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09533	112.7731	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09533	112.1143	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09533	111.9604	DOMES - MOUND ROAD 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09519	107.9801	BARNSDALL - SKIATOOK PUMP 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09519	107.9775	P12:138:AEPW:BARNSAL4:T.NO.--4
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09519	107.9293	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09094	107.7161	CLEVELAND - JAVINE 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09094	107.486	4SFORKKTP 138.00 - JAVINE 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08883	121.4136	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08883	116.6966	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08557	105.889	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08557	105.889	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08557	105.6181	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08409	111.6519	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08409	111.5634	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17224	182.566	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17224	182.566	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17025	122.5632	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11915	150.3602	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11915	150.3602	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.1144	141.9227	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.1144	141.9227	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10486	128.1465	OSAGE - WEBB CITY TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10186	150.1646	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10032	144.6805	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10032	144.1761	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09723	145.244	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09723	145.244	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09723	140.8809	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09587	145.6201	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09587	145.6159	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09587	145.4604	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09587	144.3482	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09587	143.7641	DOMES - MOUND ROAD 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09156	143.3324	CLEVELAND - JAVINE 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09156	142.1738	4SFORKTP 138.00 - JAVINE 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	127.5684	BURBANK - FAIRFAX 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	121.5258	GEN588303 1-ASGI1705-GEN0.6900
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	121.4276	4REMNGTON 138.00 - ASGI1705 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	120.6345	4OSAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	120.59	GEN301382 1-1OSAGEWINDG10.6900
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	107.2631	GEN588323 1-ASGI1709-GEN0.6900
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	107.133	ASGI1709 138.00 - FAIRFAX 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08951	151.4752	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08951	146.9374	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0892	139.8244	4CLEVLNDXFMR138.00 138/69KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08906	140.5341	4CLEVLNDXFMR138.00 138/69KV TRANSFORMER CKT 2
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08743	130.2764	RAMONA - WALMART TAP2 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08743	130.1514	WALMART TAP2 - WALMART2 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08743	129.1208	RAMONA - WALMART2 69KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08743	127.0564	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08741	129.8963	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08741	129.8963	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08741	129.3814	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08607	145.6745	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08607	145.6745	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08607	145.6745	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08607	145.6745	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08572	128.979	CLEVELAND DIST - HALLETT TAP 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08528	141.4399	CLEVELAND - HALLETT TAP 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08492	145.4435	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	165.174	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	164.272	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
0	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	108.8845	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
0	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	108.8832	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08461	144.4515	4SFORKK 138.00 - 4SFORKKTP 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08461	144.4412	4SFORKK 138.00 138/69KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06169	126.4956	SOUTH FORK - TALLANT 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06169	120.5026	2PRSHNGTP 69.000 - TALLANT 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06169	110.5839	2PRSHNGTP 69.000 - PAWYA 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06169	106.0576	NAVAL RESERVE - PAWYA 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04918	129.6947	HALLETT TAP - PAWNEE 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04918	103.9857	2GETTYTAP 69.000 - PAWNEE 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17226	175.7747	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17226	175.7747	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17026	107.8133	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11917	136.5901	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11917	136.5901	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11442	131.9608	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11442	131.9608	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10487	115.4999	OSAGE - WEBB CITY TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10189	137.7797	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10034	132.0911	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10034	131.6273	4GLENCOE 138.00 - STILLWATER 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09725	132.6561	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09725	132.6561	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09725	129.813	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09589	132.5903	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09589	132.5556	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09589	132.4226	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09589	131.7691	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09589	131.2914	DOMES - MOUND ROAD 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09575	127.6629	BARNSDALL - SKIATOOK PUMP 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09575	127.6605	P12:138:AEPW:BARNSAL4:T.NO.--4
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09575	127.5944	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09158	129.3673	CLEVELAND - JAVINE 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09158	128.4566	4SFORKKTP 138.00 - JAVINE 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09021	115.6645	BURBANK - FAIRFAX 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09021	108.6142	GEN588303 1-ASGI1705-GEN0.6900
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09021	108.5315	4REMNGTON 138.00 - ASGI1705 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09021	107.8428	GEN301382 1-10SAGEWINDG10.6900
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09021	107.7567	40SAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08954	139.2905	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08954	134.6791	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08745	117.2165	RAMONA - WALMART2 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08745	116.4061	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08742	117.4132	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08742	117.0747	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08609	130.9703	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08609	130.9703	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08609	130.9697	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08574	116.5419	CLEVELAND DIST - HALLETT TAP 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08494	129.2248	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08467	144.7089	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08467	144.7076	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08462	128.3081	4SFORKK 138.00 - 4SFORKKTP 138.00 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08462	128.302	4SFORKK 138.00 138/69KV TRANSFORMER CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0617	111.0685	SOUTH FORK - TALLANT 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0617	105.2818	2PRSHNGTP 69.000 - TALLANT 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0617	100.8072	2PRSHNGTP 69.000 - PAWYA 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04919	110.0885	HALLETT TAP - PAWNEE 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17229	175.8534	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17229	175.8534	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17027	115.011	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11918	144.2254	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11918	144.2254	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11444	132.6455	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11444	132.6455	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10191	141.0127	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10036	137.8136	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10036	137.3567	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09727	136.2177	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09727	136.2177	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09591	136.8155	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09591	136.7999	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09591	136.6624	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09591	135.5031	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09591	134.9507	DOMES - MOUND ROAD 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09161	134.5165	CLEVELAND - JAVINE 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09161	133.3986	4SFORKKTP 138.00 - JAVINE 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	119.5807	BURBANK - FAIRFAX 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	113.7217	GEN588303 1-ASGI1705-GEN0.6900
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	113.61	4REMNGTON 138.00 - ASGI1705 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	112.9471	GEN301382 1-10SAGEWINDG10.6900
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	112.8304	40SAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	99.8	GEN588323 1-ASGI1709-GEN0.6900
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	99.7	ASGI1709 138.00 - FAIRFAX 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08957	141.3716	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08957	136.7344	G15066_T 345.00 - SOONER 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0891	132.4144	4CLEVLNDXFMR138.00 138/69KV TRANSFORMER CKT 2
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08747	121.2485	RAMONA - WALMART2 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08747	119.3783	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08744	122.5276	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08611	137.4823	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08611	137.4823	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08611	137.4823	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08611	137.4823	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08576	121.4013	CLEVELAND DIST - HALLETT TAP 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08532	133.219	CLEVELAND - HALLETT TAP 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08496	137.0808	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08469	155.1825	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08469	155.1755	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
0	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08469	101.0039	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
0	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08469	101.0024	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	136.8898	4SFORKK 138.00 - 4SFORKKTP 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	136.8696	4SFORKK 138.00 138/69KV TRANSFORMER CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06171	117.6732	SOUTH FORK - TALLANT 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06171	111.6685	2PRSHNGTP 69.000 - TALLANT 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06171	107.113	2PRSHNGTP 69.000 - PAWYA 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06171	102.7122	NAVAL RESERVE - PAWYA 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04921	121.6949	HALLETT TAP - PAWNEE 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03238	123.5248	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03238	123.5248	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03181	124.1416	SOONER (SOONER5) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03212	121.6782	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03212	121.6782	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03155	122.7703	SOONER (SOONER5) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03258	115.5398	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03258	115.5398	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06205	107.9944	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05513	113.9402	SOONER - SPRING CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05513	113.8065	NORTHWEST - SPRING CREEK 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06389	105.4279	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05862	109.6743	SOONER - SPRING CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05862	109.5365	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.02963	99.1	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05475	108.312	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05475	101.2081	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05884	105.2867	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05884	105.1185	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05377	103.5741	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05377	103.4313	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05433	119.03	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05433	111.8395	SOONER - SPRING CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07085	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06563	103.7918	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06563	99.7	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06308	100.9393	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.0798	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07136	106.0876	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07136	101.848	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06773	102.0882	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07085	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06563	103.7918	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06563	99.7	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06308	100.9392	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.0798	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07136	106.0873	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07136	101.848	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06773	102.0881	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	1076	1076	0.05165	102.3655	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	1076	1076	0.05135	102.8851	SWISSVALE - WEST GARDNER 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	NORTHWEST - SPRING CREEK 345KV CKT 1	1039	1195	0.05669	101.8408	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20L	ASGI_17_09	TO->FROM	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1	189	189	0.16471	110.52	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1	189	189	0.1129	99.8	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1	189	189	0.1129	99.8	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SHIDLER - WEST PAWHUSKA 138KV CKT 1	181	189	0.16471	110.9191	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SHIDLER - WEST PAWHUSKA 138KV CKT 1	181	189	0.1129	100.1719	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SHIDLER - WEST PAWHUSKA 138KV CKT 1	181	189	0.1129	100.1719	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	SPVALLY4 138.00 - STILLWATER 138KV CKT 1	194	222	0.05296	102.7363	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	SPVALLY4 138.00 - STILLWATER 138KV CKT 1	194	222	0.05296	102.7363	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04879	115.4996	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04722	116.6035	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04722	116.4668	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04722	109.1779	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.0445	112.1712	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04596	121.6376	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04456	119.8446	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04456	119.8389	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04456	112.6805	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04193	117.1723	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05142	134.6016	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04979	125.3374	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04979	125.3188	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04979	118.245	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04694	131.5041	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04127	107.8276	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03971	99.1	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03971	99.1	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03888	99.9	AXTELL - G16-050-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03888	99.2	G16-050-TAP 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03874	101.8732	LACYGNE - STILLWELL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	103.0147	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	100.1891	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03641	99	TECUMSEH HILL (TECH TX-3) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03641	99	SWISSVALE - TECUMSEH HILL 230KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03619	99.8	LAWRENCE HILL (LAWH TX-3) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	104.6101	GEN542955 1-LACYGNE UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	103.4184	GEN542956 2-LACYGNE UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	100.4388	GEN542951 5-HAWTHORN UNIT #5
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	99.7	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	99.6	GEN300003 1-THOMAS HILL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03309	101.4986	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03309	99.9	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03192	104.4065	87th STREET - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03134	102.8172	87th STREET - CRAIG 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05392	116.7958	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05065	120.6758	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05065	120.3491	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05065	113.4468	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04865	110.4556	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.053	123.2303	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05077	115.3638	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05077	115.3468	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05077	108.3561	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04822	121.1677	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04219	99.2	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05171	113.6272	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04953	115.1769	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04953	115.1748	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04953	107.858	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04703	110.6009	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05036	107.521	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04822	100.457	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04822	100.4376	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04579	107.1251	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	VIOLA 7 345.00 (VIOLA 1X) 345/138/13.8KV TRANSFORMER CKT 1	448	492.8	0.03674	99.4	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03303	109.503	P12:138:AEPW:N.E.S.-4:CATOOSA4

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17G	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03243	118.8066	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	17G	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	101.8052	GREC TAP5 345.00 - TULSA NORTH 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	100.9615	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03242	130.5685	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03242	116.7445	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03173	124.3499	GRDA1 - GREC TAP5 345.00 345KV CKT 1
0	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03173	103.4456	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03173	103.2941	GREC TAP5 345.00 - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03157	102.6698	P12:138:AEPW-WERE:NBVILLE4:DEARING4
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03153	102.4446	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03153	101.8617	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03027	100.1821	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03027	99.6	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02961	101.7491	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.0321	131.0749	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.0321	118.1286	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03134	122.9706	GRDA1 - GREC TAP5 345.00 345KV CKT 1
0	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03134	103.2621	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03134	102.2094	GREC TAP5 345.00 - TULSA NORTH 345KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03129	102.6064	P12:138:AEPW-WERE:NBVILLE4:DEARING4
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03125	102.3668	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03125	101.7595	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02994	100.2754	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02994	99.7	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02994	99.7	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03228	111.9168	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	20WP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03228	100.2982	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	20WP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03155	104.5612	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03247	128.73	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03247	114.2254	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03178	116.6651	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03155	99.9	P12:138:AEPW-WERE:NBVILLE4:DEARING4
08ALL	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	99.6	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	25SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	99.1	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.1663	110.1744	BARNSDALL - SKIATOOK PUMP 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.1663	110.1708	P12:138:AEPW:BARNSAL4:T.NO.--4
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.1663	110.0014	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.14583	104.1276	BARTLESVILLE COMANCHE - BLUESTEM 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.14583	102.0697	BARTLESVILLE SOUTHEAST - BLUESTEM 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03046	108.9876	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03046	108.8412	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03046	104.1173	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03395	105.9919	ARCADIA - SEMINOLE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03145	100.6692	GRACEMONT - MINCO 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03038	104.6222	G14-057T 345.00 - SUNNYSIDE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03038	101.3296	G14-057T 345.00 - LAWTON EASTSIDE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03707	99.8	ARCADIA - SEMINOLE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06577	99.5	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06577	99.5	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06602	122.4773	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06602	122.4773	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06549	119.8965	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06549	119.8965	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06371	142.5648	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06371	142.5648	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06513	117.9396	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06513	117.9396	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06527	101.654	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06527	101.654	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06541	102.4312	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06541	102.4312	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.13056	102.4879	G15052_T 345.00 - ROSE HILL 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11974	101.402	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11974	101.3412	NORTHWEST - SPRING CREEK 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11487	99.5	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11487	99.4	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11323	100.5183	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11152	101.2891	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1	143	143	0.05357	118.8064	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1	143	143	0.05357	118.8064	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	DOMES - MOUND ROAD 138KV CKT 1	189	189	0.16471	105.3708	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	DOMES - PAWHUSKA TAP 138KV CKT 1	189	189	0.16471	106.3667	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04873	105.6947	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04873	105.5807	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04873	101.202	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04779	109.3352	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04642	101.3107	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04642	101.3028	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0455	105.9135	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05064	118.9769	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05064	118.9756	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05064	114.3991	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04955	129.6283	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04746	108.9917	EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04729	117.0711	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0434	101.1519	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0434	101.1519	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04335	106.2871	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04324	105.265	MORRIS COUNTY - SWISSVALE 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04302	105.194	LACYGNE - STILWELL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04284	102.6132	AXTELL - G16-050-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04284	101.9835	G16-050-TAP 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04204	99	DELAWARE - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04204	99	DELAWARE - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04186	99.9	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0417	99.5	MINGO - RED WILLOW 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0417	99.5	MINGO - RED WILLOW 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04155	100.1244	7JASPER 345.00 - BLACKBERRY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04151	99.2	FT SMITH - MUSKOGEE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04143	99.3	DELAWARE - NORTHEAST STATION 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04143	99.3	DELAWARE - NORTHEAST STATION 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04141	105.0932	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04141	102.9267	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04141	100.6904	LATHAMS7 345.00 - ROSE HILL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	102.1063	P12:115:WERE:LANG-TECH_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	102.0292	P12:115:WERE:FOUR-LANG_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.9284	LANG - READING LAKE 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.6395	OSAGE CITY JUNCTION SWITCHING STATION - READING LAKE 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.0916	OSAGE CITY JUNCTION SWITCHING STATION - SCRNTJS3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.0905	SCRANTON - SCRNTJS3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.7816	FOUR CORNERS - SCRNTJN3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.7815	SCRANTON - SCRNTJN3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.4367	P12:115:WERE:FOUR-TECH_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.3819	CARB-KW 3 - FOUR CORNERS 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.1561	CARB-KW 3 - SHAWNEE HEIGHTS 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	99.6	SHAWNEE HEIGHTS - TECUMSEH HILL 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.041	100.6044	DBL-SPRVL-IR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04097	100.1854	RENO COUNTY - WICHITA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04091	99.6	P12:161:WERE:MARM-KCPL_161::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04091	99.6	CENTERVILLE - G15-016T 161.00 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04091	99.3	CENTERVILLE - PAOLA 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0409	99.5	MINGO - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0409	99.5	MINGO - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04084	99	BROOKLINE - FLINT CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04084	99	BROOKLINE - FLINT CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04075	99	RENO COUNTY - SUMMIT 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04063	106.3436	AUBURN ROAD - JEFFREY ENERGY CENTER 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04053	99.8	G13-010T 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04053	99.7	G13-010T 345.00 - G16-049-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04053	99.4	G16-049-TAP 345.00 - SPEARVILLE 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04047	99.3	HOLCOMB - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04047	99.3	HOLCOMB - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04045	99	DELL 500 - INDEPENDENCE 500KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04044	99.7	AXTELL - PAULINE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0404	99.3	7MCCREDIE 345.00 - 7MONTGMRY 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04037	99.5	G15088_T 345.00 - MOORE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04037	99.2	G15088_T 345.00 - PAULINE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04035	99.5	CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.9	P12:115:WERE:AUBN-SMAN_115F3::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.9	P12:115:WERE:AUBN-SMAN_115F1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.9	P12:115:WERE:AUBN-SMAN_115F2::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.8	SMAN_W_3 115.00 - SOUTH MANHATTAN 115KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.67502	SOUTH ALMA - SOUTH MANHATTAN 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.11964	KEENE - SOUTH ALMA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04032	100.4624	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04032	99.8	G15063_T 345.00 - WOODRING 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04031	99.2	KEO EHV - WEST MEMPHIS 500 500KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04028	99.8	GRAND ISLAND - SWEETWATER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04023	99	7SPORTSMAN - BLACKBERRY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99.1	CLIFTON - CONCORDIA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99.1	CLIFTON - CONCORDIA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99	P12:115:WERE:KNOB-MKEC_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99	P12:115:WERE-MKEC:CLIFTON-KNOBHILL::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99	CLIFTON - GREENLEAF 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04012	99.2	G14-057T 345.00 - SUNNYSIDE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0401	99.1	5JASPER 161.00 - LAMAR 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0401	99.1	7JASPER 345.00 345/161KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04005	107.1274	P13:115-345:WERE:LANG_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04005	107.1274	LANG (LANG TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04005	107.1257	EMPORIA ENERGY CENTER - LANG 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04	99.1	AUBURN ROAD - SWISSVALE 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99.27483	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99.27483	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99	CIMARRON - DRAPER LAKE 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99	GRAND ISLAND - MCCOOL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03993	99	HAWTHORN - NASHUA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03993	98.97136	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03993	98.97136	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03991	99.6	P13:069-138:WERE:ALTO_TX-10R3P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03991	99.3	DBL-HTCH-OTA
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03991	99.1	IATAN - NASHUA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA (CONCORD6) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA - ELM CREEK 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA (CONCORD6) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA - ELM CREEK 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03975	101.2688	DBL-THIS-G15
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03975	99.1	P12:069:WERE:ALLE-TIOG_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03974	99.7	P13:115-230:WERE:MCDO_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03974	99.7	MCDOWELL CREEK - MORRIS COUNTY 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03974	99.7	MCDOWELL CREEK (MCDO TX-1) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	105.5185	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	104.141	GEN542955 1-LACYGNE UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	104.0564	GEN542962 2-IATAN UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	103.4483	GEN542956 2-LACYGNE UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	103.3168	GEN542951 5-HAWTHORN UNIT #5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	103.0529	GEN542957 1-IATAN UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	102.427	GEN300003 1-THOMAS HILL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.5974	GEN640009 1-COOPER NUCLEAR STATION
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.5263	GEN645012 2-NEBRASKA CITY 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.3423	GEN645011 1-NEBRASKA CITY 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.0707	GEN541151 3-SIBLEY GENERATING UNIT #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.3996	P12:138:WERE:BENT-NORT_138P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.2772	GEN546702 1-NM GEN N1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.2207	GEN344225 1-1CAL G1 25.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.0523	GEN300007 1-NEW MADRID UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	GEN635024 4-WALTER SCOTT UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	GEN300006 1-NEW MADRID UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	P12:115:WERE:EMAN-KSU_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	P12:069:WERE:COWS-HOOVS_69F::

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.9	GEN659103 1-ANTELOPE VALLEY UNIT1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.9	GEN659107 2-ANTELOPE VALLEY UNIT2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.9	EASTDC - ERCOT EQUIVALENCE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.8	GEN659111 2-LELAND OLDS UNIT2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.8	GEN300002 1-THOMAS HILL UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.7	GEN635023 3-WALTER SCOTT UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.7	GEN541162 1-ARIES STEAM TURBINE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.7	P12:115:WERE:PHLP-SALM_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	GEN542954 3-MONTROSE UNIT #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	GEN629075 1-OTTUMWA GENERATOR FOR OTTUMWA UNIT NO 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	GEN542953 2-MONTROSE UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	P12:138:WERE:HARR-WEAV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN590010 1-ERCOT EQUIVALENCE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN590011 2-ERCOT EQUIVALENCE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN532662 1-LAWRENCE ENERGY CENTER UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN562694 1-G15_016_3 0.6900
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	P12:115:WERE:3VAN-HEC_115P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	P12:115:WERE:EEUR-WEMP_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	P12:069:WERE:MACA-PLAZ_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.4	GEN532672 1-TECUMSEH ENERGY CENTER UNIT 8
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN542967 9-HAWTHORN UNIT #9
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN300001 1-THOMAS HILL UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN636641 1-LOUISA UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN546698 1-QN GEN2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	P12:069:WERE:HOOVN-RIPL_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN629074 1-ARNOLD LOWSIDE OF GSU XFMR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN635214 4-NEAL UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN600002 3-SHERBURNE CNTY G3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN541166 2-SHARPR#2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543108 3-BULL CREEK COMBUSTION TURBINE #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543106 1-BULL CREEK COMBUSTION TURBINE #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543107 2-BULL CREEK COMBUSTION TURBINE #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543109 4-BULL CREEK COMBUSTION TURBINE #4

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN505432 1-SIKESTON
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN541165 1-SHARPR#1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN542961 6-HAWTHORN COMBUSTION TURBINE #6
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN300011 1-ST FRANCIS UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN541163 1-ARIES COMBUSTION TURBINE #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN549893 2-SOUTHWEST 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN645025 5-NORTH OMAHA 5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	P12:069:WERE:MEAD-PLAZ_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	P12:069:WERE:COWS-SUNS_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	SHERBURNE CO 345/24.0KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344896 3-1LAB G3 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300012 1-HOLDEN UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN659110 1-LELAND OLDS UNIT1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN635213 3-NEAL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344894 1-1LAB G1 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300010 1-ST FRANCIS UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN543078 1-PAOLA COMBUSTION TURBINES
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN600000 1-SHERBURNECNTY G1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300013 1-HOLDEN UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344895 2-1LAB G2 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN645042 2-CASS COUNTY 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN600001 2-SHERBURNE CNTY G2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN645041 1-CASS COUNTY 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300015 1-1SGPDEL 18.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344897 4-1LAB G4 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	P12:115:WERE:ANZI-FITU_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	ABILENE ENERGY CENTER 115/34.5KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	4SIJOUX 1 138.00 138/18.0KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03969	100	P12:069:WERE:64TH-NORT_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03968	101.0077	HOYT (HOYT TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03968	99.5	P12:069:WERE:MOUN-NEWT_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03967	99.7	P12:138:WERE:HOOV-MURR_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03965	99	P12:138:WERE:17TH-CANA_138::

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03965	99	P12:138:WERE:NORT-WEAV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03964	99.3	P12:138:WERE:COWS-WACO_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99.8	P12:138:WERE:GECT-HOOV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99.5	P12:115:WERE:LANG-WEMP_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99.1	P13:069-138:WERE:HOOV_TX-3::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99	ALTOONA - BUTLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03962	99.2	P13:069-138:WERE:COWS_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03962	99	P13:069-138:WERE:BUTL_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03958	99	P12:115:WERE:INDA-HOYT_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03941	104.5045	MORRIS COUNTY (MORR TX-1) 345/230/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03935	99.5	OVEXFRMCCOVE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03903	100.2276	SUMMIT - UNIONRG6 230.00 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03901	99.6	P12:115:WERE:MOUN-WEMP_115P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03901	99.1	P12:115:WERE:SPCKJ-WEMP_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03874	99	MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0386	100.4994	87th STREET - CRAIG 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0384	101.8884	87th STREET - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03825	99.1	7MCCREDIE 345.00 - 7OVERTON 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03805	99.3	DBL-THIS-WWR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03784	100.9513	BENTON - WICHITA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0377	99.5	RANCHRD7 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03759	102.8606	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03759	101.7465	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03752	101.124	HUNTERS7 345.00 - WOODRING 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03752	99.2	G16-072-TAP 345.00 - HUNTERS7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03752	99.1	G16-072-TAP 345.00 - RENFROW7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05489	107.3806	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05489	107.2914	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05489	102.9466	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05459	104.9541	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05201	112.8729	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05201	112.8701	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05201	108.3238	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05115	122.7053	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04896	103.7365	EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04881	110.4837	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04464	101.0683	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04452	99.7	MORRIS COUNTY - SWISSVALE 230KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04425	99.8	LACYGNE - STILWELL 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04256	99.8	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04181	101.0892	AUBURN ROAD - JEFFREY ENERGY CENTER 230KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04123	102.2126	P13:115-345:WERE:LANG_TX-1::
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04123	102.2126	LANG (LANG TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04123	102.211	EMPORIA ENERGY CENTER - LANG 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04087	100.2299	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04087	99	GEN542955 1-LACYGNE UNIT #1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04087	99	GEN542962 2-IATAN UNIT #2
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04054	99.5	MORRIS COUNTY (MORR TX-1) 345/230/14.4KV TRANSFORMER CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05099	102.5505	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05099	102.5404	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05015	105.5003	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0499	102.1669	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0499	102.1649	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0491	112.0934	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04681	99.9	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06988	99.2	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06988	99.2	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06982	99.3	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06982	99.3	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17238	174.5054	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17238	174.5054	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17089	106.9083	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11947	135.2455	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11947	135.2455	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11507	132.6854	CLEVELAND - PAWNSW4 138.00 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11507	132.6854	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10509	114.3917	OSAGE - WEBB CITY TAP 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10223	136.7851	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10043	130.181	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10043	129.7489	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09756	131.6556	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09756	131.6556	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09756	128.8151	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0962	131.5664	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0962	131.5296	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0962	131.3874	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0962	130.7505	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0962	130.2724	DOMES - MOUND ROAD 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09605	126.5992	BARNSDALL - SKIATOOK PUMP 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09605	126.5967	P12:138:AEPW:BARNSAL4:T.NO.--4
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09605	126.529	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09188	127.9325	CLEVELAND - JAVINE 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09188	127.0573	4SFORKTTP 138.00 - JAVINE 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09046	114.431	BURBANK - FAIRFAX 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09046	107.4722	GEN588303 1-ASGI1705-GEN0.6900
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09046	107.3964	4REMNGTON 138.00 - ASGI1705 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09046	106.7052	GEN301382 1-1OSAGEWINDG10.6900
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09046	106.6263	4OSAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08982	137.614	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08982	133.0169	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08768	116.5349	RAMONA - WALMART2 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08768	115.378	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08763	116.4423	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08763	116.1289	4SFORKTTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08632	129.106	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08632	129.106	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08632	129.1013	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08599	115.3708	CLEVELAND DIST - HALLETT TAP 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08519	127.7707	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08493	142.377	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08493	142.3751	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	126.8709	4SFORKK 138.00 - 4SFORKKTP 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	126.866	4SFORKK 138.00 138/69KV TRANSFORMER CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06183	110.0706	SOUTH FORK - TALLANT 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06183	104.4088	2PRSHNGTP 69.000 - TALLANT 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06183	99.8	2PRSHNGTP 69.000 - PAWYA 69KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04939	107.3428	HALLETT TAP - PAWNEE 69KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17239	161.1549	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17239	161.1549	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17084	99	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11944	125.0771	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11944	125.0771	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11503	122.1855	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11503	122.1855	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10507	102.886	OSAGE - WEBB CITY TAP 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10219	126.0779	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10041	117.4907	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10041	117.2013	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09752	120.7157	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09752	120.7157	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09752	117.7336	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09616	120.6865	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09616	120.6568	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09616	120.576	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09616	119.7264	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09616	119.3686	DOMES - MOUND ROAD 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09602	115.3132	BARNSDALL - SKIATOOK PUMP 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09602	115.31	P12:138:AEPW:BARNSAL4:T.NO.--4
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09602	115.2312	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08978	127.3064	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08978	122.4333	G15066_T 345.00 - SOONER 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08766	104.6337	RAMONA - WALMART2 69KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08766	103.4238	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08762	104.8065	COLLINSVILLE (COLAUTO3) 161/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08762	104.8065	COLLINSVILLE (COLAUTO3) 161/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08762	103.7526	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0863	116.9276	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0863	116.9276	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0863	116.9275	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17232	181.7239	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17232	181.7239	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17085	120.5174	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11943	148.2471	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11943	148.2471	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.115	140.8777	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.115	140.8777	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10506	128.692	FAIRFAX TAP - SHIDLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10506	126.0548	OSAGE - WEBB CITY TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10216	148.79	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10038	142.0835	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10038	141.5912	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0975	143.8599	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0975	143.8599	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0975	139.4966	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09613	144.1441	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09613	144.1406	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09613	143.9912	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09613	142.9332	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09613	142.3632	DOMES - MOUND ROAD 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09181	141.4308	CLEVELAND - JAVINE 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09181	140.324	4SFORKTAP 138.00 - JAVINE 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	126.1995	BURBANK - FAIRFAX 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	119.6069	GEN588303 1-ASGI1705-GEN0.6900

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	119.5073	4REMNGTON 138.00 - ASGI1705 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	118.8161	GEN301382 1-10SAGEWINDG10.6900
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	118.7122	40SAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	105.4422	GEN588323 1-ASGI1709-GEN0.6900
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0904	105.3103	ASGI1709 138.00 - FAIRFAX 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08974	149.854	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08974	145.3059	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08927	138.5622	4CLEVLNDXFMR138.00 138/69KV TRANSFORMER CKT 2
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08763	128.6105	RAMONA - WALMART TAP2 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08763	126.6087	RAMONA - WALMART2 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08763	124.9005	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08759	128.1036	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08759	127.6181	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08626	143.7095	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08626	143.7095	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08626	143.7095	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08593	127.2877	CLEVELAND DIST - HALLETT TAP 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08548	139.2777	CLEVELAND - HALLETT TAP 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08513	143.1714	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	161.522	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	161.5202	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
0	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	104.5005	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
0	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08486	104.4948	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08481	142.1469	4SFORKK 138.00 - 4SFORKKTP 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08481	142.1281	4SFORKK 138.00 138/69KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0618	123.9105	SOUTH FORK - TALLANT 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0618	117.6453	2PRSHNGTP 69.000 - TALLANT 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0618	108.6938	2PRSHNGTP 69.000 - PAWYA 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0618	104.3098	NAVAL RESERVE - PAWYA 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04934	126.402	HALLETT TAP - PAWNEE 69KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04934	101.4286	2GETTYTAP 69.000 - PAWNEE 69KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17185	153.702	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17185	153.702	FAIRFAX - PAWNSW4 138.00 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.1188	112.8775	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.1188	112.8775	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11379	117.1189	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11379	117.1189	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10129	119.2457	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09993	106.3681	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09993	106.2312	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0967	113.8824	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0967	113.8824	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0967	112.593	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09533	112.8201	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09533	112.7848	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09533	112.7731	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09533	112.1143	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09533	111.9604	DOMES - MOUND ROAD 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09519	107.9801	BARNSDALL - SKIATOOK PUMP 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09519	107.9775	P12:138:AEPW:BARNSAL4:T.NO.--4
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09519	107.9293	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09094	107.7161	CLEVELAND - JAVINE 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09094	107.486	4SFORKKTP 138.00 - JAVINE 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08883	121.4136	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08883	116.6966	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08557	105.889	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08557	105.889	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08557	105.6181	CLEVELAND - CLEVIND 4 138.00 138KV CKT Z1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08409	111.6519	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
08ALL	20L	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08409	111.5634	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17224	182.566	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17224	182.566	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17025	122.5632	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11915	150.3602	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11915	150.3602	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.1144	141.9227	CLEVELAND - PAWNSW4 138.00 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.1144	141.9227	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10486	128.1465	OSAGE - WEBB CITY TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10186	150.1646	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10032	144.6805	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10032	144.1761	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09723	145.244	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09723	145.244	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09723	140.8809	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09587	145.6201	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09587	145.6159	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09587	145.4604	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09587	144.3482	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09587	143.7641	DOMES - MOUND ROAD 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09156	143.3324	CLEVELAND - JAVINE 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09156	142.1738	4SFORKKTP 138.00 - JAVINE 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	127.5684	BURBANK - FAIRFAX 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	121.5258	GEN588303 1-ASGI1705-GEN0.6900
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	121.4276	4REMNGTON 138.00 - ASGI1705 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	120.6345	4OSAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	120.59	GEN301382 1-1OSAGEWINDG10.6900
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	107.2631	GEN588323 1-ASGI1709-GEN0.6900
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09019	107.133	ASGI1709 138.00 - FAIRFAX 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08951	151.4752	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08951	146.9374	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0892	139.8244	4CLEVLNDXFMR138.00 138/69KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08906	140.5341	4CLEVLNDXFMR138.00 138/69KV TRANSFORMER CKT 2
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08743	130.2764	RAMONA - WALMART TAP2 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08743	130.1514	WALMART TAP2 - WALMART2 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08743	129.1208	RAMONA - WALMART2 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08743	127.0564	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08741	129.8963	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08741	129.8963	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08741	129.3814	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08607	145.6745	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08607	145.6745	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08607	145.6745	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08607	145.6745	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08572	128.979	CLEVELAND DIST - HALLETT TAP 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08528	141.4399	CLEVELAND - HALLETT TAP 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08492	145.4435	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	165.174	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	164.272	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
0	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	108.8845	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
0	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	108.8832	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08461	144.4515	4SFORKK 138.00 - 4SFORKKTP 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08461	144.4412	4SFORKK 138.00 138/69KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06169	126.4956	SOUTH FORK - TALLANT 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06169	120.5026	2PRSHNGTP 69.000 - TALLANT 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06169	110.5839	2PRSHNGTP 69.000 - PAWYA 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06169	106.0576	NAVAL RESERVE - PAWYA 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04918	129.6947	HALLETT TAP - PAWNEE 69KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04918	103.9857	2GETTYTAP 69.000 - PAWNEE 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17226	175.7747	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17226	175.7747	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17026	107.8133	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11917	136.5901	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11917	136.5901	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11442	131.9608	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11442	131.9608	CLEVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10487	115.4999	OSAGE - WEBB CITY TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10189	137.7797	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10034	132.0911	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10034	131.6273	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09725	132.6561	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09725	132.6561	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09725	129.813	P12:138:AEPW:BV-COM-4:BV-SE--4
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09589	132.5903	P12:138:AEPW:MOUNDRD4:SHIDLER4
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09589	132.5556	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09589	132.4226	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09589	131.7691	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09589	131.2914	DOMES - MOUND ROAD 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09575	127.6629	BARNSDALL - SKIATOOK PUMP 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09575	127.6605	P12:138:AEPW:BARNSAL4:T.NO.--4
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09575	127.5944	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09158	129.3673	CLEVELAND - JAVINE 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09158	128.4566	4SFORKKTP 138.00 - JAVINE 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09021	115.6645	BURBANK - FAIRFAX 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09021	108.6142	GEN588303 1-ASGI1705-GEN0.6900
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09021	108.5315	4REMNGTON 138.00 - ASGI1705 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09021	107.8428	GEN301382 1-10SAGEWINDG10.6900
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09021	107.7567	40SAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08954	139.2905	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08954	134.6791	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08745	117.2165	RAMONA - WALMART2 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08745	116.4061	RAMONA - SOUTH FORK 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08742	117.4132	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08742	117.0747	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08609	130.9703	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08609	130.9703	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08609	130.9697	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08574	116.5419	CLEVELAND DIST - HALLETT TAP 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08494	129.2248	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08467	144.7089	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08467	144.7076	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08462	128.3081	4SFORKK 138.00 - 4SFORKKTP 138.00 138KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08462	128.302	4SFORKK 138.00 138/69KV TRANSFORMER CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0617	111.0685	SOUTH FORK - TALLANT 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0617	105.2818	2PRSHNGTP 69.000 - TALLANT 69KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0617	100.8072	2PRSHNGTP 69.000 - PAWYA 69KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04919	110.0885	HALLETT TAP - PAWNEE 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17229	175.8534	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17229	175.8534	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.17027	115.011	4REMNGTON 138.00 - FAIRFAX 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11918	144.2254	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11918	144.2254	4REMNGTON 138.00 - SHIDLER 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11444	132.6455	CLEAVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.11444	132.6455	CLEAVELAND - PAWNSW4 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10191	141.0127	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10036	137.8136	4GLENCOE 138.00 - PAWNSW4 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.10036	137.3567	4GLENCOE 138.00 - STILLWATER 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09727	136.2177	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09727	136.2177	BARTLESVILLE COMANCHE - MOUND ROAD 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09591	136.8155	SHIDLER - WEST PAWHUSKA 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09591	136.7999	P12:138: AEPW:MOUNDRD4:SHIDLER4
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09591	136.6624	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09591	135.5031	DOMES - PAWHUSKA TAP 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09591	134.9507	DOMES - MOUND ROAD 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09161	134.5165	CLEAVELAND - JAVINE 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09161	133.3986	4SFORKTPT 138.00 - JAVINE 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	119.5807	BURBANK - FAIRFAX 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	113.7217	GEN588303 1-ASGI1705-GEN0.6900
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	113.61	4REMNGTON 138.00 - ASGI1705 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	112.9471	GEN301382 1-10SAGEWINDG10.6900
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	112.8304	40SAGEWIND 138.00 - 4REMNGTON 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	99.8	GEN588323 1-ASGI1709-GEN0.6900
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.09023	99.7	ASGI1709 138.00 - FAIRFAX 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08957	141.3716	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08957	136.7344	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.0891	132.4144	4CLEVLNDXFMR138.00 138/69KV TRANSFORMER CKT 2
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08747	121.2485	RAMONA - WALMART2 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08747	119.3783	RAMONA - SOUTH FORK 69KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08744	122.5276	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08611	137.4823	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08611	137.4823	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08611	137.4823	CLEVELAND - CLEVELND 4 138.00 138KV CKT Z1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08611	137.4823	CLEVELAND (CLVAUTO1) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08576	121.4013	CLEVELAND DIST - HALLETT TAP 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08532	133.219	CLEVELAND - HALLETT TAP 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08496	137.0808	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08469	155.1825	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08469	155.1755	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
0	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08469	101.0039	2CLEVLNDXFMR69.000 - CLEVELAND 69KV CKT Z1
0	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08469	101.0024	4CLEVLNDXFMR138.00 - CLEVELAND 138KV CKT Z1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	136.8898	4SFORKK 138.00 - 4SFORKKTP 138.00 138KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.08464	136.8696	4SFORKK 138.00 138/69KV TRANSFORMER CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06171	117.6732	SOUTH FORK - TALLANT 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06171	111.6685	2PRSHNGTP 69.000 - TALLANT 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06171	107.113	2PRSHNGTP 69.000 - PAWYA 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.06171	102.7122	NAVAL RESERVE - PAWYA 69KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	FAIRFAX 138/69KV TRANSFORMER CKT 1	64	64	0.04921	121.6949	HALLETT TAP - PAWNEE 69KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03238	123.5248	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03238	123.5248	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03181	124.1416	SOONER (SOONER5) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03212	121.6782	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03212	121.6782	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03155	122.7703	SOONER (SOONER5) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03258	115.5398	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03258	115.5398	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06205	107.9944	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05513	113.9402	SOONER - SPRING CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05513	113.8065	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06389	105.4279	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05862	109.6743	SOONER - SPRING CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05862	109.5365	NORTHWEST - SPRING CREEK 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.02963	99.1	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05475	108.312	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05475	101.2081	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05884	105.2867	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05884	105.1185	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05377	103.5741	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05377	103.4313	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05433	119.03	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05433	111.8395	SOONER - SPRING CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07085	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06563	103.7918	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06563	99.7	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06308	100.9393	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.0798	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07136	106.0876	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07136	101.848	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06773	102.0882	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07085	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06563	103.7918	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06563	99.7	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06308	100.9392	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.0798	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07136	106.0873	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07136	101.848	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06773	102.0881	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	1076	1076	0.05165	102.3655	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	1076	1076	0.05135	102.8851	SWISSVALE - WEST GARDNER 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	NORTHWEST - SPRING CREEK 345KV CKT 1	1039	1195	0.05669	101.8408	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1	189	189	0.16471	110.52	4REMINGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1	189	189	0.1129	99.8	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1	189	189	0.1129	99.8	CLEVELAND - TULSA NORTH 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20L	ASGI_17_09	FROM->TO	SHIDLER - WEST PAWHUSKA 138KV CKT 1	181	189	0.16471	110.9191	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SHIDLER - WEST PAWHUSKA 138KV CKT 1	181	189	0.1129	100.1719	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SHIDLER - WEST PAWHUSKA 138KV CKT 1	181	189	0.1129	100.1719	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	SPVALLY4 138.00 - STILLWATER 138KV CKT 1	194	222	0.05296	102.7363	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	SPVALLY4 138.00 - STILLWATER 138KV CKT 1	194	222	0.05296	102.7363	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04879	115.4996	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04722	116.6035	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04722	116.4668	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04722	109.1779	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.0445	112.1712	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04596	121.6376	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04456	119.8446	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04456	119.8389	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04456	112.6805	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04193	117.1723	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05142	134.6016	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04979	125.3374	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04979	125.3188	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04979	118.245	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04694	131.5041	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04127	107.8276	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03971	99.1	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03971	99.1	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03888	99.9	AXTELL - G16-050-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03888	99.2	G16-050-TAP 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03874	101.8732	LACYGNE - STILLWELL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	103.0147	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	100.1891	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03641	99	TECUMSEH HILL (TECH TX-3) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03641	99	SWISSVALE - TECUMSEH HILL 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03619	99.8	LAWRENCE HILL (LAWH TX-3) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	104.6101	GEN542955 1-LACYGNE UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	103.4184	GEN542956 2-LACYGNE UNIT #2

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	100.4388	GEN542951 5-HAWTHORN UNIT #5
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	99.7	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	99.6	GEN300003 1-THOMAS HILL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03309	101.4986	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03309	99.9	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03192	104.4065	87th STREET - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03134	102.8172	87th STREET - CRAIG 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05392	116.7958	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05065	120.6758	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05065	120.3491	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05065	113.4468	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04865	110.4556	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.053	123.2303	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05077	115.3638	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05077	115.3468	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05077	108.3561	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04822	121.1677	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04219	99.2	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05171	113.6272	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04953	115.1769	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04953	115.1748	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04953	107.858	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04703	110.6009	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05036	107.521	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04822	100.457	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04822	100.4376	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04579	107.1251	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	VIOLA 7 345.00 (VIOLA 1X) 345/138/13.8KV TRANSFORMER CKT 1	448	492.8	0.03674	99.4	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03303	109.503	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	17G	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03243	118.8066	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	17G	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	101.8052	GREC TAP5 345.00 - TULSA NORTH 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	100.9615	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	40OLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03242	130.5685	P12:138:AEPW:N.E.S.-4:CATOOSA4

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
0	17SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03242	116.7445	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	17SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03173	124.3499	GRDA1 - GREC TAP5 345.00 345KV CKT 1
0	17SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03173	103.4456	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03173	103.2941	GREC TAP5 345.00 - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03157	102.6698	P12:138:AEPW-WERE:NBVILLE4:DEARING4
08ALL	17SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03153	102.4446	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03153	101.8617	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03027	100.1821	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03027	99.6	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02961	101.7491	P12:138:GRDA:COLLINSVILLE-CLEVELAND
08ALL	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.0321	131.0749	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.0321	118.1286	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03134	122.9706	GRDA1 - GREC TAP5 345.00 345KV CKT 1
0	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03134	103.2621	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03134	102.2094	GREC TAP5 345.00 - TULSA NORTH 345KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03129	102.6064	P12:138:AEPW-WERE:NBVILLE4:DEARING4
08ALL	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03125	102.3668	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03125	101.7595	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02994	100.2754	4SFORKKTP 138.00 - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02994	99.7	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.02994	99.7	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03228	111.9168	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	20WP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03228	100.2982	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	20WP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	158	158	0.03155	104.5612	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03247	128.73	P12:138:AEPW:N.E.S.-4:CATOOSA4
0	25SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03247	114.2254	P12:138:AEPW:N.E.S.-4:CATOOSA4
08ALL	25SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03178	116.6651	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03155	99.9	P12:138:AEPW-WERE:NBVILLE4:DEARING4
08ALL	25SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	99.6	BARTLESVILLE SOUTHEAST - NORTH BARTLESVILLE 138KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	4OOLOGAH 138.00 - NORTHEAST STATION 138KV CKT 1	143	143	0.03151	99.1	COFFEYVILLE TAP - NORTH BARTLESVILLE 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.1663	110.1744	BARNSDALL - SKIATOOK PUMP 138KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.1663	110.1708	P12:138:AEPW:BARNAL4:T.NO.--4
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.1663	110.0014	SKIATOOK PUMP - TULSA NORTH 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.14583	104.1276	BARTLESVILLE COMANCHE - BLUESTEM 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	BARTLESVILLE COMANCHE - BARTLESVILLE SOUTHEAST 138KV CKT 1	153	153	0.14583	102.0697	BARTLESVILLE SOUTHEAST - BLUESTEM 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03046	108.9876	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03046	108.8412	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CANEYRV7 345.00 - NEOSHO 345KV CKT 1	766	923	0.03046	104.1173	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03395	105.9919	ARCADIA - SEMINOLE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03145	100.6692	GRACEMONT - MINCO 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03038	104.6222	G14-057T 345.00 - SUNNYSIDE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03038	101.3296	G14-057T 345.00 - LAWTON EASTSIDE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	CIMARRON - DRAPER LAKE 345KV CKT 1	717	717	0.03707	99.8	ARCADIA - SEMINOLE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06577	99.5	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06577	99.5	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06602	122.4773	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06602	122.4773	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06549	119.8965	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06549	119.8965	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06371	142.5648	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06371	142.5648	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06513	117.9396	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06513	117.9396	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06527	101.654	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	213	213	0.06527	101.654	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06541	102.4312	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	CLEVELAND - SILVER CITY 138KV CKT 1	174	174	0.06541	102.4312	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.13056	102.4879	G15052_T 345.00 - ROSE HILL 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11974	101.402	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11974	101.3412	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11487	99.5	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11487	99.4	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11323	100.5183	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20L	ASGI_17_09	FROM->TO	CLEVELAND - TULSA NORTH 345KV CKT 1	1135	1195	0.11152	101.2891	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1	143	143	0.05357	118.8064	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	COLLINSVILLE - SKIATOOK TAP 138KV CKT 1	143	143	0.05357	118.8064	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	DOMES - MOUND ROAD 138KV CKT 1	189	189	0.16471	105.3708	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	DOMES - PAWHUSKA TAP 138KV CKT 1	189	189	0.16471	106.3667	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04873	105.6947	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04873	105.5807	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04873	101.202	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04779	109.3352	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04642	101.3107	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04642	101.3028	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0455	105.9135	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05064	118.9769	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05064	118.9756	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05064	114.3991	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04955	129.6283	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04746	108.9917	EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04729	117.0711	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0434	101.1519	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0434	101.1519	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04335	106.2871	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04324	105.265	MORRIS COUNTY - SWISSVALE 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04302	105.194	LACYGNE - STILWELL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04284	102.6132	AXTELL - G16-050-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04284	101.9835	G16-050-TAP 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04204	99	DELAWARE - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04204	99	DELAWARE - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04186	99.9	GRDA1 - GREC TAP5 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0417	99.5	MINGO - RED WILLOW 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0417	99.5	MINGO - RED WILLOW 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04155	100.1244	7JASPER 345.00 - BLACKBERRY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04151	99.2	FT SMITH - MUSKOGEE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04143	99.3	DELAWARE - NORTHEAST STATION 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04143	99.3	DELAWARE - NORTHEAST STATION 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04141	105.0932	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04141	102.9267	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04141	100.6904	LATHAMS7 345.00 - ROSE HILL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	102.1063	P12:115:WERE:LANG-TECH_115P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	102.0292	P12:115:WERE:FOUR-LANG_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.9284	LANG - READING LAKE 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.6395	OSAGE CITY JUNCTION SWITCHING STATION - READING LAKE 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.0916	OSAGE CITY JUNCTION SWITCHING STATION - SCRNTJS3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	101.0905	SCRANTON - SCRNTJS3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.7816	FOUR CORNERS - SCRNTJN3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.7815	SCRANTON - SCRNTJN3 115.00 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.4367	P12:115:WERE:FOUR-TECH_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.3819	CARB-KW 3 - FOUR CORNERS 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	100.1561	CARB-KW 3 - SHAWNEE HEIGHTS 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04102	99.6	SHAWNEE HEIGHTS - TECUMSEH HILL 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.041	100.6044	DBL-SPRVL-IR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04097	100.1854	RENO COUNTY - WICHITA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04091	99.6	P12:161:WERE:MARM-KCPL_161::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04091	99.6	CENTERVILLE - G15-016T 161.00 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04091	99.3	CENTERVILLE - PAOLA 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0409	99.5	MINGO - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0409	99.5	MINGO - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04084	99	BROOKLINE - FLINT CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04084	99	BROOKLINE - FLINT CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04075	99	RENO COUNTY - SUMMIT 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04063	106.3436	AUBURN ROAD - JEFFREY ENERGY CENTER 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04053	99.8	G13-010T 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04053	99.7	G13-010T 345.00 - G16-049-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04053	99.4	G16-049-TAP 345.00 - SPEARVILLE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04047	99.3	HOLCOMB - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04047	99.3	HOLCOMB - SETAB 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04045	99	DELL 500 - INDEPENDENCE 500KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04044	99.7	AXTELL - PAULINE 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0404	99.3	7MCCREDIE 345.00 - 7MONTGMRY 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04037	99.5	G15088_T 345.00 - MOORE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04037	99.2	G15088_T 345.00 - PAULINE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04035	99.5	CHAMBER SPRINGS - CLARKSVILLE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.9	P12:115:WERE:AUBN-SMAN_115F3::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.9	P12:115:WERE:AUBN-SMAN_115F1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.9	P12:115:WERE:AUBN-SMAN_115F2::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.8	SMAN_W_3 115.00 - SOUTH MANHATTAN 115KV CKT Z1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.67502	SOUTH ALMA - SOUTH MANHATTAN 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04034	99.11964	KEENE - SOUTH ALMA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04032	100.4624	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04032	99.8	G15063_T 345.00 - WOODRING 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04031	99.2	KEO EHV - WEST MEMPHIS 500 500KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04028	99.8	GRAND ISLAND - SWEETWATER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04023	99	7SPORTSMAN - BLACKBERRY 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99.1	CLIFTON - CONCORDIA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99.1	CLIFTON - CONCORDIA 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99	P12:115:WERE:KNOB-MKEC_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99	P12:115:WERE-MKEC:CLIFTON-KNOBHILL::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04016	99	CLIFTON - GREENLEAF 115KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04012	99.2	G14-057T 345.00 - SUNNYSIDE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0401	99.1	5JASPER 161.00 - LAMAR 161KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0401	99.1	7JASPER 345.00 345/161KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04005	107.1274	P13:115-345:WERE:LANG_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04005	107.1274	LANG (LANG TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04005	107.1257	EMPORIA ENERGY CENTER - LANG 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04	99.1	AUBURN ROAD - SWISSVALE 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99.27483	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99.27483	GRDA1 - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99	CIMARRON - DRAPER LAKE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03994	99	GRAND ISLAND - MCCOOL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03993	99	HAWTHORN - NASHUA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03993	98.97136	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03993	98.97136	FLINT CREEK - SILOAM SPRINGS TAP 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03991	99.6	P13:069-138:WERE:ALTO_TX-1OR3P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03991	99.3	DBL-HTCH-OTA
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03991	99.1	IATAN - NASHUA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA (CONCORD6) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA - ELM CREEK 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA (CONCORD6) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03986	99.4	CONCORDIA - ELM CREEK 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03975	101.2688	DBL-THIS-G15
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03975	99.1	P12:069:WERE:ALLE-TIOG_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03974	99.7	P13:115-230:WERE:MCDO_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03974	99.7	MCDOWELL CREEK - MORRIS COUNTY 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03974	99.7	MCDOWELL CREEK (MCDO TX-1) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	105.5185	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	104.141	GEN542955 1-LACYGNE UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	104.0564	GEN542962 2-IATAN UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	103.4483	GEN542956 2-LACYGNE UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	103.3168	GEN542951 5-HAWTHORN UNIT #5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	103.0529	GEN542957 1-IATAN UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	102.427	GEN300003 1-THOMAS HILL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.5974	GEN640009 1-COOPER NUCLEAR STATION
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.5263	GEN645012 2-NEBRASKA CITY 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.3423	GEN645011 1-NEBRASKA CITY 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	101.0707	GEN541151 3-SIBLEY GENERATING UNIT #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.3996	P12:138:WERE:BENT-NORT_138P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.2772	GEN546702 1-NM GEN N1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.2207	GEN344225 1-1CAL G1 25.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100.0523	GEN300007 1-NEW MADRID UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	GEN635024 4-WALTER SCOTT UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	GEN300006 1-NEW MADRID UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	P12:115:WERE:EMAN-KSU_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	100	P12:069:WERE:COWS-HOOVS_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.9	GEN659103 1-ANTELOPE VALLEY UNIT1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.9	GEN659107 2-ANTELOPE VALLEY UNIT2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.9	EASTDC - ERCOT EQUIVALENCE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.8	GEN659111 2-LELAND OLDS UNIT2

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.8	GEN300002 1-THOMAS HILL UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.7	GEN635023 3-WALTER SCOTT UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.7	GEN541162 1-ARIES STEAM TURBINE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.7	P12:115:WERE:PHLP-SALM_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	GEN542954 3-MONTROSE UNIT #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	GEN629075 1-OTTUMWA GENERATOR FOR OTTUMWA UNIT NO 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	GEN542953 2-MONTROSE UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.6	P12:138:WERE:HARR-WEAV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN590010 1-ERCOT EQUIVALENCE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN590011 2-ERCOT EQUIVALENCE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN532662 1-LAWRENCE ENERGY CENTER UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	GEN562694 1-G15_016_3 0.6900
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	P12:115:WERE:3VAN-HEC_115P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	P12:115:WERE:EEUR-WEMP_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.5	P12:069:WERE:MACA-PLAZ_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.4	GEN532672 1-TECUMSEH ENERGY CENTER UNIT 8
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN542967 9-HAWTHORN UNIT #9
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN300001 1-THOMAS HILL UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN636641 1-LOUISA UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	GEN546698 1-QN GEN2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.3	P12:069:WERE:HOOVN-RIPL_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN629074 1-ARNOLD LOWSIDE OF GSU XFMR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN635214 4-NEAL UNIT 4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN600002 3-SHERBURNE CNTY G3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN541166 2-SHARPR#2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543108 3-BULL CREEK COMBUSTION TURBINE #3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543106 1-BULL CREEK COMBUSTION TURBINE #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543107 2-BULL CREEK COMBUSTION TURBINE #2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN543109 4-BULL CREEK COMBUSTION TURBINE #4
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN505432 1-SIKESTON
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN541165 1-SHARPR#1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.2	GEN542961 6-HAWTHORN COMBUSTION TURBINE #6
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN300011 1-ST FRANCIS UNIT 2

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN541163 1-ARIES COMBUSTION TURBINE #1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN549893 2-SOUTHWEST 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	GEN645025 5-NORTH OMAHA 5
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	P12:069:WERE:MEAD-PLAZ_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	P12:069:WERE:COWS-SUNS_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99.1	SHERBURNE CO 345/24.0KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344896 3-1LAB G3 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300012 1-HOLDEN UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN659110 1-LELAND OLDS UNIT1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN635213 3-NEAL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344894 1-1LAB G1 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300010 1-ST FRANCIS UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN543078 1-PAOLA COMBUSTION TURBINES
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN600000 1-SHERBURNECNTY G1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300013 1-HOLDEN UNIT 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344895 2-1LAB G2 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN645042 2-CASS COUNTY 2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN600001 2-SHERBURNE CNTY G2
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN645041 1-CASS COUNTY 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN300015 1-1SGPDEL 18.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	GEN344897 4-1LAB G4 20.000
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	P12:115:WERE:ANZI-FTJU_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	ABILENE ENERGY CENTER 115/34.5KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0397	99	4SIOUX 1 138.00 138/18.0KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03969	100	P12:069:WERE:64TH-NORT_69F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03968	101.0077	HOYT (HOYT TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03968	99.5	P12:069:WERE:MOON-NEWT_69::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03967	99.7	P12:138:WERE:HOOV-MURR_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03965	99	P12:138:WERE:17TH-CANA_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03965	99	P12:138:WERE:NORT-WEAV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03964	99.3	P12:138:WERE:COWS-WACO_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99.8	P12:138:WERE:GECT-HOOV_138::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99.5	P12:115:WERE:LANG-WEMP_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99.1	P13:069-138:WERE:HOOV_TX-3::

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03963	99	ALTOONA - BUTLER 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03962	99.2	P13:069-138:WERE:COWS_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03962	99	P13:069-138:WERE:BUTL_TX-1::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03958	99	P12:115:WERE:INDA-HOYT_115::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03941	104.5045	MORRIS COUNTY (MORR TX-1) 345/230/14.4KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03935	99.5	OVEXFRMCCOVE
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03903	100.2276	SUMMIT - UNIONRG6 230.00 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03901	99.6	P12:115:WERE:MOUN-WEMP_115P::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03901	99.1	P12:115:WERE:SPCKJ-WEMP_115F::
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03874	99	MATHWSN7 345.00 - TATONGA7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0386	100.4994	87th STREET - CRAIG 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0384	101.8884	87th STREET - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03825	99.1	7MCCREDIE 345.00 - 7OVERTON 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03805	99.3	DBL-THIS-WWR
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03784	100.9513	BENTON - WICHITA 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0377	99.5	RANCHRD7 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03759	102.8606	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03759	101.7465	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03752	101.124	HUNTERS7 345.00 - WOODRING 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03752	99.2	G16-072-TAP 345.00 - HUNTERS7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.03752	99.1	G16-072-TAP 345.00 - RENFROW7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05489	107.3806	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05489	107.2914	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05489	102.9466	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05459	104.9541	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05201	112.8729	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05201	112.8701	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05201	108.3238	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05115	122.7053	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04896	103.7365	EMPORIA ENERGY CENTER - MORRIS COUNTY 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04881	110.4837	HOYT - STRANGER CREEK 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04464	101.0683	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04452	99.7	MORRIS COUNTY - SWISSVALE 230KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04425	99.8	LACYGNE - STILWELL 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04256	99.8	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04181	101.0892	AUBURN ROAD - JEFFREY ENERGY CENTER 230KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04123	102.2126	P13:115-345:WERE:LANG_TX-1::
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04123	102.2126	LANG (LANG TX-1) 345/115/14.4KV TRANSFORMER CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04123	102.211	EMPORIA ENERGY CENTER - LANG 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04087	100.2299	GEN532663 1-LAWRENCE ENERGY CENTER UNIT 5
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04087	99	GEN542955 1-LACYGNE UNIT #1
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04087	99	GEN542962 2-IATAN UNIT #2
08ALL	20SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04054	99.5	MORRIS COUNTY (MORR TX-1) 345/230/14.4KV TRANSFORMER CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05099	102.5505	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05099	102.5404	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.05015	105.5003	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0499	102.1669	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0499	102.1649	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.0491	112.0934	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1	717	717	0.04681	99.9	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06988	99.2	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06988	99.2	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06982	99.3	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	FAIRFAX - NAVAL RESERVE 69KV CKT 1	44	44	0.06982	99.3	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03238	123.5248	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03238	123.5248	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03181	124.1416	SOONER (SOONERS) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03212	121.6782	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03212	121.6782	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03155	122.7703	SOONER (SOONERS) 345/138/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03258	115.5398	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	FARBER - SUMNER COUNTY NO. 10 BELLE PLAIN 138KV CKT 1	160	160	0.03258	115.5398	FAIRFAX - PAWNSW4 138.00 138KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06205	107.9944	VIOLA 7 345.00 - WICHITA 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05513	113.9402	SOONER - SPRING CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05513	113.8065	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.06389	105.4279	VIOLA 7 345.00 - WICHITA 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05862	109.6743	SOONER - SPRING CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05862	109.5365	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.02963	99.1	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05475	108.312	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05475	101.2081	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05884	105.2867	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05884	105.1185	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05377	103.5741	SOONER - SPRING CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05377	103.4313	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05433	119.03	NORTHWEST - SPRING CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	G15063_T 345.00 - WOODRING 345KV CKT 1	956	956	0.05433	111.8395	SOONER - SPRING CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07085	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06563	103.7918	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06563	99.7	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06308	100.9393	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.0798	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07136	106.0876	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.07136	101.848	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1	1141	1195	0.06773	102.0882	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07085	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06563	103.7918	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	16WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06563	99.7	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06308	100.9392	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.0798	99.4	EMPORIA ENERGY CENTER - G14_001T 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07136	106.0873	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.07136	101.848	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	TO->FROM	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1	1141	1195	0.06773	102.0881	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	TO->FROM	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	1076	1076	0.05165	102.3655	EMPORIA ENERGY CENTER - SWISSVALE 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	TO->FROM	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1	1076	1076	0.05135	102.8851	SWISSVALE - WEST GARDNER 345KV CKT 1
08ALL	25SP	ASGI_17_09	TO->FROM	NORTHWEST - SPRING CREEK 345KV CKT 1	1039	1195	0.05669	101.8408	G15063_T 345.00 - MATHWSN7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1	189	189	0.16471	110.52	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1	189	189	0.1129	99.8	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	PAWHUSKA TAP - WEST PAWHUSKA 138KV CKT 1	189	189	0.1129	99.8	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SHIDLER - WEST PAWHUSKA 138KV CKT 1	181	189	0.16471	110.9191	4REMNGTON 138.00 - BARNSDALL 138KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SHIDLER - WEST PAWHUSKA 138KV CKT 1	181	189	0.1129	100.1719	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SHIDLER - WEST PAWHUSKA 138KV CKT 1	181	189	0.1129	100.1719	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	SPVALLY4 138.00 - STILLWATER 138KV CKT 1	194	222	0.05296	102.7363	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	20L	ASGI_17_09	TO->FROM	SPVALLY4 138.00 - STILLWATER 138KV CKT 1	194	222	0.05296	102.7363	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04879	115.4996	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04722	116.6035	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04722	116.4668	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04722	109.1779	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	16WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.0445	112.1712	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04596	121.6376	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04456	119.8446	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04456	119.8389	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04456	112.6805	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17G	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04193	117.1723	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05142	134.6016	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04979	125.3374	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04979	125.3188	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04979	118.245	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04694	131.5041	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04127	107.8276	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03971	99.1	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03971	99.1	CLEVELAND - TULSA NORTH 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03888	99.9	AXTELL - G16-050-TAP 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03888	99.2	G16-050-TAP 345.00 - POST ROCK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03874	101.8732	LACYGNE - STILWELL 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	103.0147	CANEYRV7 345.00 - NEOSHO 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03746	100.1891	CANEYRV7 345.00 - LATHAMS7 345.00 345KV CKT 1

Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03641	99	TECUMSEH HILL (TECH TX-3) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03641	99	SWISSVALE - TECUMSEH HILL 230KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03619	99.8	LAWRENCE HILL (LAWH TX-3) 230/115/13.8KV TRANSFORMER CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	104.6101	GEN542955 1-LACYGNE UNIT #1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	103.4184	GEN542956 2-LACYGNE UNIT #2
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	100.4388	GEN542951 5-HAWTHORN UNIT #5
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	99.7	GEN532751 1-WOLF CREEK GENERATING STATION UNIT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03548	99.6	GEN300003 1-THOMAS HILL UNIT 3
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03309	101.4986	CLEVELAND - G15066_T 345.00 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03309	99.9	G15066_T 345.00 - SOONER 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03192	104.4065	87th STREET - STRANGER CREEK 345KV CKT 1
08ALL	17SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.03134	102.8172	87th STREET - CRAIG 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05392	116.7958	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05065	120.6758	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05065	120.3491	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05065	113.4468	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20L	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04865	110.4556	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.053	123.2303	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05077	115.3638	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05077	115.3468	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05077	108.3561	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04822	121.1677	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	20SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04219	99.2	LACYGNE - WEST GARDNER 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05171	113.6272	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04953	115.1769	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04953	115.1748	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04953	107.858	WAVERLY7 345.00 - WOLF CREEK 345KV CKT 1
08ALL	20WP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04703	110.6009	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.05036	107.521	HOYT - STRANGER CREEK 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04822	100.457	G16-012-TAP 345.00 - WAVERLY7 345.00 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04822	100.4376	G16-012-TAP 345.00 - LACYGNE 345KV CKT 1
08ALL	25SP	ASGI_17_09	FROM->TO	SWISSVALE - WEST GARDNER 345KV CKT 1	717	717	0.04579	107.1251	HOYT - JEFFREY ENERGY CENTER 345KV CKT 1

*Table 12: Thermal Constraints Not Requiring Additional Transmission Reinforcements*

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Contingency
08ALL	20SP	ASGI_17_09	FROM->TO	VIOLA 7 345.00 (VIOLA 1X) 345/138/13.8KV TRANSFORMER CKT 1	448	492.8	0.03674	99.4	VIOLA 7 345.00 - WICHITA 345KV CKT 1

*Table 13: Voltage Constraints Requiring Additional Transmission Reinforcements*

Dispatch Group	Season	Source	Flow	Monitored Element	RATEA (MVA)	RATEB (MVA)	TDF	TC% LOADING	Max MW Available	Contingency
				Currently, None						