



Report on

GEN-2017-073 Modification Request Impact Study

Revision R1 May 12, 2025

Submitted to
Southwest Power Pool



anedenconsulting.com

TABLE OF CONTENTS

Revision History	R-1
Executive Summary	ES-1
1.0 Scope of Study	1
1.1 Reactive Power Analysis	1
1.2 Short Circuit Analysis & Stability Analysis	1
1.3 Steady-State Analysis	1
1.4 Study Limitations	1
2.0 Project and Modification Request	2
3.0 Existing vs Modification Comparison	5
3.1 Stability Model Parameters Comparison	5
3.2 Equivalent Impedance Comparison Calculation	5
4.0 Reactive Power Analysis	6
4.1 Methodology and Criteria	6
4.2 Results	6
5.0 Short Circuit Analysis	8
5.1 Methodology	8
5.2 Results	8
6.0 Dynamic Stability Analysis	10
6.1 Methodology and Criteria	10
6.2 Fault Definitions	11
6.3 Scenario 1 Results	19
6.4 Scenario 2 Results	22
7.0 Modified Capacity Exceeds GIA Capacity	25
8.0 Material Modification Determination	26
8.1 Results	26

LIST OF TABLES

Table ES-1: GEN-2017-073 Modification Request.....	ES-1
Table 2-1: GEN-2017-073 Modification Request.....	4
Table 4-1: Shunt Reactor Size for Reactive Power Analysis.....	6
Table 5-1: Short Circuit Model Parameters*	8
Table 5-2: POI Short Circuit Comparison Results.....	8
Table 5-3: 25SP Short Circuit Comparison Results.....	9
Table 6-1: Study Scenarios (Generator Dispatch MW)	10
Table 6-2: Fault Definitions.....	11
Table 6-3: Scenario 1 Dynamic Stability Results (GEN-2017-073 = 73.8, GEN-2023-SR25 = 0).....	19
Table 6-4: Scenario 2 Dynamic Stability Results (GEN-2017-073 = 42.5, GEN-2023-SR25 = 30).....	22

LIST OF FIGURES

Figure 2-1: GEN-2017-073 Single Line Diagram (Previous Configuration*)	2
Figure 2-2: GEN-2017-073 Single Line Diagram (Modification Configuration).....	3
Figure 4-1: GEN-2017-073 Single Line Diagram (Shunt Sizes)	7

APPENDICES

APPENDIX A: GEN-2017-073 Generator Dynamic Model

APPENDIX B: Short Circuit Results

APPENDIX C: Dynamic Stability Results with Existing Base Case Issues & Simulation Plots

Revision History

DATE OR VERSION NUMBER	AUTHOR	CHANGE DESCRIPTION
05/12/2025	Aneden Consulting	Initial Report Issued

Executive Summary

Aneden Consulting (Aneden) was retained by the Southwest Power Pool (SPP) to perform a Modification Request Impact Study (Study) for the GEN-2017-073 project, an active Generation Interconnection Request (GIR) with a Point of Interconnection (POI) at the Dry Gulch 161 kV Substation.

The GEN-2017-073 project interconnects in the Grand River Dam Authority (GRDA) transmission system with a capacity of 72.5 MW. This Study has been requested to evaluate the modification of the GEN-2017-073 project to change the configuration to 20 x Sungrow SG4400 solar inverters operating at 3.69 MW for a total assumed dispatch of 73.8 MW. The inverters are rated at 4.4 MVA, thus the generating capability exceeds its Generator Interconnection Agreement (GIA) Interconnection Service amount. The injection amount must be limited to 72.5 MW at the POI as listed in Appendix A of the GIA. As a result, the customer must ensure that the amount of power injected at the POI does not exceed the Interconnection Service amount listed in its GIA. The requested modification includes the use of a Power Plant Controller (PPC) to limit the total power injected into the POI.

In addition, the modification request included changes to the collection system, generator step-up transformers, main substation transformer, auxiliary load, and generation interconnection line. The previously accepted and modified configurations for GEN-2017-073 are shown in Table ES-1 below.

Table ES-1: GEN-2017-073 Modification Request

Facility	Existing Configuration	Modification Configuration
Point of Interconnection	Dry Gulch 161 kV (512629)	Dry Gulch 161 kV (512629)
Configuration/Capacity	25 x Power Electronics FS3000 operating at 2.9 MW (solar) = 72.5 MW	20 x Sungrow SG4400 operating at 3.69 MW (solar) = 73.8 MW [dispatch] Units are rated at 4.4 MVA, PPC in place to limit POI to 72.5 MW
Generation Interconnection Line	Length = 0.5 miles R = 0.000480 pu X = 0.001800 pu B = 0.000570 pu Rating MVA = 0 MVA	Length = 0.176 miles R = 0.000081 pu X = 0.000438 pu B = 0.000317 pu Rating MVA = 253 MVA
Main Substation Transformer ¹	X = 9.979%, R = 0.25%, Winding MVA = 48 MVA, Rating MVA = 80 MVA	X12 = 9.754% R12 = 0.244%, X23 = 3.906% R23 = 0.098%, X13 = 13.646% R13 = 0.341%, Winding MVA = 72 MVA, Winding 1, 2, & 3 Rating MVA = 120 MVA
Equivalent GSU Transformer ¹	Gen 1 Equivalent Qty: 25 X = 5.722%, R = 0.572%, Winding MVA = 75 MVA, Rating MVA = 87.5 MVA	Gen 1 Equivalent Qty: 20 X = 7.96%, R = 0.796%, Winding MVA = 88 MVA, Rating MVA = 88 MVA
Equivalent Collector Line ²	R = 0.003780 pu X = 0.003900 pu B = 0.006680 pu	R = 0.004950 pu X = 0.006530 pu B = 0.014800 pu
Generator Dynamic Model ³ & Power Factor	25 x Power Electronics FS3000 3.5 MVA (REGCAU1) ³ Leading: 0.99 Lagging: 0.99	20 x Sungrow SG4400 4.4 MVA (REGCA1) ³ Leading: 0.8386 Lagging: 0.8386
Auxiliary Load	N/A	0.46 MW + 0.15 MVA _r on 34.5 kV Bus

1) X and R based on Winding MVA, 2) All pu are on 100 MVA Base, 3) DYR stability model name

SPP determined that steady-state analysis was not required because the modifications to the project were not significant enough to change the previously studied steady-state conclusions. However, SPP determined that the change in manufacturer from Power Electronics to Sungrow required short circuit and dynamic stability analyses.

The scope of this study included reactive power analysis, short circuit analysis, and dynamic stability analysis.

Aneden performed the analyses using the modification request data and the DISIS-2021-001 stability study models:

- 2025 Summer Peak (25SP),
- 2025 Winter Peak (25WP)

Aneden reviewed Generation Interconnection Requests (GIRs) that shared the same POI, Dry Gulch 161 kV, and updated their models as applicable based on SPP's confirmation of the latest project configurations. The modification under study, GEN-2017-073, is the Existing Generating Facility (EGF) for the GEN-2023-SR25 Surplus Generating Facility (SGF) project. As a result, Aneden included the accepted GEN-2023-SR25 surplus project in the base models and created two stability scenarios to accommodate the status of GEN-2023-SR25.

All analyses were performed using the Siemens PTI PSS/E¹ version 34 software and the results are summarized below.

The results of the reactive power analysis using the 25SP model showed that the GEN-2017-073 project needed a 1.5 MVAR shunt reactor on the 34.5 kV bus of the project substation with the modifications in place, an increase from the 0.7 MVAR found in the DISIS-2017-001-2 study². This is necessary to offset the capacitive effect on the transmission network caused by the project's transmission line and collector system during reduced generation conditions. The information gathered from the reactive power analysis is provided as information to the Interconnection Customer and Transmission Owner (TO) and/or Transmission Operator (TOP). The applicable reactive power requirements will be further reviewed by the TO and/or TOP.

The short circuit analysis was performed using the 25SP stability model modified for short circuit analysis. The results from the short circuit analysis with the updated topology showed that the maximum GEN-2017-073 contribution to three-phase fault currents in the immediate transmission systems at or near the GEN-2017-073 POI was 0.37 kA. The maximum three-phase fault current level within 5 buses of the POI was 44.4 kA for the 25SP model. There were several buses with a maximum three-phase fault current over 40 kA for both of the cases. These buses are highlighted in Appendix B.

The dynamic stability analysis was performed using Siemens PTI PSS/E version 34.8.1 software for the two modified study models: 25SP and 25WP, each with two dispatch scenarios to ensure all reliability conditions were studied. 81 fault events were simulated, which included three-phase faults and single-line-to-ground stuck breaker faults.

- Scenario 1: GEN-2017-073 at maximum assumed dispatch, 73.8 MW, and the corresponding SGF, GEN-2023-SR25, disconnected.

¹ Power System Simulator for Engineering

² DISIS-2017-001-2 Restudy of Stability and Short Circuit Analysis – June 16, 2022

- Scenario 2: the second scenario dispatch has both the EGF and SGF online using the selected Scenario 2 dispatch from the GEN-2023-SR25 report³. As a result, the EGF is dispatched to 42.5 MW and the SGF to 30 MW for a total combination of 72.5 MW.

The results of the dynamic stability analysis showed several existing base case issues that were found in both the original DISIS-2021-001 models (without GEN-2023-SR25) and in the models with the GEN-2017-073 modification (and GEN-2023-SR25) included. These issues were not attributed to the GEN-2017-073 modification request and are detailed in Appendix C.

There were no damping or voltage recovery violations attributed to the GEN-2017-073 modification request observed during the simulated faults. Additionally, the project was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

Based on the results of the study, SPP determined that the requested modification is **not a Material Modification**. The requested modification does not have a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date. As the requested modification places the generating capacity of the Interconnection Request at a higher amount than its Interconnection Service, the customer must install monitoring and control equipment as needed to ensure that the amount of power injected at the POI does not exceed the Interconnection Service amount listed in its GIA.

In accordance with FERC Order No. 827, the generating facility will be required to provide dynamic reactive power within the range of 0.95 leading to 0.95 lagging at the high-side of the generator substation.

It is likely that the customer may be required to reduce its generation output to 0 MW in real-time, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of transmission service or delivery rights. If the customer wishes to obtain deliverability to final customers, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the customer.

³ GEN-2023-SR25 Surplus Service Impact Study - October 25, 2023

1.0 Scope of Study

Aneden Consulting (Aneden) was retained by the Southwest Power Pool (SPP) to perform a Modification Request Impact Study (Study) for the GEN-2017-073 project. A Modification Request Impact Study is a generation interconnection study performed to evaluate the impacts of modifying the DISIS study assumptions. The determination of the required scope of the study is dependent upon the specific modification requested and how it may impact the results of the DISIS study. Impacting the DISIS results could potentially affect the cost or timing of any Interconnection Request with a later Queue priority date, deeming the requested modification a Material Modification. The criteria sections below include reasoning as to why an analysis was either included or excluded from the scope of study.

All analyses were performed using the Siemens PTI PSS/E version 34 software. The results of each analysis are presented in the following sections.

1.1 Reactive Power Analysis

SPP requires that a reactive power analysis be performed on the requested configuration if it is a non-synchronous resource. The reactive power analysis determines the capacitive effect at the POI caused by the project's collection system and transmission line's capacitance. A shunt reactor size was determined to offset the capacitive effect and maintain zero (0) MVar injection at the POI while the plant's generators and capacitors were offline.

1.2 Short Circuit Analysis & Stability Analysis

To determine whether stability and short circuit analyses are required, SPP evaluates the difference between the stability models, the stability model parameters and, if needed, the equivalent collector system impedance between the existing configuration and the requested modification. Dynamic stability analysis and short circuit analysis would be required if the differences listed above were determined to have a significant impact on the most recently performed DISIS stability analysis. Dynamic stability analysis was performed on two dispatch scenarios, the first where GEN-2017-073 was online at 100% of the assumed dispatch with GEN-2023-SR25 offline and disconnected, and the second, where both the EGF and SGF are online using the selected Scenario 2 dispatch from the GEN-2023-SR25 report⁴.

1.3 Steady-State Analysis

Steady-state analysis is performed if SPP deems it necessary based on the nature of the requested change. SPP determined that steady-state analysis was not required because the modifications to the project were not significant enough to change the previously studied steady-state conclusions.

1.4 Study Limitations

The assessments and conclusions provided in this report are based on assumptions and information provided to Aneden by others. While the assumptions and information provided may be appropriate for the purposes of this report, Aneden does not guarantee that those conditions assumed will occur. In addition, Aneden did not independently verify the accuracy or completeness of the information provided. As such, the conclusions and results presented in this report may vary depending on the extent to which actual future conditions differ from the assumptions made or information used herein.

⁴ GEN-2023-SR25 Surplus Service Impact Study - October 25, 2023


2.0 Project and Modification Request

The GEN-2017-073 Interconnection Customer requested a modification to its Generation Interconnection Request (GIR) with a Point of Interconnection (POI) at the Dry Gulch 161 kV Substation in the Grand River Dam Authority (GRDA) transmission system.

At the time of report posting, the GEN-2017-073 project is an active Interconnection Request with a queue status of “IA FULLY EXECUTED/ON SCHEDULE.” GEN-2017-073 is a solar facility with a maximum summer and winter queue capacity of 72.5 MW with Energy Resource Interconnection Service (ERIS). The GEN-2017-073 project is currently in the DISIS-2017-001 cluster.

Aneden reviewed Generation Interconnection Requests (GIRs) that shared the same POI, Dry Gulch 161 kV, and updated their models as applicable based on SPP’s confirmation of the latest project configurations. The modification under study, GEN-2017-073, is the Existing Generating Facility (EGF) for the GEN-2023-SR25 Surplus Generating Facility (SGF) project. As a result, Aneden included the accepted GEN-2023-SR25 surplus project in the base models and created two stability scenarios to accommodate the status of GEN-2023-SR25.

Figure 2-1 shows the power flow model single line diagram for the previously accepted GEN-2017-073 configuration modeled in the DISIS-2021-001 25SP stability model with the GEN-2023-SR25 surplus project included.



*based on the previously accepted configuration with the GEN-2023-SR25 surplus project included

This Study has been requested to evaluate the modification of GEN-2017-073 to change the configuration to 20 x Sungrow SG4400 solar inverters operating at 3.69 MW for a total assumed dispatch of 73.8 MW. The inverters are rated at 4.4 MVA thus the generating capability exceeds its Generator Interconnection Agreement (GIA) Interconnection Service amount. The injection amount must be limited to 72.5 MW at the POI as listed in Appendix A of the GIA. As a result, the customer must ensure that the amount of power injected at the POI does not exceed the Interconnection Service amount listed in its GIA. The requested modification includes the use of a Power Plant Controller (PPC) to limit the total power injected into the POI.

In addition, the modification request included changes to the collection system, generator step-up transformers, main substation transformer, auxiliary load, and generation interconnection line. Figure 2-2 shows the power flow model single line diagram for the GEN-2017-073 modification with the GEN-2023-

SR25 surplus project included. The previously accepted and modified configurations for GEN-2017-073 are shown in Table 2-1 below.

Figure 2-2: GEN-2017-073 Single Line Diagram (Modification Configuration)




Table 2-1: GEN-2017-073 Modification Request

Facility	Existing Configuration	Modification Configuration
Point of Interconnection	Dry Gulch 161 kV (512629)	Dry Gulch 161 kV (512629)
Configuration/Capacity	25 x Power Electronics FS3000 operating at 2.9 MW (solar) = 72.5 MW	20 x Sungrow SG4400 operating at 3.69 MW (solar) = 73.8 MW [dispatch] Units are rated at 4.4 MVA, PPC in place to limit POI to 72.5 MW
Generation Interconnection Line	Length = 0.5 miles R = 0.000480 pu X = 0.001800 pu B = 0.000570 pu Rating MVA = 0 MVA	Length = 0.176 miles R = 0.000081 pu X = 0.000438 pu B = 0.000317 pu Rating MVA = 253 MVA
Main Substation Transformer ¹	X = 9.979%, R = 0.25%, Winding MVA = 48 MVA, Rating MVA = 80 MVA	X12 = 9.754% R12 = 0.244%, X23 = 3.906% R23 = 0.098%, X13 = 13.646% R13 = 0.341%, Winding MVA = 72 MVA, Winding 1, 2, & 3 Rating MVA = 120 MVA
Equivalent GSU Transformer ¹	Gen 1 Equivalent Qty: 25 X = 5.722%, R = 0.572%, Winding MVA = 75 MVA, Rating MVA = 87.5 MVA	Gen 1 Equivalent Qty: 20
		X = 7.96%, R = 0.796%, Winding MVA = 88 MVA, Rating MVA = 88 MVA
Equivalent Collector Line ²	R = 0.003780 pu X = 0.003900 pu B = 0.006680 pu	R = 0.004950 pu X = 0.006530 pu B = 0.014800 pu
Generator Dynamic Model ³ & Power Factor	25 x Power Electronics FS3000 3.5 MVA (REGCAU1) ³ Leading: 0.99 Lagging: 0.99	20 x Sungrow SG4400 4.4 MVA (REGCA1) ³ Leading: 0.8386 Lagging: 0.8386
Auxiliary Load	N/A	0.46 MW + 0.15 MVar on 34.5 kV Bus

1) X and R based on Winding MVA, 2) All pu are on 100 MVA Base, 3) DYN stability model name

3.0 Existing vs Modification Comparison

To determine which analyses are required for the Study, the differences between the previously accepted configuration and the requested modification were evaluated. Aneden performed this comparison and the resulting analyses using a set of modified study models developed based on the modification request data and the DISIS-2021-001 stability study models. The analysis was completed using PSS/E version 34 software.

The methodology and results of the comparisons are described below.

3.1 Stability Model Parameters Comparison

SPP determined that short circuit and dynamic stability analyses were required because of the inverter change from Power Electronics to Sungrow inverters. This is because the short circuit contribution and stability responses of the existing configuration and the requested modification's configuration may differ. The generator dynamic model for the modification can be found in Appendix A.

As short circuit and dynamic stability analyses were already deemed required, a stability model parameters comparison was not needed for the determination of the scope of the study.

3.2 Equivalent Impedance Comparison Calculation

As the inverter manufacturer change determined that short circuit and dynamic stability analyses were required, an equivalent impedance comparison was not needed for the determination of the scope of the study.

4.0 Reactive Power Analysis

The reactive power analysis was performed for GEN-2017-073 to determine the capacitive charging effects during reduced generation conditions (unsuitable wind speeds, unsuitable solar irradiance, insufficient state of charge, idle conditions, curtailment, etc.) at the generation site and to size shunt reactors that would reduce the project reactive power contribution to the POI to approximately zero.

4.1 Methodology and Criteria

To determine the shunt reactor size required to compensate for the current charging attributed to the modification request, the shunt size required from the GEN-2023-SR25 surplus study was placed first. Once the shunt size for the SGF was placed, the GEN-2017-073 incremental shunt reactor size was then calculated.

For each of the shunt reactor sizes calculated, all project generators and auxiliary/station service loads were switched offline while other collector system elements remained in-service. A shunt reactor was tested at the project's collection substation 34.5 kV bus to set the MVar injection at the POI to zero.

The size of the shunt reactor is equivalent to the charging current value at unity voltage and the compensation provided is proportional to the voltage effects on the charging current (i.e., for voltages above unity, reactive compensation is greater than the size of the reactor).

Aneden performed the reactive power analysis using the modification request data based on the 25SP DISIS-2021-001 stability study model.

4.2 Results

The results from the analysis showed that the GEN-2017-073 project needed approximately 1.5 MVar of compensation at its collector substation to reduce the MVar injection at the POI to zero with the SGF reactor in place. GEN-2023-SR25 did require reactive compensation of 0.1 MVar per the surplus study report⁵, so a reactor was placed for the SGF. This is an increase from the 0.7 MVar found in the DISIS-2017-001-2 study⁶. The final shunt reactor requirements are shown in Table 4-1. Figure 4-1 illustrates the shunt reactor size needed to reduce the POI MVar to approximately zero with the updated topology.

The information gathered from the reactive power analysis is provided as information to the Interconnection Customer and Transmission Owner (TO) and/or Transmission Operator (TOP). The applicable reactive power requirements will be further reviewed by the TO and/or TOP.


Table 4-1: Shunt Reactor Size for Reactive Power Analysis

Machine	POI Bus Number	POI Bus Name	Reactor Size (MVar)
			25SP
GEN-2017-073	512629	DRYGULCH5	1.5

⁵ GEN-2023-SR25 Surplus Service Impact Study - October 25, 2023

⁶ DISIS-2017-001-2 Restudy of Stability and Short Circuit Analysis – June 16, 2022

Figure 4-1: GEN-2017-073 Single Line Diagram (Shunt Sizes)



5.0 Short Circuit Analysis

Aneden performed a short circuit study using the 25SP model for GEN-2017-073 to determine the maximum fault current requiring interruption by protective equipment for each bus in the relevant subsystem. The detailed results of the short circuit analysis are provided in Appendix B.

5.1 Methodology

The short circuit analysis included applying a 3-phase fault on buses up to 5 levels away from the 161 kV POI bus. The PSS/E “Automatic Sequence Fault Calculation (ASCC)” fault analysis module was used to calculate the fault current levels in the transmission system with and without GEN-2017-073 online. The existing SGF, GEN-2023-SR25, was left online for this analysis.

Aneden created a short circuit model using the 25SP DISIS-2021-001 stability study model by adjusting the GEN-2017-073 short circuit parameters consistent with the submitted data. The adjusted parameters used in the short circuit analysis are shown in Table 5-1 below. No other changes were made to the model.

Table 5-1: Short Circuit Model Parameters*

Parameter	Value by Generator Bus#
	589113
Machine MVA Base	88
R (pu)	0.0
X'' (pu)	0.642

*pu values based on Machine MVA Base

5.2 Results

The results of the short circuit analysis compared the 25SP model with GEN-2023-SR25 online and the GEN-2017-073 modification not connected to the stability Scenario 2 dispatch model with both the existing SGF and GEN-2017-073 in service as described in Section 6.1. The GEN-2017-073 POI bus (Dry Gulch 161 kV) fault current magnitudes for the comparison cases are provided in Table 5-2 showing a fault current of 15.52 kA with the GEN-2017-073 project online. Table 5-3 shows the maximum fault current magnitudes and fault current increases with the GEN-2017-073 project online.

The maximum fault current calculated within 5 buses of the POI was 44.4 kA for the 25SP model. There were several buses with a maximum three-phase fault current over 40 kA. These buses are highlighted in Appendix B. The maximum GEN-2017-073 contribution to three-phase fault currents was about 2.5% and 0.37 kA.

Table 5-2: POI Short Circuit Comparison Results

Case	GEN-OFF Current (kA)	GEN-ON Current (kA)	kA Change	%Change
25SP	15.15	15.52	0.37	2.5%

Table 5-3: 25SP Short Circuit Comparison Results

Voltage (kV)	Max. Current (kA)	Max kA Change	Max %Change
69	14.2	0.02	0.2%
115	17.5	0.02	0.1%
138	35.8	0.02	0.1%
161	44.4	0.37	2.5%
345	26.4	0.05	0.2%
Max	44.4	0.37	2.5%

6.0 Dynamic Stability Analysis

Aneden performed a dynamic stability analysis to identify the impact of the modifications to GEN-2017-073. The analysis was performed according to SPP's Disturbance Performance Requirements⁷. The modification details are described in Section 2.0 above and the dynamic modeling data is provided in Appendix A. The existing base case issues and simulation plots can be found in Appendix C.

6.1 Methodology and Criteria

The dynamic stability analysis was performed using models developed with the requested GEN-2017-073 configuration of 20 x Sungrow SG4400 inverters operating at 3.69 MW (REGCA1). This stability analysis was performed using Siemens PTI's PSS/E version 34.8.1 software.

The modifications requested for the GEN-2017-073 project were used to create modified stability models for this impact study based on the DISIS-2021-001 stability study models:

- 2025 Summer Peak (25SP),
- 2025 Winter Peak (25WP)

Aneden reviewed GIRs that shared the same POI, Dry Gulch 161 kV, and updated their models as applicable based on SPP's confirmation of the latest project configurations. The modification under study, GEN-2017-073, is the EGF for the GEN-2023-SR25 SGF project. As a result, Aneden included the accepted GEN-2023-SR25 surplus project in the base models and created two stability scenarios to accommodate the status of GEN-2023-SR25.

Two stability model scenarios were developed using these models to ensure all reliability conditions were studied. The first scenario (Scenario 1) was comprised of GEN-2017-073 online at 100% of the assumed dispatch (73.8 MW) while the GEN-2023-SR25 generator was offline and disconnected.

The EGF/SGF dispatch combination for the second scenario (Scenario 2) was taken from the GEN-2023-SR25 report⁸. Scenario 2 studied in the surplus study was used for this analysis as well. The study scenarios are shown in Table 6-1.

Table 6-1: Study Scenarios (Generator Dispatch MW)

Scenario	GEN-2017-073 EGF (MW)	GEN-2023-SR25 SGF (MW)	EGF + SGF (MW)
1	73.8	0 (Offline)	73.8
2	42.5	30	72.5

The dynamic model data for the GEN-2017-073 project is provided in Appendix A. The power flow models and associated dynamic database were initialized (no-fault test) to confirm that there were no errors in the initial conditions of the system and the dynamic data.

⁷ SPP Disturbance Performance Requirements:

[https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20\(twg%20approved\).pdf](https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20(twg%20approved).pdf)

⁸ GEN-2023-SR25 Surplus Service Impact Study - October 25, 2023

The following system adjustments were made to address existing base case issues that are not attributed to the modification request:

- The frequency protective relays at bus 763475 were disabled after observing the generator tripping during initial three phase fault simulations. This frequency tripping issue is a known PSS/E limitation when calculating bus frequency as it relates to non-conventional type devices.
- The PSSE dynamic simulation iterations and acceleration factor were adjusted as needed to resolve PSSE dynamic simulation crashes.

During the fault simulations, the active power (PELEC), reactive power (QELEC), and terminal voltage (ETERM) were monitored for GEN-2017-073 and other current and prior queued projects in Group 4. In addition, voltages of five (5) buses away from the POI of the GEN-2017-073 were monitored and plotted. The machine rotor angle for synchronous machines and speed for asynchronous machines within the study areas including 327 (EES-EAI), 330 (AECI), 351 (EES), 356 (AMMO), 502 (CLEC), 515 (SWPA), 520 (AEPW), 523 (GRDA), 524 (OKGE), 525 (WFEC), 526 (SPS), 527 (OMPA), 534 (SUNC), 536 (WERE), 544 (EMDE), and 546 (SPRM) were monitored. The voltages of all 100 kV and above buses within the study area were monitored as well.

6.2 Fault Definitions

Aneden developed fault events as required to study the modification. The new set of faults was simulated using the modified study models. The fault events included three-phase faults and single-line-to-ground stuck breaker faults. Single-line-to-ground faults are approximated by applying a fault impedance to bring the faulted bus positive sequence voltage to 0.6 pu. The simulated faults are listed and described in Table 6-2 below. These contingencies were applied to the modified 25SP and 25WP models.

Table 6-2: Fault Definitions

Fault ID	Planning Event	Fault Descriptions
FLT1000-SB	P4	Stuck Breaker on PENSEA 5 (512654) 161 kV Bus a. Apply single phase fault at the PENSEA 5 (512654) 161 kV Bus b. Clear fault after 16 cycles and trip the following elements: b.1.Trip the PENSEA 5 (512654) 161 kV to DRYGULCH5 (512629) 161 kV line CKT 1. b.2.Trip the PENSEA 5 (512654) 161 kV to KETCHUM5 (512669) 161 kV line CKT 1.
FLT1001-SB	P4	Stuck Breaker on PENSEA 5 (512654) 161 kV Bus a. Apply single phase fault at the PENSEA 5 (512654) 161 kV Bus b. Clear fault after 16 cycles and trip the following elements: b.1.Trip the PENSEA 5 (512654) 161 kV to KERR GR5 (512635) 161 kV line CKT 1. Trip generator(s) on the Bus PENSEA_U4 1 (512605) 13.2 kV Trip generator(s) on the Bus PENSEA_U5 1 (512607) 13.2 kV Trip generator(s) on the Bus PENSEA_U6 1 (512606) 13.2 kV
FLT1002-SB	P4	Stuck Breaker on PENSEA 5 (512654) 161 kV Bus a. Apply single phase fault at the PENSEA 5 (512654) 161 kV Bus b. Clear fault after 16 cycles and trip the following elements: b.1.Trip the PENSEA 5 (512654) 161 kV to KERR GR5 (512635) 161 kV line CKT 1. b.2.Trip the PENSEA 5 (512654) 161 kV / PENSEA 2 (512628) 69 kV / PENSEA 1 (512841) 13.8 kV XFMR CKT 1.
FLT1003-SB	P4	Stuck Breaker on PENSEA 5 (512654) 161 kV Bus a. Apply single phase fault at the PENSEA 5 (512654) 161 kV Bus b. Clear fault after 16 cycles and trip the following elements: b.1.Trip the PENSEA 5 (512654) 161 kV / PENSEA 2 (512628) 69 kV / PENSEA 1 (512841) 13.8 kV XFMR CKT 1. b.2.Trip the PENSEA 5 (512654) 161 kV to DRYGULCH5 (512629) 161 kV line CKT 1.
FLT1004-SB	P4	Stuck Breaker on PENSEA 2 (512628) 69 kV Bus a. Apply single phase fault at the PENSEA 2 (512628) 69 kV Bus b. Clear fault after 16 cycles and trip the following elements: b.1.Trip the PENSEA 2 (512628) 69 kV to CLEORP2 (512692) 69 kV line CKT 1. b.2.Trip the PENSEA 2 (512628) 69 kV / PENSEA 5 (512654) 161 kV / PENSEA 1 (512841) 13.8 kV XFMR CKT 1.

Table 6-2 Continued

Fault ID	Planning Event	Fault Descriptions
FLT1005-SB	P4	<p>Stuck Breaker on PENZA 2 (512628) 69 kV Bus</p> <p>a. Apply single phase fault at the PENZA 2 (512628) 69 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the PENZA 2 (512628) 69 kV to CLEORP2 (512692) 69 kV line CKT 1.</p> <p>b.2.Trip the PENZA 2 (512628) 69 kV to 2GRAY TP (301451) 69 kV line CKT 1.</p>
FLT1006-SB	P4	<p>Stuck Breaker on PENZA 2 (512628) 69 kV Bus</p> <p>a. Apply single phase fault at the PENZA 2 (512628) 69 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the PENZA 2 (512628) 69 kV to 2GRAY TP (301451) 69 kV line CKT 1.</p> <p>Trip generator(s) on the Bus PENZA_U1 1 (512602) 13.2 kV</p> <p>Trip generator(s) on the Bus PENZA_U2 1 (512603) 13.2 kV</p> <p>Trip generator(s) on the Bus PENZA_U3 1 (512604) 13.2 kV</p>
FLT1007-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV to LOCSTGVKM 5 (513050) 161 kV line CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV / MAID 2 (512626) 69 kV / MAITER1 1 (512836) 13.2 kV XFMR CKT 1.</p>
FLT1008-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV to LOCSTGVKM 5 (513050) 161 kV line CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV to DRYGULCH5 (512629) 161 kV line CKT 1.</p>
FLT1009-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV to DRYGULCH5 (512629) 161 kV line CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV / MAID 2 (512626) 69 kV / MAITER2 1 (512837) 13.2 kV XFMR CKT 2.</p>
FLT1010-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV / MAID 2 (512626) 69 kV / MAITER1 1 (512836) 13.2 kV XFMR CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV to GRDA1 5 (512656) 161 kV line CKT 1.</p>
FLT1011-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV to GRDA1 5 (512656) 161 kV line CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV to GRDA1 5 (512656) 161 kV line CKT 2.</p>
FLT1012-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV / MAID 2 (512626) 69 kV / MAITER1 1 (512836) 13.2 kV XFMR CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV to CATSAGR5 (512638) 161 kV line CKT 1.</p>
FLT1013-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV to CATSAGR5 (512638) 161 kV line CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV to CATSAGR5 (512638) 161 kV line CKT 2.</p>
FLT1014-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV / MAID 2 (512626) 69 kV / MAITER1 1 (512836) 13.2 kV XFMR CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV to GERALDGAY5 (512760) 161 kV line CKT 1.</p>
FLT1015-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV to GERALDGAY5 (512760) 161 kV line CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV to 5CHOTEAU1 (300069) 161 kV line CKT 1.</p>

Table 6-2 Continued

Fault ID	Planning Event	Fault Descriptions
FLT1016-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV to 5CHOTEAU1 (300069) 161 kV line CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV / MAID 2 (512626) 69 kV / MAITER2 1 (512837) 13.2 kV XFMR CKT 2.</p>
FLT1017-SB	P4	<p>Stuck Breaker on MAID 5 (512648) 161 kV Bus</p> <p>a. Apply single phase fault at the MAID 5 (512648) 161 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 5 (512648) 161 kV / MAID 2 (512626) 69 kV / MAITER1 1 (512836) 13.2 kV XFMR CKT 1.</p> <p>b.2.Trip the MAID 5 (512648) 161 kV to KERR GR5 (512635) 161 kV line CKT 1.</p> <p>b.3.Trip the MAID 5 (512648) 161 kV to KERR GR5 (512635) 161 kV line CKT 2.</p>
FLT1018-SB	P4	<p>Stuck Breaker on MAID 2 (512626) 69 kV Bus</p> <p>a. Apply single phase fault at the MAID 2 (512626) 69 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 2 (512626) 69 kV / MAID 5 (512648) 161 kV / MAITER1 1 (512836) 13.2 kV XFMR CKT 1.</p> <p>b.2.Trip the MAID 2 (512626) 69 kV to REDDEN 2 (512698) 69 kV line CKT 1.</p>
FLT1019-SB	P4	<p>Stuck Breaker on MAID 2 (512626) 69 kV Bus</p> <p>a. Apply single phase fault at the MAID 2 (512626) 69 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 2 (512626) 69 kV to REDDEN 2 (512698) 69 kV line CKT 1.</p> <p>b.2.Trip the MAID 2 (512626) 69 kV to AMERCAST S2 (512681) 69 kV line CKT 1.</p>
FLT1020-SB	P4	<p>Stuck Breaker on MAID 2 (512626) 69 kV Bus</p> <p>a. Apply single phase fault at the MAID 2 (512626) 69 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the MAID 2 (512626) 69 kV to AMERCAST S2 (512681) 69 kV line CKT 1.</p> <p>b.2.Trip the MAID 2 (512626) 69 kV / MAID 5 (512648) 161 kV / MAITER2 1 (512837) 13.2 kV XFMR CKT 2.</p>
FLT1021-SB	P4	<p>Stuck Breaker on PENZA 2 (512628) 69 kV Bus</p> <p>a. Apply single phase fault at the PENZA 2 (512628) 69 kV Bus</p> <p>b. Clear fault after 16 cycles and trip the following elements:</p> <p>b.1.Trip the PENZA 2 (512628) 69 kV to ADARNEO2 (512695) 69 kV line CKT 1.</p> <p>b.2.Trip the PENZA 2 (512628) 69 kV / PENZA 5 (512654) 161 kV / PENZA 1 (512841) 13.8 kV XFMR CKT 1.</p>
FLT9000-3PH	P1	<p>3 Phase fault on DRYGULCH5 (512629) 161 kV to GEN-2017-073 (589110) 161 kV line CKT 1, near DRYGULCH5 (512629) 161 kV.</p> <p>a. Apply fault at the DRYGULCH5 (512629) 161 kV Bus.</p> <p>b. Clear fault after 7 cycles by tripping the faulted line.</p> <p>c. Trip generator(s) on the Bus G17-073-GEN1 (589113) 0.6 kV</p> <p>d. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>e. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.</p>
FLT9001-3PH	P1	<p>3 Phase fault on DRYGULCH5 (512629) 161 kV to PENZA 5 (512654) 161 kV line CKT 1, near DRYGULCH5 (512629) 161 kV.</p> <p>a. Apply fault at the DRYGULCH5 (512629) 161 kV Bus.</p> <p>b. Clear fault after 7 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.</p>
FLT9002-3PH	P1	<p>3 Phase fault on PENZA 5 (512654) 161 kV to DRYGULCH5 (512629) 161 kV line CKT 1, near PENZA 5 (512654) 161 kV.</p> <p>a. Apply fault at the PENZA 5 (512654) 161 kV Bus.</p> <p>b. Clear fault after 7 cycles by tripping the faulted line.</p> <p>c. Wait 20 cycles, and then re-close the line in (b) back into the fault.</p> <p>d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.</p>
FLT9003-3PH	P1	<p>3 Phase fault on PENZA 5 (512654) 161 kV / PENZA 2 (512628) 69 kV / PENZA 1 (512841) 13.8 kV XFMR CKT 1, near PENZA 5 (512654) 161 kV.</p> <p>a. Apply fault at the PENZA 5 (512654) 161 kV Bus.</p> <p>b. Clear fault after 7 cycles by tripping the faulted transformer.</p>
FLT9004-3PH	P1	<p>3 Phase fault on PENZA 2 (512628) 69 kV / PENZA 5 (512654) 161 kV / PENZA 1 (512841) 13.8 kV XFMR CKT 1, near PENZA 2 (512628) 69 kV.</p> <p>a. Apply fault at the PENZA 2 (512628) 69 kV Bus.</p> <p>b. Clear fault after 7 cycles by tripping the faulted transformer.</p>

Table 6-2 Continued

Fault ID	Planning Event	Fault Descriptions
FLT9005-3PH	P1	3 Phase fault on PENZA 2 (512628) 69 kV to 2GRAY TP (301451) 69 kV line CKT 1, near PENZA 2 (512628) 69 kV. a. Apply fault at the PENZA 2 (512628) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9006-3PH	P1	3 Phase fault on 2GRAY TP (301451) 69 kV to PENZA 2 (512628) 69 kV line CKT 1, near 2GRAY TP (301451) 69 kV. a. Apply fault at the 2GRAY TP (301451) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9007-3PH	P1	3 Phase fault on 2GRAY TP (301451) 69 kV to 2ZENA TP (301453) 69 kV line CKT 1, near 2GRAY TP (301451) 69 kV. a. Apply fault at the 2GRAY TP (301451) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9008-3PH	P1	3 Phase fault on 2GRAY TP (301451) 69 kV to 2GRAY (301452) 69 kV line CKT 1, near 2GRAY TP (301451) 69 kV. a. Apply fault at the 2GRAY TP (301451) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9009-3PH	P1	3 Phase fault on PENZA 2 (512628) 69 kV to PENZA_U1 1 (512602) 13.2 kV XFMR CKT 1, near PENZA 2 (512628) 69 kV. a. Apply fault at the PENZA 2 (512628) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted transformer. Trip generator(s) on the Bus PENZA_U1 1 (512602) 13.2 kV
FLT9010-3PH	P1	3 Phase fault on PENZA 2 (512628) 69 kV to CLEORTP2 (512692) 69 kV line CKT 1, near PENZA 2 (512628) 69 kV. a. Apply fault at the PENZA 2 (512628) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9011-3PH	P1	3 Phase fault on CLEORTP2 (512692) 69 kV to PENZA 2 (512628) 69 kV line CKT 1, near CLEORTP2 (512692) 69 kV. a. Apply fault at the CLEORTP2 (512692) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9012-3PH	P1	3 Phase fault on CLEORTP2 (512692) 69 kV to AFTON 2 (512633) 69 kV line CKT 1, near CLEORTP2 (512692) 69 kV. a. Apply fault at the CLEORTP2 (512692) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9013-3PH	P1	3 Phase fault on CLEORTP2 (512692) 69 kV to 2CLEORA (301460) 69 kV line CKT 1, near CLEORTP2 (512692) 69 kV. a. Apply fault at the CLEORTP2 (512692) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9014-3PH	P1	3 Phase fault on PENZA 2 (512628) 69 kV to ADARNEO2 (512695) 69 kV line CKT 1, near PENZA 2 (512628) 69 kV. a. Apply fault at the PENZA 2 (512628) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.

Table 6-2 Continued

Fault ID	Planning Event	Fault Descriptions
FLT9015-3PH	P1	3 Phase fault on ADARNEO2 (512695) 69 kV to PENSA 2 (512628) 69 kV line CKT 1, near ADARNEO2 (512695) 69 kV. a. Apply fault at the ADARNEO2 (512695) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9016-3PH	P1	3 Phase fault on ADARNEO2 (512695) 69 kV to PARKER 2 (512696) 69 kV line CKT 1, near ADARNEO2 (512695) 69 kV. a. Apply fault at the ADARNEO2 (512695) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9017-3PH	P1	3 Phase fault on PENSA 5 (512654) 161 kV to PENSA_U6 1 (512606) 13.2 kV XFMR CKT 1, near PENSA 5 (512654) 161 kV. a. Apply fault at the PENSA 5 (512654) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted transformer. Trip generator(s) on the Bus PENSA_U6 1 (512606) 13.2 kV
FLT9018-3PH	P1	3 Phase fault on PENSA 5 (512654) 161 kV to KETCHUM5 (512669) 161 kV line CKT 1, near PENSA 5 (512654) 161 kV. a. Apply fault at the PENSA 5 (512654) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9019-3PH	P1	3 Phase fault on KETCHUM5 (512669) 161 kV to PENSA 5 (512654) 161 kV line CKT 1, near KETCHUM5 (512669) 161 kV. a. Apply fault at the KETCHUM5 (512669) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9020-3PH	P1	3 Phase fault on KETCHUM5 (512669) 161 kV to AFTON 5 (512632) 161 kV line CKT 1, near KETCHUM5 (512669) 161 kV. a. Apply fault at the KETCHUM5 (512669) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9021-3PH	P1	3 Phase fault on PENSA 5 (512654) 161 kV to KERR GR5 (512635) 161 kV line CKT 1, near PENSA 5 (512654) 161 kV. a. Apply fault at the PENSA 5 (512654) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9022-3PH	P1	3 Phase fault on KERR GR5 (512635) 161 kV to PENSA 5 (512654) 161 kV line CKT 1, near KERR GR5 (512635) 161 kV. a. Apply fault at the KERR GR5 (512635) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9023-3PH	P1	3 Phase fault on DRYGULCH5 (512629) 161 kV to MAID 5 (512648) 161 kV line CKT 1, near DRYGULCH5 (512629) 161 kV. a. Apply fault at the DRYGULCH5 (512629) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9024-3PH	P1	3 Phase fault on MAID 5 (512648) 161 kV to DRYGULCH5 (512629) 161 kV line CKT 1, near MAID 5 (512648) 161 kV. a. Apply fault at the MAID 5 (512648) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.

Table 6-2 Continued

Fault ID	Planning Event	Fault Descriptions
FLT9025-3PH	P1	3 Phase fault on MAID 5 (512648) 161 kV to KERR GR5 (512635) 161 kV line CKT 2, near MAID 5 (512648) 161 kV. a. Apply fault at the MAID 5 (512648) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9026-3PH	P1	3 Phase fault on KERR GR5 (512635) 161 kV to MAID 5 (512648) 161 kV line CKT 2, near KERR GR5 (512635) 161 kV. a. Apply fault at the KERR GR5 (512635) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9027-3PH	P1	3 Phase fault on KERR GR5 (512635) 161 kV to 412SUB 5 (512637) 161 kV line CKT 1, near KERR GR5 (512635) 161 kV. a. Apply fault at the KERR GR5 (512635) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9028-3PH	P1	3 Phase fault on KERR GR5 (512635) 161 kV to SALNCRK5 (512805) 161 kV line CKT 2, near KERR GR5 (512635) 161 kV. a. Apply fault at the KERR GR5 (512635) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9029-3PH	P1	3 Phase fault on KERR GR5 (512635) 161 kV to KERR BRK4 5 (512771) 161 kV line CKT Z0, near KERR GR5 (512635) 161 kV. a. Apply fault at the KERR GR5 (512635) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9030-3PH	P1	3 Phase fault on MAID 5 (512648) 161 kV to 5CHOTEAU1 (300069) 161 kV line CKT 1, near MAID 5 (512648) 161 kV. a. Apply fault at the MAID 5 (512648) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9031-3PH	P1	3 Phase fault on 5CHOTEAU1 (300069) 161 kV to MAID 5 (512648) 161 kV line CKT 1, near 5CHOTEAU1 (300069) 161 kV. a. Apply fault at the 5CHOTEAU1 (300069) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9032-3PH	P1	3 Phase fault on 5CHOTEAU1 (300069) 161 kV to 1CHOTST3 (300031) 16 kV XFMR CKT 10, near 5CHOTEAU1 (300069) 161 kV. a. Apply fault at the 5CHOTEAU1 (300069) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted transformer. Trip generator(s) on the Bus 1CHOTST3 (300031) 16 kV
FLT9033-3PH	P1	3 Phase fault on 5CHOTEAU2 (301348) 161 kV to 5SPORTSMAN (300741) 161 kV line CKT 1, near 5CHOTEAU2 (301348) 161 kV. a. Apply fault at the 5CHOTEAU2 (301348) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9034-3PH	P1	3 Phase fault on MAID 5 (512648) 161 kV to LOCSTGVKM 5 (513050) 161 kV line CKT 1, near MAID 5 (512648) 161 kV. a. Apply fault at the MAID 5 (512648) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.

Table 6-2 Continued

Fault ID	Planning Event	Fault Descriptions
FLT9035-3PH	P1	3 Phase fault on LOCSTGVKM 5 (513050) 161 kV to MAID 5 (512648) 161 kV line CKT 1, near LOCSTGVKM 5 (513050) 161 kV. a. Apply fault at the LOCSTGVKM 5 (513050) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9036-3PH	P1	3 Phase fault on LOCSTGVKM 5 (513050) 161 kV to 5CDRCRST (301344) 161 kV line CKT 1, near LOCSTGVKM 5 (513050) 161 kV. a. Apply fault at the LOCSTGVKM 5 (513050) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9037-3PH	P1	3 Phase fault on MAID 5 (512648) 161 kV to GERALDGAY5 (512760) 161 kV line CKT 1, near MAID 5 (512648) 161 kV. a. Apply fault at the MAID 5 (512648) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9038-3PH	P1	3 Phase fault on GERALDGAY5 (512760) 161 kV to MAID 5 (512648) 161 kV line CKT 1, near GERALDGAY5 (512760) 161 kV. a. Apply fault at the GERALDGAY5 (512760) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9039-3PH	P1	3 Phase fault on GERALDGAY5 (512760) 161 kV to NWMAID5 (512757) 161 kV line CKT 1, near GERALDGAY5 (512760) 161 kV. a. Apply fault at the GERALDGAY5 (512760) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9040-3PH	P1	3 Phase fault on MAID 5 (512648) 161 kV to GRDA1 5 (512656) 161 kV line CKT 2, near MAID 5 (512648) 161 kV. a. Apply fault at the MAID 5 (512648) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9041-3PH	P1	3 Phase fault on GRDA1 5 (512656) 161 kV to MAID 5 (512648) 161 kV line CKT 2, near GRDA1 5 (512656) 161 kV. a. Apply fault at the GRDA1 5 (512656) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9042-3PH	P1	3 Phase fault on GRDA1 5 (512656) 161 kV to WMAIN ST5 (512742) 161 kV line CKT 1, near GRDA1 5 (512656) 161 kV. a. Apply fault at the GRDA1 5 (512656) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9043-3PH	P1	3 Phase fault on GRDA1 5 (512656) 161 kV to WAGNOR 5 (512700) 161 kV line CKT 1, near GRDA1 5 (512656) 161 kV. a. Apply fault at the GRDA1 5 (512656) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9044-3PH	P1	3 Phase fault on GRDA1 5 (512656) 161 kV to CLARMR 5 (512651) 161 kV line CKT 1, near GRDA1 5 (512656) 161 kV. a. Apply fault at the GRDA1 5 (512656) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.

Table 6-2 Continued

Fault ID	Planning Event	Fault Descriptions
FLT9045-3PH	P1	3 Phase fault on GRDA1 5 (512656) 161 kV / GRDA1 2 (512727) 69 kV / GRDA1 1 (512816) 13.8 kV XFMR CKT 1, near GRDA1 5 (512656) 161 kV. a. Apply fault at the GRDA1 5 (512656) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted transformer.
FLT9046-3PH	P1	3 Phase fault on GRDA1 5 (512656) 161 kV / GRDA1 7 (512650) 345 kV / GRDA2 1 (512826) 13.8 kV XFMR CKT 2, near GRDA1 5 (512656) 161 kV. a. Apply fault at the GRDA1 5 (512656) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted transformer.
FLT9047-3PH	P1	3 Phase fault on MAID 5 (512648) 161 kV to CATSAGR5 (512638) 161 kV line CKT 2, near MAID 5 (512648) 161 kV. a. Apply fault at the MAID 5 (512648) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9048-3PH	P1	3 Phase fault on CATSAGR5 (512638) 161 kV to MAID 5 (512648) 161 kV line CKT 2, near CATSAGR5 (512638) 161 kV. a. Apply fault at the CATSAGR5 (512638) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9049-3PH	P1	3 Phase fault on CATSAGR5 (512638) 161 kV to 5ELMCRK (300993) 161 kV line CKT 1, near CATSAGR5 (512638) 161 kV. a. Apply fault at the CATSAGR5 (512638) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9050-3PH	P1	3 Phase fault on CATSAGR5 (512638) 161 kV / CATOOSA4 (509790) 138 kV / CATTER2 1 (512834) 13.8 kV XFMR CKT 2, near CATSAGR5 (512638) 161 kV. a. Apply fault at the CATSAGR5 (512638) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted transformer.
FLT9051-3PH	P1	3 Phase fault on MAID 5 (512648) 161 kV to GEN-2019-002 (763472) 161 kV line CKT 1, near MAID 5 (512648) 161 kV. a. Apply fault at the MAID 5 (512648) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. Trip generator(s) on the Bus G19-002-GEN1 (763475) 0.7 kV c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9052-3PH	P1	3 Phase fault on MAID 5 (512648) 161 kV / MAID 2 (512626) 69 kV / MAITER2 1 (512837) 13.2 kV XFMR CKT 2, near MAID 5 (512648) 161 kV. a. Apply fault at the MAID 5 (512648) 161 kV Bus. b. Clear fault after 7 cycles by tripping the faulted transformer.
FLT9053-3PH	P1	3 Phase fault on MAID 2 (512626) 69 kV to AMERCAST S2 (512681) 69 kV line CKT 1, near MAID 2 (512626) 69 kV. a. Apply fault at the MAID 2 (512626) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9054-3PH	P1	3 Phase fault on AMERCAST S2 (512681) 69 kV to MAID 2 (512626) 69 kV line CKT 1, near AMERCAST S2 (512681) 69 kV. a. Apply fault at the AMERCAST S2 (512681) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9055-3PH	P1	3 Phase fault on AMERCAST S2 (512681) 69 kV to CPPTAP 2 (512661) 69 kV line CKT 1, near AMERCAST S2 (512681) 69 kV. a. Apply fault at the AMERCAST S2 (512681) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.

Table 6-2 Continued

Fault ID	Planning Event	Fault Descriptions
FLT9056-3PH	P1	3 Phase fault on MAID 2 (512626) 69 kV to REDDEN 2 (512698) 69 kV line CKT 1, near MAID 2 (512626) 69 kV. a. Apply fault at the MAID 2 (512626) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9057-3PH	P1	3 Phase fault on REDDEN 2 (512698) 69 kV to MAID 2 (512626) 69 kV line CKT 1, near REDDEN 2 (512698) 69 kV. a. Apply fault at the REDDEN 2 (512698) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.
FLT9058-3PH	P1	3 Phase fault on REDDEN 2 (512698) 69 kV to CASTING TAP2 (512685) 69 kV line CKT 1, near REDDEN 2 (512698) 69 kV. a. Apply fault at the REDDEN 2 (512698) 69 kV Bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave Fault on for 7 cycles, then trip the line in (b) and remove fault.

6.3 Scenario 1 Results

Table 6-3 shows the relevant results of the fault events simulated for each of the modified models in Scenario 1. Existing DISIS base case issues are documented separately in Appendix C. The associated stability plots are also provided in Appendix C.

Table 6-3: Scenario 1 Dynamic Stability Results (GEN-2017-073 = 73.8, GEN-2023-SR25 = 0)

Fault ID	25SP			25WP		
	Voltage Violation	Voltage Recovery	Stable	Voltage Violation	Voltage Recovery	Stable
FLT1000-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1001-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1002-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1003-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1004-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1005-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1006-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1007-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1008-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1009-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1010-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1011-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1012-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1013-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1014-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1015-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1016-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1017-SB	Pass	Pass	Stable	Pass	Pass	Stable

Table 6-3 continued

Fault ID	25SP			25WP		
	Voltage Violation	Voltage Recovery	Stable	Voltage Violation	Voltage Recovery	Stable
FLT1018-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1019-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1020-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1021-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT9000-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9001-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9002-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9003-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9004-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9005-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9006-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9007-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9008-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9009-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9010-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9011-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9012-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9013-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9014-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9015-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9016-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9017-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9018-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9019-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9020-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9021-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9022-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9023-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9024-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9025-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9026-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9027-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9028-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9029-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9030-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9031-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9032-3PH	Pass	Pass	Stable	Pass	Pass	Stable

Table 6-3 continued

Fault ID	25SP			25WP		
	Voltage Violation	Voltage Recovery	Stable	Voltage Violation	Voltage Recovery	Stable
FLT9033-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9034-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9035-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9036-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9037-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9038-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9039-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9040-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9041-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9042-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9043-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9044-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9045-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9046-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9047-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9048-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9049-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9050-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9051-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9052-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9053-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9054-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9055-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9056-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9057-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9058-3PH	Pass	Pass	Stable	Pass	Pass	Stable

The results of the Scenario 1 dynamic stability showed several existing base case issues that were found in both the original DISIS-2021-001 models (without GEN-2023-SR25) and in the models with the GEN-2017-073 modification (and GEN-2023-SR25) included. These issues were not attributed to the GEN-2017-073 modification request and detailed in Appendix C.

There were no damping or voltage recovery violations attributed to the GEN-2017-073 modification request observed during the simulated faults. Additionally, the project was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

6.4 Scenario 2 Results

Table 6-4 shows the relevant results of the fault events simulated for each of the modified models in Scenario 2. Existing DISIS base case issues are documented separately in Appendix C. The associated stability plots are also provided in Appendix C.

Table 6-4: Scenario 2 Dynamic Stability Results (GEN-2017-073 = 42.5, GEN-2023-SR25 = 30)

Fault ID	25SP			25WP		
	Voltage Violation	Voltage Recovery	Stable	Voltage Violation	Voltage Recovery	Stable
FLT1000-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1001-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1002-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1003-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1004-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1005-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1006-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1007-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1008-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1009-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1010-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1011-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1012-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1013-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1014-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1015-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1016-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1017-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1018-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1019-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1020-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT1021-SB	Pass	Pass	Stable	Pass	Pass	Stable
FLT9000-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9001-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9002-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9003-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9004-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9005-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9006-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9007-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9008-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9009-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9010-3PH	Pass	Pass	Stable	Pass	Pass	Stable

Table 6-4 continued

Fault ID	25SP			25WP		
	Voltage Violation	Voltage Recovery	Stable	Voltage Violation	Voltage Recovery	Stable
FLT9011-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9012-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9013-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9014-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9015-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9016-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9017-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9018-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9019-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9020-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9021-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9022-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9023-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9024-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9025-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9026-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9027-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9028-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9029-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9030-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9031-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9032-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9033-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9034-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9035-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9036-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9037-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9038-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9039-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9040-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9041-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9042-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9043-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9044-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9045-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9046-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9047-3PH	Pass	Pass	Stable	Pass	Pass	Stable

Table 6-4 continued

Fault ID	25SP			25WP		
	Voltage Violation	Voltage Recovery	Stable	Voltage Violation	Voltage Recovery	Stable
FLT9048-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9049-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9050-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9051-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9052-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9053-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9054-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9055-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9056-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9057-3PH	Pass	Pass	Stable	Pass	Pass	Stable
FLT9058-3PH	Pass	Pass	Stable	Pass	Pass	Stable

The results of the Scenario 2 dynamic stability showed several existing base case issues that were found in both the original DISIS-2021-001 models (without GEN-2023-SR25) and in the models with the GEN-2017-073 modification (and GEN-2023-SR25) included. These issues were not attributed to the GEN-2017-073 modification request and detailed in Appendix C.

There were no damping or voltage recovery violations attributed to the GEN-2017-073 modification request observed during the simulated faults. Additionally, the project was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

7.0 Modified Capacity Exceeds GIA Capacity

Under FERC Order 845, Interconnection Customers are allowed to request Interconnection Service that is lower than the full generating capacity of their planned generating facilities. The Interconnection Customers must install acceptable control and protection devices that prevent the injection above their requested Interconnection Service amount measured at the POI.

As such, Interconnection Customers are allowed to increase the generating capacity of a generating facility without increasing its Interconnection Service amount stated in its GIA. This is allowable as long as they install the proper control and protection devices, and the requested modification is not determined to be a Material Modification.

The modified generating capacity of GEN-2017-073 exceeds the GIA Interconnection Service amount, 72.5 MW, as listed in Appendix A of the GIA.

The customer must install monitoring and control equipment as needed to ensure that the amount of power injected at the POI does not exceed the Interconnection Service amount listed in its GIA.

8.0 Material Modification Determination

In accordance with Attachment V of SPP's Open Access Transmission Tariff, for modifications other than those specifically permitted by Attachment V, SPP shall evaluate the proposed modifications prior to making them and inform the Interconnection Customer in writing of whether the modifications would constitute a Material Modification. Material Modification shall mean (1) modification to an Interconnection Request in the queue that has a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date; or (2) planned modification to an Existing Generating Facility that is undergoing evaluation for a Generating Facility Modification or Generating Facility Replacement, and has a material adverse impact on the Transmission System with respect to: i) steady-state thermal or voltage limits, ii) dynamic system stability and response, or iii) short-circuit capability limit; compared to the impacts of the Existing Generating Facility prior to the modification or replacement.

8.1 Results

SPP determined the requested modification is not a Material Modification based on the results of this Modification Request Impact Study performed by Aneden. Aneden evaluated the impact of the requested modification on the prior study results. Aneden determined that the requested modification did not negatively impact the prior study dynamic stability and short circuit results, and the modifications to the project were not significant enough to change the previously studied steady-state conclusions.

This determination implies that any network upgrades already required by GEN-2017-073 would not be negatively impacted and that no new upgrades are required due to the requested modification, thus not resulting in a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date.