



SPP *Southwest
Power Pool*

***System Impact Study
SPP-2017-030
For Transmission Service
Requested By:
CRGL***

From SPS.SJUANWIND1 to EDDY

***For a Reserved Amount Of
50 MW
From 08/02/2017
To 08/06/2017***

1. Executive Summary

CRGL has requested a system impact study for daily firm transmission service from SPS.SJUANWIND1 to EDDY. The period of the transaction is from 08/02/2017 00:00 to 08/06/2017 00:00. The request is for reservations 85288691, 85288748, and 85288749.

The 50 MW transaction from SPS has an impact on the following flowgates with no AFC: TUCJONTUCCAR, SPSNMTIES, PLXSUNTOLYOA and TOLPLXTOLPLX. To provide the AFC necessary for this transfer, the impact on these flowgates must be relieved.

After studying many scenarios using generation redispatch, there are several feasible scenarios that will relieve the flowgate(s) in question.

2. Introduction

CRGL has requested a system impact study for transmission service from SPS.SJUANWIND1 to EDDY.

There are 4 constrained flowgates that require relief in order for this reservation to be accepted. The flowgates and the explanations are as follows:

- TUCJONTUCCAR: TUCO – JONESSUB 230 kV for the loss of the TUCO – CARLISLE 230 kV.
- SPSNMTIES: CROSSRDS – EDDY_CO 345 kV.
- PLXSUNTOLYOA: PLXSUB – SUNDOWN 230 kV for the loss of TOKSUB – YOAKUM 230 kV.
- TOLPLXTOLPLX: TOLKSUB – PLXSUB 230 kV Circuit 1 for the loss of TOLKSUB – PLXSUB 230 Circuit 2

3. Study Methodology

A. Description

Southwest Power Pool used Transmission Adequacy & Reliability Assessment (TARA) to obtain possible unit pairings that would relieve the constraint. TARA calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

B. Model Updates

The 2017 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

C. Transfer Analysis

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using Transmission Adequacy & Reliability Assessment (TARA), specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by TARA is the amount of redispatch necessary to relieve the impact on the affected flowgate.

4. Study Results

After studying the impacts of the request, three flowgates require relief. The flowgates and associated amount of relief are as follows:

Table 1

Flowgate	Duration	Sensitivity (%)	Required Relief (MW)
5444:TUCJONTUCCAR	8/2/2017 00:00 - 8/6/2017 00:00	5.06%	3
5529:SPSNMTIES	8/2/2017 00:00 - 8/6/2017 00:00	83.38%	42
5591:PLXSUNTOLYOA	8/2/2017 00:00 - 8/6/2017 00:00	15.30%	7
5637:TOLPLXTOLPLX	8/2/2017 00:00 - 8/6/2017 00:00	10.29%	5

Table 2 displays a list of generator pairs that are possible relief options for each flowgates in question and the amount of redispatch capacity needed.

Table 2

5444:TUCJONTUCCAR			
Increment	Decrement	Sensitivity	MW
Jones	Antelope	58.27%	5
Jones	Comanche	53.08%	6
Jones	Anarko	52.78%	6
Mustang	Antelope	27.82%	11
Hobbs	Antelope	25.09%	12
Mustang	Comanche	22.64%	13
Mustang	Anarko	22.34%	13
Hobbs	Comanche	19.91%	15
Hobbs	Anarko	19.60%	15

5529:SPSNMTIES			
Increment	Decrement	Sensitivity	MW
Cunningham	Tolk	69.45%	60
Cunningham	Plant X	68.87%	61
Hobbs	Tolk	68.79%	61
Maddox	Tolk	68.28%	62
Hobbs	Plant X	68.21%	62
Cunningham	Harrington	68.12%	62
Maddox	Plant X	67.70%	62
Hobbs	Harrington	67.46%	62
Maddox	Harrington	66.96%	63

5591:PLXSUNTOLYOA			
Increment	Decrement	Sensitivity	MW
Mustang	Plant X	35.06%	20
Mustang	Tolk	31.72%	22
LCE Gas	Plant X	29.93%	23
Hobbs	Plant X	28.83%	24
LCE Gas	Tolk	26.59%	26
Mustang	Harrington	26.31%	27
Hobbs	Tolk	25.49%	27
LCE Gas	Harrington	21.19%	33
Hobbs	Harrington	20.09%	35

5637:TOLPLXTOLPLX			
Increment	Decrement	Sensitivity	MW
Nichols	Tolk	55.55%	9
Blackhawk	Tolk	54.92%	9
Holcomb	Tolk	50.17%	10
Nichols	Antelope	16.40%	30
Blackhawk	Antelope	15.77%	32
Nichols	Elk	15.24%	33
Blackhawk	Elk	14.61%	34
Holcomb	Antelope	11.01%	45
Holcomb	Elk	9.86%	51

5. Conclusion

Generation redispatch options were studied in order to relieve the necessary constraints. The results of this study shows that the constraints on the flowgates in question could be relieved by executing one or more of the options described in the Study Results section of this document. Before the Transmission Provider accepts the reservations, proof of the necessary relief options must be presented to Southwest Power Pool. Noncompliance with this guideline will result in the refusal of the reservation.