



SPP *Southwest
Power Pool*

***System Impact Study
SPP-2017-063
For Transmission Service
Requested By:
DCT***

From KCPL to AECL

***For a Reserved Amount Of
50 MW
From 12/31/2017
To 01/07/2018***

1. Executive Summary

DCT has requested a system impact study for weekly firm transmission service from KCPL to AECL. The period of the transaction is from 12/31/2017 00:00 to 01/07/2018 00:00. The request is for reservation 86072563.

The 50 MW transaction from KCPL has an impact on the following flowgates with no AFC: GRIS_LNC, and STMDSJFAFACO. To provide the AFC necessary for this transfer, the impact on these flowgates must be relieved.

After studying many scenarios using generation redispatch, there are several feasible scenarios that will relieve the flowgate(s) in question.

2. Introduction

DCT has requested a system impact study for transmission service from KCPL to AECI.

There are 2 constrained flowgates that require relief in order for this reservation to be accepted. The flowgates and the explanations are as follows:

- GRIS_LNC: GRIS_LNC: Grand Island – Lincoln Interface
-
- STMDSJFAFACO: St Joe – Avenue City 161 kV for the loss of Fairport – St Joe – Cooper 345 kV.

3. Study Methodology

A. Description

Southwest Power Pool used Transmission Adequacy & Reliability Assessment (TARA) to obtain possible unit pairings that would relieve the constraint. TARA calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

B. Model Updates

The 2017 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

C. Transfer Analysis

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using Transmission Adequacy & Reliability Assessment (TARA), specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by TARA is the amount of redispatch necessary to relieve the impact on the affected flowgate.

4. Study Results

After studying the impacts of the request, two flowgates require relief. The flowgates and associated amount of relief are as follows:

Table 1

Flowgate	Duration	Sensitivity (%)	Required Relief (MW)
6008:GRIS_LNC	12/31/2017 00:00 - 1/7/2018 00:00	3.17%	1
6152:STMDSJFAFACO	12/31/2017 00:00 - 1/7/2018 00:00	10.08%	5

Table 2 displays a list of generator pairs that are possible relief options for each flowgates in question and the amount of redispatch capacity needed.

Table 2

6009:COOPER_S			
Increment	Decrement	Sensitivity	MW
Rokeby	Burdick	59.45%	2
Sheldon	Burdick	59.39%	2
84th & Bluff	Burdick	59.27%	2
Rokeby	Canaday	57.11%	2
Sheldon	Canaday	57.04%	2
84th & Bluff	Canaday	56.93%	2
Rokeby	Gentleman	53.72%	2
Sheldon	Gentleman	53.66%	2
84th & Bluff	Gentleman	53.54%	2

6152:STMDSJFAFACO			
Increment	Decrement	Sensitivity	MW
Exirawa	Lake Road	16.99%	29
North Omaha	Lake Road	11.61%	43
Sarpy	Lake Road	11.54%	43
Exirawa	latan	11.01%	45
Exirawa	Lawrence Energy Center	9.50%	53
North Omaha	latan	5.62%	89
Sarpy	latan	5.55%	90

5. Conclusion

Generation redispatch (and reservation curtailment) options were studied in order to relieve the necessary constraints. The results of this study shows that the constraints on the flowgates in question could be relieved by executing one or more of the options described in the Study Results section of this document. Before the Transmission Provider accepts the reservations, proof of the necessary relief options must be presented to Southwest Power Pool. Noncompliance with this guideline will result in the refusal of the reservation.