



FEASIBILITY CLUSTER STUDY FOR GENERATOR INTERCONNECTION REQUESTS

FCS-2018-004

Published on 3/4/2019

By SPP Generator Interconnections Dept.

1 REVISION HISTORY

DATE OR VERSION NUMBER	AUTHOR	CHANGE DESCRIPTION	COMMENTS
02/23/2019	SPP	Report Issued (FCS-2018-004).	
3/4/2019	SPP	Added Primary and Secondary POIs for GEN-2018-075 that were previously deemed invalid.	
3/5/2019	SPP	Updated the interconnection cost for GEN-2018-075 Primary	

CONTENTS

1	Revision History	i
2	Introduction.....	3
3	Model Development	5
3.1	Upgrades Included in the Analysis	5
3.2	Higher Queued Requests Included in the Analysis.....	5
3.3	Power Flow.....	6
3.4	Dispatch of Interconnection Requests.....	7
3.5	Dynamic Stability and Short Circuit	8
4	Identification of Network Constraints (System Performance).....	9
4.1	Thermal Overloads.....	9
4.2	Voltage.....	9
4.3	Dynamic Stability.....	9
4.4	Upgrades Assigned.....	9
5	Power Flow Analysis and Results.....	11
5.1	Power Flow Analysis Methodology	11
5.2	Curtailment and System Reliability.....	12
6	Stability & Short Circuit Analysis.....	13
7	Required Interconnection Facilities	14
7.1	Facilities Analysis	15
7.2	Environmental Review	16
8	Determination of Cost Allocated Network Upgrades.....	16
8.1	Credits/Compensation for Amounts Advanced for Network Upgrades	17
9	Affected Systems Coordination	18
10	Conclusion.....	19
11	Appendices.....	20
11.1	Appendix A	20
11.2	Appendix B	22
11.3	Appendix C	25
11.4	Appendix D	34
11.5	Appendix E	36
11.6	Appendix F	38
11.7	Appendix G	79

2 INTRODUCTION

Pursuant to the Southwest Power Pool (SPP) Open Access Transmission Tariff (OATT), SPP has conducted this Feasibility Cluster Study (FCS) for generation interconnection requests received during the FCS Queue Cluster Window, which closed on November 25, 2018. The customers will be referred to in this study as the FCS Interconnection Customers. The FCS analyzes the impact of interconnecting new generation totaling 1,070.0 MW to the SPP Transmission System. The interconnecting SPP Transmission Owners include:

- Nebraska Public Power District (NPPD)
- Southwestern Public Service Company (SPS)
- Oklahoma Gas & Electric Company (OKG&E)

The primary objective of this Feasibility Cluster Study is to identify the system constraints associated with connecting the generation to the area transmission system. The Feasibility and other subsequent Interconnection Studies are designed to identify attachment facilities, Network Upgrades and other Direct Assignment Facilities needed to accept power into the grid at each specific interconnection receipt point.

Table 2-1: Point of Interconnections Requested and Studied

Interconnection Request	Fuel Type	Max Output (MW)	Service	Group	Point of Interconnection (POI) Requested	Point of Interconnection (POI) Studied	SPP Comments
GEN-2018-066	Solar / Battery	400	ER / NR	9	Gerald Gentlemen 345 kV	(P) Gerald Gentlemen 345 kV	Highly dependent on higher queued interconnection requests; would require multi-million dollar facility study and interconnection upgrades
GEN-2018-075	CT	204 SP / 230 WP	ER Only	6	Bopco 345 kV	(P) Bopco 345 kV	
					Bopco 115 kV	(S) Bopco 115 kV	
					Kiowa 345 kV	(T) Kiowa 345 kV	
GEN-2018-078	Wind	240	ER/NR	6	Tap Eddy Co – Crossroads 345 kV	(P) Tap Eddy Co – Crossroads 345 kV	
GEN-2018-127	Solar	200	ER/NR	8	Cresent 138 kV	(P) Cresent 138 kV	
					Cresent – Twin Lakes 138 kV (too close to Cresent substation)	N/A	Invalid POI; tap requested too close to an existing substation
					Cresent – Cottonwood 138 kV (too close to Cresent substation)	N/A	Invalid POI; tap requested too close to an existing substation

A First Contingency Incremental Transfer Capability (FCITC) analysis was performed for each Scenario outlined in **Table 2-2**.

Table 2-2: Scenario Descriptions

Scenario	Interconnection Request(s)	Scenario Description	Point of Interconnection (POI) Studied
Scenario 1	GEN-2018-066	Group 09 ERIS & Group 09 NRIS	(P) Gerald Gentlemen 345 kV
Scenario 2	GEN-2018-075	Group 06 ERIS & Group 06 NRIS	(T) Kiowa 345 kV
	GEN-2018-078		(P) Tap Eddy Co. – Crossroads 345 kV
Scenario 3	GEN-2018-127	Group 08 ERIS & Group 08 NRIS	(P) Crescent 138 kV
Scenario 4	GEN-2018-075	Group 06 ERIS & Group 06 NRIS	(P) Bopco 345 kV
	GEN-2018-078		(P) Tap Eddy Co. – Crossroads 345 kV
Scenario 5	GEN-2018-075	Group 06 ERIS & Group 06 NRIS	(S) Bopco 115 kV
	GEN-2018-078		(P) Tap Eddy Co. – Crossroads 345 kV

Please note that since the DISIS-2017-001, DISIS-2017-002, DISIS-2018-001, and DISIS-2018-002 have not been completed, only higher queued requests and upgrades through DISIS-2016-002 were included in this analysis.

Network upgrades assigned to higher queued interconnection requests may become the cost responsibility of lower queued interconnection requests if the higher queued request withdraws and a restudy deems the network upgrade necessary for the lower queued request.

3 MODEL DEVELOPMENT

3.1 UPGRADES INCLUDED IN THE ANALYSIS

3.1.1 BASE CASE UPGRADES

The facilities listed **Appendix A** in are part of the current SPP Transmission Expansion Plan, the Balanced Portfolio, or recently approved Priority Projects. These facilities have an approved Notification to Construct (NTC) or are in construction stages and were assumed to be in-service at the time of dispatch and added to the base case models. The Feasibility Interconnection Customers have not been assigned advancement costs for the projects listed below.

The FCS Interconnection Customers' Generation Facilities in-service dates may need to be delayed until the completion of the following upgrades. In some cases, the in-service date is beyond the allowable time a customer can delay. If the requests proceed forward into the DISIS, the Interconnection Customer may move forward with Limited Operation or remain in the DISIS Queue for additional study cycles. If, for some reason, construction on these projects is discontinued, additional restudies will be needed to determine the interconnection needs of the Interconnection Customers during the DISIS.

3.1.2 CONTINGENT UPGRADES

The facilities in **Appendix B** do not yet have approval. These facilities have been assigned to higher-queued interconnection customers. These facilities have been included in the models for this study and are assumed to be in service. This list may not be all-inclusive. The FCS Interconnection Customers, at this time, do not have cost responsibility for these facilities but may later be assigned cost if higher-queued customers terminate their Generation Interconnection Agreement or withdraw from the interconnection queue. The FCS Interconnection Customer Generation Facilities in-service dates may need to be delayed until the completion of the following upgrades.

3.1.3 POTENTIAL UPGRADES NOT IN THE BASE CASE

Any potential upgrades that do not have a Notification to Construct (NTC) and are not explicitly listed within this report have not been included in the base case. These upgrades include any identified in the SPP Extra-High Voltage (EHV) overlay plan, or any other SPP planning study other than the upgrades listed above in the previous section.

3.2 HIGHER QUEUED REQUESTS INCLUDED IN THE ANALYSIS

3.2.1 SPP REQUESTS

Appendix C outlines the higher queued SPP requests included in this analysis. These requests have higher queue priority to the FCS-2018-004 requests. Please note that DISIS-2017-001 through DISIS-2018-004 requests have been excluded from this analysis because the impact studies have not been completed.

3.2.2 MISO REQUESTS

Appendix D outlines the higher queued MISO requests included in the analysis. MISO requests are designated a group number based on electrical and geographic proximity to other SPP requests.

3.2.3 CURRENT STUDY SPP REQUESTS

Please refer to **Table 2-1** for an overview of the projects under study and the associated Point of Interconnection(s) requested. **Table 2-2** outlines the various FCITC scenarios conducted for this Feasibility study.

3.3 POWER FLOW

The power flow models used for this study are based on the 2016-series Integrated Transmission Planning models used for the 2017 ITP-Near Term analysis. These models include:

- Year 1 2017 winter peak (17WP)
- Year 2 2018 spring (18G)
- Year 2 2018 summer peak (18SP)
- Year 5 2021 summer (21SP)
- Year 5 2021 light (21L)
- Year 5 2021 winter peak (21WP)
- Year 10 2026 summer peak (26SP)

3.4 DISPATCH OF INTERCONNECTION REQUESTS

3.4.1 SPP INTERCONNECTION REQUESTS

Please refer to **Table 3-1** for an overview of SPP dispatch criteria.

Table 3-1: SPP GIR Power Flow Fuel Type Dispatch

Dispatch Type	Season	Service Type	Renewable (in group)	Renewable (out of group)	Conventional (in group)	Conventional (out of group)
ERIS HVER	All	All	100%	20%	N/A	N/A
ERIS LVER	Peak	All	20%	20%	100%	100%
NRIS HVER	Spring and Light Load	ERIS	80%	20%	N/A	N/A
		NRIS	100%	20%	100%	20%
NRIS LVER	Peak	ERIS	20%*	20%*	80%	80%
		NRIS	100%	100%	100%	100%

For Variable Energy Resources (VER) (solar/wind) in each power flow case, Energy Resource Interconnection Service (ERIS), is evaluated for the generating plants within a geographical area of the interconnection request(s) for the VERs dispatched at 100% nameplate of maximum generation. The VERs in the remote areas are dispatched at 20% nameplate of maximum generation. These projects are dispatched across the SPP footprint using load factor ratios.

Peaking units are not dispatched in the spring case, or in the “High VER” summer and winter peak cases. To study peaking units’ impacts, the Year 1 winter peak and Year 2 summer peak, Year 5 summer and winter peaks, and Year 10 summer peak models are developed with peaking units dispatched at 100% of the nameplate rating and VERs dispatched at 20% of the nameplate rating. Each interconnection request is also modeled separately at 100% nameplate for certain analyses.

All generators (VER and peaking) that requested Network Resource Interconnection Service (NRIS) are dispatched in an additional analysis into the interconnecting Transmission Owner’s (T.O.) area at 100% nameplate with Energy Resource Interconnection Service (ERIS) only requests at 80% nameplate. This method allows for identification of network constraints that are common between regional groupings to have affecting requests share the mitigating upgrade costs throughout the cluster.

3.4.2 MISO INTERCONNECTION REQUESTS

To incorporate the Interconnection Customers' request, a re-dispatch of existing generation within SPP and MISO was performed with respect to the amount of the Customers' injection. **Table 3-2** outlines the dispatch of MISO requests in the SPP models.

Table 3-2 outlines how higher queued and current study MISO requests are dispatched in the SPP cases. MISO projects are dispatched across the SPP footprint using load factor ratios. All MISO generation dispatched by SPP was sunk to the MISO Classic (West) footprint, whether ERIS or NRIS.

Table 3-2: Dispatch of MISO Requests in SPP Models

Dispatch Type	Season	Service Type	Renewable (in group)	Renewable (out of group)	Conventional (in group)	Conventional (out of group)
ERIS HVER	All	All	100%	20%	N/A	N/A
ERIS LVER	Peak	All	20%	20%	100%	100%
NRIS	Spring and Light Load	ERIS	Off	Off	Off	Off
		NRIS	100%	20%	100%	20%
	Peak	ERIS	Off	Off	Off	Off
		NRIS	100%	100%	100%	100%

HVER – High Variable Energy Resource Dispatch
LVER – Low Variable Energy Resource Dispatch
N/A – units are not dispatched up from base case amounts
Renewable – Includes wind, solar, and storage
Conventional – Includes nuclear, hydro, coal, cc, CT, oil, waste heat

3.5 DYNAMIC STABILITY AND SHORT CIRCUIT

3.5.1 DYNAMIC STABILITY

Dynamic stability studies performed as part of the PISIS and DISIS Cluster Studies will provide additional guidance as to whether required reactive compensation can be static or a portion must be dynamic (such as a SVC).

3.5.2 SHORT CIRCUIT

The Year 2 and Year 10 dynamic stability summer peak models were used for short-circuit analysis.

4 IDENTIFICATION OF NETWORK CONSTRAINTS (SYSTEM PERFORMANCE)

4.1 THERMAL OVERLOADS

Network constraints are found by using PSS/E MUST First Contingency Incremental Transfer Capability (FCITC) analysis on the entire cluster grouping dispatched at the various levels previously described.

For Energy Resource Interconnection Service (ERIS), thermal overloads are determined for system intact (n-0) greater than 100% of Rate A - normal and for contingency (n-1) greater than 100% of Rate B – emergency conditions.

The overloads are then screened to determine which interconnection requests have at least

- 3% Distribution Factor (DF) for system intact conditions (n-0),
- 20% DF upon outage-based conditions (n-1),
- or 3% DF on contingent elements that resulted in a non-converged solution.

Appropriate transmission reinforcements are identified to mitigate the constraints.

Interconnection Requests that requested Network Resource Interconnection Service (NRIS) are also studied in a separate NRIS analysis to determine if any constraint measured greater than or equal to a 3% DF. If so, these constraints are also assigned transmission reinforcements to mitigate the impacts.

4.2 VOLTAGE

Steady State Voltage analysis is performed as part of the PISIS and DISIS Cluster Studies will provide additional guidance as to whether required reactive compensation. Monitored facilities and transmission reinforcement criteria for this analysis will be provided during the PISIS and/or DISIS report

4.3 DYNAMIC STABILITY

Dynamic stability studies performed as part of the PISIS and DISIS Cluster Studies will provide additional guidance as to whether required reactive compensation can be static or a portion must be dynamic (such as a SVC). During the PISIS and/or DISIS Stability issues are considered for transmission reinforcement under ERIS. Generators that fail to meet low voltage ride-through requirements (FERC Order #661-A) or SPP's stability criteria for damping or dynamic voltage recovery are assigned upgrades such that these requirements can be met.

4.4 UPGRADES ASSIGNED

In no way does the list of constraints in [Appendix G](#) identify all potential constraints that guarantee operation for all periods of time. It should be noted that although this study analyzed many of the

most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

5 POWER FLOW ANALYSIS AND RESULTS

5.1 POWER FLOW ANALYSIS METHODOLOGY

The Direct Current (DC) FCITC function of PSS® MUST was used to simulate single element and special (i.e., breaker-to-breaker, multi-element, etc.) contingencies in portions or all of the modeled control areas of SPP, as well as, other control areas external to SPP and the resulting scenarios analyzed. Single element and multi-element contingencies are evaluated.

Table 5-1: Most Severe ERIS Constraints for Mitigation

Group	Season	Source	Mont Common Name	TDF	Rating	Contingency Loading %	Conname
06ALLP_SP	18G	GEN_18075_T_SP	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.42	1029.4	100.96	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18078_P	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.63	1029.4	100.96	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18075_P_SP	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.42	1029.4	100.86	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18078_P	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.63	1029.4	100.86	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18075_S_SP	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.42	1029.4	100.82	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18078_P	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.63	1029.4	100.82	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'

Table 5-2: Most Severe NRIS Constraints for Mitigation

Group	Season	Source	Mont Common Name	TDF	Rating	Contingency Loading %	Conname
09NR	21L	GEN_18066_P	'MONOLITH 7 115.00 - SHELDON 115KV CKT 1'	0.042	327.9	135.47	'MONOLITH 3 345.00 - MOORE 345KV CKT 1'

Complete FCITC results can be found in **Appendix E**.

5.2 CURTAILMENT AND SYSTEM RELIABILITY

In no way does this study guarantee operation for all periods of time. It should be noted that although this study analyzed many of the most probable contingencies, it is not an all-inclusive list and cannot account for every operational situation. Because of this, it is likely that the Customer(s) may be required to reduce their generation output to 0 MW, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

6 STABILITY & SHORT CIRCUIT ANALYSIS

Stability is not applicable to the FCS queue. Short Circuit Analysis was performed for each generators POI. The Short Circuit Analyses results are found in **Appendix E**.

7 REQUIRED INTERCONNECTION FACILITIES

Table 7-5 outlines the estimated interconnection costs for each request per FCITC scenario. Please note that not all requested points of interconnection were viable and were subsequently not studied. Also, some points of interconnection, while examined in this analysis, may not be viable in the future (i.e. available outlets being filled by higher queued requests).

- **Costs Not Included** – Costs on Affected Systems for Associated Electric Cooperative Inc. (AECI), Mid-Continent Independent System Operator (MISO), and Minnkota Power Cooperative, Inc (MPC). Impacts to affected systems will be coordinated with the Affected System operators if the Interconnection Request(s) enter into the Definitive Interconnection System Impact Study (DISIS) Queue.
- **Costs Not Included** – Potential upgrades required for AC voltage or transient stability constraints. Impacts to AC voltage and transient stability analysis are evaluated during the Preliminary Interconnection System Impact Study (PISIS) or DISIS Queue.

Table 7-1: ERIS Constraints for Mitigation

Monitored Element	TDF	Rating	Contingency Loading %	Contingency	Mitigation	Network Upgrade Cost
'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.42	1029.4	100.96	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'	Reconducto 52 miles of 345 kV	\$72.8 M

Table 7-2: ERIS Cost Allocation per Request

Interconnection Request	Upgrade Name	Upgrade Type	Allocated Cost	Upgrade Cost
GEN-2018-075_P	Reconducto 52 miles of 345 kV from Crossroads – Tolk Ckt 1	Current Study	\$28.4M	\$72.8 M
GEN-2018-075_S	Reconducto 52 miles of 345 kV from Crossroads – Tolk Ckt 1	Current Study	\$28.4M	\$72.8 M
GEN-2018-075_T	Reconducto 52 miles of 345 kV from Crossroads – Tolk Ckt 1	Current Study	\$28.4M	\$72.8 M
GEN-2018-078_P	Reconducto 52 miles of 345 kV from Crossroads – Tolk Ckt 1	Current Study	\$44.4M	\$72.8 M

Table 7-3: NRIS Constraints for Mitigation

Monitored Element	TDF	Rating	Contingency Loading %	Contingency	Mitigation	Network Upgrade Cost
'MONOLITH 7 115.00 - SHELDON 115KV CKT 1'	0.04282	327.9	135.47	'MONOLITH 3 345.00 - MOORE 345KV CKT 1'	Rebuild 0.5 miles of 115 kV	\$500,000

Table 7-4: NRIS Cost Allocation per Request

Interconnection Request	Upgrade Name	Upgrade Type	Allocated Cost	Upgrade Cost
GEN-2018-066_P	Rebuild 0.5 miles of 115 kV from Monolith - Sheldon Ckt 1	Current Study	\$500,000	\$500,000

Table 7-5: Estimated Interconnection Costs per Scenario

Scenario	Interconnection Request(s)	Scenario Description	Point of Interconnection (POI) Studied	Interconnection Costs	ERIS Network Upgrade Costs	NRIS Network Upgrade Costs	Total Estimated Cost
Scenario 1	GEN-2018-066	Group 09 ERIS & Group 09 NRIS	(P) Gerald Gentlemen 345 kV	\$5-10 Million range pending a more detailed engineering design and facility study	--	\$500,000	\$5.5-10.5M
Scenario 2	GEN-2018-075	Group 06 ERIS & Group 06 NRIS	(T) Kiowa 345 kV	\$5 million	\$28.4M	--	\$33.4M
	GEN-2018-078		(P) Tap Eddy Co. - Crossroads 345 kV	\$12 million	\$44.4M	--	\$56.4M
Scenario 3	GEN-2018-127	Group 08 ERIS & Group 08 NRIS	(P) Crescent 138 kV	\$3 million	--	--	\$3M
Scenario 4	GEN-2018-075	Group 06 ERIS & Group 06 NRIS	(P) Bopco 345 kV	\$6.4 million	\$28.4M	--	\$34.8M
	GEN-2018-078		(P) Tap Eddy Co. - Crossroads 345 kV	\$12 million	\$44.4M	--	\$56.4M
Scenario 5	GEN-2018-075	Group 06 ERIS & Group 06 NRIS	(S) Bopco 115 kV	\$0 ¹	\$28.4M	--	\$28.4M
	GEN-2018-078		(P) Tap Eddy Co. - Crossroads 345 kV	\$12 million	\$44.4M	--	\$56.4M

7.1 FACILITIES ANALYSIS

If requests proceed to the DISIS queue, the interconnecting Transmission Owner for each Interconnection Request will provide its preliminary analysis of required Transmission Owner

¹ The interconnection cost for GEN-2018-075 (S) assumes that the interconnection customer is responsible for 100% of the interconnection facility.

Interconnection Facilities and the associated Network Upgrades. This analysis will be limited only to the expected facilities to be constructed by the Transmission Owner at the Point of Interconnection.

7.2 ENVIRONMENTAL REVIEW

For Interconnection Requests that result in an interconnection to, or modification to, the transmission facilities of the Western-UGP, a National Environmental Policy Act (NEPA) Environmental Review will be required. The Interconnection Customer will be required to execute an Environmental Review Agreement per Section 8.6.1 of the GIP.

8 DETERMINATION OF COST ALLOCATED NETWORK UPGRADES

Cost Allocated Network Upgrades of Variable Energy Resources (VER) (solar/wind) generation interconnection requests are determined using the Year 2 spring model. Cost Allocated Network Upgrades of peaking units are determined using the Year 5 summer peak model. A PSS/E and MUST sensitivity analysis is performed to determine the Distribution Factors (DF), a distribution factor with no contingency that each generation interconnection request has on each new upgrade. The impact each generation interconnection request has on each upgrade project is weighted by the size of each request. Finally, the costs due by each request for a particular project are then determined by allocating the portion of each request's impact over the impact of all affecting requests.

For example, assume that there are three Generation Interconnection requests, X, Y, and Z that are responsible for the costs of Upgrade Project '1'. Given that their respective PTDF for the project have been determined, the cost allocation for Generation Interconnection request 'X' for Upgrade Project 1 is found by the following set of steps and formulas:

Determine an impact factor for a given project for all responsible GI requests:

$$\text{Request } X \text{ Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(X) \times \text{MW}(X) = X1$$

$$\text{Request } Y \text{ Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Y) \times \text{MW}(Y) = Y1$$

$$\text{Request } Z \text{ Impact Factor on Upgrade Project 1} = \text{PTDF}(\%)(Z) \times \text{MW}(Z) = Z1$$

Determine each request's Allocation of Cost for that particular project:

$$\text{Request } X \text{'s Project 1 Cost Allocation (\$)} = \frac{\text{Network Upgrade Project 1 Cost (\$)} \times X1}{X1 + Y1 + Z1}$$

Repeat previous for each responsible GI request for each Project.

The cost allocation of each needed Network Upgrade is determined by the size of each request and its impact on the given project. This allows for the most efficient and reasonable mechanism for sharing the costs of upgrades.

8.1 CREDITS/COMPENSATION FOR AMOUNTS ADVANCED FOR NETWORK UPGRADES

Interconnection Customer shall be entitled to either credits or potentially incremental Long Term Congestion Rights (iLTCR), otherwise known as compensation, in accordance with Attachment Z2 of the SPP Tariff for any Network Upgrades, including any tax gross-up or any other tax-related payments associated with the Network Upgrades, and not refunded to the Interconnection Customer.

9 AFFECTED SYSTEMS COORDINATION

Impacts to affected systems will be coordinated with the Affected System operators if the Interconnection Request(s) enter into the DISIS Queue.

The following procedures are in place to coordinate with Affected Systems.

- Impacts on Associated Electric Cooperative Inc. (AECI) – For any observed violations of thermal overloads on AECI facilities, AECI has been notified by SPP to evaluate the violations for impacts on its transmission system. AECI has instructed SPP to notify the affected Interconnection Customers after posting of this study to contact AECI for an Affected System Study Agreement to study further impacts on the AECI system.
- Impacts on Mid Continent Independent System Operation (MISO) – Per SPP's agreement with MISO, MISO will be contacted and provided a list of interconnection requests that proceed to move forward into the Interconnection Facilities Study Queue. MISO will then evaluate the Interconnection Requests for impacts and will be in contact with affected Interconnection Customers.
- Impacts on Minnkota Power Cooperative, Inc (MPC) – MPC will be contacted and provided a list of interconnection requests that proceed to move forward into the Interconnection Facilities Study Queue. MP will then evaluate the Interconnection Requests for impacts.
- Impacts to other affected systems – For any observed violations of thermal overloads or voltage constraints, SPP will contact the owner of the facility for further information.

10 CONCLUSION

The minimum cost of interconnecting all new generation interconnection requests per scenario included is outlined in **Table 7-5**. These costs, and other upgrades associated with Network Constraints do not include all costs associated with the deliverability of the energy to final customers. These costs are determined by separate studies if the Customer submits a Transmission Service Request (TSR) through SPP's Open Access Same Time Information System (OASIS) as required by Attachment Z1 of the SPP Open Access Transmission Tariff (OATT).

For Interconnection Requests that result in an interconnection to, or modification of, the transmission facilities of the Western-UGP (WAPA), a National Environmental Policy Act (NEPA) Environmental Review will be required. The Interconnection Customer will be required to execute an Environmental Review Agreement per Section 8.6.1 of the GIP.

11 APPENDICES

11.1 APPENDIX A

Table 11-1: SPP Transmission Expansion Plan, Balanced Portfolio, and Recently Approved Priority Projects

SPP Notification to Construct (NTC) ID	UID	Project Owner	Upgrade Name	Estimated Date of Upgrade Completion (EOC)
200223		OGE	Tatonga - Woodward District EHV 345 kV Ckt 2	3/1/2018
200223		OGE	Matthewson - Tatonga 345 kV Ckt 2	3/1/2018
200240		OGE	Chisholm - Gracemont 345 kV Ckt 1 (OGE)	3/1/2018
200255		AEP	Chisholm - Gracemont 345kV Ckt 1 (AEP)	3/1/2018
200255		AEP	Chisholm 345/230 kV Substation	3/1/2018
200255		AEP	Chisholm 230 kV	3/1/2018
200360		SPS	IMC #1 Tap - Livingston Ridge 115 kV Ckt 1 Rebuild	11/16/2018
200360		SPS	Intrepid West - Potash Junction 115 kV Ckt 1 Rebuild	11/16/2018
200360		SPS	IMC #1 Tap - Intrepid West 115 kV Ckt 1 Rebuild	11/16/2018
200360		SPS	Cardinal - Targa 115 kV Ckt 1 Rebuild	5/31/2018
200360	51250	SPS	National Enrichment Plant - Targa 115 kV Ckt 1	12/15/2018
200391	51528	OGE	DeGrasse 345 kV Substation	6/1/2019
200391	51529	OGE	DeGrasse 345/138 kV Transformer	6/1/2019
200391	51530	OGE	DeGrasse - Knob Hill 138 kV New Line	6/1/2019
200391	51569	OGE	DeGrasse 138 kV Substation (OGE)	6/1/2019
200220		NPPD	Cherry Co. (Thedford) - Gentleman 345 kV Ckt 1	10/1/2019
200220		NPPD	Cherry Co. (Thedford) Substation 345 kV	10/1/2019
200220		NPPD	Cherry Co. (Thedford) - Holt Co. 345 kV Ckt 1	10/1/2019
200220		NPPD	Holt Co. Substation 345 kV	10/1/2019
200253	50441	NPPD	Neligh 345/115 kV Substation	4/1/2018
200309		SPS	Hobbs 345/230 kV Ckt 1 Transformer	6/1/2018
200309		SPS	Hobbs - Yoakum 345 kV Ckt 1	6/1/2020
200395		SPS	Tuco - Yoakum 345 kV Ckt 1	6/1/2020
200395		SPS	Yoakum 345/230 kV Ckt 1 Transformer	6/1/2020
200256	50722	SPS	Chaves - Price 115 kV Ckt 1 Rebuild	1/30/2018
200256	50723	SPS	CV Pines - Price 115 kV Ckt 1 Rebuild	1/30/2018
200256	50724	SPS	Capitan - CV Pines 115 kV Ckt 1 Rebuild	1/30/2018
200282		SPS	China Draw - Yeso Hills 115 kV Ckt 1	6/1/2018
200282		SPS	Dollarhide - Toboso Flats 115 kV Ckt 1	6/1/2018
200309		SPS	Hobbs - Kiowa 345 kV Ckt 1	6/1/2018
200309		SPS	Kiowa 345 kV Substation	6/1/2018
200309		SPS	Kiowa - North Loving 345 kV Ckt 1	6/1/2018
200309		SPS	North Loving 345 kV Terminal Upgrades	6/1/2018
200309		SPS	China Draw - North Loving 345 kV Ckt 1	6/1/2018
200309		SPS	China Draw 345 kV Ckt 1 Terminal Upgrades	6/1/2018
200309		SPS	China Draw 345/115 kV Ckt 1 Transformer	6/1/2018
200309		SPS	North Loving 345/115 kV Ckt 1 Transformer	6/1/2018
200309		SPS	Kiowa 345/115 kV Ckt 1 Transformer	6/1/2018
200395	50924	SPS	Livingston Ridge 115 kV Substation Conversion	11/30/2017
200411		SPS	Livingston Ridge - Sage Brush 115 kV Ckt 1	6/1/2018
200309	50925	SPS	Sage Brush 115 kV Substation	12/16/2016

SPP Notification to Construct (NTC) ID	UID	Project Owner	Upgrade Name	Estimated Date of Upgrade Completion (EOC)
200309	50928	SPS	Largarto - Sage Brush 115 kV Ckt 1	12/15/2016
200309	50927	SPS	Lagarto 115 kV Substation	6/1/2018
200309	50951	SPS	Cardinal - Lagarto 115 kV Ckt 1	12/15/2016
200309	50967	SPS	Cardinal 115 kV Substation	12/15/2016
200411	50923	SPS	Ponderosa - Ponderosa Tap 115 kV Ckt 1	6/1/2017
200395		SPS	Canyon West - Dawn - Panda - Deaf Smith 115kV Ckt 1	12/15/2018
200369		SPS	Canyon East Sub - Randall County Interchange 115kV Ckt 1	12/31/2020
200359	11509	SPS	Carlisle 230/115kV transformer replacement	3/27/2018
200309		SPS	Hobbs - Yoakum - TUCO 345kV project	6/1/2018
200395		SPS	Terry County - Wolfforth 115kV Ckt 1 terminal equipment replacement	6/1/2018
200391		OGE	DeGrasse 345/138kV project	6/1/2019
200396		WFEC	DeGrasse 345/138kV project	12/31/2019
200395		SPS	Harrington East - Potter 230kV Ckt 1 terminal equipment replacement	6/1/2019
200228		WERE	Viola 345/138kV project	6/1/2018
200228		MKEC	Viola 345/138kV project	6/1/2018
200395		SPS	Seminole 230/115kV transformer Ckt 1 & 2 replacement	5/15/2018
200262		SPS	Yoakum County Interchange 230/115kV transformer Ckt 1 & 2 replacement	6/1/2019
210507			Multi - China Draw - Road Runner 345 kV	6/1/2024

11.2 APPENDIX B

Table B-1: Higher Queued SPP Network Upgrades Included in the Analysis

Assigned Study	Upgrade Name	Estimated Date of Upgrade Completion (EOC)
DISIS-2010-002	Twin Church - Dixon County 230kV Line Upgrade	
DISIS-2010-002	Buckner - Spearville 345 kV Ckt 1 Terminal Upgrades	
DISIS-2011-001	Hoskins - Dixon County 230kV Line Upgrade	
DISIS-2014-002	Plant X - Tolk 230kV rebuild circuit #1	
DISIS-2014-002	Plant X - Tolk 230kV rebuild circuit #2	
DISIS-2014-002	TUCO Interchange 345/230kV CKT 1 Replacement	
DISIS-2015-001	(NRIS Only) Renfrow – Renfrow 138kV circuit #1 rebuild.	
DISIS-2015-001	Oклаunion 345kV Reactive Power	
DISIS-2015-002	Beaver County 345kV Reactive Power Support Install +100Mvar SVC at Beaver County Substation.	
DISIS-2015-002	Border - Chisholm 345kV CKT 1 & 2	
DISIS-2015-002	Bushland - Potter County 230kV CKT 1	
DISIS-2015-002	Carlisle 115/69/13kV Transformer CKT 1	
DISIS-2015-002	Chisholm Substation Upgrade 345kV	
DISIS-2015-002	Cleo Corner - Cleo Plant Tap 138kV CKT 1	
DISIS-2015-002	Cleveland - Silver City 138kV CKT 1	
DISIS-2015-002	Cornville Tap - Naples Tap 138kV CKT 1	
DISIS-2015-002	Crawfish Draw 345/230kV Substation Upgrade Taps TUCO – Border 345kV, TUCO – Oклаunion 345kV, and TUCO – Swisher 230kV Build 345/230/13kV transformer	
DISIS-2015-002	Crawfish Draw - Border 345kV CKT 2	
DISIS-2015-002	Daglum - Dickinson 230kV CKT 1	
DISIS-2015-002	Dickinson 230/115/13.8kV CKT 2	
DISIS-2015-002	Gavins Point - Yankton Junction 115kV CKT 1	
DISIS-2015-002	GEN-2015-063 Tap - Mathewson 345kV CKT 1	
DISIS-2015-002	Grapevine - Wheeler 230kV CKT 1	
DISIS-2015-002	Naples Tap - Payne 138kV CKT 1	
DISIS-2015-002	Norge - Southwest Station 138kV CKT 1	
DISIS-2015-002	Potter County Interchange 345/230/13kV Transformer circuit #2, build.	
DISIS-2015-002	Albion - Petersburg - North Petersburg 115kV CKT 1	
DISIS-2015-002	Wheeler - Sweetwater 230kV CKT 1	
DISIS-2015-002	Woodward 345/138/13kV Transformer CKT 3	
DISIS-2016-001	Andrews 345/115/13kV Transformer CKT 1 Replace 230/115kV transformer CKT 1 with 345/115kV transformer	
DISIS-2016-001	Andrews 345/115/13kV Transformer CKT 2 Replace 230/115kV transformer CKT 2 with 345/115kV transformer	
DISIS-2016-001	Andrews Substation Voltage Conversion Convert Andrews 230kV to 345kV	
DISIS-2016-001	Atwood Capacitive Reactive Power Support Install 10 Mvars of Capacitor Bank(s)	
DISIS-2016-001	Banner County - Keystone 345kV CKT 1	

Assigned Study	Upgrade Name	Estimated Date of Upgrade Completion (EOC)
	Build approximately 140 of new 345kV from Banner County to Keystone. Banner County and Keystone Substation Work.	
DISIS-2016-001	Beaver County - Clark County 345kV CKT 1 Build approximately 125 miles of new 345kV from Grapevine – Chisholm	
DISIS-2016-001	BEPC Laramie Stability Limit Potential mitigation for BEPC Laramie Stability Limit	
DISIS-2016-001	Border 345kV Reactive Power Support Install (6)Steps of 50Mvar Capacitor Bank(s) and +300Mvar SVC at Border Substation	
DISIS-2016-001	Cleveland - Cleveland 138kV CKT Z1 NRIS only required upgrade: Replace bus tie breaker with a three breaker ring	
DISIS-2016-001	Cleveland 345/138/13kV Transformer CKT 2 NRIS only required upgrade: Install second 345/138kV Transformer	
DISIS-2016-001	Crawfish Draw 230/115/13kV Transformer CKT 1 NRIS only required upgrade: Build 115kV yard, re-terminate Hale County - TU CO 115kV, build 230/115/13kV transformer 1	
DISIS-2016-001	Drinkard - Drinkard Tap 115kV CKT 1 Rebuild approximately 2 miles from Drinkard to Drinkard Tap	
DISIS-2016-001	Drinkard Tap - West Hobbs 115kV CKT 1 Rebuild approximately 12.5 miles from Drinkard Tap to West Hobbs	
DISIS-2016-001	Fairfax Tap - Shidler 138kV CKT 1 NRIS only required upgrade: Rebuild approximately 2.4 miles of 138kV	
DISIS-2016-001	Farber - Belle Plains 138kV CKT 1 Rebuild approximately 10.3 miles of 138kV from Farber to Belle Plains	
DISIS-2016-001	GEN-2015-063 Tap - Woodring 345kV CKT 1	
DISIS-2016-001	Glenham - Mound City 230kV CKT 1 Upate CT	
DISIS-2016-001	Hitchland 345/230/13kV Transformer CKT 3 NRIS only required upgrade: Build third 345/230/13kV Transformer	
DISIS-2016-001	Jamestown - Center 345kV CKT 1 MPC mitigation for Jamestown - Center 345kV	
DISIS-2016-001	Keystone - Gentleman 345kV CKT 2 Build approximately 30 miles of new 345kV. Gentleman and Keystone Substation Work.	
DISIS-2016-001	Kildare - White Eagle 138kV CKT 1 Rebuild approximately 11 miles of 138kV from Kildare to White Eagle	
DISIS-2016-001	Kinsley - Pawnee 115kV CKT 1 Increase conductor clearance	
DISIS-2016-001	Kinze - McElroy 138kV CKT 1 Rebuild approximately 2 miles of 138kV from Kinze to McElroy	
DISIS-2016-001	Lubbock Holly 230/69/13kV CKT 2 NRIS only required upgrade: Install second Lubbock Holly 230/69/13kV Transformer	
DISIS-2016-001	Middleton Tap - Chilocco 138kV CKT 1	

Assigned Study	Upgrade Name	Estimated Date of Upgrade Completion (EOC)
	Rebuild approximately 3.45 miles of 138kV from Middleton to Chilocco	
DISIS-2016-001	National Enrichment Plant - Drinkard 115kV CKT 1 Rebuild approximately 7.5 miles from NEF Plant to Drinkard	
DISIS-2016-001	Neosho - Riverton 161kV CKT 1 Rebuild approximately 28 miles of 161kV	
DISIS-2016-001	Northwest - Spring Creek 345kV CKT 1 Replace terminal equipment	
DISIS-2016-001	Oklawhoma 345kV Reactive Power Support Incremental Upgrade Install 250Mvar capacitor banks and +/-100Mvar SVC at Oklawhoma	
DISIS-2016-001	Osage - Webb Tap 138kV CKT 1 Rebuild approximately 22 miles of 138kV from Osage to Webb City	
DISIS-2016-001	Osage - White Eagle 138kV CKT 1 Rebuild approximately 3 miles of 138kV from Osage to White Eagle	
DISIS-2016-001	Potter - Chisholm 345kV CKT 1 Build approximately 140 miles of new 345kV from Potter County - Chisholm	
DISIS-2016-001	Shamrock 115kV Capacitor Bank Add 20Mvar of Capacitor Bank(s) at Shamrock 115kV	
DISIS-2016-001	Tolk - Crawfish Draw 345kV CKT 1 Build approximately 64 miles of 345kV from Tolk - Crawfish Draw.	
DISIS-2016-001	Tolk - Potter County 345kV CKT 1 Build approximately 115 miles of 345kV from Tolk - Potter County	
DISIS-2016-001	Tolk 345/230/13kV Transformer CKT 2 Build second 345/230/13kV transformer at Tolk	
DISIS-2016-001	Webb City Tap - Fairfax Tap 138kV CKT 1 NRIS only required upgrade: Rebuild approximately 0.3 miles of 138kV. Costs included in Fairfax Tap - Shidler Upgrade	
DISIS-2016-002	Please refer to Appendix F of the most recently posted DISIS-2016-002 for network upgrades and cost allocation per DISIS request.	

11.3 APPENDIX C

Table 11-2: Higher Queued SPP Interconnection Requests Included in the Analysis

Study	Generation Interconnection Number	SP PMA X	WP PMA X	Ser vice	Group	Type	Status
PQ	ASGI-2010-006	150	150	ER	08 N-OK & S-KS	Wind	
PQ	GEN-2001-033	180. 29	180. 29	ER	06 NM & W-TX	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2001-036	80	80	ER	06 NM & W-TX	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2002-004	274. 5	274. 5	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2004-023N	75	75	ER	09 NEB	Coal	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2005-013	199. 8	199. 8	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2006-018	162	167. 22	ER	06 NM & W-TX	CT	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2006-020N	42	42	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2006-026	502	508	ER	06 NM & W-TX	Gas	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2006-038N005	80	80	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2006-038N019	80	80	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2007-011N08	81	81	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	GEN-2008-1190	60	60	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
PQ	NPPD Distributed (Broken Bow)	7.3	7.3	ER	09 NEB	Heat	
PQ	NPPD Distributed (Burwell)	3	3	ER	09 NEB	Heat	
PQ	NPPD Distributed (Ord)	10.8	10.8	ER	09 NEB	Heat	
PQ	NPPD Distributed (Stuart)	1.8	1.8	ER	09 NEB	Heat	

PQ	NPPD Distributed (Columbus Hydro)	45	45	ER	09 NEB	Hydro	
PQ	WAPA SEAMS (Gavins Pt Hydro)	102	102	ER	09 NEB	Hydro	
PQ	WAPA SEAMS (Ft Randle Hydro)	352	352	ER	09 NEB	Hydro	
PQ	WAPA SEAMS (Spirit Mound Heat)	120	120	ER	09 NEB	Heat	
PQ	SPS Distributed (Hopi)	10	10	ER	06 NM & W-TX	Solar	
PQ	SPS Distributed (Monument)	10	10	ER	06 NM & W-TX	Solar	
PQ	SPS Distributed (Lea Road)	10	10	ER	06 NM & W-TX	Solar	
PQ	SPS Distributed (Jal)	10	10	ER	06 NM & W-TX	Solar	
PQ	SPS Distributed (Ocotillo)	10	10	ER	06 NM & W-TX	Solar	
PQ	NPPD Distributed (Burt County Wind)	12	12	ER	09 NEB	Wind	
PQ	NPPD Distributed (Buffalo County Solar)	10	10	ER	09 NEB	Solar	
PQ	Sunray	34.5	34.5	ER	06 NM & W-TX	Wind	Commerical Operation
ICS1	GEN-2007-025	299.2	299.2	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
ICS1	GEN-2008-013	299.04	299.04	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-09-1	GEN-2006-037N1	74.8	74.8	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-09-1	GEN-2006-044N	40.5	40.5	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-09-1	GEN-2008-086N02	201	201	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-09-1	GEN-2009-025	59.8	59.8	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-10-1	ASGI-2010-010	42.15	42.15	ER	06 NM & W-TX	Gas	
DIS-10-1	GEN-2008-022	299.65	299.65	ER	06 NM & W-TX	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-10-1	GEN-2008-098	99.5	99.5	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION

DIS-10-1	GEN-2008-123N	89.7	89.7	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-10-1	GEN-2009-040	73.8	73.8	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-10-1	GEN-2010-003	99.5	99.5	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-10-1	GEN-2010-005	299.2	299.2	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-10-1	GEN-2010-006	180	205	ER	06 NM & W-TX	Gas	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-10-2	ASGI-2010-020	30	30	ER	06 NM & W-TX	Wind	
DIS-10-2	ASGI-2010-021	15	15	ER	06 NM & W-TX	Wind	
DIS-10-2	ASGI-2011-001	27.3	27.3	ER	06 NM & W-TX	Wind	Commerical Operation
DIS-10-2	GEN-2010-041	10.5	10.5	ER	09 NEB	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-10-2	GEN-2010-046	56	56	ER	06 NM & W-TX	Gas	IA FULLY EXECUTED/ON SCHEDULE
DIS-10-2	GEN-2010-051	200	200	ER	09 NEB	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-11-1	ASGI-2011-003	10	10	ER	06 NM & W-TX	Wind	
DIS-11-1	GEN-2010-055	4.5	4.5	ER	08 N-OK & S-KS	Gas	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-11-1	GEN-2011-018	73.6	73.6	ER/NR	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-11-1	GEN-2011-025	80	80	ER	06 NM & W-TX	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-11-1	GEN-2011-027	120	120	ER/NR	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-11-2-PQ	NPPD Distributed (North Platte - Lexington)	54	54	ER	09 NEB	Hydro	
DIS-11-2	ASGI-2011-004	19.8	19.8	ER	06 NM & W-TX	Wind	
DIS-11-2	GEN-2011-045	180	205	ER	06 NM & W-TX	NG CT	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-11-2	GEN-2011-046	23	27	ER	06 NM & W-TX	Diesel CT	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-11-2	GEN-2011-048	165	175	ER/NR	06 NM & W-TX	CT	IA FULLY EXECUTED/COMMERCIAL OPERATION

DIS-11-2	GEN-2011-056	3.6	3.6	ER	09 NEB	Hydro	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-11-2	GEN-2011-056A	3.6	3.6	ER	09 NEB	Hydro	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-11-2	GEN-2011-056B	4.5	4.5	ER	09 NEB	Hydro	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-11-2	GEN-2011-057	150	150	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-12-1	GEN-2012-001	61.2	61.2	ER	06 NM & W-TX	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-12-2	ASGI-2012-002	18.1 5	18.1 5	ER	06 NM & W-TX	Wind	
DIS-12-2	GEN-2012-020	477. 1	477. 1	ER	06 NM & W-TX	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-12-2	GEN-2012-021	4.8	4.8	ER	09 NEB	Gas	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-12-2	GEN-2012-032	350	350	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-12-2	GEN-2012-033	98.8 2	98.8 2	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-12-2	GEN-2012-034	7	7	ER	06 NM & W-TX	CT	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-12-2	GEN-2012-035	7	7	ER	06 NM & W-TX	CT	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-12-2	GEN-2012-036	7	7	ER	06 NM & W-TX	CT	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-12-2	GEN-2012-037	195	203	ER	06 NM & W-TX	CT	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-12-2	GEN-2012-041	85.3	121. 5	ER	08 N-OK & S-KS	CT	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-13-1	ASGI-2013-002	18.4	18.4	ER	06 NM & W-TX	Wind	
DIS-13-1	ASGI-2013-003	18.4	18.4	ER	06 NM & W-TX	Wind	
DIS-13-1	GEN-2013-002	50.6	50.6	ER/ NR	09 NEB	Wind	IA FULLY EXECUTED/ON SUSPENSION
DIS-13-1	GEN-2013-008	1.2	1.2	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION

DIS-13-1	GEN-2013-012	68	147	ER	08 N-OK & S-KS	Gas	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-13-1	GEN-2013-016	193	203	ER	06 NM & W-TX	CT	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-13-2	ASGI-2013-005	1.65	1.65	ER	06 NM & W-TX	Wind	
DIS-13-2	GEN-2013-019	73.6	73.6	ER/NR	09 NEB	Wind	IA FULLY EXECUTED/ON SUSPENSION
DIS-13-2	GEN-2013-022	25	25	ER/NR	06 NM & W-TX	Solar	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-13-2	GEN-2013-028	495	495	ER	08 N-OK & S-KS	Gas	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-13-2	GEN-2013-029	299	299	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-13-2	GEN-2013-032	204	204	ER	09 NEB	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-14-1	GEN-2014-001	200.6	200.6	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-14-1	GEN-2014-004	3.96	3.96	ER	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-14-1	GEN-2014-013	73.5	73.5	ER/NR	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-14-2	ASGI-2014-014	54.3	54.3	ER	08 N-OK & S-KS	Thermal	
DIS-14-2	GEN-2013-027	150	150	ER/NR	06 NM & W-TX	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-14-2	GEN-2014-028	35	35	ER	08 N-OK & S-KS	CC	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-14-2	GEN-2014-031	35.8	35.8	ER/NR	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-14-2	GEN-2014-032	10.22	10.22	ER/NR	09 NEB	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-14-2	GEN-2014-033	70	70	ER	06 NM & W-TX	Solar	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-14-2	GEN-2014-034	70	70	ER	06 NM & W-TX	Solar	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-14-2	GEN-2014-035	30	30	ER	06 NM & W-TX	Solar	IA FULLY EXECUTED/ON SCHEDULE
DIS-14-2	GEN-2014-039	73.39	73.39	ER/NR	09 NEB	Wind	IA FULLY EXECUTED/ON SCHEDULE

DIS-14-2	GEN-2014-040	320	320	ER	06 NM & W-TX	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-14-2	GEN-2014-064	248.4	248.4	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-15-1-PQ	GEN-2007-017IS	200	200	ER/NR	09 NEB	Wind	On Schedule
DIS-15-1-PQ	GEN-2007-018IS	200	200	ER/NR	09 NEB	Wind	On Schedule
DIS-15-1	ASGI-2015-002	2	2	ER	06 NM & W-TX	Wind	
DIS-15-1	ASGI-2015-004	54.3	54.3	ER	08 N-OK & S-KS	Thermal	
DIS-15-1	GEN-2015-001	200	200	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-15-1	GEN-2015-007	160	160	ER	09 NEB	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-15-1	GEN-2015-014	150	150	ER	06 NM & W-TX	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-15-1	GEN-2015-015	154.56	154.56	ER/NR	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-15-1	GEN-2015-016	200	200	ER/NR	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-15-1	GEN-2015-023	300.72	300.72	ER/NR	09 NEB	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-15-1	GEN-2015-024	220	220	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-15-1	GEN-2015-025	220	220	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-15-2	GEN-2015-020	99.96	99.96	ER	06 NM & W-TX	Solar	IA PENDING
DIS-15-2	GEN-2015-034	200	200	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-15-2	GEN-2015-047	300	300	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-15-2	GEN-2015-052	300	300	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-15-2	GEN-2015-056	101.2	101.2	ER	06 NM & W-TX	WIND	IA PENDING
DIS-15-2	GEN-2015-062	4.51	4.51	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-15-2	GEN-2015-063	300	300	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-15-2	GEN-2015-066	248.4	248.4	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/ON SUSPENSION

DIS-15-2	GEN-2015-069	300	300	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-15-2	GEN-2015-073	200. 1	200. 1	ER/ NR	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-15-2	GEN-2015-076	158. 4	158. 4	ER	09 NEB	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-15-2	GEN-2015-087	66	66	ER/ NR	09 NEB	Wind	IA FULLY EXECUTED/ON SUSPENSION
DIS-15-2	GEN-2015-088	300	300	ER/ NR	09 NEB	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-15-2	GEN-2015-090	220	220	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-16-1	ASGI-2016-002	0.35	0.35	ER	06 NM & W-TX	Wind	
DIS-16-1	ASGI-2016-004	5	5	ER	06 NM & W-TX	Wind	
DIS-16-1	GEN-2015-041	5	5	ER	06 NM & W-TX	CT	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-009	29	29	ER	08 N-OK & S-KS	Steam Turbine	IA FULLY EXECUTED/ON SCHEDULE
DIS-16-1	GEN-2016-015	100	100	ER	06 NM & W-TX	Solar	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-021	300	300	ER	09 NEB	WIND	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-022	151. 8	151. 8	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-023	301. 06	301. 06	ER	09 NEB	Wind	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-031	1.5	1.5	ER	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/COMMERCIAL OPERATION
DIS-16-1	GEN-2016-032	200	200	ER/ NR	08 N-OK & S-KS	Wind	IA FULLY EXECUTED/ON SUSPENSION
DIS-16-1	GEN-2016-043	230	230	ER	09 NEB	Wind	IA FULLY EXECUTED/ON SCHEDULE
DIS-16-1	GEN-2016-050	250. 7	250. 7	ER	09 NEB	Wind	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-056	200	200	ER	06 NM & W-TX	Wind	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-061	250. 7	250. 7	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-062	250. 7	250. 7	ER	06 NM & W-TX	Wind	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-068	250	250	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-069	31.3 5	31.3 5	ER	06 NM & W-TX	Solar	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-071	200. 1	200. 1	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-1	GEN-2016-073	220	220	ER	08 N-OK & S-KS	WIND	FACILITY STUDY STAGE
DIS-16-1	GEN-2015-089	200	200	ER	09 NEB	Wind	IA FULLY EXECUTED/ON SCHEDULE

DIS-16-1	GEN-2016-075	50	50	ER	09 NEB	Wind	FACILITY STUDY STAGE
DIS-16-2-PQ	ASGI-2017-008	158.6	158.6	ER/NR	08 N-OK & S-KS	Wind	
DIS-16-2	ASGI-2016-009	3	3	ER	06 NM & W-TX	Wind	
DIS-16-2	GEN-2015-099	70.4	70.4	ER	06 NM & W-TX	Solar	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-074	200	200	ER	09 NEB	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-096	227.7	227.7	ER	09 NEB	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-100	100	100	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-101	195	195	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-106	400	400	ER	09 NEB	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-110	152	152	ER	09 NEB	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-119	600	600	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-121	110	110	ER	06 NM & W-TX	Solar	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-123	298	298	ER	06 NM & W-TX	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-124	150	150	ER	06 NM & W-TX	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-125	74	74	ER	06 NM & W-TX	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-128	176	176	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-133	187.5	187.5	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-134	187.5	187.5	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-135	100	100	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-136	75	75	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-137	187.5	187.5	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-138	187.5	187.5	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-139	100	100	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-140	75	75	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-141	700	700	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-143	175	175	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-144	175	175	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-145	175	175	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE

DIS-16-2	GEN-2016-146	175	175	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-147	40	40	ER	09 NEB	Solar	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-153	134	134	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-162	252	252	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-163	252	252	ER	08 N-OK & S-KS	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-165	202	202	ER	09 NEB	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-171	60.8	60.8	ER	06 NM & W-TX	Solar	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-172	231	231	ER	06 NM & W-TX	Wind	FACILITY STUDY STAGE
DIS-16-2	GEN-2016-177	14.4	17	ER	06 NM & W-TX	Gas Turbine	FACILITY STUDY STAGE

11.4 APPENDIX D

Table 11-3: Higher Queued MISO Interconnection Requests Included in the Analysis

Study	POI Bus Num	GEN Bus Num	GEN ID	Generation Interconnection Number	ERIS PMAX	NRIS PMAX	Service	Group	Type	Status
DIS-15-1-PQ	66201	635215	W	J411	150	150	NR	09 IA	Wind	Done
DIS-15-1-PQ	66201	635216	W	J411	125	125	NR	09 IA	Wind	Done
DIS-15-1-PQ	66201	635216	W1	J411	25	25	NR	09 IA	Wind	Done
DIS-15-1-PQ	631206	629922	1	J416	87.5	87.5	NR	09 IA	Wind	Done
DIS-15-1-PQ	631206	629922	2	J416	11.5	11.5	NR	09 IA	Wind	Done
DIS-15-1-PQ	631206	629923	1	J416	90	90	NR	09 IA	Wind	Done
DIS-15-1-PQ	631206	629923	2	J416	11.5	11.5	NR	09 IA	Wind	Done
DIS-15-2-PQ	635206	635258	W	J412	100	100	NR	09 IA	Wind	Done
DIS-15-2-PQ	635206	635259	W	J412	100	100	NR	09 IA	Wind	Done
DIS-15-2-PQ	631085	631242	1	J438	147	147	NR	09 IA	Wind	Done
DIS-15-2-PQ	631085	631242	2	J438	20	20	NR	09 IA	Wind	Done
DIS-15-2-PQ	631243	631248	1	J455	117.5	0	ER	09 IA	Wind	Done
DIS-15-2-PQ	631243	631248	2	J455	29.9	0	ER	09 IA	Wind	Done
DIS-15-2-PQ	631243	631249	1	J455	117.5	0	ER	09 IA	Wind	Done
DIS-15-2-PQ	631243	631249	2	J455	29.9	0	ER	09 IA	Wind	Done
DIS-16-1-PQ	85831	635585	W	J499	170	170	NR	09 IA	Wind	Active
DIS-16-1-PQ	85831	635586	W	J499	170	170	NR	09 IA	Wind	Active
DIS-16-1-PQ	635570	635577	W1	J500	168	168	NR	09 IA	Wind	Active
DIS-16-1-PQ	635570	635578	W2	J500	166	166	NR	09 IA	Wind	Active
DIS-16-1-PQ	635570	635579	W3	J500	166	166	NR	09 IA	Wind	Active
DIS-16-1-PQ	65200	65203	1	J527	125	125	NR	09 IA	Wind	Active
DIS-16-1-PQ	65200	65205	2	J527	125	125	NR	09 IA	Wind	Active
DIS-16-1-PQ	65300	65303	1	J528	100	100	NR	09 IA	Wind	Active
DIS-16-1-PQ	65300	65305	1	J528	100	100	NR	09 IA	Wind	Active

Southwest Power Pool, Inc.

DIS-16-2-PQ	635590	85834	1	J583	200	200	NR	09 IA	Wind	Active
DIS-14-2-PQ	635368	635414	W	J285	125	125	NR	09 NEB	Wind	Done
DIS-14-2-PQ	635368	635415	W	J285	125	125	NR	09 NEB	Wind	Done
DIS-14-2-PQ	635034	635059	W	J343	150	150	NR	09 NEB	Wind	Done
DIS-14-2-PQ	631187	635884	W1	J344	168	168	NR	09 NEB	Wind	Done

11.5 APPENDIX E

Table 11-4: ERIS Constraints for Mitigation

Group	Season	Source	Mont Common Name	TDF	Rating	Contingency Loading %	Contname
06ALLP_SP	18G	GEN_18075_T_SP	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.42777	1029.4	100.9677	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18078_P	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.63665	1029.4	100.9677	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18075_T_SP	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.42777	1029.4	100.9677	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18078_P	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.63665	1029.4	100.9677	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18075_P_SP	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.42279	1029.4	100.869	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18078_P	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.63665	1029.4	100.869	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18075_P_SP	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.42279	1029.4	100.869	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18078_P	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.63665	1029.4	100.869	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18075_S_SP	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.4204	1029.4	100.8215	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18078_P	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.63665	1029.4	100.8215	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18075_S_SP	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.4204	1029.4	100.8215	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'
06ALLP_SP	18G	GEN_18078_P	'CROSSROADS 7345.00 - TOLK STATION 345KV CKT 1'	0.63665	1029.4	100.8215	'CRAWFISH765 765.00 - CROSSRDS765 765.00 765KV CKT 1'

Table 11-5: NRIS Constraints for Mitigation

Group	Season	Source	Mont Common Name	TDF	Rating	Contingency Loading %	Contname
09NR	21L	GEN_18066_P	'MONOLITH 7 115.00 - SHELDON 115KV CKT 1'	0.04282	327.9	135.4767	'MONOLITH 3 345.00 - MOORE 345KV CKT 1'

11.6 APPENDIX F

Short Circuit Analysis

11.6.1 GEN-2018-066 2018S:

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS

FRI, FEB 22 2019 18:28

2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL

MDWG 2018S WITH MMWG 2017S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

THREE PHASE FAULT

X----- BUS -----X		/I+/-	AN(I+)
90661 [G18066_SUB 345.00]	AMP	19074.6	-87.10
523853 [FINNEY 7345.00]	AMP	10224.3	-85.81
530554 [ATWOOD 3 115.00]	AMP	3008.0	-72.48
530555 [COLBY 3 115.00]	AMP	6077.3	-80.52
530559 [PH RUN 3 115.00]	AMP	4520.1	-77.67
530583 [POSTROCK7 345.00]	AMP	7918.2	-84.57
530584 [POSTROCK6 230.00]	AMP	10885.1	-84.71
530644 [COLBY 2 69.000]	AMP	3956.9	-84.96
530682 [SEGNTP 3 115.00]	AMP	4284.4	-75.23
530683 [SEGUIN 3 115.00]	AMP	4074.7	-76.44
531351 [BREWSTR3 115.00]	AMP	3101.1	-76.75
531353 [GOODLND3 115.00]	AMP	2653.9	-75.63
531412 [GRINNEL3 115.00]	AMP	3699.7	-77.20
531416 [CTYSERT3 115.00]	AMP	9920.0	-84.65
531429 [MINGO 3 115.00]	AMP	12487.6	-85.45
531433 [SCOTCTY3 115.00]	AMP	8922.9	-83.71
531448 [HOLCOMB3 115.00]	AMP	21536.6	-87.52
531449 [HOLCOMB7 345.00]	AMP	10313.3	-85.83
531451 [MINGO 7 345.00]	AMP	6232.1	-84.90
531464 [SETAB 3 115.00]	AMP	10554.8	-85.38
531465 [SETAB 7 345.00]	AMP	7088.6	-85.25
531501 [BUCKNER7 345.00]	AMP	9400.1	-84.99
560062 [G15-088-TAP 345.00]	AMP	11004.4	-85.11
560075 [G16-023-TAP 345.00]	AMP	5946.0	-87.12

560082	[G16-050-TAP 345.00]	AMP	6987.3	-84.87
560090	[G16-034-TAP 345.00]	AMP	6098.7	-86.41
560134	[ROSEMONT 115.00]	AMP	6275.1	-73.80
562334	[G13-010-TAP 345.00]	AMP	7604.7	-84.36
584650	[GEN-2015-023345.00]	AMP	6848.9	-85.82
585020	[GEN-2015-064115.00]	AMP	9847.6	-84.14
585030	[GEN-2015-065345.00]	AMP	5696.0	-84.79
587090	[GEN-2016-023345.00]	AMP	4989.5	-86.72
587190	[GEN-2016-029345.00]	AMP	4989.5	-86.72
587220	[GEN-2016-034345.00]	AMP	6098.7	-86.41
587350	[GEN-2016-050345.00]	AMP	6279.4	-84.77
587450	[GEN-2016-067345.00]	AMP	5696.0	-84.79
587680	[GEN-2016-074345.00]	AMP	6466.5	-84.20
587780	[GEN-2016-096345.00]	AMP	9200.9	-85.01
587784	[G16-096-TAP 345.00]	AMP	9223.1	-85.04
587850	[GEN-2016-106345.00]	AMP	8959.2	-85.52
587874	[G16-110-TAP 345.00]	AMP	6456.4	-87.33
588220	[GEN-2016-147115.00]	AMP	4094.2	-83.74
588340	[GEN-2016-165345.00]	AMP	5810.5	-85.91
588344	[G16-165-TAP 345.00]	AMP	6866.0	-86.11
640050	[AINSWND7 115.00]	AMP	3697.6	-76.25
640051	[AINSWRT7 115.00]	AMP	3404.8	-74.75
640063	[AURORA_7 115.00]	AMP	6924.4	-79.49
640065	[AXTELL 3 345.00]	AMP	9415.5	-84.80
640066	[AXTELL 7 115.00]	AMP	14107.0	-84.50
640082	[BEVERLY7 115.00]	AMP	4610.2	-80.63
640083	[BEVERLY8 69.000]	AMP	4230.9	-83.80
640089	[BROKENB7 115.00]	AMP	5506.7	-78.78
640091	[BRULE 7 115.00]	AMP	5410.3	-76.58
640093	[C.CREEK4 230.00]	AMP	7041.2	-83.35
640094	[C.CREEK7 115.00]	AMP	7157.1	-84.76
640096	[CALAMS 7 115.00]	AMP	3402.4	-75.02
640098	[CALAWAY7 115.00]	AMP	3850.1	-74.88
640100	[CAMBRIG7 115.00]	AMP	4038.9	-77.12
640101	[CAMBRIG8 69.000]	AMP	2195.7	-82.44
640102	[CANADAY4 230.00]	AMP	6199.4	-83.41
640103	[CANADAY7 115.00]	AMP	13705.7	-81.92
640107	[CENCITY7 115.00]	AMP	5041.4	-73.13
640131	[COLMB.W4 230.00]	AMP	9604.3	-84.32
640133	[COLMBUS4 230.00]	AMP	11142.5	-84.76
640139	[COOPER 3 345.00]	AMP	26663.6	-85.94
640161	[ELMCRK_7 115.00]	AMP	5893.0	-74.52
640167	[ENDERS 7 115.00]	AMP	3707.0	-77.72
640168	[ENDERS 8 69.000]	AMP	3008.0	-83.23
640178	[GENEVA 7 115.00]	AMP	9714.4	-78.75
640183	[GENTLMN3 345.00]	AMP	19074.6	-87.10
640184	[GENTLMN4 230.00]	AMP	20267.9	-87.30
640194	[GOSPER 7 115.00]	AMP	4254.9	-77.16
640196	[GOTHNBG7 115.00]	AMP	4279.9	-74.97

Southwest Power Pool, Inc.

640200	[GR ISLD4	230.00]	AMP	16413.4	-84.87
640201	[GR ISLD7	115.00]	AMP	22688.3	-84.03
640214	[HASTING4	230.00]	AMP	7246.2	-84.57
640215	[HASTING7	115.00]	AMP	19039.2	-82.74
640222	[HILDRTH7	115.00]	AMP	4189.7	-75.94
640224	[HOLDREG7	115.00]	AMP	6020.0	-78.70
640238	[JEFFREY7	115.00]	AMP	5955.6	-78.99
640240	[JOHN.1 7	115.00]	AMP	8206.4	-77.26
640242	[JOHN.2 7	115.00]	AMP	12499.5	-80.34
640248	[KEAR.NE7	115.00]	AMP	9029.6	-80.17
640250	[KEARNEY7	115.00]	AMP	11574.1	-80.91
640252	[KEYSTON3	345.00]	AMP	12222.4	-86.36
640253	[KEYSTON7	115.00]	AMP	15479.1	-86.47
640255	[KINGSLY7	115.00]	AMP	9292.5	-82.50
640261	[LOWELL 7	115.00]	AMP	7988.0	-77.65
640265	[MALONEY7	115.00]	AMP	11248.5	-80.04
640267	[MAXWELS7	115.00]	AMP	6636.1	-81.37
640269	[MCCOOK 7	115.00]	AMP	7566.4	-78.96
640270	[MCCOOK 8	69.000]	AMP	4241.9	-84.21
640271	[MCCOOL 3	345.00]	AMP	10255.5	-84.50
640272	[MCCOOL 7	115.00]	AMP	13931.7	-84.01
640273	[MCCOOL	869.000]	AMP	5450.2	-87.18
640275	[MINDEN 7	115.00]	AMP	7082.5	-80.49
640277	[MOORE 3	345.00]	AMP	21170.6	-85.26
640278	[SHELDON7	115.00]	AMP	31634.1	-85.35
640286	[N.PLATT4	230.00]	AMP	13383.0	-84.75
640287	[N.PLATT7	115.00]	AMP	18549.0	-84.73
640288	[N.PLATT8	69.000]	AMP	4909.6	-87.38
640302	[OGALALA4	230.00]	AMP	7851.0	-84.95
640304	[OGALALANPPD7	115.00]	AMP	15003.1	-85.04
640310	[ORLEANS7	115.00]	AMP	2349.7	-70.64
640312	[PAULINE3	345.00]	AMP	8029.5	-84.34
640313	[PAULINE7	115.00]	AMP	16131.5	-81.83
640314	[PAULINE8	69.000]	AMP	4707.8	-86.91
640325	[REDWILO3	345.00]	AMP	6246.9	-84.44
640326	[REDWILO7	115.00]	AMP	10368.2	-80.78
640330	[RIVERDL4	230.00]	AMP	6997.1	-83.19
640331	[RIVERDL7	115.00]	AMP	11828.6	-81.59
640353	[ST.LIB 7	115.00]	AMP	9501.9	-76.42
640359	[STAPLETON	7115.00]	AMP	4141.9	-82.08
640360	[STAPLETON	869.000]	AMP	3166.2	-85.22
640365	[STOCKVL7	115.00]	AMP	4418.9	-74.61
640366	[STOCKVL8	69.000]	AMP	3234.8	-82.15
640370	[SUTHLND7	115.00]	AMP	5423.0	-77.12
640374	[SWEET W3	345.00]	AMP	10961.3	-85.24
640381	[THEDFRD7	115.00]	AMP	9192.5	-85.46
640383	[TOWER 7	115.00]	AMP	8724.0	-81.64
640413	[YORK SW7	115.00]	AMP	7978.6	-80.34
640448	[HOLDREGE	869.000]	AMP	3654.1	-84.90

640500	[THEDFORD3	345.00]	AMP	5814.2	-85.05
640510	[HOLT.CO3	345.00]	AMP	7464.9	-85.90
640530	[STEGALL7	115.00]	AMP	7996.2	-86.70
641088	[HASTCTY7	115.00]	AMP	19039.2	-82.74
641244	[ATHEY 7	115.00]	AMP	3029.5	-77.21
642071	[SUB-D 7	115.00]	AMP	16965.8	-80.89
642072	[SUB-E 7	115.00]	AMP	16475.6	-83.16
650114	[NW68HOLDRG3	345.00]	AMP	16352.0	-85.01
650189	[103&ROKEBY3	345.00]	AMP	19591.5	-85.09
652532	[GR PRAIRIE	3345.00]	AMP	6837.8	-86.12
652832	[GRPRAR1-LNX3345.00]	AMP	6837.8	-86.12	
653571	[GR ISLD3	345.00]	AMP	12172.5	-84.94
653572	[SIDNEY 7	115.00]	AMP	4196.7	-84.21
653871	[GR ISLD-LNX3345.00]	AMP	12172.5	-84.94	
659131	[LARAMIE3	345.00]	AMP	7380.5	-87.77
659133	[SIDNEY 3	345.00]	AMP	6661.7	-85.93
659134	[SIDNEY 4	230.00]	AMP	6487.2	-85.65
659135	[STEGALL3	345.00]	AMP	5083.0	-86.12
659206	[STGXFMR4	230.00]	AMP	5548.1	-86.35
659210	[SIDXFMR4	230.00]	AMP	7009.1	-86.17
659425	[SIDNEY1-LNX3345.00]	AMP	6661.7	-85.93	
659426	[SIDNEY2-LNX3345.00]	AMP	6661.7	-85.93	
659800	[GRANTNB7	115.00]	AMP	6284.5	-79.06
659801	[OGALALA7	115.00]	AMP	15003.1	-85.04
659809	[ROSCOE 7	115.00]	AMP	6368.8	-80.70
659810	[SPCREEK7	115.00]	AMP	4356.2	-77.69
659817	[COLTON 7	115.00]	AMP	3675.6	-81.01
659824	[MCONGHY7	115.00]	AMP	5391.3	-77.29

11.6.2 GEN-2018-066 2026S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS

FRI, FEB 22 2019 18:28

2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL

MDWG 2026S WITH MMWG 2026S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING

ADMITTANCE=0.0 IN +/-0 SEQUENCES

- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

THREE PHASE FAULT

	X----- BUS -----X		/I+ /	AN(I+)
90661	[G18066_SUB 345.00]	AMP	19229.6	-87.10
523853	[FINNEY 7345.00]	AMP	10350.7	-85.83
530554	[ATWOOD 3 115.00]	AMP	3010.9	-72.47
530555	[COLBY 3 115.00]	AMP	6091.5	-80.52
530559	[PH RUN 3 115.00]	AMP	4527.9	-77.67
530583	[POSTROCK7 345.00]	AMP	7939.0	-84.56
530584	[POSTROCK6 230.00]	AMP	10921.2	-84.69
530644	[COLBY 2 69.000]	AMP	3959.3	-84.96
530682	[SEGNTP 3 115.00]	AMP	4290.4	-75.22
530683	[SEGUIN 3 115.00]	AMP	4080.3	-76.43
531351	[BREWSTR3 115.00]	AMP	3105.5	-76.74
531353	[GOODLND3 115.00]	AMP	2657.0	-75.63
531412	[GRINNEL3 115.00]	AMP	3704.9	-77.20
531416	[CTYSERT3 115.00]	AMP	9994.3	-84.65
531429	[MINGO 3 115.00]	AMP	12566.4	-85.48
531433	[SCOTCTY3 115.00]	AMP	9000.7	-83.71
531448	[HOLCOMB3 115.00]	AMP	22418.4	-87.43
531449	[HOLCOMB7 345.00]	AMP	10443.2	-85.85
531451	[MINGO 7 345.00]	AMP	6306.4	-84.95
531464	[SETAB 3 115.00]	AMP	10640.1	-85.38
531465	[SETAB 7 345.00]	AMP	7160.9	-85.27
531501	[BUCKNER7 345.00]	AMP	9451.5	-84.99
560062	[G15-088-TAP 345.00]	AMP	11061.9	-85.12
560075	[G16-023-TAP 345.00]	AMP	5949.4	-87.12
560082	[G16-050-TAP 345.00]	AMP	7004.5	-84.86
560090	[G16-034-TAP 345.00]	AMP	6105.7	-86.40
560134	[ROSEMONT 115.00]	AMP	6338.4	-73.74
562334	[G13-010-TAP 345.00]	AMP	7621.8	-84.35
584650	[GEN-2015-023345.00]	AMP	6861.3	-85.83
585020	[GEN-2015-064115.00]	AMP	9893.5	-84.16
585030	[GEN-2015-065345.00]	AMP	5756.7	-84.82
587090	[GEN-2016-023345.00]	AMP	4991.8	-86.72
587190	[GEN-2016-029345.00]	AMP	4991.8	-86.72
587220	[GEN-2016-034345.00]	AMP	6105.7	-86.40
587350	[GEN-2016-050345.00]	AMP	6293.1	-84.77
587450	[GEN-2016-067345.00]	AMP	5756.7	-84.82
587680	[GEN-2016-074345.00]	AMP	6484.4	-84.20
587780	[GEN-2016-096345.00]	AMP	9240.9	-85.01
587784	[G16-096-TAP 345.00]	AMP	9263.3	-85.04
587850	[GEN-2016-106345.00]	AMP	8985.3	-85.51
587874	[G16-110-TAP 345.00]	AMP	6459.3	-87.32
588220	[GEN-2016-147115.00]	AMP	4096.1	-83.74
588340	[GEN-2016-165345.00]	AMP	5813.0	-85.91
588344	[G16-165-TAP 345.00]	AMP	6869.5	-86.11
640050	[AINSWND7 115.00]	AMP	3697.9	-76.25
640051	[AINSWRT7 115.00]	AMP	3405.1	-74.74
640063	[AURORA_7 115.00]	AMP	6981.5	-79.50
640065	[AXTELL 3 345.00]	AMP	9456.9	-84.80

640066	[AXTELL 7	115.00]	AMP	14153.5	-84.48
640082	[BEVERLY7	115.00]	AMP	4739.7	-80.86
640083	[BEVERLY8	69.000]	AMP	4294.9	-83.97
640089	[BROKENB7	115.00]	AMP	5512.6	-78.76
640091	[BRULE 7	115.00]	AMP	5415.8	-76.57
640093	[C.CREEK4	230.00]	AMP	7070.5	-83.34
640094	[C.CREEK7	115.00]	AMP	7171.2	-84.75
640096	[CALAMS 7	115.00]	AMP	3402.8	-75.02
640098	[CALAWAY7	115.00]	AMP	3852.7	-74.87
640100	[CAMBRIG7	115.00]	AMP	4148.3	-77.26
640101	[CAMBRIG8	69.000]	AMP	2214.5	-82.54
640102	[CANADAY4	230.00]	AMP	6224.0	-83.40
640103	[CANADAY7	115.00]	AMP	13774.8	-81.89
640107	[CENCITY7	115.00]	AMP	5067.5	-73.09
640131	[COLMB.W4	230.00]	AMP	9632.8	-84.31
640133	[COLMBUS4	230.00]	AMP	11177.2	-84.75
640139	[COOPER 3	345.00]	AMP	26720.7	-85.93
640161	[ELMCRK_7	115.00]	AMP	5904.0	-74.49
640167	[ENDERS 7	115.00]	AMP	3737.2	-77.75
640168	[ENDERS 8	69.000]	AMP	3019.7	-83.26
640178	[GENEVA 7	115.00]	AMP	10002.7	-79.10
640183	[GENTLMN3	345.00]	AMP	19229.6	-87.10
640184	[GENTLMN4	230.00]	AMP	20371.2	-87.29
640194	[GOSPER 7	115.00]	AMP	4331.9	-77.24
640196	[GOTHNBG7	115.00]	AMP	4286.1	-74.95
640200	[GR ISLD4	230.00]	AMP	16762.4	-84.98
640201	[GR ISLD7	115.00]	AMP	23588.1	-84.18
640214	[HASTING4	230.00]	AMP	7303.3	-84.58
640215	[HASTING7	115.00]	AMP	19203.6	-82.72
640222	[HILDRTH7	115.00]	AMP	4195.0	-75.92
640224	[HOLDREG7	115.00]	AMP	6029.9	-78.69
640238	[JEFFREY7	115.00]	AMP	5966.2	-78.97
640240	[JOHN.1 7	115.00]	AMP	8234.3	-77.24
640242	[JOHN.2 7	115.00]	AMP	12568.6	-80.32
640248	[KEAR.NE7	115.00]	AMP	9059.3	-80.15
640250	[KEARNEY7	115.00]	AMP	11618.5	-80.89
640252	[KEYSTON3	345.00]	AMP	12281.2	-86.35
640253	[KEYSTON7	115.00]	AMP	15523.2	-86.47
640255	[KINGSLY7	115.00]	AMP	9307.2	-82.49
640261	[LOWELL 7	115.00]	AMP	8010.2	-77.62
640265	[MALONEY7	115.00]	AMP	11279.0	-80.01
640267	[MAXWELS7	115.00]	AMP	6644.7	-81.35
640269	[MCCOOK 7	115.00]	AMP	8742.8	-80.30
640270	[MCCOOK 8	69.000]	AMP	4439.3	-84.86
640271	[MCCOOL 3	345.00]	AMP	10360.5	-84.54
640272	[MCCOOL 7	115.00]	AMP	14091.3	-84.06
640273	[MCCOOL	869.000]	AMP	5464.6	-87.20
640275	[MINDEN 7	115.00]	AMP	7096.9	-80.47
640277	[MOORE 3	345.00]	AMP	21442.9	-85.29

Southwest Power Pool, Inc.

640278	[SHELDON7	115.00]	AMP	32483.1	-85.36
640286	[N.PLATT4	230.00]	AMP	13445.9	-84.73
640287	[N.PLATT7	115.00]	AMP	18633.4	-84.70
640288	[N.PLATT8	69.000]	AMP	4913.1	-87.38
640302	[OGALALA4	230.00]	AMP	7871.8	-84.95
640304	[OGALALANPPD7	115.00]	AMP	15055.2	-85.03
640310	[ORLEANS7	115.00]	AMP	2351.1	-70.63
640312	[PAULINE3	345.00]	AMP	8068.4	-84.33
640313	[PAULINE7	115.00]	AMP	16244.0	-81.77
640314	[PAULINE8	69.000]	AMP	4713.6	-86.90
640325	[REDWILO3	345.00]	AMP	6470.1	-84.59
640326	[REDWILO7	115.00]	AMP	11379.3	-81.42
640330	[RIVERDL4	230.00]	AMP	7036.8	-83.19
640331	[RIVERDL7	115.00]	AMP	11888.3	-81.57
640353	[ST.LIB 7	115.00]	AMP	9687.3	-76.43
640359	[STAPLETON	7115.00]	AMP	4144.6	-82.08
640360	[STAPLETON	869.000]	AMP	3167.1	-85.22
640365	[STOCKVL7	115.00]	AMP	4505.9	-74.61
640366	[STOCKVL8	69.000]	AMP	3262.3	-82.21
640370	[SUTHLND7	115.00]	AMP	5429.9	-77.11
640374	[SWEET W3	345.00]	AMP	11019.1	-85.24
640381	[THEDFRD7	115.00]	AMP	9201.0	-85.46
640383	[TOWER 7	115.00]	AMP	8751.6	-81.62
640413	[YORK SW7	115.00]	AMP	8025.2	-80.34
640448	[HOLDREGE	869.000]	AMP	5416.9	-82.92
640500	[THEDFORD3	345.00]	AMP	5824.9	-85.05
640510	[HOLT.CO3	345.00]	AMP	7480.0	-85.91
640530	[STEGALL7	115.00]	AMP	7998.7	-86.70
641088	[HASTCTY7	115.00]	AMP	19203.6	-82.72
641244	[ATHEY 7	115.00]	AMP	3046.8	-77.22
642071	[SUB-D 7	115.00]	AMP	17612.5	-81.04
642072	[SUB-E 7	115.00]	AMP	17512.7	-83.52
650114	[NW68HOLDRG3	345.00]	AMP	16555.5	-85.04
650189	[103&ROKEBY3	345.00]	AMP	19819.0	-85.12
652532	[GR PRAIRIE	3345.00]	AMP	6840.4	-86.12
652832	[GRPRAR1-LNX3345.00]		AMP	6840.4	-86.12
653571	[GR ISLD3	345.00]	AMP	12351.0	-85.03
653572	[SIDNEY 7	115.00]	AMP	4198.7	-84.21
653871	[GR ISLD-LNX3345.00]		AMP	12351.0	-85.03
659131	[LARAMIE3	345.00]	AMP	7383.8	-87.77
659133	[SIDNEY 3	345.00]	AMP	6672.4	-85.92
659134	[SIDNEY 4	230.00]	AMP	6495.4	-85.64
659135	[STEGALL3	345.00]	AMP	5086.0	-86.11
659206	[STGXFMR4	230.00]	AMP	5550.4	-86.35
659210	[SIDXFMR4	230.00]	AMP	7018.2	-86.17
659425	[SIDNEY1-LNX3345.00]		AMP	6672.4	-85.92
659426	[SIDNEY2-LNX3345.00]		AMP	6672.4	-85.92
659800	[GRANTNB7	115.00]	AMP	6309.3	-79.05
659801	[OGALALA7	115.00]	AMP	15055.2	-85.03

659809	[ROSCOE 7	115.00]	AMP	6378.2	-80.69
659810	[SPCREEK7	115.00]	AMP	4370.5	-77.68
659817	[COLTON 7	115.00]	AMP	3677.2	-81.01
659824	[MCONGHY7	115.00]	AMP	5397.9	-77.27

11.6.3 GEN-2018-075P 2018S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS MON, MAR 04 2019 14:11

2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL

MDWG 2018S WITH MMWG 2017S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

THREE PHASE FAULT

X----- BUS -----X /I+/ AN(I+)

90750 [G18075-PSUB 345.00] AMP 7120.8 -85.60

90753 [G18075-SUB 115.00] AMP 29225.6 -86.23

90781 [G18-078-TAP 345.00] AMP 7450.5 -85.56

Southwest Power Pool, Inc.

523961 [POTTER_CO 7345.00] AMP 11552.6 -86.04
524875 [OASIS 6230.00] AMP 7529.8 -81.81
524885 [SN_JUAN_TAP6230.00] AMP 4866.8 -83.10
524889 [SN_JUAN_WND6230.00] AMP 4652.3 -83.15
525543 [TOLK_TAP 6230.00] AMP 31540.5 -86.23
525549 [TOLK 7345.00] AMP 16481.0 -86.46
526460 [AMOCO_SS 6230.00] AMP 9626.8 -82.34
526934 [YOAKUM 3115.00] AMP 15871.0 -82.29
526935 [YOAKUM 6230.00] AMP 14269.7 -83.96
527009 [BRU_SUB 6230.00] AMP 12119.8 -83.95
527149 [MUSTANG 6230.00] AMP 14094.1 -85.35
527363 [HIGG 3115.00] AMP 10124.1 -74.43
527455 [RSWL_SLRCOL3115.00] AMP 7142.0 -83.75
527470 [CHVS_SLRCOL3115.00] AMP 6820.8 -83.63
527482 [CHAVES_CNTY3115.00] AMP 7216.4 -83.78
527483 [CHAVES_CNTY6230.00] AMP 4596.5 -82.68
527501 [URTON 3115.00] AMP 5954.9 -81.66
527509 [PRICE_TAP 3115.00] AMP 5490.5 -81.75
527546 [SAMSON 3115.00] AMP 5607.0 -80.97
527564 [ROSWLL_INT 3115.00] AMP 5872.4 -81.21
527597 [TWEEDY 3115.00] AMP 5402.3 -80.55
527654 [RSVLT_CC_W 7345.00] AMP 7686.3 -85.10
527655 [RSVLT_CC_E 7345.00] AMP 8723.8 -85.23
527656 [CROSSROADS 7345.00] AMP 9932.2 -85.39
527707 [ARTESIA 3115.00] AMP 7133.2 -79.48

Southwest Power Pool, Inc.

527710 [EAGLE_CREEK269.000] AMP 2345.7 -86.41
527711 [EAGLE_CREEK3115.00] AMP 7792.4 -79.74
527715 [NAVAJO_2TP 3115.00] AMP 7407.2 -79.43
527736 [NAVAJO_5TP 3115.00] AMP 7362.1 -79.39
527786 [ATOKA 3115.00] AMP 7463.9 -79.34
527793 [EDDY_STH 3115.00] AMP 12456.0 -84.04
527798 [EDDY_NTH 3115.00] AMP 12456.0 -84.04
527799 [EDDY_NORTH 6230.00] AMP 10079.1 -84.91
527802 [EDDY_CNTY 7345.00] AMP 8343.4 -85.59
527809 [CV-8_MILE 3115.00] AMP 5575.0 -84.56
527821 [CV-DAYTON +3115.00] AMP 7362.4 -79.22
527822 [CV-TURKYTRK3115.00] AMP 3515.4 -81.03
527864 [CUNNINHAM 3115.00] AMP 27134.8 -83.61
527865 [CUNNIGHM_N 6230.00] AMP 17042.9 -86.60
527867 [CUNNIGHM_S 6230.00] AMP 17042.9 -86.60
527891 [HOBBS_INT 3115.00] AMP 30781.7 -85.44
527894 [HOBBS_INT 6230.00] AMP 18311.7 -86.90
527896 [HOBBS_INT 7345.00] AMP 8984.5 -86.94
527929 [PCA 269.000] AMP 6400.0 -83.12
527930 [PCA 3115.00] AMP 11898.6 -79.55
527935 [CV-SKELLY 3115.00] AMP 3272.7 -80.40
527938 [CV-MALJAMAR3115.00] AMP 2892.6 -80.44
527943 [CV-LUSK 269.000] AMP 2262.7 -64.77
527947 [CV-LUSK 3115.00] AMP 3519.4 -80.38
527948 [CV-LUSK_TP 3115.00] AMP 4274.5 -80.30

Southwest Power Pool, Inc.

527952 [LIVSTNRIDGE269.000] AMP 2058.8 -67.81
527953 [LIVSTNRIDGE3115.00] AMP 8060.0 -77.88
527955 [SAGE_BRUSH 3115.00] AMP 5343.5 -77.54
527961 [POTASH_JCT 269.000] AMP 9153.7 -86.43
527962 [POTASH_JCT 3115.00] AMP 16687.1 -83.95
527963 [POTASH_JCT 6230.00] AMP 7584.4 -84.39
527965 [KIOWA 7345.00] AMP 9741.9 -86.23
527980 [DUVAL_#1 269.000] AMP 5920.4 -77.75
527989 [NMPOTASH 269.000] AMP 2573.1 -69.12
527996 [KERMAC 269.000] AMP 2996.6 -70.20
527999 [INTREPDW_TP3115.00] AMP 13814.3 -81.76
528000 [INTREPIDWST3115.00] AMP 11650.3 -80.38
528009 [WIPP 3115.00] AMP 7553.7 -77.46
528016 [SAND_DUNES 3115.00] AMP 7459.1 -77.40
528018 [RED_BLUFF 3115.00] AMP 9702.1 -79.34
528019 [NEWSUB1_7 345.00] AMP 7120.8 -85.60
528020 [BOPCO_PKRLK3115.00] AMP 13343.3 -85.08
528022 [MISSCHEM#2 269.000] AMP 6940.2 -83.27
528025 [RDRUNNER 3115.00] AMP 11094.5 -83.59
528027 [RDRUNNER 7345.00] AMP 7039.5 -85.52
528029 [IMC_#2 269.000] AMP 4345.2 -79.60
528035 [IMC_#1_TP 3115.00] AMP 9868.5 -78.87
528037 [IMC_#1 3115.00] AMP 8787.6 -78.26
528040 [BATTLE_AXE 3115.00] AMP 3039.2 -78.44
528043 [UNITEDSALT 269.000] AMP 4165.7 -79.35

Southwest Power Pool, Inc.

528070 [CV-AZMESA 3115.00] AMP 7704.8 -79.11
528076 [CV-WALTCYN 3115.00] AMP 4632.2 -76.50
528093 [7-RIVERS 269.000] AMP 2413.9 -86.38
528094 [7-RIVERS 3115.00] AMP 8675.8 -81.56
528095 [7-RIVERS 6230.00] AMP 6629.8 -83.43
528109 [CV-LAKEWOOD3115.00] AMP 6675.2 -78.82
528132 [OCOTILLO 3115.00] AMP 6337.7 -72.87
528137 [N_CANAL 3115.00] AMP 9012.8 -78.32
528145 [NATPOT_TP 269.000] AMP 9102.9 -86.34
528151 [FIESTA 3115.00] AMP 10179.9 -78.32
528159 [CARLSBAD 269.000] AMP 4924.9 -85.57
528160 [CARLSBAD 3115.00] AMP 11795.8 -79.12
528178 [PECOS 3115.00] AMP 12478.3 -80.32
528179 [PECOS 6230.00] AMP 6853.1 -83.79
528182 [NORTH_LOVNG3115.00] AMP 10490.4 -85.01
528185 [N_LOVING 7345.00] AMP 7301.2 -85.64
528190 [S_LOVING_TP269.000] AMP 3015.7 -80.48
528197 [CB_WTRFLDTP269.000] AMP 2644.4 -75.82
528218 [SLOV&NAVMAL269.000] AMP 1771.4 -68.10
528222 [CHINA_DRAW 3115.00] AMP 9904.0 -84.90
528223 [CHINA_DRAW 7345.00] AMP 6680.2 -85.49
528226 [HOPI_SUB 3115.00] AMP 7152.3 -79.78
528228 [WOOD_DRAW 3115.00] AMP 7654.9 -79.77
528230 [AGAVE_RHILL3115.00] AMP 10569.3 -82.86
528232 [OCHOA 3115.00] AMP 10343.3 -82.55

Southwest Power Pool, Inc.

528235 [WOLFCAMP_TP3115.00] AMP 11852.0 -83.03
528236 [WOLFCAMP 3115.00] AMP 10965.7 -82.87
528239 [PNDEROSATP 3115.00] AMP 7327.3 -78.46
528333 [LE-WEST_SUB3115.00] AMP 8354.8 -81.30
528334 [LE-NRTH_INT3115.00] AMP 8277.6 -81.21
528348 [BUCKEYE_TP 3115.00] AMP 8185.4 -81.57
528353 [MADDOXG23 3115.00] AMP 25680.9 -84.47
528355 [MADDOX 3115.00] AMP 25680.9 -84.47
528392 [PEARLE 3115.00] AMP 6333.7 -73.63
528394 [QUAHADA 3115.00] AMP 8268.2 -76.53
528396 [XTO_LOAD#4 115.00] AMP 9075.9 -77.85
528399 [LEA_NATIONL3115.00] AMP 6935.7 -75.12
528422 [DCP_ZIA TP 3115.00] AMP 7144.3 -75.71
528433 [BENSING 3115.00] AMP 7960.8 -73.44
528435 [MILLEN 3115.00] AMP 11443.8 -73.86
528442 [NE_HOBBS 3115.00] AMP 11739.7 -74.63
528463 [SANGER_SW 3115.00] AMP 15606.2 -80.10
528491 [MONUMENT 3115.00] AMP 15226.6 -81.83
528568 [MONUMNT_TP 3115.00] AMP 9969.4 -76.47
528602 [ANDREWS 3115.00] AMP 12812.7 -84.03
528603 [NA_ENRICH 3115.00] AMP 12154.3 -82.69
528604 [ANDREWS 6345.00] AMP 6471.8 -85.44
528610 [GAINES_GEN 6230.00] AMP 9057.7 -85.97
528611 [GAINESGENTP6345.00] AMP 7085.6 -85.89
560022 [CRAWFISH_DR 345.00] AMP 22816.8 -86.35

560059 [G1579&G1580T230.00] AMP 9133.8 -83.33
562480 [G13-027-TAP 230.00] AMP 9467.4 -82.97
583960 [G14034G14035115.00] AMP 6786.0 -83.59
584940 [GEN-2015-056345.00] AMP 7956.7 -85.13
585160 [G1579&G1580 230.00] AMP 8671.0 -83.21
587110 [GEN-2016-015345.00] AMP 6187.0 -85.02
587420 [GEN-2016-062345.00] AMP 5071.6 -85.18
587470 [GEN-2016-069115.00] AMP 6964.2 -83.74
587670 [GEN-2015-099115.00] AMP 16593.1 -80.67
587990 [GEN-2016-121115.00] AMP 10402.7 -82.44
588000 [GEN-2016-123345.00] AMP 9751.0 -85.37
588350 [GEN-2016-171230.00] AMP 8904.4 -83.28
588430 [GEN-2016-169345.00] AMP 8752.3 -86.75
599960 [EPTNP-D6 230.00] AMP 10079.1 -84.91

11.6.4 GEN-2018-075P 2026S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS MON, MAR 04 2019 14:11

2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL

MDWG 2026S WITH MMWG 2026S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES

- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

THREE PHASE FAULT

X----- BUS -----X /I+/ AN(I+)

90750 [G18075-PSUB 345.00] AMP 7354.5 -85.54

90753 [G18075-SUB 115.00] AMP 30956.9 -86.06

90781 [G18-078-TAP 345.00] AMP 7472.0 -85.54

511456 [O.K.U.-7 345.00] AMP 5566.0 -84.56

515458 [BORDER 7345.00] AMP 12592.3 -85.75

523961 [POTTER_CO 7345.00] AMP 11441.3 -86.00

524875 [OASIS 6230.00] AMP 7535.1 -81.81

524885 [SN_JUAN_TAP6230.00] AMP 4863.8 -83.11

524889 [SN_JUAN_WND6230.00] AMP 4649.7 -83.16

525524 [TOLK_EAST 6230.00] AMP 31018.0 -86.15

525531 [TOLK_WEST 6230.00] AMP 31018.0 -86.15

525543 [TOLK_TAP 6230.00] AMP 31018.0 -86.15

525549 [TOLK 7345.00] AMP 16386.1 -86.42

525828 [TUCO_INT 3115.00] AMP 21383.1 -83.62

525830 [TUCO_INT 6230.00] AMP 30777.5 -85.94

525832 [TUCO_INT 7345.00] AMP 23933.5 -86.34

525840 [ANTELOPE_1 6230.00] AMP 30428.1 -85.94

Southwest Power Pool, Inc.

525850 [ELK_CT1 345.00] AMP 23476.6 -86.30
525957 [HALE_WNDCL16230.00] AMP 10033.4 -84.28
526161 [CARLISLE 6230.00] AMP 14547.7 -83.80
526337 [JONES 6230.00] AMP 22086.1 -85.95
526435 [SUNDOWN 6230.00] AMP 11293.1 -82.45
526460 [AMOCO_SS 6230.00] AMP 9887.4 -82.42
526784 [AMOCOWASSON6230.00] AMP 14109.8 -84.89
526792 [PRENTICE 3115.00] AMP 5910.1 -75.52
526928 [PLAINS_INT 3115.00] AMP 9838.2 -78.12
526934 [YOAKUM 3115.00] AMP 16876.5 -82.87
526935 [YOAKUM 6230.00] AMP 18208.3 -85.07
526936 [YOAKUM_345 345.00] AMP 9935.8 -86.23
527009 [BRU_SUB 6230.00] AMP 14266.7 -84.51
527010 [OXYBRU 6230.00] AMP 14145.2 -84.49
527041 [ARCO_TP 3115.00] AMP 13074.2 -78.94
527146 [MUSTANG 3115.00] AMP 22483.9 -84.20
527149 [MUSTANG 6230.00] AMP 15893.7 -85.66
527151 [GS-MUSTANG 6230.00] AMP 15893.7 -85.66
527194 [LG-PLSHILL 3115.00] AMP 7543.6 -76.21
527276 [SEMINOLE 6230.00] AMP 7303.7 -82.58
527363 [HIGG 3115.00] AMP 10158.0 -74.43
527455 [RSWL_SLRCOL3115.00] AMP 7140.6 -83.75
527470 [CHVS_SLRCOL3115.00] AMP 6819.5 -83.63
527482 [CHAVES_CNTY3115.00] AMP 7215.0 -83.78
527483 [CHAVES_CNTY6230.00] AMP 4594.8 -82.68

Southwest Power Pool, Inc.

527501 [URTON 3115.00] AMP 5958.9 -81.66
527509 [PRICE_TAP 3115.00] AMP 5489.6 -81.75
527546 [SAMSON 3115.00] AMP 5608.4 -80.98
527564 [ROSWLL_INT 3115.00] AMP 5877.5 -81.22
527597 [TWEEDY 3115.00] AMP 5406.3 -80.56
527654 [RSVLT_CC_W 7345.00] AMP 7674.0 -85.11
527655 [RSVLT_CC_E 7345.00] AMP 8707.3 -85.23
527656 [CROSSROADS 7345.00] AMP 9909.8 -85.39
527707 [ARTESIA 3115.00] AMP 7139.4 -79.46
527710 [EAGLE_CREEK269.000] AMP 2346.1 -86.41
527711 [EAGLE_CREEK3115.00] AMP 7799.8 -79.73
527715 [NAVAJO_2TP 3115.00] AMP 7413.9 -79.42
527736 [NAVAJO_5TP 3115.00] AMP 7368.7 -79.38
527786 [ATOKA 3115.00] AMP 7470.7 -79.32
527793 [EDDY_STH 3115.00] AMP 12475.1 -84.03
527798 [EDDY_NTH 3115.00] AMP 12475.1 -84.03
527799 [EDDY_NORTH 6230.00] AMP 10100.4 -84.91
527802 [EDDY_CNTY 7345.00] AMP 8500.3 -85.50
527809 [CV-8_MILE 3115.00] AMP 5578.8 -84.56
527821 [CV-DAYTON +3115.00] AMP 7369.1 -79.21
527822 [CV-TURKYTRK3115.00] AMP 3516.9 -81.02
527864 [CUNNINGHAM 3115.00] AMP 26982.7 -83.58
527865 [CUNNINGHAM_N 6230.00] AMP 15292.7 -86.14
527867 [CUNNINGHAM_S 6230.00] AMP 15292.7 -86.14
527891 [HOBBS_INT 3115.00] AMP 30592.8 -85.38

Southwest Power Pool, Inc.

527894 [HOBBS_INT 6230.00] AMP 17524.3 -86.86
527896 [HOBBS_INT 7345.00] AMP 11339.1 -86.66
527929 [PCA 269.000] AMP 6416.9 -83.12
527930 [PCA 3115.00] AMP 11973.8 -79.51
527935 [CV-SKELLY 3115.00] AMP 3278.4 -80.39
527938 [CV-MALJAMAR3115.00] AMP 2897.0 -80.43
527943 [CV-LUSK 269.000] AMP 2264.7 -64.75
527947 [CV-LUSK 3115.00] AMP 3526.0 -80.37
527948 [CV-LUSK_TP 3115.00] AMP 4284.2 -80.29
527953 [LIVSTNRIDGE3115.00] AMP 8183.2 -78.33
527955 [SAGE_BRUSH 3115.00] AMP 5406.6 -78.13
527961 [POTASH_JCT 269.000] AMP 9190.3 -86.44
527962 [POTASH_JCT 3115.00] AMP 16903.8 -83.96
527963 [POTASH_JCT 6230.00] AMP 7528.3 -84.41
527965 [KIOWA 7345.00] AMP 10319.0 -86.06
527980 [DUVAL_#1 269.000] AMP 5935.6 -77.73
527989 [NMPOTASH 269.000] AMP 2575.9 -69.11
527996 [KERMAC 269.000] AMP 3000.4 -70.18
527999 [INTREPDW_TP3115.00] AMP 14048.5 -82.33
528000 [INTREPIDWST3115.00] AMP 11818.9 -80.84
528009 [WIPP 3115.00] AMP 7657.6 -77.78
528016 [SAND_DUNES 3115.00] AMP 7553.4 -77.55
528018 [RED_BLUFF 3115.00] AMP 9854.0 -79.39
528019 [NEWSUB1_7 345.00] AMP 7354.5 -85.54
528020 [BOPCO_PKRLK3115.00] AMP 13618.2 -85.07

Southwest Power Pool, Inc.

528022 [MISSCHEM#2 269.000] AMP 6961.3 -83.27
528025 [RDRUNNER 3115.00] AMP 11313.6 -83.84
528027 [RDRUNNER 7345.00] AMP 7277.7 -85.47
528029 [IMC_#2 269.000] AMP 4353.4 -79.59
528035 [IMC_#1_TP 3115.00] AMP 10090.4 -79.99
528037 [IMC_#1 3115.00] AMP 8965.0 -79.25
528040 [BATTLE_AXE 3115.00] AMP 3055.6 -78.48
528043 [UNITEDSALT 269.000] AMP 4173.2 -79.34
528070 [CV-AZMESA 3115.00] AMP 7715.5 -79.09
528076 [CV-WALTCYN 3115.00] AMP 4636.0 -76.48
528093 [7-RIVERS 269.000] AMP 2414.3 -86.38
528094 [7-RIVERS 3115.00] AMP 8685.3 -81.54
528095 [7-RIVERS 6230.00] AMP 6628.9 -83.43
528109 [CV-LAKEWOOD3115.00] AMP 6680.6 -78.80
528132 [OCOTILLO 3115.00] AMP 6350.4 -72.82
528137 [N_CANAL 3115.00] AMP 9039.3 -78.28
528145 [NATPOT_TP 269.000] AMP 9139.0 -86.36
528151 [FIESTA 3115.00] AMP 10217.8 -78.27
528159 [CARLSBAD 269.000] AMP 4929.6 -85.56
528160 [CARLSBAD 3115.00] AMP 11846.9 -79.06
528178 [PECOS 3115.00] AMP 12529.7 -80.26
528179 [PECOS 6230.00] AMP 6836.2 -83.80
528182 [NORTH_LOVNG3115.00] AMP 10650.8 -84.98
528185 [N_LOVING 7345.00] AMP 7585.3 -85.52
528190 [S_LOVING_TP269.000] AMP 3017.4 -80.47

Southwest Power Pool, Inc.

528192 [SOUTH_LOVNG3115.00] AMP 7745.6 -82.61
528197 [CB_WTRFLDTP269.000] AMP 2645.7 -75.81
528218 [NAVAJOMALGA269.000] AMP 1771.9 -68.09
528222 [CHINA_DRAW 3115.00] AMP 10058.1 -84.87
528223 [CHINA_DRAW 7345.00] AMP 6899.6 -85.40
528226 [HOPI_SUB 3115.00] AMP 7193.7 -79.73
528228 [WOOD_DRAW 3115.00] AMP 7744.5 -79.69
528230 [AGAVE_RHILL3115.00] AMP 10771.6 -83.14
528232 [OCHOA 3115.00] AMP 10538.7 -82.84
528235 [WOLFCAMP_TP3115.00] AMP 12069.3 -83.00
528236 [WOLFCAMP 3115.00] AMP 11151.4 -82.84
528239 [PNDEROSATP 3115.00] AMP 7472.2 -79.39
528246 [YESO_HILLS 3115.00] AMP 2981.7 -78.85
528333 [LE-WEST_SUB3115.00] AMP 8349.8 -81.29
528334 [LE-NRTH_INT3115.00] AMP 8273.3 -81.20
528348 [BUCKEYE_TP 3115.00] AMP 8171.2 -81.57
528353 [MADDOXG23 3115.00] AMP 25768.7 -84.48
528355 [MADDOX 3115.00] AMP 25768.7 -84.48
528392 [PEARLE 3115.00] AMP 6337.2 -73.61
528394 [QUAHADA 3115.00] AMP 8279.5 -76.51
528396 [XTO_LOAD#4 115.00] AMP 9104.3 -77.82
528399 [LEA_NATIONL3115.00] AMP 6942.4 -75.10
528422 [DCP_ZIA TP 3115.00] AMP 7152.7 -75.69
528433 [BENSING 3115.00] AMP 7954.6 -73.44
528435 [MILLEN 3115.00] AMP 11435.1 -73.86

Southwest Power Pool, Inc.

528442 [NE_HOBBS 3115.00] AMP 11734.8 -74.63
528463 [SANGER_SW 3115.00] AMP 15626.6 -80.10
528491 [MONUMENT 3115.00] AMP 15272.7 -81.82
528568 [MONUMNT_TP 3115.00] AMP 10145.1 -78.57
528602 [ANDREWS 3115.00] AMP 13469.6 -84.32
528603 [NA_ENRICH 3115.00] AMP 12676.7 -83.06
528604 [ANDREWS 6345.00] AMP 7207.3 -85.20
528610 [GAINES_GEN 6230.00] AMP 9989.1 -85.72
528611 [GAINESGENTP6345.00] AMP 8044.2 -85.61
560021 [CRAWFISH_DR2230.00] AMP 25430.6 -85.41
560022 [CRAWFISH_DR 345.00] AMP 24496.0 -86.37
560059 [G1579&G1580T230.00] AMP 9180.7 -83.40
562480 [G13-027-TAP 230.00] AMP 9496.9 -82.98
583840 [GEN-2013-027230.00] AMP 8996.6 -83.10
583960 [G14034G14035115.00] AMP 6784.8 -83.59
584940 [GEN-2015-056345.00] AMP 7942.5 -85.13
585060 [GEN-2015-068345.00] AMP 16238.1 -85.78
585160 [G1579&G1580 230.00] AMP 8713.2 -83.27
587110 [GEN-2016-015345.00] AMP 6855.6 -84.75
587420 [GEN-2016-062345.00] AMP 5492.6 -84.97
587470 [GEN-2016-069115.00] AMP 6962.9 -83.74
587670 [GEN-2015-099115.00] AMP 16629.8 -80.66
587964 [G16-120-TAP 345.00] AMP 8593.2 -85.25
587990 [GEN-2016-121115.00] AMP 10596.0 -82.64
588000 [GEN-2016-123345.00] AMP 9729.7 -85.37

588350 [GEN-2016-171230.00] AMP 8948.9 -83.34

588430 [GEN-2016-169345.00] AMP 10971.4 -86.43

599960 [EPTNP-D6 230.00] AMP 10100.4 -84.91

11.6.5 GEN-2018-075S 2018S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS MON, MAR 04 2019 14:20
2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL
MDWG 2018S WITH MMWG 2017S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

THREE PHASE FAULT

X----- BUS -----X /I+/ AN(I+)
90753 [G18075-SUB 115.00] AMP 28679.7 -86.22
90757 [G18075-SSUB 345.00] AMP 5396.0 -85.71
90781 [G18-078-TAP 345.00] AMP 7432.1 -85.56
527799 [EDDY_NORTH 6230.00] AMP 10037.6 -84.89
527802 [EDDY_CNTY 7345.00] AMP 8276.7 -85.59
527894 [HOBBS_INT 6230.00] AMP 18265.0 -86.89
527896 [HOBBS_INT 7345.00] AMP 8934.2 -86.93
527930 [PCA 3115.00] AMP 11884.3 -79.51
527953 [LIVSTNRIDGE3115.00] AMP 8153.0 -77.76
527961 [POTASH_JCT 269.000] AMP 9149.1 -86.41
527962 [POTASH_JCT 3115.00] AMP 16660.9 -83.88
527963 [POTASH_JCT 6230.00] AMP 7570.8 -84.36
527965 [KIOWA 7345.00] AMP 9559.9 -86.22
527999 [INTREPDW_TP3115.00] AMP 13817.5 -81.70
528009 [WIPP 3115.00] AMP 7665.3 -77.32
528016 [SAND_DUNES 3115.00] AMP 7638.6 -77.21
528018 [RED_BLUFF 3115.00] AMP 10218.5 -79.08
528019 [NEWSUB1_7 345.00] AMP 6772.1 -85.63
528020 [BOPCO_PKRLK3115.00] AMP 16188.0 -85.71
528025 [RDRUNNER 3115.00] AMP 11165.2 -83.37
528027 [RDRUNNER 7345.00] AMP 6772.4 -85.54
528040 [BATTLE_AXE 3115.00] AMP 3044.1 -78.37
528160 [CARLSBAD 3115.00] AMP 11772.1 -79.10

528178 [PECOS 3115.00] AMP 12450.0 -80.30
528182 [NORTH_LOVNG3115.00] AMP 10428.0 -84.95
528185 [N_LOVING 7345.00] AMP 7152.7 -85.62
528222 [CHINA_DRAW 3115.00] AMP 9958.0 -84.75
528223 [CHINA_DRAW 7345.00] AMP 6496.6 -85.49
528226 [HOPI_SUB 3115.00] AMP 7135.5 -79.77
528228 [WOOD_DRAW 3115.00] AMP 8220.4 -79.46
528230 [AGAVE_RHILL3115.00] AMP 10631.2 -82.66
528232 [OCHOA 3115.00] AMP 10401.5 -82.35
528235 [WOLFCAMP_TP3115.00] AMP 13780.6 -83.14
528236 [WOLFCAMP 3115.00] AMP 12596.7 -82.95
528611 [GAINESGENTP6345.00] AMP 7064.3 -85.88
587990 [GEN-2016-121115.00] AMP 10464.1 -82.23
588430 [GEN-2016-169345.00] AMP 8704.5 -86.74

11.6.6 GEN-2018-075S 2026S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS MON, MAR 04 2019 14:20

2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL

MDWG 2026S WITH MMWG 2026S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

THREE PHASE FAULT

X----- BUS -----X /I+/ AN(I+)

90753 [G18075-SUB 115.00] AMP 30407.6 -86.05
90757 [G18075-SSUB 345.00] AMP 5504.9 -85.69
90781 [G18-078-TAP 345.00] AMP 7455.1 -85.54
526936 [YOAKUM_345 345.00] AMP 9922.4 -86.23
527799 [EDDY_NORTH 6230.00] AMP 10062.5 -84.89
527802 [EDDY_CNTY 7345.00] AMP 8437.7 -85.49
527894 [HOBBS_INT 6230.00] AMP 17486.5 -86.84
527896 [HOBBS_INT 7345.00] AMP 11286.6 -86.65
527930 [PCA 3115.00] AMP 11962.3 -79.48
527953 [LIVSTNRIDGE3115.00] AMP 8275.6 -78.20
527961 [POTASH_JCT 269.000] AMP 9186.8 -86.42
527962 [POTASH_JCT 3115.00] AMP 16883.9 -83.90
527963 [POTASH_JCT 6230.00] AMP 7516.6 -84.39
527965 [KIOWA 7345.00] AMP 10135.9 -86.05
527999 [INTREPDW_TP3115.00] AMP 14055.1 -82.27
528009 [WIPP 3115.00] AMP 7768.3 -77.63
528016 [SAND_DUNES 3115.00] AMP 7731.7 -77.36
528018 [RED_BLUFF 3115.00] AMP 10371.9 -79.12
528019 [NEWSUB1_7 345.00] AMP 7000.7 -85.56
528020 [BOPCO_PKRLK3115.00] AMP 16514.6 -85.69
528025 [RDRUNNER 3115.00] AMP 11388.1 -83.62
528027 [RDRUNNER 7345.00] AMP 7008.1 -85.48
528040 [BATTLE_AXE 3115.00] AMP 3060.7 -78.41
528160 [CARLSBAD 3115.00] AMP 11826.0 -79.04

528178 [PECOS 3115.00] AMP 12504.6 -80.24
528182 [NORTH_LOVNG3115.00] AMP 10592.7 -84.92
528185 [N_LOVING 7345.00] AMP 7438.0 -85.50
528192 [SOUTH_LOVNG3115.00] AMP 7714.6 -82.57
528222 [CHINA_DRAW 3115.00] AMP 10115.6 -84.72
528223 [CHINA_DRAW 7345.00] AMP 6716.2 -85.40
528226 [HOPI_SUB 3115.00] AMP 7178.5 -79.71
528228 [WOOD_DRAW 3115.00] AMP 8309.4 -79.38
528230 [AGAVE_RHILL3115.00] AMP 10836.7 -82.93
528232 [OCHOA 3115.00] AMP 10600.0 -82.64
528235 [WOLFCAMP_TP3115.00] AMP 14021.9 -83.10
528236 [WOLFCAMP 3115.00] AMP 12798.1 -82.91
528246 [YESO_HILLS 3115.00] AMP 2986.5 -78.80
528611 [GAINESGENTP6345.00] AMP 8026.6 -85.60
587990 [GEN-2016-121115.00] AMP 10660.5 -82.43
588430 [GEN-2016-169345.00] AMP 10922.3 -86.42

11.6.7 GEN-2018-075T 2018S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS

FRI, FEB 22 2019 18:26
2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL
MDWG 2018S WITH MMWG 2017S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/- SEQUENCES

- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

		THREE PHASE FAULT		
X-----	BUS -----X	/I+/-	AN(I+)	
90753	[G18075-SUB 115.00]	AMP	25442.4	-85.78
90781	[G18-078-TAP 345.00]	AMP	7297.9	-85.54
523961	[POTTER_CO 7345.00]	AMP	11551.4	-86.04
524875	[OASIS 6230.00]	AMP	7522.9	-81.81
524885	[SN_JUAN_TAP6230.00]	AMP	4854.3	-83.11
524889	[SN_JUAN_WND6230.00]	AMP	4641.4	-83.16
525543	[TOLK_TAP 6230.00]	AMP	31507.4	-86.23
525549	[TOLK 7345.00]	AMP	16455.4	-86.46
526460	[AMOCO_SS 6230.00]	AMP	9621.4	-82.34
526934	[YOAKUM 3115.00]	AMP	15853.0	-82.30
526935	[YOAKUM 6230.00]	AMP	14233.1	-83.98
527009	[BRU_SUB 6230.00]	AMP	12096.2	-83.97
527149	[MUSTANG 6230.00]	AMP	14068.6	-85.37
527363	[HIGG 3115.00]	AMP	10102.4	-74.48
527455	[RSWL_SLRCOL3115.00]	AMP	7092.2	-83.76
527470	[CHVS_SLRCOL3115.00]	AMP	6775.6	-83.65
527482	[CHAVES_CNTY3115.00]	AMP	7165.6	-83.79
527483	[CHAVES_CNTY6230.00]	AMP	4556.0	-82.70
527501	[URTON 3115.00]	AMP	5919.4	-81.68
527509	[PRICE_TAP 3115.00]	AMP	5460.5	-81.77
527546	[SAMSON 3115.00]	AMP	5574.6	-81.00
527564	[ROSWLL_INT 3115.00]	AMP	5836.0	-81.23
527597	[TWEEDY 3115.00]	AMP	5370.1	-80.57
527654	[RSVLT_CC_W 7345.00]	AMP	7652.9	-85.11
527655	[RSVLT_CC_E 7345.00]	AMP	8679.0	-85.23
527656	[CROSSROADS 7345.00]	AMP	9871.7	-85.39
527707	[ARTESIA 3115.00]	AMP	7024.6	-79.54
527710	[EAGLE_CREEK269.000]	AMP	2338.6	-86.40
527711	[EAGLE_CREEK3115.00]	AMP	7662.9	-79.80
527715	[NAVAJO_2TP 3115.00]	AMP	7290.2	-79.49
527736	[NAVAJO_5TP 3115.00]	AMP	7246.5	-79.46
527786	[ATOKA 3115.00]	AMP	7343.9	-79.41
527793	[EDDY_STH 3115.00]	AMP	12135.6	-84.03
527798	[EDDY_NTH 3115.00]	AMP	12135.6	-84.03
527799	[EDDY_NORTH 6230.00]	AMP	9677.1	-84.82
527802	[EDDY_CNTY 7345.00]	AMP	7811.4	-85.45
527809	[CV-8_MILE 3115.00]	AMP	5509.9	-84.55
527821	[CV-DAYTON +3115.00]	AMP	7246.0	-79.29
527822	[CV-TURKYTRK3115.00]	AMP	3489.5	-81.04
527864	[CUNNINGHAM 3115.00]	AMP	26723.7	-83.71
527865	[CUNNIGHM_N 6230.00]	AMP	16570.8	-86.61
527867	[CUNNIGHM_S 6230.00]	AMP	16570.8	-86.61
527891	[HOBBS_INT 3115.00]	AMP	30312.0	-85.53
527894	[HOBBS_INT 6230.00]	AMP	17761.9	-86.89

527896	[HOBBS_INT	7345.00]	AMP	8502.6	-86.89
527929	[PCA	269.000]	AMP	6323.2	-83.11
527930	[PCA	3115.00]	AMP	11514.1	-79.64
527935	[CV-SKELLY	3115.00]	AMP	3242.9	-80.42
527938	[CV-MALJAMAR	3115.00]	AMP	2869.3	-80.46
527943	[CV-LUSK	269.000]	AMP	2253.5	-64.84
527947	[CV-LUSK	3115.00]	AMP	3485.0	-80.40
527948	[CV-LUSK_TP	3115.00]	AMP	4223.8	-80.33
527952	[LIVSTNRIDGE	269.000]	AMP	2050.8	-67.87
527953	[LIVSTNRIDGE	3115.00]	AMP	7747.3	-78.02
527955	[SAGE_BRUSH	3115.00]	AMP	5239.0	-77.64
527961	[POTASH_JCT	269.000]	AMP	8992.9	-86.35
527962	[POTASH_JCT	3115.00]	AMP	15800.9	-83.83
527963	[POTASH_JCT	6230.00]	AMP	7350.0	-84.31
527965	[KIOWA	7345.00]	AMP	8480.8	-85.78
527980	[DUVAL_#1	269.000]	AMP	5852.6	-77.79
527989	[NMPOTASH	269.000]	AMP	2560.5	-69.18
527996	[KERMAC	269.000]	AMP	2979.4	-70.27
527999	[INTREPDW_TP	3115.00]	AMP	13176.0	-81.75
528000	[INTREPIDWST	3115.00]	AMP	11193.1	-80.43
528009	[WIPP	3115.00]	AMP	7247.7	-77.61
528016	[SAND_DUNES	3115.00]	AMP	7094.4	-77.55
528018	[RED_BLUFF	3115.00]	AMP	8931.8	-79.36
528019	[NEWSUB1_7	345.00]	AMP	5578.4	-84.62
528020	[BOPCO_PKRLK	3115.00]	AMP	11561.0	-84.34
528022	[MISSCHEM#2	269.000]	AMP	6847.1	-83.25
528025	[RDRUNNER	3115.00]	AMP	10108.8	-83.16
528027	[RDRUNNER	7345.00]	AMP	5686.3	-84.69
528029	[IMC_#2	269.000]	AMP	4308.5	-79.62
528035	[IMC_#1_TP	3115.00]	AMP	9499.4	-78.96
528037	[IMC_#1	3115.00]	AMP	8493.8	-78.36
528040	[BATTLE_AXE	3115.00]	AMP	2959.9	-78.44
528043	[UNITEDSALT	269.000]	AMP	4132.0	-79.37
528070	[CV-AZMESA	3115.00]	AMP	7562.4	-79.19
528076	[CV-WALTCYN	3115.00]	AMP	4580.6	-76.58
528093	[7-RIVERS	269.000]	AMP	2405.8	-86.37
528094	[7-RIVERS	3115.00]	AMP	8504.4	-81.60
528095	[7-RIVERS	6230.00]	AMP	6443.4	-83.41
528109	[CV-LAKEWOOD	3115.00]	AMP	6576.3	-78.89
528132	[OCOTILLO	3115.00]	AMP	6229.7	-73.05
528137	[N_CANAL	3115.00]	AMP	8793.1	-78.45
528145	[NATPOT_TP	269.000]	AMP	8943.8	-86.26
528151	[FIESTA	3115.00]	AMP	9898.6	-78.46
528159	[CARLSBAD	269.000]	AMP	4890.2	-85.56
528160	[CARLSBAD	3115.00]	AMP	11419.4	-79.25
528178	[PECOS	3115.00]	AMP	12060.2	-80.42
528179	[PECOS	6230.00]	AMP	6650.2	-83.73
528182	[NORTH_LOVNG	3115.00]	AMP	9803.7	-84.77
528185	[N_LOVING	7345.00]	AMP	6301.7	-85.13

528190	[S_LOVING_TP269.000]	AMP	3002.7	-80.50
528197	[CB_WTRFLDTP269.000]	AMP	2634.5	-75.85
528218	[SLOV&NAVMAL269.000]	AMP	1767.1	-68.14
528222	[CHINA_DRAW 3115.00]	AMP	9048.3	-84.54
528223	[CHINA_DRAW 7345.00]	AMP	5571.0	-84.81
528226	[HOPI_SUB 3115.00]	AMP	6943.0	-79.87
528228	[WOOD_DRAW 3115.00]	AMP	7059.7	-79.78
528230	[AGAVE_RHILL3115.00]	AMP	9690.0	-82.53
528232	[OCHOA 3115.00]	AMP	9508.4	-82.25
528235	[WOLFCAMP_TP3115.00]	AMP	10469.0	-82.62
528236	[WOLFCAMP 3115.00]	AMP	9771.2	-82.51
528239	[PNDEROSATP 3115.00]	AMP	7030.6	-78.48
528333	[LE-WEST_SUB3115.00]	AMP	8337.3	-81.32
528334	[LE-NRTH_INT3115.00]	AMP	8260.6	-81.23
528348	[BUCKEYE_TP 3115.00]	AMP	8150.4	-81.61
528353	[MADDOXG23 3115.00]	AMP	25339.9	-84.57
528355	[MADDOX 3115.00]	AMP	25339.9	-84.57
528392	[PEARLE 3115.00]	AMP	6298.0	-73.70
528394	[QUAHADA 3115.00]	AMP	8155.1	-76.62
528396	[XTO_LOAD#4 115.00]	AMP	8893.3	-77.95
528399	[LEA_NATIONL3115.00]	AMP	6862.9	-75.20
528422	[DCP_ZIA TP 3115.00]	AMP	7059.8	-75.79
528433	[BENSING 3115.00]	AMP	7939.8	-73.49
528435	[MILLEN 3115.00]	AMP	11382.6	-73.96
528442	[NE_HOBBS 3115.00]	AMP	11675.6	-74.73
528463	[SANGER_SW 3115.00]	AMP	15484.5	-80.19
528491	[MONUMENT 3115.00]	AMP	15094.3	-81.91
528568	[MONUMNT_TP 3115.00]	AMP	9881.0	-76.58
528602	[ANDREWS 3115.00]	AMP	12517.7	-84.08
528603	[NA_ENRICH 3115.00]	AMP	11884.3	-82.77
528604	[ANDREWS 6345.00]	AMP	6260.3	-85.48
528610	[GAINES_GEN 6230.00]	AMP	8800.2	-86.01
528611	[GAINESGENTP6345.00]	AMP	6830.2	-85.93
560022	[CRAWFISH_DR 345.00]	AMP	22811.8	-86.36
560059	[G1579&G1580T230.00]	AMP	9064.6	-83.37
562480	[G13-027-TAP 230.00]	AMP	9463.0	-82.98
583960	[G14034G14035115.00]	AMP	6741.0	-83.60
584940	[GEN-2015-056345.00]	AMP	7918.2	-85.14
585160	[G1579&G1580 230.00]	AMP	8608.6	-83.25
587110	[GEN-2016-015345.00]	AMP	5993.5	-85.08
587420	[GEN-2016-062345.00]	AMP	4946.1	-85.23
587470	[GEN-2016-069115.00]	AMP	6916.8	-83.75
587670	[GEN-2015-099115.00]	AMP	16451.5	-80.76
587990	[GEN-2016-121115.00]	AMP	9530.3	-82.13
588000	[GEN-2016-123345.00]	AMP	9693.4	-85.37
588350	[GEN-2016-171230.00]	AMP	8838.6	-83.31
588430	[GEN-2016-169345.00]	AMP	8294.3	-86.71
599960	[EPTNP-D6 230.00]	AMP	9677.1	-84.82

11.6.8 GEN-2018-075T 2026S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS

FRI, FEB 22 2019 18:26

2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL
MDWG 2026S WITH MMWG 2026S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES

- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

THREE PHASE FAULT			
X-----	BUS -----X	/I+/-	AN(I+)
90753	[G18075-SUB 115.00]	AMP 27185.1	-85.63
90781	[G18-078-TAP 345.00]	AMP 7331.8	-85.52
511456	[O.K.U.-7 345.00]	AMP 5565.8	-84.56
515458	[BORDER 7345.00]	AMP 12591.4	-85.75
523961	[POTTER_CO 7345.00]	AMP 11439.3	-86.00
524875	[OASIS 6230.00]	AMP 7527.1	-81.82
524885	[SN_JUAN_TAP6230.00]	AMP 4851.8	-83.12
524889	[SN_JUAN_WND6230.00]	AMP 4639.1	-83.17
525524	[TOLK_EAST 6230.00]	AMP 30968.1	-86.16
525531	[TOLK_WEST 6230.00]	AMP 30968.1	-86.16
525543	[TOLK_TAP 6230.00]	AMP 30968.1	-86.16
525549	[TOLK 7345.00]	AMP 16351.4	-86.43
525828	[TUCO_INT 3115.00]	AMP 21377.3	-83.63
525830	[TUCO_INT 6230.00]	AMP 30751.1	-85.94
525832	[TUCO_INT 7345.00]	AMP 23902.2	-86.35
525840	[ANTELOPE_1 6230.00]	AMP 30402.4	-85.94
525850	[ELK_CT1 345.00]	AMP 23446.4	-86.31
525957	[HALE_WNDCL16230.00]	AMP 10031.1	-84.28
526161	[CARLISLE 6230.00]	AMP 14542.1	-83.80
526337	[JONES 6230.00]	AMP 22079.5	-85.96
526435	[SUNDOWN 6230.00]	AMP 11279.7	-82.46
526460	[AMOCO_SS 6230.00]	AMP 9874.3	-82.43
526784	[AMOCOWASSON6230.00]	AMP 14047.5	-84.91
526792	[PRENTICE 3115.00]	AMP 5906.6	-75.53
526928	[PLAINS_INT 3115.00]	AMP 9825.3	-78.14
526934	[YOAKUM 3115.00]	AMP 16833.9	-82.88
526935	[YOAKUM 6230.00]	AMP 18065.1	-85.09
526936	[YOAKUM_345 345.00]	AMP 9796.6	-86.25
527009	[BRU_SUB 6230.00]	AMP 14190.4	-84.53

527010	[OXYBRU	6230.00]	AMP	14070.1	-84.51
527041	[ARCO_TP	3115.00]	AMP	13052.8	-78.96
527146	[MUSTANG	3115.00]	AMP	22430.4	-84.23
527149	[MUSTANG	6230.00]	AMP	15823.1	-85.68
527151	[GS-MUSTANG	6230.00]	AMP	15823.1	-85.68
527194	[LG-PLSHILL	3115.00]	AMP	7537.1	-76.23
527276	[SEMINOLE	6230.00]	AMP	7287.5	-82.60
527363	[HIGG	3115.00]	AMP	10133.0	-74.48
527455	[RSWL_SLRCOL	3115.00]	AMP	7094.6	-83.76
527470	[CHVS_SLRCOL	3115.00]	AMP	6777.8	-83.65
527482	[CHAVES_CNTY	3115.00]	AMP	7168.1	-83.79
527483	[CHAVES_CNTY	6230.00]	AMP	4557.3	-82.70
527501	[URTON	3115.00]	AMP	5926.0	-81.68
527509	[PRICE_TAP	3115.00]	AMP	5461.9	-81.77
527546	[SAMSON	3115.00]	AMP	5578.5	-81.00
527564	[ROSWLL_INT	3115.00]	AMP	5843.9	-81.24
527597	[TWEEDY	3115.00]	AMP	5376.6	-80.58
527654	[RSVLT_CC_W	7345.00]	AMP	7641.5	-85.11
527655	[RSVLT_CC_E	7345.00]	AMP	8663.6	-85.23
527656	[CROSSROADS	7345.00]	AMP	9851.0	-85.39
527707	[ARTESIA	3115.00]	AMP	7040.1	-79.52
527710	[EAGLE_CREEK	269.000]	AMP	2339.6	-86.40
527711	[EAGLE_CREEK	3115.00]	AMP	7681.4	-79.78
527715	[NAVAJO_2TP	3115.00]	AMP	7306.8	-79.47
527736	[NAVAJO_5TP	3115.00]	AMP	7262.9	-79.43
527786	[ATOKA	3115.00]	AMP	7361.0	-79.38
527793	[EDDY_STH	3115.00]	AMP	12181.5	-84.01
527798	[EDDY_NTH	3115.00]	AMP	12181.5	-84.01
527799	[EDDY_NORTH	6230.00]	AMP	9731.2	-84.82
527802	[EDDY_CNTY	7345.00]	AMP	8003.7	-85.36
527809	[CV-8_MILE	3115.00]	AMP	5519.3	-84.54
527821	[CV-DAYTON	+3115.00]	AMP	7262.5	-79.27
527822	[CV-TURKYTRK	3115.00]	AMP	3493.2	-81.04
527864	[CUNNINGHAM	3115.00]	AMP	26601.9	-83.65
527865	[CUNNINGHM_N	6230.00]	AMP	14908.5	-86.14
527867	[CUNNINGHM_S	6230.00]	AMP	14908.5	-86.14
527891	[HOBBS_INT	3115.00]	AMP	30158.8	-85.45
527894	[HOBBS_INT	6230.00]	AMP	17059.6	-86.85
527896	[HOBBS_INT	7345.00]	AMP	10826.7	-86.61
527929	[PCA	269.000]	AMP	6347.2	-83.11
527930	[PCA	3115.00]	AMP	11621.3	-79.59
527935	[CV-SKELLY	3115.00]	AMP	3251.4	-80.41
527938	[CV-MALJAMAR	3115.00]	AMP	2875.9	-80.45
527943	[CV-LUSK	269.000]	AMP	2256.3	-64.82
527947	[CV-LUSK	3115.00]	AMP	3494.7	-80.39
527948	[CV-LUSK_TP	3115.00]	AMP	4238.2	-80.31
527953	[LIVSTNRIDGE	3115.00]	AMP	7893.7	-78.46
527955	[SAGE_BRUSH	3115.00]	AMP	5314.1	-78.22
527961	[POTASH_JCT	269.000]	AMP	9044.2	-86.36

527962	[POTASH_JCT 3115.00]	AMP	16081.9	-83.84
527963	[POTASH_JCT 6230.00]	AMP	7314.2	-84.33
527965	[KIOWA 7345.00]	AMP	9061.7	-85.63
527980	[DUVAL_#1 269.000]	AMP	5874.3	-77.77
527989	[NMPOTASH 269.000]	AMP	2564.5	-69.16
527996	[KERMAC 269.000]	AMP	2984.9	-70.24
527999	[INTREPDW_TP3115.00]	AMP	13453.3	-82.30
528000	[INTREPIDWST3115.00]	AMP	11394.8	-80.87
528009	[WIPP 3115.00]	AMP	7373.7	-77.91
528016	[SAND_DUNES 3115.00]	AMP	7212.8	-77.69
528018	[RED_BLUFF 3115.00]	AMP	9122.1	-79.41
528019	[NEWSUB1_7 345.00]	AMP	5812.1	-84.59
528020	[BOPCO_PKRLK3115.00]	AMP	11887.7	-84.36
528022	[MISSCHEM#2 269.000]	AMP	6876.9	-83.25
528025	[RDRUNNER 3115.00]	AMP	10371.6	-83.43
528027	[RDRUNNER 7345.00]	AMP	5930.3	-84.67
528029	[IMC_#2 269.000]	AMP	4320.3	-79.61
528035	[IMC_#1_TP 3115.00]	AMP	9744.1	-80.05
528037	[IMC_#1 3115.00]	AMP	8690.7	-79.33
528040	[BATTLE_AXE 3115.00]	AMP	2982.2	-78.49
528043	[UNITEDSALT 269.000]	AMP	4142.8	-79.36
528070	[CV-AZMESA 3115.00]	AMP	7585.2	-79.16
528076	[CV-WALTCYN 3115.00]	AMP	4588.9	-76.55
528093	[7-RIVERS 269.000]	AMP	2406.9	-86.37
528094	[7-RIVERS 3115.00]	AMP	8528.4	-81.57
528095	[7-RIVERS 6230.00]	AMP	6458.1	-83.40
528109	[CV-LAKEWOOD3115.00]	AMP	6590.2	-78.86
528132	[OCOTILLO 3115.00]	AMP	6251.6	-72.99
528137	[N_CANAL 3115.00]	AMP	8837.9	-78.39
528145	[NATPOT_TP 269.000]	AMP	8994.5	-86.28
528151	[FIESTA 3115.00]	AMP	9959.8	-78.39
528159	[CARLSBAD 269.000]	AMP	4898.0	-85.55
528160	[CARLSBAD 3115.00]	AMP	11501.1	-79.18
528178	[PECOS 3115.00]	AMP	12145.2	-80.35
528179	[PECOS 6230.00]	AMP	6650.2	-83.75
528182	[NORTH_LOVNG3115.00]	AMP	10005.5	-84.75
528185	[N_LOVING 7345.00]	AMP	6602.7	-85.03
528190	[S_LOVING_TP269.000]	AMP	3005.6	-80.49
528192	[SOUTH_LOVNG3115.00]	AMP	7398.0	-82.54
528197	[CB_WTRFLDTP269.000]	AMP	2636.7	-75.84
528218	[NAVAJOMALGA269.000]	AMP	1768.0	-68.13
528222	[CHINA_DRAW 3115.00]	AMP	9243.3	-84.52
528223	[CHINA_DRAW 7345.00]	AMP	5803.5	-84.75
528226	[HOPI_SUB 3115.00]	AMP	7000.9	-79.81
528228	[WOOD_DRAW 3115.00]	AMP	7179.1	-79.71
528230	[AGAVE_RHILL3115.00]	AMP	9933.3	-82.82
528232	[OCHOA 3115.00]	AMP	9743.6	-82.56
528235	[WOLFCAMP_TP3115.00]	AMP	10734.9	-82.61
528236	[WOLFCAMP 3115.00]	AMP	10002.4	-82.50

528239	[PNDEROSATP 3115.00]	AMP	7195.4	-79.41
528246	[YESO_HILLS 3115.00]	AMP	2905.6	-78.89
528333	[LE-WEST_SUB3115.00]	AMP	8331.9	-81.31
528334	[LE-NRTH_INT3115.00]	AMP	8255.8	-81.22
528348	[BUCKEYE_TP 3115.00]	AMP	8138.3	-81.60
528353	[MADDOXG23 3115.00]	AMP	25452.1	-84.56
528355	[MADDOX 3115.00]	AMP	25452.1	-84.56
528392	[PEARLE 3115.00]	AMP	6304.4	-73.68
528394	[QUAHADA 3115.00]	AMP	8176.2	-76.58
528396	[XTO_LOAD#4 115.00]	AMP	8937.7	-77.90
528399	[LEA_NATIONL3115.00]	AMP	6875.9	-75.17
528422	[DCP_ZIA TP 3115.00]	AMP	7075.6	-75.76
528433	[BENSING 3115.00]	AMP	7933.2	-73.49
528435	[MILLEN 3115.00]	AMP	11377.5	-73.94
528442	[NE_HOBBS 3115.00]	AMP	11674.2	-74.71
528463	[SANGER_SW 3115.00]	AMP	15513.2	-80.17
528491	[MONUMENT 3115.00]	AMP	15152.2	-81.89
528568	[MONUMNT_TP 3115.00]	AMP	10060.2	-78.65
528602	[ANDREWS 3115.00]	AMP	13225.3	-84.36
528603	[NA_ENRICH 3115.00]	AMP	12451.6	-83.11
528604	[ANDREWS 6345.00]	AMP	7024.7	-85.23
528610	[GAINES_GEN 6230.00]	AMP	9773.6	-85.75
528611	[GAINESGENTP6345.00]	AMP	7817.5	-85.63
560021	[CRAWFISH_DR2230.00]	AMP	25412.2	-85.41
560022	[CRAWFISH_DR 345.00]	AMP	24464.6	-86.38
560059	[G1579&G1580T230.00]	AMP	9099.2	-83.43
562480	[G13-027-TAP 230.00]	AMP	9488.6	-82.99
583840	[GEN-2013-027230.00]	AMP	8989.2	-83.11
583960	[G14034G14035115.00]	AMP	6743.2	-83.60
584940	[GEN-2015-056345.00]	AMP	7905.0	-85.14
585060	[GEN-2015-068345.00]	AMP	16224.0	-85.79
585160	[G1579&G1580 230.00]	AMP	8639.8	-83.30
587110	[GEN-2016-015345.00]	AMP	6690.3	-84.79
587420	[GEN-2016-062345.00]	AMP	5390.2	-85.00
587470	[GEN-2016-069115.00]	AMP	6919.1	-83.75
587670	[GEN-2015-099115.00]	AMP	16498.6	-80.74
587964	[G16-120-TAP 345.00]	AMP	8591.6	-85.25
587990	[GEN-2016-121115.00]	AMP	9764.2	-82.36
588000	[GEN-2016-123345.00]	AMP	9673.6	-85.37
588350	[GEN-2016-171230.00]	AMP	8871.5	-83.37
588430	[GEN-2016-169345.00]	AMP	10491.0	-86.39
599960	[EPTNP-D6 230.00]	AMP	9731.2	-84.82

11.6.9 GEN-2018-078 2018S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS

FRI, FEB 22 2019 18:31

2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL

MDWG 2018S WITH MMWG 2017S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING

ADMITTANCE=0.0 IN +/-0 SEQUENCES

- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

THREE PHASE FAULT			
X-----	BUS -----X	/I+/-	AN(I+)
90753	[G18075-SUB 115.00]	AMP 25442.4	-85.78
90781	[G18-078-TAP 345.00]	AMP 7297.9	-85.54
511456	[O.K.U.-7 345.00]	AMP 5542.0	-84.57
511468	[L.E.S.-7 345.00]	AMP 13195.5	-84.79
511553	[CHISHOLM7 345.00]	AMP 12927.3	-85.48
511565	[OKLAUN HVDC7345.00]	AMP 5525.3	-84.57
515375	[WWRDEHV7 345.00]	AMP 19960.7	-86.08
515458	[BORDER 7345.00]	AMP 12557.1	-85.75
523095	[HITCHLAND 6230.00]	AMP 15147.7	-86.29
523097	[HITCHLAND 7345.00]	AMP 16056.2	-85.89
523101	[NOBLE_WND 7345.00]	AMP 15985.9	-85.89
523112	[NOVUS1 7345.00]	AMP 15748.2	-85.86
523215	[FREWHELCOL17345.00]	AMP 9476.2	-85.60
523309	[MOORE_CNTY 6230.00]	AMP 6987.1	-82.69
523823	[WALKEMEYER 7345.00]	AMP 8301.7	-84.90
523869	[CHAN+TASCOS6230.00]	AMP 4370.5	-81.51
523959	[POTTER_CO 6230.00]	AMP 22657.3	-85.03
523961	[POTTER_CO 7345.00]	AMP 11551.4	-86.04
523979	[HARRNG_EST 6230.00]	AMP 27434.9	-86.37
524010	[ROLLHILLS 6230.00]	AMP 20514.3	-84.86
524267	[BUSHLAND 6230.00]	AMP 9882.5	-82.96
524296	[SPNSPUR_WND7345.00]	AMP 5562.6	-85.08
524875	[OASIS 6230.00]	AMP 7522.9	-81.81
524885	[SN_JUAN_TAP6230.00]	AMP 4854.3	-83.11
524889	[SN_JUAN_WND6230.00]	AMP 4641.4	-83.16
524909	[ROSEVELT_N 6230.00]	AMP 9101.1	-81.93
524911	[ROSEVELT_S 6230.00]	AMP 9101.1	-81.93
525213	[SWISHER 6230.00]	AMP 11161.1	-82.39
525461	[NEWHART 6230.00]	AMP 11530.4	-82.16
525481	[PLANT_X 6230.00]	AMP 24074.6	-84.80
525524	[TOLK_EAST 6230.00]	AMP 31507.4	-86.23
525531	[TOLK_WEST 6230.00]	AMP 31507.4	-86.23
525543	[TOLK_TAP 6230.00]	AMP 31507.4	-86.23

525549	[TOLK	7345.00]	AMP	16455.4	-86.46
525637	[LAMB_CNTY	6230.00]	AMP	5444.3	-81.75
525830	[TUCO_INT	6230.00]	AMP	29794.0	-85.79
525832	[TUCO_INT	7345.00]	AMP	22170.6	-86.32
525850	[ELK_CT1	345.00]	AMP	21778.5	-86.28
527455	[RSWL_SLRCOL3115.00]		AMP	7092.2	-83.76
527470	[CHVS_SLRCOL3115.00]		AMP	6775.6	-83.65
527482	[CHAVES_CNTY3115.00]		AMP	7165.6	-83.79
527483	[CHAVES_CNTY6230.00]		AMP	4556.0	-82.70
527501	[URTON	3115.00]	AMP	5919.4	-81.68
527509	[PRICE_TAP	3115.00]	AMP	5460.5	-81.77
527546	[SAMSON	3115.00]	AMP	5574.6	-81.00
527564	[ROSWLL_INT	3115.00]	AMP	5836.0	-81.23
527597	[TWEEDY	3115.00]	AMP	5370.1	-80.57
527654	[RSVLT_CC_W	7345.00]	AMP	7652.9	-85.11
527655	[RSVLT_CC_E	7345.00]	AMP	8679.0	-85.23
527656	[CROSSROADS	7345.00]	AMP	9871.7	-85.39
527707	[ARTESIA	3115.00]	AMP	7024.6	-79.54
527710	[EAGLE_CREEK269.000]		AMP	2338.6	-86.40
527711	[EAGLE_CREEK3115.00]		AMP	7662.9	-79.80
527715	[NAVAJO_2TP	3115.00]	AMP	7290.2	-79.49
527736	[NAVAJO_5TP	3115.00]	AMP	7246.5	-79.46
527786	[ATOKA	3115.00]	AMP	7343.9	-79.41
527793	[EDDY_STH	3115.00]	AMP	12135.6	-84.03
527798	[EDDY_NTH	3115.00]	AMP	12135.6	-84.03
527799	[EDDY_NORTH	6230.00]	AMP	9677.1	-84.82
527802	[EDDY_CNTY	7345.00]	AMP	7811.4	-85.45
527809	[CV-8_MILE	3115.00]	AMP	5509.9	-84.55
527821	[CV-DAYTON	+3115.00]	AMP	7246.0	-79.29
527822	[CV-TURKYTRK3115.00]		AMP	3489.5	-81.04
527864	[CUNNINGHAM	3115.00]	AMP	26723.7	-83.71
527865	[CUNNIGHM_N	6230.00]	AMP	16570.8	-86.61
527867	[CUNNIGHM_S	6230.00]	AMP	16570.8	-86.61
527891	[HOBBS_INT	3115.00]	AMP	30312.0	-85.53
527894	[HOBBS_INT	6230.00]	AMP	17761.9	-86.89
527896	[HOBBS_INT	7345.00]	AMP	8502.6	-86.89
527929	[PCA	269.000]	AMP	6323.2	-83.11
527930	[PCA	3115.00]	AMP	11514.1	-79.64
527948	[CV-LUSK_TP	3115.00]	AMP	4223.8	-80.33
527961	[POTASH_JCT	269.000]	AMP	8992.9	-86.35
527962	[POTASH_JCT	3115.00]	AMP	15800.9	-83.83
527963	[POTASH_JCT	6230.00]	AMP	7350.0	-84.31
527965	[KIOWA	7345.00]	AMP	8480.8	-85.78
527980	[DUVAL_#1	269.000]	AMP	5852.6	-77.79
527996	[KERMAC	269.000]	AMP	2979.4	-70.27
527999	[INTREPDW_TP3115.00]		AMP	13176.0	-81.75
528000	[INTREPIDWST3115.00]		AMP	11193.1	-80.43
528018	[RED_BLUFF	3115.00]	AMP	8931.8	-79.36
528019	[NEWSUB1_7	345.00]	AMP	5578.4	-84.62

528020	[BOPCO_PKRLK3115.00]	AMP	11561.0	-84.34
528022	[MISSCHEME#2 269.000]	AMP	6847.1	-83.25
528025	[RDRUNNER 3115.00]	AMP	10108.8	-83.16
528027	[RDRUNNER 7345.00]	AMP	5686.3	-84.69
528035	[IMC_#1_TP 3115.00]	AMP	9499.4	-78.96
528040	[BATTLE_AXE 3115.00]	AMP	2959.9	-78.44
528070	[CV-AZMESA 3115.00]	AMP	7562.4	-79.19
528093	[7-RIVERS 269.000]	AMP	2405.8	-86.37
528094	[7-RIVERS 3115.00]	AMP	8504.4	-81.60
528095	[7-RIVERS 6230.00]	AMP	6443.4	-83.41
528109	[CV-LAKEWOOD3115.00]	AMP	6576.3	-78.89
528132	[OCOTILLO 3115.00]	AMP	6229.7	-73.05
528137	[N_CANAL 3115.00]	AMP	8793.1	-78.45
528145	[NATPOT_TP 269.000]	AMP	8943.8	-86.26
528151	[FIESTA 3115.00]	AMP	9898.6	-78.46
528159	[CARLSBAD 269.000]	AMP	4890.2	-85.56
528160	[CARLSBAD 3115.00]	AMP	11419.4	-79.25
528178	[PECOS 3115.00]	AMP	12060.2	-80.42
528179	[PECOS 6230.00]	AMP	6650.2	-83.73
528182	[NORTH_LOVNG3115.00]	AMP	9803.7	-84.77
528185	[N_LOVING 7345.00]	AMP	6301.7	-85.13
528222	[CHINA_DRAW 3115.00]	AMP	9048.3	-84.54
528223	[CHINA_DRAW 7345.00]	AMP	5571.0	-84.81
528226	[HOPI_SUB 3115.00]	AMP	6943.0	-79.87
528230	[AGAVE_RHILL3115.00]	AMP	9690.0	-82.53
528396	[XTO_LOAD#4 115.00]	AMP	8893.3	-77.95
528604	[ANDREWS 6345.00]	AMP	6260.3	-85.48
528610	[GAINES_GEN 6230.00]	AMP	8800.2	-86.01
528611	[GAINESGENTP6345.00]	AMP	6830.2	-85.93
560010	[G14-037-TAP 345.00]	AMP	15706.3	-85.99
560021	[CRAWFISH_DR2230.00]	AMP	24731.4	-85.30
560022	[CRAWFISH_DR 345.00]	AMP	22811.8	-86.36
560035	[GRAPEVINE 345.00]	AMP	6510.9	-85.17
560059	[G1579&G1580T230.00]	AMP	9064.6	-83.37
562480	[G13-027-TAP 230.00]	AMP	9463.0	-82.98
576395	[GEN-2010-014345.00]	AMP	11645.2	-83.00
583090	[G1149&G1504 345.00]	AMP	9860.1	-85.40
583960	[G14034G14035115.00]	AMP	6741.0	-83.60
584940	[GEN-2015-056345.00]	AMP	7918.2	-85.14
585060	[GEN-2015-068345.00]	AMP	15424.2	-85.80
587470	[GEN-2016-069115.00]	AMP	6916.8	-83.75
587960	[GEN-2016-120345.00]	AMP	6363.1	-85.07
587964	[G16-120-TAP 345.00]	AMP	8505.1	-85.27
587970	[GEN-2016-175345.00]	AMP	5111.7	-84.91
587990	[GEN-2016-121115.00]	AMP	9530.3	-82.13
588000	[GEN-2016-123345.00]	AMP	9693.4	-85.37
588430	[GEN-2016-169345.00]	AMP	8294.3	-86.71
599960	[EPTNP-D6 230.00]	AMP	9677.1	-84.82

11.6.10 GEN-2018-078 2026S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS

FRI, FEB 22 2019 18:31

2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL
MDWG 2026S WITH MMWG 2026S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES

- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

			THREE PHASE FAULT	
X-----	BUS -----X		/I+/-	AN(I+)
90753	[G18075-SUB 115.00]	AMP	27185.1	-85.63
90781	[G18-078-TAP 345.00]	AMP	7331.8	-85.52
511456	[O.K.U.-7 345.00]	AMP	5565.8	-84.56
511468	[L.E.S.-7 345.00]	AMP	13318.9	-84.79
511553	[CHISHOLM7 345.00]	AMP	12949.5	-85.48
511565	[OKLAUN HVDC7345.00]	AMP	5549.0	-84.56
515375	[WWRDEHV7 345.00]	AMP	19998.8	-86.07
515458	[BORDER 7345.00]	AMP	12591.4	-85.75
523095	[HITCHLAND 6230.00]	AMP	15121.9	-86.31
523097	[HITCHLAND 7345.00]	AMP	16043.1	-85.89
523101	[NOBLE_WND 7345.00]	AMP	15972.9	-85.89
523112	[NOVUS1 7345.00]	AMP	15735.6	-85.86
523215	[FREWHELCOL17345.00]	AMP	9471.9	-85.60
523309	[MOORE_CNTY 6230.00]	AMP	6937.0	-82.72
523823	[WALKEMEYER 7345.00]	AMP	8326.5	-84.90
523869	[CHAN+TASCOS6230.00]	AMP	4342.4	-81.54
523959	[POTTER_CO 6230.00]	AMP	21824.3	-85.00
523961	[POTTER_CO 7345.00]	AMP	11439.3	-86.00
523979	[HARRNG_EST 6230.00]	AMP	25753.5	-86.13
524010	[ROLLHILLS 6230.00]	AMP	19589.7	-84.76
524267	[BUSHLAND 6230.00]	AMP	9732.0	-82.98
524296	[SPNSPUR_WND7345.00]	AMP	5538.1	-85.07
524875	[OASIS 6230.00]	AMP	7527.1	-81.82
524885	[SN_JUAN_TAP6230.00]	AMP	4851.8	-83.12
524889	[SN_JUAN_WND6230.00]	AMP	4639.1	-83.17
524909	[ROSEVELT_N 6230.00]	AMP	9093.2	-81.94
524911	[ROSEVELT_S 6230.00]	AMP	9093.2	-81.94
525213	[SWISHER 6230.00]	AMP	11071.6	-82.42
525461	[NEWHART 6230.00]	AMP	11379.8	-82.18

525481	[PLANT_X	6230.00]	AMP	23413.8	-84.56
525524	[TOLK_EAST	6230.00]	AMP	30968.1	-86.16
525531	[TOLK_WEST	6230.00]	AMP	30968.1	-86.16
525543	[TOLK_TAP	6230.00]	AMP	30968.1	-86.16
525549	[TOLK	7345.00]	AMP	16351.4	-86.43
525637	[LAMB_CNTY	6230.00]	AMP	5548.8	-82.09
525830	[TUCO_INT	6230.00]	AMP	30751.1	-85.94
525832	[TUCO_INT	7345.00]	AMP	23902.2	-86.35
525850	[ELK_CT1	345.00]	AMP	23446.4	-86.31
526935	[YOAKUM	6230.00]	AMP	18065.1	-85.09
526936	[YOAKUM_345	345.00]	AMP	9796.6	-86.25
527455	[RSWL_SLRCOL3115.00]		AMP	7094.6	-83.76
527470	[CHVS_SLRCOL3115.00]		AMP	6777.8	-83.65
527482	[CHAVES_CNTY3115.00]		AMP	7168.1	-83.79
527483	[CHAVES_CNTY6230.00]		AMP	4557.3	-82.70
527501	[URTON	3115.00]	AMP	5926.0	-81.68
527509	[PRICE_TAP	3115.00]	AMP	5461.9	-81.77
527546	[SAMSON	3115.00]	AMP	5578.5	-81.00
527564	[ROSWLL_INT	3115.00]	AMP	5843.9	-81.24
527597	[TWEEDY	3115.00]	AMP	5376.6	-80.58
527654	[RSVLT_CC_W	7345.00]	AMP	7641.5	-85.11
527655	[RSVLT_CC_E	7345.00]	AMP	8663.6	-85.23
527656	[CROSSROADS	7345.00]	AMP	9851.0	-85.39
527707	[ARTESIA	3115.00]	AMP	7040.1	-79.52
527710	[EAGLE_CREEK269.000]		AMP	2339.6	-86.40
527711	[EAGLE_CREEK3115.00]		AMP	7681.4	-79.78
527715	[NAVAJO_2TP	3115.00]	AMP	7306.8	-79.47
527736	[NAVAJO_5TP	3115.00]	AMP	7262.9	-79.43
527786	[ATOKA	3115.00]	AMP	7361.0	-79.38
527793	[EDDY_STH	3115.00]	AMP	12181.5	-84.01
527798	[EDDY_NTH	3115.00]	AMP	12181.5	-84.01
527799	[EDDY_NORTH	6230.00]	AMP	9731.2	-84.82
527802	[EDDY_CNTY	7345.00]	AMP	8003.7	-85.36
527809	[CV-8_MILE	3115.00]	AMP	5519.3	-84.54
527821	[CV-DAYTON	+3115.00]	AMP	7262.5	-79.27
527822	[CV-TURKYTRK3115.00]		AMP	3493.2	-81.04
527864	[CUNNINGHAM	3115.00]	AMP	26601.9	-83.65
527865	[CUNNINGHM_N	6230.00]	AMP	14908.5	-86.14
527867	[CUNNINGHM_S	6230.00]	AMP	14908.5	-86.14
527891	[HOBBS_INT	3115.00]	AMP	30158.8	-85.45
527894	[HOBBS_INT	6230.00]	AMP	17059.6	-86.85
527896	[HOBBS_INT	7345.00]	AMP	10826.7	-86.61
527929	[PCA	269.000]	AMP	6347.2	-83.11
527930	[PCA	3115.00]	AMP	11621.3	-79.59
527948	[CV-LUSK_TP	3115.00]	AMP	4238.2	-80.31
527961	[POTASH_JCT	269.000]	AMP	9044.2	-86.36
527962	[POTASH_JCT	3115.00]	AMP	16081.9	-83.84
527963	[POTASH_JCT	6230.00]	AMP	7314.2	-84.33
527965	[KIOWA	7345.00]	AMP	9061.7	-85.63

527980	[DUVAL_#1	269.000]	AMP	5874.3	-77.77
527996	[KERMAC	269.000]	AMP	2984.9	-70.24
527999	[INTREPDW_TP3115.00]	AMP	13453.3	-82.30	
528000	[INTREPIDWST3115.00]	AMP	11394.8	-80.87	
528018	[RED_BLUFF	3115.00]	AMP	9122.1	-79.41
528019	[NEWSUB1_7	345.00]	AMP	5812.1	-84.59
528020	[BOPCO_PKRLK3115.00]	AMP	11887.7	-84.36	
528022	[MISSCHEME#2	269.000]	AMP	6876.9	-83.25
528025	[RDRUNNER	3115.00]	AMP	10371.6	-83.43
528027	[RDRUNNER	7345.00]	AMP	5930.3	-84.67
528035	[IMC_#1_TP	3115.00]	AMP	9744.1	-80.05
528040	[BATTLE_AXE	3115.00]	AMP	2982.2	-78.49
528070	[CV-AZMESA	3115.00]	AMP	7585.2	-79.16
528093	[7-RIVERS	269.000]	AMP	2406.9	-86.37
528094	[7-RIVERS	3115.00]	AMP	8528.4	-81.57
528095	[7-RIVERS	6230.00]	AMP	6458.1	-83.40
528109	[CV-LAKWOOD3115.00]	AMP	6590.2	-78.86	
528132	[OCOTILLO	3115.00]	AMP	6251.6	-72.99
528137	[N_CANAL	3115.00]	AMP	8837.9	-78.39
528145	[NATPOT_TP	269.000]	AMP	8994.5	-86.28
528151	[FIESTA	3115.00]	AMP	9959.8	-78.39
528159	[CARLSBAD	269.000]	AMP	4898.0	-85.55
528160	[CARLSBAD	3115.00]	AMP	11501.1	-79.18
528178	[PECOS	3115.00]	AMP	12145.2	-80.35
528179	[PECOS	6230.00]	AMP	6650.2	-83.75
528182	[NORTH_LOVNG3115.00]	AMP	10005.5	-84.75	
528185	[N_LOVING	7345.00]	AMP	6602.7	-85.03
528192	[SOUTH_LOVNG3115.00]	AMP	7398.0	-82.54	
528222	[CHINA_DRAW	3115.00]	AMP	9243.3	-84.52
528223	[CHINA_DRAW	7345.00]	AMP	5803.5	-84.75
528226	[HOPI_SUB	3115.00]	AMP	7000.9	-79.81
528230	[AGAVE_RHILL3115.00]	AMP	9933.3	-82.82	
528396	[XTO_LOAD#4	115.00]	AMP	8937.7	-77.90
528604	[ANDREWS	6345.00]	AMP	7024.7	-85.23
528610	[GAINES_GEN	6230.00]	AMP	9773.6	-85.75
528611	[GAINESGENTP6345.00]	AMP	7817.5	-85.63	
560010	[G14-037-TAP	345.00]	AMP	15695.2	-86.00
560021	[CRAWFISH_DR2230.00]	AMP	25412.2	-85.41	
560022	[CRAWFISH_DR	345.00]	AMP	24464.6	-86.38
560035	[GRAPEVINE	345.00]	AMP	6497.0	-85.17
560059	[G1579&G1580T230.00]	AMP	9099.2	-83.43	
562480	[G13-027-TAP	230.00]	AMP	9488.6	-82.99
576395	[GEN-2010-014345.00]	AMP	11638.6	-83.00	
583090	[G1149&G1504	345.00]	AMP	9880.7	-85.40
583960	[G14034G14035115.00]	AMP	6743.2	-83.60	
584940	[GEN-2015-056345.00]	AMP	7905.0	-85.14	
585060	[GEN-2015-068345.00]	AMP	16224.0	-85.79	
587470	[GEN-2016-069115.00]	AMP	6919.1	-83.75	
587960	[GEN-2016-120345.00]	AMP	6402.6	-85.06	

587964	[G16-120-TAP 345.00]	AMP	8591.6	-85.25
587970	[GEN-2016-175345.00]	AMP	5139.0	-84.90
587990	[GEN-2016-121115.00]	AMP	9764.2	-82.36
588000	[GEN-2016-123345.00]	AMP	9673.6	-85.37
588430	[GEN-2016-169345.00]	AMP	10491.0	-86.39
599960	[EPTNP-D6 230.00]	AMP	9731.2	-84.82

11.6.11 GEN-2018-127 2018S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS

FRI, FEB 22 2019 17:31

2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL

MDWG 2018S WITH MMWG 2017S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING ADMITTANCE=0.0 IN +/-0 SEQUENCES
- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

THREE PHASE FAULT

X-----BUS-----X		/I+/-	AN(I+)
91271 [G18127-SUB 138.00]	AMP	10260.9	-81.77
300136 [4MEMORAL 138.00]	AMP	20667.7	-81.86
514510 [BURGETT4 138.00]	AMP	22578.4	-84.81
514714 [WOODRNG4 138.00]	AMP	19869.2	-83.48
514733 [MARSHL 4 138.00]	AMP	8437.9	-80.79
514774 [HENESEY4 138.00]	AMP	8926.0	-80.48
514827 [CTNWOOD4 138.00]	AMP	19054.6	-81.15
514829 [PINE ST4 138.00]	AMP	12628.3	-78.24
514830 [FITZGRD4 138.00]	AMP	9229.6	-77.13
514831 [WATRL004 138.00]	AMP	14701.1	-81.53
514842 [CHTWOOD4 138.00]	AMP	21090.1	-83.09
514880 [NORTWST7 345.00]	AMP	32516.8	-86.09
514906 [JNSKAM04 138.00]	AMP	20811.3	-81.88
514907 [ARCADIA4 138.00]	AMP	42568.8	-85.69
514908 [ARCADIA7 345.00]	AMP	26502.2	-86.52
514909 [REDBUD 7 345.00]	AMP	25493.1	-86.86
514941 [HSL 4 138.00]	AMP	44552.9	-84.05
515008 [KINZE 4 138.00]	AMP	13817.5	-80.27
515045 [SEMINOL7 345.00]	AMP	26581.6	-86.12
515373 [LBRTYLK4 138.00]	AMP	14401.7	-81.25

515377	[CRESENT4	138.00]	AMP	10260.9	-81.77
515461	[RNDBARN4	138.00]	AMP	40408.7	-85.61
515465	[LGARBER4	138.00]	AMP	21405.3	-82.35
515467	[WHITESB4	138.00]	AMP	15763.0	-81.87
520600	[EKNGFSH3	138.00]	AMP	5283.2	-78.67
520603	[NKNGFSH	138.00]	AMP	6187.2	-78.94
520847	[CASHION4	138.00]	AMP	5985.9	-79.30
520879	[DOVER 4	138.00]	AMP	7047.1	-79.29
520881	[DOVERSW2	69.000]	AMP	6654.2	-83.36
520882	[DOVERSW4	138.00]	AMP	9976.6	-80.35
521006	[MARSHAL4	138.00]	AMP	8395.3	-80.73
521016	[OKEENE 4	138.00]	AMP	5005.8	-75.09
521037	[REEDING2	138.00]	AMP	4893.5	-78.80
521073	[TWNLAKE4	138.00]	AMP	8303.3	-80.62
560077	[G16-032-TAP	345.00]	AMP	4236.1	-80.96
587210	[GEN-2016-032138.00]		AMP	8917.5	-81.57
587940	[GEN-2016-118138.00]		AMP	7518.3	-83.39

11.6.12 GEN-2018-127 2016S

PSS(R)E-33.10.0 ASCC SHORT CIRCUIT CURRENTS

FRI, FEB 22 2019 17:32

2016 MDWG FINAL WITH 2015 SERIES MMWG FINAL
MDWG 2026S WITH MMWG 2026S

OPTIONS USED:

- SET PRE-FAULT VOLTAGE ON ALL BUSES TO 1.00 PU AT 0 PHASE SHIFT ANGLE
- SET SYNCHRONOUS/ASYNCHRONOUS MACHINE POWER OUTPUTS TO P=0.0, Q=0.0
- SET GENERATOR POSITIVE SEQUENCE REACTANCES TO SUBTRANSIENT
- SET TRANSFORMER TAP RATIOS=1.0 PU AND PHASE SHIFT ANGLES=0.0
- SET LINE CHARGING=0.0 IN +/-0 SEQUENCES
- SET LINE/FIXED/SWITCHED SHUNTS=0.0 AND TRANSFORMER MAGNETIZING

ADMITTANCE=0.0 IN +/-0 SEQUENCES

- SET LOAD=0.0 IN +/- SEQUENCES
- DC LINES AND FACTS DEVICES BLOCKED
- IMPEDANCE CORRECTIONS APPLIED TO TRANSFORMER ZERO SEQUENCE IMPEDANCES

THREE PHASE FAULT

X-----	BUS -----X		/I+/-	AN(I+)	
91271	[G18127-SUB	138.00]	AMP	10269.7	-81.78
300136	[4MEMORAL	138.00]	AMP	20391.2	-81.88
514510	[BURGETT4	138.00]	AMP	22459.0	-84.83
514714	[WOODRNG4	138.00]	AMP	19915.4	-83.46
514733	[MARSHL 4	138.00]	AMP	8441.3	-80.78
514774	[HENESEY4	138.00]	AMP	8969.7	-80.51
514827	[CTNWOOD4	138.00]	AMP	19029.8	-81.16
514829	[PINE ST4	138.00]	AMP	12618.9	-78.24
514830	[FITZGRD4	138.00]	AMP	9226.7	-77.13
514831	[WATRL004	138.00]	AMP	14666.5	-81.54

Southwest Power Pool, Inc.

514842	[CHTWOOD4	138.00]	AMP	20790.3	-83.05
514880	[NORTWST7	345.00]	AMP	32413.9	-86.09
514906	[JNSKAM04	138.00]	AMP	20530.3	-81.89
514907	[ARCADIA4	138.00]	AMP	42277.7	-85.73
514908	[ARCADIA7	345.00]	AMP	26609.9	-86.55
514909	[REDBUD 7	345.00]	AMP	25832.4	-86.82
514941	[HSL 4	138.00]	AMP	41002.5	-83.61
515008	[KINZE 4	138.00]	AMP	13826.5	-80.23
515045	[SEMINOL7	345.00]	AMP	26549.0	-86.12
515373	[LBRTYLK4	138.00]	AMP	14375.2	-81.26
515377	[CRESENT4	138.00]	AMP	10269.7	-81.78
515461	[RNDBARN4	138.00]	AMP	40142.2	-85.64
515465	[LGARBER4	138.00]	AMP	21239.2	-82.36
515467	[WHITESB4	138.00]	AMP	15717.8	-81.88
520600	[EKNGFSH3	138.00]	AMP	5299.0	-78.69
520603	[NKNGFSH	138.00]	AMP	6211.9	-78.97
520847	[CASHION4	138.00]	AMP	5996.5	-79.31
520879	[DOVER 4	138.00]	AMP	7071.1	-79.31
520881	[DOVERSW2	69.000]	AMP	6818.4	-83.40
520882	[DOVERSW4	138.00]	AMP	10052.9	-80.41
521006	[MARSHAL4	138.00]	AMP	8398.7	-80.73
521016	[OKEENE 4	138.00]	AMP	5038.3	-75.16
521037	[REEDING2	138.00]	AMP	4903.5	-78.81
521073	[TWNLAKE4	138.00]	AMP	8319.1	-80.62
560077	[G16-032-TAP	345.00]	AMP	4235.4	-80.96
587210	[GEN-2016-032138.00]		AMP	8916.4	-81.57
587940	[GEN-2016-118138.00]		AMP	7549.0	-83.43

11.7 APPENDIX G

Proposed Point of Interconnection Slider Diagrams




Figure 11-1: GEN-2018-066 Primary Point of Interconnection




Figure 11-2: GEN-2018-075 (SP) Primary Point of Interconnection




Figure 11-3: GEN-2018-075 (WP) Primary Point of Interconnection




Figure 11-4: GEN-2018-075 (SP) Secondary Point of Interconnection




Figure 11-5: GEN-2018-075 (WP) Secondary Point of Interconnection




Figure 11-6: GEN-2018-075 (SP) Tertiary Point of Interconnection




Figure 11-7: GEN-2018-075 (WP) Tertiary Point of Interconnection




Figure 11-8: GEN-2018-078 Primary Point of Interconnection




Figure 11-9: GEN-2018-127 Primary Point of Interconnection