



# **AGGREGATE FACILITIES STUDY**

**SPP-2019-AG1-AFS-2**

Published on 11/7/2019

SPP Engineering, Transmission Services

# REVISION HISTORY

---

DATE OR VERSION NUMBER	AUTHOR	CHANGE DESCRIPTION	COMMENTS
11/7/2019	SPP	Original	

# CONTENTS

---

Revision History .....i

Executive Summary ..... 1

Introduction ..... 2

Financial Analysis ..... 4

Make-Whole Payment ..... 5

Third-Party Facilities ..... 6

Study Methodology ..... 7

    Description ..... 7

    Model Development ..... 7

    Transmission Request Modeling ..... 8

    Transfer Analysis ..... 8

    Curtailment and Redispatch Evaluation ..... 8

Study Results .....10

    Study Analysis Results ..... 10

        Table 1 ..... 10

        Table 2 ..... 10

        Table 3 ..... 10

        Table 4 ..... 10

        Table 5 ..... 10

        Table 6 ..... 10

        Table 7 ..... 11

        Base Plan Upgrades ..... 11

    Study Definitions ..... 12

Conclusion .....13

Appendix A .....14

    BASE CASE SETTINGS: ..... 14

    ACCC CASE SETTINGS: ..... 14

## EXECUTIVE SUMMARY

---

This study report provides results for Southwest Power Pool, Inc. (SPP) Aggregate Transmission Service Study (ATSS) SPP-2019-AG1-AFS-2. Pursuant to Attachment Z1 of the SPP Open Access Transmission Tariff (OATT), 2,482 MW of long-term transmission service requests have been studied in this Aggregate Facilities Study (AFS).

The principal objective of the AFS is to identify system problems and potential modifications necessary to facilitate these transfers while maintaining or improving system reliability, as well as summarizing the operating limits and determination of the financial characteristics associated with facility upgrades. Facility upgrade costs are allocated on a prorated basis to all requests positively impacting any individual overloaded facility.

Transmission Customers (Customer) requesting service in this study specified five parameters under which they agreed to confirm service. The five parameters are:

1. Directly Assigned Upgrade Cost (E&C and Credit Payment Obligation)
2. Third-Party Upgrade Cost
3. Latest Deferred Start Date
4. Interim Re-dispatch Acceptance
5. Letter of Credit Amount

This final study report provides details and indicates for each request whether any of the five parameters were exceeded. The specific parameters defined by the Customer are confidential and will not be included in this report.

SPP will accept the requests in which the specified study parameters were met and will tender a Service Agreement for each of these requests identifying the terms and conditions of the confirmed service. SPP has refused all requests in which the parameters were exceeded.

All allocated revenue requirements for facility upgrades are assigned to the Customer in the AFS data tables. Potential base plan funding allowable is contingent upon validation of designated resources meeting Attachment J, Section III B criteria.

## INTRODUCTION

---

All requests for long-term transmission service with a Completed Application received before June 1, 2019 have been included in this ATSS.

The results of the AFS are detailed in Tables 1 through 7. Detailed results depict individual upgrade costs by study and potential base plan allowances determined by Attachments J and Z1 of the SPP OATT.

To understand the extent to which Base Plan Upgrades may be applied to both Point-to-Point (PTP) and Network Integration Transmission Services (NITS), it is necessary to highlight the definition of Designated Resource. Per Section 1 of the SPP OATT, a Designated Resource is:

“Any designated generation resource owned, purchased or leased by a Transmission Customer to serve load in the SPP Region. Designated Resources do not include any resource, or any portion thereof, that is committed for sale to third parties or otherwise cannot be called upon to meet the Transmission Customer's load on a non-interruptible basis.”

Both NITS and PTP service have potential for base plan funding if the conditions for classifying upgrades associated with designated resources as Base Plan Upgrades as defined in Section III.B of Attachment J are met.

Pursuant to Attachment J, Section III.B of the SPP OATT, the Customer must provide SPP information necessary to verify that the new or changed Designated Resource meets the following conditions:

1. Customer's commitment to the requested new or changed Designated Resource must have duration of at least five years.
2. During the first year the Designated Resource is planned to be used by the Customer, the accredited capacity of the Customer's existing Designated Resources plus the lesser of:
  - a. The planned maximum net dependable capacity applicable to the Customer or
  - b. The requested capacity; shall not exceed 125% of the Customer's projected system peak responsibility determined pursuant to SPP Criteria 2.

According to Attachment Z1 Section V.A, PTP Customers pay the higher of the monthly transmission access charge (base rate) or the monthly revenue requirement associated with the directly assigned portion of the Service Upgrade, if any.

NITS Customers pay the total monthly transmission access charges and the monthly revenue requirement associated with the directly assigned portion of the Service Upgrade, if any.

Customers paying for a directly assigned Network Upgrade shall receive credits for new transmission service using the facility as specified in Attachment Z2.

Facilities identified as limiting the requested Transmission Service have been reviewed to determine the required in-service date of each Network Upgrade. Both previously assigned facilities and the facilities assigned to this request for Transmission Service were evaluated.

In some instances, due to lead times for engineering and construction, Network Upgrades may not be available when required to accommodate a request for Transmission Service. When this occurs,

the ATC with available Network Upgrades will be less than the capacity requested during either a portion of or all of the requested reservation period. The ATC may be limited by expansion plan projects or Customer assigned upgrades.

Some constraints identified in the AFS were not assigned to the Customer because SPP determined that upgrades are not required due to various reasons or the Transmission Owner has construction plans pending for these upgrades. These facilities are listed by reservation in Table 3. Table 7 lists the costs allocated per request for each Service Upgrade assigned in this AFS.

By taking the transmission service subject to interim redispatch, the Customer agrees to any limitations to Auction Revenue Rights that may result. In the absence of implementation of interim redispatch as requested by SPP for Customer transactions resulting in overloads on limiting facilities, SPP may curtail the Customer's schedule.

## FINANCIAL ANALYSIS

---

The AFS utilizes the allocated Customer's E&C cost in a present worth analysis to determine the monthly levelized revenue requirement of each facility upgrade over the term of the reservation. In some cases, Network Upgrades cannot be completed within the requested reservation period, thus deferred reservation periods will be utilized in the present worth analysis. If the Customer chose Option 5, Use of Interim Redispatch, in Appendix 1 of the Aggregate Facilities Study Agreement, the present worth analysis of revenue requirements will be based on the deferred term with redispatch in the subsequent AFS. The upgrade levelized revenue requirement includes interest, depreciation, and carrying costs.

Each request for Transmission Service is evaluated independently as the cost associated with each Network Upgrade is assigned to a request. When facilities are upgraded throughout the reservation period, the Customer will pay the total E&C costs and other annual operating costs associated with the new facilities.

In the event that the engineering and construction of a previously assigned Network Upgrade may be accelerated with no additional upgrades to accommodate a new request for Transmission Service, the levelized present worth of only the incremental expenses through the reservation period of the new request, excluding depreciation, shall be assigned to the new request. These incremental expenses, excluding depreciation, include:

1. The levelized difference in present worth of the engineering and construction expenses given the change in date to complete construction to account for additional interest expense and reduced engineering and construction expense due to inflation,
2. The levelized present worth of all expediting fees, and
3. The levelized present worth of the incremental annual carrying charges, excluding depreciation and interest, during the new reservation period taking into account both:
  - a. The reservation in which the project was originally assigned, and
  - b. A reservation, if any, in which the project was previously accelerated.

In the case of a Base Plan Upgrade being deferred or displaced by an earlier in service date for a requested upgrade, the methodology for achievable base plan avoided revenue requirements shall be determined per Attachment J, Section VII.A or Section VII.B, respectively. A deferred Base Plan Upgrade is defined as a different requested Network Upgrade needed at an earlier date that negates the need for the initial Base Plan Upgrade within the planning horizon. A displaced Base Plan Upgrade is defined as the same Network Upgrade being displaced by a requested upgrade needed at an earlier date.

A 40-year service life assumption is utilized for Base Plan funded projects, unless another assumption is provided by the Transmission Owner. A present worth analysis of revenue requirements on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan revenue requirements due to the displacement or deferral of the Base Plan Upgrade by the Requested Upgrade. The difference in present worth between the Base Plan and Requested Upgrades is assigned to the transmission requests impacting this upgrade based on the displacement or deferral.

## MAKE-WHOLE PAYMENT

---

Make-whole payment (MWP) is a potential cost that may be allocated to a Request in a completed AFS meeting the Study Completion Conditions but with unresolved third party impacts. For a Request with identified third party impact(s) where the Customer has not notified SPP of a successful conclusion to the third-party negotiation by the deadline described in Section III.D.2 of Attachment Z1 in the OATT, SPP will deem the Request to be terminated and withdrawn and the Customer may be subject to a MWP in accordance with Section III.D.4 of Attachment Z1 in the OATT. The calculation of the Customer's MWP shall include any impacts to subsequent completed AFS(s).

The MWP assigned to a withdrawn Request will be any reallocated upgrade costs that are in excess of the sum of (i) the DAUC and (ii) the amounts included in rates, for any remaining confirmed Request(s).

If there is more than one withdrawn Request then the MWP, if any, shall be assigned to the withdrawn Customers based upon the impact of the withdrawal of each withdrawn Customer's request on those upgrades for which the DAUC increased for the confirmed requests, thereby resulting in the MWP. Upgrade costs for facilities only required by the withdrawn Customer's request(s) shall not be included as part of the calculation of the MWP. A Customer required to pay a MWP will enter into a Sponsored Upgrade Agreement with SPP in accordance with Attachment J of the OATT and will be eligible for revenue credits in accordance with Attachment Z2 of the OATT.



## THIRD-PARTY FACILITIES

---

For third-party facilities listed in Table 3 and Table 5, the Customer is responsible for funding the necessary upgrades of these facilities per Section 21.1 of SPP's OATT. In this AFS, third-party facilities were not identified.

All modeled facilities within the SPP system were monitored during the development of this study, as well as certain facilities in first-tier neighboring systems. Third-party facilities must be upgraded when it is determined that they are overloaded while accommodating the requested Transmission Service. An agreement between the Customer and third party owner detailing the mitigation of the third party impact must be provided to SPP prior to tendering of a Transmission Service Agreement. These facilities also include those owned by members of SPP who have not placed their facilities under SPP's OATT. Upgrades on the Southwestern Power Administration (SWPA) network requires prepayment of the upgrade cost prior to construction of the upgrade.

Third-party facilities are evaluated for only those requests whose load sinks within the SPP footprint. The Customer must arrange with the applicable Transmission Providers for study of third party facilities for service that sinks outside the SPP footprint.

## STUDY METHODOLOGY

---

### *DESCRIPTION*

The facility study analysis was conducted to determine the steady-state impact of the requested service on the SPP and first tier non-SPP control area systems. The steady-state analysis was performed consistent with current SPP Criteria and NERC Reliability Standards requirements. SPP conforms to NERC Reliability Standards, which provide strict requirements related to voltage violations and thermal overloads during normal conditions and during a contingency. NERC Standards require all facilities to be within normal operating ratings for normal system conditions and within emergency ratings after a contingency.

Normal operating ratings and emergency operating ratings monitored are Rate A and B in the SPP Integrated Transmission Planning (ITP) models, respectively. The upper bound and lower bound of the normal voltage range monitored is 105% and 95%. The upper bound and lower bound of the emergency voltage range monitored is 105% and 90%. Transmission Owner voltage monitoring criteria is used if more restrictive. The SPS Tuco 230 kV bus voltage is monitored at 92.5% due to pre-determined system stability limitations. The WERE Wolf Creek 345 kV bus voltage is monitored at 103.5% and 98.5% due to transmission operating procedure.

The contingency set includes all SPP control area branches and ties 69 kV and above; first tier non-SPP control area branches and ties 115 kV and above; any defined contingencies for these control areas; and generation unit outages for the control areas with SPP reserve share program redispatch. The monitored elements include all SPP control area branches, ties, and buses 69 kV and above, and all first tier non-SPP control area branches and ties 115 kV and above. Voltage monitoring was performed for SPP control area buses 69 kV and above.

A 3% transfer distribution factor (TDF) cutoff was applied to all SPP control area facilities. For first tier non-SPP control area facilities, SPP used the appropriate TDF threshold defined by AECL, AMRN (Ameren), and ENTR (Entergy) control areas. For voltage monitoring, a 0.02 per unit change in voltage must occur due to the transfer or modeling upgrades to be considered a valid limit to the transfer.

### *MODEL DEVELOPMENT*

SPP used the following 2019 ITP models, used in the 2019 ITP Assessment, to study the aggregate transfers over a variety of requested service periods and to determine the impact of the requested service on the transmission system:

- 2019 Winter
- 2021 Light Load, Summer, and Winter
- 2024 Light Load, Summer, and Winter
- 2029 Light Load, Summer, and Winter

The Summer Peak models apply to June through September, the Winter Peak models apply to October through March, and the Light Load models apply to April through May.

The chosen base case models were modified to reflect the current modeling information. One group of requests was developed from the aggregate to model the requested service. Base Reliability

model scenarios were utilized. Base Reliability includes projected usage of transmission included in the SPP 2019 ITP Cases.

### ***TRANSMISSION REQUEST MODELING***

NITS requests are modeled as Generation to Load transfers in addition to Generation to Generation transfers because the requested NITS is a request to serve network load with the new designated network resource, and the impacts on the Transmission System are determined accordingly. PTP Transmission Service requests are modeled as Generation to Generation transfers. Generation to Generation transfers are accomplished by developing a post-transfer case for comparison by dispatching the requested source and redispatching the requested sink.

### ***TRANSFER ANALYSIS***

Using the selected cases both with and without the requested transfers modeled, the PSS/E Activity ACCC was run on the cases and compared to determine the facility overloads caused or impacted by the transfer. TDF cutoffs (SPP and 1<sup>st</sup>-Tier) and voltage threshold (0.02 change) were applied to determine the impacted facilities. The PSS/E options chosen to conduct the analysis can be found in Appendix A.

### ***CURTAILMENT AND REDISPATCH EVALUATION***

During any period in which SPP determines that a transmission constraint exists on and may impair Transmission System reliability, SPP will take whatever actions are reasonably necessary to maintain reliability. If SPP determines Transmission System reliability can be maintained by redispatching resources, it will evaluate the interim redispatch of units to provide service prior to completion of any assigned Network Upgrades. Any redispatch may not unduly discriminate between the Transmission Owners' use of the Transmission System on behalf of their Native Load Customers and any Customer's use of the Transmission System to serve its designated load. Redispatch was evaluated to provide only interim service during the time frame prior to completion of any assigned Network Upgrades.

SPP determined potential relief pairs to relieve the incremental MW impact on limiting facilities. Using the selected cases where the limiting facilities were identified, potential incremental and decremental units were identified by determining the generation amount available for increasing and decreasing from the units' generation amount, maximum generation amount, and minimum generation amount. If the incremental or decremental amount was greater than 1 MW, the unit was considered as a potential incremental or decremental unit.

Generation shift factors were calculated for the potential incremental and decremental units using the Siemens power flow analysis tool, Managing and Utilizing System Transmission (MUST). Relief pairs from the generation shift factors for the incremental and decremental units with a TDF greater than 3% on the limiting constraint were determined from the incremental units with the lowest generation shift factors and decremental units with highest generation shift factors. If the aggregate redispatch amount for the potential relief pair was determined to be three times greater than the lower of the increment or decrement, then the pair was determined not to be feasible and is not included. The potential relief pairs were not evaluated to determine impacts on limiting facilities in the SPP and first tier systems.

The AFS analyzes the most probable contingencies and does not account for every situation that may be encountered in real-time operation. Because of this, it is possible that the Customer may be

Southwest Power Pool, Inc.

curtailed under certain system conditions to allow system operators to maintain the reliability of the transmission network.

## STUDY RESULTS

---

### *STUDY ANALYSIS RESULTS*

Tables 1 through 7 contain the AFS steady-state analysis results.

#### **TABLE 1**

Table 1 identifies the participating long-term Transmission Service requests included in the AFS. This table lists deferred start and stop dates both with and without redispatch (based on Customer selection of redispatch if available) and the minimum annual allocated ATC without upgrades, the season of first impact, and indicates which requests, if any, had parameters that were exceeded.

#### **TABLE 2**

Table 2 identifies total E&C cost allocated to each Customer, letter of credit requirements, third party E&C cost assignments, potential base plan E&C funding (lower of allocated E&C or Attachment J Section III B criteria), PTP base rate charge, total revenue requirements for assigned upgrades with consideration of potential base plan funding, final total cost allocation to the Customer, and directly assigned upgrade cost to the Customer. In addition, Table 2 identifies any SWPA upgrade costs that require prepayment in addition to other allocated costs.

#### **TABLE 3**

Table 3 provides additional details for each request including all assigned facility upgrades required, allocated E&C costs, allocated revenue requirements for upgrades, upgrades not assigned to the Customer but required for service to be confirmed, credits to be paid for previously assigned AFS or Generation Interconnection Network Upgrades, and any required third party upgrades.

#### **TABLE 4**

Table 4 lists all upgrade requirements with associated solutions needed to provide Transmission Service for the AFS, earliest date upgrade is required (DUN), estimated date the upgrade will be completed and in service (EOC), and estimated E&C cost.

#### **TABLE 5**

Table 5 lists identified third-party constrained facilities.

#### **TABLE 6**

Reserved

**TABLE 7**

Table 7 lists costs allocated per request for Service Upgrades assigned in this AFS.

**BASE PLAN UPGRADES**

The potential base plan funding allowable is contingent on meeting each of the conditions for classifying upgrades associated with designated resources as Base Plan Upgrades as defined in Section III.B of Attachment J. If the additional capacity of the new or changed Designated Resource exceeds the 125% resource to load forecast for the year of start of service, the requested resource is not eligible for base plan funding of required Network Upgrades and the full cost of the upgrades is assignable to the Customer.

If the request is for wind generation, the total requested capacity of wind generation plus existing wind generation capacity shall not exceed 20% of the customer's projected system peak responsibility in the first year the Designated Resource is planned to be used by the customer. If the five-year term and 125% resource to load criteria are met, (as well as the 20% wind resource to load criteria for wind generation requests) the requested capacity is multiplied by \$180,000 to determine the potential base plan funding allowable. The maximum potential base plan funding allowable may be less than the potential base plan funding allowable, due to the E&C cost allocated to the customer being lower than the potential amount allowable to the Customer. The Customer is responsible for any assigned upgrade costs in excess of potential base plan E&C funding allowable. Network Upgrades required for wind generation requests located in a zone other than the Customer's Point of Delivery (POD) shall be allocated as 67% base plan region-wide charge and 33% directly assigned to the Customer.

Regarding application of base plan funding for PTP requests, if PTP base rate exceeds upgrade revenue requirements without taking into effect the reduction of revenue requirements by potential base plan funding, then the base rate revenue pays back the Transmission Owner for upgrades and no base plan funding is applicable as the access charge must be paid as it is the higher of "OR" pricing.

However, if initially the upgrade revenue requirements exceed the PTP base rate, then potential base plan funding would be applicable. The test of the higher of "OR" pricing would then be made against the remaining assignable revenue requirements versus PTP base rate. Examples are as follows:

***Example A:***

E&C allocated for upgrades is \$74 million with revenue requirements of \$140 million and PTP base rate of \$101 million. Potential base plan funding is \$47 million, with the difference of \$27 million E&C assignable to the Customer. If the revenue requirements for the assignable portion is \$54 million and the PTP base rate is \$101 million, the Customer will pay the higher amount (so-called "or pricing") of \$101 million base rate of which \$54 million revenue requirements will be paid back to the Transmission Owners for the upgrades, and the remaining revenue requirements of \$86 million (\$140 million less \$54 million) will be paid by base plan funding.

***Example B:***

E&C allocated for upgrades is \$74 million with revenue requirements of \$140 million and PTP base rate of \$101 million. Potential base plan funding is \$10 million with the difference of \$64 million

E&C assignable to the Customer. If the revenue requirements for this assignable portion is \$128 million and the PTP base rate is \$101 million, the Customer will pay the higher amount of \$128 million revenue requirements to be paid back to the Transmission Owners, and the remaining revenue requirements of \$12 million (\$140 million less \$128 million) will be paid by base plan funding.

***Example C:***

E&C allocated for upgrades is \$25 million with revenue requirements of \$50 million and PTP base rate of \$101 million. Potential base plan funding is \$10 million. Base plan funding is not applicable as the higher amount of PTP base rate of \$101 million must be paid and the \$50 million revenue requirements will be paid from this.

The 125% resource to load determination is performed on a per-request basis and is not based on a total of Designated Resource requests per Customer.

***STUDY DEFINITIONS***

- The date upgrade needed date (DUN) is the earliest date the upgrade is required to alleviate a constraint considering all requests.
- End of construction (EOC) is the estimated date the upgrade will be completed and in service.
- Total engineering and construction cost (E&C) is the upgrade solution cost as determined by the Transmission Owner.
- The Transmission Customer's allocation of the E&C cost is based on the request (1) having an impact of at least 3% on the limiting element, and (2) having a positive impact on the upgraded facility.

## CONCLUSION

---

The results of the AFS show limiting constraints on the regional Transmission System.

SPP will accept the requests in which the specified study parameters were met and will tender a Service Agreement for each of these requests identifying the terms and conditions of the confirmed service. SPP has refused all requests in which the parameters were exceeded.



## APPENDIX A

---

### PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

#### *BASE CASE SETTINGS:*

- Solutions: Fixed slope decoupled Newton-Raphson solution (FDNS)
- Tap adjustment: Stepping
- Area Interchange Control: Tie lines and loads
- Var limits: Apply immediately
- Solution Options:
  - Phase shift adjustment
  - Flat start
  - Lock DC taps
  - Lock switched shunts

#### *ACCC CASE SETTINGS:*

- Solutions: AC contingency checking (ACCC)
- MW mismatch tolerance: 0.5
- System intact rating: Rate A
- Contingency case rating: Rate B
- Percent of rating: 100
- Output code: Summary
- Min flow change in overload report: 3 MW
- Excl'd cases w/ no overloads from report: YES
- Exclude interfaces from report: NO
- Perform voltage limit check: YES
- Elements in available capacity table: 60000
- Cutoff threshold for available capacity table: 99999.0
- Min. contng. Case Vltg chng for report: 0.02
- Sorted output: None
- Newton Solution: Stepping
- Tap adjustment: Tie lines and loads (Disabled for generator outages)
- Area interchange control: Apply immediately
- Var limits:  Phase shift adjustment
- Solution options:
  - Flat start
  - Lock DC taps
  - Lock switched shunts

**Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study**

Customer	Study Number	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date without interim redispatch (Parameter)	Deferred Stop Date without interim redispatch	Start Date with interim redispatch	Stop Date with interim redispatch	<sup>5</sup> One or More Study Parameters Exceeded
AEPM	AG1-2019-001	88844850	CSWS	EES	181	1/1/2020	1/1/2025	1/1/2020	1/1/2025	1/1/2020	1/1/2025	NO
BEPM	AG1-2019-005	88489552	WAUE	WAUE	45	10/1/2023	10/1/2035	10/1/2023	10/1/2035	Note 4	Note 4	NO
BEPM	AG1-2019-006	88512339	WAUE	WAUE	140	10/1/2023	10/1/2035	10/1/2023	10/1/2035	Note 4	Note 4	NO
BRPS	AG1-2019-007	89203861	OKGE	NPPD	20	6/1/2021	6/1/2026	6/1/2021	6/1/2026	6/1/2021	6/1/2026	NO
BRPS	AG1-2019-008	89204005	WAUE	NPPD	1	1/1/2020	1/1/2049	1/1/2020	1/1/2049	1/1/2020	1/1/2049	NO
EDE	AG1-2019-009	89219628	EDE	EDE	150	7/1/2020	7/1/2040	7/1/2020	7/1/2040	7/1/2020	7/1/2040	NO
EDE	AG1-2019-010	89219810	X	EDE	301	11/1/2020	11/1/2040	11/1/2020	11/1/2040	11/1/2020	11/1/2040	NO
EDE	AG1-2019-011	89220085	EDE	EDE	150	10/1/2020	10/1/2040	10/1/2020	10/1/2040	10/1/2020	10/1/2040	NO
ETEC	AG1-2019-012	89073059	OKGE	CSWS	23	6/1/2020	10/1/2040	6/1/2020	10/1/2040	6/1/2020	10/1/2040	NO
ETEC	AG1-2019-013	89073070	OKGE	CSWS	76	6/1/2020	10/1/2040	6/1/2020	10/1/2040	6/1/2020	10/1/2040	NO
INDP	AG1-2019-014	89183980	CSWS	KCPL	60	6/1/2020	6/1/2030	6/1/2020	6/1/2030	6/1/2020	6/1/2030	NO
KMEA	AG1-2019-015	89210890	GRDA	SECI	9	1/1/2021	1/1/2026	1/1/2021	1/1/2026	1/1/2021	1/1/2026	NO
MCPI	AG1-2019-016	88109856	WFEC	ERCOTN	100	7/1/2021	9/1/2022	7/1/2021	9/1/2022	7/1/2021	9/1/2022	NO
MCPI	AG1-2019-017	88109857	WFEC	ERCOTN	120	7/1/2021	9/1/2022	7/1/2021	9/1/2022	7/1/2021	9/1/2022	NO
MCPI	AG1-2019-018	88109858	CSWS	ERCOTE	100	7/1/2021	9/1/2022	7/1/2021	9/1/2022	7/1/2021	9/1/2022	NO
OGE	AG1-2019-026	89175798	OKGE	OKGE	320	12/1/2019	12/1/2040	12/1/2019	12/1/2040	12/1/2019	12/1/2040	NO
OPPM	AG1-2019-027	88405091	OPPD	OPPD	150	6/1/2020	6/1/2022	6/1/2020	6/1/2022	6/1/2020	6/1/2022	NO
SPSM	AG1-2019-029	89170351	SPS	SPS	150	12/1/2019	12/1/2048	12/1/2019	12/1/2048	Note 4	Note 4	NO
SSCN	AG1-2019-030	89162227	OKGE	NPPD	8	1/1/2022	1/1/2031	1/1/2022	1/1/2031	Note 4	Note 4	NO
SSCN	AG1-2019-031	89162887	LES	NPPD	13	1/1/2020	1/1/2025	1/1/2020	1/1/2025	1/1/2020	1/1/2025	NO
WFEC	AG1-2019-037	89038173	OKGE	WFEC	250	12/1/2019	5/1/2049	12/1/2019	5/1/2049	Note 4	Note 4	NO
WRGS	AG1-2019-039	89210446	WR	WR	35	1/1/2020	1/1/2025	1/1/2020	1/1/2025	1/1/2020	1/1/2025	NO
WRGS	AG1-2019-040	89217003	SECI	WR	80	1/1/2020	1/1/2025	1/1/2020	1/1/2025	1/1/2020	1/1/2025	NO

2482

**Requests with Study Parameters Exceeded**

APM	AG1-2019-002	89182016	X	SPA	10	1/1/2020	1/1/2025	1/1/2020	1/1/2025	Note 4	Note 4	YES
APM	AG1-2019-003	89183931	X	OKGE	17	1/1/2020	1/1/2025	1/1/2020	1/1/2025	Note 4	Note 4	YES
APM	AG1-2019-004	89183944	X	CSWS	58	1/1/2020	1/1/2025	1/1/2020	1/1/2025	Note 4	Note 4	YES
MCPI	AG1-2019-019	88109859	CSWS	ERCOTE	100	7/1/2021	9/1/2022	12/1/2021	2/1/2023	12/1/2021	2/1/2023	YES
MCPI	AG1-2019-020	88109862	CSWS	ERCOTE	50	7/1/2021	9/1/2022	7/1/2021	9/1/2022	7/1/2021	9/1/2022	YES
MCPI	AG1-2019-021	88109863	CSWS	ERCOTE	50	7/1/2021	9/1/2022	7/1/2021	9/1/2022	7/1/2021	9/1/2022	YES
MCPI	AG1-2019-022	88109864	CSWS	ERCOTE	50	7/1/2021	9/1/2022	7/1/2021	9/1/2022	7/1/2021	9/1/2022	YES
MCPI	AG1-2019-023	88109865	CSWS	ERCOTE	50	7/1/2021	9/1/2022	12/1/2021	2/1/2023	12/1/2021	2/1/2023	YES
MCPI	AG1-2019-024	88109866	CSWS	ERCOTE	100	7/1/2021	9/1/2022	12/1/2021	2/1/2023	12/1/2021	2/1/2023	YES
MCPI	AG1-2019-025	88109871	CSWS	ERCOTE	50	7/1/2021	9/1/2022	12/1/2021	2/1/2023	12/1/2021	2/1/2023	YES
SPRM	AG1-2019-028	89227031	SPA	SPRM	50	4/1/2020	4/1/2050	12/1/2021	12/1/2051	12/1/2021	12/1/2051	YES
TNSK	AG1-2019-032	88109881	CSWS	ERCOTE	50	7/1/2020	9/1/2021	6/1/2023	8/1/2024	6/1/2023	8/1/2024	YES
TNSK	AG1-2019-033	88109886	CSWS	ERCOTE	50	7/1/2021	9/1/2022	6/1/2023	8/1/2024	6/1/2023	8/1/2024	YES
TNSK	AG1-2019-034	88109895	CSWS	ERCOTE	50	7/1/2020	9/1/2021	6/1/2023	8/1/2024	6/1/2023	8/1/2024	YES
TNSK	AG1-2019-035	88109896	CSWS	ERCOTE	50	7/1/2020	9/1/2021	6/1/2023	8/1/2024	6/1/2023	8/1/2024	YES
TNSK	AG1-2019-036	88109897	CSWS	ERCOTE	50	7/1/2020	9/1/2021	6/1/2023	8/1/2024	6/1/2023	8/1/2024	YES
WRGS	AG1-2019-038	89210410	WR	WR	125	1/1/2020	1/1/2025	1/1/2020	1/1/2025	1/1/2020	1/1/2025	YES
WRGS	AG1-2019-041	89217294	WR	WR	6	1/1/2020	1/1/2025	1/1/2020	1/1/2025	1/1/2020	1/1/2025	YES

966

**Note 1:** Start and Stop Dates with interim redispatch are determined based on customers choosing option to pursue redispatch to start service at Requested Start and Stop Dates or earliest date possible.

**Note 2:** Start dates with and without redispatch are based on the assumed completion dates of previous Aggregate Transmission Service Studies currently being conducted. Actual start dates may differ from the potential start dates upon completion of

**Table 1 - Long-Term Transmission Service Requests Included in Aggregate Facility Study**

<b>Note 3:</b> Request is unable to be deferred due to fixed stop dates.
<b>Note 4:</b> Transmission customer did not select "remain in the study using interim redispatch" option.
<b>Note 5:</b> Request paramaters have been exceeded.

Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests

Customer	Study Number	Reservation	Engineering and Construction Cost of Upgrades Allocated to Customer for Revenue Requirements	<sup>1</sup> Letter of Credit Amount Required (Parameter)	<sup>2</sup> Potential Base Plan Engineering and Construction Funding Allowable	Notes	<sup>4</sup> Additional Engineering and Construction Cost for 3rd Party Upgrades (Parameter)	<sup>3</sup> Total Revenue Requirements for Assigned Service Upgrades Over Term of Reservation NOT COVERED by Base Plan Funding	<sup>3,5</sup> Total Revenue Requirements for Assigned Service Upgrades Over Term of Reservation COVERED by Base Plan Funding	<sup>6,7</sup> Total Gross CPOs for Creditable Upgrades Over Reservation Period NOT COVERED by Base Plan Funding	<sup>5,6,7</sup> Total Gross CPOs for Creditable Upgrades Over Reservation Period COVERED by Base Plan Funding	<sup>4,9</sup> Point-to-Point Base Rate Available to Offset Revenue Requirements Over Reservation Period	<sup>4</sup> Total Cost of Reservation Assignable to Customer Contingent Upon Base Plan Funding	Directly Assigned Upgrade Cost (DAUC) (Parameter)
AEPM	AG1-2019-001	88844850	\$131,768	\$0	\$131,768		\$0	\$0	\$0	\$0	\$511,735	\$0	Schedule 9 & 11 Charges	\$0
BEPM	AG1-2019-005	88489552	\$0	\$0	\$0		\$0	\$0	\$0	\$0	\$0	\$0	Schedule 9 & 11 Charges	\$0
BEPM	AG1-2019-006	88512339	\$129,080	\$0	\$129,080		\$0	\$0	\$0	\$0	\$214,435	\$0	Schedule 9 & 11 Charges	\$0
BRPS	AG1-2019-007	89203861	\$53,023	\$51,426	\$1,597		\$0	\$0	\$0	\$225,059	\$1,912	\$0	\$225,059	\$51,426
BRPS	AG1-2019-008	89204005	\$626	\$0	\$626		\$0	\$0	\$0	\$0	\$1,162	\$0	Schedule 9 & 11 Charges	\$0
EDE	AG1-2019-009	89219628	\$4,304,274	\$4,304,274	\$0		\$0	\$11,086,152	\$0	\$0	\$0	\$0	\$11,086,152	\$4,304,274
EDE	AG1-2019-010	89219810	\$23,765,289	\$23,765,289	\$0		\$0	\$62,834,280	\$0	\$606,382	\$0	\$0	\$63,440,662	\$23,765,289
EDE	AG1-2019-011	89220085	\$4,445,215	\$4,445,215	\$0		\$0	\$11,697,277	\$0	\$0	\$0	\$0	\$11,697,277	\$4,445,215
ETEC	AG1-2019-012	89073059	\$56,245	\$0	\$56,245		\$0	\$0	\$0	\$0	\$388,489	\$0	Schedule 9 & 11 Charges	\$0
ETEC	AG1-2019-013	89073070	\$185,851	\$0	\$185,851		\$0	\$0	\$0	\$0	\$1,283,686	\$0	Schedule 9 & 11 Charges	\$0
INDP	AG1-2019-014	89183980	\$94,681	\$94,681	\$0		\$0	\$0	\$0	\$627,845	\$0	\$0	\$627,845	\$94,681
KMEA	AG1-2019-015	89210890	\$28,374	\$0	\$28,374		\$0	\$0	\$0	\$0	\$149,917	\$0	Schedule 9 & 11 Charges	\$0
MCPI	AG1-2019-016	88109856	\$0	\$0	\$0		\$0	\$0	\$0	\$124,296	\$0	\$6,595,698	\$6,595,698	\$0
MCPI	AG1-2019-017	88109857	\$0	\$0	\$0		\$0	\$0	\$0	\$124,296	\$0	\$7,914,838	\$7,914,838	\$0
MCPI	AG1-2019-018	88109858	\$0	\$0	\$0		\$0	\$0	\$0	\$0	\$0	\$6,595,698	\$6,595,698	\$0
OGE	AG1-2019-026	89175798	\$999,545	\$0	\$999,545		\$0	\$0	\$0	\$0	\$5,747,440	\$0	Schedule 9 & 11 Charges	\$0
OPPM	AG1-2019-027	88405091	\$0	\$0	\$0		\$0	\$0	\$0	\$0	\$0	\$0	Schedule 9 & 11 Charges	\$0
SPSM	AG1-2019-029	89170351	\$802,702	\$801,324	\$1,378		\$0	\$0	\$0	\$1,433,454	\$2,506	\$0	\$1,433,454	\$801,324
SSCN	AG1-2019-030	89162227	\$275,237	\$4,865	\$270,372		\$0	\$0	\$0	\$32,223	\$453,742	\$0	\$32,223	\$4,865
SSCN	AG1-2019-031	89162887	\$2,247	\$0	\$2,247		\$0	\$0	\$0	\$0	\$2,712	\$0	Schedule 9 & 11 Charges	\$0
WFEC	AG1-2019-037	89038173	\$1,830,607	\$1,745,482	\$85,125		\$0	\$0	\$0	\$10,743,516	\$157,374	\$0	\$10,743,516	\$1,745,482
WRGS	AG1-2019-039	89210446	\$1,386,391	\$1,343,885	\$42,506		\$0	\$0	\$0	\$1,816,336	\$57,345	\$0	\$1,816,336	\$1,343,885
WRGS	AG1-2019-040	89217003	\$1,410,852	\$1,350,771	\$60,081		\$0	\$0	\$0	\$2,404,612	\$81,954	\$0	\$2,404,612	\$1,350,771
<b>Grand Total</b>			<b>\$39,902,006</b>	<b>\$37,907,212</b>	<b>\$1,994,794</b>		<b>\$0</b>	<b>\$85,617,709</b>	<b>\$0</b>	<b>\$18,138,019</b>	<b>\$9,054,410</b>			<b>\$37,907,212</b>
<b>Requests with Study Parameters Exceeded</b>														
APM	AG1-2019-002	89182016	\$105,276	\$105,276	\$0		\$0	\$114,588	\$0	\$108,011	\$0	\$0	\$222,599	\$105,276
APM	AG1-2019-003	89183931	\$152,189	\$152,189	\$0		\$0	\$148,915	\$0	\$200,985	\$0	\$0	\$349,900	\$152,189
APM	AG1-2019-004	89183944	\$664,491	\$664,491	\$0		\$0	\$537,853	\$0	\$843,632	\$0	\$0	\$1,381,485	\$664,491
MCPI	AG1-2019-019	88109859	\$0	\$0	\$0		\$1,854,069	\$0	\$0	\$0	\$0	\$6,598,036	\$6,598,036	\$0
MCPI	AG1-2019-020	88109862	\$0	\$0	\$0		\$1,005,249	\$0	\$0	\$0	\$0	\$3,299,018	\$3,299,018	\$0
MCPI	AG1-2019-021	88109863	\$0	\$0	\$0		\$1,005,249	\$0	\$0	\$0	\$0	\$3,299,018	\$3,299,018	\$0
MCPI	AG1-2019-022	88109864	\$0	\$0	\$0		\$1,005,249	\$0	\$0	\$0	\$0	\$3,299,018	\$3,299,018	\$0
MCPI	AG1-2019-023	88109865	\$0	\$0	\$0		\$927,035	\$0	\$0	\$0	\$0	\$3,299,018	\$3,299,018	\$0
MCPI	AG1-2019-024	88109866	\$0	\$0	\$0		\$1,854,069	\$0	\$0	\$0	\$0	\$6,598,036	\$6,598,036	\$0
MCPI	AG1-2019-025	88109871	\$0	\$0	\$0		\$927,035	\$0	\$0	\$0	\$0	\$3,299,018	\$3,299,018	\$0
SPRM	AG1-2019-028	89227031	\$327,989	\$0	\$327,989		\$3,535,254	\$0	\$1,420,510	\$0	\$0	\$0	Schedule 9 & 11 Charges	\$0
TNSK	AG1-2019-032	88109881	\$20,000,000	\$20,000,000	\$0		\$1,005,249	\$40,000,000	\$0	\$0	\$0	\$3,299,018	\$40,000,000	\$20,000,000
TNSK	AG1-2019-033	88109886	\$20,000,000	\$20,000,000	\$0		\$1,005,249	\$40,000,000	\$0	\$0	\$0	\$3,299,018	\$40,000,000	\$20,000,000
TNSK	AG1-2019-034	88109895	\$20,000,000	\$20,000,000	\$0		\$1,005,249	\$40,000,000	\$0	\$0	\$0	\$3,299,018	\$40,000,000	\$20,000,000
TNSK	AG1-2019-035	88109896	\$20,000,000	\$20,000,000	\$0		\$1,005,249	\$40,000,000	\$0	\$0	\$0	\$3,299,018	\$40,000,000	\$20,000,000
TNSK	AG1-2019-036	88109897	\$20,000,000	\$20,000,000	\$0		\$1,005,249	\$40,000,000	\$0	\$0	\$0	\$3,299,018	\$40,000,000	\$20,000,000
WRGS	AG1-2019-038	89210410	\$17,018,797	\$16,954,873	\$63,924		\$0	\$0	\$0	\$21,278,410	\$86,650	\$0	\$21,278,410	\$16,954,873
WRGS	AG1-2019-041	89217294	\$12,282,367	\$12,278,390	\$3,977		\$0	\$12,443,134	\$0	\$27,192	\$5,425	\$0	\$12,470,326	\$12,278,390
<b>Grand Total</b>			<b>\$130,551,109</b>	<b>\$130,155,218</b>	<b>\$395,890</b>		<b>\$17,139,451</b>	<b>\$213,244,491</b>	<b>\$0</b>	<b>\$22,458,229</b>	<b>\$92,075</b>			<b>\$130,155,218</b>

**Table 2 - Total Revenue Requirements Associated with Long-Term Transmission Service Requests**

<p><b>Note 1:</b> Letter of Credit required for financial security for transmission owner for network upgrades is determined by allocated engineering and construction costs less engineering and construction costs for upgrades when network customer is the transmission owner less the E &amp; C allocation of expedited projects. Letter of Credit is required for upgrades assigned to PTP requests. The amount of the letter of credit will be adjusted down on an annual basis to reflect cost recovery based on revenue allocation. This letter of credit is not required for those facilities that are fully base plan funded. The Letter Of Credit Amount listed is based on meeting OATT Attachment J requirements for base plan funding.</p>
<p><b>Note 2:</b> If potential base plan funding is applicable, this value is the lesser of the Engineering and Construction costs of assignable upgrades or the value of base plan funding calculated pursuant to Attachment J, Section III B criteria. Allocation of base plan funding is contingent upon verification of customer agreements meeting Attachment J, Section II B criteria. Not applicable if Point-to-Point base rate exceeds revenue requirements.</p>
<p><b>Note 3:</b> Revenue Requirements (RR) are based upon deferred end dates if applicable. Deferred dates are based upon customer's choice to pursue redispatch. Achievable Base Plan Avoided RR in the case of a Base Plan upgrade being displaced or deferred by an earlier in service date for a Requested Upgrade shall be determined per Attachment J, Section VII.C methodology. Assumption of a 40 year service life is utilized for Base Plan funded projects. A present worth analysis of RR on a common year basis between the Base Plan and Requested Upgrades was performed to determine avoided Base Plan RR due to the displacement or deferral of the Base Plan upgrade by the Requested Upgrade. The incremental increase in present worth of a Requested Upgrade on a common year basis as a Base Plan upgrade is assigned to the transmission requests impacting the upgrade based on the displacement or deferral. If the displacement analysis results in lower RR due to the shorter amortization period of the requested upgrade when compared to a base plan amortization period, then no direct assignment of the upgrade cost is made due to the displacement to an earlier start date.</p>
<p><b>Note 4:</b> For Point-to-Point requests, total cost is based on the higher of the base rate <b>OR</b> assigned upgrade revenue requirements. For Network requests, the total cost is based on the directly assigned upgrade revenue requirements <b>AND</b> Schedules 1, 1A, 2, 9, 11, &amp; 12 charges. Network cost amounts populated in this column are reduced by offsets (if available) from base plan funding, which is determined using Attachment J, Section II B Criteria. Additionally E &amp; C of 3rd Party upgrades is assignable to Customer. This includes prepayments required for any SWPA upgrades. Revenue requirements for 3rd Party facilities are not calculated. Total cost to customer is based on assumption of Revenue Requirements with confirmation of base plan funding. Customer is responsible for negotiating redispatch costs if applicable. Customer is also responsible to pay credits for previously assigned upgrades that are impacted by their request. Credits can be paid from base plan funding if applicable.</p>
<p><b>Note 5:</b> RR with base plan funding may increase or decrease even if no base plan funding is applicable to a particular request if another request that shares the upgrade is now full base plan funded resulting in a different amortization period for the upgrade and thus different RR.</p>
<p><b>Note 6:</b> RR for creditable upgrades.</p>
<p><b>Note 7:</b> CPOs for creditable upgrades may be calculated based on estimated upgrade cost and are subject to change.</p>
<p><b>Note 8:</b> CPOs for creditable upgrade(s) may be required based on completion of GI review.</p>
<p><b>Note 9:</b> Point-To-Point Base Rate used to offset Revenue Requirements are calculated using the following available rate(s): Schedule 7, Schedule 11 Base Plan Zonal, Schedule 11 Base Plan Regional. The ancillary rates (Schedules 1, 1A, 2, and 12) are not included in the Point-to-Point Base Rate. These rate(s) are subject to change.</p>

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 AEPM AG1-2019-001

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
AEPM	88844850	CSWS	EES	181	1/1/2020	1/1/2025	1/1/2020	1/1/2025	\$ 131,768	\$ -	\$ 131,768	\$ 511,735
									\$ 131,768	\$ -	\$ 131,768	\$ 511,735

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88844850	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total Revenue Requirements
88844850	HUGO - VALLIANT 345KV CKT 1	7/1/2012	7/1/2012			\$ 110,368	\$ 437,132
	Valliant 345 kV (AEP)	4/17/2012	4/17/2012			\$ 21,400	\$ 74,602
<b>Total</b>						\$ 131,768	\$ 511,735

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 BEPM AG1-2019-005

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
BEPM	88489552	WAUE	WAUE	45	10/1/2023	10/1/2035	10/1/2023	10/1/2035	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88489552	None					\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 BEPM AG1-2019-006

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
BEPM	88512339	WAUE	WAUE	140	10/1/2023	10/1/2035	10/1/2023	10/1/2035	\$ 129,080	\$ -	\$ 129,080	\$ 214,435
									\$ 129,080	\$ -	\$ 129,080	\$ 214,435

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88512339	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total Revenue Requirements
88512339	Fort Randall - Madison County 230kV Ckt 1	12/23/2013	12/23/2013			\$ 129,080	\$ 214,435
Total						\$ 129,080	\$ 214,435

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.





**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
BRPS AG1-2019-008

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
BRPS	89204005	WAUE	NPPD	1	1/1/2020	1/1/2049	1/1/2020	1/1/2049	\$ 626	\$ -	\$ 626	\$ 1,162
									\$ 626	\$ -	\$ 626	\$ 1,162

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89204005	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total Revenue Requirements
89204005	Kelly - Madison County 230kV Ckt 1	11/1/2014	11/1/2014			\$ 559	\$ 1,051
	Twin Church - Dixon County 230kV Line Upgrade	11/1/2018	11/1/2018			\$ 68	\$ 111
<b>Total</b>						\$ 626	\$ 1,162

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 EDE AG1-2019-009

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
EDE	89219628	EDE	EDE	150	7/1/2020	7/1/2040	7/1/2020	7/1/2040	\$ -	\$ -	\$ 4,304,274	\$ 11,086,152
									\$ -	\$ -	\$ 4,304,274	\$ 11,086,152

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89219628	Neosho - Riverton 161kV Line Rebuild (EMDE)	10/1/2023	10/1/2023			\$ -	\$ 3,767,680	\$ 3,767,680	\$ 28,410,000	\$ 9,633,060
	Neosho - Riverton 161kV Line Rebuild (WERE)	10/1/2023	10/1/2023			\$ -	\$ 536,594	\$ 536,594	\$ 4,046,161	\$ 1,453,093
	Total					\$ -	\$ 4,304,274	\$ 4,304,274	\$ 32,456,161	\$ 11,086,152

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
EDE AG1-2019-010

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
EDE	89219810	X	EDE	301	11/1/2020	11/1/2040	11/1/2020	11/1/2040	\$ -	\$ -	\$ 23,765,289	\$ 63,440,661
									\$ -	\$ -	\$ 23,765,289	\$ 63,440,661

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89219810	Neosho - Riverton 161kV Line Rebuild (EMDE)	10/1/2023	10/1/2023			\$ -	\$ 20,751,270	\$ 20,751,270	\$ 28,410,000	\$ 54,632,461
	Neosho - Riverton 161kV Line Rebuild (WERE)	10/1/2023	10/1/2023			\$ -	\$ 2,955,402	\$ 2,955,402	\$ 4,046,161	\$ 8,201,818
	<b>Total</b>					\$ -	\$ 23,706,672	\$ 23,706,672	\$ 32,456,161	\$ 62,834,279

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total Revenue Requirements
89219810	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006			\$ -	\$ 29,258	\$ 29,258	\$ 415,939
	SUB 110 - ORONOGO JCT. - SUB 452 - RIVERTON 161KV CKT 1	6/1/2011	6/1/2011			\$ -	\$ 29,358	\$ 29,358	\$ 190,442
	<b>Total</b>					\$ -	\$ 58,617	\$ 58,617	\$ 606,382

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 EDE AG1-2019-011

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
EDE	89220085	EDE	EDE	150	10/1/2020	10/1/2040	10/1/2020	10/1/2040	\$ -	\$ -	\$ 4,445,215	\$ 11,697,277
									\$ -	\$ -	\$ 4,445,215	\$ 11,697,277

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89220085	Neosho - Riverton 161kV Line Rebuild (EMDE)	10/1/2023	10/1/2023			\$ -	\$ 3,891,050	\$ 3,891,050	\$ 28,410,000	\$ 10,168,861
	Neosho - Riverton 161kV Line Rebuild (WERE)	10/1/2023	10/1/2023			\$ -	\$ 554,165	\$ 554,165	\$ 4,046,161	\$ 1,528,416
Total						\$ -	\$ 4,445,215	\$ 4,445,215	\$ 32,456,161	\$ 11,697,277

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 ETEC AG1-2019-012

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
ETEC	89073059	OKGE	CSWS	23	6/1/2020	10/1/2040	6/1/2020	10/1/2040	\$ 56,245	\$ -	\$ 56,245	\$ 388,489
									\$ 56,245	\$ -	\$ 56,245	\$ 388,489

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89073059	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total Revenue Requirements
89073059	HUGO - VALLIANT 345KV CKT 1	7/1/2012	7/1/2012			\$ 39,811	\$ -	\$ 39,811	\$ 280,693
	HUGO 345/138KV TRANSFORMER CKT 1	7/1/2012	7/1/2012			\$ 8,700	\$ -	\$ 8,700	\$ 60,902
	Valliant 345 kV (AEP)	4/17/2012	4/17/2012			\$ 7,734	\$ -	\$ 7,734	\$ 46,894
<b>Total</b>						\$ 56,245	\$ -	\$ 56,245	\$ 388,489

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 ETEC AG1-2019-013

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
ETEC	89073070	OKGE	CSWS	76	6/1/2020	10/1/2040	6/1/2020	10/1/2040	\$ 185,851	\$ -	\$ 185,851	\$ 1,283,686
									\$ 185,851	\$ -	\$ 185,851	\$ 1,283,686

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89073070	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total Revenue Requirements
89073070	HUGO - VALLIANT 345KV CKT 1	7/1/2012	7/1/2012			\$ 131,549	\$ -	\$ 131,549	\$ 927,505
	HUGO 345/138KV TRANSFORMER CKT 1	7/1/2012	7/1/2012			\$ 28,745	\$ -	\$ 28,745	\$ 201,229
	Valliant 345 kV (AEP)	4/17/2012	4/17/2012			\$ 25,557	\$ -	\$ 25,557	\$ 154,952
<b>Total</b>						\$ 185,851	\$ -	\$ 185,851	\$ 1,283,686

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 INDP AG1-2019-014

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
INDP	89183980	CSWS	KCPL	60	6/1/2020	6/1/2030	6/1/2020	6/1/2030	\$ -	\$ -	\$ 94,681	\$ 627,845
									\$ -	\$ -	\$ 94,681	\$ 627,845

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89183980	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total Revenue Requirements
89183980	COFFEYVILLE TAP - DEARING 138KV CKT 1 (WR) #2	6/9/2010	6/9/2010			\$ 18	\$ 102
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006			\$ 16,090	\$ 155,978
	NORTHWEST - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010			\$ 78,573	\$ 471,764
<b>Total</b>						\$ 94,681	\$ 627,845

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
KMEA AG1-2019-015

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
KMEA	89210890	GRDA	SECI	9	1/1/2021	1/1/2026	1/1/2021	1/1/2026	\$ 28,374	\$ -	\$ 28,374	\$ 149,917
									\$ 28,374	\$ -	\$ 28,374	\$ 149,917

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89210890	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total Revenue Requirements
89210890	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006			\$ 791	\$ 6,640
	NORTHWEST - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010			\$ 27,072	\$ 141,176
	SUB 110 - ORONOGO JCT. - SUB 452 - RIVERTON 161KV CKT 1	6/1/2011	6/1/2011			\$ 510	\$ 2,101
Total						\$ 28,374	\$ 149,917

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 MCPI AG1-2019-016

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MCPI	88109856	WFEC	ERCOTN	100	7/1/2021	9/1/2022	7/1/2021	9/1/2022	\$ -	\$ 6,595,698	\$ 124,296	\$ 124,296
									\$ -	\$ 6,595,698	\$ 124,296	\$ 124,296

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109856	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total Revenue Requirements
88109856	POWER SYSTEM STABILIZERS IN SPS	11/30/2014	11/30/2014			\$ 124,296	\$ 124,296
					Total	\$ 124,296	\$ 124,296

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 MCPI AG1-2019-017

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MCPI	88109857	WFEC	ERCOTN	120	7/1/2021	9/1/2022	7/1/2021	9/1/2022	\$ -	\$ 7,914,838	\$ 124,296	\$ 124,296
									\$ -	\$ 7,914,838	\$ 124,296	\$ 124,296

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109857	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total Revenue Requirements
88109857	POWER SYSTEM STABILIZERS IN SPS	11/30/2014	11/30/2014			\$ 124,296	\$ 124,296
					Total	\$ 124,296	\$ 124,296

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 MCPI AG1-2019-018

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MCPI	88109858	CSWS	ERCOTE	100	7/1/2021	9/1/2022	7/1/2021	9/1/2022	\$ -	\$ 6,595,698	\$ -	\$ -
									\$ -	\$ 6,595,698	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109858	None					\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 OGE AG1-2019-026

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
OGE	89175798	OKGE	OKGE	320	12/1/2019	12/1/2040	12/1/2019	12/1/2040	\$ 999,545	\$ -	\$ 999,545	\$ 5,747,440
									\$ 999,545	\$ -	\$ 999,545	\$ 5,747,440

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89175798	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total Revenue Requirements
89175798	EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 (AEP)	3/23/2009	3/23/2009			\$ 14,940	\$ 133,484
	BEELINE - EXPLORER GLENPOOL 138KV CKT 1	6/1/2009	6/1/2009			\$ 30,681	\$ 274,121
	EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 (OGE)	6/1/2009	6/1/2009			\$ 39,990	\$ 305,245
	HUGO - VALLIANT 345KV CKT 1	7/1/2012	7/1/2012			\$ 167,350	\$ 1,153,911
	Kingfisher Co Tap - Mathewson 345kv CKT 1	3/1/2018	3/1/2018			\$ 207,817	\$ 339,406
	NORTHWEST - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010			\$ 377,989	\$ 3,145,416
	Valliant 345 kV (AEP)	4/17/2012	4/17/2012			\$ 32,435	\$ 192,601
	Woodward EHV 138kV Phase Shifting Transformer circuit #1	8/2/2017	8/2/2017			\$ 128,343	\$ 203,256
<b>Total</b>						\$ 999,545	\$ 5,747,440

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 OPPM AG1-2019-027

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
OPPM	88405091	OPPD	OPPD	150	6/1/2020	6/1/2022	6/1/2020	6/1/2022	\$ -	\$ -	\$ -	\$ -
									\$ -	\$ -	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88405091	None					\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
SPSM AG1-2019-029

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SPSM	89170351	SPS	SPS	150	12/1/2019	12/1/2048	12/1/2019	12/1/2048	\$ 1,378	\$ -	\$ 802,702	\$ 1,435,959
									\$ 1,378	\$ -	\$ 802,702	\$ 1,435,959

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89170351	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total Revenue Requirements
89170351	PLANT X - TOLK 230KV REBUILD CIRCUIT #1	12/31/2017	12/31/2017			\$ -	\$ 118,281	\$ 118,281	\$ 211,587
	PLANT X - TOLK 230KV REBUILD CIRCUIT #2	12/31/2017	12/31/2017			\$ -	\$ 114,674	\$ 114,674	\$ 205,136
	POWER SYSTEM STABILIZERS IN SPS	11/30/2014	11/30/2014			\$ 1,378	\$ -	\$ 1,378	\$ 2,506
	TUCO INTERCHANGE 345/230KV CKT 1 REPLACEMENT	6/1/2018	6/1/2018			\$ -	\$ 568,369	\$ 568,369	\$ 1,016,731
<b>Total</b>						\$ 1,378	\$ 801,324	\$ 802,702	\$ 1,435,959

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.





**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
SSCN AG1-2019-031

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SSCN	89162887	LES	NPPD	13	1/1/2020	1/1/2025	1/1/2020	1/1/2025	\$ 2,247	\$ -	\$ 2,247	\$ 2,712
									\$ 2,247	\$ -	\$ 2,247	\$ 2,712

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89162887	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total Revenue Requirements
89162887	Gavins Point - Yankton Junction 115 kV	10/1/2020	10/1/2020			\$ 946	\$ 1,035
	Fort Randall - Madison County 230kV Ckt 1	12/23/2013	12/23/2013			\$ 1,075	\$ 1,420
	Twin Church - Dixon County 230kV Line Upgrade	11/1/2018	11/1/2018			\$ 226	\$ 257
Total						\$ 2,247	\$ 2,712

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
WRGS AG1-2019-039

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WRGS	89210446	WR	WR	35	1/1/2020	1/1/2025	1/1/2020	1/1/2025	\$ 42,506	\$ -	\$ 1,386,391	\$ 1,873,681
									\$ 42,506	\$ -	\$ 1,386,391	\$ 1,873,681

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89210446	None					\$ -	\$ -	\$ -
						Total	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total Revenue Requirements	
89210446	FLATRDG3 - MEDICINE LODGE 138KV CKT 1	12/1/2009	12/1/2009			\$ -	\$ 8,279	\$ 8,279	\$ 38,827	
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006			\$ -	\$ 3,497	\$ 3,497	\$ 26,863	
	MEDICINE LODGE - PRATT 115KV CKT 1	12/1/2009	12/1/2009			\$ -	\$ 25,848	\$ 25,848	\$ 117,073	
	MEDICINE LODGE 138/115KV TRANSFORMER CKT 1	12/1/2009	12/1/2009			\$ -	\$ 2,627	\$ 2,627	\$ 13,679	
	Rice - Lyons 115 kV Ckt 1	4/1/2013	4/1/2013			\$ -	\$ 133,654	\$ 133,654	\$ 180,842	
	Rice County 230/115 kV transformer Ckt 1	10/1/2012	10/1/2012			\$ -	\$ 60,315	\$ 60,315	\$ 82,942	
	Tap Wichita - Thistle 345 kV Ckt 1 & 2 - Pratt Addition (NU)	12/31/2016	12/31/2016			\$ 4,478	\$ -	\$ 4,478	\$ 5,473	
	Tap Wichita - Thistle 345 kV Ckt 1 & 2 - Pratt Co Addition (NU)	10/16/2016	10/16/2016			\$ -	\$ 1,109,665	\$ 1,109,665	\$ 1,356,111	
	Wheatland 115 kV #2	12/31/2012	12/31/2012			\$ 38,028	\$ -	\$ 38,028	\$ 51,872	
						Total	\$ 42,506	\$ 1,343,885	\$ 1,386,391	\$ 1,873,681

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
WRGS AG1-2019-040

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WRGS	89217003	SECI	WR	80	1/1/2020	1/1/2025	1/1/2020	1/1/2025	\$ 60,081	\$ -	\$ 1,410,852	\$ 2,486,566
									\$ 60,081	\$ -	\$ 1,410,852	\$ 2,486,566

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89217003	None					\$ -	\$ -	\$ -
						Total	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total Revenue Requirements	
89217003	FLATRDG3 - HARPER 138KV CKT 1	12/1/2009	12/1/2009			\$ -	\$ 39,326	\$ 39,326	\$ 196,049	
	Ironwood 345 kV Substation Ford Co Addition	12/17/2014	12/17/2014			\$ -	\$ 662,462	\$ 662,462	\$ 846,986	
	NORTHWEST - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010			\$ -	\$ 142,079	\$ 142,079	\$ 680,327	
	Rice - Lyons 115 kV Ckt 1	4/1/2013	4/1/2013			\$ -	\$ 327,017	\$ 327,017	\$ 442,472	
	Rice County 230/115 kV transformer Ckt 1	10/1/2012	10/1/2012			\$ -	\$ 127,760	\$ 127,760	\$ 175,687	
	Wheatland 115 kV #2	12/31/2012	12/31/2012			\$ 60,081	\$ -	\$ 60,081	\$ 81,954	
	Woodward EHV 138kV Phase Shifting Transformer circuit #1	8/2/2017	8/2/2017			\$ -	\$ 52,126	\$ 52,126	\$ 63,091	
						Total	\$ 60,081	\$ 1,350,771	\$ 1,410,852	\$ 2,486,566

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade

Requests with Study Parameters Exceeded

Customer Study Number  
APM AG1-2019-002

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
APM	89182016	X	SPA	10	1/1/2020	1/1/2025	1/1/2020	1/1/2025	\$ -	\$ -	\$ 105,276	\$ 222,599	
										\$ -	\$ -	\$ 105,276	\$ 222,599

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89182016	Neosho - Riverton 161kV Line Rebuild (EMDE)	10/1/2021	12/1/2022			\$ -	\$ 61,071	\$ 61,071	\$ 28,410,000	\$ 98,236
	Neosho - Riverton 161kV Line Rebuild (WERE)	10/1/2021	12/1/2022			\$ -	\$ 8,698	\$ 8,698	\$ 4,046,161	\$ 16,352
Total						\$ -	\$ 69,769	\$ 69,769	\$ 32,456,161	\$ 114,588

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total Revenue Requirements
89182016	HUGO - VALLIANT 345KV CKT 1	7/1/2012	7/1/2012			\$ -	\$ 2,744	\$ 2,744	\$ 10,869
	Kingfisher Co Tap - Mathewson 345KV CKT 1	3/1/2018	3/1/2018			\$ -	\$ 12,722	\$ 12,722	\$ 15,332
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006			\$ -	\$ 944	\$ 944	\$ 7,253
	NORTHWEST - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010			\$ -	\$ 14,039	\$ 14,039	\$ 67,225
	Valliant 345 kV (AEP)	4/17/2012	4/17/2012			\$ -	\$ 532	\$ 532	\$ 1,855
	Woodward EHV 138kV Phase Shifting Transformer circuit #1	8/2/2017	8/2/2017			\$ -	\$ 4,525	\$ 4,525	\$ 5,477
Total						\$ -	\$ 35,507	\$ 35,507	\$ 108,011

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
APM AG1-2019-003

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
APM	89183931	X	OKGE	17	1/1/2020	1/1/2025	1/1/2020	1/1/2025	\$ -	\$ -	\$ 152,189	\$ 349,900
									\$ -	\$ -	\$ 152,189	\$ 349,900

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89183931	Neosho - Riverton 161kV Line Rebuild (EMDE)	10/1/2021	12/1/2022			\$ -	\$ 79,367	\$ 79,367	\$ 28,410,000	\$ 127,666
	Neosho - Riverton 161kV Line Rebuild (WERE)	10/1/2021	12/1/2022			\$ -	\$ 11,303	\$ 11,303	\$ 4,046,161	\$ 21,249
	<b>Total</b>					\$ -	\$ 90,670	\$ 90,670	\$ 32,456,161	\$ 148,915

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total Revenue Requirements
89183931	HUGO - VALLIANT 345KV CKT 1	7/1/2012	7/1/2012			\$ -	\$ 7,270	\$ 7,270	\$ 28,795
	Kingfisher Co Tap - Mathewson 345kv CKT 1	3/1/2018	3/1/2018			\$ -	\$ 18,055	\$ 18,055	\$ 21,759
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006			\$ -	\$ 2,523	\$ 2,523	\$ 19,385
	NORTHWEST - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010			\$ -	\$ 24,339	\$ 24,339	\$ 116,544
	Valliant 345 kV (AEP)	4/17/2012	4/17/2012			\$ -	\$ 1,410	\$ 1,410	\$ 4,914
	Woodward EHV 138kV Phase Shifting Transformer circuit #1	8/2/2017	8/2/2017			\$ -	\$ 7,922	\$ 7,922	\$ 9,589
	<b>Total</b>					\$ -	\$ 61,519	\$ 61,519	\$ 200,985

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
APM AG1-2019-004

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements	
APM	89183944	X	CSWS	58	1/1/2020	1/1/2025	1/1/2020	1/1/2025	\$ -	\$ -	\$ 664,491	\$ 1,381,485	
										\$ -	\$ -	\$ 664,491	\$ 1,381,485

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements	
89183944	Neosho - Riverton 161kV Line Rebuild (EMDE)	10/1/2021	12/1/2022			\$ -	\$ 286,656	\$ 286,656	\$ 28,410,000	\$ 461,102	
	Neosho - Riverton 161kV Line Rebuild (WERE)	10/1/2021	12/1/2022			\$ -	\$ 40,826	\$ 40,826	\$ 4,046,161	\$ 76,752	
						Total	\$ -	\$ 327,482	\$ 327,482	\$ 32,456,161	\$ 537,853

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total Revenue Requirements	
89183944	DEARING 138KV	6/30/2013	6/30/2013			\$ -	\$ 136	\$ 136	\$ 478	
	FAIRFAX - PAWNEE 138KV CKT 2	10/14/2014	10/14/2014			\$ -	\$ 56,609	\$ 56,609	\$ 72,965	
	HUGO - VALLIANT 345KV CKT 1	7/1/2012	7/1/2012			\$ -	\$ 27,057	\$ 27,057	\$ 107,165	
	Kingfisher Co Tap - Mathewson 345kV CKT 1	3/1/2018	3/1/2018			\$ -	\$ 61,565	\$ 61,565	\$ 74,196	
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006			\$ -	\$ 8,979	\$ 8,979	\$ 68,977	
	NORTHWEST - WOODWARD 345KV CKT 1	1/1/2010	1/1/2010			\$ -	\$ 78,259	\$ 78,259	\$ 374,734	
	Osage - Shidler 138kV	7/1/2014	7/1/2014			\$ -	\$ 4,435	\$ 4,435	\$ 5,762	
	Pawnee 138 kV	10/3/2014	10/3/2014			\$ -	\$ 16,488	\$ 16,488	\$ 21,252	
	Shidler 138 kV	4/30/2014	4/30/2014			\$ -	\$ 53,309	\$ 53,309	\$ 69,645	
	Valliant 345 kV (AEP)	4/17/2012	4/17/2012			\$ -	\$ 5,246	\$ 5,246	\$ 18,289	
	Woodward EHV 138kV Phase Shifting Transformer circuit #1	8/2/2017	8/2/2017			\$ -	\$ 24,925	\$ 24,925	\$ 30,169	
						Total	\$ -	\$ 337,009	\$ 337,009	\$ 843,632

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 MCPI AG1-2019-019

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MCPI	88109859	CSWS	ERCOTE	100	7/1/2021	9/1/2022	12/1/2021	2/1/2023	\$ -	\$ 6,598,036	\$ -	\$ -
									\$ -	\$ 6,598,036	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109859	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109859	Rebuild Eastman Gen - North Texas Eastman ckt 1	7/1/2021	12/1/2021		No	\$ 149,188	\$ 596,751
	Rebuild Eastman Gen - North Texas Eastman ckt 2	7/1/2021	12/1/2021		No	\$ 149,188	\$ 596,751
	EASTMAN 138/13.8KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 777,847	\$ 3,111,386
	EASTMAN 138/13.8KV TRANSFORMER #3	6/1/2021	6/1/2021		No	\$ 777,847	\$ 3,111,386
Total						\$ 1,854,069	\$ 7,416,274

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 MCPI AG1-2019-020

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MCPI	88109862	CSWS	ERCOTE	50	7/1/2021	9/1/2022	7/1/2021	9/1/2022	\$ -	\$ 3,299,018	\$ -	\$ -
									\$ -	\$ 3,299,018	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109862	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109862	WELSH 345/18.0KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 1,005,249	\$ 8,041,990
					Total	\$ 1,005,249	\$ 8,041,990

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 MCPI AG1-2019-021

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MCPI	88109863	CSWS	ERCOTE	50	7/1/2021	9/1/2022	7/1/2021	9/1/2022	\$ -	\$ 3,299,018	\$ -	\$ -
									\$ -	\$ 3,299,018	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109863	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109862	WELSH 345/18.0KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 1,005,249	\$ 8,041,990
					Total	\$ 1,005,249	\$ 8,041,990

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 MCPI AG1-2019-022

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MCPI	88109864	CSWS	ERCOTE	50	7/1/2021	9/1/2022	7/1/2021	9/1/2022	\$ -	\$ 3,299,018	\$ -	\$ -
									\$ -	\$ 3,299,018	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109864	None					\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109862	WELSH 345/18.0KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 1,005,249	\$ 8,041,990
					Total	\$ 1,005,249	\$ 8,041,990

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 MCPI AG1-2019-023

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MCPI	88109865	CSWS	ERCOTE	50	7/1/2021	9/1/2022	12/1/2021	2/1/2023	\$ -	\$ 3,299,018	\$ -	\$ -
									\$ -	\$ 3,299,018	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109865	None					\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109865	Rebuild Eastman Gen - North Texas Eastman ckt 1	7/1/2021	12/1/2021		No	\$ 74,594	\$ 596,751
	Rebuild Eastman Gen - North Texas Eastman ckt 2	7/1/2021	12/1/2021		No	\$ 74,594	\$ 596,751
	EASTMAN 138/13.8KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 388,923	\$ 3,111,386
	EASTMAN 138/13.8KV TRANSFORMER #3	6/1/2021	6/1/2021		No	\$ 388,923	\$ 3,111,386
Total						\$ 927,035	\$ 7,416,274

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 MCPI AG1-2019-024

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MCPI	88109866	CSWS	ERCOTE	100	7/1/2021	9/1/2022	12/1/2021	2/1/2023	\$ -	\$ 6,598,036	\$ -	\$ -
									\$ -	\$ 6,598,036	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109866	None					\$ -	\$ -	\$ -
<b>Total</b>						\$ -	\$ -	\$ -

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109866	Rebuild Eastman Gen - North Texas Eastman ckt 1	7/1/2021	12/1/2021		No	\$ 149,188	\$ 596,751
	Rebuild Eastman Gen - North Texas Eastman ckt 2	7/1/2021	12/1/2021		No	\$ 149,188	\$ 596,751
	EASTMAN 138/13.8KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 777,847	\$ 3,111,386
	EASTMAN 138/13.8KV TRANSFORMER #3	6/1/2021	6/1/2021		No	\$ 777,847	\$ 3,111,386
<b>Total</b>						\$ 1,854,069	\$ 7,416,274

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 MCPI AG1-2019-025

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
MCPI	88109871	CSWS	ERCOTE	50	7/1/2021	9/1/2022	12/1/2021	2/1/2023	\$ -	\$ 3,299,018	\$ -	\$ -
									\$ -	\$ 3,299,018	\$ -	\$ -

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109871	None					\$ -	\$ -	\$ -
						\$ -	\$ -	\$ -
					Total	\$ -	\$ -	\$ -

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109871	Rebuild Eastman Gen - North Texas Eastman ckt 1	7/1/2021	12/1/2021		No	\$ 74,594	\$ 596,751
	Rebuild Eastman Gen - North Texas Eastman ckt 2	7/1/2021	12/1/2021		No	\$ 74,594	\$ 596,751
	EASTMAN 138/13.8KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 388,923	\$ 3,111,386
	EASTMAN 138/13.8KV TRANSFORMER #3	6/1/2021	6/1/2021		No	\$ 388,923	\$ 3,111,386
					Total	\$ 927,035	\$ 7,416,274

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
 SPRM AG1-2019-028

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
SPRM	89227031	SPA	SPRM	50	4/1/2020	4/1/2050	12/1/2021	12/1/2051	\$ 327,989	\$ -	\$ 327,989	\$ 1,420,510
									\$ 327,989	\$ -	\$ 327,989	\$ 1,420,510

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89227031	Neosho - Riverton 161kV Line Rebuild (EMDE)	10/1/2021	12/1/2022			\$ 287,100	\$ 28,410,000	\$ 1,239,380
	Neosho - Riverton 161kV Line Rebuild (WERE)	10/1/2021	12/1/2022			\$ 40,889	\$ 4,046,161	\$ 181,130
Total						\$ 327,989	\$ 32,456,161	\$ 1,420,510

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
89227031	Everton - St Joe 161kV Rebuild	6/1/2021	12/1/2021		No	\$ 2,746,496	\$ 12,960,277
	Hilltop - St Joe 161 kV Rebuild	6/1/2021	12/1/2021		No	\$ 788,758	\$ 3,722,024
Total						\$ 3,535,254	\$ 16,682,300

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
TNSK AG1-2019-032

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
TNSK	88109881	CSWS	ERCOTE	50	7/1/2020	9/1/2021	6/1/2023	8/1/2024	\$ -	\$ 3,299,018	\$ 20,000,000	\$ 40,000,000
									\$ -	\$ 3,299,018	\$ 20,000,000	\$ 40,000,000

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109881	ERCOT EAST DC Tie Expansion	6/1/2021	6/1/2023			\$ 20,000,000	\$ 100,000,000	\$ 40,000,000
						\$ 20,000,000	\$ 100,000,000	\$ 40,000,000

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109862	WELSH 345/18.0KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 1,005,249	\$ 8,041,990
						\$ 1,005,249	\$ 8,041,990

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.



**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
TNSK AG1-2019-033

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
TNSK	88109886	CSWS	ERCOTE	50	7/1/2021	9/1/2022	6/1/2023	8/1/2024	\$ -	\$ 3,299,018	\$ 20,000,000	\$ 40,000,000
									\$ -	\$ 3,299,018	\$ 20,000,000	\$ 40,000,000

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109886	ERCOT EAST DC Tie Expansion	6/1/2021	6/1/2023			\$ 20,000,000	\$ 100,000,000	\$ 40,000,000
					Total	\$ 20,000,000	\$ 100,000,000	\$ 40,000,000

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109862	WELSH 345/18.0KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 1,005,249	\$ 8,041,990
					Total	\$ 1,005,249	\$ 8,041,990

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
TNSK AG1-2019-034

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
TNSK	88109895	CSWS	ERCOTE	50	7/1/2020	9/1/2021	6/1/2023	8/1/2024	\$ -	\$ 3,299,018	\$ 20,000,000	\$ 40,000,000
									\$ -	\$ 3,299,018	\$ 20,000,000	\$ 40,000,000

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109895	ERCOT EAST DC Tie Expansion	6/1/2021	6/1/2023			\$ 20,000,000	\$ 100,000,000	\$ 40,000,000
					Total	\$ 20,000,000	\$ 100,000,000	\$ 40,000,000

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109862	WELSH 345/18.0KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 1,005,249	\$ 8,041,990
					Total	\$ 1,005,249	\$ 8,041,990

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
TNSK AG1-2019-035

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
TNSK	88109896	CSWS	ERCOTE	50	7/1/2020	9/1/2021	6/1/2023	8/1/2024	\$ -	\$ 3,299,018	\$ 20,000,000	\$ 40,000,000
									\$ -	\$ 3,299,018	\$ 20,000,000	\$ 40,000,000

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109896	ERCOT EAST DC Tie Expansion	6/1/2021	6/1/2023			\$ 20,000,000	\$ 100,000,000	\$ 40,000,000
						\$ 20,000,000	\$ 100,000,000	\$ 40,000,000

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109862	WELSH 345/18.0KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 1,005,249	\$ 8,041,990
						\$ 1,005,249	\$ 8,041,990

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
TNSK AG1-2019-036

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
TNSK	88109897	CSWS	ERCOTE	50	7/1/2020	9/1/2021	6/1/2023	8/1/2024	\$ -	\$ 3,299,018	\$ 20,000,000	\$ 40,000,000
									\$ -	\$ 3,299,018	\$ 20,000,000	\$ 40,000,000

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
88109897	ERCOT EAST DC Tie Expansion	6/1/2021	6/1/2023			\$ 20,000,000	\$ 100,000,000	\$ 40,000,000
					Total	\$ 20,000,000	\$ 100,000,000	\$ 40,000,000

Third Party Limitations.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	*Allocated E & C Cost	*Total E & C Cost
88109862	WELSH 345/18.0KV TRANSFORMER #1	6/1/2021	6/1/2021		No	\$ 1,005,249	\$ 8,041,990
					Total	\$ 1,005,249	\$ 8,041,990

\*Estimated cost allocation as a percentage of total cost is shown for third-party limitations when costs have not yet been established by the third-party.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
WRGS AG1-2019-038

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WRGS	89210410	WR	WR	125	1/1/2020	1/1/2025	1/1/2020	1/1/2025	\$ 63,924	\$ -	\$ 17,018,797	\$ 21,365,060
									\$ 63,924	\$ -	\$ 17,018,797	\$ 21,365,060

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89210410	None					\$ -	\$ -	\$ -	\$ -	\$ -
Total						\$ -	\$ -	\$ -	\$ -	\$ -

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Base Plan Funding for Wind	Directly Assigned for Wind	Allocated E & C Cost	Total Revenue Requirements
89210410	FLATRDG3 - MEDICINE LODGE 138KV CKT 1	12/1/2009	12/1/2009			\$ -	\$ 29,151	\$ 29,151	\$ 136,722
	LACYGNE - WEST GARDNER 345KV CKT 1	6/1/2006	6/1/2006			\$ -	\$ 12,073	\$ 12,073	\$ 92,746
	MEDICINE LODGE - PRATT 115KV CKT 1	12/1/2009	12/1/2009			\$ -	\$ 85,027	\$ 85,027	\$ 385,114
	MEDICINE LODGE 138/115KV TRANSFORMER CKT 1	12/1/2009	12/1/2009			\$ -	\$ 9,317	\$ 9,317	\$ 48,517
	Rice - Lyons 115 kV Ckt 1	4/1/2013	4/1/2013			\$ -	\$ 305,081	\$ 305,081	\$ 412,792
	Rice County 230/115 kV transformer Ckt 1	10/1/2012	10/1/2012			\$ -	\$ 134,971	\$ 134,971	\$ 185,603
	Tap Wichita - Thistle 345 kV Ckt 1 & 2 - Pratt Addition (NU)	12/31/2016	12/31/2016			\$ 3,843	\$ -	\$ 3,843	\$ 4,696
	Tap Wichita - Thistle 345 kV Ckt 1 & 2 - Pratt Co Addition (NU)	10/16/2016	10/16/2016			\$ -	\$ 16,379,251	\$ 16,379,251	\$ 20,016,916
	Wheatland 115 kV #2	12/31/2012	12/31/2012			\$ 60,081	\$ -	\$ 60,081	\$ 81,954
Total						\$ 63,924	\$ 16,954,873	\$ 17,018,797	\$ 21,365,060

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 3 - Additional Details for Each Request Including All Facility Upgrades Required and Allocated Costs for Each Upgrade**

Customer Study Number  
WRGS AG1-2019-041

Customer	Reservation	POR	POD	Requested Amount	Requested Start Date	Requested Stop Date	Deferred Start Date Without Redispatch	Deferred Stop Date Without Redispatch	Potential Base Plan Funding Allowable	Point-to-Point Base Rate	Allocated E & C Cost	Total Revenue Requirements
WRGS	89217294	WR	WR	6	1/1/2020	1/1/2025	1/1/2020	1/1/2025	\$ 3,977	\$ -	\$ 12,282,367	\$ 12,475,752
									\$ 3,977	\$ -	\$ 12,282,367	\$ 12,475,752

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total E & C Cost	Total Revenue Requirements
89217294	Circleville - Goff 115kV Rebuild	6/1/2024	6/1/2024			\$ 12,258,391	\$ 12,258,391	\$ 12,443,134
Total						\$ 12,258,391	\$ 12,258,391	\$ 12,443,134

Credits may be required for the following Network Upgrades in accordance with Attachment Z2 of the SPP OATT.

Reservation	Upgrade Name	DUN	EOC	Earliest Start Date	Redispatch Available	Allocated E & C Cost	Total Revenue Requirements
89217294	Rice - Lyons 115 kV Ckt 1	4/1/2013	4/1/2013			\$ 13,979	\$ 18,914
	Rice County 230/115 kV transformer Ckt 1	10/1/2012	10/1/2012			\$ 6,020	\$ 8,278
	Wheatland 115 kV #2	12/31/2012	12/31/2012			\$ 3,977	\$ 5,425
Total						\$ 23,976	\$ 32,617

\*Note: CPOs may be calculated based on estimated upgrade cost and are subject to change.

**Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study**

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
EMDE	Neosho - Riverton 161kV Line Rebuild (EMDE)	Empire portion of upgrade: rebuild 28.41 miles of 161kV line from Neosho to Riverton and upgrade any necessary terminal equipment	10/1/2023	10/1/2023	\$28,410,000
WERE	Neosho - Riverton 161kV Line Rebuild (WERE)	Westar portion of upgrade: rebuild 2.44 miles of Neosho-Riverton 161kV line using bundled 1590 Lapwing ACSR and OPGW. Remove the wavetrap.	10/1/2023	10/1/2023	\$4,046,161

**Table 4 - Upgrade Requirements and Solutions Needed to Provide Transmission Service for the Aggregate Study**

Network Upgrades requiring credits per Attachment Z2 of the SPP OATT.

Transmission Owner	Upgrade	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Total Gross CPO Allocation
AEP	EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 (AEP)	Reconductor 1.82 miles with ACCC. Replace wave trap jumpers at Riverside.	3/23/2009	3/23/2009	\$ 133,484
AEP	Valliant 345 kV (AEP)	Install 345 kV terminal equipment at Valliant substation.	4/17/2012	4/17/2012	\$ 609,849
EDE	SUB 110 - ORONOJO JCT. - SUB 452 - RIVERTON 161KV CKT 1	Reconductor 11.9 miles of Oronogo Jct. to Riverton 161kV Ckt. 1 from 556 ACSR to 795 ACSR, change CT settings @ Oronogo, and replace wavetrap.	6/1/2011	6/1/2011	\$ 192,544
ITCM	HUGO - VALLIANT 345KV CKT 1	Install new line from Valliant 345 kV to Hugo Power Plant with 19 miles of bundled 1590 ACSR conductor.	7/1/2012	7/1/2012	\$ 3,647,640
ITCM	HUGO 345/138KV TRANSFORMER CKT 1	Install new 345/138 kV transformer	7/1/2012	7/1/2012	\$ 1,440,262
ITCM	Ironwood 345 kV Substation Ford Co Addition	New Transmission Owner 345kV substation ("Ironwood Substation") i. Revenue Metering including 345kV PTs and CTs ii. 345kV Dead end tower and miscellaneous 345kV terminal equipment to the Interconnection Customer Facility iii. One (1) 345kV disconnect switch	12/17/2014	12/17/2014	\$ 846,986
KCPL	LACYGNE - WEST GARDNER 345KV CKT 1	KCPL Sponsored Project to Reconductor Line to be In-Service by 6/1/2006	6/1/2006	6/1/2006	\$ 643,543
MIDW	Rice - Lyons 115 kV Ckt 1	Rebuild and extend 115 kV transmission line from existing Rice Co. substation to new Rice Co. substation, including engineering, surveying, and modification of existing easements as required.	4/1/2013	4/1/2013	\$ 623,314
MIDW	Rice County 230/115 kV transformer Ckt 1	Install 230/115 kV transformer at Rice County.	10/1/2012	10/1/2012	\$ 258,629
MIDW	Wheatland 115 kV #2	Install metering equipment at the Wheatland 115 kV substation.	12/31/2012	12/31/2012	\$ 133,826
MKEC	FLATRDG3 - HARPER 138KV CKT 1	Rebuild 24.15 mile line	12/1/2009	12/1/2009	\$ 196,049
MKEC	FLATRDG3 - MEDICINE LODGE 138KV CKT 1	Rebuild 8.05 mile line	12/1/2009	12/1/2009	\$ 38,827
MKEC	MEDICINE LODGE - PRATT 115KV CKT 1	Rebuild 26 mile line	12/1/2009	12/1/2009	\$ 117,073
MKEC	MEDICINE LODGE 138/115KV TRANSFORMER CKT 1	Upgrade transformer	12/1/2009	12/1/2009	\$ 13,679
NPPD	Fort Randall - Madison County 230kV Ckt 1	Raise structures and line clearances as necessary to re-rate the transmission line to 320 MVA	12/23/2013	12/23/2013	\$ 226,990
NPPD	Kelly - Madison County 230kV Ckt 1	Raise structures and line clearances as necessary to re-rate the transmission line to 320MVA	11/1/2014	11/1/2014	\$ 1,051
NPPD	Twin Church - Dixon County 230kV Line Upgrade	Increase clearances to accommodate 320MVA facility rating	11/1/2018	11/1/2018	\$ 4,389
OGE	BEELINE - EXPLORER GLENPOOL 138KV CKT 1	Reconductor .92miles of line with Drake ACCC/TW.	6/1/2009	6/1/2009	\$ 274,121
OGE	EXPLORER GLENPOOL - RIVERSIDE STATION 138KV CKT 1 (OGE)	Reconductor 1.82 miles line with Drake ACCC/TW.	6/1/2009	6/1/2009	\$ 305,245
OGE	Kingfisher Co Tap - Mathewson 345kV CKT 1	Replace structures	3/1/2018	3/1/2018	\$ 1,980,986
OGE	NORTHWEST - WOODWARD 345KV CKT 1	Build 345 kV line	1/1/2010	1/1/2010	\$ 11,730,264
OGE	Renfrow-Renfrow Tap 138kV Ckt 1	Replace terminal equipment.	9/25/2017	9/25/2017	\$ 157,374
OGE	Tap Woodring - Mathewson 345kV - Kingfisher Co (NU)	Transmission Owner's 345kV Substation: Construct three (3) 3000 continuous ampacity breakers, cut in transmission line and re-terminate, control panel replacement, line relaying, disconnect switches, structures, foundations, conductors, insulators, and all other associated work and materials.	10/2/2017	10/2/2017	\$ 302,684
OGE	Woodward EHV 138kV Phase Shifting Transformer circuit #1	Install one (1) 138 kV phase shifting transformer along with upgrading relay, protective, and metering equipment, and all associated and miscellaneous materials.	8/2/2017	8/2/2017	\$ 266,347
SPS	PLANT X - TOLK 230KV REBUILD CIRCUIT #1	Rebuild Plant X - Tolk 230kV transmission circuit #1 which is approximately 10 miles in length. The existing 795 MCM ACSR conductor will be replaced with 995 MCM ACCS conductor along with upgrading associated disconnect switches and structural steel.	12/31/2017	12/31/2017	\$ 211,587
SPS	PLANT X - TOLK 230KV REBUILD CIRCUIT #2	Rebuild Plant X - Tolk 230kV transmission circuit #2 which is approximately 10 miles in length. The existing 795 MCM ACSR conductor will be replaced with 995 MCM ACCS conductor along with upgrading associated disconnect switches and structural steel.	12/31/2017	12/31/2017	\$ 205,136
SPS	POWER SYSTEM STABILIZERS IN SPS	Install Power System Stabilizers (PSS) at Tolk (Units: 1,2) and Jones (Units: 1,2,3).	11/30/2014	11/30/2014	\$ 251,098
SPS	TUCO INTERCHANGE 345/230KV CKT 1 REPLACEMENT	The existing 345/230kV 560/560MVA autotransformer at Tuco Substation will be replaced with a new transformer unit to match the other transformer at this site. The new transformer can be installed at Tuco Substation by removing the existing transformer from the existing foundation and replacing with the new unit. New 345kV and 230kV electrical connections will be required. All new control cable terminations will be required. The new transformer will have top emergency ratings of 644MVA in the summer/spring/fall seasons and 700MVA in the winter season.	6/1/2018	6/1/2018	\$ 1,016,731
WAPA	Gavins Point - Yankton Junction 115 kV	Rebuild approximately four (4) miles of 115 kV and replace associated terminal equipment.	10/1/2020	10/1/2020	\$ 1,035
WR	COFFEYVILLE TAP - DEARING 138KV CKT 1 (WR) #2	Replace Disconnect Switches, Wavetrap, Breaker, Jumpers with a minimum 2000 amp emergency rating equipment	6/9/2010	6/9/2010	\$ 102
WR	Tap Wichita - Thistle 345 kV Ckt 1 & 2 - Pratt Addition (NU)	Relaying settings changes at the new 345kV switching station.	12/31/2016	12/31/2016	\$ 5,473
WR	Tap Wichita - Thistle 345 kV Ckt 1 & 2 - Pratt Co Addition (NU)	345 kV Breaker and Half Substation (No metering or customer equipment); Eight (8) 345 kV Breakers; Twenty (20) 345 kV switches; Two (2) 345 kV reactor switches; Fourteen (14) VTs; Two (2) 345 kV 50 Mvar line reactors; New redundant primary relaying, relay	10/16/2016	10/16/2016	\$ 1,356,111

\*Note: CPOs may be calculated based on upgrade(s) currently in study and/or estimated upgrade cost(s), which may be subject to change.



**Table 5 - Third Party Facility Constraints**

Transmission Owner	UpgradeName	Solution	Earliest Date Upgrade Required (DUN)	Estimated Date of Upgrade Completion (EOC)	Estimated Engineering & Construction Cost
None					

**Table 6 - Reserved**

**Reserved**

**Table 7- Service Upgrade Cost Allocation per Request**

<b>Upgrade Name</b>	<b>Customer</b>	<b>Study Number</b>	<b>Reservation</b>	<b>Allocation Percentage</b>	<b>Allocated E &amp; C Cost</b>
Neosho - Riverton 161kV Line Rebuild (EMDE)	EDE	AG1-2019-009	89219628	13.26%	\$3,767,680
Neosho - Riverton 161kV Line Rebuild (EMDE)	EDE	AG1-2019-010	89219810	73.04%	\$20,751,270
Neosho - Riverton 161kV Line Rebuild (EMDE)	EDE	AG1-2019-011	89220085	13.70%	\$3,891,050
				<b>Total:</b>	<b>\$28,410,000</b>

**Table 7- Service Upgrade Cost Allocation per Request**

<b>Upgrade Name</b>	<b>Customer</b>	<b>Study Number</b>	<b>Reservation</b>	<b>Allocation Percentage</b>	<b>Allocated E &amp; C Cost</b>
Neosho - Riverton 161kV Line Rebuild (WERE)	EDE	AG1-2019-009	89219628	13.26%	\$536,594
Neosho - Riverton 161kV Line Rebuild (WERE)	EDE	AG1-2019-010	89219810	73.04%	\$2,955,402
Neosho - Riverton 161kV Line Rebuild (WERE)	EDE	AG1-2019-011	89220085	13.70%	\$554,165
				<b>Total:</b>	<b>\$4,046,161</b>