

SPP DISIS-2021-001 AFS STUDY REPORT

INTRODUCTION

Associated Electric Cooperative Inc. (AECI), through coordination with the Southwest Power Pool (SPP), has identified generator interconnection requests (GIRs) within the DISIS-2021 Study Cycle (the “Study Cycle”) for an Affected System Study (AFS) evaluation on the AECI transmission system (the “Study”). The full list of Study Cycle requests included in the Study is listed in Table 1.

Table 1: Study Cycle Requests Evaluated

| Project # | TO | SP Capacity (MW) | WP Capacity (MW) | Fuel Type | POI |
|---------------------------|------|------------------|------------------|-----------------|---|
| GEN-2021-001 | OGE | 100 | 100 | Battery Storage | 138kV Brown Substation |
| GEN-2021-004 ¹ | OGE | 250 | 250 | Solar | Poolville 138kV Bus |
| GEN-2021-005 | WERE | 350 | 350 | Battery Storage | Summit 345 kV substation in Saline County, KS |
| GEN-2021-006 | WERE | 300 | 300 | Battery Storage | Neosho 345kV substation in Labette County, KS |
| GEN-2021-007 | NPPD | 600 | 600 | Wind | 345kV bus of Turtle Creek Substation |
| GEN-2021-008 | BEPC | 200 | 200 | Solar | 345kV Bus at BEPC Patent Gate Substation, McKenzie County, ND |
| GEN-2021-010 | OGE | 233.98 | 233.98 | Solar | Border 345 kV interconnection substation |
| GEN-2021-012 | OGE | 227 | 227 | Battery Storage | Border 345 kV interconnection substation |
| GEN-2021-014 | OGE | 233.98 | 233.98 | Solar | Border 345 kV interconnection substation |
| GEN-2021-016 ² | AEP | 255 | 255 | Wind | Sunnyside-Johnston 345 kV |
| GEN-2021-018 | OGE | 235.35 | 235.35 | Solar | Sooner 345 kV |
| GEN-2021-019 | OGE | 75.89 | 75.89 | Battery Storage | Sooner 345 kV |
| GEN-2021-023 | WERE | 306.18 | 306.18 | Solar | Wild Plains 345kV Substation |
| GEN-2021-024 | WAPA | 203.04 | 203.04 | Wind | WAPA 230kV Jamestown Substation |
| GEN-2021-025 | WFEC | 203.04 | 203.04 | Wind | Western Farmers 138kV Mooreland Substation |
| GEN-2021-027 | NPPD | 102.06 | 102.06 | Solar | Olive Creek 115 kV Substation |
| GEN-2021-028 | WFEC | 204.12 | 204.12 | Solar | Western Farmers 138kV Mooreland Substation |
| GEN-2021-029 | KCPL | 253.8 | 253.8 | Battery Storage | Evergy Tap the La Cygne to Stillwell 345 kV Line |
| GEN-2021-030 | KCPL | 510.3 | 510.3 | Solar | Evergy Tap the La Cygne to Stillwell 345 kV Line |
| GEN-2021-033 | OGE | 204.12 | 204.12 | Solar | Grand Prairie 161kV Substation |
| GEN-2021-034 | LES | 113 | 113 | Solar | Rokeby 115 kV Substation |
| GEN-2021-036 | AEP | 204.12 | 204.12 | Solar | Craig to Patterson 138 kV Transmission Line |
| GEN-2021-037 | NPPD | 244.22 | 244.22 | Wind | NPPD Sidney to Keystone 345 kV Line |
| GEN-2021-038 | AEP | 200 | 200 | Battery Storage | Welsh 345kV Substation |

¹ GIR withdrew mid-study, removal will be captured in a future restudy.

² GIR decreased in MW capacity mid-study, this change will be captured in a future restudy.

| Project # | TO | SP Capacity (MW) | WP Capacity (MW) | Fuel Type | POI |
|--------------|------|------------------|------------------|-----------------|--|
| GEN-2021-039 | OPPD | 100 | 100 | Battery Storage | New 161kV substation looping in OPPD 161kV lines S1211 to S1220 and S1211 to S1299 |
| GEN-2021-040 | OPPD | 200 | 200 | Battery Storage | OPPD District, Cass County Power Plant Substation, 345kV Bus |
| GEN-2021-041 | OGE | 100.657 | 100.657 | Battery Storage | Mustang 138kV Substation |
| GEN-2021-042 | INDN | 100 | 100 | Battery Storage | Independence Power & Light, Blue Valley Substation, 161kV Bus |
| GEN-2021-043 | LES | 250 | 250 | Battery Storage | 8000 SW 12th (Rokeyby) Station, 115kV Bus |
| GEN-2021-047 | GRDA | 250 | 250 | Solar | Tulsa (Bus #509852) - Igloo (Bus #513596) 345kV line |
| GEN-2021-048 | LES | 75 | 75 | Battery Storage | Wagener 115kV Substation |
| GEN-2021-049 | LES | 250 | 250 | Solar | Wagener 115kV Substation |
| GEN-2021-050 | KCPL | 200 | 200 | Solar | 161kV Stilwell-Clinton Line |
| GEN-2021-051 | KCPL | 75 | 75 | Battery Storage | 161kV Stilwell-Clinton Line |
| GEN-2021-053 | OGE | 300 | 300 | Solar | Pecan Creek 345 kV Substation |
| GEN-2021-056 | WERE | 300 | 300 | Wind | Viola 345kV Substation |
| GEN-2021-057 | NPPD | 300 | 300 | Wind | Antelope 345kV substation |
| GEN-2021-063 | AEP | 155 | 155 | Solar | Craig JCT 138kV |
| GEN-2021-064 | AEP | 100 | 100 | Solar | Carnegie South 138kV |
| GEN-2021-068 | SUNC | 249.6 | 249.6 | Wind | SUNC Spearville - Holcomb 345kV |
| GEN-2021-069 | SUNC | 249.6 | 249.6 | Wind | SUNC Spearville - Holcomb 345kV |
| GEN-2021-070 | SUNC | 504 | 504 | Wind | SUNC Spearville - Holcomb 345kV |
| GEN-2021-072 | BEPC | 600 | 600 | Solar | 345kV Transmission Line from Antelope Valley to Leland Olds Substation |
| GEN-2021-073 | NPPD | 240 | 240 | Solar | Tap on the Sweetwater to Gerald Gentleman 345 kV Line |
| GEN-2021-075 | AEP | 300 | 300 | Solar | CAMPBOR4 138kV Substation |
| GEN-2021-077 | GMO | 95 | 95 | Solar | Windsor to AEC Sedalia 161 kV |
| GEN-2021-086 | AEP | 165 | 165 | Solar | Okay - Turk 138kV |
| GEN-2021-088 | OGE | 100 | 100 | Battery Storage | Cedar Lane - Canadian 138 kV Transmission Line |
| GEN-2021-090 | SPS | 400 | 400 | Solar | Yoakum 345kV Substation |
| GEN-2021-096 | WERE | 500 | 500 | Solar | Wolf Creek - Benton 345 kV |
| GEN-2021-098 | OGE | 160 | 160 | Wind | Dewey District 138 kV Substation |
| GEN-2021-101 | WERE | 159 | 159 | Solar | Evergy's Midland Substation 115kV bus |
| GEN-2021-103 | WERE | 150 | 150 | Battery Storage | Evergy's Atlantic Substation 115kV bus |
| GEN-2021-106 | NPPD | 102.06 | 102.06 | Solar | Hebron North 115kV substation |
| GEN-2021-107 | WERE | 201.6 | 201.6 | Solar | Evergy 345kV Jeffrey Energy Center |
| GEN-2021-108 | OPPD | 182.25 | 182.25 | Solar | OPPD 345kV Cass County Substation |

INPUTS AND ASSUMPTIONS

Each of the SERC member transmission planners is responsible for submitting system modeling data to SERC for development of the power flow models. Power flow analysis utilized the latest Long-Term Working Group (LTWG) models as developed by SERC Reliability Corporation (SERC). Each of the power flow models for the steady state analysis was modified to include appropriate higher-queued generation interconnection requests. Modeling parameters from the SPP DISIS 2021-001 steady state models were referenced for each of the Study Cycle requests.

Full details of the inputs and assumptions are provided in Appendix A.

METHODOLOGY

Steady state analysis was performed to confirm the reliability impacts on the AECI system under a variety of system conditions and outages. AECI's transmission system must be capable of operating within the applicable normal ratings, emergency ratings, and voltage limits of AECI planning criteria. AECI is a member of SERC, one of eight Electric Reliability Organizations under the North American Electric Reliability Corporation (NERC). As a member of SERC, AECI develops its planning criteria consistent with NERC Reliability Planning Standards and the SERC planning criteria. The NERC TPL-001-5 Planning Standard Table 1 requires that, for normal and contingency conditions, line and equipment loading shall be within applicable thermal limits, voltage levels shall be maintained within applicable limits, all customer demands shall be supplied (except as noted), and stability of the network shall be maintained.

In evaluating the impacts of the Study Cycle requests, the following thermal and voltage limits were applied to the analysis for P0 or normal system conditions:

- Thermal Limits within Applicable Rating – Applicable Rating shall be defined as the Normal Rating. The thermal limit shall be 100% of Rating A.
- Voltage Limits within Applicable Rating – Applicable Rating shall have the meaning of Nominal Voltage. Voltage limits shall be set at plus or minus five percent (+/- 5%), 0.95 p.u. - 1.05 p.u. for systems operating at 60 kV or above on load serving buses.

The following thermal and voltage limits were applied to the analysis for contingency conditions under P1 and P2EHV planning events:

- Thermal Limits within Applicable Rating – Applicable Rating shall be defined as the Emergency Rating. The thermal limit shall be 100% of Rating B.
- Voltage Limits within Applicable Rating – Applicable Rating shall have the meaning of Nominal Voltage. Voltage limits shall be set at plus five percent to minus ten percent (+5%/-10%), 0.90 p.u. – 1.05 p.u. for systems operating at 60 kV or above on load serving buses.

In order for the Study Cycle requests to have a negative impact (i.e. criteria violation) on the system, the Study Cycle must cause a three percent (3%) or greater increase in flow on an overloaded facility based upon the rating of the facility. In order for the Project to have a negative voltage impact on the system, the Project must cause a voltage violation and have a two percent (2%) or greater change in the voltage.

System upgrades are required for constraints resulting from the addition of the Study Cycle requests under P0, P1, P2.1, P2.2 (EHV only), and P2.3 (EHV only) system conditions. For the purpose of this study, P2.1

events are included as part of the P1 contingency file. As such, these events will be denoted as a P1 event in the results. All improvements were developed and studied in coordination with AECI.

AECI will perform an annual limited operations study which will indicate seasonal operating limits for SPP/MISO/AECI generation interconnection requests that will reach commercial operation in the 12 month horizon but whose AECI network upgrades have not yet been energized.

STEADY STATE ANALYSIS RESULTS

Steady state analysis results showed ten (10) constraints reported on the AECI transmission system, as shown in Table 2, which are attributed to the Study Cycle requests. Transmission upgrades were evaluated to mitigate the impacts reported from the analysis as a result of the Study Cycle requests. Simulations were performed on each of the scenarios with the identified network upgrade and contingent network upgrades included.

The upgrades shown in Table 7 were evaluated in order to mitigate the reported steady state constraints for the Study Cycle requests; results from the simulations found that the network upgrades were able to mitigate the reported overload conditions as shown in Table 2.

Table 2: Steady State Constraints for the Study Cycle Requests with Upgrades

| Constraint ID | Event | Monitored Facility | Contingency | Season | Base Loading | Project Loading | Upgrade Loading |
|---------------|-------|---|---|--------|--------------|-----------------|-----------------|
| NU01 | P2EHV | 300101 5MORGAN 161.00 547478 DAD368 5 161.00 1 | OPEN BRANCH FROM BUS 300042 [7HUBEN 345.00] TO BUS 300045 [7MORGAN 345.00] CKT 1 OPEN BRANCH FROM BUS 300045 [7MORGAN 345.00] TO BUS 549984 [BROOKLINE 7345.00] CKT 1 | 28W | 89.2 | 108.0 | 85.3 |
| | | | | 33W | 87.7 | 107.4 | 85.1 |
| NU02 | P1 | 300101 5MORGAN 161.00 549969 BROOKLINE 5161.00 1 | OPEN LINE FROM BUS 300045 [7MORGAN 345.00] TO BUS 549984 [BROOKLINE 7345.00] CKT 1 OPEN BRANCH FROM BUS 300042 [7HUBEN 345.00] TO BUS 300045 [7MORGAN 345.00] CKT 1 OPEN BRANCH FROM BUS 300045 [7MORGAN 345.00] TO BUS 549984 [BROOKLINE 7345.00] CKT 1 | 33S | 75.0 | 100.4 | 69.4 |
| | P2EHV | | | 28S | 82.6 | 106.1 | 74.5 |
| | | | | 28W | 84.1 | 106.3 | 91.8 |
| | | | | 33S | 83.6 | 106.8 | 75.0 |
| | | | | 33W | 82.7 | 105.2 | 90.8 |
| NU03 | P2EHV | 300648 2LAMRRLS 69.000 300655 2LAMRCTN 69.000 1 | OPEN BRANCH FROM BUS 300045 [7MORGAN 345.00] TO BUS 709500 [GI-95_POI 345.00] CKT 1 OPEN BRANCH FROM BUS 300042 [7HUBEN 345.00] TO BUS 300045 [7MORGAN 345.00] CKT 1 | 33S | 51.5 | 100.3 | 53.2 |
| NU04 | P2EHV | 300651 2LAMR 69.000 300656 2JACK ST 69.000 1 | OPEN BRANCH FROM BUS 300045 [7MORGAN 345.00] TO BUS 709500 [GI-95_POI 345.00] CKT 1 OPEN BRANCH FROM BUS 300042 [7HUBEN 345.00] TO BUS 300045 [7MORGAN 345.00] CKT 1 | 28W | 72.3 | 102.1 | 60.6 |
| | | | | 33W | 70.5 | 100.9 | 60.0 |
| NU05 | P1 | 300655 2LAMRCTN 69.000 300656 2JACK ST 69.000 1 | OPEN LINE FROM BUS 300045 [7MORGAN 345.00] TO BUS 709500 [GI-95_POI 345.00] CKT 1 | 28S | 54.6 | 101.2 | 53.7 |
| | | | | 33S | 55.7 | 102.3 | 54.2 |

| Constraint ID | Event | Monitored Facility | Contingency | Season | Base Loading | Project Loading | Upgrade Loading |
|---------------|-------|--|---|--------|-----------------|--------------------|-------------------|
| | P2EHV | | OPEN BRANCH FROM BUS 300045 [7MORGAN 345.00] TO BUS 709500 [GI-95_POI 345.00] CKT 1 OPEN BRANCH FROM BUS 300042 [7HUBEN 345.00] TO BUS 300045 [7MORGAN 345.00] CKT 1 | 28S | 57.3 | 105.9 | 56.2 |
| | P2EHV | | | 33S | 58.5 | 107.1 | 56.8 |
| NU06 | P2EHV | 300712 2RICHLND 69.000 547548 BOS249 2 69.000 1 | OPEN BRANCH FROM BUS 300045 [7MORGAN 345.00] TO BUS 709500 [GI-95_POI 345.00] CKT 1 OPEN BRANCH FROM BUS 300042 [7HUBEN 345.00] TO BUS 300045 [7MORGAN 345.00] CKT 1 | 33S | 51.1 | 100.0 | 75.8 |
| NU07 | P1 | 300168 5GOBKNOB 161.00 300173 2GOBKNOB 69.000 4 | OPEN LINE FROM BUS 300048 [7STFRAN 345.00] TO BUS 300054 [7GOBKNOB 345.00] CKT 1 | 28W | 149.7 | 152.7 | 98.9 ³ |
| NU08 | P2EHV | 300381 5BEVIER 161.00 300387 2BEVIER 69.000 1 | OPEN BRANCH FROM BUS 344000 [7ZACHARY 345.00] TO BUS 345438 [7FABIUS 345.00] CKT 1 OPEN BRANCH FROM BUS 345438 [7FABIUS 345.00] TO BUS 345435 [7MAYWOOD 345.00] CKT 1 OPEN BRANCH FROM BUS 345992 [7SPENCER 345.00] TO BUS 345435 [7MAYWOOD 345.00] CKT 1 | 28S | NB ⁴ | 100.0 ⁵ | 90.9 ³ |
| NU09 | P1 | 300123 5WPLAINW 161.00 301123 2WSTPL3 69.000 1 | OPEN LINE FROM BUS 301123 [2WSTPL3 69.000] TO BUS 301549 [5WPLAINE 161.00] CKT 2 | 28S | 122.2 | 126.3 | 87.1 ³ |
| NU10 | P1 | 301123 2WSTPL3 69.000 301549 5WPLAINE 161.00 2 | OPEN LINE FROM BUS 300123 [5WPLAINW 161.00] TO BUS 301123 [2WSTPL3 69.000] CKT 1 | 28S | 120.4 | 126.7 | 87.3 ³ |
| | P1 | | | 33W | 101.6 | 106.1 | 76.1 ³ |

Table 2 shows stressed modeling conditions in which the Base Loading represents models built with higher queue generation requests in service, but without network upgrades tagged to those higher queue requests. Multiple iterations of solutions, which can include applicable higher queued network upgrades, were tested to alleviate both the Base Loading and the additional loading contributed by the Study Cycle (Project Loading). Table 2 lists facilities in which Project Loading cannot be mitigated by higher queue upgrades and in which a negative impact due to the Study Cycle was still present.

³ ‘Upgrades Loading’ reflects loading on Monitored Facility with tap adjustments.

⁴ Monitored Facility created as part of the Network Upgrades, no Base loading available. NB = no branch.

⁵ ‘Project Loading’ reflects the loading with the Network Upgrades included, prior to mitigation.

CONTINGENT FACILITY RESULTS

Sixty-six (66) facilities were reported as Contingent Facilities with the addition of the Study Cycle requests, as shown in Table 3. Contingent Facilities are those facilities identified that are the responsibility of higher-queued generators or are included in the Transmission Provider’s transmission expansion plan and that if not included in the Study may otherwise be the responsibility of the Study Cycle requests as necessary to interconnect to the transmission system.

The transmission upgrades for the Contingent Facilities were evaluated in order to confirm that the planned system adjustments were sufficient to mitigate the overload seen for the addition of the Study Cycle requests. Simulations were performed on each of the scenarios with the identified network upgrade and contingent network upgrades included. The upgrades shown in Table 5 were evaluated in order to mitigate the reported constraints as listed in Table 3 below.

Table 3: Steady State Contingent Constraints for the Study Cycle Requests with Upgrades

| Constraint ID | Event | Monitored Facility | Season | Base Loading | Project Loading | Upgrade Loading | Contingent Generator(s) |
|---------------|-------|--|--------|--------------|-----------------|-----------------|---------------------------|
| CF01 | P1 | 300073 5GENTRY 161.00 300076 5FAIRPTB2 161.00 1 | 28S | 94.1 | 101.2 | 96.9 | SPP DISIS-2017-002 SPP NU |
| CF02 | P1 | 300323 2CENTRV 69.000 300336 2HOLDEN 69.000 1 | 28S | 90.8 | 100.5 | 95.0 | SPP DISIS-2017-002 SPP NU |
| | | | 33S | 90.2 | 100.0 | 95.1 | |
| CF03 | P1 | 300688 2AUSTIN 69.000 300696 2CREIGH 69.000 1 | 28S | 83.1 | 104.9 | 82.6 | SPP DISIS-2017-002 SPP NU |
| | | | 33S | 79.7 | 101.7 | 80.9 | |
| CF04 | P1 | 300651 2LAMR 69.000 300794 5LAMAR 161.00 1 | 28H | 89.4 | 110.5 | 73.8 | SPP DISIS-2017-002 |
| | | | 28S | 84.8 | 101.9 | 64.9 | |
| | | | 28W | 118.6 | 139.4 | 91.0 | |
| | | | 33S | 87.5 | 104.2 | 65.3 | |
| | | | 33W | 115.5 | 137.9 | 90.3 | |
| | P2EHV | | 28H | 91.2 | 113.9 | 75.5 | |
| | | | 28S | 116.1 | 140.2 | 88.7 | |
| | | | 28W | 119.7 | 142.0 | 92.4 | |
| | | | 33S | 118.9 | 142.6 | 89.2 | |
| | | | 33W | 116.7 | 140.4 | 91.4 | |
| CF05 | P1 | 300772 2COFMAN 69.000 300780 2KNOBBY 69.000 1 | 28S | 75.1 | 106.7 | 49.3 | SPP DISIS-2017-002 |
| | | | 28W | 98.0 | 120.0 | 77.5 | |
| | | | 33S | 79.3 | 100.8 | 57.7 | |
| | | | 33W | 96.8 | 119.3 | 76.9 | |

| Constraint ID | Event | Monitored Facility | Season | Base Loading | Project Loading | Upgrade Loading | Contingent Generator(s) | |
|---------------|-------|---|--------|--------------|-----------------|-----------------|-------------------------------|------|
| CF06 | P1 | 300780 2KNOBBY 69.000 301401 2TURKEYCRK 69.000 1 | 28S | 80.6 | 110.5 | 29.7 | SPP DISIS-2017-002 | |
| | | | 28W | 86.2 | 109.3 | 36.2 | | |
| | | | 33S | 90.2 | 111.6 | 35.0 | | |
| | | | 33W | 86.5 | 109.1 | 36.2 | | |
| CF07 | P1 | 300173 2GOBKNOB 69.000 301230 2FAIRDLG 69.000 1 | 28S | 102.8 | 111.9 | 61.6 | GI-099/100/SPP DISIS-2018-001 | |
| | | | 33S | 103.3 | 112.0 | 61.6 | | |
| CF08 | P1 | 301201 2DONIPH 69.000 301227 2RIPLEY 69.000 1 | 28S | 86.9 | 103.1 | 52.9 | GI-099/100/SPP DISIS-2018-001 | |
| | | | 33S | 88.2 | 103.2 | 52.9 | | |
| CF09 | P1 | 301217 2OXLEY 69.000 301227 2RIPLEY 69.000 1 | 28S | 87.0 | 103.2 | 53.0 | GI-099/100/SPP DISIS-2018-001 | |
| | | | 33S | 88.4 | 103.3 | 53.0 | | |
| CF10 | P1 | 301217 2OXLEY 69.000 301230 2FAIRDLG 69.000 1 | 28S | 95.4 | 104.9 | 33.1 | GI-099/100/SPP DISIS-2018-001 | |
| | | | 33S | 96.4 | 105.0 | 33.1 | | |
| CF11 | P1 | 300293 2CAMRNJ 69.000 300312 2TURNEY 69.000 1 | 28H | 150.7 | 160.5 | 45.2 | AECI | |
| | | | 28L | 142.9 | 148.7 | 38.3 | | |
| | | | 28S | 185.3 | 191.4 | 57.0 | | |
| | | | 33S | 183.7 | 189.3 | 56.4 | | |
| CF12 | P1 | 301201 2DONIPH 69.000 505440 DONIPHNS 161.00 1 | 28S | 109.8 | 113.6 | 78.6 | SPP DISIS-2018-001 | |
| | | | 28W | 109.6 | 116.1 | 76.1 | | |
| CF13 | P1 | 300541 2SEDALI 69.000 300545 2SYLVAN 69.000 1 | 28W | 100.5 | 110.6 | 60.6 | GI-091 | |
| | | | 33W | 88.6 | 101.4 | 55.1 | | |
| CF14 | P1 | 300772 2COFMAN 69.000 300779 2J&7 69.000 1 | 28S | 65.6 | 100.5 | 25.4 | SPP DISIS-2020 | |
| | | | 28W | 90.2 | 120.5 | 41.3 | | |
| | | | 33S | 70.7 | 100.6 | 30.4 | | |
| | | | 33W | 88.5 | 119.1 | 40.7 | | |
| CF15 | P0 | 300115 5STFRANB2 161.00 338202 5JIM HILL% 161.00 1 | 28H | 122.0 | 126.7 | 57.4 | MISO DPP-2019 | |
| | | | 28S | 129.9 | 132.9 | 60.2 | | |
| | | | 28W | 116.1 | 119.4 | 65.4 | | |
| | | | 33S | 128.8 | 131.8 | 59.8 | | |
| | | | 33W | 116.5 | 119.8 | 65.6 | | |
| | P1 | | 28H | 126.9 | 131.5 | 59.6 | | |
| | | | 28L | 162.3 | 165.5 | 75.0 | | |
| | | | 28S | 138.1 | 141.1 | 64.0 | | |
| | | | 28W | 120.5 | 123.8 | 67.7 | | |
| | | | 33S | 133.9 | 136.9 | 62.1 | | |
| | | | 33W | 120.9 | 124.2 | 68.0 | | |
| | | | P2EHV | 28H | 124.2 | 128.7 | | 58.3 |
| | | | | 28L | 181.1 | 208.5 | | 93.7 |
| 28S | 137.8 | 140.9 | | 63.8 | | | | |

| Constraint ID | Event | Monitored Facility | Season | Base Loading | Project Loading | Upgrade Loading | Contingent Generator(s) |
|---------------|-------|--|--------|--------------|-----------------|-----------------|-------------------------|
| | | | 28W | 117.5 | 120.6 | 66.0 | |
| | | | 33S | 136.6 | 139.8 | 63.3 | |
| | | | 33W | 117.9 | 121.0 | 66.2 | |
| CF16 | P1 | 300124 5HOLDENB2 161.00 300336 2HOLDEN 69.000 1 | 28S | 114.6 | 127.4 | 64.1 | MISO DPP-2019 |
| | | | 33S | 115.2 | 128.2 | 64.9 | |
| CF17 | P1 | 300327 2ELM 69.000 300336 2HOLDEN 69.000 1 | 28S | 108.7 | 122.6 | 89.0 | MISO DPP-2019 |
| | | | 33S | 110.3 | 124.5 | 90.9 | |
| CF18 | P1 | 300061 5BOONE 161.00 300519 5MLRSBGB1 161.00 1 | 33S | 96.1 | 100.5 | 85.8 | MISO DPP-2019 |
| CF19 | P0 | 300387 2BEVIER 69.000 301623 2BEVIERTP 69.000 1 | 28S | 108.8 | 129.3 | 80.1 | MISO DPP-2019 |
| | | | 33S | 108.7 | 129.8 | 80.4 | |
| | | | 28H | 86.1 | 101.3 | 62.8 | |
| | P1 | | 28L | 89.2 | 101.9 | 62.2 | |
| | | | 28S | 107.3 | 127.5 | 78.9 | |
| | | | 28W | 85.5 | 105.8 | 79.5 | |
| | | | 33S | 107.3 | 128.0 | 79.3 | |
| | | | 33W | 83.4 | 103.1 | 77.4 | |
| | P2EHV | | 28H | 84.8 | 100.0 | 62.0 | |
| | | | 28S | 109.6 | 130.5 | 80.8 | |
| | | | 28W | 81.8 | 102.2 | 77.1 | |
| 33S | | 109.6 | 131.0 | 81.1 | | | |
| CF20 | P1 | 300398 2LOVELK 69.000 300401 2MACNTP 69.000 1 | 28S | 80.9 | 102.5 | 71.6 | MISO DPP-2019 |
| | | | 33S | 80.3 | 102.1 | 71.4 | |
| CF21 | P0 | 300400 2MACNLK 69.000 301623 2BEVIERTP 69.000 1 | 28H | 103.1 | 122.2 | 51.0 | MISO DPP-2019 |
| | | | 28S | 135.7 | 162.6 | 67.9 | |
| | | | 28W | 87.3 | 106.8 | 44.9 | |
| | | | 33S | 135.7 | 163.2 | 68.1 | |
| | | | 33W | 85.0 | 104.1 | 43.7 | |
| | P1 | | 28H | 101.4 | 120.0 | 50.1 | |
| | | | 28L | 93.2 | 108.1 | 45.5 | |
| | | | 28S | 133.8 | 160.2 | 66.9 | |
| | | | 28W | 85.9 | 105.1 | 44.1 | |
| | | | 33S | 133.8 | 160.9 | 67.1 | |
| | | | 33W | 83.5 | 102.3 | 42.9 | |
| | | | P2EHV | 28H | 103.8 | 123.0 | |
| | 28L | | | 87.1 | 101.0 | 42.7 | |
| | 28S | | | 136.5 | 163.6 | 68.3 | |
| 28W | 88.0 | 107.6 | | 45.2 | | | |
| | | | 33S | 136.5 | 164.2 | 68.5 | |

| Constraint ID | Event | Monitored Facility | Season | Base Loading | Project Loading | Upgrade Loading | Contingent Generator(s) |
|---------------|-------|--|--------|--------------|-----------------|-----------------|-------------------------|
| | | | 33W | 85.7 | 104.9 | 44.0 | |
| CF22 | P0 | 300388 2AXTELL 69.000 300401 2MACNTP 69.000 1 | 28H | 87.9 | 106.4 | 44.7 | MISO DPP-2019 |
| | | | 28S | 117.4 | 143.8 | 60.4 | |
| | | | 33S | 116.5 | 143.5 | 60.3 | |
| | P1 | | 28H | 86.2 | 104.2 | 43.8 | |
| | | | 28L | 88.6 | 103.3 | 43.6 | |
| | | | 28S | 115.5 | 141.5 | 59.4 | |
| | | | 28W | 88.6 | 114.4 | 48.7 | |
| | | | 33S | 114.7 | 141.3 | 59.4 | |
| | | | 33W | 85.3 | 110.2 | 47.0 | |
| | P2EHV | | 28H | 88.6 | 107.2 | 45.1 | |
| | | | 28L | 88.7 | 100.5 | 42.2 | |
| | | | 28S | 118.3 | 144.8 | 60.8 | |
| | | | 28W | 83.8 | 109.8 | 47.0 | |
| | | | 33S | 117.5 | 144.6 | 60.8 | |
| 33W | 80.0 | 104.8 | 44.9 | | | | |
| CF23 | P0 | 300388 2AXTELL 69.000 300400 2MACNLK 69.000 1 | 28H | 92.9 | 111.6 | 46.8 | MISO DPP-2019 |
| | | | 28S | 123.9 | 150.4 | 63.0 | |
| | | | 33S | 123.2 | 150.4 | 63.0 | |
| | P1 | | 28H | 91.2 | 109.4 | 45.8 | |
| | | | 28L | 90.2 | 105.0 | 44.2 | |
| | | | 28S | 122.0 | 148.1 | 62.0 | |
| | | | 28W | 82.0 | 102.3 | 43.1 | |
| | | | 33S | 121.4 | 148.1 | 62.0 | |
| | | | 33W | 81.4 | 101.5 | 42.8 | |
| | P2EHV | | 28H | 93.6 | 112.4 | 47.1 | |
| | | | 28L | 90.2 | 102.2 | 42.8 | |
| | | | 28S | 124.7 | 151.5 | 63.4 | |
| | | | 28W | 80.4 | 100.2 | 42.3 | |
| | | | 33S | 124.2 | 151.4 | 63.4 | |
| 33W | 87.5 | 112.4 | 47.9 | | | | |
| CF24 | P1 | 300571 2MEXICO 69.000 300580 2SLTRVR 69.000 1 | 28S | 59.4 | 102.1 | 74.6 | GI-083 |
| | | | 33S | 59.4 | 103.6 | 75.7 | |
| CF25 | P1 | 300090 5KINGDMB1 161.00 300523 5WLMSBG 161.00 1 | 28W | 95.5 | 101.3 | 83.3 | GI-083 |
| CF26 | P1 | 300099 5MONTCT 161.00 300523 5WLMSBG 161.00 1 | 28W | 98.4 | 104.4 | 85.5 | GI-083 |
| | | | 33W | 94.9 | 100.4 | 82.4 | |

| Constraint ID | Event | Monitored Facility | Season | Base Loading | Project Loading | Upgrade Loading | Contingent Generator(s) |
|---------------|-------|--|--------|-----------------|-----------------|-----------------|-------------------------|
| CF27 | P1 | 300517 2KINGDM 69.000 301497 5KINGDMB2 161.00 2 | 28H | 99.2 | 102.2 | NB ⁶ | GI-083 |
| | | | 28S | 145.4 | 149.5 | NB ⁶ | |
| | | | 28W | 129.9 | 133.1 | NB ⁶ | |
| | | | 33S | 147.2 | 151.0 | NB ⁶ | |
| | P2EHV | | 33W | 133.1 | 136.1 | NB ⁶ | |
| | | | 28H | 99.1 | 102.5 | NB ⁶ | |
| | | | 28W | 116.8 | 120.1 | NB ⁶ | |
| | | | 33W | 120.2 | 123.6 | NB ⁶ | |
| CF28 | P1 | 300517 2KINGDM 69.000 301497 5KINGDMB2 161.00 3 | 28H | 109.6 | 113.1 | 66.7 | GI-083 |
| | | | 28S | 145.2 | 149.4 | 88.1 | |
| | | | 28W | 129.8 | 132.9 | 80.8 | |
| | | | 33S | 147.0 | 150.8 | 88.5 | |
| | P2EHV | | 33W | 133.0 | 136.0 | 82.8 | |
| | | | 28H | 99.0 | 102.4 | 65.7 | |
| | | | 28W | 116.7 | 120.0 | 79.4 | |
| | | | 33W | 120.1 | 123.5 | 82.1 | |
| CF29 | P1 | 300530 2GEOGT2 69.000 300541 2SEDALI 69.000 1 | 28S | 94.7 | 137.2 | 81.1 | GI-091 |
| | | | 33S | 93.7 | 135.8 | 81.0 | |
| CF30 | P2EHV | 300168 5GOBKNOB 161.00 300173 2GOBKNOB 69.000 3 | 28W | 135.2 | 138.5 | 93.5 | GI-099/100 |
| CF31 | P2EHV | 300168 5GOBKNOB 161.00 300173 2GOBKNOB 69.000 4 | 28W | 144.2 | 147.6 | 99.7 | GI-099/100 |
| CF32 | P1 | 300254 2GOWER 69.000 300268 2STEW RV 69.000 1 | 28S | 97.7 | 102.6 | 85.2 | GI-101/102 |
| | | | 33S | 96.7 | 101.1 | 83.7 | |
| CF33 | P1 | 300259 2MAYSVL 69.000 300268 2STEW RV 69.000 1 | 28S | 104.2 | 109.1 | 91.7 | GI-101/102 |
| | | | 33S | 103.2 | 107.7 | 90.3 | |
| CF34 | P0 | 500 SHOALCR 161.00 300036 5ELATHRP 161.00 1 | 28H | 134.8 | 140.6 | 39.5 | GI-101/102 |
| | | | 28L | 136.6 | 140.1 | 38.4 | |
| | | | 28S | 151.8 | 155.7 | 43.8 | |
| | | | 33S | 150.4 | 153.8 | 43.3 | |
| | P1 | | 28H | 135.4 | 141.2 | 39.6 | |
| | | | 28L | 137.1 | 140.7 | 38.6 | |
| | | | 28S | 153.4 | 157.3 | 44.1 | |
| | | | 28W | NC ⁷ | 143.6 | 42.2 | |
| | | | 33S | 152.0 | 155.4 | 43.7 | |
| | | | 33W | NC ⁷ | 143.5 | 42.2 | |

⁶ With the inclusion of Network Upgrades and Contingent Facilities, monitored facility no longer exists. NB = no branch.

⁷ Contingency that causes reported overload created as part of the Project or Network Upgrades; no Base loading available. NC = no contingency.

| Constraint ID | Event | Monitored Facility | Season | Base Loading | Project Loading | Upgrade Loading | Contingent Generator(s) |
|---------------|-------|---|--------|-----------------|-----------------|-----------------|-------------------------|
| | P2EHV | | 28H | 134.8 | 140.6 | 39.5 | |
| | | | 28L | 136.7 | 140.2 | 38.5 | |
| | | | 28S | 151.9 | 155.8 | 43.8 | |
| | | | 33S | 150.5 | 153.8 | 43.3 | |
| CF35 | P1 | 300091 5LATHRP 161.00 300302 2LATHRP 69.000 1 | 28H | 227.3 | 234.3 | 82.8 | GI-101/102 |
| | | | 28L | 221.2 | 224.3 | 82.5 | |
| | | | 28S | 252.1 | 256.6 | 86.5 | |
| | | | 33S | 251.4 | 255.6 | 88.0 | |
| CF36 | P1 | 300192 2RCKWOLT 69.000 300292 2CAMERN 69.000 1 | 28H | 109.2 | 115.9 | 68.0 | GI-101/102 |
| | | | 28L | 100.0 | 104.0 | 54.6 | |
| | | | 28S | 134.8 | 139.1 | 86.3 | |
| | | | 33S | 133.9 | 137.8 | 85.6 | |
| CF37 | P1 | 300192 2RCKWOLT 69.000 300293 2CAMRNJ 69.000 1 | 28H | 103.5 | 110.2 | 62.1 | GI-101/102 |
| | | | 28L | 98.2 | 102.1 | 52.7 | |
| | | | 28S | 127.3 | 131.4 | 78.3 | |
| | | | 33S | 126.1 | 129.9 | 77.4 | |
| CF38 | P0 | 300297 2HOLT 69.000 300302 2LATHRP 69.000 1 | 28H | 106.3 | 111.9 | 53.4 | GI-101/102 |
| | | | 28S | 130.7 | 134.3 | 65.1 | |
| | | | 33S | 131.1 | 134.4 | 65.3 | |
| | P1 | | 28H | 107.3 | 113.0 | 53.8 | |
| | | | 28L | 111.1 | 114.1 | 45.8 | |
| | | | 28S | 132.2 | 135.3 | 65.7 | |
| | | | 28W | NC ⁷ | 108.7 | 59.0 | |
| | | | 33S | 131.7 | 134.9 | 65.5 | |
| | | | 33W | NC ⁷ | 109.3 | 59.5 | |
| | P2EHV | | 28H | 106.5 | 112.1 | 53.4 | |
| | | | 28L | 98.5 | 103.1 | 43.7 | |
| | | | 28S | 131.0 | 134.5 | 65.1 | |
| CF39 | P0 | 300297 2HOLT 69.000 300311 2SMRSET 69.000 1 | 28H | 93.9 | 100.0 | 47.1 | GI-101/102 |
| | | | 28S | 114.7 | 118.3 | 56.7 | |
| | | | 33S | 114.8 | 118.2 | 56.9 | |
| | P1 | | 28H | 95.1 | 101.1 | 47.5 | |
| | | | 28L | 107.4 | 110.4 | 43.8 | |
| | | | 28S | 116.4 | 119.4 | 57.4 | |
| | | | 33S | 115.3 | 118.8 | 57.1 | |
| | P2EHV | | 28H | 97.4 | 103.4 | 48.3 | |
| | | | 28S | 115.0 | 118.5 | 56.8 | |
| | | | 33S | 117.0 | 120.1 | 57.2 | |

| Constraint ID | Event | Monitored Facility | Season | Base Loading | Project Loading | Upgrade Loading | Contingent Generator(s) | |
|---------------|-------|---|--------|-----------------|-----------------|-----------------|-------------------------|------|
| CF40 | P1 | 300301 2KEARNY 69.000 300311 2SMRSET 69.000 1 | 28H | 97.7 | 102.3 | 31.5 | GI-101/102 | |
| | | | 28L | 103.2 | 106.3 | 31.4 | | |
| | | | 28S | 109.5 | 112.7 | 36.0 | | |
| CF41 | P1 | 300302 2LATHRP 69.000 300313 2WESTBR 69.000 1 | 28H | 142.2 | 147.7 | 84.4 | GI-101/102 | |
| | | | 28S | 157.2 | 160.6 | 91.7 | | |
| | | | 33S | 156.1 | 159.9 | 91.4 | | |
| CF42 | P1 | 300302 2LATHRP 69.000 301627 2LATHRPLD 69.000 1 | 28H | 137.3 | 147.1 | 75.5 | GI-101/102 | |
| | | | 28L | 138.4 | 144.3 | 71.9 | | |
| | | | 28S | 168.3 | 174.2 | 95.1 | | |
| | | | 33S | 166.2 | 171.7 | 93.2 | | |
| CF43 | P1 | 300312 2TURNEY 69.000 300316 2LATHRPEMG 69.000 1 | 28H | 146.0 | 155.8 | 42.7 | GI-101/102 | |
| | | | 28L | 141.2 | 147.1 | 37.5 | | |
| | | | 28S | 179.3 | 185.4 | 53.8 | | |
| | | | 33S | 177.6 | 183.2 | 53.1 | | |
| CF44 | P1 | 300316 2LATHRPEMG 69.000 301627 2LATHRPLD 69.000 1 | 28H | 145.9 | 155.7 | 42.6 | GI-101/102 | |
| | | | 28L | 141.1 | 146.9 | 37.4 | | |
| | | | 28S | 179.2 | 185.2 | 53.7 | | |
| | | | 33S | 177.5 | 183.1 | 53.0 | | |
| CF45 | P1 | 300249 2FAIRPT 69.000 300259 2MAYSVL 69.000 1 | 28S | 95.7 | 101.4 | 72.7 | GI-101/102 | |
| | | | 33S | 106.0 | 110.5 | 93.1 | | |
| CF46 | P1 | 300306 2PARADS 69.000 300310 2SMITHV 69.000 1 | 28S | 103.9 | 107.8 | 59.7 | GI-101/102 | |
| | | | 33S | 102.7 | 106.3 | 58.5 | | |
| CF47 | P1 | 300306 2PARADS 69.000 300313 2WESTBR 69.000 1 | 28S | 104.2 | 108.0 | 60.0 | GI-101/102 | |
| | | | 33S | 102.9 | 106.6 | 58.8 | | |
| CF48 | P0 | 300036 5ELATHRP 161.00 300091 5LATHRP 161.00 1 | 28H | 123.1 | 128.9 | 34.7 | GI-101/102 | |
| | | | 28L | 125.0 | 128.5 | 33.7 | | |
| | | | 28S | 140.1 | 144.0 | 39.1 | | |
| | | | 33S | 138.7 | 142.1 | 38.6 | | |
| | P1 | | 28H | 123.7 | 129.5 | 34.9 | | |
| | | | 28L | 125.5 | 129.0 | 33.8 | | |
| | | | 28S | 141.7 | 145.6 | 39.4 | | |
| | | | 28W | NC ⁷ | 134.2 | 42.4 | | |
| | | | 33S | 140.3 | 143.7 | 39.0 | | |
| | | | 33W | NC ⁷ | 134.0 | 42.4 | | |
| | | | P2EHV | 28H | 123.0 | 128.9 | | 34.7 |
| | | | | 28L | 125.1 | 128.6 | | 33.7 |
| | | | | 28S | 140.2 | 144.1 | | 39.1 |
| 33S | 138.7 | 142.1 | | 38.6 | | | | |
| CF49 | P0 | | 28H | 99.2 | 104.7 | 29.6 | GI-101/102 | |

| Constraint ID | Event | Monitored Facility | Season | Base Loading | Project Loading | Upgrade Loading | Contingent Generator(s) |
|---------------|-------|---|--------|-----------------|-----------------|-----------------|-------------------------|
| | P1 | 300091 5LATHRP 161.00 301563 5MOCITYB1 161.00 1 | 28L | 105.3 | 108.9 | 31.2 | |
| | | | 28S | 113.0 | 116.7 | 33.2 | |
| | | | 33S | 111.4 | 114.6 | 32.5 | |
| | | | 28H | 99.7 | 105.3 | 29.8 | |
| | | | 28L | 105.9 | 109.4 | 31.4 | |
| | | | 28S | 114.7 | 118.3 | 33.7 | |
| | | | 28W | NC ⁷ | 111.8 | 31.3 | |
| | | | 33S | 113.1 | 116.3 | 33.0 | |
| | | | 33W | NC ⁷ | 111.5 | 31.2 | |
| | P2EHV | | 28H | 99.1 | 104.7 | 29.6 | |
| | | | 28L | 105.4 | 108.9 | 31.2 | |
| | | | 28S | 113.0 | 116.7 | 33.2 | |
| | | | 33S | 111.5 | 114.7 | 32.5 | |
| CF50 | P1 | 300107 5OSBORN 161.00 300290 2OSBORN 69.000 1 | 28H | 145.8 | 150.7 | 80.5 | GI-101/102 |
| | | | 28L | 127.4 | 130.5 | 55.9 | |
| | | | 28S | 166.2 | 169.9 | 93.8 | |
| | | | 33S | 178.4 | 181.9 | 93.1 | |
| CF51 | P1 | 300290 2OSBORN 69.000 301629 2OSBORNTPS 69.000 1 | 28H | 95.7 | 101.7 | 55.7 | GI-101/102 |
| | | | 28S | 108.1 | 111.2 | 73.1 | |
| | | | 33S | 117.9 | 121.4 | 70.2 | |
| CF52 | P1 | 300292 2CAMERN 69.000 301629 2OSBORNTPS 69.000 1 | 28H | 95.7 | 101.7 | 55.7 | GI-101/102 |
| | | | 28S | 108.1 | 111.2 | 73.1 | |
| | | | 33S | 117.9 | 121.4 | 70.2 | |
| CF53 | P1 | 300137 4BRISTOW 138.00 300140 4SILVCTY 138.00 1 | 28L | 94.9 | 100.3 | 51.5 | GI-103 |
| CF54 | P1 | 300137 4BRISTOW 138.00 300686 4WOODY 138.00 1 | 28H | NC ⁷ | 127.2 | 66.4 | GI-103 |
| | | | 28L | 140.3 | 145.9 | 78.3 | |
| | | | 28S | NC ⁷ | 133.3 | 69.5 | |
| | | | 28W | NC ⁷ | 109.0 | 59.6 | |
| | | | 33S | NC ⁷ | 133.6 | 69.6 | |
| | | | 33W | NC ⁷ | 111.2 | 60.9 | |
| CF55 | P1 | 300137 4BRISTOW 138.00 300889 2BRIISTOW 69.000 2 | 28H | NC ⁷ | 147.0 | 50.1 | GI-103 |
| | | | 28L | 78.4 | 104.8 | 36.0 | |
| | | | 28S | NC ⁷ | 158.9 | 53.4 | |
| | | | 28W | NC ⁷ | 136.0 | 46.1 | |
| | | | 33S | NC ⁷ | 160.4 | 53.9 | |
| | | | 33W | NC ⁷ | 137.5 | 46.6 | |
| CF56 | P1 | 300686 4WOODY 138.00 521026 PHAROAH4 138.00 1 | 28H | NC ⁷ | 120.0 | 71.7 | GI-103 |
| | | | 28L | 141.4 | 146.1 | 89.1 | |

| Constraint ID | Event | Monitored Facility | Season | Base Loading | Project Loading | Upgrade Loading | Contingent Generator(s) |
|---------------|-------|---|--------|-----------------|-----------------|-----------------|----------------------------------|
| | | | 28S | NC ⁷ | 123.6 | 73.8 | |
| | | | 33S | NC ⁷ | 123.5 | 73.7 | |
| CF57 | P1 | 300889 2BRIISTOW 69.000 513092 BEGGS 2 69.000 1 | 28W | 97.1 | 100.1 | 67.2 | GI-103 |
| | | | 33S | 97.0 | 101.2 | 74.7 | |
| | | | 33W | 97.4 | 101.0 | 67.8 | |
| CF58 | P1 | 300196 2WOODY 69.000 300906 2NUYAKA 69.000 1 | 28L | 102.8 | 117.1 | 63.5 | AECI/GI-105 |
| CF59 | P1 | 300906 2NUYAKA 69.000 513092 BEGGS 2 69.000 1 | 28L | 104.2 | 118.5 | 64.2 | AECI/GI-105 |
| CF60 | P1 | 300045 7MORGAN 345.00 301622 5MORGANXF1 161.00 1 | 28S | 90.7 | 112.2 | 78.7 | DISIS-2018-001 |
| | | | 28W | 85.8 | 100.9 | 71.6 | |
| | | | 33S | 92.3 | 113.1 | 79.6 | |
| | | | 33W | 86.3 | 102.5 | 72.5 | |
| | P2EHV | | 28H | 88.6 | 104.4 | 74.1 | |
| | | | 28S | 104.4 | 122.6 | 87.5 | |
| | | | 28W | 113.6 | 126.7 | 91.4 | |
| | | | 33S | 105.6 | 123.1 | 88.0 | |
| CF61 | P1 | 300043 7KINGDM 345.00 300090 5KINGDMB1 161.00 1 | 28H | 91.1 | 102.7 | 58.4 | GI-113 ⁸ |
| | | | 28L | 96.0 | 106.0 | 60.3 | |
| | | | 28S | 91.4 | 102.4 | 58.2 | |
| | | | 28W | 101.8 | 116.4 | 66.1 | |
| | | | 33S | 90.7 | 101.3 | 57.6 | |
| | | | 33W | 100.6 | 114.6 | 65.1 | |
| CF62 | P1 | 300520 2REFORM 69.000 300626 2CHAMOI 69.000 1 | 28W | 61.0 | 102.5 | 62.5 | GI-113 ⁸ |
| | | | 33W | 59.0 | 102.2 | 62.4 | |
| CF63 | P1 | 300889 2BRIISTOW 69.000 300898 2GYPSY 69.000 1 | 28H | 97.5 | 101.7 | NB ⁸ | AECI |
| CF64 | P1 | 300773 2ELKTON 69.000 300817 2OSCEOLA 69.000 1 | 28S | 66.7 | 105.8 | 83.8 | AECI |
| | | | 28W | 85.7 | 102.1 | 85.8 | |
| | | | 33S | 67.2 | 106.3 | 84.6 | |
| | | | 33W | 86.8 | 103.2 | 90.7 | |
| CF65 | P1 | 301050 2CONWY 69.000 301071 2PBURG 69.000 1 | 28S | 76.8 | 101.3 | 81.8 | AECI |
| | | | 33S | 78.0 | 102.1 | 82.5 | |
| CF66 | P1 | 300069 5CHOTEAU1 161.00 512648 MAID 5 161.00 1 | 28H | 114.5 | 129.9 | 129.8 | Prior Queue Studies ⁹ |
| | | | 28L | 126.9 | 131.0 | 130.9 | |
| | | | 28S | 119.7 | 133.5 | 133.4 | |
| | | | 28W | 110.4 | 123.8 | 123.6 | |

⁸ GI-113 withdrew mid-study, the impact of its withdrawal will be evaluated in a future restudy.

⁹ Ongoing studies show this element will be the responsibility of a higher queue SPP cluster. Current mitigations for these clusters are still being determined. Withdrawals from those clusters may result in a restudy of DISIS-2021.

| Constraint ID | Event | Monitored Facility | Season | Base Loading | Project Loading | Upgrade Loading | Contingent Generator(s) |
|---------------|-------|--------------------|--------|--------------|-----------------|-----------------|-------------------------|
| | | | 33S | 119.8 | 133.5 | 133.3 | |
| | | | 33W | 109.9 | 123.4 | 123.2 | |

NEIGHBORING SYSTEM RESULTS

The Study has identified impacts from the Study Cycle requests on the AECI ties with neighboring systems. The most limiting component of the AECI owned portion of the facility was evaluated and if found inadequate, a network upgrade for the AECI equipment was determined. Network upgrades for transmission facilities limited by non-AECI equipment are not captured and may need to be coordinated with the appropriate transmission owner.

Three (3) facilities were reported on the AECI ties with the addition of the Study Cycle requests. The most severe constraints are shown in Table 4.

Table 4: Steady State Neighboring System Constraints for the Study Cycle Requests

| Constraint ID | Event | Monitored Facility | Area | Season | Base Loading | Project Loading |
|---------------|-------|--|-----------|--------|--------------|-----------------|
| AFS01 | P1 | 300071 5CLINTN 161.00 761278 G17-108-TAP 161.00 1 | AECI/KCPL | 28S | 34.2 | 106.3 |
| | | | | 33S | 34.4 | 106.6 |
| AFS02 | P0 | 300098 5MOCITYB2 161.00 541248 LBRTYST5 161.00 1 | AECI/KCPL | 28S | 81.2 | 101.4 |
| | | | | 33S | 82.4 | 101.7 |
| | P1 | | | 28H | 87.1 | 115.5 |
| | | | | 28L | 95.2 | 119.6 |
| | P2EHV | | | 28S | 87.1 | 107.1 |
| | | | | 28W | 89.9 | 114.3 |
| | | | | 33S | 88.3 | 107.5 |
| | | | | 33W | 90.3 | 115.8 |
| | | | | 28S | 85.4 | 104.2 |
| | | | | 33S | 86.5 | 104.5 |
| AFS03 | P1 | 300740 7SPORTSMAN 345.00 512650 GRDA1 7 345.00 1 | AECI/GRDA | 28H | 96.4 | 110.5 |
| | | | | 28L | 107.1 | 111.1 |
| | | | | 28S | 101.7 | 113.9 |
| | | | | 28W | 106.9 | 120.2 |
| | | | | 33S | 101.6 | 113.8 |
| | | | | 33W | 106.5 | 119.8 |

NETWORK UPGRADES

The upgrades shown in Table 5 were evaluated in order to mitigate the reported steady state contingent constraints for the Study Cycle requests as listed in Table 3.

Table 5: Network Upgrades for the Study Cycle Contingent Constraints

| Constraint ID | Monitored Facility | Network Upgrade |
|---------------|---|--|
| CF01 | 300073 5GENTRY 161.00 300076 5FAIRPTB2 161.00 1 | Contingent on SPP DISIS-2017-002 SPP NU: Build a new 161 kV line from Archie to G17-108-TAP and place into service. |
| CF02 | 300323 2CENTRV 69.000 300336 2HOLDEN 69.000 1 | |
| CF03 | 300688 2AUSTIN 69.000 300696 2CREIGH 69.000 1 | |
| CF04 | 300651 2LAMR 69.000 300794 5LAMAR 161.00 1 | Contingent on SPP DISIS-2017-002: Install a second Lamar 161/69 kV transformer rated at 84 MVA Summer, 95 MVA Winter unit. |
| CF05 | 300772 2COFMAN 69.000 300780 2KNOBBY 69.000 1 | Contingent on SPP DISIS-2017-002: Rebuild 4.70 mile long line from Coffman Bend-Knobby 69 kV to 795 ACSR rated at 100C. |
| CF06 | 300780 2KNOBBY 69.000 301401 2TURKEYCRK 69.000 1 | Contingent on SPP DISIS-2017-002: Rebuild 12.1 mile long line from Knobby to Turkey Creek 69 kV to 795 ACR rated at 100C. |
| CF07 | 300173 2GOBKNOB 69.000 301230 2FAIRDLG 69.000 1 | Contingent on GI-099/100: See upgrade for CF30 below. Contingent on SPP DISIS-2018-001: Rebuild 2.5 mile long 4/0 section of Gobbler Knob-Fairdealing 69 kV line to 795 ACSR at 100C. |
| CF08 | 301201 2DONIPH 69.000 301227 2RIPLEY 69.000 1 | Contingent on GI-099/100: See upgrade for CF30 below. Contingent on SPP DISIS-2018-001: Rebuild 1.3 mile long line from Doniphan-Ripley 69 kV to 336 ACSR, rated at 100C. |
| CF09 | 301217 2OXLEY 69.000 301227 2RIPLEY 69.000 1 | Contingent on GI-099/100: See upgrade for CF30 below. Contingent on SPP DISIS-2018-001: Rebuild 3.8 mile long line from Ripley-Oxly 69 kV to 336 ACSR, rated at 100C. |
| CF10 | 301217 2OXLEY 69.000 301230 2FAIRDLG 69.000 1 | Contingent on GI-099/100: See upgrade for CF30 below. Contingent on SPP DISIS-2018-001: Rebuild 5.9 mile long 4/0 section of Oxly-Fairdealing 69 kV line to 795 ACSR at 100C. |
| CF11 | 300293 2CAMRNJ 69.000 300312 2TURNEY 69.000 1 | Contingent on AECI: Rebuild 7.7-mile-long Cameron Junction-Turney 69 kV line to 336 ACSR at 100C. |
| CF12 | 301201 2DONIPH 69.000 505440 DONIPH5 161.00 1 | Contingent on SPP DISIS-2018-001: See upgrade for CF07. See upgrade for CF10. |
| CF13 | 300541 2SEDALI 69.000 300545 2SYLVAN 69.000 1 | Contingent on GI-091: Upgrade bushing CTs (via breaker upgrade), breaker switchers on Sylvan-Sedalia 69 kV line (at Sedalia) to 1200 amp rating. |

| Constraint ID | Monitored Facility | Network Upgrade |
|---------------|---|---|
| CF14 | 300772 2COFMAN 69.000 300779 2J&7 69.000 1 | Contingent on SPP DISIS-2020: Rebuild 69 kV 6.31 mile long line from Coffman Bend- J-7 to 795 ACSR rated at 100C. |
| CF15 | 300115 5STFRANB2 161.00 338202 5JIM HILL% 161.00 1 | Contingent on MISO DPP-2019: Rebuild 9.9 mile-long St. Francis to Jim Hill 161 kV line to 1192 ACSS at 250C. Replace jumpers at St. Francis with 1192 ACSS at 250C. Replace disconnect switches at St. Francis 161 kV bus on Jim Hill line with 3000A switches. |
| CF16 | 300124 5HOLDENB2 161.00 300336 2HOLDEN 69.000 1 | Contingent on MISO DPP-2019: Add a second 161/69 kV transformer at Holden with rating of 84 MVA Summer, 95 MVA Winter. |
| CF17 | 300327 2ELM 69.000 300336 2HOLDEN 69.000 1 | Contingent on MISO DPP-2019: Rebuild 3.1 mile 336 ACSR segment of Elm-Holden (existing double circuit). Utilize 556 ACSR at 100C for 69 kV circuit. |
| CF18 | 300061 5BOONE 161.00 300519 5MLRSBGB1 161.00 1 | Contingent on MISO DPP-2019: Reconductor 9.4 mile long Boone-Millersburg 161 kV line with 795 ACSS at 250C. Replace jumpers on both side of line with 795 ACSS High Temp. |
| CF19 | 300387 2BEVIER 69.000 301623 2BEVIERTP 69.000 1 | Contingent on MISO DPP-2019: Rebuild 0.1 mile-long Bevier-Bevier Tap 69 line to 795 ACSR at 100C. |
| CF20 | 300398 2LOVELK 69.000 300401 2MACNTP 69.000 1 | Contingent on MISO DPP-2019: Rebuild 12.2 mile-long Love Lake-Macon Tap line to 336 ACSR at 100C. |
| CF21 | 300400 2MACNLK 69.000 301623 2BEVIERTP 69.000 1 | Contingent on MISO DPP-2019: Rebuild the 4.136-mile-long Bevier-Macon Lake 69 kV line to 795 ACSR. |
| CF22 | 300388 2AXTELL 69.000 300401 2MACNTP 69.000 1 | Contingent on MISO DPP-2019: Rebuild 1.05 mile-long Axtell-Macon Tap 69 kV line to 795 ACSR. |
| CF23 | 300388 2AXTELL 69.000 300400 2MACNLK 69.000 1 | Contingent on MISO DPP-2019: Rebuild 1.15 mile-long Axtell-Macon Lake 69 line to 795 ACSR. |
| CF24 | 300571 2MEXICO 69.000 300580 2SLTRVR 69.000 1 | Contingent on GI-083: Kingdom City/Auxvasse/Salt River Upgrades: Rebuild 8 mile-long Kingdom City-Auxvasse 69 kV line to 161 kV. - Utilize 795 ACSR at 100C. - Re-terminate the line on the 161 kV Bus #1 at Kingdom City. Rebuild 9 mile Auxvasse-Salt River Tap 69 kV line to 161 kV. - Utilize 795 ACSR at 100C. - Re-terminate the line on the 161 kV bus at Salt River. Rebuild 1 mile-long Salt River Tap-Salt River line to 161/69 kV D.C. - 161 kV will be 795 ACSR at 100C. - 69 kV will be 336 ACSR at 100C. Modify the Salt River 69 kV station to include a 161/69 kV 84 MVA Summer/96 MVA Winter transformer and 2 161 kV terminal positions. Construct new 69 kV section between Salt River and Vandiver. Convert Auxvasse 69 kV station to 161 kV. |
| CF25 | 300090 5KINGDMB1 161.00 300523 5WLMSBG 161.00 1 | |
| CF26 | 300099 5MONTCT 161.00 300523 5WLMSBG 161.00 1 | |
| CF27 | 300517 2KINGDM 69.000 301497 5KINGDMB2 161.00 2 | |
| CF28 | 300517 2KINGDM 69.000 301497 5KINGDMB2 161.00 3 | |
| CF29 | 300530 2GEOGT2 69.000 300541 2SEDALI 69.000 1 | Contingent on GI-091: Upgrade bushing CTs (via breaker upgrade), breaker switchers on Georgetown-Sedalia 69 kV line (at Sedalia) to 1200 amp rating. |
| CF30 | 300168 5GOBKNOB 161.00 300173 2GOBKNOB 69.000 3 | Contingent on GI-099/100: Rebuild existing 69 kV line from Gobbler - PB South - Harviell - Poplar Bluff - Township - Green Forest to double circuit 161 and 69 kV. The 69 kV circuit will be constructed to 795 ACSR and terminate at stations as it currently does. The 161 kV circuit will be constructed to 795 ACSS High Temp at 200C and terminate only at Gobbler Knob and Green Forest. Add terminals and associated equipment as needed at Gobbler and Green Forest stations. |

| Constraint ID | Monitored Facility | Network Upgrade |
|---------------|---|--|
| CF31 | 300168 5GOBKNOB 161.00 300173 2GOBKNOB 69.000 4 | The individual line segments are: - Rebuild 4.4-mile-long Gobbler Knob-Poplar Bluff South 69 kV line with 795 ACSR at 100C. - Rebuild 2.5-mile-long Green Forest-Township 69kV line with 795 ACSR at 100C. - Rebuild 4.5-mile-long Harviell-Poplar Bluff South 69 kV line with 795 ACSR at 100C. - Rebuild 6.3-mile-long Harviell-Poplar Bluff 69 kV line with 795 ACSR at 100C. - Rebuild 2.7-mile-long Poplar Bluff-Township 69 kV line with 795 ACSR at 100C. - Construct a new 161 kV circuit from Gobbler Knob-Green Forest along the existing 69 kV path between these stations. Use 795 ACSS High Temp at 200C. |
| CF32 | 300254 2GOWER 69.000 300268 2STEW RV 69.000 1 | <p>Contingent on GI-101/102: Build a new 27.8 mile long 161 kV circuit between Shoal Creek and Missouri City utilizing 1192 ACSS at 200C. Line will be overbuilt on the 69 kV line from Turney-Lathrop Load-Lathrop-Holt-Summerset-Kearney-Missouri City. The 69 kV lines will be replaced with 336 ACSR at 100C. Add a new 161 kV terminal and reconfigure Missouri City 161 kV bus to accommodate the new 161 kV line between Missouri City and Shoal Creek. Add a new 161 kV terminal and reconfigure MO City 161 kV bus as needed to accommodate the new 161 kV line between MO City and Shoal Creek.</p> |
| CF33 | 300259 2MAYSVL 69.000 300268 2STEW RV 69.000 1 | |
| CF34 | 500 SHOALCR 161.00 300036 5ELATHRP 161.00 1 | |
| CF35 | 300091 5LATHRP 161.00 300302 2LATHRP 69.000 1 | |
| CF36 | 300192 2RCKWOLT 69.000 300292 2CAMERN 69.000 1 | |
| CF37 | 300192 2RCKWOLT 69.000 300293 2CAMRNJ 69.000 1 | |
| CF38 | 300297 2HOLT 69.000 300302 2LATHRP 69.000 1 | |
| CF39 | 300297 2HOLT 69.000 300311 2SMRSET 69.000 1 | |
| CF40 | 300301 2KEARNY 69.000 300311 2SMRSET 69.000 1 | |
| CF41 | 300302 2LATHRP 69.000 300313 2WESTBR 69.000 1 | |
| CF42 | 300302 2LATHRP 69.000 301627 2LATHRPLD 69.000 1 | |
| CF43 | 300312 2TURNEY 69.000 300316 2LATHRPEMG 69.000 1 | |
| CF44 | 300316 2LATHRPEMG 69.000 301627 2LATHRPLD 69.000 1 | |
| CF45 | 300249 2FAIRPT 69.000 300259 2MAYSVL 69.000 1 | |
| CF46 | 300306 2PARADS 69.000 300310 2SMITHV 69.000 1 | |
| CF47 | 300306 2PARADS 69.000 300313 2WESTBR 69.000 1 | |
| CF48 | 300036 5ELATHRP 161.00 300091 5LATHRP 161.00 1 | |
| CF49 | 300091 5LATHRP 161.00 301563 5MOCITYB1 161.00 1 | <p>Contingent on GI-101/102: Rebuild 23.2 mile long Missouri City-Lathrop 161 kV line to 1192 ACSS at 200C. Upgrade jumpers at Lathrop and Missouri City on line to 1192 ACSS at 200C. Upgrade relay limits at Missouri City to 477 MVA Summer, 595 MVA Winter minimum.</p> |
| CF50 | 300107 5OSBORN 161.00 300290 2OSBORN 69.000 1 | <p>Contingent on GI-101/102: Osborn Upgrades: - Construct a new 161 kV switchyard called Shoal Creek ~0.5 miles east of Rockies Express. - Cut existing REX-Osborn 161 kV line in/out of new switchyard. - Rebuild 12.2 mile long Osborn-Shoal Creek 161 kV line to 1192 ACSR at 100C. - Upgrade jumpers at Osborn on line to 1192 ACSR. - Upgrade disconnect switches at Osborn on line to 2,000 amp switches. - Upgrade bushing CTs at Osborn on line to 2,000 base amps.</p> |

| Constraint ID | Monitored Facility | Network Upgrade |
|---------------|---|---|
| CF51 | 300290 2OSBORN 69.000 301629 2OSBORNTPS 69.000 1 | Contingent on GI-101/102: See upgrades on CF50 |
| CF52 | 300292 2CAMERN 69.000 301629 2OSBORNTPS 69.000 1 | |
| CF53 | 300137 4BRISTOW 138.00 300140 4SILVCTY 138.00 1 | Contingent on GI-103: Rebuild 21.6 mile Bristow-Silver City 138 kV line to 1192 ACSR at 100C. At Bristow 138 kV substation: - Upgrade wave trap to 2000 A. - Upgrade jumpers to 1192 ACSR. - Upgrade disconnect switches to 2000 A. - Upgrade breaker switchers to 2000 A. At Silver City 138 KV substation: - Upgrade jumpers to 1192 ACSR. |
| CF54 | 300137 4BRISTOW 138.00 300686 4WOODY 138.00 1 | Contingent on GI-103: Rebuild 21.7 mile Bristow-Woody 138 kV line to 1192 ACSR at 100C. At Bristow 138 kV substation: - Upgrade wave trap to 2000 A. - Upgrade jumpers to 1192 ACSR. - Upgrade disconnect switches to 2000 A. - Upgrade breaker switchers to 2000 A. - Upgrade bushing CTs to 2000 A. At Woody 138 KV substation: - Upgrade jumpers to 1192 ACSR. |
| CF55 | 300137 4BRISTOW 138.00 300889 2BRIISTOW 69.000 2 | Contingent on GI-103: Upgrade existing Bristow 138/69 kV transformer to a 112 MVA Summer/127 MVA Winter rated unit. Add a second 138/69 kV transformer at Bristow with rating of 112 MVA Summer/127 MVA Winter. |
| CF56 | 300686 4WOODY 138.00 521026 PHAROAH4 138.00 1 | Contingent on GI-103: Rebuild 13.40 mile Woody-Pharoah 138 kV line to 1192 ACSR at 100C. At Woody 138 kV substation: - Upgrade jumpers to 1192 ACSR. At Pharoah 138 kV substation: - Upgrade jumpers to 1192 ACSR. |
| CF57 | 300889 2BRIISTOW 69.000 513092 BEGGS 2 69.000 1 | Contingent on GI-103: Rebuild 0.90 mile KAMO owned line section of Bristow-Beggs 69 kV line to 336 ACSR at 100C. |
| CF58 | 300196 2WOODY 69.000 300906 2NUYAKA 69.000 1 | Contingent on AECI: See upgrade for CF63 below. Contingent on GI-105: Rebuild 9.4 mile Woody-Nuyaka 69 kV line to 336 ACSR at 100C. |
| CF59 | 300906 2NUYAKA 69.000 513092 BEGGS 2 69.000 1 | Contingent on AECI: See upgrade for CF63 below. Contingent on GI-105: Rebuild 9.20 mile Beggs-Nuyaka 69 kV line to 336 ACSR at 100C |
| CF60 | 300045 7MORGAN 345.00 301622 5MORGANXF1 161.00 1 | Contingent on DISIS-2018-001: Replace the Morgan 345/161 kV transformer with a unit rated 560 MVA Summer and 638 MVA Winter. Upgrade 161 kV breaker switchers and relay limits as needed to accommodate larger transformer rating. |
| CF61 | 300043 7KINGDM 345.00 300090 5KINGDMB1 161.00 1 | Contingent on GI-113⁸: Install a second 345/161 kV transformer rated for 560 MVA Summer, 638 MVA Winter at Kingdom City. |
| CF62 | 300520 2REFORM 69.000 300626 2CHAMOI 69.000 1 | Contingent on GI-113⁸: Upgrade Bushing CT's to 600A rating at the Chamois bus on Chamois-Reform 69 kV line. |

| Constraint ID | Monitored Facility | Network Upgrade |
|---------------|---|--|
| CF63 | 300889 2BRIISTOW 69.000 300898 2GYPSY 69.000 1 | Contingent on AECI: Rebuild and convert 9.5-mile-long section of Bristow-Gypsy 69 kV line to 138 kV 1192.5 ACSR at 100C -Convert Gypsy substation to 138kV. -Install a GOAB near Gypsy station to create a 3 terminal 138 kV line between Stroud, Gypsy, and Bristow. -Build additional 138kV bay at Bristow. -Re-terminate line at Bristow sub to land on 138kV bay. Rebuild and convert 0.09-mile-long section of Gypsy-Stroud 69 kV line to 138 kV 1192.5 ACSR at 100C. -Build additional 138kV bay at Stroud. -Re-terminate line at Stroud sub to land on 138 kV bay. |
| CF64 | 300773 2ELKTON 69.000 300817 2OSCEOLA 69.000 1 | Contingent on AECI: Rebuild and convert Buffalo Area to 161 kV. -Add 84 MVA 161/69 kV transformer at Buffalo. -Rebuild March-Buffalo-Long Lane 69 kV lines to 161 kV at 795 ACSR at 100C. |
| CF65 | 301050 2CONWY 69.000 301071 2PBURG 69.000 1 | -Convert Long Lane and March load substations to 161 kV. -Convert Long Lane-Phillipsburg and Cross Way-March to 161 kV operation. They are currently designed for 161 kV but operated at 69 kV. |
| CF66 | 300069 5CHOTEAU1 161.00 512648 MAID 5 161.00 1 | Contingent on Prior Queued Studies: Overload will be mitigated by upgrades tagged to higher queue request. Final scope of the upgrades tagged to higher queue request are still being developed. |

No upgrades were evaluated for the neighboring system constraints listed in Table 4. The upgrades for these impacts may need to be resolved through coordination with the transmission owner as listed in Table 6 below.

Table 6: Neighboring System Constraints

| Constraint ID | Monitored Facility | Network Upgrade |
|---------------|---|--|
| AFS01 | 300071 5CLINTN 161.00 761278 G17-108-TAP 161.00 1 | MLE owned by KCPL; no upgrade evaluated. |
| AFS02 | 300098 5MOCITYB2 161.00 541248 LBRTYST5 161.00 1 | MLE owned by KCPL; no upgrade evaluated. |
| AFS03 | 300740 7SPORTSMAN 345.00 512650 GRDA1 7 345.00 1 | MLE owned by GRDA; no upgrade evaluated. |

AECI developed non-binding, good faith estimates of the timing and cost estimates for upgrades needed as a result of the addition of the Study Cycle requests as shown in Table 7.

Table 7: Network Upgrade Costs

| ID | Option/Description | Estimated Cost | Estimated Lead Time ¹⁰ |
|---------------|---|----------------|-----------------------------------|
| NU01 | Upgrade separately mounted bushing CTs on Morgan-Dadeville 161 kV line (at Morgan) to 2,000 amp rating. | \$500,000 | 36 months |
| NU02 | Rebuild 26.5 mile long line from Morgan-Brookline 161 kV to 1192 ACSR, rated at 100C. | \$20,352,000 | 48 months |
| NU03 | Rebuild 1.2 mile long line from Lamar City North-Lamar Rural South 69 kV to 336 ACSR, rated at 100C. | \$1,000,000 | 36 months |
| NU04 | Rebuild 4.5 mile long line from Lamar-Jackson Street 69 kV to 795 ACSR, rated at 100C. | \$3,456,000 | 36 months |
| NU05 | Rebuild 0.3 mile long line from Lamar City North-Jackson Street 69 kV to 336 ACSR, rated at 100C. | \$500,000 | 36 months |
| NU06 | Rebuild 2.4 mile long line from Richland-Boston 69 kV (AECI owned portion) to 336 ACSR, rated at 100C. | \$1,740,000 | 36 months |
| NU07/08/09/10 | Adjustment of transformer taps required to mitigate overload. | \$0 | - |

¹⁰ Estimated Lead Time is the estimated time to place a network upgrade in service once AECI has received Provision of Security equal to the total Estimated Cost of the Network Upgrade.

| ID | Option/Description | Estimated Cost | Estimated Lead Time ¹⁰ |
|--------|--|----------------|-----------------------------------|
| N11 | Rebuild 2.6 mile 161 kV line from Truman to Lost Valley to 1192 ACSR at 100C ¹¹ | See footnote | See footnote |
| Total: | | \$27,548,000 | |

Cost allocations for each of the impacted facilities are discussed in the Cost Allocation section below.

¹¹ SPP identified Facility as overloaded in their study of DISIS-2021. AECI owns limiting equipment on this facility and has provided SPP an estimated cost to perform work shown. Reference SPP report for cost information on this facility.

COST ALLOCATION

Network upgrade costs are allocated to each of the Study Cycle projects based on the worst MW impact¹² each project had on the constraint and as described in the steps below:

1. Determine the MW impact each Study Cycle project had on each constraint using the size of each request in the season it was reported:

$$\text{Project X MW Impact on Constraint 1} = DFAX (X) * MW (X) = X1$$

$$\text{Project Y MW Impact on Constraint 1} = DFAX (Y) * MW (Y) = Y1$$

$$\text{Project Z MW Impact on Constraint 1} = DFAX (Z) * MW (Z) = Z1$$

2. Determine the maximum MW% impact each generator has as a percentage of the total Study Cycle impact on a given constraint.

$$X2 = \text{Project X MW impact \%} = \frac{X1}{\text{Total MW Impact of Study Cycle on Constraint}}$$

$$Y2 = \text{Project Y MW impact \%} = \frac{Y1}{\text{Total MW Impact of Study Cycle on Constraint}}$$

$$Z2 = \text{Project Z MW impact \%} = \frac{Z1}{\text{Total MW Impact of Study Cycle on Constraint}}$$

3. Apply three percent (3%) MW impact De Minimis Threshold: If a Study Cycle project MW% impact is less than 3% for a particular constraint then the project MW% impact is adjusted to 0 for that constraint and the Study Cycle project will not be allocated cost for that particular constraint.
4. Determine the cost allocated to each remaining Study Cycle project for each upgrade using the total cost of a given upgrade:

$$\text{Project X Upgrade 1 Cost Allocation (\$)} = \frac{\text{Network Upgrade 1 Cost (\$)} * X2}{X2 + Y2 + Z2}$$

The associated cost allocation of the network upgrades to each of the Study Cycle projects is shown below in Table 8. Further breakdown of costs is provided in Appendix B.

¹² All negative MW impacts (helpers) were set to 0 MW impact.

Table 8: Network Upgrade Cost Allocation

| Project | Cluster Group | POI | MW | Total Cost |
|----------------------------|---------------|--|---------|-------------|
| GEN-2021-001 | 04 SOUTHEAST | 138kV Brown Substation | 100 | \$0 |
| GEN-2021-004 ¹ | 04 SOUTHEAST | Poolville 138kV Bus | 250 | \$0 |
| GEN-2021-005 | 03 CENTRAL | Summit 345 kV substation in Saline County, KS | 350 | \$1,567,534 |
| GEN-2021-006 | 03 CENTRAL | Neosho 345kV substation in Labette County, KS | 300 | \$3,225,881 |
| GEN-2021-007 | 02 NEBRASKA | 345kV bus of Turtle Creek Substation | 600 | \$1,636,782 |
| GEN-2021-008 | 01 NORTH | 345kV Bus at BEPC Patent Gate Substation, McKenzie County, ND | 200 | \$0 |
| GEN-2021-010 | 04 SOUTHEAST | Border 345 kV interconnection substation | 233.98 | \$0 |
| GEN-2021-012 | 04 SOUTHEAST | Border 345 kV interconnection substation | 227 | \$0 |
| GEN-2021-014 | 04 SOUTHEAST | Border 345 kV interconnection substation | 233.98 | \$0 |
| GEN-2021-016 ¹³ | 04 SOUTHEAST | Sunnyside-Johnston 345 kV | 250 | \$0 |
| GEN-2021-018 | 04 SOUTHEAST | Sooner 345 kV | 235.35 | \$0 |
| GEN-2021-019 | 04 SOUTHEAST | Sooner 345 kV | 75.89 | \$0 |
| GEN-2021-023 | 03 CENTRAL | Wild Plains 345kV Substation | 306.18 | \$1,223,681 |
| GEN-2021-024 | 01 NORTH | WAPA 230kV Jamestown Substation | 203.04 | \$0 |
| GEN-2021-025 | 04 SOUTHEAST | Western Farmers 138kV Mooreland Substation | 203.04 | \$0 |
| GEN-2021-027 | 02 NEBRASKA | Olive Creek 115 kV Substation | 102.06 | \$0 |
| GEN-2021-028 | 04 SOUTHEAST | Western Farmers 138kV Mooreland Substation | 204.12 | \$0 |
| GEN-2021-029 | 03 CENTRAL | Every Tap the La Cygne to Stillwell 345 kV Line | 253.8 | \$2,025,870 |
| GEN-2021-030 | 03 CENTRAL | Every Tap the La Cygne to Stillwell 345 kV Line | 510.3 | \$4,073,291 |
| GEN-2021-033 | 04 SOUTHEAST | Grand Prairie 161kV Substation | 204.12 | \$0 |
| GEN-2021-034 | 02 NEBRASKA | Rokeby 115 kV Substation | 113 | \$0 |
| GEN-2021-036 | 04 SOUTHEAST | Craig to Patterson 138 kV Transmission Line | 204.12 | \$0 |
| GEN-2021-037 | 02 NEBRASKA | NPPD Sidney to Keystone 345 kV Line | 244.22 | \$0 |
| GEN-2021-038 ¹³ | 04 SOUTHEAST | Welsh 345kV Substation | 201.32 | \$0 |
| GEN-2021-039 | 02 NEBRASKA | New 161kV substation looping in OPPD 161kV lines S1211 to S1220 and S1211 to S1299 | 100 | \$0 |
| GEN-2021-040 | 02 NEBRASKA | OPPD District, Cass County Power Plant Substation, 345kV Bus | 200 | \$0 |
| GEN-2021-041 | 04 SOUTHEAST | Mustang 138kV Substation | 100.657 | \$0 |
| GEN-2021-042 | 03 CENTRAL | Independence Power & Light, Blue Valley Substation, 161kV Bus | 100 | \$0 |
| GEN-2021-043 | 02 NEBRASKA | 8000 SW 12th (Rokeby) Station, 115kV Bus | 250 | \$0 |
| GEN-2021-047 | 04 SOUTHEAST | Tulsa (Bus #509852) - Igloo (Bus #513596) 345kV line | 250 | \$0 |
| GEN-2021-048 | 02 NEBRASKA | Wagener 115kV Substation | 75 | \$0 |
| GEN-2021-049 | 02 NEBRASKA | Wagener 115kV Substation | 250 | \$0 |
| GEN-2021-050 | 03 CENTRAL | 161kV Stilwell-Clinton Line | 200 | \$2,402,822 |
| GEN-2021-051 | 03 CENTRAL | 161kV Stilwell-Clinton Line | 75 | \$676,826 |
| GEN-2021-053 | 04 SOUTHEAST | Pecan Creek 345 kV Substation | 300 | \$0 |
| GEN-2021-056 | 03 CENTRAL | Viola 345kV Substation | 300 | \$885,234 |
| GEN-2021-057 | 02 NEBRASKA | Antelope 345kV substation | 300 | \$666,156 |

¹³ MW used in Cost Allocations reflects the latest information available in SPP's queue.

| Project | Cluster Group | POI | MW | Total Cost |
|--------------|---------------|--|-------------------|---------------------|
| GEN-2021-063 | 04 SOUTHEAST | Craig JCT 138kV | 155 | \$0 |
| GEN-2021-064 | 04 SOUTHEAST | Carnegie South 138kV | 100 | \$0 |
| GEN-2021-068 | 03 CENTRAL | SUNC Spearville - Holcomb 345kV | 249.6 | \$0 |
| GEN-2021-069 | 03 CENTRAL | SUNC Spearville - Holcomb 345kV | 249.6 | \$0 |
| GEN-2021-070 | 03 CENTRAL | SUNC Spearville - Holcomb 345kV | 504 | \$1,266,366 |
| GEN-2021-072 | 01 NORTH | 345kV Transmission Line from Antelope Valley to Leland Olds Substation | 600 | \$1,385,901 |
| GEN-2021-073 | 02 NEBRASKA | Tap on the Sweetwater to Gerald Gentleman 345 kV Line | 240 | \$0 |
| GEN-2021-075 | 04 SOUTHEAST | CAMP COR4 138kV Substation | 300 | \$0 |
| GEN-2021-077 | 03 CENTRAL | Windsor to AEC Sedalia 161 kV | 95 | \$747,513 |
| GEN-2021-086 | 04 SOUTHEAST | Okay - Turk 138kV | 165 | \$0 |
| GEN-2021-088 | 04 SOUTHEAST | Cedar Lane - Canadian 138 kV Transmission Line | 100 | \$0 |
| GEN-2021-090 | 05 SOUTHWEST | Yoakum 345kV Substation | 400 | \$0 |
| GEN-2021-096 | 03 CENTRAL | Wolf Creek - Benton 345 kV | 500 | \$4,966,537 |
| GEN-2021-098 | 04 SOUTHEAST | Dewey District 138 kV Substation | 160 | \$0 |
| GEN-2021-101 | 03 CENTRAL | Evergy's Midland Substation 115kV bus | 159 | \$0 |
| GEN-2021-103 | 03 CENTRAL | Evergy's Atlantic Substation 115kV bus | 150 | \$0 |
| GEN-2021-106 | 02 NEBRASKA | Hebron North 115Kv substation | 102.06 | \$0 |
| GEN-2021-107 | 03 CENTRAL | Evergy 345kV Jeffrey Energy Center | 201.6 | \$797,607 |
| GEN-2021-108 | 02 NEBRASKA | OPPD 345KV Cass County Substation | 182.25 | \$0 |
| | | | Total Cost | \$27,548,000 |

VERSION HISTORY

| Version Number and Date | Author | Change Description |
|-------------------------|--------|--------------------|
| V0 – 06/20/2024 | AECI | Initial release |