



INTERCONNECTION FACILITY STUDY

for

Generation Interconnection Request GEN 2022-154

**100MW Battery/Storage Interconnection
in Cleveland County, OK.**

November 2025

SUMMARY

Pursuant to Attachment V of the tariff and at the request of the Southwest Power Pool (SPP), Western Farmers Electric Cooperative (WFEC) performed the following facility Study to satisfy the Facility Study agreement executed by the requesting customer for SPP Generation Interconnection request GEN-2022-154. The request for interconnection was placed with SPP in accordance with SPP's Open Access Transmission Tariff, which covers new generation interconnections on SPP's transmission system. The requirements for interconnection consist of equipping a new 138kV terminal at the WFEC Canadian Switch Station. The total interconnection cost for WFEC to accommodate the interconnection request at the 138kV POI is \$3,500,000.




Table of Contents

Introduction	4
Interconnection Facilities.....	5
Interconnection Cost.....	8
Figure 1: One-line Diagram Facilities for GEN-2022-154	5

Introduction

The Southwest Power Pool has requested a facility Study for the purpose of interconnecting 100 MW of Battery/Storage within the service territory of WFEC in Cleveland County, Oklahoma. The proposed 138kV interconnection is to a new terminal at the WFEC Canadian 138kV Switch Station (35°8'49"N, 97°24'13"W).

The total cost for expanding the switch station and adding a new terminal is \$3,500,000.

Network constraints within WFEC may be verified with a transmission service request and associated studies.

Interconnection Facilities

The primary objective of this study is to identify WFEC interconnection facilities. Figure 1 below shows the proposed interconnection of GEN-2025-154.




Figure 1: One-line Diagram Facilities for GEN-2022-154

To accommodate an interconnection for GEN 2022-154 WFEC will expand the switch station to the east reconfiguring the station from a four breaker ring bus to a 6 breaker breaker ring bus in order to equip a new terminal at the existing Canadian Switch Station. The customer will construct a new 138kV transmission line from their collector sub to the point of demarcation. WFEC will require the customer to install OPGW for communications from Customer's collector sub to WFEC's switch station.

The total cost for the interconnection facilities at POI is estimated at \$3,500,000. This cost does not include the construction of the 138kV line from the customer substation to the point of demarcation at the edge of WFEC's property. The customer is responsible for this 138kV line up to the point of interconnection.

This facility study does not guarantee the availability of transmission service necessary to deliver additional generation to any specific point inside or outside of the SPP transmission system. The transmission network facilities may not be adequate to deliver any additional generation output to the system. If the customer requests firm transmission service under the SPP open access transmission tariff at a future date, Network Upgrades or other new construction may be required to provide the service requested under the SPP OATT.

Short Circuit Fault Duty Evaluation:

It is standard practice for WFEC to recommend replacing a circuit breaker when the current through the breaker for a potential fault exceeds 100% of its interrupting rating, as determined by the ANSI/IEEE standard C37-010-2016 breaker rating methods. Existing levels of available fault current at the Canadian 138kV station is shown below. As an inverter-based resource (IBR) the maximum fault current contribution is estimated at 1.4 times peak load current of the Inverter during the subtransient period. This equates to an increase in available fault current of approximately 586A at the POI, so no existing breakers are expected to exceed capacity with the proposed interconnection.

WFEC has evaluated the potential maximum fault current in this area and no issues with short circuit duty ratings are expected on existing WFEC breakers with the proposed interconnection of 100MW of battery/storage at Canadian Switch Station.

Table 1: Canadian Switch Station 138kV Breaker Capacity

BUS	BREAKER	DUTY %	DUTY (A)	BKR CAPACITY (A)
Canadian Switch Station 138kV	138kV Breakers (x4) (172 – 472)	52%	20600 (3LG)	40000

Interconnection Cost

Table 2: Transmission Owner Interconnection Facilities

Transmission Owner Interconnection Facilities (TOIF)	Cost Estimate (\$)	Estimated Lead Time
UID: 158088		
WFEC Canadian Switch Interconnection Substation: line switches, dead end structures, line relaying, communications, revenue metering, line arrestors, and all associated equipment and facilities necessary to accept transmission line from Interconnection Customer's Generating Facility.	Engineering: \$ 42,000 ROW: \$ 15,000 Material: \$ 230,000 <u>Construction: \$ 230,000</u> TOTAL: \$ 517,000	36 Months

Table 3: Non-Shared Network Upgrades

Non-Shared Network Upgrades Description	Cost Estimate (\$)	Estimated Lead Time
UID: 158090		
WFEC Canadian Switch Interconnection Substation: Construct breakers, bus rung, switches, foundations, overhead static, ground grid, gravel, grading, line relaying and communications.	Engineering: \$ 480,000 ROW: \$ 0 Material: \$ 1,251,500 <u>Construction: \$ 1,251,500</u> TOTAL: \$ 2,983,000	36 Months