



**SPP**

*Southwest  
Power Pool*

***System Impact Study  
SPP-2022-019  
For Transmission Service  
Requested By:  
SPSM***

***From SPS.SAGAMOREWD to SPS***

***For a Reserved Amount Of  
248 MW***

***From 04/01/2022  
To 06/02/2022***

## **1. Executive Summary**

SPSM has requested a system impact study for monthly firm transmission service from SPS.SAGAMOREWD to SPS. The period of the transaction is from 04/01/2022 00:00 to 06/02/2022 00:00. The request is for reservation 96049579.

The 248 MW transaction from SPS.SAGAMOREWD has an impact on the following flowgate with no AFC: SPSNMTIES. To provide the AFC necessary for this transfer, the impact on this flowgate must be relieved.

After studying many scenarios using generation redispatch, there are several feasible scenarios that will relieve the flowgate in question.

## **2. Introduction**

SPSM has requested a system impact study for transmission service from SPS.SAGAMOREWD to SPS.

There is one constrained flowgate that requires relief in order for this reservation to be accepted. The flowgate and the explanation is as follows:

- SPSNMTIES: CROSSRDS – EDDY\_CO 345 kV.

### **3. Study Methodology**

#### **A. Description**

Southwest Power Pool used Transmission Adequacy & Reliability Assessment (TARA) to obtain possible unit pairings that would relieve the constraint. TARA calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

#### **B. Model Updates**

The 2022 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

#### **C. Transfer Analysis**

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using Transmission Adequacy & Reliability Assessment (TARA), specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by TARA is the amount of redispatch necessary to relieve the impact on the affected flowgate.

## **4. Study Results**

After studying the impacts of the request, one flowgate requires relief. The flowgate and associated amount of relief is as follows:

**Table 1**

<b>Flowgate</b>	<b>Duration</b>	<b>Sensitivity (%)</b>	<b>Required Relief (MW)</b>
5529:SPSNMTIES	5/1/2022 00:00 - 7/1/2022 00:00	17.28%	42.85

Table 2 displays a list of generator pairs that are possible relief options for each flowgate in question and the amount of redispatch capacity needed.

**Table 2**

<b>5529:SPSNMTIES</b>			
<b>Increment</b>	<b>Decrement</b>	<b>Sensitivity</b>	<b>MW</b>
Cunningham 1	Plant X4	75.14%	57.03
Cunningham 1	Harrington 2	74.82%	57.27
Cunningham 1	Nichols 3	74.82%	57.27

## **5. Conclusion**

Generation redispatch options were studied in order to relieve the necessary constraints. The results of this study shows that the constraints on the flowgate in question could be relieved by executing one or more of the options described in the Study Results section of this document. Before the Transmission Provider accepts the reservations, proof of the necessary relief options must be presented to Southwest Power Pool. Noncompliance with this guideline will result in the refusal of the reservation.