



SPP *Southwest
Power Pool*

***System Impact Study
SPP-2022-150
For Transmission Service
Requested By:
TNSK***

From CSWS.EASTMAN to ERCOTE

***For a Reserved Amount Of
50 MW***

***From 12/17/2022
To 12/31/2022***

1. Executive Summary

TNSK has requested a system impact study for weekly firm transmission service from CSWS.EASTMAN to ERCOTE. The period of the transaction is from 12/17/2022 00:00 to 12/31/2022 00:00. The request is for reservation 98507439.

The 50 MW transaction from CSWS.EASTMAN has an impact on the following flowgate(s) with no AFC: PSOSWEPCOTIE, PITVALSUNHUG. To provide the AFC necessary for this transfer, the impact on these flowgates must be relieved.

After studying many scenarios using generation redispatch, there are several feasible scenarios that will relieve the flowgate(s) in question.

2. Introduction

TNSK has requested a system impact study for transmission service from CSWS.EASTMAN to ERCOTE.

There are two constrained flowgates that require relief for this reservation to be accepted. The flowgates and the explanations are as follows:

- PSOSWEPCOTIE: PSO – SWEPCO Tie.
- PITVALSUNHUG: Pittsburg – Valiant 345kv for the loss of Sunnyside to Hugo 345kV.

3. Study Methodology

A. Description

Southwest Power Pool used Transmission Adequacy & Reliability Assessment (TARA) to obtain possible unit pairings that would relieve the constraint. TARA calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

B. Model Updates

The 2022 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

C. Transfer Analysis

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using TARA, specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by TARA is the amount of redispatch necessary to relieve the impact on the affected flowgate.

4. Study Results

After studying the impacts of the request, two flowgates require relief. The flowgates and associated amount of relief are as follows:

Table 1

Flowgate	Duration	Sensitivity (%)	Required Relief (MW)
5578:PSOSWEP COTIE	12/17/2022 00:00 - 12/31/2022 00:00	9.41%	4.71
5661:PITVALSUNHUG	12/17/2022 00:00 - 12/31/2022 00:00	5.05%	2.52

Table 2 displays a list of generator pairs that are possible relief options for each flowgate in question and the amount of redispatch capacity needed.

Table 2

5578:PSOSWEP COTIE			
Increment	Decrement	Sensitivity	MW
WILKE3-1	COM2-1	76.71%	6.14
WILKE3-1	ANADRK5	75.99%	6.20
WILKE3-1	MCLN 1S	75.14%	6.27
LIEBR3-1	COM2-1	73.36%	6.42
LIEBR3-1	ANADRK5	72.63%	6.48
ARSHILL1	COM2-1	72.09%	6.53
LIEBR3-1	MCLN 1S	71.79%	6.56
ARSHILL1	ANADRK5	71.37%	6.60
ARSHILL1	MCLN 1S	70.52%	6.68

5661:PITVALSUNHUG			
Increment	Decrement	Sensitivity	MW
WILKE3-1	COM2-1	37.88%	6.65
WILKE3-1	MCLN 1S	37.34%	6.75
WILKE3-1	ANADRK5	37.26%	6.76
LIEBR3-1	COM2-1	34.34%	7.34
ARSHILL1	COM2-1	33.96%	7.42
LIEBR3-1	MCLN 1S	33.81%	7.45
LIEBR3-1	ANADRK5	33.72%	7.47
ARSHILL1	MCLN 1S	33.42%	7.54
ARSHILL1	ANADRK5	33.34%	7.56

5. Conclusion

Generation redispatch options were studied in order to relieve the necessary constraint(s). The results of this study shows that the constraints on the flowgate(s) in question could be relieved by executing one or more of the options described in the Study Results section of this document.