



GEN-2023-GR6

GENERATOR REPLACEMENT STUDY

By Aneden Consulting and SPP Generator Interconnection

Published on 4/5/2024

REVISION HISTORY

| DATE OR VERSION NUMBER | AUTHOR | CHANGE DESCRIPTION | COMMENTS |
|------------------------|-------------------------------|--------------------|----------|
| 4/5/2024 | Aneden Consulting & SPP Staff | Original Version | |
| | | | |
| | | | |

CONTENTS

| | |
|--|----|
| REVISION HISTORY..... | 1 |
| LIST OF TABLES..... | 2 |
| LIST OF FIGURES..... | 2 |
| APPENDICES..... | 2 |
| EXECUTIVE SUMMARY..... | 3 |
| SCOPE OF STUDY..... | 5 |
| Reliability Assessment Study..... | 5 |
| Replacement Impact Study..... | 5 |
| Steady State Analysis..... | 6 |
| Stability and Short Circuit Analyses..... | 6 |
| Reactive Power Analysis..... | 6 |
| Study Limitations..... | 6 |
| PROJECT AND REPLACEMENT REQUEST..... | 7 |
| RELIABILITY ASSESSMENT STUDY..... | 11 |
| Planning Analysis..... | 11 |
| Model Development..... | 11 |
| Analysis Results..... | 11 |
| REPLACEMENT IMPACT STUDY..... | 14 |
| Existing Vs. Replacement Comparison..... | 14 |
| Stability Model Parameters Comparison..... | 14 |
| Equivalent Impedance Comparison Calculation..... | 14 |
| Reactive Power Analysis..... | 15 |
| Methodology and Criteria..... | 15 |
| Results..... | 15 |
| Short-Circuit Analysis..... | 17 |
| Methodology..... | 17 |
| Results..... | 17 |
| Dynamic Stability Analysis..... | 19 |
| Methodology and Criteria..... | 19 |

| | |
|--|----|
| Fault Definitions..... | 20 |
| Results | 26 |
| Installed Capacity Exceeds GIA Capacity..... | 29 |
| Necessary Interconnection Facilities..... | 29 |
| RESULTS..... | 30 |
| Reliability Assessment Study | 30 |
| Replacement Impact Study | 30 |
| Next Steps..... | 30 |

LIST OF TABLES

| | |
|--|----|
| Table 1: EGF and RGF Configuration Details..... | 10 |
| Table 2: Shunt Reactor Size for Reactive Power Analysis..... | 15 |
| Table 3: GEN-2023-GR6 Short-Circuit Parameters* | 17 |
| Table 4: POI Short-Circuit Results..... | 18 |
| Table 5: 25SP Short-Circuit Results | 18 |
| Table 6: Fault Definitions..... | 20 |
| Table 7: Stability Analysis Results | 26 |
| Table 8: Necessary Interconnection Facilities..... | 29 |

LIST OF FIGURES

| | |
|---|----|
| Figure 1: Existing Generation Single Line Diagram (EGF Configuration)*..... | 8 |
| Figure 2: GEN-2023-GR6 Single Line Diagram (RGF Configuration) | 9 |
| Figure 3: GEN-2023-GR6 Single Line Diagram (Shunt Sizes)..... | 16 |

APPENDICES

APPENDIX A: GEN-2023-GR6 Generator Dynamic Model

APPENDIX B: Short Circuit Results

APPENDIX C: Dynamic Stability Results with Existing Base Case Issues & Simulation Plots

EXECUTIVE SUMMARY

Pursuant to the Southwest Power Pool (SPP) Open Access Transmission Tariff (SPP tariff) Attachment V section 3.9 and SPP Business Practice 7800, Interconnection Customers can submit replacement requests for its Existing Generating Facilities. The Interconnection Customer of an Existing Generating Facility (EGF) with a Point of Interconnection (POI) at the Washita 138 kV Substation requested to be studied in the SPP Generator Replacement process.

GEN-2023-GR6, the Replacement Generating Facility (RGF), will connect to, the existing POI, the Washita 138 kV Substation in the Western Farmers Electric Cooperative (WFEC) area.

The EGF has 74.25 MW of available replacement capacity, based on the EGF Generation Interconnection Agreement (GIA). This Study has been requested to evaluate the replacement configuration of 17 x Vestas V150 4.5 MW + 1 x Vestas V150 4.2 MW wind turbines with a proportionally reduced dispatch of 75.2 MW as specified by the Interconnection Customer. This generating capacity for the RGF (80.7 MW), exceeds its requested Interconnection Service amount of 74.25 MW. As a result, the customer must install monitoring and control equipment as needed to ensure that the amount of power injected at the POI does not exceed the Interconnection Service amount.

The Generator Replacement Process consists of two parts: a Reliability Assessment Study and a Replacement Impact Study. The Reliability Assessment Study identifies any system impacts between the removal of the EGF from service and the commission date of the RGF and system adjustments to mitigate those issues. The Replacement Impact Study identifies whether the RGF is a Material Modification.

Reliability Assessment Study

In the Reliability Assessment Study initial operational and planning pre-screening, SPP determined that additional detailed analysis would be needed to fully determine the impact of removing the EGF from service. Study scoping discussions with the Interconnection Customer and Transmission Owner determined that the scope would include a planning assessment consisting of steady state and stability analyses. Ultimately, **no issues requiring mitigation** were identified.

Replacement Impact Study

Aneden Consulting (Aneden) was retained by SPP to perform the Replacement Impact Study (Impact Study) for GEN-2023-GR6.

SPP determined that steady state analysis was not required because the requested capacity of the RGF does not exceed the previously studied EGF output of 74.25 MW. In addition, the EGF was previously studied at maximum Interconnection Service under all necessary reliability conditions. However, SPP determined that short circuit and dynamic stability analyses were required as the

dynamic model for the EGF and RGF are different (WT1G1 and REGCA1, respectively). The scope of this Impact Study included reactive power analysis, short circuit analysis, and dynamic stability analysis.

The results of the Impact Study showed that the requested replacement did not have a material adverse impact on the SPP transmission system. The requested generator replacement of the EGF with GEN-2023-GR6 was determined **not a Material Modification**.

As the requested replacement generating capacity is higher than its Interconnection Service, the customer must install monitoring and control equipment as needed to ensure that the amount of power injected at the POI does not exceed the requested Interconnection Service amount. The monitoring and control scheme may be reviewed by the Transmission Owner (TO) and documented in Appendix C of the RGF GIA.

In accordance with FERC Order No. 827, the generating facility will be required to provide dynamic reactive power within the range of 0.95 leading to 0.95 lagging at the high-side of the generator substation.

It is likely that the customer may be required to reduce its generation output in real-time, also known as curtailment, under certain system conditions to allow system operators to maintain the reliability of the transmission network.

Nothing in this study should be construed as a guarantee of transmission service or delivery rights. Transfer of an existing resource designation from the EGF to the RGF can be achieved by submitting a transfer of designation request pursuant to Section 30.2.1 of the SPP tariff. If the customer would like to obtain new deliverability to final customers, a separate request for transmission service must be requested on Southwest Power Pool's OASIS by the customer.

SCOPE OF STUDY

Pursuant to SPP tariff Attachment V section 3.9 and SPP Business Practice 7800, Interconnection Customers can submit replacement requests for its Existing Generating Facilities. A Generator Replacement Impact Study is an interconnection study performed to evaluate the impacts of replacing existing generation with new generation. Two analyses covering different time frames are evaluated:

- Reliability Assessment Study – study performed to evaluate the performance of the Transmission System for the time period between the date that the Existing Generating Facility (EGF) ceases commercial operations and the Commercial Operation Date (COD) of the Replacement Generating Facility (RGF).
- Replacement Impact Study – study performed to evaluate if the RGF has a material adverse impact on the SPP Transmission System.

For any impacts to the system identified in the Reliability Assessment Study, non-transmission solutions such as redispatch, remedial action schemes, or reactive setting adjustments will be identified to mitigate issues originating after the removal of the EGF from service and before the commission of the RGF.

If the Replacement Impact Study identifies any materially adverse impact from operating the RGF when compared to the EGF, such impacts shall be deemed a Material Modification.

RELIABILITY ASSESSMENT STUDY

The Reliability Assessment Study evaluates regional transmission impacts from removing the EGF from service.

Based on the initial operational and planning pre-screening, SPP determined that additional detailed analysis would be needed to fully determine the impacts of removing the EGF from service. After a study scoping discussion with the Interconnection Customer, SPP determined that the scope of the Reliability Assessment Study would only include a Planning Analysis. The Planning Analysis consisted of steady state and stability analyses to determine whether system constraints exist with the removal of the EGF.

REPLACEMENT IMPACT STUDY

Aneden Consulting (Aneden) was retained by SPP to perform the Replacement Impact Study (Impact Study) for GEN-2023-GR6. All analyses were performed using Siemens PTI PSS/E version 34 software.

STEADY STATE ANALYSIS

To determine whether steady state analysis is required, SPP evaluates if all required reliability conditions were previously studied. This is done by comparing the current DISIS steady state requirements versus the steady state analysis previously performed on the EGF. SPP determined that since the EGF was previously studied at maximum Interconnection Service under all necessary reliability conditions, no steady state analysis for the RGF is required.

STABILITY AND SHORT CIRCUIT ANALYSES

To determine whether stability and short circuit analyses are required, SPP evaluates the difference between the stability models and corresponding parameters and, if needed, the collector system impedance between the existing configuration and the requested replacement. Dynamic stability analysis and short circuit analysis would be required if the differences listed above may result in a significant impact on the most recently performed DISIS stability analysis.

REACTIVE POWER ANALYSIS

A reactive power analysis was performed on the requested replacement configuration as it is a non-synchronous resource. The reactive power analysis determines the capacitive effect at the POI caused by the project's collector system and transmission line's capacitance. A shunt reactor size is determined in order to offset the capacitive effect and maintain zero (0) MVAR flow at the POI while the project's generators and capacitors (if any) are offline.

STUDY LIMITATIONS


The assessments and conclusions provided in this report are based on assumptions and information provided to SPP/Aheden by others. While the assumptions and information provided may be appropriate for the purposes of this report, SPP/Aheden does not guarantee that those conditions assumed will occur. In addition, SPP/Aheden did not independently verify the accuracy or completeness of the information provided. As such, the conclusions and results presented in this report may vary depending on the extent to which actual future conditions differ from the assumptions made or information used herein.

PROJECT AND REPLACEMENT REQUEST

The GEN-2023-GR6 Interconnection Customer has requested a replacement to its EGF, a wind generating facility with a POI at the Washita 138 kV Substation and a requested retirement date of July 18, 2024. The Interconnection Service available for replacement is 74.25 MW, based on the EGF Generation Interconnection Agreement (GIA). Of the Interconnection Service available, the RGF Interconnection Customer has requested 74.25 MW of Energy Resource Interconnection Service (ERIS). The requested RGF is a wind farm consisting of 17 x Vestas V150 4.5 MW + 1 x Vestas V150 4.2 MW wind turbines with a proportionally reduced dispatch of 75.2 MW as specified by the Interconnection Customer. This generating capacity for the RGF (80.7 MW), exceeds its requested Interconnection Service amount of 74.25 MW. As a result, the customer must install monitoring and control equipment as needed to ensure that the amount of power injected at the POI does not exceed the Interconnection Service amount. The RGF has a planned commercial operation date of December 31, 2024.

The POI of the EGF and RGF is at the Washita 138 kV Substation in the Western Farmers Electric Cooperative (WFEC) area, and the EGF and RGF are not expected to be operational simultaneously. Figure 1 and Figure 2 show the steady state model single-line diagram for the EGF and RGF configurations, respectively. Table 1 details the existing and replacement configurations for GEN-2023-GR6.

Figure 1: Existing Generation Single Line Diagram (EGF Configuration)*



*based on the DISIS-2017-002-1 25SP stability models

Figure 2: GEN-2023-GR6 Single Line Diagram (RGF Configuration)




Table 1: EGF and RGF Configuration Details

| Facility | Existing Generator Facility Configuration | Replacement Generator Facility Configuration | |
|---|---|---|--|
| Point of Interconnection | Washita 138kV Substation (521089) | Washita 138kV Substation (521089) | |
| Configuration/Capacity | 45 x Vestas (Neg Micon) NM72 1.65 MW (wind) = 74.25 MW | 17 x Vestas V150 4.5 MW (wind) + 1 x Vestas V150 4.2 MW (wind) = 80.7 MW [75.2 MW dispatch] PPC to limit GEN-2023-GR6 to 74.25 MW at the POI | |
| Generation Interconnection Line | Length = 4.6 miles R = 0.001650 pu X = 0.017499 pu B = 0.005230 pu Rating A/B MVA = 299/353 MVA | Length = 4.6 miles R = 0.001650 pu X = 0.017499 pu B = 0.005230 pu Rating A/B MVA = 299/353 MVA | |
| Main Substation Transformer ¹ | X12 = 8.405% R12 = 0.301%, X23 = 16.493% R23 = 0%, X13 = 39.3% R13 = 0%, Voltage = 4.98/34.5/138 kV (Wye Grounded/Wye Grounded), Taps Available = 5 Taps, ±5% Winding 1-2 MVA = 45 MVA, Winding 2-3/3-1 MVA = 100 MVA, Winding 1, & 2 Rating MVA = 75 MVA Winding 3 Rating MVA = 7.5 MVA | X = 9.527%, R = 0.23%, Voltage = 34.5/138 kV (Wye Grounded/Wye Grounded), Taps Available = 33 Taps, ±10% Winding MVA = 72 MVA, Rating MVA = 120 MVA | |
| Generator Step Up Transformer | <u>Gen 1 Equivalent Qty: 45</u> X ² = 7.744%, R ² = 0%, Voltage = 0.6/34.5 kV, Taps Available = 5 Taps, ±5% Winding MVA = 100 MVA, Rating MVA = 74.3 MVA | <u>Gen 1 Equivalent Qty: 17</u> X ¹ = 9.869%, R ¹ = 0.789%, Voltage = 0.72/34.5 kV, Taps Available = 5 Taps, ±5% Winding MVA = 90.1 MVA, Rating MVA = 90.1 MVA | <u>Gen 2 Equivalent Qty: 1</u> X ¹ = 9.869%, R ¹ = 0.789%, Voltage = 0.72/34.5 kV, Taps Available = 5 Taps, ±5% Winding MVA = 5.1 MVA, Rating MVA = 5.1 MVA |
| Equivalent Collector Line ³ | R = 0.012108 pu X = 0.011446 pu B = 0.018620 pu | R = 0.007113 pu X = 0.008322 pu B = 0.020526 pu | |
| Generator Dynamic Model ⁴ & Power Factor | 45 x Vestas (Neg Micon) NM72 1.65 MW (WT1G1) ⁴ Leading: 1.0 Lagging: 1.0 | 17 x Vestas V150 4.5 MW (REGCA1) ⁴ Leading: 0.942 Lagging: 0.87 | 1 x Vestas V150 4.2 MW (REGCA1) ⁴ Leading: 0.949 Lagging: 0.903 |
| 1) X and R based on Winding MVA, 2) X and R based on System MVA, 3) All pu are on 100 MVA Base, 4) DYR stability model name | | | |

RELIABILITY ASSESSMENT STUDY

PLANNING ANALYSIS

Based on the initial operational and planning pre-screening, and a study scoping discussion with the Interconnection Customer, SPP determined that the scope of the Reliability Assessment Study would only include a Planning Analysis. The Planning Analysis consisted of steady state and stability analyses to determine whether system constraints exist with the removal of the EGF. The planning analysis was performed using the 2023 ITP Base Reliability models.

MODEL DEVELOPMENT

BASE CASE

The following 2023 TPL models were used as base cases for the steady state analysis:

1. 2024 Light Load
2. 2024 Summer Peak

The following 2023 TPL models were used as base cases for the stability analysis:

1. 2024 Light Load
2. 2024 Summer Peak

The 2024 Light Load and 2024 Summer Peak models were selected based on the period of time between the EGF's requested retirement date of July 18, 2024 and the RGF's planned commercial operation date of December 31, 2024. The base cases have the EGF dispatched according to the TPL models, while SPP created change cases where the EGF was removed from the base cases to demonstrate the retirement of the EGF. SPP then compared the performance of both sets of cases to determine the impact of removing the EGF from service to the SPP transmission system.

ANALYSIS RESULTS

STEADY STATE ANALYSIS

Aneden was retained by SPP to perform the Planning Steady State Analysis portion of the Reliability Assessment Study (Assessment Study) for GEN-2023-GR6.

Aneden compared the base cases to the change cases by using PowerGEM TARA software to perform the steady state analysis and determine the impacts of removing the EGF from service.

The following assumptions were made for the steady state analysis:

- Monitored Elements
 - SPP facilities 69 kV and above
 - First-tier companies 100 kV and above
- Contingencies
 - P1, P2, P3, P4, P5, P6 and P7 events¹ within 5 buses of the EGF's POI for all models
- Impact Criteria
 - The system performance in the base and study cases were evaluated based on the SPP Planning Criteria² (Section 5.4.2).
 - Any new voltage violations or thermal violations were identified as new impacts

The results of the steady state analysis showed that there were no thermal or voltage violations identified in the change cases due to the EGF retirement. As no impacts were observed in the study area, removing the EGF from service was determined to meet SPP Planning Criteria.

STABILITY ANALYSIS

SPP Staff performed the stability analysis portion of the Reliability Assessment Study (Assessment Study) for GEN-2023-GR6. SPP Staff utilized the transient stability contingencies that were developed during the 2023 Planning Assessment for the Western Farmers Electric Cooperative (WFEC) and Oklahoma Gas and Electric (OG&E) Transmission Planning areas.

A transient stability analysis using PTI's PSS/E was performed for these member-submitted events for the base and change 2024 Light Load and 2024 Summer Peak cases. The contingencies included P1-P7 Planning and Extreme Events for a total of 285 events.

The simulations were performed for 20 seconds, and the following parameters were monitored according to the SPP Disturbance Performance Requirements³:

- Rotor angle stability within the SPP Planning Coordinator (PC) Area
- Oscillation damping within the SPP PC Area
- Transient voltage stability within 10 buses of the fault bus

SPP Staff compared the post processed results from the base and change cases to determine the impact on the SPP Bulk Electric System (BES).

¹ NERC TPL-001 Standard Table 1

² SPP Planning Criteria Revision 4.3, November 6, 2023

³ [SPP Disturbance Performance Requirements:](https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20(twg%20approved).pdf)

[https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20\(twg%20approved\).pdf](https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20(twg%20approved).pdf)

The results of the transient stability analysis showed that there were no rotor angle stability, oscillation damping, and transient voltage stability violations identified in the change cases due to the EGF retirement. As no impacts were observed in the study area, removing the EGF from service was determined to meet SPP Disturbance Performance Requirements and Planning Criteria.

REPLACEMENT IMPACT STUDY

Aneden was retained by SPP to perform the Replacement Impact Study (Impact Study) for GEN-2023-GR6.

EXISTING VS. REPLACEMENT COMPARISON

To determine which analyses are required for the Impact Study, the differences between the existing configuration and the requested replacement were evaluated. SPP performed this comparison and the resulting analyses using a set of modified study models developed based on the replacement request data and the DISIS-2017-002-1 study models.

STABILITY MODEL PARAMETERS COMPARISON

Because the dynamic model for the EGF and RGF are different (WT1G1 and REGCA1, respectively), SPP determined short-circuit and dynamic stability analyses were required. This is because the short-circuit contribution and stability responses of the existing configuration and the requested replacement's configuration may differ. The generator dynamic model for the RGF can be found in Appendix A.

As short-circuit and dynamic stability analyses were required, a stability model parameters comparison was not needed for the determination of the scope of the study.

EQUIVALENT IMPEDANCE COMPARISON CALCULATION

As the turbine stability model change determined that short circuit and dynamic stability analyses were required, an equivalent impedance comparison was not needed for the determination of the scope of the study.

REACTIVE POWER ANALYSIS

Aneden performed a reactive power analysis for GEN-2023-GR6 to determine the capacitive charging effects under reduced generation conditions (unsuitable wind speeds, unsuitable solar irradiance, insufficient state of charge, idle conditions, curtailment, etc.) at the generation site and to size shunt reactors that would reduce the project reactive power contribution to the POI to approximately zero.

METHODOLOGY AND CRITERIA

For this analysis the nearby projects that share the gen-tie line were disconnected. The GEN-2023-GR6 generators were switched out of service while other system elements remained in-service. A shunt reactor was tested at the project’s collection substation 34.5 kV bus to set the MVAR flow into the POI to approximately zero. The size of the shunt reactor is equivalent to the charging current value at unity voltage and the compensation provided is proportional to the voltage effects on the charging current (i.e., for voltages above unity, reactive compensation is greater than the size of the reactor).

Aneden performed the reactive power analysis using the replacement request data based on the DISIS-2017-002-1 stability study 2025 Summer Peak (25SP) model.

RESULTS


The results from the analysis showed that the GEN-2023-GR6 project needed approximately 4.79 MVAR of compensation at its collector substation, to reduce the POI MVAR to zero. Figure 3 illustrates the shunt reactor size needed to reduce the POI MVAR to approximately zero with the updated configuration. The final shunt reactor requirements for GEN-2023-GR6 are shown in Table 2.

The information gathered from the reactive power analysis is provided as information to the Interconnection Customer and Transmission Owner (TO) and/or Transmission Operator (TOP). The applicable reactive power requirements will be further reviewed by the TO and/or TOP.

Table 2: Shunt Reactor Size for Reactive Power Analysis

| Machine | POI Bus Number | POI Bus Name | Reactor Size (MVAR) |
|--------------|----------------|--------------|---------------------|
| | | | 25SP |
| GEN-2023-GR6 | 521089 | WASHITA4 | 4.79 |

Figure 3: GEN-2023-GR6 Single Line Diagram (Shunt Sizes)



SHORT-CIRCUIT ANALYSIS

Aneden performed a short circuit study using the 25SP model to determine the maximum fault current requiring interruption by protective equipment with the RGF online for each bus in the relevant subsystem, and the amount of increase in maximum fault current due to the addition of the RGF. The detailed results of the short circuit analysis are provided in Appendix B.

METHODOLOGY

The short-circuit analysis included applying a three-phase fault on buses up to five levels away from the 138 kV POI bus. The PSS/E “Automatic Sequence Fault Calculation (ASCC)” fault analysis module was used to calculate the fault current levels in the transmission system with and without the GEN-2023-GR6 RGF online.

SPP created a short circuit model using the 25SP stability study model by adjusting the GEN-2023-GR6 short-circuit parameters consistent with the replacement data. The adjusted parameters are shown in Table 3 below.

Table 3: GEN-2023-GR6 Short-Circuit Parameters*

| Parameter | Value by Generator Bus# | Value by Generator Bus# |
|------------------|-------------------------|-------------------------|
| | | 923563 |
| Machine MVA Base | 90.1 | 5.1 |
| R (pu) | 0 | 0 |
| X" (pu) | 0.93458 | 0.93458 |

*pu values based on Machine MVA Base

RESULTS

The results of the short circuit analysis for the 25SP model are summarized in Table 4 and Table 5. The GEN-2023-GR6 POI bus (Washita 138 kV) fault current magnitude is provided in Table 4 showing a fault current of 30.14 kA with the RGF online. The addition of the RGF increased the POI bus fault current by 0.18 kA. Table 5 shows the maximum fault current magnitudes and fault current increases with the RGF project online.

The maximum fault current calculated within 5 buses of the POI was 46.3 kA for the 25SP model. There were several buses with a maximum three-phase fault current over 40 kA. These buses are highlighted in Appendix B. The maximum contribution to three-phase fault currents due to the addition of the RGF was about 0.6% and 0.18 kA.

Table 4: POI Short-Circuit Results

| Case | GEN-OFF Current (kA) | GEN-ON Current (kA) | kA Change | %Change |
|------|----------------------|---------------------|-----------|---------|
| 25SP | 29.96 | 30.14 | 0.18 | 0.6% |

Table 5: 25SP Short-Circuit Results

| Voltage (kV) | Max. Current (kA) | Max kA Change | Max %Change |
|--------------|-------------------|---------------|-------------|
| 69 | 16.6 | 0.01 | 0.1% |
| 138 | 46.3 | 0.18 | 0.6% |
| 230 | 11.5 | 0.00 | 0.0% |
| 345 | 36.5 | 0.01 | 0.1% |
| Max | 46.3 | 0.18 | 0.6% |

DYNAMIC STABILITY ANALYSIS

Aneden performed a dynamic stability analysis to identify the impact of the GEN-2023-GR6 project. The analysis was performed according to SPP's Disturbance Performance Requirements⁴. The replacement details are described in the Project and Replacement Request section and the dynamic modeling data is provided in Appendix A. The existing base case issues and simulation plots can be found in Appendix C.

METHODOLOGY AND CRITERIA

The dynamic stability analysis was performed using models developed with the requested RGF configuration of 17 x Vestas V150 4.5 MW + 1 x Vestas V150 4.2 MW (REGCA1). This stability analysis was performed using PTI's PSS/E version 34.8.0 software.

The RGF project details were used to create modified stability models for this impact study based on the DISIS-2017-002-1 stability study models:

- 2025 Summer Peak (25SP)
- 2025 Winter Peak (25WP)

The dynamic model data for the GEN-2023-GR6 project is provided in Appendix A. The modified power flow models and associated dynamics database were initialized (no-fault test) to confirm that there were no errors in the initial conditions of the system and the dynamic data.

The following system adjustments were made to address existing base case issues that are not attributed to the replacement request:

- The frequency protective relays at buses 920002, 599003, 920001, 920003, 920004, 520522, 511971, 511970, 520521, 515907, 515445, 515439, 599117, 599119, 599120, 515551, 587773, and 587793 were disabled after observing the generators tripping during initial three phase fault simulations. This frequency tripping issue is a known PSS/E limitation when calculating bus frequency as it relates to non-conventional type devices.
- The voltage protective relays at buses 920001, 920002, 920003, 920004, 599003, 760979, 760958, 760937, 761232, 520522, 520519, 521153, 923563, 923565, 587793, 587773, 599117, 515551, 599119, 599120, 515969, 515968, 515967, 515986, 515985, and 515984 were disabled to avoid generator tripping due to an instantaneous over voltage spike after fault clearing.

⁴ [SPP Disturbance Performance Requirements:](https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20(twg%20approved).pdf)

[https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20\(twg%20approved\).pdf](https://www.spp.org/documents/28859/spp%20disturbance%20performance%20requirements%20(twg%20approved).pdf)

- A few WTDTA1 models were disabled at buses 511969 and 515395, and the acceleration factor of REGCAU1 models was adjusted to 0.01 at buses 511969, 515395, 920001, 920002, 920003, 920004, 520522, and 599003 to resolve stability simulation crashes.
- The fault simulation file acceleration factor was reduced, and the iteration limit was increased as needed to resolve stability simulation crashes.
- The Blue Canyon II generators located at the same POI do not settle at the end of the 20 second simulation (seen in the cases with and without the RGF). To mitigate this issue, the WTDTA1 drive train model was disabled at corresponding buses of 920001, 920002, 920003, 920004, 599003, and 520522.

During the fault simulations, the active power (PELEC), reactive power (QELEC), and terminal voltage (ETERM) were monitored for the EGF and SGF and other current and prior queued projects in Group 4⁵. In addition, voltages of five (5) buses away from the POI of the RGF were monitored and plotted. The machine rotor angle for synchronous machines and speed for asynchronous machines within the study areas including 330 (AECI), 515 (SWPA), 520 (AEPW), 523 (GRDA), 524 (OKGE), 525 (WFEC), 527 (OMPA), and 534 (SUNC) were monitored. The voltages of all 100 kV and above buses within the study area were monitored as well.

FAULT DEFINITIONS

Aneden developed fault events as required in order to study the RGF. The new set of faults were simulated using the modified study models. The fault events included three-phase faults and single-line-to-ground stuck breaker faults. Single-line-to-ground faults are approximated by applying a fault impedance to bring the faulted bus positive sequence voltage to 0.6 pu. The simulated faults are listed and described in Table 6. These contingencies were applied to the modified 25SP and 25WP models.

Table 6: Fault Definitions

| Fault ID | Planning Event | Fault Descriptions |
|-------------|----------------|--|
| FLT9001-3PH | P1 | 3 phase fault on the WASHITA4 (521089) to GRACMNT4 (515802) 138kV line CKT 1, near WASHITA4. a. Apply fault at the WASHITA4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9002-3PH | P1 | 3 phase fault on the WASHITA 138 kV (521089) /69 kV (521088) /13.8kV (521179) transformer CKT 1, near WASHITA 138kV. a. Apply fault at the WASHITA4 138 kV (521089) bus. b. Clear fault after 7 cycles by tripping the faulted line. |
| FLT9003-3PH | P1 | 3 phase fault on the WASHITA4 (521089) to S.W.S. -4 (511477) 138kV line CKT 1, near WASHITA4. a. Apply fault at the WASHITA4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |

⁵ Based on the DISIS-2017-002 Cluster Groups

Table 6 Continued

| Fault ID | Planning Event | Fault Descriptions |
|-------------|----------------|---|
| FLT9004-3PH | P1 | 3 phase fault on the WASHITA4 (521089) to ONEY 4 (521017) 138kV line CKT 1, near WASHITA4. a. Apply fault at the WASHITA4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9005-3PH | P1 | 3 phase fault on the ONEY 4 (521017) to BINGERJ4 (520827) 138kV line CKT 1, near ONEY 4. a. Apply fault at the ONEY 4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9006-3PH | P1 | 3 phase fault on the BINGERJ4 (520827) to NIJECT 4 (521010) 138kV line CKT 1, near BINGERJ4. a. Apply fault at the BINGERJ4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9007-3PH | P1 | 3 phase fault on the BINGERJ4 (520827) to SICKLES4 (521050) 138kV line CKT 1, near BINGERJ4. a. Apply fault at the BINGERJ4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9008-3PH | P1 | 3 phase fault on the GRACMNT3 (515802) to ANADARK4 (520814) 138kV line CKT 1, near GRACMNT3. a. Apply fault at the GRACMNT3 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9009-3PH | P1 | 3 phase fault on the GRACMNT3 138 kV (515802) /345 kV (515800) /13.8kV (515801) transformer CKT 1, near GRACMNT4 138kV. a. Apply fault at the GRACMNT4 138kV bus. b. Clear fault after 7 cycles by tripping the faulted line. |
| FLT9010-3PH | P1 | 3 phase fault on the ANADARK4 (520814) to POCASET4 (521031) 138kV line CKT 1, near ANADARK4. a. Apply fault at the ANADARK4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9011-3PH | P1 | 3 phase fault on the ANADARK4 (520814) to CLVLDSW4 (520508) 138kV line CKT 1, near ANADARK4. a. Apply fault at the ANADARK4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9012-3PH | P1 | 3 phase fault on the ANADARK4 (520814) to SEQUOYAHJ4 (520422) 138kV line CKT 1, near ANADARK4. a. Apply fault at the ANADARK4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9013-3PH | P1 | 3 phase fault on the ANADARK4 (520814) to CHERRYRD 4 (521129) 138kV line CKT 1, near ANADARK4. a. Apply fault at the ANADARK4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9014-3PH | P1 | 3 phase fault on the ANADARK4 (520814) to GEORGIA4 (520923) 138kV line CKT 1, near ANADARK4. a. Apply fault at the ANADARK4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9015-3PH | P1 | 3 phase fault on the ANADARK 138 kV (520814) /69 kV (520810) /13.8kV (521181) transformer CKT 1, near ANADARK4 138kV. a. Apply fault at the ANADARK4 138 kV (520814) bus. b. Clear fault after 7 cycles by tripping the faulted line. |
| FLT9016-3PH | P1 | 3 phase fault on the ANADARK 138 kV (520814) /13.8kV (520812) transformer CKT 1, near ANADARK4 138kV. a. Apply fault at the ANADARK4 138 kV (520814) bus. b. Clear fault after 7 cycles by tripping the faulted line. Trip generator on bus ANADARK5 (520812) |

Table 6 Continued

| Fault ID | Planning Event | Fault Descriptions |
|-------------|----------------|---|
| FLT9017-3PH | P1 | 3 phase fault on the ANADARK 138 kV (520814) /13.8kV (521110) transformer CKT 1, near ANADARK4 138kV. a. Apply fault at the ANADARK4 138 kV (520814) bus. b. Clear fault after 7 cycles by tripping the faulted line. Trip generator on bus ORME1 (521110) |
| FLT9018-3PH | P1 | 3 phase fault on the ANADARK 138 kV (520814) /13.8kV (521101) transformer CKT 1, near ANADARK4 138kV. a. Apply fault at the ANADARK4 138 kV (520814) bus. b. Clear fault after 7 cycles by tripping the faulted line. Trip generator on bus GENCO1 (521101) |
| FLT9019-3PH | P1 | 3 phase fault on the S.W.S.-4 138 kV (511477) /24 kV (511848) transformer CKT 1, near S.W.S.-4 138kV. a. Apply fault at the S.W.S.-4 138 kV (520814) bus. b. Clear fault after 7 cycles by tripping the faulted line. Trip generator on bus SWS3-1 (511848) |
| FLT9020-3PH | P1 | 3 phase fault on the S.W.S.-4 138 kV (511477) /13.8 kV (511849) /13.8kV (511850) transformer CKT 1, near S.W.S.-4 138 kV (511477). a. Apply fault at the S.W.S.-4 138 kV (511477) bus. b. Clear fault after 7 cycles by tripping the faulted line. Trip generator on bus SWS NG4 (511849) and SWS NG5 (511850) |
| FLT9021-3PH | P1 | 3 phase fault on the S.W.S.-4 138 kV (511477) /69 kV (511476) /13.8kV (511413) transformer CKT 1, near S.W.S.-4 138 kV (511477). a. Apply fault at the S.W.S.-4 138 kV (511477) bus. b. Clear fault after 7 cycles by tripping the faulted line. |
| FLT9022-3PH | P1 | 3 phase fault on the S.W.S-4 (511477) to NORGE-4 (511483) 138kV line CKT 1, near S.W.S-4. a. Apply fault at the S.W.S-4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9023-3PH | P1 | 3 phase fault on the S.W.S-4 (511477) to CARNEG-4 4 (511445) 138kV line CKT 1, near S.W.S-4. a. Apply fault at the S.W.S-4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9024-3PH | P1 | 3 phase fault on the S.W.S-4 (511477) to ELSWORTH 4 (511563) 138kV line CKT 1, near S.W.S-4. a. Apply fault at the S.W.S-4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9025-3PH | P1 | 3 phase fault on the S.W.S-4 (511477) to VERDEN 4 (511421) 138kV line CKT 1, near S.W.S-4. a. Apply fault at the S.W.S-4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9026-3PH | P1 | 3 phase fault on the S.W.S-4 (511477) to G16-097-TAP (587794) 138kV line CKT 1, near S.W.S-4. a. Apply fault at the S.W.S-4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT9027-3PH | P1 | 3 phase fault on the GRACMNT7 (515800) to MINCO (514801) 345kV line CKT 1, near GRACMNT7. a. Apply fault at the GRACMNT7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9028-3PH | P1 | 3 phase fault on the GRACMNT7 (515800) to GEN-2015-093 (563269) 345kV line CKT 1, near GRACMNT7. a. Apply fault at the GRACMNT7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. Trip generator G15-093-GEN1 (563272). Trip generator G15-093-GEN2 (563273). c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |

Table 6 Continued

| Fault ID | Planning Event | Fault Descriptions |
|-------------|----------------|---|
| FLT9029-3PH | P1 | 3 phase fault on the GRACMNT7 (515800) to G16-037-TAP (560078) 345kV line CKT 1, near GRACMNT7. a. Apply fault at the GRACMNT7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9030-3PH | P1 | 3 phase fault on the GRACMNT7 (515800) to G16-091-TAP (587744) 345kV line CKT 1, near GRACMNT7. a. Apply fault at the GRACMNT7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9031-3PH | P1 | 3 phase fault on the MINCO 7 (514801) to GEN-2017-233 (761250) 345kV line CKT 1, near MINCO 7. a. Apply fault at the MINCO 7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. Trip generator G17-150GEN1 (761232). Trip generator G17-233-GEN1 (761253). c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9032-3PH | P1 | 3 phase fault on the MINCO 7 (514801) to MCNOWND7 (515444) 345kV line CKT 1, near MINCO 7. a. Apply fault at the MINCO 7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9033-3PH | P1 | 3 phase fault on the MINCO 7 (514801) to MNCWND37 (515549) 345kV line CKT 1, near MINCO 7. a. Apply fault at the MINCO 7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9034-3PH | P1 | 3 phase fault on the MINCO 7 (514801) to NSUB345 (555234) 345kV line CKT 1, near MINCO 7. a. Apply fault at the MINCO 7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9035-3PH | P1 | 3 phase fault on the MINCO 7 (514801) to CIMARON7 (514901) 345kV line CKT 1, near MINCO 7. a. Apply fault at the MINCO 7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9036-3PH | P1 | 3 phase fault on the G16-037-TAP (560078) to CHISHOLM7 (511553) 345kV line CKT 1, near G16-037-TAP. a. Apply fault at the G16-037-TAP 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9037-3PH | P1 | 3 phase fault on the G16-037-TAP (560078) to GEN-2016-037 (587230) 345kV line CKT 1, near G16-037-TAP. a. Apply fault at the G16-037-TAP 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. Trip generator on bus G16-037-GEN1 (587233). c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9038-3PH | P1 | 3 phase fault on the G16-091-TAP (587744) to L.E.S.-7 (511468) 345kV line CKT 1, near GRACMNT7. a. Apply fault at the GRACMNT7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9039-3PH | P1 | 3 phase fault on the G16-091-TAP (587744) to GEN-2016-095 (587770) 345kV line CKT 1, near G16-091-TAP. a. Apply fault at the G16-091-TAP 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. Trip generator on bus G16-095-GEN1 (587773) c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |

Table 6 Continued

| Fault ID | Planning Event | Fault Descriptions |
|-------------|----------------|--|
| FLT9040-3PH | P1 | 3 phase fault on the G16-091-TAP (587744) to GEN-2016-091 (587740) 345kV line CKT 1, near G16-091-TAP. a. Apply fault at the G16-091-TAP 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. Trip generator on bus G16-091-GEN1 (587743), G16-091-GEN2 (587749), G16-091-GEN3 (587747), G16-091-GEN4 (587748) c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9041-3PH | P1 | 3 phase fault on the CHISHOLM7 345 kV (511553) /230 kV (511557) /13.2kV (511558) transformer CKT 1, near CHISHOLM7 (511553) 345 kV. a. Apply fault at the CHISHOLM7 (511553) 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. |
| FLT9042-3PH | P1 | 3 phase fault on the CHISHOLM7 (511553) to WWDBORDT (755000) 345kV line CKT 1, near CHISHOLM7. a. Apply fault at the CHISHOLM7 345 kV bus. b. Clear fault after 6 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 6 cycles, then trip the line in (b) and remove fault. |
| FLT9043-3PH | P1 | 3 phase fault on the S.W.S-4 (511477) to ANADARK4 (520814) 138kV line CKT 1, near S.W.S-4. a. Apply fault at the S.W.S-4 138 kV bus. b. Clear fault after 7 cycles by tripping the faulted line. c. Wait 20 cycles, and then re-close the line in (b) back into the fault. d. Leave fault on for 7 cycles, then trip the line in (b) and remove fault. |
| FLT1001-SB | P4 | Stuck Breaker on at GRACMNT4 (515802) at 138kV a. Apply single-phase fault at GRACMNT4 (515802) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the GRACMNT4 (515802) to WASHITA4 (521089) 138kV line CKT 1. d. Trip the GRACMNT3 138 kV (515802) /345 kV (515800) /13.8kV (515801) transformer CKT 1. |
| FLT1002-SB | P4 | Stuck Breaker on at GRACMNT4 (515802) at 138kV a. Apply single-phase fault at GRACMNT4 (515802) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the GRACMNT3 (515802) to ANADARK4 (520814) 138kV line CKT 1. Trip the GRACMNT3 (515802) to ANADARK4 (520814) 138kV line CKT 2. d. Trip the GRACMNT3 138 kV (515802) /345 kV (515800) /13.8kV (515801) transformer CKT 1. |
| FLT1003-SB | P4 | Stuck Breaker on at GRACMNT4 (515802) at 138kV a. Apply single-phase fault at GRACMNT4 (515802) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the GRACMNT3 (515802) to ANADARK4 (520814) 138kV line CKT 1. Trip the GRACMNT3 (515802) to ANADARK4 (520814) 138kV line CKT 2. d. Trip the GRACMNT4 (515802) to WASHITA4 (521089) 138kV line CKT 2. |
| FLT1004-SB | P4 | Stuck Breaker on at GRACMNT4 (515802) at 138kV a. Apply single-phase fault at GRACMNT4 (515802) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the GRACMNT4 (515802) to WASHITA4 (521089) 138kV line CKT 1. d. Trip the GRACMNT4 (515802) to WASHITA4 (521089) 138kV line CKT 2. |
| FLT1005-SB | P4 | Stuck Breaker on at GRACMNT7 (515800) at 345kV a. Apply single-phase fault at GRACMNT7 (515800) on the 345kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the GRACMNT7 (515800) to MINCO (514801) 345kV line CKT 1. d. Trip the GRACMNT7 (515800) to G16-091-TAP (587744) 345kV line CKT 1. |
| FLT1006-SB | P4 | Stuck Breaker on at GRACMNT7 (515800) at 345kV a. Apply single-phase fault at GRACMNT7 (515800) on the 345kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the GRACMNT3 138 kV (515802) /345 kV (515800) /13.8kV (515801) transformer CKT 1. d. Trip the GRACMNT7 (515800) to G16-091-TAP (587744) 345kV line CKT 1. |

Table 6 Continued

| Fault ID | Planning Event | Fault Descriptions |
|------------|----------------|---|
| FLT1007-SB | P4 | <p>Stuck Breaker on at GRACMNT7 (515800) at 345kV</p> <p>a. Apply single-phase fault at GRACMNT7 (515800) on the 345kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the GRACMNT7 (515800) to G16-037-TAP (560078) 345kV line CKT 1. d. Trip the GRACMNT3 138 kV (515802) /345 kV (515800) /13.8kV (515801) transformer CKT 1.</p> |
| FLT1008-SB | P4 | <p>Stuck Breaker on at GRACMNT7 (515800) at 345kV</p> <p>a. Apply single-phase fault at GRACMNT7 (515800) on the 345kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the GRACMNT7 (515800) to MINCO (514801) 345kV line CKT 1. d. Trip the GRACMNT7 (515800) to G16-037-TAP (560078) 345kV line CKT 1.</p> |
| FLT1009-SB | P4 | <p>Stuck Breaker at ONEY (521017) at 138kV</p> <p>a. Apply single phase fault at ONEY (521017) on the 138kV bus. b. Clear fault after 16 cycles and trip the following elements c. Trip the whole bus ONEY (521017).</p> |
| FLT1010-SB | P4 | <p>Stuck Breaker on at WASHITA4 (521089) at 138kV</p> <p>a. Apply single-phase fault at WASHITA4 (521089) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the WASHITA4 (521089) to GRACMNT4 (515802) 138kV line CKT 1. d. Trip the WASHITA4 (521089) to GRACMNT4 (515802) 138kV line CKT 2.</p> |
| FLT1011-SB | P4 | <p>Stuck Breaker on at WASHITA4 (521089) at 138kV</p> <p>a. Apply single-phase fault at WASHITA4 (521089) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the WASHITA4 (521089) to GRACMNT4 (515802) 138kV line CKT 1. d. Trip the WASHITA4 (521089) to ONEY (521017) 138kV line CKT 1.</p> |
| FLT1012-SB | P4 | <p>Stuck Breaker on at WASHITA4 (521089) at 138kV</p> <p>a. Apply single-phase fault at WASHITA4 (521089) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the WASHITA 138 kV (521089) /69 kV (521088) /13.8kV (521179) transformer CKT 1. d. Trip the WASHITA4 (521089) to ONEY (521017) 138kV line CKT 1.</p> |
| FLT1013-SB | P4 | <p>Stuck Breaker on at WASHITA4 (521089) at 138kV</p> <p>a. Apply single-phase fault at WASHITA4 (521089) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the WASHITA4 (521089) to S.W.S.-4 (511477) 138kV line CKT 1. d. Trip the WASHITA4 (521089) to GRACMNT4 (515802) 138kV line CKT 2.</p> |
| FLT1014-SB | P4 | <p>Stuck Breaker on at WASHITA4 (521089) at 138kV</p> <p>a. Apply single-phase fault at WASHITA4 (521089) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the WASHITA4 (521089) to S.W.S.-4 (511477) 138kV line CKT 1. d. Trip the WASHITA4 (521089) to SLKHILLS 4 (521103) 138kV line CKT 1. Trip generators on buses G23-GR6-GEN1 (923563), G23-GR6-GEN2 (923565), BLUCAN2-WTG1 (920001), BLUCAN2-WTG2 (920002), BLUCAN2-WTG3 (920003), BLUCAN2-WTG4 (920004), BLUCAN2-WTG5 (599003), BCVI_WTG1 (520522)</p> |
| FLT1015-SB | P4 | <p>Stuck Breaker on at WASHITA4 (521089) at 138kV</p> <p>a. Apply single-phase fault at WASHITA4 (521089) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the WASHITA 138 kV (521089) /69 kV (521088) /13.8kV (521179) transformer CKT 1. d. Trip the WASHITA4 (521089) to SLKHILLS 4 (521017) 138kV line CKT 1. Trip generators on buses G23-GR6-GEN1 (923563), G23-GR6-GEN2 (923565), BLUCAN2-WTG1 (920001), BLUCAN2-WTG2 (920002), BLUCAN2-WTG3 (920003), BLUCAN2-WTG4 (920004), BLUCAN2-WTG5 (599003), BCVI_WTG1 (520522)</p> |

Table 6 Continued

| Fault ID | Planning Event | Fault Descriptions |
|------------|----------------|---|
| FLT1016-SB | P4 | Stuck Breaker on at S.W.S.-4 (511477) at 138kV a. Apply single-phase fault at S.W.S.-4 (511477) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the S.W.S.-4 (511477) to NORGE-4 (511483) 138kV line CKT 1. d. Trip the S.W.S.-4 138 kV (511477) /69 kV (511476) /13.8kV (511413) transformer CKT 1. |
| FLT1017-SB | P4 | Stuck Breaker on at S.W.S.-4 (511477) at 138kV a. Apply single-phase fault at S.W.S.-4 (511477) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the S.W.S.-4 (511477) to WASHITA4 (521089) 138kV line CKT 1. d. Trip S.W.S.-4 138 kV (511477) /13.8 kV (511849) /13.8kV (511850) transformer CKT 1. Trip generator SWS NG4 (511849). Trip generator SWS NG5 (511850). |
| FLT1018-SB | P4 | Stuck Breaker on at S.W.S.-4 (511477) at 138kV a. Apply single-phase fault at S.W.S.-4 (511477) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the S.W.S.-4 (511477) to ANADARK4 (520814) 138kV line CKT 1. d. Trip the S.W.S.-4 (511477) to VERDEN 4 (511421) 138kV line CKT 1. |
| FLT1019-SB | P4 | Stuck Breaker on at S.W.S.-4 (511477) at 138kV a. Apply single-phase fault at S.W.S.-4 (511477) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the S.W.S.-4 (511477) to CARNEG-4 4 (511445) 138kV line CKT 1. d. Trip S.W.S 138/24kV (511477 /511848) transformer CKT 1. Trip generator SWS3-1 (511848). |
| FLT1020-SB | P4 | Stuck Breaker on at S.W.S.-4 (511477) at 138kV a. Apply single-phase fault at S.W.S.-4 (511477) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the S.W.S.-4 (511477) to G16-097-TAP (587794) 138kV line CKT 1. d. Trip S.W.S 138/14.4kV (511477 /511846) transformer CKT 1. Trip generator SWS1-1 (511846). |
| FLT1021-SB | P4 | Stuck Breaker on at S.W.S.-4 (511477) at 138kV a. Apply single-phase fault at S.W.S.-4 (511477) on the 138kV bus. b. Clear fault after 16 cycles and remove fault. c. Trip the S.W.S.-4 (511477) to ELSWORTH 4 (511563) 138kV line CKT 1. d. Trip S.W.S 138/14.4kV (511477 /511847) transformer CKT 1. Trip generator SWS2-1 (511847). |

RESULTS

Table 7 shows the relevant results of the fault events simulated for each of the modified cases. Existing DISIS base case issues are documented separately in Appendix C. The associated stability plots are also provided in Appendix C.

Table 7: Stability Analysis Results

| Fault ID | 25SP | | | 25WP | | |
|-------------|-------------------|------------------|--------|-------------------|------------------|--------|
| | Voltage Violation | Voltage Recovery | Stable | Voltage Violation | Voltage Recovery | Stable |
| FLT9001-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9002-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9003-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9004-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9005-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9006-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9007-3PH | Pass | Pass | Stable | Pass | Pass | Stable |

Table 7 Continued

| Fault ID | 25SP | | | 25WP | | |
|-------------|-------------------|------------------|--------|-------------------|------------------|--------|
| | Voltage Violation | Voltage Recovery | Stable | Voltage Violation | Voltage Recovery | Stable |
| FLT9008-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9009-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9010-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9011-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9012-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9013-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9014-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9015-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9016-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9017-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9018-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9019-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9020-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9021-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9022-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9023-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9024-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9025-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9026-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9027-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9028-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9029-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9030-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9031-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9032-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9033-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9034-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9035-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9036-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9037-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9038-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9039-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9040-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9041-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9042-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT9043-3PH | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1001-SB | Pass | Pass | Stable | Pass | Pass | Stable |

Table 7 Continued

| Fault ID | 25SP | | | 25WP | | |
|------------|-------------------|------------------|--------|-------------------|------------------|--------|
| | Voltage Violation | Voltage Recovery | Stable | Voltage Violation | Voltage Recovery | Stable |
| FLT1002-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1003-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1004-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1005-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1006-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1007-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1008-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1009-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1010-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1011-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1012-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1013-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1014-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1015-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1016-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1017-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1018-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1019-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1020-SB | Pass | Pass | Stable | Pass | Pass | Stable |
| FLT1021-SB | Pass | Pass | Stable | Pass | Pass | Stable |

The results of the dynamic stability analysis showed existing base case issues that were found in both the original DISIS-2017-002-1 model and the model with GEN-2023-GR6 included. These issues were not attributed to the GEN-2023-GR6 replacement request and are detailed in Appendix C.

There were no damping or voltage recovery violations attributed to the GEN-2023-GR6 replacement request observed during the simulated faults. Additionally, the project was found to stay connected during the contingencies that were studied and, therefore, will meet the Low Voltage Ride Through (LVRT) requirements of FERC Order #661A.

INSTALLED CAPACITY EXCEEDS GIA CAPACITY

Under FERC Order 845, Interconnection Customers are allowed to request Interconnection Service that is lower than the full generating capacity of their planned generating facilities. The Interconnection Customers must install acceptable control and protection devices that prevent the injection above their requested Interconnection Service amount measured at the POI.

NECESSARY INTERCONNECTION FACILITIES

This study identified necessary Interconnection Facilities to accommodate GEN-2023-GR6 as shown in Table 8.

Table 8: Necessary Interconnection Facilities

| Upgrade Name | Upgrade Description |
|--|---|
| Washita 138 kV GEN-2023-GR6 Interconnection (TOIF) (WFEC) | Interconnection upgrades and cost estimates needed to interconnect the following Interconnection Customer facility, GEN-2023-GR6, into the POI at Washita 138 kV. |
| Washita 138 kV GEN-2023-GR6 Interconnection (Non-Shared NU) (WFEC) | Interconnection upgrades and cost estimates needed to interconnect the following Interconnection Customer facility, GEN-2023-GR6, into the POI at Washita 138 kV. |

Should the Interconnection Customer choose to move forward with this request, an Interconnection Facilities Study will be necessary to determine the full scope, cost, and time required to interconnect these upgrades. SPP will work with the TO(s) indicated for the Interconnection Facilities Study.

RESULTS

RELIABILITY ASSESSMENT STUDY

In accordance with Attachment V and Business Practice 7800, the Reliability Assessment Study for Generator Replacements evaluates regional transmission impacts from removing the EGF from service and any non-transmission mitigations necessary for those impacts.

Based on the findings of the Reliability Assessment Planning Analysis, **no mitigations will be necessary** due to the removal of the EGF from service.

REPLACEMENT IMPACT STUDY

In accordance with SPP tariff Attachment V, any material adverse impact from operating the RGF when compared to the EGF would be identified as a Material Modification. In the case that the Interconnection Customer chooses to move forward with the RGF, it must submit the RGF as a new Interconnection Request.

Because no material adverse impacts to the SPP Transmission System were identified, SPP determined the requested replacement is **not a Material Modification**. SPP determined that the requested replacement did not cause a materially adverse impact to the dynamic stability and short-circuit characteristics of the SPP system.

This determination implies that no new upgrades beyond those required for interconnection of the RGF are required, thus not resulting in a material adverse impact on the cost or timing of any other Interconnection Request with a later Queue priority date.

NEXT STEPS

As the requested replacement is determined to not be a Material Modification, pursuant to SPP tariff Attachment V section 3.9.3, the Interconnection Customer shall inform SPP within 30 Calendar Days after having received these study results of its election to proceed.

If the Interconnection Customer chooses to proceed with the studied replacement, SPP will initiate an Interconnection Facilities Study and subsequently tender a draft GIA. The Interconnection Customer shall withdraw any associated Attachment AB retirement requests of the EGF, if applicable, and complete the Attachment AE requirements for de-registration of the EGF and registration of the RGF, including transfer or termination of applicable existing transmission service. If the Interconnection Customer would like to obtain new deliverability to final customers, a separate request for transmission service must be requested on Southwest Power Pool's OASIS.

Failure by the Interconnection Customer to provide an election to proceed within 30 Calendar Days will result in withdrawal of the Interconnection Request pursuant to section 3.7 of SPP tariff Attachment V.