



SPP *Southwest Power Pool*

***System Impact Study
SPP-2023-035
For Transmission Service
Requested By:
TNSK***

From SPRM_SPRM to SPA

***For a Reserved Amount Of
25 MW***

***From 07/01/2023
To 09/01/2023***

1. Executive Summary

TNSK has requested a system impact study for monthly firm transmission service from SPRM_SPRM to SPA. The period of the transaction is from 07/01/2023 00:00 to 09/01/2023 00:00. The request is for reservation 99673011.

The 25 MW transaction from SPRM_SPRM has an impact on the following flowgate(s) with no AFC: PITVALSUNHUG. To provide the AFC necessary for this transfer, the impact on these flowgates must be relieved.

After studying many scenarios using generation redispatch, there are several feasible scenarios that will relieve the flowgate(s) in question.

2. Introduction

TNSK has requested a system impact study for transmission service from SPRM_SPRM to SPA.

One constrained flowgate requires relief for this reservation to be accepted. The flowgate and their explanation is as follows:

- PITVALSUNHUG: Pittsburg – Valiant 345kV for the loss of Sunnyside – Hugo 345kV.

3. Study Methodology

A. Description

Southwest Power Pool used Transmission Adequacy & Reliability Assessment (TARA) to obtain possible unit pairings that would relieve the constraint. TARA calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

B. Model Updates

The 2023 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

C. Transfer Analysis

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using TARA, specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by TARA is the amount of redispatch necessary to relieve the impact on the affected flowgate.

4. Study Results

After studying the impacts of the request, one flowgate requires relief. The flowgate and associated amount of relief is as follows:

Table 1

Flowgate	Duration	Sensitivity (%)	Required Relief (MW)
5661:PITVALSUNHUG	7/1/2023 00:00 - 9/1/2023 00:00	3.45%	0.86

Table 2 displays a list of generator pairs that are possible relief options for each flowgate in question and the amount of redispatch capacity needed.

Table 2

5661:PITVALSUNHUG			
Increment	Decrement	Sensitivity	MW
FULTONU1 1	COM1-1	38.84%	2.21
FULTONU1 1	MCLN 1S	38.36%	2.24
FULTONU1 1	ANADRK5	38.28%	2.25
TENGAS 1	COM1-1	36.31%	2.37
TENGAS 1	MCLN 1S	35.83%	2.40
LIEBR3-1	COM1-1	35.78%	2.40
TENGAS 1	ANADRK5	35.75%	2.41
LIEBR3-1	MCLN 1S	35.31%	2.44
LIEBR3-1	ANADRK5	35.23%	2.44

5. Conclusion

Generation redispatch options were studied in order to relieve the necessary constraint(s). The results of this study shows that the constraints on the flowgate(s) in question could be relieved by executing one or more of the options described in the Study Results section of this document.