



SPP *Southwest Power Pool*

***System Impact Study
SPP-2023-074
For Transmission Service
Requested By:
TEA***

From WFEC to ERCOTN

***For a Reserved Amount Of
195 MW***

***From 11/07/2023
To 11/09/2023***

1. Executive Summary

TEA has requested a system impact study for daily firm transmission service from WFEC to ERCOTN. The period of the transaction is from 11/07/2023 00:00 to 11/09/2023 00:00. The request is for reservation 101247249.

The 195 MW transaction from WFEC has an impact on the following flowgate(s) with no AFC: CORNAPTERSUN, REDMINAXTPOS. To provide the AFC necessary for this transfer, the impact on these flowgates must be relieved.

After studying many scenarios using generation redispatch, there are several feasible scenarios that will relieve the flowgate(s) in question.

2. Introduction

TEA has requested a system impact study for transmission service from WFEC to ERCOTN.

Two constrained flowgates require relief for this reservation to be accepted. The flowgates and the explanations are as follows:

- CORNAPTERSUN: Cornville Tap – Naples 138 kV for the loss of Terry Road – Sunnyside 345 kV.
- REDMINAXTPOS: Red Willow – Mingo 345kV for the loss of Axtell – Post Rock 345kV.

3. Study Methodology

A. Description

Southwest Power Pool used Transmission Adequacy & Reliability Assessment (TARA) to obtain possible unit pairings that would relieve the constraint. TARA calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

B. Model Updates

The 2023 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

C. Transfer Analysis

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using TARA, specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved and the generation sensitivity factor calculated by TARA is the amount of redispatch necessary to relieve the impact on the affected flowgate.

4. Study Results

After studying the impacts of the request, Two flowgates require relief. The flowgates and associated amount of relief are as follows:

Table 1

Flowgate	Duration	Sensitivity (%)	Required Relief (MW)
5107:CORNAPTERSUN	11/7/2023 14:00 - 11/7/2023 18:00	3.85%	7.51
5526:REDMINAXTPOS	11/7/2023 00:00 - 11/9/2023 00:00	3.44%	6.71

Table 2 displays a list of generator pairs that are possible relief options for each flowgate in question and the amount of redispatch capacity needed.

Table 2

5107:CORNAPTERSUN			
Increment	Decrement	Sensitivity	MW
FULTONU1 1	SWS3-1	8.91%	84.32
WILKE3-1	SWS3-1	8.88%	84.53

5526:REDMINAXTPOS			
Increment	Decrement	Sensitivity	MW
FULTONU1 1	GENTLM1G	28.37%	23.65
WILKE3-1	GENTLM1G	28.28%	23.72
FULTONU1 1	LELAND_2-BEG	10.95%	61.29
WILKE3-1	LELAND_2-BEG	10.86%	61.77

5. Conclusion

Generation redispatch options were studied in order to relieve the necessary constraint(s). The results of this study shows that the constraints on the flowgate(s) in question could be relieved by executing one or more of the options described in the Study Results section of this document.