



# **DPA-2024-MARCH-1924**

## Delivery Point Network Study

Published on 07/01/2024

By SPP Engineering, Transmission Services

# REVISION HISTORY

---

DATE OR VERSION NUMBER	AUTHOR	CHANGE DESCRIPTION	COMMENTS
07/01/2024	SPP	Original	

# CONTENTS

---

Revision History ..... i

Section 1: Introduction ..... 1

Section 2: Study Methodology ..... 2

    Objective ..... 2

    Study Process ..... 2

Section 3: Results of Analysis ..... 4

    Potential Thermal Overloads and Voltage Violations ..... 4


    Short Circuit ..... 10

    Stability ..... 11

Section 4: Conclusion ..... 14

## SECTION 1: INTRODUCTION

This report outlines the results of an evaluation of regional transmission impacts from delivery point request DPA-2024-March-1924. The requesting entity plans to add a new delivery point called Claremore. The Claremore delivery point is in the Grand River Dam Authority (GRDA) transmission system.



The load flow models used for the evaluation were 2024 ITP models. SPP performed an AC contingency analysis on these models using PSS@E.

## SECTION 2: STUDY METHODOLOGY

### OBJECTIVE

The purpose of this study was to determine the regional transmission system impacts within the SPP footprint due to the new load served by GRDA. SPP performed a Delivery Point Network Study (DPNS) with the configurations shown in Table 2-1 below.

### STUDY PROCESS

- Model Assumptions
  - 2024 ITP models
    - Model years 2025, 2028, and 2033
    - Summer Peak (2025S, 2028S and 2033S), Winter Peak (2025W 2028W, and 2033W), and Light Load (2028L and 2033L)
  - 2024 ITP Short Circuit model set
    - 2028 Summer Max Fault
  - 2024 TPL Dynamic model set
    - 2033 Summer Peak Base and Change Case

Case Name	Study Year	Season	Scenario	Load (250.0/35.6)
2024ITPPF-25S.sav	2025	Summer Peak	Base Reliability	Base Case
2024ITPPF-25W.sav	2025	Winter Peak	Base Reliability	Base Case
2024ITPPF-28L.sav	2028	Light Load	Base Reliability	Base Case
2024ITPPF-28S.sav	2028	Summer Peak	Base Reliability	Base Case
2024ITPPF-28W.sav	2028	Winter Peak	Base Reliability	Base Case
2024ITPPF-33L.sav	2033	Light Load	Base Reliability	Base Case
2024ITPPF-33S.sav	2033	Summer Peak	Base Reliability	Base Case
2024ITPPF-33W.sav	2032	Winter Peak	Base Reliability	Base Case
2024ITPPF-25S_1924.sav	2025	Summer Peak	Base Reliability	Claremore = 250.0/35.6
2024ITPPF-25W_1924.sav	2025	Winter Peak	Base Reliability	Claremore = 250.0/35.6
2024ITPPF-28L_1924.sav	2028	Light Load	Base Reliability	Claremore = 250.0/35.6
2024ITPPF-28S_1924.sav	2028	Summer Peak	Base Reliability	Claremore = 250.0/35.6
2024ITPPF-28W_1924.sav	2028	Winter Peak	Base Reliability	Claremore = 250.0/35.6
2024ITPPF-33L_1924.sav	2033	Light Load	Base Reliability	Claremore = 250.0/35.6
2024ITPPF-33S_1924.sav	2033	Summer Peak	Base Reliability	Claremore = 250.0/35.6
2024ITPPF-33W_1924.sav	2033	Winter Peak	Base Reliability	Claremore = 250.0/35.6

**Table 2-1: Study Cases**

- Steady State Analysis
  - Assumptions (consistent with the ITP analysis)
    - AC contingency analysis on all load flow models using PSS@E
    - Monitored Elements
      - SPP facilities 69 kV and above
      - First-tier companies 100 kV and above
    - Contingencies (consistent with the ITP analysis)
      - Provided for the ITP by SPP members and first-tier companies
    - Apply SPP Criteria and NERC reliability standards
  - Compare thermal overloads and voltage violations that occur with and without the Claremore delivery point change to determine thermal overloads and voltage violations resulting from the load addition to the transmission system.
- Dynamics Analysis
  - Assumptions
    - 2024 TPL Dynamics Model Set
      - 2033 Summer Peak Base and Change Case
  - Analyses
    - Fast Fault Screening using POM Studio
- Short Circuit Analysis
  - Assumptions
    - Used 2024 Final ITP Short Circuit models (Max Fault)
      - Placed all available facilities in service
        - Generation
        - Transmission lines
        - Transformers
        - Buses
      - Short Circuit Output
        - Physical
      - Short Circuit Coordinates
        - Polar
      - Short Circuit Parameters
        - 3 Phase
      - FLAT – classical fault analysis conditions
  - Analyses
    - Three-phase fault

## SECTION 3: RESULTS OF ANALYSIS

### POTENTIAL THERMAL OVERLOADS AND VOLTAGE VIOLATIONS

The analysis identified potential thermal overloads and no voltage violations resulting from the new Claremore delivery point. Table 3-1 details the potential thermal violations.

Year	Season	Facility Name	Contingency Name	Rate A, Rate B (MVA)	Max Flow (MVA)	Change Case Max Loading (%)
2028	Light	CLARMR 5 - CLRAUTO4 - 1	40OLOGAHKAMO-OOLOGAH4-Z1	205/256	264.7	103.4
2028	Light	CLARMR 5 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	264.7	103.4
2028	Light	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH4-40OLOGAHKAMO-Z1	205/256	264.7	103.4
2028	Light	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	264.7	103.4
2028	Light	CLARMR 4 - CLARMORE 4 - 1	40OLOGAHKAMO-OOLOGAH4-Z1	199/239	258.8	108.3
2028	Light	CLARMR 4 - CLARMORE 4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	199/239	258.8	108.3
2028	Light	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH4-40OLOGAHKAMO-Z1	199/239	258.8	108.3
2028	Light	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	199/239	258.8	108.3
2028	Light	CLARMR 4 - CLRAUTO4 - 1	40OLOGAHKAMO-OOLOGAH4-Z1	205/256	258.8	101.1
2028	Light	CLARMR 4 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	258.8	101.1
2028	Light	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH4-40OLOGAHKAMO-Z1	205/256	258.8	101.1
2028	Light	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	258.8	101.1
2028	Light	CLARMR 4 - CLARMORE 4 - 1	40OLOGAHKAMO-CLARMORE4-1	199/239	257.2	107.6
2028	Light	CLARMR 4 - CLARMORE 4 - 1	CLARMORE4-40OLOGAHKAMO-1	199/239	257.2	107.6
2028	Light	CLARMR 4 - CLRAUTO4 - 1	40OLOGAHKAMO-CLARMORE4-1	205/256	257.0	100.4
2028	Light	CLARMR 4 - CLRAUTO4 - 1	CLARMORE4-40OLOGAHKAMO-1	205/256	257.0	100.4
2028	Light	CLARMR 5 - CLRAUTO4 - 1	40OLOGAHKAMO-CLARMORE4-1	205/256	262.9	102.7
2028	Light	CLARMR 5 - CLRAUTO4 - 1	CLARMORE4-40OLOGAHKAMO-1	205/256	262.9	102.7
2028	Light	N.E.S.-4 - OOLOGAH 4 - 1	CLARMR 4 - CLARMORE 4 - 1	199/239	258.1	108
2028	Light	N.E.S.-4 - OOLOGAH 4 - 1	CLARMR 5 - CLARMR 4 - 1	199/239	258.1	108
2028	Light	CLARMORE4-40OLOGAHKAMO-1	CLARMR 4 - CLARMORE 4 - 1	199/239	253.8	106.2
2028	Light	CLARMORE4-40OLOGAHKAMO-1	CLARMR 5 - CLARMR 4 - 1	199/239	253.8	106.2
2028	Summer	N.E.S.-4 - OOLOGAH 4 - 1	GRDA_MSOLAR - CLARMR 5 - 1	199/239	296.8	124.2
2028	Summer	CLARMR 5 - CLRAUTO4 - 1	40OLOGAHKAMO-OOLOGAH4-Z1	205/256	270.1	105.5
2028	Summer	CLARMR 5 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	270.1	105.5
2028	Summer	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH4-40OLOGAHKAMO-Z1	205/256	270.1	105.5
2028	Summer	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	270.1	105.5

Year	Season	Facility Name	Contingency Name	Rate A, Rate B (MVA)	Max Flow (MVA)	Change Case Max Loading (%)
2028	Summer	OOLOGAH4-4OOLOGAHKAMO-Z1	GRDA_MSOLAR - CLARMR 5 - 1	286/286	293.4	102.6
2028	Summer	CLARMORE4-4OOLOGAHKAMO-1	GRDA_MSOLAR - CLARMR 5 - 1	199/239	287.3	120.2
2028	Summer	CLARMR 4 - CLARMORE 4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	199/239	263.6	110.3
2028	Summer	CLARMR 4 - CLARMORE 4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	199/239	263.6	110.3
2028	Summer	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	199/239	263.6	110.3
2028	Summer	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	199/239	263.6	110.3
2028	Summer	CLARMR 4 - CLRAUTO4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	205/256	263.7	103
2028	Summer	CLARMR 4 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	263.7	103
2028	Summer	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	205/256	263.7	103
2028	Summer	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	263.7	103
2028	Summer	CLARMR 4 - CLARMORE 4 - 1	4OOLOGAHKAMO-CLARMORE4-1	199/239	257.4	107.7
2028	Summer	CLARMR 4 - CLARMORE 4 - 1	CLARMORE4-4OOLOGAHKAMO-1	199/239	257.4	107.7
2028	Summer	CLARMR 4 - CLRAUTO4 - 1	4OOLOGAHKAMO-CLARMORE4-1	205/256	257.3	100.5
2028	Summer	CLARMR 4 - CLRAUTO4 - 1	CLARMORE4-4OOLOGAHKAMO-1	205/256	257.3	100.5
2028	Summer	CLARMR 5 - CLRAUTO4 - 1	4OOLOGAHKAMO-CLARMORE4-1	205/256	263.2	102.8
2028	Summer	CLARMR 5 - CLRAUTO4 - 1	CLARMORE4-4OOLOGAHKAMO-1	205/256	263.2	102.8
2028	Summer	N.E.S.-4 - OOLOGAH 4 - 1	BASE CASE	199/239	269.4	135.4
2028	Summer	CLARMORE4-4OOLOGAHKAMO-1	BASE CASE	199/239	260.7	131
2028	Winter	N.E.S.-4 - OOLOGAH 4 - 1	CLARTOK4 - N.E.S.-4 - 1	238/271	315.7	116.5
2028	Winter	CLARMORE4-4OOLOGAHKAMO-1	CLARTOK4 - N.E.S.-4 - 1	205/256	306.4	119.7
2028	Winter	N.E.S.-4 - OOLOGAH 4 - 1	BASE CASE	238/271	295.1	124
2028	Winter	CLARMR 5 - CLRAUTO4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	205/256	269.8	105.4
2028	Winter	CLARMR 5 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	269.8	105.4
2028	Winter	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	205/256	269.8	105.4
2028	Winter	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	269.8	105.4
2028	Winter	CLARMORE4-4OOLOGAHKAMO-1	BASE CASE	205/256	286.0	139.5
2028	Winter	CLARMR 4 - CLARMORE 4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	205/256	263.7	103
2028	Winter	CLARMR 4 - CLARMORE 4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	263.7	103
2028	Winter	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	205/256	263.7	103
2028	Winter	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	263.7	103
2028	Winter	CLARMR 4 - CLRAUTO4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	205/256	263.7	103
2028	Winter	CLARMR 4 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	263.7	103

Year	Season	Facility Name	Contingency Name	Rate A, Rate B (MVA)	Max Flow (MVA)	Change Case Max Loading (%)
2028	Winter	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	205/256	263.7	103
2028	Winter	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	263.7	103
2028	Winter	CLARMR 4 - CLARMORE 4 - 1	4OOLOGAHKAMO-CLARMORE4-1	205/256	257.3	100.5
2028	Winter	CLARMR 4 - CLARMORE 4 - 1	CLARMORE4-4OOLOGAHKAMO-1	205/256	257.3	100.5
2028	Winter	CLARMR 4 - CLRAUTO4 - 1	4OOLOGAHKAMO-CLARMORE4-1	205/256	257.3	100.5
2028	Winter	CLARMR 4 - CLRAUTO4 - 1	CLARMORE4-4OOLOGAHKAMO-1	205/256	257.3	100.5
2028	Winter	CLARMR 5 - CLRAUTO4 - 1	4OOLOGAHKAMO-CLARMORE4-1	205/256	262.9	102.7
2028	Winter	CLARMR 5 - CLRAUTO4 - 1	CLARMORE4-4OOLOGAHKAMO-1	205/256	262.9	102.7
2033	Light	CLARMR 5 - CLRAUTO4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	205/256	265.0	103.5
2033	Light	CLARMR 5 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	265.0	103.5
2033	Light	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	205/256	265.0	103.5
2033	Light	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	265.0	103.5
2033	Light	CLARMR 5 - CLRAUTO4 - 1	4OOLOGAHKAMO-CLARMORE4-1	205/256	263.2	102.8
2033	Light	CLARMR 5 - CLRAUTO4 - 1	CLARMORE4-4OOLOGAHKAMO-1	205/256	263.2	102.8
2033	Light	CLARMR 4 - CLARMORE 4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	199/239	258.8	108.3
2033	Light	CLARMR 4 - CLARMORE 4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	199/239	258.8	108.3
2033	Light	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	199/239	258.8	108.3
2033	Light	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	199/239	258.8	108.3
2033	Light	CLARMR 4 - CLRAUTO4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	205/256	258.8	101.1
2033	Light	CLARMR 4 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	258.8	101.1
2033	Light	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	205/256	258.8	101.1
2033	Light	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	258.8	101.1
2033	Light	CLARMR 4 - CLRAUTO4 - 1	4OOLOGAHKAMO-CLARMORE4-1	205/256	257.3	100.5
2033	Light	CLARMR 4 - CLRAUTO4 - 1	CLARMORE4-4OOLOGAHKAMO-1	205/256	257.3	100.5
2033	Light	CLARMR 4 - CLARMORE 4 - 1	4OOLOGAHKAMO-CLARMORE4-1	199/239	257.2	107.6
2033	Light	CLARMR 4 - CLARMORE 4 - 1	CLARMORE4-4OOLOGAHKAMO-1	199/239	257.2	107.6
2033	Light	N.E.S.-4 - OOLOGAH 4 - 1	CLARMR 4 - CLARMORE 4 - 1	199/239	258.1	108
2033	Light	N.E.S.-4 - OOLOGAH 4 - 1	CLARMR 5 - CLARMR 4 - 1	199/239	258.1	108
2033	Light	CLARMORE4-4OOLOGAHKAMO-1	CLARMR 4 - CLARMORE 4 - 1	199/239	253.8	106.2
2033	Light	CLARMORE4-4OOLOGAHKAMO-1	CLARMR 5 - CLARMR 4 - 1	199/239	253.8	106.2
2033	Summer	N.E.S.-4 - OOLOGAH 4 - 1	GRDA_MSOLAR - CLARMR 5 - 1	199/239	306.2	128.1
2033	Summer	CLARMR 5 - CLRAUTO4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	205/256	270.3	105.6
2033	Summer	CLARMR 5 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	270.3	105.6
2033	Summer	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	205/256	270.3	105.6

Year	Season	Facility Name	Contingency Name	Rate A, Rate B (MVA)	Max Flow (MVA)	Change Case Max Loading (%)
2033	Summer	CLARMORE4-40OLOGAHKAMO-1	GRDA_MSOLAR - CLARMR 5 - 1	199/239	296.6	124.1
2033	Summer	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	270.3	105.6
2033	Summer	N.E.S.-4 - OOLOGAH 4 - 1	BASE CASE	199/239	282.6	142
2033	Summer	CLARMORE4-40OLOGAHKAMO-1	BASE CASE	199/239	273.6	137.5
2033	Summer	CLARMR 5 - CLRAUTO4 - 1	40OLOGAHKAMO-CLARMORE4-1	205/256	263.4	102.9
2033	Summer	CLARMR 5 - CLRAUTO4 - 1	CLARMORE4-40OLOGAHKAMO-1	205/256	263.4	102.9
2033	Summer	CLARMR 4 - CLARMORE 4 - 1	40OLOGAHKAMO-OOLOGAH4-Z1	199/239	263.9	110.4
2033	Summer	CLARMR 4 - CLARMORE 4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	199/239	263.9	110.4
2033	Summer	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH4-40OLOGAHKAMO-Z1	199/239	263.9	110.4
2033	Summer	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	199/239	263.9	110.4
2033	Summer	CLARMR 4 - CLRAUTO4 - 1	40OLOGAHKAMO-OOLOGAH4-Z1	205/256	263.9	103.1
2033	Summer	CLARMR 4 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	263.9	103.1
2033	Summer	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH4-40OLOGAHKAMO-Z1	205/256	263.9	103.1
2033	Summer	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	263.9	103.1
2033	Summer	CLARMR 4 - CLARMORE 4 - 1	40OLOGAHKAMO-CLARMORE4-1	199/239	257.4	107.7
2033	Summer	CLARMR 4 - CLARMORE 4 - 1	CLARMORE4-40OLOGAHKAMO-1	199/239	257.4	107.7
2033	Summer	CLARMR 4 - CLRAUTO4 - 1	40OLOGAHKAMO-CLARMORE4-1	205/256	257.3	100.5
2033	Summer	CLARMR 4 - CLRAUTO4 - 1	CLARMORE4-40OLOGAHKAMO-1	205/256	257.3	100.5
2033	Summer	OOLOGAH4-40OLOGAHKAMO-Z1	GRDA_MSOLAR - CLARMR 5 - 1	286/286	302.9	105.9
2033	Summer	OOLOGAH4-40OLOGAHKAMO-Z1	CHAMSPR7 - CLARKSV7 - 1	286/286	294.9	103.1
2033	Summer	OOLOGAH4-40OLOGAHKAMO-Z1	CLARTOK4 - N.E.S.-4 - 1	286/286	294.9	103.1
2033	Summer	OOLOGAH4-40OLOGAHKAMO-Z1	OWASO2_4 - N.E.S.-4 - 1	286/286	294.0	102.8
2033	Summer	OOLOGAH4-40OLOGAHKAMO-Z1	RICE CK4 - N.E.S.-4 - 1	286/286	294.0	102.8
2033	Summer	OOLOGAH4-40OLOGAHKAMO-Z1	5ELMCRK - CATSAGR5 - 1	286/286	293.7	102.7
2033	Summer	OOLOGAH4-40OLOGAHKAMO-Z1	CATSAGR5 - 5ELMCRK - 1	286/286	293.7	102.7
2033	Summer	OOLOGAH4-40OLOGAHKAMO-Z1	VERDIGS4 - CLARTOK4 - 1	286/286	293.4	102.6
2033	Summer	OOLOGAH4-40OLOGAHKAMO-Z1	OWAS1094 - N.E.S.-4 - 1	286/286	293.2	102.5

Year	Season	Facility Name	Contingency Name	Rate A, Rate B (MVA)	Max Flow (MVA)	Change Case Max Loading (%)
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	RICE CK4 - BV-SE--4 - 1	286/286	292.9	102.4
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	N.E.S.-4 - HAWTHRN4 - 1	286/286	292.0	102.1
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	CHELSA4 - HAWTHRN4 - 1	286/286	291.4	101.9
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	NBVILLE4 - BV-SE--4 - 1	286/286	290.9	101.7
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	CLARMR 5 - MCSTAP 5 - 1	286/286	290.6	101.6
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	GRDA1 5 - MCSTAP 5 - 1	286/286	290.6	101.6
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	5ELMCRK - COLINS 5 - 1	286/286	290.3	101.5
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	GEN512000 1	286/286	290.3	101.5
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	COLINS 5 - 5ELMCRK - 1	286/286	290.3	101.5
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	NBVILLE4 - COFFEYT4 - 1	286/286	290.0	101.4
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	5CHOTEAU1 - MAID 5 - 1	286/286	289.7	101.3
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	CHELSA4 - ALWUETP4 - 1	286/286	289.7	101.3
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	MAID 5 - 5CHOTEAU1 - 1	286/286	289.7	101.3
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	TERNITP4 - VERDIGS4 - 1	286/286	289.4	101.2
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	PCATSAT4 - OWASO2_4 - 1	286/286	289.4	101.2
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	GEN509394 1	286/286	289.4	101.2
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	VINTAJC4 - ALWUETP4 - 1	286/286	288.9	101
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	FLINTCR5 - FLINTCR1 - 1	286/286	288.9	101
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	WATOVA 4 - N.E.S.-4 - 1	286/286	288.6	100.9
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	DEARING4 - COFFEYT4 - 1	286/286	288.6	100.9
2033	Summer	OOLOGAH4- 4OOLOGAHKAMO-Z1	GEN512614 1	286/286	288.3	100.8

Year	Season	Facility Name	Contingency Name	Rate A, Rate B (MVA)	Max Flow (MVA)	Change Case Max Loading (%)
2033	Summer	OOLOGAH4-4OOLOGAHKAMO-Z1	GREC TAP7 - GRECCTG_1 - 1	286/286	288.3	100.8
2033	Summer	OOLOGAH4-4OOLOGAHKAMO-Z1	WATOVA 4 - NOWATA-4 - 1	286/286	288.0	100.7
2033	Summer	OOLOGAH4-4OOLOGAHKAMO-Z1	GRDA1 7 - GREC TAP7 - 1	286/286	288.0	100.7
2033	Summer	OOLOGAH4-4OOLOGAHKAMO-Z1	T.NO.--4 - N.E.S.-4 - 1	286/286	287.7	100.6
2033	Summer	OOLOGAH4-4OOLOGAHKAMO-Z1	OWASOTP4 - OWAS1094 - 1	286/286	287.4	100.5
2033	Summer	OOLOGAH4-4OOLOGAHKAMO-Z1	BV-SE--4 - NOWATA-4 - 1	286/286	286.9	100.3
2033	Winter	N.E.S.-4 - OOLOGAH 4 - 1	CLARTOK4 - N.E.S.-4 - 1	238/271	320.3	118.2
2033	Winter	CLARMORE4-4OOLOGAHKAMO-1	CLARTOK4 - N.E.S.-4 - 1	205/256	310.8	121.4
2033	Winter	N.E.S.-4 - OOLOGAH 4 - 1	BASE CASE	238/271	300.6	126.3
2033	Winter	CLARMR 5 - CLRAUTO4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	205/256	270.1	105.5
2033	Winter	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	205/256	270.1	105.5
2033	Winter	CLARMR 5 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	269.8	105.4
2033	Winter	CLARMR 5 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	269.8	105.4
2033	Winter	CLARMORE4-4OOLOGAHKAMO-1	BASE CASE	205/256	291.5	142.2
2033	Winter	CLARMR 5 - CLRAUTO4 - 1	4OOLOGAHKAMO-CLARMORE4-1	205/256	262.9	102.7
2033	Winter	CLARMR 5 - CLRAUTO4 - 1	CLARMORE4-4OOLOGAHKAMO-1	205/256	262.9	102.7
2033	Winter	CLARMR 4 - CLARMORE 4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	205/256	263.7	103
2033	Winter	CLARMR 4 - CLARMORE 4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	263.7	103
2033	Winter	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	205/256	263.7	103
2033	Winter	CLARMR 4 - CLARMORE 4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	263.7	103
2033	Winter	CLARMR 4 - CLRAUTO4 - 1	4OOLOGAHKAMO-OOLOGAH4-Z1	205/256	263.7	103
2033	Winter	CLARMR 4 - CLRAUTO4 - 1	N.E.S.-4 - OOLOGAH 4 - 1	205/256	263.7	103
2033	Winter	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH4-4OOLOGAHKAMO-Z1	205/256	263.7	103
2033	Winter	CLARMR 4 - CLRAUTO4 - 1	OOLOGAH 4 - N.E.S.-4 - 1	205/256	263.7	103
2033	Winter	CLARMR 4 - CLARMORE 4 - 1	4OOLOGAHKAMO-CLARMORE4-1	205/256	257.3	100.5
2033	Winter	CLARMR 4 - CLARMORE 4 - 1	CLARMORE4-4OOLOGAHKAMO-1	205/256	257.3	100.5
2033	Winter	CLARMR 4 - CLRAUTO4 - 1	4OOLOGAHKAMO-CLARMORE4-1	205/256	257.3	100.5
2033	Winter	CLARMR 4 - CLRAUTO4 - 1	CLARMORE4-4OOLOGAHKAMO-1	205/256	257.3	100.5

**Table 3-1: Potential Thermal Overloads**

**SHORT CIRCUIT**

SPP performed short circuit analysis for the 2028 Summer Peak with the new load addition. The analysis identified the currents as listed in Table 3-2.

Season	Model	Fault	Bus	Current (Amps)
28S	Max Fault	Three Phase	4OOLOGAHKAMO138.00	21,604
28S	Max Fault	Three Phase	5ELMCRK 161.00	13,668
28S	Max Fault	Three Phase	5KETONVL 161.00	11,917
28S	Max Fault	Three Phase	DENVTAP4 138.00	9,338
28S	Max Fault	Three Phase	T.NO.--4 138.00	35,058
28S	Max Fault	Three Phase	CDC-ET 4 138.00	22,718
28S	Max Fault	Three Phase	PCATSAT4 138.00	21,030
28S	Max Fault	Three Phase	CDC-WT 4 138.00	23,764
28S	Max Fault	Three Phase	OWASO2_4 138.00	15,070
28S	Max Fault	Three Phase	OWASOTP4 138.00	14,625
28S	Max Fault	Three Phase	P&P WTP4 138.00	15,100
28S	Max Fault	Three Phase	VERDIGS4 138.00	15,130
28S	Max Fault	Three Phase	OWAS1094 138.00	14,226
28S	Max Fault	Three Phase	CLARTOK4 138.00	15,109
28S	Max Fault	Three Phase	T.NO.2-4 138.00	34,973
28S	Max Fault	Three Phase	46ST-TP-4 138.00	17,978
28S	Max Fault	Three Phase	SKIATKTP4 138.00	10,777
28S	Max Fault	Three Phase	WATOVA 4 138.00	9,073
28S	Max Fault	Three Phase	RICE CK4 138.00	11,428
28S	Max Fault	Three Phase	BV-SE--4 138.00	12,329
28S	Max Fault	Three Phase	N.E.S.-4 138.00	36,220
28S	Max Fault	Three Phase	NOWATA-4 138.00	8,439
28S	Max Fault	Three Phase	CHELSA4 138.00	6,018
28S	Max Fault	Three Phase	HAWTHRN4 138.00	20,446
28S	Max Fault	Three Phase	NES1-1 14.400	87,541
28S	Max Fault	Three Phase	NES1-1A 18.000	86,139
28S	Max Fault	Three Phase	NES1-1B 18.000	85,332
28S	Max Fault	Three Phase	NES2-1 22.000	59,670
28S	Max Fault	Three Phase	CENTLFT2 69.000	11,521
28S	Max Fault	Three Phase	COLINS 5 161.00	12,717
28S	Max Fault	Three Phase	MAID 5 161.00	43,744
28S	Max Fault	Three Phase	GRDA1 7 345.00	26,478
28S	Max Fault	Three Phase	CLARMR 5 161.00	14,140
28S	Max Fault	Three Phase	GRDA1 5 161.00	43,272
28S	Max Fault	Three Phase	CLARMR 2 69.000	12,918
28S	Max Fault	Three Phase	GRDA15-1 22.800	17,352
28S	Max Fault	Three Phase	WAGNOR 5 161.00	9,552
28S	Max Fault	Three Phase	COLLINS4 138.00	7,923
28S	Max Fault	Three Phase	CLARMR 4 138.00	15,290
28S	Max Fault	Three Phase	CHELGR2 69.000	4,460
28S	Max Fault	Three Phase	GRDA1 2 69.000	12,201
28S	Max Fault	Three Phase	WMAIN ST5 161.00	26,131
28S	Max Fault	Three Phase	CLARMR4 13.800	4,821

Season	Model	Fault	Bus	Current (Amps)
28S	Max Fault	Three Phase	CLARMR1 13.800	17,788
28S	Max Fault	Three Phase	CLARMR2 13.800	17,062
28S	Max Fault	Three Phase	GRDA1 1 13.800	14,211
28S	Max Fault	Three Phase	GRDA1 13.800	15,882
28S	Max Fault	Three Phase	GRDA2 1 13.800	16,729
28S	Max Fault	Three Phase	COLLIN1 1 13.800	990
28S	Max Fault	Three Phase	COLLIN2 1 13.800	13,923
28S	Max Fault	Three Phase	COLLIN3 1 13.800	9,579
28S	Max Fault	Three Phase	CLARMORE 4 138.00	18,485
28S	Max Fault	Three Phase	COLNSGR2 69.000	10,224
28S	Max Fault	Three Phase	CLARMTP 2 69.000	10,828
28S	Max Fault	Three Phase	CLARCTY1 2 69.000	9,995
28S	Max Fault	Three Phase	CLARCTY2 2 69.000	9,161
28S	Max Fault	Three Phase	CLARCTY4 2 69.000	9,132
28S	Max Fault	Three Phase	OOLOGAH 4 138.00	21,627
28S	Max Fault	Three Phase	SEQUOYA 2 69.000	6,895
28S	Max Fault	Three Phase	MCSTAP 5 161.00	20,052
28S	Max Fault	Three Phase	CLARMRDUP* 13.800	4,821

**Table 3-2: Short Circuit Results**

\*CLARMRDUP is the tertiary bus of the solution’s new transformer at existing Claremore substation

**STABILITY**

SPP performed a Fast Fault Screening (FFS) for the base case and change case models. The change case models include the Claremore delivery point changes. The FFS was performed for 2033 Summer Peak. There were no significant differences in the critical clearing times between the base and change case. Therefore, a transient stability analysis is not required.

### **TRANSMISSION SOLUTIONS**

The addition of the load at the new Claremore delivery point caused potential thermal overloads on the 138 kV system around Claremore and on a third-party transmission facility as indicated in Table 3-1. SPP solutions considered rebuilding the surrounding 138 kV system and bringing in nearby transmission sources. The solutions are listed below.

**Solution #1:** 138 kV Rebuild (Total cost \$11,981,322)

- Rebuild N.E.S. to Oologah 138 kV circuit 1
- Rebuild Oologah to Claremore 138 kV circuit 1
- Rebuild Claremore to Claremore4 138 kV circuit 1
- New 161/138 kV transformer at Claremore4

**Solution #2** 345 kV Source (Total cost \$28,125,155)

- New 345 kV substation at Claremore tapping N.E.S. to Oneta 345 kV circuit 1
- Build 1.54 miles of new 345 kV lines from tapped N.E.S. to Oneta line to new Claremore 345 kV substation
- New 345/138 kV transformer at new Claremore substation
- Rebuild N.E.S. to Oologah 138 kV circuit 1
- Rebuild Oologah to Claremore 138 kV circuit 1

SPP chose to move forward with Solution #1. This solution solves all issues identified in Table 3-1 in the most cost-effective manner.

<b>New Upgrade Description*</b>	<b>Mileage</b>	<b>MVA (Rate B)</b>	<b>Date Needed**</b>	<b>Host Transmission Owner</b>	<b>Estimated Cost***</b>
Rebuild N.E.S. to Oologah 138 kV circuit 1	2.98	325	6/1/2026	GRDA	\$2,918,314
Rebuild Oologah to Claremore 138 kV circuit 1	1.7	325	6/1/2026	GRDA	\$1,659,913
Rebuild Claremore to Claremore4 138 kV circuit 1	5.09	265	6/1/2026	GRDA	\$4,979,740
New 161/138 kV transformer at Claremore4	-	256	6/1/2026	GRDA	\$2,423,355
<b>TOTAL NEW UPGRADE COST</b>					<b>\$11,981,322</b>

**Table 3-3: Recommended Upgrade Solution 1**

\*All requests with a Network Upgrade(s) identified in the DPNS will be subject to further evaluation in the soonest available Integrated Transmission Planning Assessment that is able to include the load changes, if it is determined that the Network Upgrade(s) will be able to meet the study timeframe requirements pursuant to the standardized project timelines in SPP Business Practices, based on the SPP determined Network Upgrade(s) need date. If it is determined that a Network Upgrade(s) identified from a DPNS is unable to be further evaluated pursuant to the Integrated Transmission Planning Assessment, the DPNS report will be posted on the SPP website once SPP is notified by the Transmission Customer to update the applicable Network Integration Transmission Service Agreement to reflect the changes in delivery points and the Network Upgrade(s).

Pursuant to Attachment AQ of the Tariff, the Transmission provider is responsible for assessing the impacts on the Transmission System caused by modifying an existing delivery point or establishing the new delivery point through the Delivery Point Network Study (DPNS). The DPNS may determine the need for a Network Upgrade(s) necessary for the modification of an existing delivery point or the establishment of a new delivery point. A Network Upgrade(s) that the Transmission Customer or Host Transmission Owner desires that exceeds the needed Network Upgrade(s) identified in the DPNS will need to be studied through the Transmission Provider's Sponsored Upgrade study process to evaluate the impacts of the desired changes on the Transmission System.

\*\*If the project need date specified in this study cannot be met, the Transmission Owner will be required to submit mitigations pursuant to the SPP Project Tracking process. All upgrades or mitigations must be in place prior to the dates shown in Table 3-4.

\*\*\*Note that the estimated new upgrade cost provided in this report is an SPP Conceptual Cost Estimate only; this is preliminary, and a more refined Study Cost Estimate will be developed after issuance of this report through a Standardized Cost Estimate Reporting Template (SCERT).

## SECTION 4: CONCLUSION

---

The AC analysis revealed potential thermal violations associated with the Claremore load addition on SPP facilities and a third-party transmission facility. The study shows that the following SPP upgrades are required to reliably serve the load addition:

- Rebuild N.E.S. to Oologah 138 kV circuit 1
- Rebuild Oologah to Claremore 138 kV circuit 1
- Rebuild Claremore to Claremore4 138 kV circuit 1
- New 161/138 kV transformer at Claremore4

The transmission upgrades in Table 3-3 are recommended to mitigate the potential thermal violations.