



System Impact Study
SPP-2026-006

For Transmission Service
Requested By:
TEA

From CSWS.GATEWAY to ERCOTE

For a Reserved Amount Of
100 MW

From 01/28/2026
To 01/30/2026

1. Executive Summary

TEA has requested a system impact study for daily firm transmission service from CSWS.GATEWAY to ERCOTE. The period of the transaction is from 01/28/2026 00:00 to 01/30/2026 00:00. The request is for reservation 108267677.

The 100 MW transaction from CSWS.GATEWAY has an impact on the following flowgates with no AFC: PSOSWEPCOTIE, PITVALSUNHUG. To provide the AFC necessary for this transfer, the impact on the flowgates must be relieved.

After studying many scenarios using generation redispatch, there are several feasible scenarios that will relieve the flowgates in question.

2. Introduction

TEA has requested a system impact study for transmission service from CSWS.GATEWAY to ERCOTE.

Two constrained flowgates require relief for this reservation to be accepted. The flowgates and their explanations are as follows:

- PSOSWEPCOTIE: PSO – SWEPCO Tie
- PITVALSUNHUG: Pittsburg – Valiant 345 kV for the loss of Sunnyside – Hugo 345 kV

3. Study Methodology

A. Description

Southwest Power Pool used Transmission Adequacy & Reliability Assessment (TARA) to obtain possible unit pairings that would relieve the constraint. TARA calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the time period of the reservation.

B. Model Updates

The 2025 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

C. Transfer Analysis

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using Transmission Adequacy & Reliability Assessment (TARA), specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved, and the generation sensitivity factor calculated by TARA is the amount of redispatch necessary to relieve the impact on the affected flowgate.

4. Study Results

After studying the impacts of the request, two flowgates require relief. The flowgates and associated amount of relief are as follows:

Table 1

Flowgate	Duration	Sensitivity (%)	Required Relief (MW)
5578:PSOSWEPOTIE	1/28/2026 00:00 - 1/30/2026 00:00	8.95%	8.95
5661:PITVALSUNHUG	1/29/2026 00:00 - 1/30/2026 00:00	3.74%	3.74

Table 2 displays a list of generator pairs that are possible relief options for each flowgate in question and the amount of redispatch capacity needed.

Table 2

5578:PSOSWEPOTIE			
Increment	Decrement	Sensitivity	MW
WILKE2-1	SEMINL1G	77.38%	11.57
WILKE2-1	ANADRK5	77.11%	11.61
WILKE2-1	MCLN 1S	76.23%	11.74
TURKCOAL 1	SEMINL1G	74.97%	11.94
TURKCOAL 1	ANADRK5	74.70%	11.98
TURKCOAL 1	MCLN 1S	73.82%	12.12
SIKESTON	SEMINL1G	13.87%	64.52
SIKESTON	ANADRK5	13.60%	65.82
SIKESTON	MCLN 1S	12.72%	70.37

5661:PITVALSUNHUG			
Increment	Decrement	Sensitivity	MW
TURKCOAL 1	SEMINL1G	43.41%	8.61
TURKCOAL 1	MCLN 1S	42.28%	8.85
TURKCOAL 1	ANADRK5	42.17%	8.87
WILKE2-1	SEMINL1G	38.86%	9.62
WILKE2-1	MCLN 1S	37.73%	9.91
WILKE2-1	ANADRK5	37.61%	9.94
SIKESTON	SEMINL1G	14.73%	25.39
SIKESTON	MCLN 1S	13.60%	27.50
SIKESTON	ANADRK5	13.48%	27.74

Increment	Decrement	Sensitivity	MW

5. Conclusion

Generation redispatch options were studied to relieve the necessary constraints. The results of this study show that the constraints on the flowgates in question could be relieved by executing one or more of the options described in the Study Results section of this document.