



SYSTEM IMPACT STUDY

SPP-2026-058

REQUESTED BY: TNSK

INTERFACE: SPRM_SPRM TO SPA

RESERVED AMOUNT: 50 MW

TRANSACTION PERIOD: 07/01/2026 – 09/01/2026

EXECUTIVE SUMMARY

TNSK has requested a system impact study for daily firm transmission service from SPRM_SPRM to SPA. The transaction period is from 07/01/2026 00:00 to 09/01/2026 00:00. The reservation request number is 109460092.

The 50 MW transaction from SPRM_SPRM has an impact on the following flowgate with no AFC: PITVALSUNHUG. To provide the AFC necessary for this transfer, the impact on the flowgate(s) must be relieved.

After studying many scenarios using generation redispatch, there are several feasible scenarios that will relieve the flowgate(s) in question.

INTRODUCTION

TNSK has requested a system impact study for transmission service from SPRM_SPRM to SPA.

One constrained flowgate requires relief for this reservation to be accepted. The flowgate and its description are as follows:

Flowgate	Description
PITVALSUNHUG	Pittsburg - Valiant 345 kV for the loss of Sunnyside - Hugo 345 kV

STUDY METHODOLOGY

DESCRIPTION

Southwest Power Pool used Transmission Adequacy & Reliability Assessment (TARA) to obtain possible unit pairings that would relieve the constraint. TARA calculates impacts on monitored facilities for all units within the Southwest Power Pool Footprint. The SPP ATC Calculator is used to determine response factors for the reservation transaction period.

MODEL UPDATES

The 2026 Southwest Power Pool model was used for the study. This model was updated to reflect the most current information available.

TRANSFER ANALYSIS

Using the short-term calculator, the limiting constraints for the transfer are identified. The response factor of the transfer on each constraint is also determined.

The product of the transfer amount and the response factor is the impact of a transfer on a limiting flowgate that must be relieved. With multiple flowgates affected by a transfer, relief of the largest impact may also provide relief of smaller impacts.

Using Transmission Adequacy & Reliability Assessment (TARA), specific generator pairs are chosen to reflect the units available for redispatch. The quotient of the amount of impact that must be relieved, and the generation sensitivity factor calculated by TARA is the amount of redispatch necessary to relieve the impact on the affected flowgate.

STUDY RESULTS

After studying the impacts of the request, one flowgate requires relief. The flowgate and associated amount of relief are as follows:

Table 1

Flowgate	Duration	Sensitivity (%)	Required Relief (MW)
5661:PITVALSUNHUG	7/1/2026 00:00 - 9/1/2026 00:00	3.32%	1.66

Table 2 displays a list of generator pairs that are possible relief options for each flowgate in question and the amount of redispatch capacity needed.

Table 2

5746: PECAGEPEC5TR			
Increment	Decrement	Sensitivity	MW
TURKCOAL 3	SEMINL2G	44.22%	3.75
TURKCOAL 3	MCLN 1S	42.27%	3.93
TURKCOAL 3	SWS2-1	42.22%	3.93
EDE_1PLUMPT	SEMINL2G	16.93%	9.81
SIKESTON	SEMINL2G	15.49%	10.72
EDE_1PLUMPT	MCLN 1S	14.98%	11.08
EDE_1PLUMPT	SWS2-1	14.93%	11.12
SIKESTON	MCLN 1S	13.54%	12.26
SIKESTON	SWS2-1	13.49%	12.30

CONCLUSION

Generation redispatch options were studied to relieve the necessary constraints. The results of this study show that the constraints on the flowgate(s) in question could be relieved by executing one or more of the options described in the Study Results section of this document.