



SPP *Southwest Power Pool*

***System Impact Study SPP-2001-264
For Transmission Service
Requested By
Western Resources Generation
Services***

***From Western Resources to Kansas
City Power & Light***

***For a Reserved Amount Of 100MW
From 10/9/01
To 10/9/02***

SPP Transmission Planning

Table of Contents

1. EXECUTIVE SUMMARY	3
2. INTRODUCTION	4
3. STUDY METHODOLOGY	5
A. DESCRIPTION.....	5
B. MODEL UPDATES.....	5
C. TRANSFER ANALYSIS	5
4. STUDY RESULTS.....	6
A. STUDY ANALYSIS RESULTS	6
TABLE 1 – SPP FACILITY OVERLOADS CAUSED BY THE WR TO KCPL 100MW TRANSFER	7
TABLE 2 – NON - SPP FACILITY OVERLOADS CAUSED BY THE WR TO KCPL 100MW TRANSFER.....	8
TABLE 3 – PREVIOUSLY ASSIGNED AND IDENTIFIED SPP FACILITIES IMPACTED BY THE WR TO KCPL 100MW TRANSFER.	8
5. CONCLUSION	9
APPENDIX A	10

1. Executive Summary

Western Resources Generation Services has requested a system impact study for long-term Firm Point-to-Point transmission service from Western Resources to Kansas City Power & Light. The period of the transaction is from 10/9/01 to 10/9/02. The request is for OASIS reservations 289040 and 289041 for a total of 100MW.

The principal objective of this study is to identify system problems and potential system modifications necessary to facilitate the additional 100MW transfer while maintaining system reliability.

New overloads caused by the 100MW transfer were identified along with determining the impact of the transfer on any previously assigned and identified facilities.

The WR to KCPL transfer impacts several facilities that have been identified as limiting constraints for previously studied transfers. Due to the inability to upgrade these limiting constraints within the reservation period using normal construction practices, the ATC is zero for the requested WR to KCPL 100MW transfer.

2. Introduction

Western Resources Generation Services has requested an impact study for transmission service from WR to KCPL.

The principal objective of this study is to identify the restraints on the SPP Regional Tariff System that may limit the transfer to less than 100MW. This study includes steady-state contingency analyses (PSS/E function ACCC) and Available Transfer Capability (ATC) analyses.

The steady-state analyses consider the impact of the 100MW transfer on transmission line loading and transmission bus voltages for outages of single and selected multiple transmission lines and transformers on the SPP system.

ATC analyses shows the amount of First Contingency Incremental Transfer Capabilities (FCITC) between the given study systems and what the limitations are, if any, for transferring up to 100MW.

3. Study Methodology

A. Description

Two analyses were conducted to determine the impact of the 100MW transfer on the system. The first analysis was conducted to identify any new overloads caused by the 100MW transfer. The second analysis was done to ensure that available capacity exists on previously identified circuits.

The first analysis was to study the steady-state analysis impact of the 100MW transfer on the SPP system. The second step was to study Available Transfer Capability (ATC) of the facilities identified in the steady-state analysis impact. The steady-state analysis was done to ensure current SPP Criteria and NERC Planning Standards requirements are fulfilled. The Southwest Power Pool (SPP) conforms to the NERC Planning Standards, which provide the strictest requirements, related to thermal overloads with a contingency. It requires that all facilities be within emergency ratings after a contingency.

The second analysis was done to determine the impact of the transfer on previously assigned and identified facilities.

B. Model Updates

SPP used four seasonal models to study the 100MW request. The SPP 2001 Series Cases 2001 Fall, 2001/02 Winter Peak, 2002 Spring, and 2002 Summer Peak were used to study the impact of the 100MW transfer on the SPP system during the transaction period of 10/9/01 to 10/9/02.

The chosen base case models were modified to reflect the most current modeling information. The cases were modified to reflect future firm transfers during the request period that were not already included in the January 2001 base case series models.

C. Transfer Analysis

Using the created models and the ACCC function of PSS/E, single and select double contingency outages were analyzed. Then full AC solution was used to obtain the most accurate results possible. Any facility overloaded, using MVA ratings, in the transfer case and not overloaded in the base case was flagged. The PSS/E options chosen to conduct the Impact Study analysis can be found in Appendix A.

4. Study Results

A. Study Analysis Results

Tables 1, 2, and 3 contain the analysis results of the System Impact Study. The tables identify the seasonal case in which the event occurred; the emergency rating of the overloaded circuit (Rate B), the contingent loading percentage of circuit with and without the studied transfer, the estimated ATC value using interpolation if calculated, any SPP identification or assignment of the event, and any solutions received from the transmission owners.

Table 1 shows the new facility overloads caused by the 100MW transfer. Upgrades associated with these new overloads can be directly assigned to the WR to KCPL 100MW transfer.

Table 2 documents overloads on Non SPP Regional Tariff participants' transmission systems caused by the 100MW transfer.

Table 3 documents the 100MW transfer impact on previously assigned and identified facilities. Available estimated in-service dates for the completion of the previously assigned upgrades are given in the table.

Table 1 – SPP Facility Overloads caused by the WR to KCPL 100MW Transfer

Study Year	From Area - To Area	Branch Over 100% Rate B	Rate B	BC % Loading	TC % Loading	Outaged Branch Causing Overload	ATC (MW)
01FA	WERE-WERE	PENTAGON 161/115KV TR 56916 PENTAGN5 161 to 57261 PENTAGN3 115 CKT 1	55	98.6	101.2	PENTAGON TAP TO GREENWOOD, 161KV 56917 PENTGNT5 161 to 58031 GRNWOOD5 161 CKT1	53
02SP	WERE-WERE	HOYT HTI SWITCHING JUNCTION TO CIRCLEVILLE, 115KV 57165 HTI JCT3 115 to 57152 CIRCLVL3 115 CKT 1	92	100.0	100.9	MIDLAND 161/115KV TR 56915 MIDLAND5 161 to 57252 MIDLAND3 115 CKT1	0
02SP	WERE-WERE	HALSTEAD TO MUD CREEK JUNCTION, 69KV 57736 HALSTED269.0 to 57744 MUDCRKJ269.0 CKT 1	59	100.0	100.5	HALSTEAD NORHT TO MOUNDRIDGE, 138KV 57011 HALSTDN4 138 to 57013 MOUND 4 138 CKT1	0
02SP	WERE-WERE	HOYT TO HOYT HTI SWITCHING JUNCTION, 115KV 57163 HOYT 3 115 to 57165 HTI JCT3 115 CKT 1	92	99.9	100.6	STILWELL TO PLEASANT HILL, 345KV 57968 STILWEL7 345 to 59200 PHILL 7 345 CKT1	18
02SP	WERE-WERE	GILL ENERGY CENTER EAST TO OATVILLE, 69KV 57795 GILL E 269.0 to 57825 OATVILL269.0 CKT 1	72	98.6	104.9	GILL ENERGY CENTER EAST TO HAYSVILLE JUNCTION, 69KV 57795 GILL E 269.0 to 57804 HAYSVLJ269.0 CKT1	23
02SP	WERE-WERE	GILL ENERGY CENTER EAST TO MACARTHUR, 69KV 57795 GILL E 269.0 to 57813 MACARTH269.0 CKT 1	68	97.8	103.6	GILL ENERGY CENTER EAST TO OATVILLE, 69KV 57795 GILL E 269.0 to 57825 OATVILL269.0 CKT1	38
02SP	WERE-WERE	HYDRAULIC NORTH TO MACARTHUR, 69KV 57807 HYDRA N269.0 to 57813 MACARTH269.0 CKT 1	63	97.4	100.6	CANAL TO RUTAN, 69KV 57784 CANAL 269.0 to 57838 RUTAN 269.0 CKT1	82

Table 2 – Non - SPP Facility Overloads caused by the WR to KCPL 100MW Transfer

Study Year	From Area - To Area	Branch Over 100% Rate B	Rate B	BC % Loading	TC % Loading	Outaged Branch Causing Overload	ATC (MW)
01FA		NONE				NONE	100
01WP		NONE				NONE	100
02G		NONE				NONE	100
02SP		NONE				NONE	100

Table 3 – Previously Assigned and Identified SPP Facilities Impacted by the WR to KCPL 100MW Transfer.

Study Year	From Area - To Area	Branch Over 100% Rate B	Rate B	BC % Loading	TC % Loading	Outaged Branch Causing Overload	ATC (MW)	Assignment
01WP	AEPW-AEPW	EAST ROGERS TO DYESS, 161KV 53135 EROGERS5 161 to 53131 DYESS 5 161 CKT 1	245	103.5	103.7	EAST CENTERTON TO GENTRY REC, 161KV 53133 ECNTRTN5 161 to 53187 GENTRYR5 161 CKT1	0	Upgrade Assigned to SPP-2000-004 163951 Est. In-Service Date 6/1/2002
02SP	SWPA-SWPA	ROBERT S. KERR TO VAN BUREN 52782 RS KERR5 161 to 52722 VAN BUR5 161 CKT 1	167	101.0	101.2	BONANZA TAP TO AES, 161KV 55261 BONANZT5 161 to 55262 AES 5 161 CKT1	0	Previously Identified
02SP	KACP-KACP	STILLWELL TO LA CYGNE, 345KV 57968 STILWEL7 345 to 57981 LACYGNE7 345 CKT 1	1251	100.0	102.2	WEST GARDNER TO LA CYGNE, 345KV 57965 W.GRDNR7 345 to 57981 LACYGNE7 345 CKT1	0	SPP Flowgate
02SP	AEPW-AEPW	EAST CENTERTON TO GENTRY REC, 161KV 53133 ECNTRTN5 161 to 53187 GENTRYR5 161 CKT 1	335	100.9	101.1	DYESS TO EAST ROGERS, 161KV 53131 DYESS 5 161 to 53135 EROGERS5 161 CKT1	100	Upgrade Assigned to SPP-2000-086 150680 Est. In-Service Date 4/1/2002

5. Conclusion

The previously assigned and identified facilities limit the ATC to zero due to the inability to upgrade the constraints as required. Those facilities that have an ATC of zero are given below.

- For the 2001/2002 Winter (12/1/01 – 4/1/02), the ATC is zero due to the loading of the East Rogers to Dyess 161kV line.
- For the 2002 Summer (6/1/02 – 10/1/02), the ATC is zero due the loading of the R.S. Kerr to Van Buren 161kV line and the La Cygne to Stillwell 345kV line.

Due to the inability to upgrade these facilities in the time period allowed, the ATC of the existing transmission system cannot be increased as required to provide continuous service over the reservation period. Therefore, the requested reservations will be refused.

Appendix A

PSS/E CHOICES IN RUNNING LOAD FLOW PROGRAM AND ACCC

BASE CASES:

Solutions - Fixed slope decoupled Newton-Raphson solution (FDNS)

1. Tap adjustment – Stepping
2. Area interchange control – Tie lines only
3. Var limits – Apply automatically
4. Solution options - Phase shift adjustment
 - _ Flat start
 - _ Lock DC taps
 - _ Lock switched shunts

ACCC CASES:

Solutions – AC contingency checking (ACCC)

1. MW mismatch tolerance –0.5
2. Contingency case rating – Rate B
3. Percent of rating – 100
4. Output code – Summary
5. Min flow change in overload report – 1mw
6. Excl'd cases w/ no overloads form report – YES
7. Exclude interfaces from report – NO
8. Perform voltage limit check – YES
9. Elements in available capacity table – 60000
10. Cutoff threshold for available capacity table – 99999.0
11. Min. contng. case Vltg chng for report – 0.02
12. Sorted output – None

Newton Solution:

1. Tap adjustment – Stepping
2. Area interchange control – Tie lines only
3. Var limits - Apply automatically
4. Solution options - Phase shift adjustment
 - _ Flat start
 - _ Lock DC taps
 - _ Lock switched shunts